

ภาคผนวก จ26

Preventive Maintenance Plan

INSPECTION AND PREVENTIVE MAINTENANCE PLAN 2018 FOR LABIX.

รายการ CHECK ประจำปี	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Remark
1. FIRE WATER LINE (FLUSHING DEAD END)													Every 3 month
2. BREATHING APPARATUS (SCBA)													Every 3 month
3. PORTABLE EXTINGUISHERS													Every 6 month
4. FIRE HOSE BOX / FIRE POINT													Every 6 month
5. FIRE HYDRANT													Every 6 month
6. FIXED MOUNTOR													Every 6 month
7. DRY RISER LINE													Every 6 month
8. FIRE PROTECTION FOR TANK													Every 12 month

Note: Item 2, 3, 4, 5 inspection every month and PM. as schedule.

ผู้จัดทำ *Thana Makhay*
 ผู้อนุมัติ *[Signature]*