



Analysis / Test Report

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O : 005-4304217105

Project Name : Water Testing : BPK

Project Location :

TESTING

No.0009

Lot ID: 21106996

Date Received : Oct 06, 2021

Date Reported : Oct 12, 2021

Report Number : 2089219-1

Page 1 of 1

Sample Number	21106996-1
Sampled Date	Oct 05, 2021 11:37 AM
Sample Description	น้ำเสียก่อนเข้าระบบบำบัด (น้ำรวม)
Location	บ่อบำบัดน้ำเสียรวม
Date Analysis Commenced	Oct 07, 2021
Condition of Sample	Contained in one amber glass bottle and four plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Water Testing							
BOD (5 days at 20 degree C) *	mg/L	-	2	78	≤20	Based on APHA (2017), 5210 B	Bangkok
COD	mg/L	1.5	5	201	No Standard	Based on APHA (2017), 5220 D	Bangkok
Oil & Grease	mg/L	-	3	8	≤20	Based on APHA (2017), 5520 B	Bangkok
pH at 25 degree C		-	-	7.6	5.0-9.0	Based on APHA (2017), 4500-H (B)	Bangkok
Settleable Solid *	mL/L/hr	-	0.1	<0.1	≤0.5	Based on APHA (2017), 2540 F	Bangkok
Sulfide *	mg/L	-	0.5	1.8	≤1	Based on APHA (2017), 4500-S2(C), (F)	Bangkok
Total Dissolved solids Dried at 180 degree C	mg/L	-	5	524	No Standard	Based on APHA (2017), 2540 C	Bangkok
Total Kjeldahl Nitrogen as N *	mg/L	0.15	1.0	53.2	≤35	Based on APHA (2017), 4500-Norg (C)	Bangkok
Total Suspended Solids Dried at 103-105 degree C	mg/L	-	5	27	≤30	Based on APHA (2017), 2540 D	Bangkok

Guideline : Notification of Ministry of Natural Resources and Environment November, 7, B.E. 2548 on Effluent Control Standard from Types and Sized of Buildings, Type A.

(1) : The values are in addition to the Total Dissolved Solids of the water used not more than 500 mg/L.

Sampled By : Yuttapong Rattana

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.

Approved by

Siriluk P.

Siriluk Puengpang
Supervisor

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.