



Analysis / Test Report

TESTING
No.0009

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O :

Project Name : Water Testing : BPK

Project Location :

Lot ID: 2190351

Date Received : Jul 31, 2021

Date Reported : Aug 04, 2021

Report Number : 2062652-1

Page 1 of 1

Sample Number	2190351-1
Sampled Date	Jul 30, 2021 11:00 AM
Sample Description	น้ำทิ้งหลังออกจากระบบ (น้ำรวม)
Location	บ่อบำบัดน้ำเสียรวม
Date Analysis Commenced	Aug 03, 2021
Condition of Sample	Contained in one plastic bottle, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Water Testing							
Total Dissolved solids Dried at 180 degree C	mg/L	-	5	596	No Standard	Based on APHA (2017), 2540 C	Bangkok
Total Suspended Solids Dried at 103-105 degree C	mg/L	-	5	14	≤30	Based on APHA (2017), 2540 D	Bangkok

Guideline : Notification of Ministry of Natural Resources and Environment November, 7, B.E. 2548 on Effluent Control Standard from Types and Sized of Buildings, Type A.

(1) : The values are in addition to the Total Dissolved Solids of the water used not more than 500 mg/L.

Sampled By : Yuttapong Rattana

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Siriluk P.

Siriluk Puenggang
Supervisor