



Analysis / Test Report

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O : 005-4304217105

Project Name : Water Testing : BPK

Project Location :

Lot ID: 21102404

Date Received : Sep 08, 2021

Date Reported : Sep 24, 2021

Report Number : 2080571-1

Page 1 of 1

Sample Number	21102404-1
Sampled Date	Sep 07, 2021 10:28 AM
Sample Description	น้ำในถาด Cooling Tower
Location	Cooling Tower
Date Analysis Commenced	Sep 08, 2021
Condition of Sample	Contained in two plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Microbiological Testing							
<i>Legionella spp.</i>	CFU/L	-	-	Not Detected**	Not Detected	ISO 11731 (2017)	Bangkok

Guideline : Notification of Department of Health about Legionella Control in Cooling Tower.

Note : ** Not Detected mean Bacteria not found in agar plate.

Sampled By : Yuttapong Rattana

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Tuanjai Thangklang
Assistant Manager