



Analysis / Test Report

TESTING
No.0009

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000
P/O : 005-4304217105
Project Name : Water Testing : BPK
Project Location :

Lot ID: 2184429
Date Received : Aug 04, 2021
Date Reported : Aug 10, 2021
Report Number : 2046267-1

Page 1 of 1

Sample Number 2184429-1
Sampled Date Aug 03, 2021 11:40 AM
Sample Description น้ำเสียก่อนเข้าระบบบำบัด (น้ำรวม)
Location น้ำเสียก่อนเข้าระบบบำบัด (น้ำรวม)
Date Analysis Commenced Aug 05, 2021
Condition of Sample Contained in three plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Water Testing							
BOD (5 days at 20 degree C)	mg/L	-	2	85	≤20	Based on APHA (2017), 5210 B	Bangkok
COD	mg/L	1.5	5	180	No Standard	Based on APHA (2017), 5520 C	Bangkok
Total Dissolved solids Dried at 180 degree C	mg/L	-	5	524	No Standard	Based on APHA (2017), 2540 C	Bangkok
Total Kjeldahl Nitrogen as N *	mg/L	0.15	1.0	52.1	≤35	Based on APHA (2017), 4500-Norg (C)	Bangkok
Total Suspended Solids Dried at 103-105 degree C	mg/L	-	5	20	≤30	Based on APHA (2017), 2540 D	Bangkok

Guideline : Notification of Ministry of Natural Resources and Environment November, 7, B.E. 2548 on Effluent Control Standard from Types and Sized of Buildings, Type A.

(1) : The values are in addition to the Total Dissolved Solids of the water used not more than 500 mg/L.

Note : สารที่ละลายได้ทั้งหมดในน้ำใช้ = 178 มิลลิกรัมต่อลิตร (ALS Lot 2184416-1)

Sampled By : Yuttapong Rattana

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Siriluk P.

Siriluk Puengpang
Supervisor