



Analysis / Test Report

TESTING
No.0166

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O : 005 - 4304217106

Project Name : Water Testing : BPK

Project Location :

Lot ID: 21127311

Date Received : Dec 08, 2021

Date Reported : Dec 14, 2021

Report Number : 2149987-1

Page 1 of 1

Sample Number	21127311-1
Sampled Date	Dec 07, 2021 11:00 AM
Sample Description	น้ำทิ้งหลังออกจากกระบ (น้ำรวม)
Location	บ่อบำบัดน้ำเสียรวม
Date Analysis Commenced	Dec 08, 2021
Condition of Sample	Contained in four plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Microbiological Testing							
Fecal Coliform	MPN/100mL	-	-	<1.8	No Standard	APHA (2017), 9221 E	Songkhla
Total Coliform	MPN/100mL	-	-	<1.8	No Standard	APHA (2017), 9221 B	Songkhla
Water Testing							
BOD *	mg/L	-	2	<2	≤20	Based on APHA (2017), 5210 (B), 4500-O (C)	Songkhla
COD	mg/L	-	5	79	No Standard	Based on APHA (2017), 5220 D	Songkhla
Residual Free Chlorine	mg/L	-	0.1	0.5	No Standard	APHA (2017), 4500-Cl (F)	Songkhla
Total Dissolved solids Dried at 180 degree C	mg/L	-	5	596	No Standard	APHA (2017), 2540 C	Songkhla
Total Kjeldahl Nitrogen as N *	mg/L	0.15	1.0	6.2	≤35	Based on APHA (2017), 4500-Norg (C)	Bangkok (C)
Total Suspended Solids	mg/L	-	5	5	≤30	APHA (2017), 2540 D	Songkhla

Guideline : Notification of Ministry of Natural Resources and Environment November, 7, B.E. 2548 on Effluent Control Standard from Types and Sized of Buildings, Type A.

(1) : The values are in addition to the Total Dissolved Solids of the water used not more than 500 mg/L.

Sampled By : Yuttapong Rattana , Thaksin Aintrom

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.

Approved by

Sutthirak T.

Sutthirak Tiprat
Scientist (2)

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068
ALS LABORATORY GROUP (THAILAND) CO., LTD. Part of the ALS Group

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER