



Accreditation No. 1031/47

## Analysis / Test Report

**Client** : Bangkok Phuket Hospital Co., Ltd.  
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000  
**P/O** : 005-4304217105  
**Project Name** : Water Testing : BPK  
**Project Location** :

**Lot ID: 2184441**

Date Received : Aug 04, 2021

Date Reported : Aug 20, 2021

Report Number : 2046316-1

Page 1 of 1

**Sample Number** 2184441-1  
**Sampled Date** Aug 03, 2021 9:25 AM  
**Sample Description** บ่อเก็บน้ำใต้ดิน  
**Location** บ่อเก็บน้ำห้อง Fire pump  
**Date Analysis Commenced** Aug 04, 2021  
**Condition of Sample** Contained in two plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Method	Testing Location
<b>Microbiological Testing</b>						
<i>Legionella spp.</i>	CFU/L	-	-	<1	ISO 11731 (2017)	Bangkok

**Note** : Microbiological Testing Result <1 mean Bacteria not found in agar plate.

**Sampled By** : Yuttapong Rattana

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked \* is/are not included in scope of Accreditation ISO/IEC 17025.

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Tuanjai Thangklang  
Assistant Manager