



Analysis / Test Report

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O : 005-4304851039

Project Name : Water Testing : BPK

Project Location :

Lot ID: 21143304

Date Received : Feb 02, 2022

Date Reported : Feb 19, 2022

Report Number : 2168242-2

Page 1 of 1

Sample Number 21143304-1
Sampled Date Feb 01, 2022 11:45 AM
Sample Description น้ำดื่มขวดเขียวในระบบ Cooling Tower
Location Cooling Tower
Date Analysis Commenced Feb 02, 2022
Condition of Sample Contained in five plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Microbiological Testing							
<i>Legionella spp.</i>	CFU/L	-	-	Not Detected**	Not Detected	ISO 11731 (2017)	Bangkok

Guideline : Notification of Department of Health about Legionella Control in Cooling Tower.

Note : ** Not Detected mean Bacteria not found in agar plate.

Sampled By : Thaksin Aintrom

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)

Approved by

Sithichok T.

Sithichok Thongnguen
Scientist (3)

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.