



Accreditation No. 1031/47

Analysis / Test Report

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O :

Project Name : Water Testing : BPK

Project Location :

Lot ID: 21139674

Date Received : Jan 05, 2022

Date Reported : Jan 21, 2022

Report Number : 2159565-1

Page 1 of 1

Sample Number	21139674-1
Sampled Date	Jan 04, 2022 10:20 AM
Sample Description	น้ำพุ ธ.ทหารไทย
Location	บ่อเก็บน้ำใต้ตึก
Date Analysis Commenced	Jan 05, 2022
Condition of Sample	Contained in two plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Method	Testing Location
Microbiological Testing						
<i>Legionella spp.</i>	CFU/L	-	-	<1	ISO 11731 (2017)	Bangkok

Note : Microbiological Testing Result <1 mean Bacteria not found in agar plate.

Sampled By : Yuttapong Rattana

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Tuanjai Thangklang
Assistant Manager

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER