



## Analysis / Test Report

**Client :** Bangkok Phuket Hospital Co., Ltd.  
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

**P/O :** 005-4304851039

**Project Name :** Water Testing : BPK

**Project Location :**

**Lot ID: 21143307**

Date Received : Feb 02, 2022

Date Reported : Feb 19, 2022

Report Number : 2168244-1

Page 1 of 1

**Sample Number** 21143307-1  
**Sampled Date** Feb 01, 2022 11:50 AM  
**Sample Description** น้ำในถาด Cooling Tower  
**Location** Cooling Tower  
**Date Analysis Commenced** Feb 02, 2022  
**Condition of Sample** Contained in two plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
<b>Microbiological Testing</b>							
<i>Legionella spp.</i>	CFU/L	-	-	Not Detected**	Not Detected	ISO 11731 (2017)	Bangkok

**Guideline :** Notification of Department of Health about Legionella Control in Cooling Tower.

**Note :** \*\* Not Detected mean Bacteria not found in agar plate.

**Sampled By :** Thaksin Aintrom

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)

Approved by

Sithichok T.

Sithichok Thongnguen  
Scientist (3)

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.