



Analysis / Test Report

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000
P/O : 005-4305045534
Project Name : Water Testing : BPK
Project Location :

Lot ID: 2252631

Date Received : May 04, 2022

Date Reported : May 21, 2022

Report Number : 2320513-1

Page 1 of 1

Sample Number 2252631-2
Sampled Date May 03, 2022 11:47 AM
Sample Description น้ำในถาด Cooling tower
Location น้ำในถาด Cooling tower
Date Analysis Commenced May 04, 2022
Condition of Sample Contained in two plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Microbiological Testing							
<i>Legionella spp.</i>	CFU/L	-	-	Not Detected**	Not Detected (1)	ISO 11731 (2017)	Bangkok

Guideline : หนังสือการปรังแต่งคุณภาพน้ำ มาตรฐานน้ำใน Cooling Tower ดร.มันสัน ตัณฑกุลเวศน์
(1) ประกาศกรมอนามัย พ.ศ. 2544 เรื่องข้อปฏิบัติการควบคุมเชื้อลิจิโอนลลา ในหอฝ้งเย็นของอาคารในประเทศไทย

Note : ** Not Detected mean Bacteria not found in agar plate.

Sampled By : Yuttapong Rattana , Thaksin Aintrom

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Sithichok T.

Sithichok Thongnguen
Scientist (3)