



Analysis / Test Report

TESTING
No.0166

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000
P/O : 005-4305119734
Project Name : Water Testing : BPK
Project Location :

Lot ID: 2267887
Date Received : Jun 08, 2022
Date Reported : Jun 24, 2022
Report Number : 2346191-1

Page 1 of 1

Sample Number 2267887-2
Sampled Date Jun 07, 2022 10:30 AM
Sample Description น้ำประปาปลายทาง (น้ำประปา GI)
Location อ่างน้ำผนง GI
Date Analysis Commenced Jun 08, 2022
Condition of Sample Contained in four plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Metals Testing							
Iron	mg/L	0.001	0.005	<0.005	≤0.3	Based on APHA (2017), 3125	Songkhla
Manganese	mg/L	0.001	0.005	0.006	≤0.3	Based on APHA (2017), 3125	Songkhla
Microbiological Testing							
<i>Escherichia coli</i>	MPN/100mL	-	-	<1.1	<1.1	APHA (2017), 9221 F	Songkhla
Total Coliform	MPN/100mL	-	-	<1.1	<1.1	APHA (2017), 9221 B	Songkhla
Water Testing							
^[A] Chloride as Cl	mg/L	0.06	0.2	27.7	≤250	APHA (2017), 4110 B	Bangkok
Color (Apparent) *	Color unit	-	5	<5	≤15	APHA (2017), 2120 B	Songkhla
^[A] Nitrate as NO ₃	mg/L	0.3	1.0	35.4	≤50	APHA (2017), 4110 B	Bangkok
pH at 25 degree C		-	-	7.3	6.5-8.5	Based on APHA (2017), 4500-H (B)	Songkhla
Residual Free Chlorine	mg/L	-	0.1	0.4	No Standard	APHA (2017), 4500-Cl (F)	Songkhla
^[A] Sulfate	mg/L	0.15	0.5	8.5	≤250	APHA (2017), 4110 B	Bangkok
Total Dissolved solids Dried at 180 degree C	mg/L	-	5	180	≤500	APHA (2017), 2540 C	Songkhla
Total Hardness as CaCO ₃	mg/L	-	1	56	≤300	APHA (2017), 2340 C	Songkhla
Turbidity	NTU	-	0.1	0.33	≤5	APHA (2017), 2130 B	Songkhla

Guideline : เกณฑ์คุณภาพน้ำประปาดื่มได้ ประกาศ กรมอนามัย พ.ศ. 2563

Sampled By : Yuttapong Rattana , Thaksin Aintrom

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- [A] Analysis conducted by ALS Laboratory Group (Thailand) Co.,Ltd. Bangkok Branch, DMS Accreditation No. 1031/47.
- The laboratory has been accepted as an accredited laboratory complying with the ISO/IEC 17025.

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Sutthirak T.

Sutthirak Tiprat
Scientist (2)

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER