

ภาคผนวก ข1

เอกสารการตรวจสอบระบบบำบัดแบบตะกอนเร่ง
(Activated Sludge)

ภาคผนวก ข

เอกสารประกอบการปฏิบัติตามมาตรการด้านสิ่งแวดล้อม

ภาคผนวก ข

เอกสารประกอบการปฏิบัติตามมาตรการด้านสิ่งแวดล้อม

- ข1 เอกสารการตรวจสอบระบบบำบัดแบบตะกอนเร่ง (Activated Sludge)
- ข2 เอกสารการดูแลรักษาและควบคุมระบบบำบัดน้ำเสีย
- ข3 เอกสารการสูบน้ำตะกอนส่วนเกินจากระบบบำบัดน้ำเสีย
- ข4 เอกสารการประสานงานร้านซื้อของเก่าใกล้เคียงให้เข้ามารับซื้อมูลฝอย
- ข5 เอกสารระบบป้องกันและเตือนอัคคีภัย
- ข6 เอกสารการตรวจสอบระบบป้องกันและเตือนอัคคีภัย
- ข7 เอกสารการจัดอบรมและซ้อมการอพยพคนกรณีเพลิงไหม้
- ข8 เอกสารการปฏิบัติตามข้อกำหนดในประกาศกรมอนามัย
ข้อปฏิบัติการควบคุมเชื้อลิจิโอเนลลาในหอผึ่งเย็นของอาคาร
- ข9 เอกสารการตรวจสอบอุปกรณ์ที่ใช้ระบายอากาศ
- ข10 เอกสารการรณรงค์ให้ผู้มาใช้บริการใช้บริการรถไฟฟ้าขนส่งมวลชน
- ข11 เอกสารการปฏิบัติตาม พ.ร.บ. การส่งเสริมการอนุรักษ์พลังงาน พ.ศ.2535
- ข12 เอกสารประชาสัมพันธ์วิธีการประหยัดพลังงาน

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 1

MONTH 1/65
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY [REDACTED] RECHECK BY นายพรชัย กรุดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 2

MONTH 1/65
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System						
	2	Cleanning Overall Inside Panel Control						
	3	Fitting All Inside Panel Control						
	4	Testing Overload						
	5	Testing Timer Operation						
	6	Check Sludge Level In The Tank						
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY [REDACTED] นายพรชัย กระจุกทอง
RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 1

MONTH 2/65
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY .. 

RECHECK BY **นายพรชัย กรุดทอง**
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 2

MONTH 2/65.....
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY 

RECHECK BY นายพรชัย อรุณทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 1

MONTH 3/65
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/	/				
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun, Sep, Dec	7	Cleanning & Check Shake Valve	/					
	8	Check Guide Well					/	
	9	Check Piping And Valve					/	

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY 

RECHECK BY นายพรชัย กรุดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 2

MONTH 3/65
TIME


TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System						
	2	Cleanning Overall Inside Panel Control						
	3	Fitting All Inside Panel Control						
	4	Testing Overload						
	5	Testing Timer Operation						
	6	Check Sludge Level In The Tank						
3 Month	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

COMMENT

RECORD BY



RECHECK BY

นายพรชัย คุรุทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 1

MONTH 4/65
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ..



นายพรชัย กรุดทอง
CHIEF ENGINEER
RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 2

MONTH 4/65
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY



RECHECK BY นายพรชัย กรุดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 1

MONTH 5/65
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun, Sep, Dec	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE


.....

.....

COMMENT

.....

.....

RECORD BY 

RECHECK BY นายพรชัย กรุดทอง **CHIEF ENGINEER**

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 2

MONTH 5/65.....
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE


.....

.....

COMMENT

.....

.....

RECORD BY 

RECHECK BY นายพรชัย กรุดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT


SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 1

MONTH 6/65
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/	/				
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month	7	Cleanning & Check Shake Valve					/	
	8	Check Guide Well					/	
Mar,Jun,Sep,Dec	9	Check Piping And Valve					/	

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE
.....
.....
.....
.....
COMMENT
.....
.....
.....

RECORD BY  นายพรชัย กรุดทอง
RECHECK BY **CHIEF ENGINEER**

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT
EFFLUENT PUMP 2


MONTH 6/65
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System						
	2	Cleanning Overall Inside Panel Control						
	3	Fitting All Inside Panel Control						
	4	Testing Overload						
	5	Testing Timer Operation						
	6	Check Sludge Level In The Tank						
3 Month	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

COMMENT

RECORD BY  นายพรชัย คุรุคทอง
RECHECK BY **CHIEF ENGINEER**

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 1/65

EJECTOR PUMP NO ...1.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

COMMENT

RECORD BY

RECHECK BY นายพรชัย กรุดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 1/65

EJECTOR PUMP NO ...2.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ... RECHECK BY ... นายพรชัย กรุดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 1/65

EJECTOR PUMP NO ...3.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

COMMENT

RECORD BY [REDACTED]

RECHECK BY นายพรชัย ทรุดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 1 / 65

EJECTOR PUMP NO ...4.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System						
	2	Cleanning Overall Inside Panel Control						
	3	Fitting All Inside Panel Control						
	4	Testing Overload						
	5	Testing Timer Operate						
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

RECHECK BY นายพรชัย กรุดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 1/65

EJECTOR PUMP NO ...5.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System						
	2	Cleanning Overall Inside Panel Control						
	3	Fitting All Inside Panel Control						
	4	Testing Overload						
	5	Testing Timer Operate						
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE


.....

.....

COMMENT

.....

.....

RECORD BY นายพรชัย กรุดทอง
RECHECK BY ...CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH ...1/65.....

EJECTOR PUMP NO ...6.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System						
	2	Cleanning Overall Inside Panel Control						
	3	Fitting All Inside Panel Control						
	4	Testing Overload						
	5	Testing Timer Operate						
3 Month Mar,Jun,Sept,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

COMMENT

RECORD BY [REDACTED]

RECHECK BYนายพรชัย กรุดทอง
CHIEF ENGINEER

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 11/65

EJECTOR PUMP NO ...7.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING


A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

COMMENT

RECORD BY 

.....นายพรชัย กระจุกทอง
RECHECK BYCHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 1/65

EJECTOR PUMP NO ...8.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System						
	2	Cleanning Overall Inside Panel Control						
	3	Fitting All Inside Panel Control						
	4	Testing Overload						
	5	Testing Timer Operate						
3 Month	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

COMMENT

RECORD BY

นายพรชัย กรุดทอง
RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 2/65.....

EJECTOR PUMP NO ...1.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/	/				
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY


 นายพรชัย กรุดทอง
 RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 2/65

EJECTOR PUMP NO ...2.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System						
	2	Cleanning Overall Inside Panel Control						
	3	Fitting All Inside Panel Control						
	4	Testing Overload						
	5	Testing Timer Operate						
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES

R = REPAIR P = REPLACED

NOTE

COMMENT

RECORD BY

นายพรชัย กรุดทอง
CHIEF ENGINEER
RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 2/63

EJECTOR PUMP NO ...3.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

COMMENT

RECORD BY ..



RECHECK BY นายพรชัย กรุดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 2/65

EJECTOR PUMP NO ...4.....

TIME


TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System						
	2	Cleanning Overall Inside Panel Control						
	3	Fitting All Inside Panel Control						
	4	Testing Overload						
	5	Testing Timer Operate						
3 Month <small>Mar,Jun,Sep,Dec</small>	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES

R = REPAIR P = REPLACED

NOTE

COMMENT

RECORD BY 

RECHECK BY นายพรชัย ฤวดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 2/65

EJECTOR PUMP NO ...5.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System						
	2	Cleanning Overall Inside Panel Control						
	3	Fitting All Inside Panel Control						
	4	Testing Overload						
	5	Testing Timer Operate						
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES
R = REPAIR P = REPLACED

NOTE

COMMENT

RECORD BY [REDACTED] นายพรชัย กรุดทอง
RECHECK BYCHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 9/65

EJECTOR PUMP NO ...6.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES

R = REPAIR P = REPLACED

NOTE

COMMENT

RECORD BY

นายพรชัย กรุดทอง
RECHECK BYCHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 2/65

EJECTOR PUMP NO ...7.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES

R = REPAIR P = REPLACED

NOTE

COMMENT

RECORD BY

นายพรชัย กรุดทอง
RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH ...2/65.....

EJECTOR PUMP NO ...8.....

TIME


TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES

R = REPAIR P = REPLACED

NOTE

COMMENT

RECORD BY ...  นายพรชัย กรุดทอง
RECHECK BYCHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 3/65

EJECTOR PUMP NO ...1.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain					/	
	8	Check Piping And Valves					/	

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES
R = REPAIR P = REPLACED

NOTE

COMMENT

RECORD BY ..

นายพรชัย กล้วยทอง
RECHECK BY **CHIEF ENGINEER**

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 3/65

EJECTOR PUMP NO ...2.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/	/				
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sept,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain					/	
	8	Check Piping And Valves					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ..

 นายพรชัย กฤตทอง
 CHIEF ENGINEER

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 3/65

EJECTOR PUMP NO ...3.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain					/	
	8	Check Piping And Valves					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

COMMENT

.....

.....

RECORD BY ..


 นายพรชัย อรุณทอง
 RECHECK BY CHIEF ENGINEER

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 3/65

EJECTOR PUMP NO ...4.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain					/	
	8	Check Piping And Valves					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY ...

RECHECK BY

นายพรชัย กรุดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 3/65

EJECTOR PUMP NO ...5.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System		/			/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun, Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain					/	
	8	Check Piping And Valves					/	

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES

R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

..... นายพรชัย..กรุดทอง

RECORD BY ...

RECHECK BY **CHIEF ENGINEER**

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 3/65

EJECTOR PUMP NO ...6.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain					/	
	8	Check Piping And Valves					/	

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES

R = REPAIR P = REPLACED

NOTE

COMMENT

RECORD BY


 นายพรชัย กรุดทอง
 RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 3/65

EJECTOR PUMP NO ...7.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/	/				
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain					/	
	8	Check Piping And Valves					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY ..


 นายพรชัย กระจุกทอง
 RECHECK BY ..CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 3/65.....

EJECTOR PUMP NO ...8.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sept,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain					/	
	8	Check Piping And Valves					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....


.....

COMMENT

.....

.....

RECORD BY


 นายพรชัย กรุดทอง
 RECHECK BY **CHIEF ENGINEER**

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 4/65

EJECTOR PUMP NO ...1.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

COMMENT

RECORD BY [REDACTED]

RECHECK BY นายพรชัย กรุดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 4/65

EJECTOR PUMP NO ...2.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

COMMENT

RECORD BY ...

นายพรชัย ฤทธิ์ทอง
RECHECK BYCHIEF ENGINEER

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 4/65.....

EJECTOR PUMP NO ...3.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System						
	2	Cleanning Overall Inside Panel Control						
	3	Fitting All Inside Panel Control						
	4	Testing Overload						
	5	Testing Timer Operate						
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ...

 นายพรชัย กรุดทอง
 RECHECK BY CHIEF ENGINEER

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 4/65

EJECTOR PUMP NO ...4.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES
R = REPAIR P = REPLACED

NOTE

COMMENT

RECORD BY

RECHECK BY นายพรชัย กรุดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 4/65

EJECTOR PUMP NO ...5.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

COMMENT

.....

.....

RECORD BY



RECHECK BY

 นายพรชัย ฤทธิทอง
 CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 4/65

EJECTOR PUMP NO ...6.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY  RECHECK BY นายพรชัย ฤทธิทอง

CHIEF ENGINEER

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 4/165

EJECTOR PUMP NO ...7.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY .

นายพรชัย กรุดทอง
RECHECK BY CHIEF ENGINEER

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 4/65

EJECTOR PUMP NO ...8.....

TIME


TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES

R = REPAIR P = REPLACED

NOTE

COMMENT

RECORD BY  RECHECK BY นายพรชัย ฤกษ์ทอง CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 5/65.....

EJECTOR PUMP NO ...1.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
	2	Cleanning Overall Inside Panel Control	✓					
	3	Fitting All Inside Panel Control		✓				
	4	Testing Overload					✓	
	5	Testing Timer Operate					✓	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY 
 นายพรชัย กรุดทอง
 CHIEF ENGINEER
 RECHECK BY

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 5/65

EJECTOR PUMP NO ...2.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sept,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

COMMENT

.....

.....

RECORD BY [REDACTED]

นายพรชัย กรุดทอง
CHIEF ENGINEER

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 5/65

EJECTOR PUMP NO ...3.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

COMMENT

RECORD BY

นายพรชัย กรุดทอง
CHIEF ENGINEER

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 5/65.....

EJECTOR PUMP NO ...4.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY [REDACTED]

 นายพรชัย กรุดทอง
 CHIEF ENGINEER
 RECHECK BY

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 5/65

EJECTOR PUMP NO ...5.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY 

นายพรชัย ฤๅดทอง
CHIEF ENGINEER
RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 5/65

EJECTOR PUMP NO ...6.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sept,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

COMMENT

.....

.....

RECORD BY


 นายพรชัย ฤกษ์ทอง
 CHIEF ENGINEER

RECHECK BY

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 5/65

EJECTOR PUMP NO ...7.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES

R = REPAIR P = REPLACED

NOTE

COMMENT

RECORD BY



RECHECK BY

นายพรชัย กรุดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 5/65

EJECTOR PUMP NO ...8...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

COMMENT

RECORD BY


 นายพรชัย กรุดทอง
 RECHECK BY CHIEF ENGINEER

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 6/65

EJECTOR PUMP NO ...1.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain					/	
	8	Check Piping And Valves					/	

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES
R = REPAIR P = REPLACED

NOTE

COMMENT

RECORD BY ...

 นายพรชัย กรุดทอง
 RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 6/65

EJECTOR PUMP NO ...2.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain					/	
	8	Check Piping And Valves					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES


R = REPAIR

P = REPLACED

NOTE

COMMENT

RECORD BY


 นายพรชัย ฤกษ์ทอง
 RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 6/65

EJECTOR PUMP NO ...3.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain					/	
	8	Check Piping And Valves					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

.....นายพรชัย กระจุกทอง
RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 6/65

EJECTOR PUMP NO ...4.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System						
	2	Cleanning Overall Inside Panel Control						
	3	Fitting All Inside Panel Control						
	4	Testing Overload						
	5	Testing Timer Operate						
3 Month Mar,Jun,Sept,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES
R = REPAIR P = REPLACED

NOTE

COMMENT

RECORD BY .. นายพรชัย กระจุกทอง
RECHECK BY .. CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 6/65

EJECTOR PUMP NO ...5.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sept,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain					/	
	8	Check Piping And Valves					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY


 นายพรชัย กรุดทอง
 RECHECK BY CHIEF ENGINEER

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 6/65

EJECTOR PUMP NO ...6.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System						
	2	Cleanning Overall Inside Panel Control						
	3	Fitting All Inside Panel Control						
	4	Testing Overload						
	5	Testing Timer Operate						
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES
R = REPAIR P = REPLACED

NOTE

COMMENT

RECORD BY

นายพรชัย ฤกษ์ทอง
CHIEF ENGINEER
RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 6/65

EJECTOR PUMP NO ...7.....

TIME


TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operate					/	
3 Month Mar,Jun,Sept,Dec	6	Check Air Inlet Filter					/	
	7	Check Chain					/	
	8	Check Piping And Valves					/	

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED GREASES
R = REPAIR P = REPLACED

NOTE

COMMENT

RECORD BY ...



RECHECK BY ... นายพรชัย กรุดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 6/65

EJECTOR PUMP NO ...8.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System						
	2	Cleanning Overall Inside Panel Control						
	3	Fitting All Inside Panel Control						
	4	Testing Overload						
	5	Testing Timer Operate						
3 Month Mar,Jun,Sep,Dec	6	Check Air Inlet Filter						
	7	Check Chain						
	8	Check Piping And Valves						

N = NORMAL

AB = ABNORMAL

C = CLEANING


A = ADJUST&ADDED GREASES

R = REPAIR

P = REPLACED

NOTE

COMMENT

RECORD BY 

นายพรชัย กรุดทอง
CHIEF ENGINEER
RECHECK BY

EJECTOR PUMP

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 1/65

SLUDGE RETURN PUMP 1

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System						
	2	Cleanning Overall Inside Panel Control						
	3	Fitting All Inside Panel Control						
	4	Testing Overload						
	5	Testing Timer Operation						
	6	Check Sludge Level In The Tank						
3 Month	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL

AB = ABNORMAL

C = CLEANING


A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

COMMENT

RECORD BY RECHECK BY นายพรชัย ฤกษ์ทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH1/65.....

SLUDGE RETURN PUMP 2

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY



RECHECK BY

นายพรชัย กรุดทอง

CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 2/65.....

SLUDGE RETURN PUMP 1

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month <small>Mar,Jun, Sep,Dec</small>	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY .. 

RECHECK BY นายพรชัย กฤตทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 2/65

SLUDGE RETURN PUMP 2

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System						
	2	Cleanning Overall Inside Panel Control						
	3	Fitting All Inside Panel Control						
	4	Testing Overload						
	5	Testing Timer Operation						
	6	Check Sludge Level In The Tank						
3 Month	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

..... นายพรชัย กระจุกทอง

RECORD BY

RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 3/65

SLUDGE RETURN PUMP 1

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve	/					
	8	Check Guide Well					/	
	9	Check Piping And Valve					/	

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ...


 RECHECK BY นายพรชัย นฤตทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 3/65.....

SLUDGE RETURN PUMP 2

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System	/				/	
	2	Cleanning Overall Inside Panel Control	/	/				
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve	/					
	8	Check Guide Well					/	
	9	Check Piping And Valve					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ...



RECHECK BY

 นายพรชัย กรุดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 4/65.....

SLUDGE RETURN PUMP 1

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

.....นายพรชัย ญรุดทอง
RECHECK BYCHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 4/65

SLUDGE RETURN PUMP 2

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

Mar,Jun,Seq,Dec

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY

นายพรชัย ฤกษ์ทอง
RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 5/65

SLUDGE RETURN PUMP 1

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ...

RECHECK BY นายพรชัย กรุดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 5/65

SLUDGE RETURN PUMP 2

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

RECHECK BY

นายพรชัย กรุดทอง

CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 6/65

SLUDGE RETURN PUMP 1

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System						
	2	Cleanning Overall Inside Panel Control						
	3	Fitting All Inside Panel Control						
	4	Testing Overload						
	5	Testing Timer Operation						
	6	Check Sludge Level In The Tank						
3 Month	7	Cleanning & Check Shake Valve						
	8	Check Guide Well						
	9	Check Piping And Valve						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

นายพรชัย ญาคทอง
RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY WASTE WATER TREATMENT

MONTH 6/65

SLUDGE RETURN PUMP 2

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
	2	Cleanning Overall Inside Panel Control	/					
	3	Fitting All Inside Panel Control		/				
	4	Testing Overload					/	
	5	Testing Timer Operation					/	
	6	Check Sludge Level In The Tank					/	
3 Month Mar,Jun,Sep,Dec	7	Cleanning & Check Shake Valve					/	
	8	Check Guide Well					/	
	9	Check Piping And Valve					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY


 นายพรชัย อนุทอง
 RECHECK BY **CHIEF ENGINEER**