

ภาคผนวก ข2

เอกสารการดูแลรักษาและควบคุมระบบบำบัดน้ำเสีย

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH 1-2/1/25

WASTE WATERTREATMENT PLANT

TIME _____

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual							M	M
	Current(A)	R						11.1	11.2
		S						11.0	11.1
		T						11.1	11.2
	Overload -Alarm							N	N
	Latching relay control							N	M
Pilot Lamp								N	N
WWP2	Auto/Off/Manual							M	M
	Current(A)	R						11.1	11.2
		S						11.2	11.2
		T						11.0	11.1
	Overload -Alarm							N	N
	Latching relay control							N	N
Pilot Lamp								N	N
SLP1	Auto/Off/Manual							A	A
	Current(A)	R						1.2	1.1
		S						1.1	1.2
		T						1.2	1.1
	Timer							N	N
	Overload -Alarm							N	N
Pilot Lamp								N	N
SLP2	Auto/Off/Manual							M	M
	Current(A)	R						1.2	1.1
		S						1.1	1.2
		T						1.1	1.1
	Timer							N	N
	Overload -Alarm							N	N
Pilot Lamp								N	N
DPI	Auto/Off/Manual							M	M
	Current(A)	R						7.1	8.1
		S						7.0	8.1
		T						7.1	8.2
	Overload -Alarm							N	N
	Latching relay control							N	N
Pilot Lamp								N	N
DP2	Auto/Off/Manual							M	M
	Current(A)	R						1.2	1.1
		S						1.1	1.2
		T						1.2	1.1
	Overload -Alarm							N	N
	Latching relay control							N	N
Pilot Lamp								N	N
SP1	Auto/Off/Manual							M	M
	Current(A)	R						1.1	1.2
		S						1.0	1.1
		T						1.1	1.1
	Overload -Alarm							N	N
	Latching relay control							N	N
Pilot Lamp								N	N
SP2	Auto/Off/Manual							M	M
	Current(A)	R						1.1	1.1
		S						1.0	1.2
		T						1.1	1.1
	Overload -Alarm							N	N
	Latching relay control							N	N
Pilot Lamp								N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual							A	A
	Current(A)	R						1.0	1.1
		S						1.1	1.2
		T						1.1	1.1
	Timer							N	N
	Overload -Alarm							N	N
Pilot Lamp							N	N	
SE2	Auto/Off/Manual							M	M
	Current(A)	R						1.1	1.2
		S						1.2	1.1
		T						1.1	1.1
	Timer							N	N
	Overload -Alarm							N	N
Pilot Lamp							N	N	
SE3	Auto/Off/Manual							A	A
	Current(A)	R						1.0	1.1
		S						1.1	1.2
		T						1.1	1.1
	Timer							N	N
	Overload -Alarm							N	N
Pilot Lamp							N	N	
SE4	Auto/Off/Manual							M	M
	Current(A)	R						1.1	1.1
		S						1.2	1.2
		T						1.1	1.1
	Timer							N	N
	Overload -Alarm							N	N
Pilot Lamp							N	N	
SE5	Auto/Off/Manual							A	A
	Current(A)	R						1.1	1.1
		S						1.2	1.2
		T						1.0	1.1
	Timer							N	N
	Overload -Alarm							N	N
Pilot Lamp							N	N	
SE6	Auto/Off/Manual							A	A
	Current(A)	R						1.1	1.1
		S						1.0	1.2
		T						1.1	1.1
	Timer							N	N
	Overload -Alarm							N	N
Pilot Lamp							N	N	
SE7	Auto/Off/Manual							Off	Off
	Current(A)	R						1	1
		S						1	1
		T						1	1
	Timer							1	1
	Overload -Alarm							1	1
Pilot Lamp							1	1	
SE8	Auto/Off/Manual							A	A
	Current(A)	R						6.2	6.1
		S						6.1	6.2
		T						6.2	6.1
	Timer							N	N
	Overload -Alarm							N	N
Pilot Lamp							N	N	
Date Check >>			1	1	1	1	1		
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH.....1/65

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.1	11.1	11.1	11.1	11.1	11.0	11.1
		S	11.0	11.1	11.0	11.1	11.0	11.1	11.1
		T	11.1	11.1	11.1	11.1	11.1	11.1	11.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
WWP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.1	11.1	11.0	11.1	11.0	11.1	11.0
		S	11.1	11.0	11.1	11.0	11.1	11.0	11.1
		T	11.1	11.1	11.1	11.1	11.1	11.1	11.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SLP1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	11.0	11.1	11.1	11.1	11.1	11.1	11.1
		S	11.1	11.0	11.1	11.0	11.1	11.1	11.1
		T	11.1	11.0	11.1	11.1	11.1	11.0	11.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SLP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.2	1.1	1.2
		S	1.1	1.1	1.2	1.1	1.1	1.2	1.1
		T	1.2	1.2	1.1	1.2	1.2	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
DP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.0	7.1	7.1	7.1	7.1	7.0	7.1
		S	7.1	7.1	7.1	7.1	7.1	7.1	7.0
		T	7.1	7.1	7.1	7.1	7.1	7.1	7.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.0	1.1	1.1	1.1	1.0	1.1
		S	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		T	1.1	1.0	1.1	1.0	1.1	1.1	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SP1	Auto/Off/Manual		M	N	M	M	M	M	M
	Current(A)	R	1.2	1.2	1.2	1.2	1.2	1.2	1.1
		S	1.1	1.1	1.1	1.1	1.1	1.0	1.1
		T	1.2	1.1	1.1	1.1	1.1	1.1	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.0	1.1	1.1	1.0	1.1	1.1	1.1
		S	1.1	1.0	1.1	1.1	1.1	1.1	1.1
		T	1.1	1.1	1.1	1.0	1.1	1.0	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.1	1.1	1.1	1.0	1.0	1.0	1.0
		S	1.0	1.2	1.1	1.1	1.0	1.0	1.0
		T	1.1	1.1	1.1	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.2	1.2	1.2	1.2	1.2	1.2	1.2
		T	1.1	1.1	1.1	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.2	1.1	1.1	1.2	1.2	1.2	1.2
		S	1.1	1.2	1.2	1.1	1.1	1.1	1.1
		T	1.2	1.1	1.1	1.2	1.2	1.2	1.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE4	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.2	1.1	1.2	1.1	1.1	1.1	1.1
		S	1.1	1.2	1.1	1.1	1.0	1.0	1.0
		T	1.2	1.1	1.1	1.0	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE5	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.1	1.2	1.1	1.2	1.1	1.1	1.1
		S	1.2	1.1	1.2	1.1	1.1	1.1	1.1
		T	1.0	1.1	1.1	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE6	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	2.1	2.1	2.1	2.0	2.1	2.1	2.1
		S	2.2	2.2	2.2	2.1	2.1	2.1	2.1
		T	2.1	2.2	2.1	2.1	2.1	2.1	2.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE7	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		-	-	-	-	-	-	-
	Overload -Alarm		-	-	-	-	-	-	-
Pilot Lamp		-	-	-	-	-	-	-	
SE8	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.2	1.2	1.1	1.1	1.1	1.1	1.2
		S	1.2	1.1	1.2	1.2	1.2	1.2	1.2
		T	1.1	1.2	1.2	1.2	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
Date Check >>			3/1/10	4/1/15	5/1/15	6/1/15	7/1/15	8/1/15	9/1/15
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH..... 1/65

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.1	11.1	11.1	11.1	11.1	11.1	11.1
		S	11.8	11.8	11.0	11.1	11.0	11.0	11.0
		T	11.1	11.2	11.1	11.1	11.1	11.1	11.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
WWP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.8	11.2	11.2	11.1	11.1	11.1	11.1
		S	11.1	11.1	11.1	11.2	11.1	11.1	11.1
		T	11.8	11.2	11.2	11.1	11.1	11.1	11.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SLP1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.8	1.1	1.2	1.1	1.1	1.1	1.1
		S	1.1	1.8	1.1	1.2	1.1	1.1	1.1
		T	1.8	1.1	1.2	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
SLP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.8	1.2	1.1	1.1	1.1	1.1
		S	1.8	1.1	1.1	1.2	1.1	1.1	1.1
		T	1.1	1.8	1.2	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
DP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	2.2	2.1	2.1	2.0	2.0	2.0	2.0
		S	2.1	2.2	2.0	2.1	2.1	2.1	2.1
		T	2.1	2.1	2.1	2.0	2.0	2.0	2.0
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.8	1.1	1.2	1.1	1.1	1.1	1.1
		S	1.8	1.2	1.1	1.2	1.1	1.1	1.1
		T	1.1	1.1	1.2	1.1	1.1	1.1	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.8	1.1	1.1	1.2	1.2	1.2	1.2
		S	1.1	1.8	1.1	1.1	1.1	1.1	1.1
		T	1.8	1.1	1.2	1.2	1.1	1.1	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.0	1.0	1.0	1.0	1.0	1.0	1.0
		T	1.1	1.1	1.1	1.1	1.1	1.1	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.0	1.1	1.1	1.1	1.1	1.1	1.2
		S	1.0	1.1	1.1	1.1	1.1	1.2	1.1
		T	1.1	1.1	1.1	1.1	1.1	1.1	1.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.2	1.1	1.0	1.1	1.1
		S	1.2	1.2	1.1	1.2	1.1	1.0	1.0
		T	1.1	1.2	1.1	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.1	1.2	1.1	1.1	1.1	1.1	1.1
		S	1.2	1.1	1.1	1.1	1.1	1.1	1.1
		T	1.1	1.1	1.2	1.2	1.2	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE4	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.0	1.1	1.0	1.1	1.0	1.1	1.1
		T	1.1	1.0	1.1	1.0	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE5	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.0	1.1
		S	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		T	1.1	1.0	1.0	1.0	1.0	1.1	1.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE6	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.1	1.0	1.1	1.1	1.1	1.1	1.1
		S	1.0	1.1	1.1	1.1	1.1	1.0	1.1
		T	1.0	1.1	1.1	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE7	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		-	-	-	-	-	-	-
	Overload -Alarm		-	-	-	-	-	-	-
Pilot Lamp		-	-	-	-	-	-	-	
SE8	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.2	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.2	1.1	1.2	1.1	1.1	1.1
		T	1.2	1.1	1.1	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
Date Check >>			10/1/65	11/1/65	12/1/65	13/1/65	14/1/65	15/1/65	16/1/65
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH. 1/65

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	H	H	N	M	M
	Current(A)	R	11.0	11.0	11.1	11.0	11.1	11.1	11.1
		S	11.1	11.0	11.0	11.1	11.1	11.0	11.0
		T	11.1	11.0	11.1	11.1	11.1	11.0	11.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
WWP2	Auto/Off/Manual		M	M	H	H	N	M	M
	Current(A)	R	11.1	11.1	11.0	11.1	11.1	11.1	11.0
		S	11.0	11.0	11.1	11.0	11.0	11.1	11.1
		T	11.0	11.1	11.1	11.1	11.1	11.2	11.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SLP1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	11.1	11.1	11.1	11.1	11.1	11.6	11.1
		S	11.0	11.1	11.1	11.0	11.0	11.0	11.0
		T	11.1	11.1	11.0	11.1	11.1	11.0	11.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SLP2	Auto/Off/Manual		M	M	H	M	M	M	M
	Current(A)	R	1.2	1.2	1.2	1.2	1.0	1.2	1.1
		S	1.1	1.1	1.1	1.2	1.0	1.1	1.2
		T	1.2	1.1	1.1	1.1	1.1	1.2	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
DPI	Auto/Off/Manual		H	M	M	H	M	M	M
	Current(A)	R	7.1	7.1	7.0	7.1	7.1	7.0	7.0
		S	7.0	7.0	7.1	7.0	7.0	7.1	7.1
		T	7.1	7.1	7.1	7.1	7.0	7.1	7.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
DP2	Auto/Off/Manual		M	M	H	H	M	M	M
	Current(A)	R	1.0	1.0	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.1	1.0	1.0	1.0	1.0	1.0
		T	1.1	1.1	1.0	1.0	1.0	1.1	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SPI	Auto/Off/Manual		M	M	H	H	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.2	1.1	1.2	1.1	1.1	1.1	1.2
		T	1.1	1.1	1.1	1.1	1.1	1.2	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SP2	Auto/Off/Manual		M	M	H	H	M	M	M
	Current(A)	R	1.1	1.1	1.0	1.1	1.1	1.2	1.2
		S	1.0	1.0	1.1	1.1	1.1	1.1	1.1
		T	1.1	1.1	1.1	1.1	1.1	1.2	1.2
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.2	1.2
		S	1.0	1.0	1.1	1.1	1.1	1.2	1.1
		T	1.1	1.0	1.1	1.0	1.0	1.1	1.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.2	1.1
		S	1.1	1.1	1.1	1.0	1.1	1.1	1.2
		T	1.0	1.0	1.1	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.2	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.1	1.2	1.1	1.1	1.1	1.1
		T	1.1	1.2	1.1	1.1	1.1	1.2	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE4	Auto/Off/Manual		M	M	N	N	M	M	N
	Current(A)	R	1.0	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.1	1.1	1.1	1.1	1.0	1.1
		T	1.0	1.0	1.0	1.1	1.1	1.0	1.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE5	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.2	1.1
		S	1.1	1.1	1.1	1.1	1.1	1.0	1.1
		T	1.1	1.1	1.0	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE6	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.0	1.0	1.1	1.1	1.1	1.2	1.1
		S	1.1	1.1	1.0	1.1	1.1	1.1	1.2
		T	1.0	1.1	1.0	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE7	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		-	-	-	-	-	-	-
	Overload -Alarm		-	-	-	-	-	-	-
Pilot Lamp		-	-	-	-	-	-	-	
SE8	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.2	1.1	1.2	1.1	1.1	1.2	1.2
		S	1.1	1.1	1.2	1.1	1.1	1.2	1.1
		T	1.1	1.1	1.1	1.1	1.1	1.1	1.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
Date Check >>			17/1/65	18/1/65	19/1/65	20/1/65	21/1/65	22/1/65	23/1/65
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH 1/65

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.0	11.0	11.0	11.0	11.1	11.1
		S	11.1	11.1	11.1	11.1	11.1	11.1	11.1
		T	11.0	11.0	11.0	11.0	11.1	11.1	11.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
WWP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.1	11.1	11.1	11.1	11.1	11.1	11.1
		S	11.1	11.1	11.1	11.1	11.1	11.1	11.1
		T	11.0	11.0	11.0	11.0	11.1	11.1	11.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SLP1	Auto/Off/Manual		A	A	A	A	M	M	M
	Current(A)	R	11.1	11.1	11.1	11.1	11.1	11.1	11.1
		S	11.0	11.0	11.0	11.0	11.1	11.1	11.1
		T	11.1	11.1	11.1	11.1	11.0	11.0	11.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SLP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.2	1.2	1.2	1.2	1.2	1.2	1.2
		S	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		T	1.2	1.2	1.2	1.2	1.2	1.2	1.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
DP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.1	7.1	7.1	7.1	7.1	7.1	7.1
		S	7.0	7.0	7.0	7.0	7.0	7.1	7.1
		T	7.0	7.1	7.1	7.1	7.1	7.1	7.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.1	1.1	1.1	1.0	1.0	1.0
		T	1.0	1.0	1.0	1.0	1.0	1.0	1.0
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.2	1.2	1.2	1.2	1.2	1.2	1.2
		T	1.2	1.1	1.1	1.1	1.1	1.1	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.2	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		T	1.1	1.1	1.1	1.1	1.0	1.0	1.0
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		M	H	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.2	1.2	1.2	1.2	1.2	1.2	1.2
		T	1.1	1.1	1.1	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		T	1.1	1.1	1.1	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE3	Auto/Off/Manual		M	H	M	M	M	M	M
	Current(A)	R	1.0	1.0	1.0	1.0	1.0	1.0	1.0
		S	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		T	1.1	1.1	1.1	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE4	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.0	1.0	1.0	1.0	1.0	1.0
		S	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		T	1.1	1.0	1.0	1.0	1.0	1.0	1.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE5	Auto/Off/Manual		A	A	A	M	M	M	M
	Current(A)	R	1.0	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		T	1.1	1.1	1.1	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE6	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.1	7.1	7.1	7.1	7.1	7.1	7.1
		S	7.2	7.2	7.1	7.1	7.1	7.1	7.1
		T	7.1	7.1	7.1	7.1	7.1	7.1	7.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE7	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	8.1	8.0	8.0	8.0	8.0	8.1	8.1
		S	8.0	8.1	8.1	8.1	8.1	8.1	8.1
		T	8.1	8.0	8.0	8.0	8.0	8.1	8.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE8	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.2	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.0	1.0	1.0	1.0	1.0	1.0
		T	1.2	1.1	1.1	1.0	1.0	1.0	1.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
Date Check >>			24/1/65	25/1/65	26/1/65	27/1/65	28/1/65	29/1/65	30/1/65
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

Remark.....

DAILY REPORT

MONTH. 1/65

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M						
	Current(A)	R	11.1						
		S	11.0						
		T	11.1						
	Overload -Alarm		N						
	Latching relay control		N						
Pilot Lamp			N						
WWP2	Auto/Off/Manual		M						
	Current(A)	R	11.1						
		S	11.1						
		T	11.1						
	Overload -Alarm		N						
	Latching relay control		N						
Pilot Lamp			N						
SLP1	Auto/Off/Manual		A						
	Current(A)	R	11.0						
		S	11.1						
		T	11.0						
	Timer		N						
	Overload -Alarm		N						
Pilot Lamp			N						
SLP2	Auto/Off/Manual		M						
	Current(A)	R	1.1						
		S	1.1						
		T	1.2						
	Timer		N						
	Overload -Alarm		N						
Pilot Lamp			N						
DP1	Auto/Off/Manual		M						
	Current(A)	R	7.0						
		S	7.1						
		T	7.1						
	Overload -Alarm		N						
	Latching relay control		N						
Pilot Lamp			N						
DP2	Auto/Off/Manual		M						
	Current(A)	R	1.1						
		S	1.1						
		T	1.1						
	Overload -Alarm		N						
	Latching relay control		N						
Pilot Lamp			N						
SP1	Auto/Off/Manual		M						
	Current(A)	R	1.2						
		S	1.1						
		T	1.1						
	Overload -Alarm		N						
	Latching relay control		N						
Pilot Lamp			N						
SP2	Auto/Off/Manual		M						
	Current(A)	R	1.1						
		S	1.2						
		T	1.1						
	Overload -Alarm		N						
	Latching relay control		N						
Pilot Lamp			N						

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		M						
	Current(A)	R	1.2						
		S	1.1						
		T	1.1						
	Timer		N						
	Overload -Alarm		N						
Pilot Lamp			N						
SE2	Auto/Off/Manual		M						
	Current(A)	R	1.1						
		S	1.0						
		T	1.1						
	Timer		N						
	Overload -Alarm		N						
Pilot Lamp			N						
SE3	Auto/Off/Manual		M						
	Current(A)	R	1.0						
		S	1.1						
		T	1.0						
	Timer		N						
	Overload -Alarm		N						
Pilot Lamp			N						
SE4	Auto/Off/Manual		M						
	Current(A)	R	1.1						
		S	1.1						
		T	1.1						
	Timer		N						
	Overload -Alarm		N						
Pilot Lamp			N						
SE5	Auto/Off/Manual		M						
	Current(A)	R	2.0						
		S	1.0						
		T	1.1						
	Timer		N						
	Overload -Alarm		N						
Pilot Lamp			N						
SE6	Auto/Off/Manual		M						
	Current(A)	R	7.1						
		S	7.2						
		T	7.1						
	Timer		N						
	Overload -Alarm		N						
Pilot Lamp			N						
SE7	Auto/Off/Manual		A						
	Current(A)	R	8.0						
		S	8.0						
		T	8.1						
	Timer		N						
	Overload -Alarm		N						
Pilot Lamp			N						
SE8	Auto/Off/Manual		M						
	Current(A)	R	1.1						
		S	1.1						
		T	1.2						
	Timer		N						
	Overload -Alarm		N						
Pilot Lamp			N						
Date Check >>			31.1.15	/	/	/	/	/	/
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH 2/65

WASTE WATERTREATMENT PLANT

TIME

Description / Day		Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M
	Current(A)	R	11.1	11.1	11.1	11.0	11.1	11.1
		S	11.1	11.1	11.0	11.0	11.0	11.0
		T	11.0	11.0	11.0	11.0	11.0	11.0
	Overload -Alarm		N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N
WWP2	Auto/Off/Manual		M	M	M	M	M	M
	Current(A)	R	11.1	11.1	11.1	11.1	11.1	11.1
		S	11.1	11.1	11.1	11.1	11.1	11.0
		T	11.1	11.0	11.0	11.0	11.0	11.0
	Overload -Alarm		N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N
SLP1	Auto/Off/Manual		A	M	A	M	M	M
	Current(A)	R	11.1	11.1	11.1	11.1	11.1	11.0
		S	11.0	11.0	11.0	11.0	11.0	11.0
		T	11.1	11.1	11.1	11.1	11.0	11.1
	Timer		N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N
SLP2	Auto/Off/Manual		M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.1	1.1	1.1	1.1	1.0
		T	1.1	1.0	1.0	1.0	1.0	1.0
	Timer		N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N
DP1	Auto/Off/Manual		M	M	M	M	M	M
	Current(A)	R	7.1	7.1	7.1	7.1	7.1	7.0
		S	7.0	7.0	7.0	7.0	7.0	7.1
		T	7.1	7.1	7.1	7.1	7.0	7.1
	Overload -Alarm		N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N
DP2	Auto/Off/Manual		M	M	M	M	M	M
	Current(A)	R	1.0	1.0	1.0	1.0	1.0	1.1
		S	1.1	1.1	1.1	1.1	1.1	1.0
		T	1.0	1.0	1.0	1.0	1.1	1.0
	Overload -Alarm		N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N
SP1	Auto/Off/Manual		M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.2
		S	1.2	1.2	1.2	1.2	1.2	1.2
		T	1.1	1.1	1.1	1.1	1.1	1.1
	Overload -Alarm		N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N
SP2	Auto/Off/Manual		M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.2
		S	1.1	1.1	1.1	1.1	1.1	1.2
		T	1.2	1.2	1.2	1.2	1.2	1.1
	Overload -Alarm		N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual			H	M	M	M	M	M
	Current(A)	R		1.1	1.1	1.1	1.1	1.1	1.1
		S		1.2	1.2	1.2	1.2	1.2	1.2
		T		1.2	1.2	1.2	1.2	1.2	1.1
	Timer			N	N	2	2	2	2
	Overload -Alarm			N	N	2	2	2	2
Pilot Lamp			N	N	2	2	2	2	
SE2	Auto/Off/Manual			M	M	3	3	M	3
	Current(A)	R		1.1	1.1	1.1	1.1	1.1	1.0
		S		1.1	1.1	1.1	1.1	1.1	1.0
		T		1.1	1.1	1.1	1.0	1.0	1.1
	Timer			N	N	2	2	2	2
	Overload -Alarm			N	N	2	2	2	2
Pilot Lamp			N	N	2	2	2	2	
SE3	Auto/Off/Manual			M	M	3	3	3	3
	Current(A)	R		1.0	1.0	1.0	1.0	1.0	1.1
		S		1.1	1.1	1.1	1.1	1.1	1.0
		T		1.1	1.1	1.1	1.1	1.1	1.0
	Timer			N	N	2	2	2	2
	Overload -Alarm			N	N	2	2	2	2
Pilot Lamp			N	N	2	2	2	2	
SE4	Auto/Off/Manual			M	3	2	3	3	3
	Current(A)	R		1.1	1.1	1.1	1.1	1.1	1.0
		S		1.1	1.1	1.1	1.1	1.1	1.0
		T		1.0	1.0	1.0	1.0	1.0	1.0
	Timer			N	N	2	2	2	2
	Overload -Alarm			N	N	2	2	2	2
Pilot Lamp			N	N	2	2	2	2	
SE5	Auto/Off/Manual			M	M	3	3	3	3
	Current(A)	R		1.0	1.0	1.0	1.0	1.0	1.1
		S		1.1	1.1	1.1	1.1	1.1	1.1
		T		1.0	1.0	1.0	1.0	1.1	1.0
	Timer			N	N	2	2	2	2
	Overload -Alarm			N	N	2	2	2	2
Pilot Lamp			N	N	2	2	2	2	
SE6	Auto/Off/Manual			M	3	3	3	3	3
	Current(A)	R		1.0	1.0	1.0	1.0	1.0	1.1
		S		1.1	1.1	1.1	1.1	1.1	1.1
		T		1.1	1.1	1.1	1.1	1.1	1.0
	Timer			N	N	2	2	2	2
	Overload -Alarm			N	N	2	2	2	2
Pilot Lamp			N	N	2	2	2	2	
SE7	Auto/Off/Manual			A	A	A	A	3	3
	Current(A)	R		8.1	8.1	8.1	8.1	8.1	8.0
		S		8.1	8.1	8.1	8.1	8.1	8.1
		T		8.0	8.0	8.0	8.0	8.1	8.1
	Timer			N	N	2	2	2	2
	Overload -Alarm			N	N	2	2	2	2
Pilot Lamp			N	N	2	2	2	2	
SE8	Auto/Off/Manual			M	M	3	3	3	3
	Current(A)	R		1.1	1.1	1.1	1.1	1.1	1.0
		S		1.1	1.1	1.1	1.1	1.1	1.1
		T		1.1	1.1	1.1	1.1	1.1	1.1
	Timer			N	N	2	2	2	2
	Overload -Alarm			N	N	2	2	2	2
Pilot Lamp			N	N	2	2	2	2	
Date Check >>				1/2/65	2/2/65	3/2/66	4/2/65	5/2/65	6/2/66
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH 2/65

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.1	11.0	11.1	11.1	11.1	11.1
		S	11.1	11.1	11.1	11.1	11.1	11.1	11.0
		T	11.1	11.1	11.1	11.1	11.0	11.1	11.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
WWP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.1	11.0	11.1	11.0	11.1	11.1	11.1
		S	11.0	11.1	11.0	11.1	11.0	11.0	11.0
		T	11.0	11.0	11.1	11.1	11.1	11.1	11.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SLP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.1	11.1	11.1	11.1	11.1	11.0	11.1
		S	11.0	11.1	11.0	11.1	11.1	11.1	11.0
		T	11.0	11.0	11.0	11.0	11.1	11.0	11.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SLP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.0	1.0	1.0	1.0	1.1	1.1	1.1
		S	1.0	1.1	1.0	1.1	1.1	1.0	1.0
		T	1.1	1.1	1.1	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
DP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.1	7.1	7.1	7.1	7.0	7.1	7.0
		S	7.1	7.1	7.1	7.1	7.1	7.0	7.1
		T	7.0	7.1	7.0	7.1	7.1	7.1	7.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.0
		S	1.1	1.0	1.1	1.0	1.1	1.1	1.1
		T	1.0	1.1	1.0	1.1	1.1	1.0	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.2	1.1	1.2	1.1	1.1	1.0	1.1
		S	1.2	1.2	1.2	1.2	1.1	1.1	1.1
		T	1.1	1.1	1.1	1.1	1.1	1.0	1.0
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.2	1.2	1.2	1.1	1.1	1.1	1.0
		S	1.1	1.1	1.1	1.2	1.1	1.1	1.1
		T	1.1	1.1	1.1	1.1	1.1	1.1	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		M	M	M	M	M	H	H
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		T	1.2	1.1	1.1	1.1	1.1	1.1	1.0
	Timer		2	2	2	2	2	N	N
	Overload -Alarm		2	2	2	2	2	N	N
Pilot Lamp		2	2	2	2	2	N	N	
SE2	Auto/Off/Manual		M	M	M	M	M	H	H
	Current(A)	R	1.1	1.1	1.1	1.0	1.1	1.1	1.1
		S	1.0	1.1	1.1	1.1	1.1	1.1	1.1
		T	1.0	1.0	1.0	1.1	1.1	1.0	1.1
	Timer		2	2	2	2	2	N	N
	Overload -Alarm		2	2	2	2	2	N	N
Pilot Lamp		2	2	2	2	2	N	N	
SE3	Auto/Off/Manual		M	M	M	M	M	H	H
	Current(A)	R	1.0	1.1	1.0	1.1	1.1	1.0	1.1
		S	1.1	1.0	1.1	1.0	1.1	1.1	1.0
		T	1.1	1.1	1.1	1.0	1.1	1.0	1.1
	Timer		2	2	2	2	2	N	N
	Overload -Alarm		2	2	2	2	2	N	N
Pilot Lamp		2	2	2	2	2	N	N	
SE4	Auto/Off/Manual		M	M	M	M	M	H	H
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.0	1.0	1.0	1.0	1.1	1.0	1.1
		T	1.0	1.1	1.0	1.1	1.1	1.0	1.1
	Timer		2	2	2	2	2	N	N
	Overload -Alarm		2	2	2	2	2	N	N
Pilot Lamp		2	2	2	2	2	N	N	
SE5	Auto/Off/Manual		M	M	M	M	M	H	A
	Current(A)	R	1.0	1.0	1.0	1.1	1.1	1.1	1.1
		S	1.1	1.0	1.1	1.1	1.1	1.1	1.0
		T	1.1	1.1	1.1	1.0	1.1	1.0	1.1
	Timer		2	2	2	2	2	N	N
	Overload -Alarm		2	2	2	2	2	N	N
Pilot Lamp		2	2	2	2	2	N	N	
SE6	Auto/Off/Manual		M	M	M	M	M	H	M
	Current(A)	R	1.0	1.1	1.0	1.1	1.1	1.0	1.1
		S	1.1	1.1	1.1	1.0	1.1	1.1	1.1
		T	1.1	1.1	1.1	1.1	1.1	1.1	1.0
	Timer		2	2	2	2	2	N	N
	Overload -Alarm		2	2	2	2	2	N	N
Pilot Lamp		2	2	2	2	2	N	N	
SE7	Auto/Off/Manual		M	M	M	M	M	H	A
	Current(A)	R	8.1	8.1	8.1	8.1	8.1	8.1	8.0
		S	8.1	8.1	8.1	8.1	8.0	8.0	8.1
		T	8.0	8.1	8.0	8.1	8.1	8.1	8.1
	Timer		2	2	2	2	2	N	N
	Overload -Alarm		2	2	2	2	2	N	N
Pilot Lamp		2	2	2	2	2	N	N	
SE8	Auto/Off/Manual		M	M	M	M	M	H	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.0	1.1
		S	1.1	1.1	1.1	1.1	1.1	1.1	1.0
		T	1.0	1.1	1.0	1.1	1.1	1.1	1.1
	Timer		2	2	2	2	2	N	N
	Overload -Alarm		2	2	2	2	2	N	N
Pilot Lamp		2	2	2	2	2	N	N	
Date Check >>			7/2/65	8/2/65	9/2/65	10/2/65	11/2/65	12/2/65	13/2/65
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH 2/65

WASTE WATERTREATMENT PLANT

TIME

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.1	11.1	11.1	11.1	11.1	1.1	11.1
		S	11.0	11.1	11.1	11.0	1.0	1.1	11.0
		T	11.1	11.1	11.0	11.0	1.1	1.0	11.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
WWP2	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	11.1	11.1	11.1	11.1	11.1	11.1	11.1
		S	11.1	11.1	11.0	11.1	11.1	11.0	11.1
		T	11.1	11.1	11.1	11.0	11.1	11.1	11.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SLP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.1	11.1	11.1	11.1	11.1	11.0
		S	11.1	11.0	11.1	11.0	11.1	11.0	11.1
		T	11.1	11.1	11.1	11.1	11.0	11.0	11.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
SLP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.2	1.1	1.1	1.0
		S	1.0	1.0	1.1	1.1	1.1	1.0	1.1
		T	1.1	1.0	1.1	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
DP1	Auto/Off/Manual		N	M	M	M	M	M	M
	Current(A)	R	7.1	7.1	7.1	7.1	7.1	7.1	7.0
		S	7.0	7.1	7.1	7.1	7.1	7.1	7.1
		T	7.0	7.0	7.1	7.0	7.1	7.0	7.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.2	1.1	1.1	1.1
		S	1.0	1.0	1.1	1.1	1.1	1.1	1.1
		T	1.1	1.1	1.1	1.1	1.1	1.0	1.0
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.0	1.1	1.1	1.2	1.1	1.1	1.1
		S	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		T	1.1	1.1	1.1	1.1	1.1	1.1	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.1	1.1	1.2	1.1	1.1	1.1
		T	1.0	1.1	1.1	1.2	1.1	1.1	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.0	1.1	1.2	1.1	1.1	1.1
		T	1.1	1.1	1.1	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.0	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		T	1.1	1.0	1.1	1.2	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE3	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.2	1.1	1.1	1.2	1.1	1.1	1.0
		T	1.1	1.1	1.1	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE4	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.1	1.1	1.1	1.2	1.1	1.1
		T	1.0	1.0	1.1	1.2	1.1	1.2	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE5	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.1	1.1	1.1	1.2	1.1	1.1	1.1
		S	1.0	1.0	1.1	1.1	1.1	1.0	1.1
		T	1.1	1.1	1.1	1.1	1.1	1.1	1.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE6	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.1	7.1	7.1	7.1	7.1	7.0	7.1
		S	7.0	7.1	7.1	7.2	7.1	7.1	7.0
		T	7.0	7.0	7.1	7.2	7.1	7.1	7.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE7	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	8.1	8.1	8.1	8.1	8.1	8.1	8.0
		S	8.1	8.0	8.1	8.0	8.0	8.1	8.1
		T	8.0	8.1	8.1	8.0	8.1	8.0	8.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE8	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.0	1.1	1.2	1.2	1.1	1.1
		T	1.0	1.1	1.1	1.1	1.1	1.1	1.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
Date Check >>			14/2/65	15/2/65	16/2/65	17/2/65	18/2/65	19/2/65	20/2/65
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH.....2/65.....

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.1	11.1	11.1	11.1	11.0	11.0	11.1
		S	11.1	11.0	11.0	11.1	11.1	11.0	11.1
		T	11.0	11.1	11.0	11.1	11.1	11.1	11.0
	Overload - Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
WWP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.1	11.1	11.1	11.1	11.1	11.1	11.1
		S	11.0	11.0	11.1	11.0	11.1	11.1	11.0
		T	11.1	11.0	11.0	11.1	11.1	11.0	11.1
	Overload - Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SLP1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	11.0	11.1	11.1	11.1	11.1	11.1	11.1
		S	11.0	11.0	11.1	11.1	11.1	11.0	11.0
		T	11.0	11.1	11.1	11.0	11.1	11.1	11.0
	Timer		N	N	N	N	N	N	N
	Overload - Alarm		N	N	N	N	N	N	N
SLP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.2	1.2	1.1	1.1	1.1	1.1	1.1
		S	1.2	1.1	1.2	1.1	1.1	1.0	1.1
		T	1.1	1.1	1.1	1.0	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload - Alarm		N	N	N	N	N	N	N
DP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.1	7.1	7.1	7.1	7.1	7.0	7.1
		S	7.0	7.1	7.1	7.1	7.1	7.1	7.1
		T	7.1	7.1	7.1	7.0	7.1	7.1	7.0
	Overload - Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.0	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.0	1.1	1.1	1.1	1.0	1.1
		T	1.1	1.1	1.1	1.0	1.1	1.1	1.0
	Overload - Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.0	1.1	1.1	1.0	1.1	1.1	1.0
		T	1.1	1.0	1.1	1.1	1.1	1.0	1.1
	Overload - Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.0	1.1
		S	1.1	1.1	1.0	1.1	1.1	1.1	1.1
		T	1.0	1.0	1.1	1.1	1.1	1.1	1.0
	Overload - Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		M	M	M	M	M	H	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.0	1.1	1.1	1.0	1.1	1.0	1.1
		T	1.0	1.0	1.1	1.1	1.1	1.1	1.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE2	Auto/Off/Manual		M	M	M	M	M	H	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.1	1.1	1.0	1.1	1.1	1.0
		T	1.1	1.0	1.1	1.1	1.1	1.0	1.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE3	Auto/Off/Manual		M	M	M	M	M	H	M
	Current(A)	R	1.0	1.1	1.1	1.1	1.1	1.0	1.1
		S	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		T	1.1	1.1	1.0	1.1	1.1	1.0	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE4	Auto/Off/Manual		M	M	M	M	M	H	M
	Current(A)	R	1.1	1.1	1.1	1.0	1.1	1.1	1.1
		S	1.1	1.1	1.1	1.1	1.1	1.1	1.0
		T	1.0	1.1	1.1	1.1	1.1	1.0	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE5	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.0	1.0	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.1	1.1	1.1	1.1	1.0	1.1
		T	1.1	1.0	1.1	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE6	Auto/Off/Manual		M	M	M	M	M	H	M
	Current(A)	R	7.0	7.1	7.1	7.1	7.1	7.0	7.1
		S	7.1	7.1	7.0	7.1	7.1	7.1	7.0
		T	7.0	7.0	7.1	7.0	7.1	7.1	7.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE7	Auto/Off/Manual		M	M	M	M	M	H	M
	Current(A)	R	8.1	8.1	8.1	8.0	8.1	8.0	8.0
		S	8.0	8.0	8.1	8.1	8.1	8.1	8.0
		T	8.1	8.1	8.1	8.1	8.1	8.1	8.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE8	Auto/Off/Manual		M	M	M	M	M	H	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.0	1.1
		S	1.1	1.1	1.1	1.0	1.1	1.1	1.1
		T	1.2	1.1	1.1	1.1	1.1	1.1	1.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
Date Check >>			21/2/65	22/2/65	23/2/65	24/2/65	25/2/65	26/2/65	27/2/65
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH..... 2 / 65

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day		Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual	M						
	Current(A)	R	11.1					
		S	11.1					
		T	11.1					
	Overload -Alarm	N						
	Latching relay control	N						
	Pilot Lamp	N						
WWP2	Auto/Off/Manual	M						
	Current(A)	R	11.1					
		S	11.1					
		T	11.1					
	Overload -Alarm	N						
	Latching relay control	N						
	Pilot Lamp	N						
SLP1	Auto/Off/Manual	A						
	Current(A)	R	11.1					
		S	11.1					
		T	11.1					
	Timer	N						
	Overload -Alarm	N						
	Pilot Lamp	N						
SLP2	Auto/Off/Manual	M						
	Current(A)	R	1.1					
		S	1.1					
		T	1.1					
	Timer	N						
	Overload -Alarm	N						
	Pilot Lamp	N						
DP1	Auto/Off/Manual	M						
	Current(A)	R	7.1					
		S	7.1					
		T	7.1					
	Overload -Alarm	N						
	Latching relay control	N						
	Pilot Lamp	N						
DP2	Auto/Off/Manual	M						
	Current(A)	R	1.1					
		S	1.1					
		T	1.1					
	Overload -Alarm	N						
	Latching relay control	N						
	Pilot Lamp	N						
SP1	Auto/Off/Manual	M						
	Current(A)	R	1.0					
		S	1.0					
		T	1.0					
	Overload -Alarm	N						
	Latching relay control	N						
	Pilot Lamp	N						
SP2	Auto/Off/Manual	M						
	Current(A)	R	1.1					
		S	1.1					
		T	1.1					
	Overload -Alarm	N						
	Latching relay control	N						
	Pilot Lamp	N						

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		M						
	Current(A)	R	1.1						
		S	1.1						
		T	1.1						
	Timer		N						
	Overload -Alarm		N						
Pilot Lamp			N						
SE2	Auto/Off/Manual		M						
	Current(A)	R	1.1						
		S	1.1						
		T	1.1						
	Timer		N						
	Overload -Alarm		N						
Pilot Lamp			N						
SE3	Auto/Off/Manual		M						
	Current(A)	R	1.1						
		S	1.1						
		T	1.1						
	Timer		N						
	Overload -Alarm		N						
Pilot Lamp			N						
SE4	Auto/Off/Manual		M						
	Current(A)	R	1.1						
		S	1.1						
		T	1.1						
	Timer		N						
	Overload -Alarm		N						
Pilot Lamp			N						
SE5	Auto/Off/Manual		A						
	Current(A)	R	1.0						
		S	1.6						
		T	1.0						
	Timer		N						
	Overload -Alarm		N						
Pilot Lamp			N						
SE6	Auto/Off/Manual		M						
	Current(A)	R	1.1						
		S	1.1						
		T	1.1						
	Timer		N						
	Overload -Alarm		N						
Pilot Lamp			N						
SE7	Auto/Off/Manual		M						
	Current(A)	R	8.1						
		S	8.1						
		T	8.1						
	Timer		N						
	Overload -Alarm		N						
Pilot Lamp			N						
SE8	Auto/Off/Manual		M						
	Current(A)	R	1.1						
		S	1.1						
		T	1.1						
	Timer		N						
	Overload -Alarm		N						
Pilot Lamp			N						
Date Check >>			28/2/25	/ /	/ /	/ /	/ /	/ /	/ /
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH. 3/65

WASTE WATERTREATMENT PLANT

TIME

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual			M	M	M	M	M	M
	Current(A)	R		11.1	11.0	11.1	11.0	11.1	11.1
		S		11.1	11.1	11.1	11.1	11.1	11.1
		T		11.1	11.1	11.1	11.1	11.0	11.0
	Overload -Alarm			N	N	N	N	N	N
	Latching relay control			N	N	N	N	N	N
WWP2	Auto/Off/Manual			M	M	M	M	M	M
	Current(A)	R		11.1	11.1	11.0	11.1	11.0	11.0
		S		11.0	11.1	11.1	11.1	11.0	11.0
		T		11.1	11.1	11.1	11.0	11.1	11.1
	Overload -Alarm			N	N	N	N	N	N
	Latching relay control			N	N	N	N	N	N
SLP1	Auto/Off/Manual			A	A	A	A	M	M
	Current(A)	R		11.1	11.0	11.1	11.0	11.1	11.1
		S		11.1	11.1	11.1	11.1	11.1	11.1
		T		11.1	11.1	11.1	11.1	11.1	11.1
	Timer			N	N	N	N	N	N
	Overload -Alarm			N	N	N	N	N	N
SLP2	Auto/Off/Manual			M	M	M	M	M	M
	Current(A)	R		1.1	1.0	1.1	1.1	1.0	1.0
		S		1.1	1.1	1.1	1.0	1.0	1.0
		T		1.1	1.1	1.1	1.1	1.1	1.0
	Timer			N	N	N	N	N	N
	Overload -Alarm			N	N	N	N	N	N
DP1	Auto/Off/Manual			M	M	M	M	M	M
	Current(A)	R		7.1	7.0	7.1	7.1	7.0	7.0
		S		7.1	7.1	7.1	7.1	7.0	7.0
		T		7.1	7.1	7.1	7.0	7.1	7.1
	Overload -Alarm			N	N	N	N	N	N
	Latching relay control			N	N	N	N	N	N
DP2	Auto/Off/Manual			M	M	M	M	M	M
	Current(A)	R		1.1	1.0	1.1	1.0	1.1	1.1
		S		1.1	1.1	1.1	1.1	1.1	1.1
		T		1.1	1.1	1.1	1.1	1.1	1.0
	Overload -Alarm			N	N	N	N	N	N
	Latching relay control			N	N	N	N	N	N
SP1	Auto/Off/Manual			M	M	M	M	M	M
	Current(A)	R		1.0	1.1	1.1	1.1	1.0	1.0
		S		1.1	1.1	1.0	1.0	1.0	1.0
		T		1.1	1.1	1.1	1.1	1.1	1.1
	Overload -Alarm			N	N	N	N	N	N
	Latching relay control			N	N	N	N	N	N
SP2	Auto/Off/Manual			M	M	M	M	M	M
	Current(A)	R		1.1	1.0	1.1	1.0	1.0	1.0
		S		1.1	1.1	1.1	1.1	1.0	1.0
		T		1.1	1.1	1.0	1.1	1.1	1.1
	Overload -Alarm			N	N	N	N	N	N
	Latching relay control			N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual			M	M	M	M	M	M
	Current(A)	R		1.1	1.0	1.1	1.0	1.1	1.1
		S		1.1	1.1	1.1	1.1	1.1	1.1
		T		1.1	1.1	1.1	1.1	1.0	1.0
	Timer			2	2	2	2	2	2
	Overload -Alarm			2	2	2	2	2	2
Pilot Lamp			2	2	2	2	2	2	
SE2	Auto/Off/Manual			M	M	M	M	M	M
	Current(A)	R		1.1	1.0	1.1	1.0	1.0	1.0
		S		1.1	1.1	1.1	1.1	1.0	1.0
		T		1.1	1.1	1.1	1.1	1.1	1.1
	Timer			2	2	2	2	2	2
	Overload -Alarm			2	2	2	2	2	2
Pilot Lamp			2	2	2	2	2	2	
SE3	Auto/Off/Manual			M	M	M	M	M	M
	Current(A)	R		1.1	1.0	1.1	1.0	1.1	1.1
		S		1.1	1.1	1.1	1.1	1.1	1.1
		T		1.1	1.1	1.1	1.1	1.0	1.0
	Timer			2	2	2	2	2	2
	Overload -Alarm			2	2	2	2	2	2
Pilot Lamp			2	2	2	2	2	2	
SE4	Auto/Off/Manual			M	M	M	M	M	M
	Current(A)	R		1.1	1.0	1.1	1.1	1.1	1.1
		S		1.1	1.1	1.1	1.1	1.1	1.1
		T		1.1	1.1	1.1	1.1	1.1	1.1
	Timer			2	2	2	2	2	2
	Overload -Alarm			2	2	2	2	2	2
Pilot Lamp			2	2	2	2	2	2	
SE5	Auto/Off/Manual			A	A	A	A	M	M
	Current(A)	R		1.0	1.1	1.1	1.1	1.0	1.0
		S		1.0	1.1	1.0	1.0	1.0	1.0
		T		1.1	1.1	1.1	1.0	1.1	1.1
	Timer			2	2	2	2	2	2
	Overload -Alarm			2	2	2	2	2	2
Pilot Lamp			2	2	2	2	2	2	
SE6	Auto/Off/Manual			M	M	M	M	M	M
	Current(A)	R		1.1	1.0	1.1	1.1	1.0	1.0
		S		1.1	1.1	1.0	1.0	1.0	1.0
		T		1.1	1.1	1.1	1.0	1.1	1.1
	Timer			2	2	2	2	2	2
	Overload -Alarm			2	2	2	2	2	2
Pilot Lamp			2	2	2	2	2	2	
SE7	Auto/Off/Manual			M	M	M	M	M	M
	Current(A)	R		6.1	6.1	6.1	6.0	6.0	6.0
		S		6.0	6.1	6.0	6.1	6.0	6.0
		T		6.1	6.1	6.1	6.1	6.1	6.1
	Timer			2	2	2	2	2	2
	Overload -Alarm			2	2	2	2	2	2
Pilot Lamp			2	2	2	2	2	2	
SE8	Auto/Off/Manual			M	M	M	M	M	M
	Current(A)	R		1.1	1.0	1.1	1.0	1.1	1.1
		S		1.1	1.1	1.0	1.1	1.1	1.1
		T		1.1	1.1	1.1	1.1	1.0	1.0
	Timer			2	2	2	2	2	2
	Overload -Alarm			2	2	2	2	2	2
Pilot Lamp			2	2	2	2	2	2	
Date Check >>				1 '3 '65	2 '3 '65	3 '3 '65	4 '3 '65	5 '3 '65	6 '3 '65
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH: 3/65

WASTE WATERTREATMENT PLANT

TIME:

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.1	11.0	11.0	11.1	11.0	11.0
		S	11.1	11.0	11.0	11.1	11.0	11.0	11.0
		T	11.1	11.0	11.1	11.1	11.1	11.0	11.0
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
WWP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.1	11.1	11.0	11.1	11.1	11.1
		S	11.0	11.1	11.1	11.0	11.1	11.1	11.1
		T	11.1	11.0	11.0	11.1	11.1	11.1	11.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SLP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.1	11.0	11.1	11.1	11.0	11.0	11.0
		S	11.1	11.1	11.1	11.1	11.1	11.1	11.1
		T	11.1	11.1	11.0	11.1	11.1	11.1	11.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SLP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.0	1.1	1.1	1.1	1.1	1.0	1.0
		S	1.1	1.2	1.2	1.1	1.1	1.0	1.0
		T	1.1	1.1	1.2	1.1	1.0	1.0	1.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
DP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.1	7.1	7.2	7.1	7.2	7.2	7.2
		S	7.0	7.1	7.2	7.1	7.1	7.2	7.0
		T	7.1	7.2	7.1	7.1	7.1	7.2	7.2
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.0	1.1	1.0	1.1	1.2	1.2	1.2
		S	1.1	1.2	1.0	1.1	1.1	1.2	1.2
		T	1.0	1.2	1.2	1.1	1.2	1.2	1.2
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.2	1.2	1.2	1.1	1.1	1.1
		S	1.0	1.1	1.2	1.2	1.2	1.2	1.1
		T	1.1	1.1	1.1	1.2	1.1	1.1	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.2	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		T	1.0	1.1	1.2	1.1	1.2	1.2	1.2
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.0	1.0	1.0	1.0	1.0
		S	1.0	1.1	1.0	1.0	1.1	1.0	1.0
		T	1.0	1.1	1.1	1.0	1.0	1.0	1.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.0	1.1	1.1	1.2	1.1	1.1
		T	1.0	1.1	1.0	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE3	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.0	1.1	1.2	1.2	1.2
		S	1.0	1.1	1.0	1.1	1.1	1.2	1.2
		T	1.0	1.1	1.1	1.1	1.1	1.2	1.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE4	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.2	1.2	1.2	1.2	1.2	1.2	1.1
		S	1.1	1.1	1.2	1.2	1.2	1.2	1.2
		T	1.2	1.1	1.0	1.2	1.1	1.2	1.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE5	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.2	1.1	1.0	1.1	1.2	1.2	1.2
		S	1.2	1.2	1.0	1.1	1.1	1.2	1.2
		T	1.1	1.1	1.1	1.1	1.2	1.2	1.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE6	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.2	1.2	1.2	1.2	1.2	1.2	1.2
		S	1.1	1.1	1.2	1.2	1.1	1.2	1.2
		T	1.1	1.1	1.1	1.2	1.2	1.2	1.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE7	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	8.1	8.1	8.0	8.1	8.1	9.1	8.1
		S	7.9	8.1	8.0	8.1	8.2	8.1	8.1
		T	8.1	8.0	8.1	8.0	8.1	8.1	8.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE8	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.2	1.2	1.2
		S	1.2	1.2	1.1	1.1	1.1	1.2	1.2
		T	1.1	1.1	1.2	1.1	1.1	1.2	1.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
Date Check >>			7/3/15	8/3/15	9/3/15	10/3/15	11/3/15	12/3/15	13/3/15
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH..... 3/65

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.0	11.1	11.0	11.0	11.1	11.1
		S	11.0	11.1	11.1	11.1	11.1	11.0	11.0
		T	11.0	11.1	11.1	11.1	11.0	11.1	11.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
WWP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.1	11.0	11.1	11.1	11.1	11.0	11.0
		S	11.1	11.0	11.1	11.1	11.1	11.0	11.0
		T	11.1	11.1	11.1	11.0	11.0	11.0	11.0
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SLP1	Auto/Off/Manual		M	A	A	A	A	A	A
	Current(A)	R	11.0	11.1	11.1	11.1	11.1	11.1	11.1
		S	11.0	11.0	11.1	11.0	11.0	11.1	11.1
		T	11.0	11.0	11.1	11.1	11.0	11.1	11.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
SLP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.0	1.1	1.1	1.1	1.0	1.0	1.0
		S	1.0	1.0	1.1	1.0	1.1	1.1	1.1
		T	1.0	1.1	1.1	1.1	1.0	1.0	1.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
DP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.2	7.1	7.2	7.1	7.1	7.1	7.1
		S	7.2	7.1	7.1	7.2	7.0	7.1	7.1
		T	7.2	7.2	7.1	7.1	7.0	7.1	7.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
DP2	Auto/Off/Manual		M	N	M	M	M	M	M
	Current(A)	R	1.2	1.1	1.1	1.2	1.1	1.1	1.1
		S	1.2	1.2	1.2	1.1	1.2	1.1	1.1
		T	1.2	1.2	1.2	1.1	1.1	1.1	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.2	1.1	1.2	1.2
		S	1.1	1.1	1.1	1.1	1.2	1.2	1.2
		T	1.1	1.2	1.1	1.1	1.2	1.2	1.2
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.2	1.2	1.1	1.2	1.2	1.2
		S	1.1	1.2	1.1	1.2	1.1	1.2	1.2
		T	1.2	1.2	1.2	1.2	1.1	1.2	1.2
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		M	A	A	A	A	A	A
	Current(A)	R	1.0	1.0	1.1	1.1	1.1	1.1	1.1
		S	1.0	1.1	1.1	1.0	1.0	1.1	1.1
		T	1.0	1.0	1.0	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.0	1.1	1.1
		S	1.1	1.0	1.1	1.0	1.1	1.1	1.1
		T	1.1	1.0	1.0	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE3	Auto/Off/Manual		M	A	A	A	A	A	A
	Current(A)	R	1.2	1.1	1.2	1.1	1.2	1.2	1.2
		S	1.2	1.2	1.1	1.1	1.1	1.1	1.2
		T	1.2	1.1	1.1	1.2	1.1	1.1	1.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE4	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.2	1.2	1.2	1.1	1.0	1.0	1.0
		S	1.2	1.1	1.1	1.1	1.1	1.0	1.0
		T	1.2	1.1	1.1	1.1	1.1	1.0	1.0
	Timer		N	N	N	N	1.0	1.0	1.0
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE5	Auto/Off/Manual		A	M	M	M	M	M	M
	Current(A)	R	1.2	1.2	1.1	1.1	1.1	1.1	1.1
		S	1.2	1.1	1.2	1.2	1.1	1.1	1.1
		T	1.2	1.1	1.2	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	1.0	1.1	1.1
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE6	Auto/Off/Manual		M	A	A	A	A	A	A
	Current(A)	R	1.2	1.2	1.2	1.1	1.1	1.1	1.1
		S	1.2	1.2	1.1	1.2	1.1	1.1	1.1
		T	1.2	1.1	1.1	1.1	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE7	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	8.1	8.1	8.1	8.2	8.1	8.1	8.1
		S	8.1	8.2	8.1	8.1	8.1	8.1	8.1
		T	8.1	8.1	8.2	8.1	8.2	8.1	8.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE8	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.2	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.2	1.1	1.2	1.2	1.1	1.1	1.1
		T	1.2	1.1	1.2	1.1	1.2	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
Date Check >>			14/3/65	15/3/65	16/3/65	17/3/65	18/3/65	19/3/65	20/3/65
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH.....

3/65

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.1	11.0	11.1	11.0	11.0	11.0
		S	11.0	11.1	11.0	11.1	11.1	11.1	11.0
		T	11.1	11.1	11.1	11.0	11.0	11.0	11.0
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
WWP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.1	11.0	11.0	11.0	11.0	11.0	11.0
		S	11.0	11.0	11.0	11.1	11.0	11.0	11.0
		T	11.0	11.1	11.1	11.1	11.0	11.0	11.0
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SLP1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	11.1	11.0	11.1	1.0	1.1	1.1	1.1
		S	11.1	11.1	11.1	1.1	1.1	1.1	1.1
		T	11.1	11.0	11.1	1.1	1.0	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
SLP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.1	11.0	11.1	11.0	11.0	11.0
		S	11.1	11.0	11.1	11.1	11.1	11.1	11.0
		T	11.0	11.1	11.1	11.0	11.1	11.1	11.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
DPI	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.1	7.1	7.1	7.0	7.1	7.1	7.0
		S	7.1	7.0	7.0	7.1	7.1	7.1	7.0
		T	7.0	7.1	7.1	7.1	7.0	7.1	7.0
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.0	1.1	1.1	1.1	1.1	1.0
		S	1.1	1.1	1.0	1.1	1.0	1.0	1.0
		T	1.1	1.0	1.1	1.1	1.0	1.0	1.0
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.2	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.2	1.1	1.1	1.1	1.1	1.1
		T	1.1	1.1	1.0	1.1	1.0	1.1	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.0	1.0	1.1	1.1	1.0	1.0	1.0
		S	1.0	1.1	1.1	1.1	1.0	1.0	1.0
		T	1.1	1.0	1.1	1.0	1.1	1.0	1.0
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.2	1.2	1.1	1.1	1.0	1.1	1.1
		S	1.1	1.0	1.1	1.1	1.1	1.1	1.1
		T	1.1	1.2	1.2	1.0	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.0	1.1	1.1	1.0	1.1	1.1	1.0
		S	1.1	1.0	1.1	1.1	1.0	1.0	1.0
		T	1.0	1.1	1.0	1.1	1.0	1.0	1.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.2	1.2	1.2	1.2	1.2	1.2	1.2
		S	1.1	1.2	1.1	1.1	1.1	1.2	1.2
		T	1.1	1.1	1.1	1.1	1.1	1.2	1.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE4	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.2	1.2	1.1	1.1	1.0	1.0	1.0
		S	1.1	1.1	1.1	1.0	1.0	1.0	1.0
		T	1.2	1.1	1.1	1.1	1.1	1.0	1.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE5	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.2	1.1	1.2	1.1	1.1	1.1
		S	1.2	1.1	1.2	1.1	1.1	1.1	1.1
		T	1.2	1.2	1.1	1.2	1.0	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE6	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.2	1.0	1.0	1.1	1.2	1.1	1.1
		T	1.1	1.0	1.0	1.0	1.1	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE7	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	8.1	8.1	8.1	8.0	8.1	8.1	8.1
		S	8.0	8.0	8.1	8.1	8.1	8.1	8.1
		T	8.0	8.0	8.1	8.1	8.0	8.1	8.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE8	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.2	1.1	1.2	1.2	1.1	1.1	1.1
		S	1.1	1.1	1.1	1.1	1.2	1.2	1.2
		T	1.1	1.2	1.1	1.2	1.1	1.1	1.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
Date Check >>			21/3/65	22/3/65	23/3/65	24/3/65	25/3/65	26/3/65	27/3/65
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH.....3/65

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M			
	Current(A)	R	11.0	11.0	11.0	11.0			
		S	11.0	11.1	11.1	11.1			
		T	11.1	11.1	11.1	11.1			
	Overload -Alarm		N	N	N	N			
	Latching relay control		N	N	N	N			
WWP2	Auto/Off/Manual		M	M	M	M			
	Current(A)	R	11.0	11.1	11.1	11.1			
		S	11.1	11.0	11.0	11.0			
		T	11.1	11.0	11.0	11.0			
	Overload -Alarm		N	N	N	N			
	Latching relay control		N	N	N	N			
SLP1	Auto/Off/Manual		A	A	A	A			
	Current(A)	R	11.0	11.1	11.1	11.1			
		S	11.0	11.0	11.0	11.0			
		T	11.1	11.1	11.1	11.1			
	Timer		N	N	N	N			
	Overload -Alarm		N	N	N	N			
SLP2	Auto/Off/Manual		M	M	M	M			
	Current(A)	R	11.1	11.0	11.0	11.0			
		S	11.1	11.0	11.0	11.0			
		T	11.0	11.1	11.1	11.1			
	Timer		N	N	N	N			
	Overload -Alarm		N	N	N	N			
DP1	Auto/Off/Manual		M	M	M	M			
	Current(A)	R	7.1	7.0	7.0	7.0			
		S	7.0	7.1	7.1	7.1			
		T	7.1	7.1	7.1	7.1			
	Overload -Alarm		N	N	N	N			
	Latching relay control		N	N	N	N			
DP2	Auto/Off/Manual		M	M	M	M			
	Current(A)	R	1.1	1.2	1.2	1.2			
		S	1.0	1.1	1.1	1.1			
		T	1.1	1.1	1.1	1.1			
	Overload -Alarm		N	N	N	N			
	Latching relay control		N	N	N	N			
SP1	Auto/Off/Manual		M	M	M	M			
	Current(A)	R	11.0	11.0	11.0	11.0			
		S	11.0	11.1	11.1	11.1			
		T	11.0	11.1	11.1	11.1			
	Overload -Alarm		N	N	N	N			
	Latching relay control		N	N	N	N			
SP2	Auto/Off/Manual		M	M	M	M			
	Current(A)	R	1.1	1.1	1.0	1.0			
		S	1.0	1.0	1.1	1.1			
		T	1.0	1.0	1.1	1.1			
	Overload -Alarm		N	N	N	N			
	Latching relay control		N	N	N	N			
Pilot Lamp			N	N	N	N			

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A			
	Current(A)	R	1.1	1.1	1.1	1.0			
		S	1.2	1.0	1.0	1.1			
		T	1.1	1.1	1.1	1.0			
	Timer		N	N	N	N			
	Overload -Alarm		N	N	N	N			
Pilot Lamp		N	N	N	N				
SE2	Auto/Off/Manual		M	M	M	M			
	Current(A)	R	1.1	1.0	1.0	1.0			
		S	1.0	1.1	1.1	1.1			
		T	1.0	1.1	1.1	1.0			
	Timer		N	N	N	N			
	Overload -Alarm		N	N	N	N			
Pilot Lamp		N	N	N	N				
SE3	Auto/Off/Manual		A	A	A	A			
	Current(A)	R	1.1	1.1	1.1	1.1			
		S	1.0	1.2	1.2	1.2			
		T	1.1	1.1	1.1	1.1			
	Timer		N	N	N	N			
	Overload -Alarm		N	N	N	N			
Pilot Lamp		N	N	N	N				
SE4	Auto/Off/Manual		M	M	M	M			
	Current(A)	R	1.1	1.2	1.2	1.2			
		S	1.0	1.1	1.1	1.1			
		T	1.0	1.1	1.1	1.1			
	Timer		N	N	N	N			
	Overload -Alarm		N	N	N	N			
Pilot Lamp		N	N	N	N				
SE5	Auto/Off/Manual		M	M	M	M			
	Current(A)	R	1.1	1.2	1.2	1.2			
		S	1.2	1.1	1.1	1.1			
		T	1.1	1.1	1.1	1.1			
	Timer		N	N	N	N			
	Overload -Alarm		N	N	N	N			
Pilot Lamp		N	N	N	N				
SE6	Auto/Off/Manual		A	A	A	A			
	Current(A)	R	1.1	1.1	1.1	1.1			
		S	1.0	1.1	1.1	1.1			
		T	1.1	1.2	1.2	1.2			
	Timer		N	N	N	N			
	Overload -Alarm		N	N	N	N			
Pilot Lamp		N	N	N	N				
SE7	Auto/Off/Manual		M	M	M	M			
	Current(A)	R	8.1	8.2	8.1	8.1			
		S	7.9	8.0	8.0	8.0			
		T	8.0	8.1	8.1	8.1			
	Timer		N	N	N	N			
	Overload -Alarm		N	N	N	N			
Pilot Lamp		N	N	N	N				
SE8	Auto/Off/Manual		M	M	M	M			
	Current(A)	R	1.2	1.2	1.1	1.2			
		S	1.1	1.1	1.1	1.1			
		T	1.1	1.1	1.1	1.1			
	Timer		N	N	N	N			
	Overload -Alarm		N	N	N	N			
Pilot Lamp		N	N	N	N				
Date Check >>			28/3/15	29/3/15	30/3/15	31/3/15	/	/	/
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

Remark:

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH..... 4/65

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual						M	M	M
	Current(A)	R					11.0	11.0	11.0
		S					11.0	11.0	11.0
		T					11.0	11.0	11.0
	Overload -Alarm						N	N	N
	Latching relay control						N	N	N
WWP2	Auto/Off/Manual						M	M	M
	Current(A)	R					11.1	11.1	11.1
		S					11.1	11.1	11.1
		T					11.1	11.1	11.1
	Overload -Alarm						N	N	N
	Latching relay control						N	N	N
SLP1	Auto/Off/Manual						A	A	A
	Current(A)	R					11.1	11.1	11.1
		S					11.0	11.0	11.0
		T					11.0	11.0	11.0
	Timer						N	N	N
	Overload -Alarm						N	N	N
SLP2	Auto/Off/Manual						M	M	M
	Current(A)	R					11.0	11.0	11.0
		S					11.0	11.0	11.0
		T					11.0	11.0	11.0
	Timer						N	N	N
	Overload -Alarm						N	N	N
DPI	Auto/Off/Manual						M	M	M
	Current(A)	R					7.0	7.0	7.0
		S					7.0	7.0	7.0
		T					7.0	7.0	7.0
	Overload -Alarm						N	N	N
	Latching relay control						N	N	N
DP2	Auto/Off/Manual						M	M	M
	Current(A)	R					1.1	1.1	1.1
		S					1.1	1.1	1.1
		T					1.1	1.1	1.1
	Overload -Alarm						N	N	N
	Latching relay control						N	N	N
SP1	Auto/Off/Manual						M	M	M
	Current(A)	R					11.0	11.0	11.0
		S					11.1	11.1	11.1
		T					11.1	11.1	11.0
	Overload -Alarm						N	N	N
	Latching relay control						N	N	N
SP2	Auto/Off/Manual						M	M	M
	Current(A)	R					1.0	1.0	1.0
		S					1.1	1.1	1.1
		T					1.1	1.1	1.1
	Overload -Alarm						N	N	N
	Latching relay control						N	N	N

Description / Day		Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual					A	A	A
	Current(A)	R				1.0	1.0	1.0
		S				1.1	1.1	1.1
		T				1.0	1.0	1.0
	Timer					N	N	N
	Overload -Alarm					N	N	N
SE2	Auto/Off/Manual					M	M	M
	Current(A)	R				1.0	1.0	1.0
		S				1.1	1.1	1.1
		T				1.0	1.0	1.0
	Timer					N	N	N
	Overload -Alarm					N	N	N
SE3	Auto/Off/Manual					A	A	A
	Current(A)	R				1.1	1.1	1.1
		S				1.2	1.2	1.2
		T				1.1	1.1	1.1
	Timer					N	N	N
	Overload -Alarm					N	N	N
SE4	Auto/Off/Manual					M	M	M
	Current(A)	R				1.2	1.2	1.2
		S				1.1	1.1	1.1
		T				1.1	1.1	1.1
	Timer					N	N	N
	Overload -Alarm					N	N	N
SE5	Auto/Off/Manual					M	M	M
	Current(A)	R				1.2	1.2	1.2
		S				1.1	1.1	1.1
		T				1.1	1.1	1.1
	Timer					N	N	N
	Overload -Alarm					N	N	N
SE6	Auto/Off/Manual					A	A	A
	Current(A)	R				1.1	1.1	1.1
		S				1.1	1.1	1.1
		T				1.2	1.2	1.2
	Timer					N	N	N
	Overload -Alarm					N	N	N
SE7	Auto/Off/Manual					M	M	M
	Current(A)	R				2.1	2.1	2.1
		S				2.0	2.0	2.0
		T				2.1	2.1	2.1
	Timer					N	N	N
	Overload -Alarm					N	N	N
SE8	Auto/Off/Manual					M	M	M
	Current(A)	R				1.2	1.2	1.2
		S				1.1	1.1	1.1
		T				1.1	1.1	1.2
	Timer					N	N	N
	Overload -Alarm					N	N	N
Date Check >>		/ /	/ /	/ /	/ /	1 / 6 / 15	2 / 6 / 16	3 / 6 / 16
Record By >>								
Recheck By >>								

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH 4/65

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.1	11.0	11.0	11.0	11.0	11.0
		S	11.0	11.1	11.0	11.0	11.0	11.1	11.0
		T	11.0	11.1	11.1	11.0	11.0	11.1	11.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
WWP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.1	11.0	11.1	11.1	11.1	11.0	11.0
		S	11.1	11.0	11.1	11.1	11.1	11.1	11.1
		T	11.1	11.0	11.0	11.1	11.1	11.1	11.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SLP1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	11.1	11.0	11.1	11.1	11.1	11.1	11.1
		S	11.0	11.1	11.1	11.1	11.1	11.2	11.2
		T	11.0	11.1	11.0	11.1	11.1	11.1	11.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
SLP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.1	11.0	11.0	11.0	11.0	11.1
		S	11.1	11.1	11.0	11.0	11.0	11.1	11.0
		T	11.0	11.0	11.1	11.0	11.0	11.0	11.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
DPI	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.0	7.1	7.0	7.0	7.0	7.0	7.0
		S	7.0	7.1	7.0	7.0	7.0	7.0	7.0
		T	7.1	7.0	7.1	7.1	7.0	7.0	7.0
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.2	1.0	1.0	1.0	3.0	5.0
		S	1.2	1.2	1.1	1.1	1.0	3.0	3.1
		T	1.2	1.0	1.1	1.1	1.0	3.1	3.2
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.1	11.0	11.0	11.0	1.2	1.2
		S	11.1	11.1	11.0	11.0	11.0	1.2	1.1
		T	11.0	11.0	11.1	11.1	11.0	1.2	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.0	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		T	1.1	1.0	1.0	1.1	1.1	1.1	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.0	1.1	1.0	1.0	1.0	6.3	6.3
		S	1.1	1.1	1.0	1.0	1.0	6.3	6.3
		T	1.0	1.0	1.1	1.0	1.0	6.4	6.2
	Timer		2	2	2	N	N	N	N
	Overload -Alarm		2	2	2	N	N	N	N
Pilot Lamp		2	2	2	N	N	N	N	2
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.0	1.0	1.1	1.1	1.1	6.1	6.1
		S	1.1	1.0	1.1	1.1	1.1	6.3	6.2
		T	1.0	1.1	1.0	1.1	1.1	6.1	6.2
	Timer		2	2	2	N	N	N	N
	Overload -Alarm		2	2	2	N	N	N	N
Pilot Lamp		2	2	2	N	N	N	N	2
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.1	1.2	1.1	1.1	1.1	6.1	6.1
		S	1.2	1.2	1.1	1.1	1.1	6.1	6.1
		T	1.1	1.1	1.2	1.1	1.1	6.2	6.1
	Timer		2	2	2	N	N	N	N
	Overload -Alarm		2	2	2	N	N	N	N
Pilot Lamp		2	2	2	N	N	N	N	2
SE4	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.2	1.1	1.2	1.2	1.2	6.1	6.1
		S	1.1	1.1	1.2	1.2	1.2	6.2	6.2
		T	1.1	1.2	1.0	1.2	1.2	6.1	6.2
	Timer		2	2	2	N	N	N	N
	Overload -Alarm		2	2	2	N	N	N	N
Pilot Lamp		2	2	2	N	N	N	N	2
SE5	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.2	1.1	1.2	1.2	1.2	6.1	6.1
		S	1.1	1.1	1.2	1.2	1.2	6.2	6.2
		T	1.1	1.2	1.1	1.2	1.2	6.1	6.1
	Timer		2	2	2	N	N	N	N
	Overload -Alarm		2	2	2	N	N	N	N
Pilot Lamp		2	2	2	N	N	N	N	2
SE6	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.1	1.2	1.1	1.1	1.1	7.1	7.1
		S	1.1	1.2	1.1	1.1	1.1	7.1	7.1
		T	1.2	1.1	1.2	1.1	1.1	7.0	7.2
	Timer		2	2	2	N	N	N	N
	Overload -Alarm		2	2	2	N	N	N	N
Pilot Lamp		2	2	2	N	N	N	N	2
SE7	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	8.0	8.1	8.0	8.0	8.0	7.1	7.1
		S	8.1	8.1	8.0	8.0	8.0	7.3	7.1
		T	8.1	8.0	8.1	8.0	8.0	7.0	7.2
	Timer		N	2	N	N	N	N	N
	Overload -Alarm		2	2	2	N	N	N	N
Pilot Lamp		2	2	2	N	N	N	N	2
SE8	Auto/Off/Manual		M	M	M	M	M	A	A
	Current(A)	R	1.2	1.1	1.0	1.1	1.1	8.1	8.1
		S	1.1	1.1	1.1	1.1	1.1	8.0	8.0
		T	1.0	1.2	1.1	1.1	1.1	8.1	8.1
	Timer		2	2	2	N	N	N	N
	Overload -Alarm		2	2	2	N	N	N	N
Pilot Lamp		2	2	2	N	N	N	N	2
Date Check >>			A 'A '25	B 'A '26	b 'A '65	y 'A '66	8 'A '65	9 'A '65	10 'A '65
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH.....4/65

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.0	11.0	11.0	11.1	11.0	11.0
		S	11.0	11.1	11.0	11.0	11.1	11.0	11.0
		T	11.0	11.0	11.0	11.0	11.1	11.1	11.0
	Overload -Alarm		2	2	N	N	N	2	N
	Latching relay control		2	2	N	N	N	2	N
WWP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.1	11.1	11.1	11.1	11.0	11.1	11.1
		S	11.0	11.1	11.1	11.1	11.0	11.1	11.0
		T	11.0	11.1	11.1	11.1	11.0	11.0	11.1
	Overload -Alarm		2	2	N	N	N	2	N
	Latching relay control		2	2	N	N	N	2	N
SLP1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	11.0	11.1	11.1	11.1	11.1	11.0	11.0
		S	11.0	11.0	11.1	11.0	11.0	11.0	11.1
		T	11.1	11.0	11.1	11.0	11.1	11.1	11.1
	Timer		2	2	N	N	N	2	N
	Overload -Alarm		2	2	N	N	N	2	N
SLP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.1	11.1	11.0	11.1	11.1	11.0	11.0
		S	11.1	11.1	11.1	11.0	11.1	11.0	11.1
		T	11.0	11.1	11.0	11.1	11.1	11.1	11.1
	Timer		2	2	N	N	N	2	N
	Overload -Alarm		2	2	N	N	N	2	N
DP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.0	7.0	7.0	7.0	7.0	7.1	7.1
		S	7.0	7.0	7.0	7.0	7.0	7.1	7.0
		T	7.1	7.1	7.0	7.0	7.0	7.0	7.1
	Overload -Alarm		2	2	N	N	N	2	N
	Latching relay control		2	2	N	N	N	2	N
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	3.4	3.1	3.1	3.1	3.1	3.0	3.1
		S	3.0	3.3	3.1	3.1	3.1	3.1	3.0
		T	3.4	3.3	3.1	3.1	3.1	3.1	3.0
	Overload -Alarm		2	2	N	N	N	2	N
	Latching relay control		2	2	N	N	N	2	N
SP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.0	1.0
		S	1.1	1.1	1.1	1.1	1.1	1.0	1.0
		T	1.1	1.1	1.1	1.1	1.1	1.1	1.1
	Overload -Alarm		2	2	N	N	N	2	N
	Latching relay control		2	2	N	N	N	2	N
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.0	1.0
		S	1.1	1.1	1.1	1.1	1.1	1.0	1.1
		T	1.0	1.1	1.1	1.1	1.1	1.1	1.0
	Overload -Alarm		2	2	N	N	N	2	N
	Latching relay control		2	2	N	N	N	2	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.3	6.3	6.3	6.3	6.3	6.3	6.2
		S	6.3	6.2	6.3	6.3	6.3	6.2	6.3
		T	6.1	6.4	6.3	6.3	6.3	6.3	6.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.1	6.1	6.1	6.1	6.1	6.0	6.1
		S	6.2	6.1	6.1	6.1	6.1	6.0	6.0
		T	6.1	6.1	6.1	6.1	6.1	6.1	6.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.1	6.1	6.1	6.1	6.1	6.0	6.1
		S	6.2	6.2	6.1	6.1	6.1	6.0	6.0
		T	6.1	6.1	6.1	6.1	6.1	6.1	6.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
SE4	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.1	6.1	6.1	6.1	6.1	6.0	6.0
		S	6.1	6.1	6.1	6.1	6.1	6.0	6.1
		T	6.2	6.2	6.1	6.1	6.1	6.0	6.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
SE5	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.1	6.1	6.1	6.1	6.1	6.0	6.0
		S	6.1	6.1	6.1	6.1	6.1	6.0	6.1
		T	6.2	6.2	6.1	6.1	6.1	6.0	6.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
SE6	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	7.1	7.1	7.1	7.1	7.1	7.0	7.0
		S	7.1	7.0	7.0	7.0	7.0	7.0	7.0
		T	7.0	7.1	7.1	7.1	7.0	7.1	7.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
SE7	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.1	7.1	7.1	7.0	7.0	7.1	7.1
		S	7.0	7.0	7.0	7.1	7.1	7.1	7.1
		T	7.1	7.1	7.1	7.0	7.0	7.0	7.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
SE8	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	8.0	8.0	8.0	8.0	8.0	8.1	8.1
		S	8.1	8.1	8.0	8.0	8.0	8.0	8.0
		T	8.1	8.1	8.0	8.0	8.0	8.0	8.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Date Check >>			11/4/65	12/4/65	13/4/65	14/4/65	15/4/65	16/4/65	17/4/65
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH..... 4/65

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.1	11.1	11.1	11.1	11.0	11.1	11.0
		S	11.1	11.1	11.1	11.2	11.2	11.2	11.1
		T	11.1	11.2	11.2	11.1	11.1	11.0	11.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
WWP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.0	11.0	11.1	11.1	11.2	11.2
		S	11.1	11.0	11.0	11.0	11.1	11.2	11.1
		T	11.0	11.1	11.1	11.0	11.0	11.1	11.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SLP1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	11.0	11.0	11.0	11.0	11.0	11.0	11.0
		S	11.1	11.0	11.1	11.1	11.1	11.1	11.0
		T	11.0	11.1	11.1	11.1	11.1	11.1	11.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
SLP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.0	11.0	11.1	11.0	11.0	11.1
		S	11.0	11.1	11.1	11.0	11.0	11.1	11.0
		T	11.1	11.0	11.1	11.1	11.1	11.1	11.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
DP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.0	7.0	7.0	7.0	7.1	7.1	7.2
		S	7.0	7.1	7.1	7.2	7.2	7.2	7.1
		T	7.1	7.0	7.0	7.0	7.1	7.1	7.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	3.1	3.0	3.0	3.1	3.1	3.1	3.0
		S	3.0	3.1	3.1	3.1	3.1	3.0	3.1
		T	3.1	3.1	3.1	3.1	3.0	3.0	3.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.0	1.1	1.1	1.0	1.0	1.0	1.0
		S	1.1	1.0	1.0	1.1	1.1	1.1	1.0
		T	1.0	1.0	1.1	1.1	1.1	1.0	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.0	1.1	1.2	1.2	1.2	1.2
		S	1.0	1.0	1.1	1.2	1.1	1.1	1.1
		T	1.0	1.1	1.0	1.0	1.0	1.1	1.2
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.2	6.2	6.2	6.1	6.2	6.1	6.2
		S	6.1	6.1	6.1	6.1	6.1	6.1	6.1
		T	6.2	6.1	6.1	6.1	6.1	6.1	6.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.0	6.1	6.1	6.2	6.2	6.1	6.0
		S	6.1	6.0	6.0	6.0	6.0	6.0	6.1
		T	6.1	6.1	6.1	6.1	6.1	6.1	6.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.1	6.1	6.1	6.1	6.0	6.1	6.0
		S	6.0	6.1	6.1	6.0	6.1	6.0	6.0
		T	6.1	6.1	6.0	6.0	6.1	6.1	6.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE4	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.0	6.0	6.1	6.1	6.0	6.1	6.1
		S	6.0	6.1	6.0	6.1	6.1	6.0	6.1
		T	6.0	6.1	6.1	6.0	6.1	6.1	6.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE5	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.1	6.1	6.1	6.1	6.1	6.0	6.1
		S	6.0	6.0	6.0	6.1	6.0	6.1	6.0
		T	6.1	6.1	6.1	6.1	6.1	6.1	6.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE6	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	7.0	7.1	7.2	7.2	7.1	7.1	7.2
		S	7.1	7.1	7.2	7.1	7.1	7.1	7.1
		T	7.0	7.1	7.1	7.1	7.0	7.0	7.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE7	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.1	7.1	7.1	7.2	7.2	7.1	7.1
		S	7.1	7.2	7.2	7.1	7.1	7.1	7.1
		T	7.1	7.1	7.1	7.2	7.1	7.1	7.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE8	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	8.1	8.0	8.1	8.0	8.1	8.0	8.0
		S	8.0	8.1	8.1	8.1	8.0	8.1	8.1
		T	8.1	8.1	8.0	8.1	8.0	8.1	8.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
Date Check >>			18/4/64	19/4/64	20/4/65	21/4/65	22/4/65	23/4/65	24/4/65
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH..... 4 / 65

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	
	Current(A)	R	11.0	11.0	11.1	11.1	11.1	11.1	
		S	11.1	11.0	11.1	11.1	11.1	11.1	
		T	11.1	11.0	11.1	11.1	11.1	11.1	
	Overload -Alarm		2	N	N	N	N	N	
	Latching relay control		2	N	N	N	N	N	
	Pilot Lamp		2	N	N	N	N	N	
WWP2	Auto/Off/Manual		M	M	M	M	M	N	
	Current(A)	R	11.2	11.1	11.1	11.0	11.0	11.0	
		S	11.1	11.1	11.1	11.0	11.0	11.0	
		T	11.1	11.1	11.1	11.0	11.0	11.0	
	Overload -Alarm		2	N	N	N	N	N	
	Latching relay control		2	N	N	N	N	N	
	Pilot Lamp		2	N	N	N	N	N	
SLP1	Auto/Off/Manual		A	A	A	A	A	A	
	Current(A)	R	11.0	11.0	11.0	11.0	11.0	11.0	
		S	11.0	11.0	11.0	11.0	11.0	11.0	
		T	11.1	11.1	11.1	11.0	11.0	11.0	
	Timer		2	N	N	N	N	N	
	Overload -Alarm		2	N	N	N	N	N	
	Pilot Lamp		2	N	N	N	N	N	
SLP2	Auto/Off/Manual		M	M	M	M	M	M	
	Current(A)	R	11.1	11.1	11.1	11.1	11.1	11.1	
		S	11.0	11.0	11.0	11.1	11.1	11.1	
		T	11.0	11.0	11.0	11.1	11.1	11.1	
	Timer		2	N	N	N	N	N	
	Overload -Alarm		2	N	N	N	N	N	
	Pilot Lamp		2	N	N	N	N	N	
DPI	Auto/Off/Manual		M	M	M	M	M	M	
	Current(A)	R	7.2	7.1	7.1	7.1	7.1	7.1	
		S	7.1	7.1	7.1	7.1	7.1	7.1	
		T	7.1	7.1	7.1	7.1	7.1	7.1	
	Overload -Alarm		2	N	N	N	N	N	
	Latching relay control		2	N	N	N	N	N	
	Pilot Lamp		2	N	N	N	N	N	
DP2	Auto/Off/Manual		M	M	M	M	M	M	
	Current(A)	R	3.0	3.0	3.0	3.0	3.0	3.0	
		S	3.1	3.0	3.0	3.0	3.0	3.0	
		T	3.1	3.0	3.0	3.0	3.0	3.0	
	Overload -Alarm		2	N	N	N	N	N	
	Latching relay control		2	N	N	N	N	N	
	Pilot Lamp		2	N	N	N	N	N	
SP1	Auto/Off/Manual		M	M	M	M	M	M	
	Current(A)	R	1.0	1.0	1.0	1.0	1.0	1.0	
		S	1.0	1.0	1.0	1.0	1.0	1.0	
		T	1.1	1.0	1.0	1.0	1.0	1.0	
	Overload -Alarm		2	N	N	N	N	N	
	Latching relay control		2	N	N	N	N	N	
	Pilot Lamp		2	N	N	N	N	N	
SP2	Auto/Off/Manual		M	M	M	M	M	M	
	Current(A)	R	1.2	1.1	1.1	1.1	1.1	1.1	
		S	1.1	1.1	1.1	1.1	1.1	1.1	
		T	1.1	1.1	1.1	1.1	1.1	1.1	
	Overload -Alarm		2	N	N	N	N	N	
	Latching relay control		2	N	N	N	N	N	
	Pilot Lamp		2	N	N	N	N	N	

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	
	Current(A)	R	6.2	6.1	6.1	6.1	6.1	6.1	
		S	6.1	6.1	6.1	6.1	6.1	6.1	
		T	6.1	6.1	6.1	6.1	6.1	6.1	
	Timer		N	N	N	N	N	N	
	Overload -Alarm		N	N	N	N	N	N	
Pilot Lamp		N	N	N	N	N	N		
SE2	Auto/Off/Manual		M	M	M	M	M	M	
	Current(A)	R	6.0	6.1	6.1	6.1	6.1	6.1	
		S	6.1	6.1	6.1	6.1	6.1	6.1	
		T	6.1	6.1	6.1	6.1	6.1	6.1	
	Timer		N	N	N	N	N	N	
	Overload -Alarm		N	N	N	N	N	N	
Pilot Lamp		N	N	N	N	N	N		
SE3	Auto/Off/Manual		A	A	A	A	A	A	
	Current(A)	R	6.0	6.0	6.0	6.0	6.0	6.0	
		S	6.0	6.0	6.0	6.0	6.0	6.0	
		T	6.1	6.0	6.0	6.0	6.0	6.0	
	Timer		N	N	N	N	N	N	
	Overload -Alarm		N	N	N	N	N	N	
Pilot Lamp		N	N	N	N	N	N		
SE4	Auto/Off/Manual		M	M	M	M	M	M	
	Current(A)	R	6.1	6.1	6.1	6.1	6.1	6.1	
		S	6.1	6.1	6.1	6.1	6.1	6.1	
		T	6.2	6.1	6.1	6.1	6.1	6.1	
	Timer		N	N	N	N	N	N	
	Overload -Alarm		N	N	N	N	N	N	
Pilot Lamp		N	N	N	N	N	N		
SE5	Auto/Off/Manual		M	M	M	M	M	M	
	Current(A)	R	6.1	6.1	6.1	6.1	6.0	6.0	
		S	6.0	6.0	6.0	6.0	6.0	6.0	
		T	6.0	6.0	6.0	6.0	6.0	6.0	
	Timer		N	N	N	N	N	N	
	Overload -Alarm		N	N	N	N	N	N	
Pilot Lamp		N	N	N	N	N	N		
SE6	Auto/Off/Manual		A	A	A	A	A	A	
	Current(A)	R	7.0	7.0	7.0	7.0	7.0	7.0	
		S	7.1	7.0	7.0	7.0	7.0	7.0	
		T	7.1	7.0	7.0	7.0	7.0	7.0	
	Timer		N	N	N	N	N	N	
	Overload -Alarm		N	N	N	N	N	N	
Pilot Lamp		N	N	N	N	N	N		
SE7	Auto/Off/Manual		M	M	M	M	M	M	
	Current(A)	R	7.1	7.1	7.1	7.1	7.1	7.1	
		S	7.1	7.1	7.1	7.1	7.1	7.1	
		T	7.0	7.1	7.1	7.1	7.1	7.1	
	Timer		N	N	N	N	N	N	
	Overload -Alarm		N	N	N	N	N	N	
Pilot Lamp		N	N	N	N	N	N		
SE8	Auto/Off/Manual		A	A	A	A	A	A	
	Current(A)	R	8.0	8.0	8.0	8.0	8.0	8.0	
		S	8.1	8.0	8.0	8.0	8.0	8.0	
		T	8.1	8.0	8.0	8.0	8.0	8.0	
	Timer		N	N	N	N	N	N	
	Overload -Alarm		N	N	N	N	N	N	
Pilot Lamp		N	N	N	N	N	N		
Date Check >>			25/4/15	26/4/15	27/4/15	28/4/15	29/4/15	30/4/15	/ /
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH..... 5/65

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual								M
	Current(A)	R							11.1
		S							11.1
		T							11.0
	Overload -Alarm								N
	Latching relay control								N
	Pilot Lamp								N
WWP2	Auto/Off/Manual								M
	Current(A)	R							11.0
		S							11.1
		T							11.1
	Overload -Alarm								N
	Latching relay control								N
	Pilot Lamp								N
SLP1	Auto/Off/Manual								A
	Current(A)	R							11.0
		S							11.1
		T							11.0
	Timer								N
	Overload -Alarm								N
	Pilot Lamp								N
SLP2	Auto/Off/Manual								M
	Current(A)	R							11.0
		S							11.1
		T							11.1
	Timer								N
	Overload -Alarm								N
	Pilot Lamp								N
DP1	Auto/Off/Manual								M
	Current(A)	R							3.0
		S							3.1
		T							3.1
	Overload -Alarm								N
	Latching relay control								N
	Pilot Lamp								N
DP2	Auto/Off/Manual								M
	Current(A)	R							3.0
		S							3.1
		T							3.1
	Overload -Alarm								N
	Latching relay control								N
	Pilot Lamp								N
SP1	Auto/Off/Manual								M
	Current(A)	R							1.0
		S							1.1
		T							1.0
	Overload -Alarm								N
	Latching relay control								N
	Pilot Lamp								N
SP2	Auto/Off/Manual								M
	Current(A)	R							1.1
		S							1.1
		T							1.1
	Overload -Alarm								N
	Latching relay control								N
	Pilot Lamp								N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual								A
	Current(A)	R							6.1
		S							6.0
		T							6.1
	Timer								N
	Overload -Alarm								N
Pilot Lamp									N
SE2	Auto/Off/Manual								M
	Current(A)	R							6.1
		S							6.0
		T							6.0
	Timer								N
	Overload -Alarm								N
Pilot Lamp									N
SE3	Auto/Off/Manual								A
	Current(A)	R							6.1
		S							6.0
		T							6.0
	Timer								N
	Overload -Alarm								N
Pilot Lamp									N
SE4	Auto/Off/Manual								M
	Current(A)	R							6.1
		S							6.1
		T							6.0
	Timer								N
	Overload -Alarm								N
Pilot Lamp									N
SE5	Auto/Off/Manual								M
	Current(A)	R							6.0
		S							6.0
		T							6.1
	Timer								N
	Overload -Alarm								N
Pilot Lamp									N
SE6	Auto/Off/Manual								A
	Current(A)	R							7.1
		S							7.0
		T							7.0
	Timer								N
	Overload -Alarm								N
Pilot Lamp									N
SE7	Auto/Off/Manual								A
	Current(A)	R							7.1
		S							7.1
		T							7.0
	Timer								N
	Overload -Alarm								N
Pilot Lamp									N
SE8	Auto/Off/Manual								A
	Current(A)	R							8.0
		S							8.0
		T							8.1
	Timer								N
	Overload -Alarm								N
Pilot Lamp									N
Date Check >>			/ /	/ /	/ /	/ /	/ /	/ /	1/5/85
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

Remark.....

DAILY REPORT

MONTH 5/65

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.1	11.1	11.1	11.0	11.1	11.0
		S	11.1	11.1	11.1	11.1	11.0	11.1	11.0
		T	11.1	11.1	11.0	11.1	11.1	11.0	11.0
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
WWP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.1	11.1	11.0	11.1	11.1	11.0	11.0
		S	11.1	11.1	11.1	11.1	11.2	11.1	11.1
		T	11.0	11.1	11.1	11.0	11.1	11.0	11.0
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SLP1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	11.1	11.1	11.1	11.1	11.1	11.0	11.0
		S	11.1	11.1	11.1	11.1	11.2	11.1	11.1
		T	11.1	11.1	11.1	11.1	11.2	11.1	11.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SLP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.0	11.1	11.0	11.1	11.0	11.0
		S	11.1	11.1	11.1	11.1	11.1	11.0	11.0
		T	11.0	11.0	11.1	11.1	11.1	11.0	11.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
DPI	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.1	7.1	7.1	7.1	7.1	7.0	7.0
		S	7.1	7.1	7.1	7.1	7.1	7.1	7.0
		T	7.1	7.1	7.1	7.1	7.1	7.1	7.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	3.1	3.1	3.0	3.1	3.1	3.1	3.1
		S	3.0	3.0	3.1	3.0	3.0	3.1	3.1
		T	3.1	3.1	3.1	3.1	3.1	3.0	3.0
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SPI	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.0	1.1	1.1
		S	1.0	1.0	1.1	1.0	1.1	1.0	1.1
		T	1.1	1.1	1.1	1.1	1.0	1.1	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.0	1.0	1.1	1.1	1.1	1.1	1.0
		T	1.1	1.1	1.0	1.1	1.0	1.0	1.0
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.1	6.1	6.1	6.1	6.0	6.1	6.1
		S	6.1	6.1	6.1	6.1	6.1	6.1	6.1
		T	6.0	6.0	6.1	6.0	6.1	6.1	6.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.0	6.0	6.1	6.1	6.0	6.1	6.1
		S	6.1	6.1	6.0	6.0	6.1	6.1	6.1
		T	6.1	6.1	6.1	6.1	6.1	6.0	6.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE3	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		-	-	-	-	-	-	-
	Overload -Alarm		-	-	-	-	-	-	-
Pilot Lamp			-	-	-	-	-	-	-
SE4	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.1	6.1	6.1	6.1	6.1	6.1	6.1
		S	6.1	6.0	6.1	6.1	6.0	6.1	6.1
		T	6.0	6.1	6.1	6.0	6.1	6.1	6.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE5	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.0	6.0	6.1	6.1	6.1	6.1	6.1
		S	6.1	6.1	6.1	6.1	6.0	6.1	6.0
		T	6.0	6.0	6.1	6.0	6.1	6.0	6.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE6	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	7.1	7.1	7.1	7.1	7.1	7.0	7.0
		S	7.1	7.1	7.0	7.1	7.1	7.1	7.1
		T	7.1	7.1	7.1	7.0	7.1	7.1	7.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE7	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.1	7.1	7.1	7.1	7.0	7.1	7.1
		S	7.1	7.1	7.1	7.1	7.1	7.0	7.0
		T	7.1	7.1	7.1	7.1	7.0	7.1	7.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
SE8	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	8.1	8.1	8.1	8.0	8.0	8.1	8.1
		S	8.1	8.1	8.1	8.1	8.0	8.0	8.0
		T	8.1	8.1	8.0	8.1	8.1	8.1	8.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	N
Date Check >>			9/5/16	9/5/16	9/5/16	9/5/16	9/5/16	9/5/16	9/5/16
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

Remark 12/5/16 SE 3 overload

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH 5/65

WASTE WATERTREATMENT PLANT

TIME

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.1	11.1	11.1	11.0	11.1	11.0
		S	11.0	11.0	11.1	11.2	11.1	11.2	11.2
		T	11.0	11.1	11.1	11.0	11.0	11.0	11.0
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
WWP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.1	11.0	11.1	11.2	11.2	11.1
		S	11.1	11.0	11.0	11.0	11.0	11.1	11.2
		T	11.0	11.1	11.0	11.0	11.2	11.0	11.2
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SLP1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	11.0	11.1	11.0	11.1	1.0	1.1	1.1
		S	11.1	11.0	11.1	11.1	1.1	1.1	1.2
		T	11.1	11.1	11.0	1.2	1.2	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SLP2	Auto/Off/Manual		M	M	M	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		-	-	-	-	-	-	-
	Overload -Alarm		-	-	-	-	-	-	-
	Pilot Lamp		-	-	-	-	-	-	-
DPI	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.0	7.0	7.0	7.0	7.1	7.1	7.1
		S	7.0	7.0	7.0	7.0	7.2	7.1	7.0
		T	7.0	7.0	7.0	7.1	7.1	7.2	7.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	3.1	3.1	3.1	3.1	3.2	3.1	3.0
		S	3.1	3.1	3.1	3.0	3.0	3.0	3.1
		T	3.1	3.1	3.1	3.1	3.1	3.1	3.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.2	1.1	1.2	1.1
		S	1.1	1.1	1.1	1.1	1.2	1.1	1.2
		T	1.1	1.1	1.1	1.1	1.1	1.1	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.0	1.1	1.0
		S	1.0	1.0	1.1	1.1	1.0	1.1	1.1
		T	1.1	1.1	1.1	1.2	1.2	1.1	1.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.1	6.1	6.1	6.1	6.0	6.1	6.2
		S	6.1	6.1	6.1	6.0	6.1	6.2	6.1
		T	6.1	6.1	6.1	6.1	6.1	6.1	6.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.1	6.1	6.1	6.0	6.1	6.0	6.1
		S	6.1	6.1	6.1	6.1	6.2	6.2	6.2
		T	6.1	6.1	6.1	6.1	6.1	6.1	6.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE3	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		-	-	-	-	-	-	-
	Overload -Alarm		-	-	-	-	-	-	-
Pilot Lamp		-	-	-	-	-	-	-	
SE4	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.1	6.1	6.1	6.0	6.1	6.0	6.1
		S	6.1	6.1	6.1	6.1	6.1	6.1	6.2
		T	6.1	6.1	6.1	6.1	6.0	6.1	6.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE5	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.1	6.1	6.1	6.3	6.2	6.2	6.2
		S	6.1	6.1	6.1	6.2	6.0	6.1	6.1
		T	6.1	6.1	6.1	6.0	6.2	6.2	6.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE6	Auto/Off/Manual		A	A	A	A	OFF O/L	A	A
	Current(A)	R	7.0	7.0	7.0	7.1	-	7.1	7.0
		S	7.0	7.0	7.0	7.0	-	7.0	7.1
		T	7.0	7.0	7.0	6.9	-	7.1	7.1
	Timer		N	N	N	N	-	N	N
	Overload -Alarm		N	N	N	N	-	N	N
Pilot Lamp		N	N	N	N	UN	N	N	
SE7	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.1	7.1	7.1	7.2	7.1	7.1	7.2
		S	7.1	7.1	7.1	7.1	7.1	7.2	7.1
		T	7.1	7.1	7.1	7.1	7.0	7.1	7.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SE8	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	8.0	8.0	8.0	8.1	8.1	8.0	8.1
		S	8.0	8.0	8.0	8.0	8.0	8.1	8.0
		T	8.0	8.0	8.0	8.1	8.0	8.1	8.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
Date Check >>			9 / 5 / 65	10 / 5 / 65	11 / 5 / 65	12 / 5 / 65	13 / 5 / 65	14 / 5 / 65	15 / 5 / 65
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH..... 5/65

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.0	11.0	11.0	11.1	11.0	11.0	11.0
		S	11.0	11.0	11.0	11.0	11.0	11.0	11.0
		T	11.0	11.0	11.0	11.0	11.0	11.0	11.0
	Overload - Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
WWP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.1	11.1	11.1	11.0	11.1	11.1	11.1
		S	11.1	11.1	11.1	11.1	11.1	11.1	11.1
		T	11.1	11.1	11.1	11.1	11.1	11.1	11.1
	Overload - Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SLP1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.0	1.0
		S	1.1	1.1	1.1	1.1	1.1	1.0	1.0
		T	1.1	1.1	1.1	1.1	1.1	1.0	1.0
	Timer		N	N	N	N	N	N	N
	Overload - Alarm		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SLP2	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		-	-	-	-	-	-	-
	Overload - Alarm		-	-	-	-	-	-	-
	Pilot Lamp		-	-	-	-	-	-	-
DP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	3.1	3.1	3.1	3.1	3.1	3.0	3.0
		S	3.1	3.1	3.1	3.1	3.1	3.0	3.0
		T	3.1	3.1	3.1	3.1	3.1	3.0	3.0
	Overload - Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	3.0	3.0	3.0	3.0	3.0	3.0	3.0
		S	3.0	3.0	3.0	3.0	3.0	3.0	3.0
		T	3.0	3.0	3.0	3.0	3.0	3.0	3.0
	Overload - Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.0	1.0
		S	1.1	1.1	1.1	1.1	1.1	1.0	1.0
		T	1.1	1.1	1.1	1.1	1.1	1.0	1.0
	Overload - Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.0	1.0
		S	1.1	1.1	1.1	1.1	1.1	1.0	1.0
		T	1.1	1.1	1.1	1.1	1.1	1.0	1.0
	Overload - Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
	Pilot Lamp		N	N	N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.1	6.1	6.1	6.1	6.1	6.0	6.0
		S	6.1	6.1	6.1	6.1	6.1	6.0	6.0
		T	6.1	6.1	6.1	6.1	6.1	6.0	6.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.1	6.1	6.1	6.1	6.1	6.0	6.0
		S	6.1	6.1	6.1	6.1	6.1	6.0	6.0
		T	6.1	6.1	6.1	6.1	6.1	6.0	6.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE3	Auto/Off/Manual		OFF	OFF	OFF	OFF	OFF	OFF	OFF
	Current(A)	R	-	-	-	-	-	-	-
		S	-	-	-	-	-	-	-
		T	-	-	-	-	-	-	-
	Timer		-	-	-	-	-	-	-
	Overload -Alarm		-	-	-	-	-	-	-
Pilot Lamp			-	-	-	-	-	-	
SE4	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.1	6.1	6.1	6.1	6.1	6.0	6.0
		S	6.1	6.1	6.1	6.1	6.1	6.0	6.0
		T	6.1	6.1	6.1	6.1	6.1	6.0	6.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE5	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.1	6.1	6.1	6.1	6.1	6.0	6.0
		S	6.1	6.1	6.1	6.1	6.1	6.0	6.0
		T	6.1	6.1	6.1	6.1	6.1	6.0	6.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE6	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	7.1	7.1	7.1	7.1	7.1	7.0	7.0
		S	7.1	7.1	7.1	7.1	7.1	7.0	7.0
		T	7.1	7.1	7.1	7.1	7.1	7.0	7.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE7	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.2	7.2	7.2	7.2	7.2	7.0	7.0
		S	7.2	7.2	7.2	7.2	7.2	7.0	7.0
		T	7.2	7.2	7.2	7.2	7.2	7.0	7.0
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
SE8	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	8.1	8.1	8.1	8.1	8.1	8.1	8.1
		S	8.1	8.1	8.1	8.1	8.1	8.0	8.1
		T	8.1	8.1	8.1	8.1	8.1	8.0	8.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp			N	N	N	N	N	N	
Date Check >>									
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=High level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH 5/65

WASTE WATERTREATMENT PLANT

TIME

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual								
	Current(A)	R							
		S							
		T							
	Overload -Alarm								
	Latching relay control								
	Pilot Lamp								
WWP2	Auto/Off/Manual								
	Current(A)	R							
		S							
		T							
	Overload -Alarm								
	Latching relay control								
	Pilot Lamp								
SLP1	Auto/Off/Manual								
	Current(A)	R							
		S							
		T							
	Timer								
	Overload -Alarm								
	Pilot Lamp								
SLP2	Auto/Off/Manual								
	Current(A)	R							
		S							
		T							
	Timer								
	Overload -Alarm								
	Pilot Lamp								
DP1	Auto/Off/Manual								
	Current(A)	R							
		S							
		T							
	Overload -Alarm								
	Latching relay control								
	Pilot Lamp								
DP2	Auto/Off/Manual								
	Current(A)	R							
		S							
		T							
	Overload -Alarm								
	Latching relay control								
	Pilot Lamp								
SP1	Auto/Off/Manual								
	Current(A)	R							
		S							
		T							
	Overload -Alarm								
	Latching relay control								
	Pilot Lamp								
SP2	Auto/Off/Manual								
	Current(A)	R							
		S							
		T							
	Overload -Alarm								
	Latching relay control								
	Pilot Lamp								

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R							
		S							
		T							
	Timer		22	22	22	22	22	22	22
Overload -Alarm									
Pilot Lamp									
SE2	Auto/Off/Manual		3	3	3	3	3	3	3
	Current(A)	R							
		S							
		T							
	Timer		22	22	22	22	22	22	22
Overload -Alarm									
Pilot Lamp									
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R							
		S							
		T							
	Timer		22	22	22	22	22	22	22
Overload -Alarm									
Pilot Lamp									
SE4	Auto/Off/Manual		3	3	3	3	3	3	3
	Current(A)	R							
		S							
		T							
	Timer		22	22	22	22	22	22	22
Overload -Alarm									
Pilot Lamp									
SE5	Auto/Off/Manual		3	3	3	3	3	3	3
	Current(A)	R							
		S							
		T							
	Timer		22	22	22	22	22	22	22
Overload -Alarm									
Pilot Lamp									
SE6	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R							
		S							
		T							
	Timer		22	22	22	22	22	22	22
Overload -Alarm									
Pilot Lamp									
SE7	Auto/Off/Manual		3	3	3	3	3	3	3
	Current(A)	R							
		S							
		T							
	Timer		22	22	22	22	22	22	22
Overload -Alarm									
Pilot Lamp									
SE8	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R							
		S							
		T							
	Timer		22	22	22	22	22	22	22
Overload -Alarm									
Pilot Lamp									
Date Check >>			23/5/65	24/5/65	25/5/65	26/5/65	27/5/65	28/5/65	29/5/65
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH.....5/66

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M					
	Current(A)	R	11.0	11.0					
		S	11.0	11.0					
		T	11.0	11.0					
	Overload -Alarm		N	N					
	Latching relay control		N	N					
WWP2	Auto/Off/Manual		M	M					
	Current(A)	R	11.1	11.1					
		S	11.1	11.1					
		T	11.1	11.1					
	Overload -Alarm		N	N					
	Latching relay control		N	N					
SLP1	Auto/Off/Manual		A	A					
	Current(A)	R	1.1	1.1					
		S	1.1	1.1					
		T	1.1	1.1					
	Timer		N	N					
	Overload -Alarm		N	N					
SLP2	Auto/Off/Manual		M	M					
	Current(A)	R	1.2	1.2					
		S	1.2	1.2					
		T	1.2	1.2					
	Timer		N	N					
	Overload -Alarm		N	N					
DPI	Auto/Off/Manual		M	M					
	Current(A)	R	2.1	2.1					
		S	2.1	2.1					
		T	2.1	2.1					
	Overload -Alarm		N	N					
	Latching relay control		N	N					
DP2	Auto/Off/Manual		M	M					
	Current(A)	R	3.0	3.0					
		S	3.0	3.0					
		T	3.0	3.0					
	Overload -Alarm		N	N					
	Latching relay control		N	N					
SP1	Auto/Off/Manual		M	M					
	Current(A)	R	1.1	1.1					
		S	1.1	1.1					
		T	1.1	1.1					
	Overload -Alarm		N	N					
	Latching relay control		N	N					
SP2	Auto/Off/Manual		M	M					
	Current(A)	R	1.1	1.1					
		S	1.1	1.1					
		T	1.1	1.1					
	Overload -Alarm		N	N					
	Latching relay control		N	N					
Pilot Lamp			N	N					

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A					
	Current(A)	R	6.1	6.1					
		S	6.1	6.1					
		T	6.1	6.1					
	Timer		N	N					
	Overload -Alarm		N	N					
Pilot Lamp			N	N					
SE2	Auto/Off/Manual		M	M					
	Current(A)	R	6.3	6.3					
		S	6.3	6.3					
		T	6.3	6.3					
	Timer		N	N					
	Overload -Alarm		N	N					
Pilot Lamp			N	N					
SE3	Auto/Off/Manual		A	A					
	Current(A)	R	6.3	6.3					
		S	6.3	6.3					
		T	6.3	6.3					
	Timer		N	N					
	Overload -Alarm		N	N					
Pilot Lamp			N	N					
SE4	Auto/Off/Manual		M	M					
	Current(A)	R	6.2	6.2					
		S	6.2	6.2					
		T	6.2	6.2					
	Timer		N	N					
	Overload -Alarm		N	N					
Pilot Lamp			N	N					
SE5	Auto/Off/Manual		M	M					
	Current(A)	R	6.1	6.1					
		S	6.1	6.1					
		T	6.1	6.1					
	Timer		N	N					
	Overload -Alarm		N	N					
Pilot Lamp			N	N					
SE6	Auto/Off/Manual		A	A					
	Current(A)	R	3.2	3.2					
		S	3.2	3.2					
		T	3.2	3.2					
	Timer		N	N					
	Overload -Alarm		N	N					
Pilot Lamp			N	N					
SE7	Auto/Off/Manual		M	M					
	Current(A)	R	2.1	2.1					
		S	2.1	2.1					
		T	2.1	2.1					
	Timer		N	N					
	Overload -Alarm		N	N					
Pilot Lamp			N	N					
SE8	Auto/Off/Manual		A	A					
	Current(A)	R	2.0	2.0					
		S	2.0	2.0					
		T	2.0	2.0					
	Timer		N	N					
	Overload -Alarm		N	N					
Pilot Lamp			N	N					
Date Check >>			10/6/16	11/10/16	/ /	/ /	/ /	/ /	/ /
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH 6/65

WASTE WATERTREATMENT PLANT

TIME

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual				M	M	M	M	M
	Current(A)	R			11.1	11.0	11.1	11.1	11.1
		S			11.2	11.1	11.1	11.1	11.1
		T			11.1	11.1	11.1	11.1	11.1
	Overload -Alarm				N	N	N	N	N
	Latching relay control				N	N	N	N	N
WWP2	Auto/Off/Manual				M	M	M	M	M
	Current(A)	R			11.0	11.1	11.1	11.1	11.1
		S			11.1	11.2	11.2	11.1	11.2
		T			11.1	11.1	11.1	11.1	11.1
	Overload -Alarm				N	N	N	N	N
	Latching relay control				N	N	N	N	N
SLP1	Auto/Off/Manual				A	A	A	A	A
	Current(A)	R			1.2	1.1	1.1	1.1	1.1
		S			1.0	1.0	1.1	1.1	1.2
		T			1.1	1.1	1.1	1.1	1.1
	Timer				N	N	N	N	N
	Overload -Alarm				N	N	N	N	N
SLP2	Auto/Off/Manual				M	M	M	M	M
	Current(A)	R			1.1	1.0	1.0	1.1	1.1
		S			1.2	1.2	1.1	1.1	1.1
		T			1.1	1.1	1.1	1.1	1.1
	Timer				N	N	N	N	N
	Overload -Alarm				N	N	N	N	N
DP1	Auto/Off/Manual				M	M	M	M	M
	Current(A)	R			7.1	7.0	7.0	7.0	7.0
		S			7.2	7.2	7.1	7.1	7.1
		T			7.1	7.2	7.1	7.1	7.1
	Overload -Alarm				N	N	N	N	N
	Latching relay control				N	N	N	N	N
DP2	Auto/Off/Manual				M	M	M	M	M
	Current(A)	R			3.1	3.1	3.1	3.1	3.1
		S			3.0	3.0	3.0	3.0	3.0
		T			3.1	3.1	3.1	3.1	3.0
	Overload -Alarm				N	N	N	N	N
	Latching relay control				N	N	N	N	N
SP1	Auto/Off/Manual				M	M	M	M	M
	Current(A)	R			1.1	1.1	1.1	1.1	1.1
		S			1.1	1.1	1.1	1.1	1.1
		T			1.2	1.2	1.2	1.2	1.2
	Overload -Alarm				N	N	N	N	N
	Latching relay control				N	N	N	N	N
SP2	Auto/Off/Manual				M	M	M	M	M
	Current(A)	R			1.0	1.0	1.1	1.1	1.1
		S			1.0	1.1	1.1	1.1	1.1
		T			1.1	1.1	1.1	1.1	1.1
	Overload -Alarm				N	N	N	N	N
	Latching relay control				N	N	N	N	N

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual				A	A	A	A	A
	Current(A)	R			6.1	6.0	6.0	6.0	6.0
		S			6.0	6.1	6.1	6.0	6.1
		T			6.1	6.1	6.1	6.1	6.0
	Timer				N	N	N	N	N
	Overload -Alarm				N	N	N	N	N
Pilot Lamp					N	N	N	N	N
SE2	Auto/Off/Manual				M	M	M	M	M
	Current(A)	R			6.3	6.2	6.1	6.1	6.1
		S			6.2	6.2	6.1	6.1	6.1
		T			6.2	6.1	6.1	6.1	6.1
	Timer				N	N	N	N	N
	Overload -Alarm				N	N	N	N	N
Pilot Lamp					N	N	N	N	N
SE3	Auto/Off/Manual				A	A	A	A	A
	Current(A)	R			6.2	6.1	6.1	6.1	6.2
		S			6.1	6.1	6.1	6.1	6.1
		T			6.1	6.0	6.1	6.1	6.2
	Timer				N	N	N	N	N
	Overload -Alarm				N	N	N	N	N
Pilot Lamp					N	N	N	N	N
SE4	Auto/Off/Manual				M	M	M	M	M
	Current(A)	R			6.2	6.2	6.1	6.1	6.1
		S			6.1	6.1	6.1	6.1	6.2
		T			6.1	6.1	6.1	6.1	6.1
	Timer				N	N	N	N	N
	Overload -Alarm				N	N	N	N	N
Pilot Lamp					N	N	N	N	N
SE5	Auto/Off/Manual				M	M	M	M	M
	Current(A)	R			6.1	6.2	6.1	6.1	6.2
		S			6.1	6.1	6.2	6.1	6.1
		T			6.2	6.2	6.1	6.1	6.1
	Timer				N	N	N	N	N
	Overload -Alarm				N	N	N	N	N
Pilot Lamp					N	N	N	N	N
SE6	Auto/Off/Manual				A	A	A	A	A
	Current(A)	R			7.2	7.2	7.1	7.1	7.1
		S			7.1	7.2	7.2	7.1	7.2
		T			7.1	7.1	7.1	7.1	7.1
	Timer				N	N	N	N	N
	Overload -Alarm				N	N	N	N	N
Pilot Lamp					N	N	N	N	N
SE7	Auto/Off/Manual				M	M	M	M	M
	Current(A)	R			7.1	7.1	7.1	7.1	7.1
		S			7.2	7.0	7.1	7.1	7.2
		T			7.1	7.1	7.0	7.1	7.1
	Timer				N	N	N	N	N
	Overload -Alarm				N	N	N	N	N
Pilot Lamp					N	N	N	N	N
SE8	Auto/Off/Manual				A	A	A	A	A
	Current(A)	R			8.0	8.1	8.1	8.1	8.1
		S			8.1	8.1	8.0	8.1	8.2
		T			8.1	8.1	8.1	8.1	8.1
	Timer				N	N	N	N	N
	Overload -Alarm				N	N	N	N	N
Pilot Lamp					N	N	N	N	N
Date Check >>			1/6/65	2/6/65	3/6/65	4/6/65	5/6/65	6/6/65	
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH.....

6/65

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		3	3	3	3	3	3	3
	Current(A)	R	11.3	11.3	11.3	11.3	11.3	11.2	11.2
		S	11.3	11.3	11.3	11.3	11.3	11.2	11.2
		T	11.3	11.3	11.3	11.3	11.3	11.2	11.2
	Overload -Alarm		22	22	22	22	22	22	22
	Latching relay control		22	22	22	22	22	22	22
WWP2	Auto/Off/Manual		3	3	3	3	3	3	3
	Current(A)	R	11.3	11.3	11.3	11.3	11.3	11.2	11.2
		S	11.3	11.3	11.3	11.3	11.3	11.2	11.2
		T	11.3	11.3	11.3	11.3	11.3	11.2	11.2
	Overload -Alarm		22	22	22	22	22	22	22
	Latching relay control		22	22	22	22	22	22	22
SLP1	Auto/Off/Manual		3	3	3	3	3	3	3
	Current(A)	R	11.3	11.3	11.3	11.3	11.3	11.2	11.2
		S	11.3	11.3	11.3	11.3	11.3	11.2	11.2
		T	11.3	11.3	11.3	11.3	11.3	11.2	11.2
	Timer		22	22	22	22	22	22	22
	Overload -Alarm		22	22	22	22	22	22	22
SLP2	Auto/Off/Manual		3	3	3	3	3	3	3
	Current(A)	R	11.3	11.3	11.3	11.3	11.3	11.2	11.2
		S	11.3	11.3	11.3	11.3	11.3	11.2	11.2
		T	11.3	11.3	11.3	11.3	11.3	11.2	11.2
	Timer		22	22	22	22	22	22	22
	Overload -Alarm		22	22	22	22	22	22	22
DP1	Auto/Off/Manual		3	3	3	3	3	3	3
	Current(A)	R	11.3	11.3	11.3	11.3	11.3	11.2	11.2
		S	11.3	11.3	11.3	11.3	11.3	11.2	11.2
		T	11.3	11.3	11.3	11.3	11.3	11.2	11.2
	Overload -Alarm		22	22	22	22	22	22	22
	Latching relay control		22	22	22	22	22	22	22
DP2	Auto/Off/Manual		3	3	3	3	3	3	3
	Current(A)	R	11.3	11.3	11.3	11.3	11.3	11.2	11.2
		S	11.3	11.3	11.3	11.3	11.3	11.2	11.2
		T	11.3	11.3	11.3	11.3	11.3	11.2	11.2
	Overload -Alarm		22	22	22	22	22	22	22
	Latching relay control		22	22	22	22	22	22	22
SPI	Auto/Off/Manual		3	3	3	3	3	3	3
	Current(A)	R	11.3	11.3	11.3	11.3	11.3	11.2	11.2
		S	11.3	11.3	11.3	11.3	11.3	11.2	11.2
		T	11.3	11.3	11.3	11.3	11.3	11.2	11.2
	Overload -Alarm		22	22	22	22	22	22	22
	Latching relay control		22	22	22	22	22	22	22
SP2	Auto/Off/Manual		3	3	3	3	3	3	3
	Current(A)	R	11.3	11.3	11.3	11.3	11.3	11.2	11.2
		S	11.3	11.3	11.3	11.3	11.3	11.2	11.2
		T	11.3	11.3	11.3	11.3	11.3	11.2	11.2
	Overload -Alarm		22	22	22	22	22	22	22
	Latching relay control		22	22	22	22	22	22	22

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	D
	Current(A)	R	6.0	6.0	6.1	6.1	6.1	6.1	6.2
		S	6.1	6.1	6.1	6.1	6.1	6.1	6.2
		T	6.1	6.1	6.1	6.1	6.1	6.1	6.2
	Timer		22	22	22	22	22	22	22
	Overload -Alarm		22	22	22	22	22	22	22
SE2	Auto/Off/Manual		3	3	3	3	3	3	3
	Current(A)	R	6.1	6.1	6.1	6.1	6.1	6.1	6.2
		S	6.1	6.1	6.1	6.1	6.1	6.1	6.1
		T	6.1	6.1	6.1	6.1	6.1	6.1	6.1
	Timer		22	22	22	22	22	22	22
	Overload -Alarm		22	22	22	22	22	22	22
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.2	6.1	6.1	6.1	6.1	6.1	6.2
		S	6.1	6.1	6.1	6.1	6.1	6.1	6.1
		T	6.1	6.1	6.1	6.1	6.1	6.1	6.2
	Timer		22	22	22	22	22	22	22
	Overload -Alarm		22	22	22	22	22	22	22
SE4	Auto/Off/Manual		3	3	3	3	3	3	3
	Current(A)	R	6.2	6.2	6.2	6.2	6.2	6.2	6.2
		S	6.2	6.2	6.2	6.2	6.2	6.2	6.2
		T	6.2	6.2	6.2	6.2	6.2	6.2	6.2
	Timer		22	22	22	22	22	22	22
	Overload -Alarm		22	22	22	22	22	22	22
SE5	Auto/Off/Manual		3	3	3	3	3	3	3
	Current(A)	R	6.1	6.1	6.1	6.1	6.1	6.1	6.1
		S	6.1	6.1	6.1	6.1	6.1	6.1	6.1
		T	6.1	6.1	6.1	6.1	6.1	6.1	6.1
	Timer		22	22	22	22	22	22	22
	Overload -Alarm		22	22	22	22	22	22	22
SE6	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	7.1	7.1	7.1	7.1	7.1	7.1	7.1
		S	7.1	7.1	7.1	7.1	7.1	7.1	7.1
		T	7.1	7.1	7.1	7.1	7.1	7.1	7.1
	Timer		22	22	22	22	22	22	22
	Overload -Alarm		22	22	22	22	22	22	22
SE7	Auto/Off/Manual		3	3	3	3	3	3	3
	Current(A)	R	7.2	7.1	7.1	7.1	7.1	7.1	7.1
		S	7.1	7.1	7.1	7.1	7.1	7.1	7.1
		T	7.1	7.1	7.1	7.1	7.1	7.1	7.1
	Timer		22	22	22	22	22	22	22
	Overload -Alarm		22	22	22	22	22	22	22
SE8	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	8.1	8.1	8.1	8.1	8.1	8.1	8.1
		S	8.1	8.1	8.1	8.1	8.1	8.1	8.1
		T	8.1	8.1	8.1	8.1	8.1	8.1	8.1
	Timer		22	22	22	22	22	22	22
	Overload -Alarm		22	22	22	22	22	22	22
Date Check >>			6/6/65	7/6/65	8/6/65	9/6/65	10/6/65	11/6/65	12/6/65
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH.....

6/65

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.1	11.1	11.1	11.1	11.1	11.1	11.1
		S	11.2	11.2	11.1	11.1	11.1	11.1	11.1
		T	11.1	11.1	11.2	11.1	11.1	11.1	11.1
	Overload -Alarm		2	2	2	2	2	2	2
	Latching relay control		2	2	2	2	2	2	2
Pilot Lamp		2	2	2	2	2	2	2	2
WWP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	11.1	11.1	11.1	11.1	11.1	11.1	11.1
		S	11.1	11.2	11.2	11.1	11.1	11.1	11.1
		T	11.1	11.1	11.1	11.1	11.1	11.1	11.1
	Overload -Alarm		2	2	2	2	2	2	2
	Latching relay control		2	2	2	2	2	2	2
Pilot Lamp		2	2	2	2	2	2	2	2
SLP1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.1	1.1	1.2	1.1	1.1	1.1	1.1
		S	1.1	1.2	1.1	1.1	1.1	1.1	1.1
		T	1.2	1.1	1.2	1.1	1.2	1.1	1.1
	Timer		2	2	2	2	2	2	2
	Overload -Alarm		2	2	2	2	2	2	2
Pilot Lamp		2	2	2	2	2	2	2	2
SLP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.2	1.1	1.2	1.1	1.1	1.1	1.1
		S	1.2	1.1	1.1	1.1	1.1	1.1	1.1
		T	1.1	1.2	1.2	1.2	1.2	1.2	1.1
	Timer		2	2	2	2	2	2	2
	Overload -Alarm		2	2	2	2	2	2	2
Pilot Lamp		2	2	2	2	2	2	2	2
DPI	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	9.0	9.0	9.0	9.0	9.0	9.0	9.0
		S	9.1	9.2	9.1	9.0	9.0	9.0	9.0
		T	9.1	9.6	9.0	9.0	9.0	9.0	9.0
	Overload -Alarm		2	2	2	2	2	2	2
	Latching relay control		2	2	2	2	2	2	2
Pilot Lamp		2	2	2	2	2	2	2	2
DP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	3.1	3.0	3.1	3.0	3.0	3.0	3.0
		S	3.0	3.1	3.0	3.0	3.0	3.0	3.0
		T	3.0	3.1	3.1	3.0	3.0	3.0	3.0
	Overload -Alarm		2	2	2	2	2	2	2
	Latching relay control		2	2	2	2	2	2	2
Pilot Lamp		2	2	2	2	2	2	2	2
SP1	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.1	1.2	1.1	1.1	1.1	1.1	1.1
		S	1.1	1.1	1.2	1.1	1.1	1.1	1.1
		T	1.1	1.1	1.1	1.1	1.1	1.1	1.1
	Overload -Alarm		2	2	2	2	2	2	2
	Latching relay control		2	2	2	2	2	2	2
Pilot Lamp		2	2	2	2	2	2	2	2
SP2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	1.2	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.2	1.2	1.2	1.1	1.1	1.1	1.1
		T	1.2	1.1	1.1	1.1	1.1	1.1	1.1
	Overload -Alarm		2	2	2	2	2	2	2
	Latching relay control		2	2	2	2	2	2	2
Pilot Lamp		2	2	2	2	2	2	2	2

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	R	A	A	A	A
	Current(A)	R	6.1	6.1	6.1	6.3	6.3	6.4	6.4
		S	6.1	6.1	6.1	6.3	6.3	6.4	6.4
		T	6.1	6.2	6.2	6.3	6.3	6.4	6.4
	Timer		2	2	2	2	2	2	2
	Overload -Alarm		2	2	2	2	2	2	2
Pilot Lamp		2	2	2	2	2	2	2	2
SE2	Auto/Off/Manual		M	M	M	A	A	A	A
	Current(A)	R	6.2	6.2	6.1	6.1	6.1	6.1	6.1
		S	6.2	6.2	6.2	6.1	6.1	6.1	6.1
		T	6.2	6.2	6.1	6.4	6.1	6.6	6.1
	Timer		2	2	2	2	2	2	2
	Overload -Alarm		2	2	2	2	2	2	2
Pilot Lamp		2	2	2	2	2	2	2	2
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.1	6.1	6.2	6.4	6.4	6.4	6.4
		S	6.1	6.0	6.1	6.4	6.4	6.6	6.4
		T	6.1	6.1	6.0	6.4	6.4	6.4	6.4
	Timer		2	2	2	2	2	2	2
	Overload -Alarm		2	2	2	2	2	2	2
Pilot Lamp		2	2	2	2	2	2	2	2
SE4	Auto/Off/Manual		M	M	M	A	A	A	A
	Current(A)	R	6.2	6.1	6.1	6.2	6.2	6.1	6.1
		S	6.2	6.2	6.1	6.2	6.2	6.1	6.1
		T	6.2	6.1	6.2	6.2	6.2	6.1	6.1
	Timer		2	2	2	2	2	2	2
	Overload -Alarm		2	2	2	2	2	2	2
Pilot Lamp		2	2	2	2	2	2	2	2
SE5	Auto/Off/Manual		M	M	M	A	A	A	A
	Current(A)	R	6.1	6.1	6.0	6.4	6.4	6.4	6.4
		S	6.1	6.0	6.0	6.4	6.4	6.4	6.4
		T	6.1	6.1	6.0	6.4	6.4	6.4	6.4
	Timer		2	2	2	2	2	2	2
	Overload -Alarm		2	2	2	2	2	2	2
Pilot Lamp		2	2	2	2	2	2	2	2
SE6	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	9.1	9.0	9.1	9.9	9.9	9.9	9.9
		S	9.1	9.1	9.0	9.9	9.9	9.9	9.9
		T	9.1	9.0	9.0	9.9	9.9	9.9	9.9
	Timer		2	2	2	2	2	2	2
	Overload -Alarm		2	2	2	2	2	2	2
Pilot Lamp		2	2	2	2	2	2	2	2
SE7	Auto/Off/Manual		M	M	M	A	A	A	A
	Current(A)	R	9.0	9.1	9.1	9.9	9.9	9.9	9.9
		S	9.0	9.0	9.0	9.9	9.9	9.9	9.9
		T	9.0	9.1	9.1	9.9	9.9	9.9	9.9
	Timer		2	2	2	2	2	2	2
	Overload -Alarm		2	2	2	2	2	2	2
Pilot Lamp		2	2	2	2	2	2	2	2
SE8	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.1	6.1	6.1	6.1	6.1	6.1	6.1
		S	6.1	6.0	6.0	6.1	6.1	6.1	6.1
		T	6.0	6.1	6.0	6.1	6.1	6.1	6.1
	Timer		2	2	2	2	2	2	2
	Overload -Alarm		2	2	2	2	2	2	2
Pilot Lamp		2	2	2	2	2	2	2	2
Date Check >>			13/6/15	14/6/15	15/6/15	16/6/15	17/6/15	18/6/15	19/6/15
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH.....

6/65

WASTE WATERTREATMENT PLANT

TIME.....

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual		3	3	3	M	M	M	M
	Current(A)	R	11.1	11.1	11.1	11.0	11.1	11.1	11.1
		S	11.1	11.1	11.1	11.1	11.1	11.0	11.2
		T	11.2	11.1	11.0	11.1	11.1	11.1	11.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
WWP2	Auto/Off/Manual		3	3	3	M	M	M	M
	Current(A)	R	11.1	11.1	11.1	11.2	11.1	11.1	11.1
		S	11.1	11.1	11.1	11.1	11.2	11.1	11.2
		T	11.2	11.2	11.2	11.2	11.2	11.0	11.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SLP1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		S	1.0	1.0	1.0	1.0	1.2	1.2	1.2
		T	1.2	1.2	1.2	1.2	1.2	1.1	1.1
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SLP2	Auto/Off/Manual		B	B	B	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.2	1.2	1.2
		S	1.1	1.1	1.1	1.1	1.2	1.1	1.1
		T	1.1	1.1	1.1	1.1	1.1	1.2	1.2
	Timer		N	N	N	N	N	N	N
	Overload -Alarm		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
DP1	Auto/Off/Manual		0	0	0	M	M	M	M
	Current(A)	R	7.1	7.0	7.0	7.1	7.0	7.0	7.0
		S	7.1	7.0	7.0	7.0	7.0	7.1	7.1
		T	7.1	7.0	7.0	7.0	7.1	7.1	7.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
DP2	Auto/Off/Manual		0	0	0	M	M	M	M
	Current(A)	R	3.1	3.1	3.1	3.1	3.1	3.1	3.1
		S	3.1	3.1	3.1	3.1	3.1	3.2	3.2
		T	3.1	3.1	3.1	3.1	3.1	3.1	3.1
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SP1	Auto/Off/Manual		3	3	3	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.2	1.2	1.2
		S	1.1	1.1	1.1	1.2	1.1	1.1	1.1
		T	1.1	1.1	1.1	1.1	1.1	1.2	1.2
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	
SP2	Auto/Off/Manual		3	3	3	M	M	M	M
	Current(A)	R	1.1	1.1	1.1	1.1	1.2	1.2	1.2
		S	1.1	1.1	1.1	1.2	1.1	1.1	1.1
		T	1.1	1.1	1.1	1.1	1.2	1.2	1.2
	Overload -Alarm		N	N	N	N	N	N	N
	Latching relay control		N	N	N	N	N	N	N
Pilot Lamp		N	N	N	N	N	N	N	

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.1	6.1	6.0	6.1	6.1	6.1	6.2
		S	6.1	6.1	6.0	6.1	6.1	6.1	6.1
		T	6.1	6.1	6.0	6.1	6.0	6.1	6.1
	Timer		22	22	22	22	22	22	22
	Overload -Alarm		22	22	22	22	22	22	22
Pilot Lamp		22	22	22	22	22	22	22	22
SE2	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.2	6.2	6.1	6.1	6.2	6.2	6.2
		S	6.2	6.2	6.1	6.0	6.1	6.1	6.1
		T	6.2	6.2	6.1	6.1	6.1	6.1	6.2
	Timer		22	22	22	22	22	22	22
	Overload -Alarm		22	22	22	22	22	22	22
Pilot Lamp		22	22	22	22	22	22	22	22
SE3	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	6.1	6.1	6.1	6.1	6.2	6.2	6.2
		S	6.1	6.1	6.1	6.1	6.1	6.1	6.1
		T	6.1	6.1	6.1	6.2	6.1	6.1	6.2
	Timer		22	22	22	22	22	22	22
	Overload -Alarm		22	22	22	22	22	22	22
Pilot Lamp		22	22	22	22	22	22	22	22
SE4	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.1	6.1	6.1	6.1	6.2	6.2	6.2
		S	6.1	6.1	6.1	6.1	6.2	6.2	6.1
		T	6.1	6.1	6.1	6.1	6.1	6.1	6.2
	Timer		22	22	22	22	22	22	22
	Overload -Alarm		22	22	22	22	22	22	22
Pilot Lamp		22	22	22	22	22	22	22	22
SE5	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	6.1	6.1	6.1	6.1	6.2	6.2	6.1
		S	6.1	6.1	6.1	6.2	6.1	6.1	6.2
		T	6.1	6.1	6.1	6.2	6.2	6.2	6.1
	Timer		22	22	22	22	22	22	22
	Overload -Alarm		22	22	22	22	22	22	22
Pilot Lamp		22	22	22	22	22	22	22	22
SE6	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	7.1	7.1	7.2	7.1	7.1	7.1	7.1
		S	7.1	7.1	7.2	7.2	7.0	7.0	7.0
		T	7.1	7.1	7.2	7.2	7.0	7.1	7.1
	Timer		22	22	22	22	22	22	22
	Overload -Alarm		22	22	22	22	22	22	22
Pilot Lamp		22	22	22	22	22	22	22	22
SE7	Auto/Off/Manual		M	M	M	M	M	M	M
	Current(A)	R	7.0	7.0	7.0	7.0	7.1	7.2	7.2
		S	7.0	7.0	7.0	7.1	7.0	7.0	7.0
		T	7.0	7.0	7.0	7.0	7.1	7.1	7.1
	Timer		22	22	22	22	22	22	22
	Overload -Alarm		22	22	22	22	22	22	22
Pilot Lamp		22	22	22	22	22	22	22	22
SE8	Auto/Off/Manual		A	A	A	A	A	A	A
	Current(A)	R	8.1	8.1	8.1	8.1	8.1	8.1	8.1
		S	8.1	8.1	8.1	8.0	8.0	8.0	8.0
		T	8.1	8.1	8.1	8.0	8.0	8.1	8.1
	Timer		22	22	22	22	22	22	22
	Overload -Alarm		22	22	22	22	22	22	22
Pilot Lamp		22	22	22	22	22	22	22	22
Date Check >>			20/6/65	21/6/65	22/6/65	23/6/65	24/6/65	25/6/65	26/6/65
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....

CENTRE POINT RATCHADAMRI

DAILY REPORT

SYSTEM & SAFETY DEPT.

MONTH 6/65

WASTE WATERTREATMENT PLANT

TIME

Description / Day		Mon	Tue	Wed	Thu	Fri	Sat	Sun
WWP1	Auto/Off/Manual	3	3	3	3			
	Current(A)	1.1	1.1	1.1	1.1			
	Overload -Alarm	22	22	22	22			
	Latching relay control	22	22	22	22			
WWP2	Auto/Off/Manual	3	3	3	3			
	Current(A)	1.1	1.1	1.1	1.1			
	Overload -Alarm	22	22	22	22			
	Latching relay control	22	22	22	22			
SLP1	Auto/Off/Manual	3	3	3	3			
	Current(A)	1.1	1.1	1.1	1.1			
	Overload -Alarm	22	22	22	22			
	Latching relay control	22	22	22	22			
SLP2	Auto/Off/Manual	3	3	3	3			
	Current(A)	1.1	1.1	1.1	1.1			
	Overload -Alarm	22	22	22	22			
	Latching relay control	22	22	22	22			
DP1	Auto/Off/Manual	3	3	3	3			
	Current(A)	1.1	1.1	1.1	1.1			
	Overload -Alarm	22	22	22	22			
	Latching relay control	22	22	22	22			
DP2	Auto/Off/Manual	3	3	3	3			
	Current(A)	1.1	1.1	1.1	1.1			
	Overload -Alarm	22	22	22	22			
	Latching relay control	22	22	22	22			
SP1	Auto/Off/Manual	3	3	3	3			
	Current(A)	1.1	1.1	1.1	1.1			
	Overload -Alarm	22	22	22	22			
	Latching relay control	22	22	22	22			
SP2	Auto/Off/Manual	3	3	3	3			
	Current(A)	1.1	1.1	1.1	1.1			
	Overload -Alarm	22	22	22	22			
	Latching relay control	22	22	22	22			

Description / Day			Mon	Tue	Wed	Thu	Fri	Sat	Sun
SE1	Auto/Off/Manual		A	A	A	A			
	Current(A)	R							
		S							
		T							
	Timer								
Overload -Alarm									
Pilot Lamp									
SE2	Auto/Off/Manual		3	3	3	3			
	Current(A)	R							
		S							
		T							
	Timer								
Overload -Alarm									
Pilot Lamp									
SE3	Auto/Off/Manual		A	A	A	A			
	Current(A)	R							
		S							
		T							
	Timer								
Overload -Alarm									
Pilot Lamp									
SE4	Auto/Off/Manual		3	3	3	3			
	Current(A)	R							
		S							
		T							
	Timer								
Overload -Alarm									
Pilot Lamp									
SE5	Auto/Off/Manual		3	3	3	3			
	Current(A)	R							
		S							
		T							
	Timer								
Overload -Alarm									
Pilot Lamp									
SE6	Auto/Off/Manual		3	3	3	3			
	Current(A)	R							
		S							
		T							
	Timer								
Overload -Alarm									
Pilot Lamp									
SE7	Auto/Off/Manual		3	3	3	3			
	Current(A)	R							
		S							
		T							
	Timer								
Overload -Alarm									
Pilot Lamp									
SE8	Auto/Off/Manual		3	3	3	3			
	Current(A)	R							
		S							
		T							
	Timer								
Overload -Alarm									
Pilot Lamp									
Date Check >>			97.6.18	97.6.18	97.6.18	97.6.18			
Record By >>									
Recheck By >>									

N=Normal UN=Unnormal R=Repair F=Fault L=Low H=Hight level

Remark.....