

ภาคผนวก ข9

เอกสารการตรวจสอบอุปกรณ์ที่ใช้ระบายอากาศ

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 1 / 65

AHU NO....L1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

RECHECK BY

นายพรชัย นฤคทอง

CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 1/65

AHU NO....L2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY .  ..
 นายพรชัย กรุดทอง
 CHIEF ENGINEER
 RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 1/65

AHU NO....L3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY 
 นายพรชัย กรุดทอง
 CHIEF ENGINEER
 RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 1/65

AHU NO....M1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/	/				
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

RECHECK BY

นายวิชาญ บัวทอง

CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH ...1/65...

AHU NO....M2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY 
 นายพรชัย อดุทธอง
 RECHECK BYCHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 1/65

AHU NO....M3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY [REDACTED]

นายพรชัย กระจุกทอง
RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 1/65.....

AHU NO....4-1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY 

.....นายพรชัย กรุดทอง
RECHECK BYCHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 1/65.....

AHU NO....4-2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/	/				
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY RECHECK BY นายพรชัย ฤกษ์ทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 1/65.....

AHU NO....F1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

RECHECK BY

นายพรชัย กรุดทอง

CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 1/65

AHU NO....F2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY


 นายพรชัย กรุดทอง
 RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 2/65

AHU NO....L1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System	/				/	
		Cleanning Overall Inside Panel Control	/	/				
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY ..


 นายพรชัย ฤกษ์ทอง
 RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 2/65

AHU NO....L2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/	/				
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY


 นายพรชัย ฤกษ์ทอง
 RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 2/65

AHU NO....L3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/			/	
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY

RECHECK BYนายพรชัย กระจุกทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 2/65

AHU NO....M1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....


COMMENT

.....

.....

.....

RECORD BY


 นายพรชัย กรุดทอง
 RECHECK BY **CHIEF ENGINEER**

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 2/65

AHU NO....M2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun, Sep, Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY


 RECHECK BY **CHIEF ENGINEER**

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 2/65

AHU NO....M3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY RECHECK BY นายพริ้ม นฤตพร
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 2/65.....

AHU NO....4-1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/	/				
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ... 

นายพรชัย อรุณทอง
RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 2/65.....

AHU NO....4-2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System		/			/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun, Sep, Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY


 RECHECK BY ...พ.อ.ท. ชัยวัฒน์ ชื่นชูชัยกิจ
 CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 2/65

AHU NO....F1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

.....นายพรชัย กรุดทอง
RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 2/65

AHU NO....F2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY RECHECK BY นายพรชัย..ถูดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 3/65

AHU NO....L1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply	/					
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/					

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ..



นายพรชัย นฤตทอง
CHIEF ENGINEER
RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 3/65

AHU NO....L2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply	/					
Mar,Jun, Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY



RECHECK BY

นายพรชัย ฤทธิ์ทอง

CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 3/65

AHU NO....L3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply	/					
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ...



RECHECK BY

นายพรชัย กรุดทอง

CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 3/65

AHU NO....M1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply	/					
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

 นายพรชัย อรุณทอง
 RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 3/65

AHU NO....M2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	/					
	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY ..


 นายพรชัย กรุดทอง
 RECHECK BY ... CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 3/65

AHU NO....M3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply	/					
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY .



RECHECK BY

 นายพรชัย กรุดทอง
 CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 3/65.....

AHU NO....4-1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	/					
	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY


 นายพรชัย อรุณทอง
 RECHECK BY ..CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 3/65.....

AHU NO....4-2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply	/					
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY


 นายพรชัย กระจุกทอง
 RECHECK BY **CHIEF ENGINEER**

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 3/65

AHU NO....F1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	/					
	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY ...


นายพรชัย กรุดทอง
 RECHECK BY ...CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 3/65

AHU NO....F2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply	/					
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY ..


 นายพรชัย กรุดทอง
 RECHECK BY ...CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 4/65

AHU NO....L1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

RECHECK BY นายพรชัย กรุดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 4/65.....

AHU NO....L2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun, Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 
 นายพรชัย ญาคุดทอง
 CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 4/65

AHU NO....L3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun, Sep, Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY



RECHECK BY

นายพรชัย ฤกษ์ทอง

CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 4/65

AHU NO....M1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY



RECHECK BY

นายพรชัย ฤกษ์ทอง

CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 4/65

AHU NO....M2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY



RECHECK BY

นายพรชัย ฤกษ์ทอง

CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 4/65

AHU NO....M3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY 
 นายพรชัย กรุดทอง
 RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 4/65

AHU NO....4-2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
 R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY


 นายพรชัย ฤกษ์ทอง
 RECHECK BY **CHIEF ENGINEER**

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 4/68.....

AHU NO....F1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY . นายพรชัย กรุดทอง
RECHECK BYCHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 4/65

AHU NO....F2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ..



RECHECK BY ..

นายพรชัย กุศลทอง

CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 5/65

AHU NO....L1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY [REDACTED]

 นายพรชัย ฤกษ์ทอง
 CHIEF ENGINEER

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 5/65

AHU NO....L2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY RECHECK BY นายพรชัย กรุดทอง
...CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 5/65

AHU NO....L3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1.	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY


 นายพรชัย ญรุดทอง
 RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 5/65

AHU NO....M1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY


 นายพรชัย กรุดทอง
 RECHECK BY **CHIEF ENGINEER**

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 5/65

AHU NO....M2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ..


 นายพรชัย อดุลทอง
 RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 5/65

AHU NO....M3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

นายพรชัย กรุดทอง
RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 5/65.....

AHU NO....4-1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun, Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY


 นายพรชัย ทรัพย์ทอง
 RECHECK BYCHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 5/65

AHU NO....4-2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY


 นายพรชัย กรุดทอง
 RECHECK BYCHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 5/65

AHU NO....F1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ...

นายพรชัย กรุดทอง
RECHECK BYCHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 5/65.....

AHU NO....F2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ..


 นายพรชัย อรุณทอง
 RECHECK BYCHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 6/65

AHU NO....L1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply	/					
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY


 RECHECK BY นายพรชัย อรุณทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH

6/65

AHU NO....L2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply	/					
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY



นายพรชัย ฤทธิทอง

RECHECK BY .CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 6/65

AHU NO....L3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply	/					
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY


 นายพรชัย อรุณทอง
 RECHECK BY **CHIEF ENGINEER**

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 6/65

AHU NO....MI...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System						
		Cleanning Overall Inside Panel Control						
		Fitting All Inside Panel Control						
		Testing Overload						
	2	Check Operation						
	3	Check Motor& Blower						
	4	Check Belt						
	5	Check Bearing						
	6	Check&Cleaned Frame						
	7	Check & Fitting Support						
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

 นายพรชัย ธีรเดชทอง
 CHIEF ENGINEER
 RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 6/65

AHU NO....M2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/	/				
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	/					
	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY


 นายพรชัย ญะดอง
 RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 6/65

AHU NO....M3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System	/				/	
		Cleanning Overall Inside Panel Control	/	/				
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	/					
	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY ...


 นายพรชัย ฤวดทอง
 CHIEF ENGINEER

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 6/65

AHU NO....4-1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply	/					
Mar,Jun, Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ...


 นายพรชัย นฤเดชอง
 RECHECK BY **CHIEF ENGINEER**

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 6/65

AHU NO....4-2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply	/					
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....


COMMENT

.....

.....

.....

RECORD BY


 นายพรชัย ญะอุทอง
 RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 6/65

AHU NO....F1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month	8	Cleanning Air Grill Return & Supply	/					
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY


 นายพรชัย ภูมทอง
 RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 6/65

AHU NO....F2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt					/	
	5	Check Bearing					/	
	6	Check&Cleaned Frame					/	
	7	Check & Fitting Support					/	
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	/	/				
	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ...


 นายพรชัย กรุดทอง
 RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....L....

MONTH 1/165.....
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY .. [REDACTED]

..... นายพรชัย กรุดทอง
RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....7....

MONTH 1 / 65
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month Mar,Jun,Sep,Dec	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
	8	Cleanning Air Grill Return & Supply						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY 

RECHECK BY นายพรชัย อนุทอง CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....L....

MONTH 2/65
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System		/			/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month <small>Mar,Jun,Sep,Dec</small>	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
	8	Cleanning Air Grill Return & Supply						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

COMMENT

.....

.....

RECORD BY



.....นายพรชัย กรุดทอง
RECHECK BYCHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....7....

MONTH 2/65.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System		/			/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY



.....นายพรชัย นฤตพงศ์
RECHECK BYCHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....L....

MONTH 3/65
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower					/	
	7	Check & Fitting Support					/	
Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	/				/	

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ... [REDACTED]

RECHECK BY นายพรชัย คุรุทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....7....

MONTH 3/65
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System	/				/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Motor& Blower					/	
3 Month	3	Check Belt					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower					/	
Mar,Jun,Sep,Dec	7	Check & Fitting Support					/	
	8	Cleanning Air Grill Return & Supply	/					

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY [REDACTED]นายพรชัย.ดรุดทอง
RECHECK BYCHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....L....

MONTH 4/65
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System		/			/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
Mar,Jun, Sep,Dec	8	Cleanning Air Grill Return & Supply						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY ... 

RECHECK BY นายพรชัย กรุดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....7....

MONTH 4/65
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE


.....

.....

COMMENT

.....

.....

RECORD BY 

RECHECK BY นายพรชัย กรุดทอง **CHIEF ENGINEER**

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....L....

MONTH 5/65
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

COMMENT

RECORD BY [REDACTED] RECHECK BYนายพรชัย ญูทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....7....

MONTH 5/65
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
	8	Cleanning Air Grill Return & Supply						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED


NOTE

.....

.....

COMMENT

.....

RECORD BY .. 

RECHECK BY นายพรชัย กรุดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....L....


MONTH 6/65.....
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System	/				/	
		Cleanning Overall Inside Panel Control	/	/				
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month Mar,Jun,Sep,Dec	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower		/				
	7	Check & Fitting Support					/	
	8	Cleanning Air Grill Return & Supply	/					

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

COMMENT

RECORD BY ... 

.....นายพรชัย ภูวดทอง
RECHECK BYCHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....7....

MONTH 6/65
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System	/				/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower		/				
	7	Check & Fitting Support					/	
Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	/					

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

COMMENT

.....

.....

RECORD BY



นายพรชัย ฤกษ์ทอง
RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 1/65

PRESSURIZE FAN 1

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Damperes						
	10	Added Grease The Damper Motordrive						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
 R = REPAIR P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY 
 นายพรชัย คุรุคทอง
 RECHECK BY **CHIEF ENGINEER**

GRANDE CENTRE POINT RATCHADAMRI

SYSTEM & SAFETY

MONTH 1/65

PRESSURIZE FAN 2

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Damperes						
	10	Added Grease The Damper Motordrive						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED

R = REPAIR P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY 

นายพรชัย ทรุดทอง
RECHECK BY **CHIEF ENGINEER**

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 2/65

PRESSURIZE FAN 1

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Damperes						
	10	Added Grease The Damper Motordrive						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

นายพรชัย กรุดทอง
RECHECK BY CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

SYSTEM & SAFETY

MONTH 2/65

PRESSURIZE FAN 2

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Damperes						
	10	Added Grease The Damper Motordrive						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY



นายพรชัย ฤทธิทอง
RECHECK BYCHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 3/65

PRESSURIZE FAN 1

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return	/					
	8	Cleanning Relief Damper	/					
	9	Cleanning Supply Dampers	/					
	10	Added Grease The Damper Motordrive		/				

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ...


 นายพรชัย อรุณทอง
 RECHECK BY ... CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

SYSTEM & SAFETY

MONTH 3/65

PRESSURIZE FAN 2

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System						
		Cleanning Overall Inside Panel Control						
		Fitting All Inside Panel Control						
		Testing Overload						
	2	Check Timer Operation						
	3	Check Motor& Blower						
	4	Check Bearing						
	5	Check&Cleaned Frame						
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support						
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Damperes						
	10	Added Grease The Damper Motordrive						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED

R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY

นายพรชัย กุศลทอง
CHIEF ENGINEER

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 4/ 65

PRESSURIZE FAN I

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Damperes						
	10	Added Grease The Damper Motordrive						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED

R = REPAIR P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY  นายพรชัย กรุดทอง
CHIEF ENGINEER

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

SYSTEM & SAFETY

MONTH 4/65

PRESSURIZE FAN 2

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Damperes						
	10	Added Grease The Damper Motordrive						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED

R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY



RECHECK BYนายพรชัย กระจุกทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 5/65

PRESSURIZE FAN 1

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/	/				
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Dampers						
	10	Added Grease The Damper Motordrive						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....


COMMENT

.....

.....

.....

RECORD BY .



RECHECK BY

นายพรชัย กรุดทอง

CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

SYSTEM & SAFETY

MONTH 5/65

PRESSURIZE FAN 2

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleared Frame					/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Damperes						
	10	Added Grease The Damper Motordrive						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY



RECHECK BY

นายพรชัย กรุดทอง
CHIEF ENGINEER

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 6/65

PRESSURIZE FAN 1

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return	/					
	8	Cleanning Relief Damper					/	
	9	Cleanning Supply Damperes					/	
	10	Added Grease The Damper Motordrive		/				

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY


 นายพรชัย กรุดทอง
 RECHECK BY **CHIEF ENGINEER**

GRANDE CENTRE POINT RATCHADAMRI

SYSTEM & SAFETY

MONTH 6/65

PRESSURIZE FAN 2

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return	/					
	8	Cleanning Relief Damper					/	
	9	Cleanning Supply Damperes					/	
	10	Added Grease The Damper Motordrive		/				

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY .



นายพรชัย กุศลทอง
CHIEF ENGINEER
RECHECK BY

CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 1/65

SMOKE EXHAUST FAN ...M1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
	6	Check & Fitting Support					/	
3 Month	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY [REDACTED] ...

นายพรชัย กุศลทอง
RECHECK BY CHIEF ENGINEER

CENTRE POINT RATCHADAMRI

GRANDE CENTRE POINT RATCHADAMRI

MONTH 1/65

SMOKE EXHAUST FAN ...M2....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
	6	Check & Fitting Support					/	
3 Month	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY


 นายพรชัย กรุดทอง
 RECHECK BY ...CHIEF ENGINEER

CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 1/65

SMOKE EXHAUST FAN ...2-1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
	6	Check & Fitting Support					/	
3 Month	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL UN = UNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....
.....
.....

COMMENT

.....
.....
.....

RECORD BY

RECHECK BY

นายพรชัย กรุดทอง
CHIEF ENGINEER

CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 2/65

SMOKE EXHAUST FAN ...M1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY 

RECHECK BY นายพรชัย กรุดทอง
CHIEF ENGINEER

CENTRE POINT RATCHADAMRI

GRANDE CENTRE POINT RATCHADAMRI

MONTH 2/65

SMOKE EXHAUST FAN ...M2....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
	6	Check & Fitting Support					/	
3 Month	7	Cleanning Air Grill Return						
Mar,Jun,Sept,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY


 นายพรชัย กรุดทอง
 RECHECK BY **CHIEF ENGINEER**

CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 2/65

SMOKE EXHAUST FAN ...2-1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
	6	Check & Fitting Support						
3 Month	7	Cleanning Air Grill Return						
Mar,Jun,Sept,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ..


 นายพรชัย กรุดทอง
 RECHECK BYCHIEF ENGINEER

CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 3/65

SMOKE EXHAUST FAN ...M1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/		/			
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return	/					
	11	Tighting All Bolt/Nut Motor & Blower					/	

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY RECHECK BY นายพรชัย ฤกษ์ทอง
CHIEF ENGINEER

CENTRE POINT RATCHADAMRI

GRANDE CENTRE POINT RATCHADAMRI

MONTH 3/65.....

SMOKE EXHAUST FAN ...M2....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/	/				
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return	/					
	11	Tighting All Bolt/Nut Motor & Blower					/	

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY ...


 นายพรชัย กรุดทอง
 RECHECK BY **CHIEF ENGINEER**

CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 2/65.....

SMOKE EXHAUST FAN ...2-1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System	/				/	
		Cleanning Overall Inside Panel Control	/	/				
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
3 Month	5	Check&Cleaned Frame					/	
	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return	/					
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower	/				/	

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY  RECHECK BY นายพรชัย นฤพนธ์
CHIEF ENGINEER

CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 4/65

SMOKE EXHAUST FAN ...M1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
3 Month	5	Check&Cleaned Frame					/	
	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY



RECHECK BY

 นายพรชัย กรุดทอง
 CHIEF ENGINEER

CENTRE POINT RATCHADAMRI

GRANDE CENTRE POINT RATCHADAMRI

MONTH 4/65

SMOKE EXHAUST FAN ...M2....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support						
	7	Cleanning Air Grill Return						
	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY ...


 นายพรชัย กรุดทอง
 RECHECK BY ... **CHIEF ENGINEER**

CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 4/65

SMOKE EXHAUST FAN ...2-1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System	/				/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return						
	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL UN = UNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY  RECHECK BY นายพรชัย กรุดทอง
CHIEF ENGINEER

CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 5/65

SMOKE EXHAUST FAN ...M1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
	6	Check & Fitting Support					/	
3 Month	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY [REDACTED] RECHECK BY นายพรชัย กรุดทอง
CHIEF ENGINEER

CENTRE POINT RATCHADAMRI

GRANDE CENTRE POINT RATCHADAMRI

MONTH 5/65

SMOKE EXHAUST FAN ...M2....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY นายพรชัย ฤกษ์ทอง

RECHECK BY CHIEF ENGINEER

CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 5/65.....

SMOKE EXHAUST FAN ...2-1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
	6	Check & Fitting Support					/	
3 Month	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL UN = UNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY  นายพรชัย กรุดทอง
RECHECK BY CHIEF ENGINEER

CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 6/65

SMOKE EXHAUST FAN ...M1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System	/				/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
	6	Check & Fitting Support					/	
3 Month	7	Cleanning Air Grill Return	/					
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower					/	

N = NORMAL

UN = UNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE :

.....

.....

.....

COMMENT

.....

.....

RECORD BY


 นายพรชัย กรุดทอง
 RECHECK BY **CHIEF ENGINEER**

CENTRE POINT RATCHADAMRI

GRANDE CENTRE POINT RATCHADAMRI

MONTH 6/65

SMOKE EXHAUST FAN ...M2....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return	/					
	11	Tighting All Bolt/Nut Motor & Blower					/	

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY

นายพรชัย ฤกษ์ทอง
RECHECK BY CHIEF ENGINEER

CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 6/65

SMOKE EXHAUST FAN ...2-1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System	/				/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return	/					
	11	Tighting All Bolt/Nut Motor & Blower					/	

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY ... นายพรชัย อรุณทอง
RECHECK BY ... CHIEF ENGINEER