

Analysis/Test Report

Customer Name : CENTERLISE CO.,LTD.

Address : 45 Soi Sukhumvit 23 (Prasarnmit), Sukhumvit Road, Khlong Toei Nuac, Wattana, Bangkok. 10110

Sampling Site : Grande Centre Point Hotel (Ratchadamri)

Sample Type : Cooling Water

Sampling by : Customer

Sampling Method : Grab

Sampling Date : 12/09/2022

Sampling Time : -

Received Date : 14/09/2022

Analytical Date : 14 - 24/09/2022

Report Date : 26/09/2022

Report No. : RS20343/65

Parameters	Unit	Method	TS21477 /65
			Cooling Water
Legionella spp.	CFU/L	ISO 11731 : 2017	not detected
Sample Condition		Observation	Light Yellow, Clear

Miss NISACHOL EUNGKLIENG

Analyst

26/09/2022

บริษัท เทสท์ เทค จำกัด

Deputy Technical Manager

26/09/2022

Reported results refer to the sample as received only.

Test report shall not be reproduced except in full, without written approved of the laboratory.