

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 7 / 65

AHU NO....L1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					<input checked="" type="checkbox"/>	
		Cleanning Overall Inside Panel Control	<input checked="" type="checkbox"/>					
		Fitting All Inside Panel Control	<input checked="" type="checkbox"/>					
		Testing Overload		<input checked="" type="checkbox"/>			<input checked="" type="checkbox"/>	
	2	Check Operation		<input checked="" type="checkbox"/>				
	3	Check Motor& Blower		<input checked="" type="checkbox"/>				
	4	Check Belt		<input checked="" type="checkbox"/>				
	5	Check Bearing		<input checked="" type="checkbox"/>				
	6	Check&Cleaned Frame		<input checked="" type="checkbox"/>				
	7	Check & Fitting Support		<input checked="" type="checkbox"/>				
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 7/65

AHU NO....L2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH7/65.....

AHU NO....L3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 7/65

AHU NO....M1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY  RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 7/65

AHU NO....M2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
 R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 7 / 65

AHU NO....M3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 7/65

AHU NO....4-1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload						
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 7/65

AHU NO....4-2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 7/65

AHU NO....F1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

COMMENT

.....

.....

RECORD BY ...



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 7/65

AHU NO....F2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

COMMENT

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 6/65

AHU NO....L1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....


COMMENT

.....

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 06/65

AHU NO....L2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control	✓					
		Testing Overload					✓	
	2	Check Operation		✓				
	3	Check Motor& Blower		✓				
	4	Check Belt		✓				
	5	Check Bearing		✓				
	6	Check&Cleaned Frame		✓				
	7	Check & Fitting Support		✓				
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 8/65

AHU NO....L3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....


COMMENT

.....

.....

.....

RECORD BY ..



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 8/65

AHU NO....M1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 8/65

AHU NO....M2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control	✓					
		Testing Overload					✓	
	2	Check Operation		✓				
	3	Check Motor& Blower		✓				
	4	Check Belt		✓				
	5	Check Bearing		✓				
	6	Check&Cleaned Frame		✓				
	7	Check & Fitting Support		✓				
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....


COMMENT

.....

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 8/65

AHU NO....M3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 8/65

AHU NO....4-1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY .. 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 8/69

AHU NO....4-2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 8/65

AHU NO....F1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....


COMMENT

.....

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 8/65

AHU NO....F2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY .



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 9/65

AHU NO....L1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation						
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	/	/				
	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/	/				

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY ... 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 9/56.....

AHU NO....L2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply		/				
	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower		/				

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 9/65

AHU NO....L3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control	✓					
		Testing Overload					✓	
	2	Check Operation		✓				
	3	Check Motor& Blower		✓				
	4	Check Belt		✓				
	5	Check Bearing		✓				
	6	Check&Cleaned Frame		✓				
	7	Check & Fitting Support		✓				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply		✓				
	9	Tighting All Bolt/Nut Motor & Blower		✓				
	10	Cleanning Motor & Blower		✓				

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

9/56

SYSTEM & SAFETY

MONTH

AHU NO....M1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply	/	/				
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/	/				

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY ..



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 9/56

AHU NO....M2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply		/				
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower		/				

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 9/65

AHU NO....M3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply		/				
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower		/				

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 9/15

AHU NO....4-1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload		/			/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply		/				
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower		/				

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED

R = REPAIR P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 9/15

AHU NO....4-2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply		/				
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower		/				

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 9/69

AHU NO....F1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply	/	/				
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/	/				

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY ...



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 9/65

AHU NO....F2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply		/				
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower		/				

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 10/65

AHU NO....L1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 10/65.....

AHU NO....L2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 10/65

AHU NO....L3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					<u>/</u>	
		Cleanning Overall Inside Panel Control	<u>/</u>					
		Fitting All Inside Panel Control	<u>/</u>					
		Testing Overload					<u>/</u>	
	2	Check Operation		<u>/</u>				
	3	Check Motor& Blower		<u>/</u>				
	4	Check Belt		<u>/</u>				
	5	Check Bearing		<u>/</u>				
	6	Check&Cleaned Frame		<u>/</u>				
	7	Check & Fitting Support		<u>/</u>				
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....


COMMENT

.....

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH10/65.....

AHU NO....M1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 10/65

AHU NO....M2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....


COMMENT

.....

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 10/65

AHU NO....M3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY [REDACTED]

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 10/65

AHU NO....4-1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 10/65

AHU NO....4-2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 10/15

AHU NO....F1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 10/65

AHU NO....F2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 11/65.....

AHU NO....L1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY ... 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 11/65

AHU NO....L2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload		/				
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 11/15

AHU NO....L3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload		/				
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 11/15

AHU NO....M1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload		/				
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 11/165.....

AHU NO....M2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload		/				
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 11/65.....

AHU NO....M3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control	✓					
		Testing Overload		✓				
	2	Check Operation		✓				
	3	Check Motor& Blower		✓				
	4	Check Belt		✓				
	5	Check Bearing		✓				
	6	Check&Cleaned Frame		✓				
	7	Check & Fitting Support		✓				
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 11/65.....

AHU NO....4-1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control	✓					
		Testing Overload		✓				
	2	Check Operation		✓				
	3	Check Motor& Blower		✓				
	4	Check Belt		✓				
	5	Check Bearing		✓				
	6	Check&Cleaned Frame		✓				
	7	Check & Fitting Support		✓				
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED

R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 11/65

AHU NO....4-2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control	✓					
		Testing Overload		✓				
	2	Check Operation		✓				
	3	Check Motor& Blower		✓				
	4	Check Belt		✓				
	5	Check Bearing		✓				
	6	Check&Cleaned Frame		✓				
	7	Check & Fitting Support		✓				
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 11/65

AHU NO....F1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control	✓					
		Testing Overload		✓				
	2	Check Operation		✓				
	3	Check Motor& Blower		✓				
	4	Check Belt		✓				
	5	Check Bearing		✓				
	6	Check&Cleaned Frame		✓				
	7	Check & Fitting Support		✓				
3 Month	8	Cleanning Air Grill Return & Supply						
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 11/65

AHU NO....F2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control	✓					
		Testing Overload		✓				
	2	Check Operation		✓				
	3	Check Motor& Blower		✓				
	4	Check Belt		✓				
	5	Check Bearing		✓				
	6	Check&Cleaned Frame		✓				
	7	Check & Fitting Support		✓				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						
	9	Tighting All Bolt/Nut Motor & Blower						
	10	Cleanning Motor & Blower						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 12/65AHU NO....L1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control					/	
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply	/	/				
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower		/				
	10	Cleanning Motor & Blower	/					

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 12/65

AHU NO....L2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower					/	
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame	/	/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	/	/				
	9	Tighting All Bolt/Nut Motor & Blower	/	/				
	10	Cleanning Motor & Blower	/	/				

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 12/85

AHU NO....L3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/			/	
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame		/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply	/	/				
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower	/	/				
	10	Cleanning Motor & Blower	/	/				

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 12/65

AHU NO....M1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/			/	
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame	/	/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply	/	/				
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower	/	/				
	10	Cleanning Motor & Blower	/	/				

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 19/65

AHU NO....M2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Operation					/	
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame	/	/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	/	/				
	9	Tighting All Bolt/Nut Motor & Blower	/	/				
	10	Cleanning Motor & Blower	/	/				

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY ...



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH12/65.....

AHU NO....M3...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/			/	
		Testing Overload		/			/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame	/	/				
	7	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply	/	/				
	9	Tighting All Bolt/Nut Motor & Blower	/	/				
	10	Cleanning Motor & Blower	/	/				

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED

R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 12/05

AHU NO....4-1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/			/	
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame	/	/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply	/	/				
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower	/	/				
	10	Cleanning Motor & Blower	/	/				

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....


COMMENT

.....

.....

.....

RECORD BY ...



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 19/65

AHU NO....4-2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/			/	
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame	/	/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply	/	/				
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower	/	/				
	10	Cleanning Motor & Blower	/	/				

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED

R = REPAIR P = REPLACED

NOTE

.....

.....

.....


COMMENT

.....

.....

.....

RECORD BY ...



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 12/65

AHU NO....F1...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/			/	
		Testing Overload					/	
	2	Check Operation		/				
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame	/	/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply	/	/				
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower	/	/				
	10	Cleanning Motor & Blower	/	/				

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....


COMMENT

.....

.....

.....

RECORD BY ...



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 12/09

AHU NO....F2...

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/			/	
		Testing Overload					/	
	2	Check Operation		/			/	
	3	Check Motor& Blower		/				
	4	Check Belt		/				
	5	Check Bearing		/				
	6	Check&Cleaned Frame	/	/				
	7	Check & Fitting Support		/				
3 Month	8	Cleanning Air Grill Return & Supply	/	/				
Mar,Jun,Sep,Dec	9	Tighting All Bolt/Nut Motor & Blower	/	/				
	10	Cleanning Motor & Blower	/	/				

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....L....

MONTH7/65.....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control					/	
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Motor& Blower		/				
	3	Check Belt		/				
	4	Check Bearing	/	/				
3 Month Mar,Jun,Sep,Dec	5	Check&Cleaned Frame	/	/				
	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
	8	Cleanning Air Grill Return & Supply						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....7....

MONTH 7 / 69
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control					✓	
		Fitting All Inside Panel Control		✓				
		Testing Overload					✓	
	2	Check Motor& Blower		✓				
	3	Check Belt		✓				
	4	Check Bearing	✓	✓				
	5	Check&Cleaned Frame	✓	✓				
3 Month	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
	8	Cleanning Air Grill Return & Supply						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

COMMENT

.....

.....

RECORD BY  RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....L....

MONTH 4/65.....
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Motor& Blower		/				
	3	Check Belt		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame		/				
3 Month Mar,Jun,Sep,Dec	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
	8	Cleanning Air Grill Return & Supply						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE


.....

.....

COMMENT

.....

.....

RECORD BY ... 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....7....

MONTH 8/65
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Motor& Blower		/				
	3	Check Belt		/				
	4	Check Bearing		/				
3 Month	5	Check&Cleaned Frame		/				
	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
	8	Cleanning Air Grill Return & Supply						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ..



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....L....

MONTH 9/15
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month Mar,Jun,Sep,Dec	5	Check&Cleaned Frame	/					
	6	Tighting All Bolt/Nut Motor & Blower					/	
	7	Check & Fitting Support		/				
	8	Cleanning Air Grill Return & Supply		/				

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE


.....

.....

COMMENT

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....7....

MONTH ...9/65.....
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month Mar,Jun,Sep,Dec	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower		/				
	7	Check & Fitting Support		/				
	8	Cleanning Air Grill Return & Supply		/				

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....L....

MONTH 10/65.....
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control		✓				
		Testing Overload					✓	
	2	Check Motor& Blower					✓	
	3	Check Belt					✓	
	4	Check Bearing					✓	
3 Month	5	Check&Cleaned Frame					✓	
	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
Mar,Jun,Sep,Dec	8	Cleanning Air Grill Return & Supply						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....7....

MONTH 10/15
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month Mar,Jun,Sep,Dec	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
	8	Cleanning Air Grill Return & Supply						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....


.....

COMMENT

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....L....

MONTH 11/15
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control		✓				
		Testing Overload					✓	
	2	Check Motor& Blower					✓	
	3	Check Belt					✓	
	4	Check Bearing					✓	
3 Month Mar,Jun,Sep,Dec	5	Check&Cleaned Frame					✓	
	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
	8	Cleanning Air Grill Return & Supply						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

COMMENT

.....

.....

RECORD BY . 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....7....

MONTH 11/65
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Motor& Blower					/	
	3	Check Belt					/	
	4	Check Bearing					/	
3 Month <small>Mar,Jun,Sep,Dec</small>	5	Check&Cleaned Frame					/	
	6	Tighting All Bolt/Nut Motor & Blower						
	7	Check & Fitting Support						
	8	Cleanning Air Grill Return & Supply						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE


.....

.....

COMMENT

.....

.....

RECORD BY


RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....L....

MONTH 12/65
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/			/	
		Testing Overload					/	
	2	Check Motor& Blower		/				
	3	Check Belt		/				
	4	Check Bearing		/				
3 Month	5	Check&Cleaned Frame	/	/				
	6	Tighting All Bolt/Nut Motor & Blower		/				
	7	Check & Fitting Support	/	/				
	8	Cleanning Air Grill Return & Supply	/	/				

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY
EXHAUST FAN....7....

MONTH12/65.....
TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/			/	
		Testing Overload					/	
	2	Check Motor& Blower		/				
	3	Check Belt		/				
	4	Check Bearing		/				
3 Month Mar,Jun,Sep,Dec	5	Check&Cleaned Frame	/	/				
	6	Tighting All Bolt/Nut Motor & Blower		/				
	7	Check & Fitting Support	/	/				
	8	Cleanning Air Grill Return & Supply	/	/				

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....
.....
.....

COMMENT

.....
.....
.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 7/69

PRESSURIZE FAN 1

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/			/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower		/			/	
	4	Check Bearing		/				
	5	Check&Cleaned Frame		/				
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support		/				
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Damperes						
	10	Added Grease The Damper Motordrive						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

SYSTEM & SAFETY

MONTH 8/65

PRESSURIZE FAN 2

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Timer Operation		/				
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame		/				
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support		/				
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Damperes						
	10	Added Grease The Damper Motordrive						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....


COMMENT

.....

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 8/65

PRESSURIZE FAN 1

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Timer Operation		/				
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame		/				
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support		/				
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Damperes						
	10	Added Grease The Damper Motordrive						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

SYSTEM & SAFETY

MONTH 7/65

PRESSURIZE FAN 2

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control		/			/	
		Fitting All Inside Panel Control		/			/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame	/	/				
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support	/	/				
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Damperes						
	10	Added Grease The Damper Motordrive						

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 9/65

PRESSURIZE FAN 1

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload		/				
	2	Check Timer Operation		/				
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame		/				
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support		/				
	7	Cleanning Air Grill Return		/				
	8	Cleanning Relief Damper		/				
	9	Cleanning Supply Damperes		/				
	10	Added Grease The Damper Motordrive		/				

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED

R = REPAIR P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

SYSTEM & SAFETY

MONTH 9/69

PRESSURIZE FAN 2

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload		/				
	2	Check Timer Operation		/				
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame		/				
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support		/				
	7	Cleanning Air Grill Return		/				
	8	Cleanning Relief Damper		/				
	9	Cleanning Supply Damperes		/				
	10	Added Grease The Damper Motordrive		/				

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 10/65

PRESSURIZE FAN 1

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower					/	
	4	Check Bearing					/	
	5	Check&Cleaned Frame					/	
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support					/	
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Damperes						
	10	Added Grease The Damper Motordrive						

N = NORMAL AB = ABNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY .



RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

SYSTEM & SAFETY

MONTH 10/65

PRESSURIZE FAN 2

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload		/				
	2	Check Timer Operation		/				
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame		/				
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support		/				
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Damperes						
	10	Added Grease The Damper Motordrive						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 11/65

PRESSURIZE FAN 1

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓					
		Fitting All Inside Panel Control	✓					
		Testing Overload					✓	
	2	Check Timer Operation		✓				
	3	Check Motor& Blower		✓				
	4	Check Bearing		✓				
	5	Check&Cleaned Frame		✓				
3 Month Mar,Jun, Sep, Dec	6	Check & Fitting Support		✓				
	7	Cleanning Air Grill Return						
	8	Cleanning Relief Damper						
	9	Cleanning Supply Damperes						
	10	Added Grease The Damper Motordrive						

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

SYSTEM & SAFETY

MONTH 11/65

PRESSURIZE FAN 2

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Timer Operation		/				
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame		/				
	6	Check & Fitting Support		/				
	7	Cleanning Air Grill Return						
3 Month Mar,Jun,Sep,Dec	8	Cleanning Relief Damper						
	9	Cleanning Supply Damperes						
	10	Added Grease The Damper Motordrive						

N = NORMAL AB = ABNORMAL C = CLEANING A = ADJUST&ADDED

R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY ... 

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH19/69.....

PRESSURIZE FAN 1

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/			/	
		Testing Overload					/	
	2	Check Timer Operation		/			/	
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame		/				
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support		/				
	7	Cleanning Air Grill Return	/	/				
	8	Cleanning Relief Damper	/	/				
	9	Cleanning Supply Damperes	/					
	10	Added Grease The Damper Motordrive					/	

N = NORMAL

AB = ABNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY ...

RECHECK BY

GRANDE CENTRE POINT RATCHADAMRI

SYSTEM & SAFETY

MONTH12/05.....

PRESSURIZE FAN 2

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	AB
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/			/	
		Testing Overload					/	
	2	Check Timer Operation		/			/	
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame	/	/				
	6	Check & Fitting Support		/				
3 Month Mar,Jun,Sep,Dec	7	Cleanning Air Grill Return	/	/				
	8	Cleanning Relief Damper	/	/				
	9	Cleanning Supply Damperes	/	/				
	10	Added Grease The Damper Motordrive					/	

N = NORMAL

AB = ABNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....


COMMENT

.....

.....

.....

RECORD BY



RECHECK BY

CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 7/65

SMOKE EXHAUST FAN ...M1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/			/	
		Testing Overload					/	
	2	Check Timer Operation		/			/	
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame	/	/				
	6	Check & Fitting Support	/	/				
3 Month	7	Cleanning Air Grill Return						
Mar.,Jun, Sep, Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY



RECHECK BY

CENTRE POINT RATCHADAMRI

GRANDE CENTRE POINT RATCHADAMRI

MONTH 7/69

SMOKE EXHAUST FAN ...M2....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control	✓				✓	
		Fitting All Inside Panel Control		✓			✓	
		Testing Overload					✓	
	2	Check Timer Operation		✓				
	3	Check Motor& Blower		✓				
	4	Check Bearing		✓				
	5	Check&Cleaned Frame	✓	✓				
	6	Check & Fitting Support	✓	✓				
3 Month	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY



RECHECK BY

CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 7/65

SMOKE EXHAUST FAN ...2-1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/			/	
		Testing Overload					/	
	2	Check Timer Operation		/				
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame	/	/				
	6	Check & Fitting Support	/	/				
3 Month	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY



RECHECK BY

CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 4/65

SMOKE EXHAUST FAN ...M1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Timer Operation		/				
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame		/				
	6	Check & Fitting Support		/				
3 Month	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL UN = UNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY .. 

RECHECK BY

CENTRE POINT RATCHADAMRI

GRANDE CENTRE POINT RATCHADAMRI

MONTH 4/65

SMOKE EXHAUST FAN ...M2....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Timer Operation		/				
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame		/				
	6	Check & Fitting Support		/				
	7	Cleanning Air Grill Return						
3 Month Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL UN = UNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 8/65.....

SMOKE EXHAUST FAN ...2-1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control	/					
		Testing Overload					/	
	2	Check Timer Operation		/				
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame		/				
	6	Check & Fitting Support		/				
3 Month	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY ...



RECHECK BY

CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 9/65

SMOKE EXHAUST FAN ...M1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control		/				
		Fitting All Inside Panel Control		/				
		Testing Overload		/				
	2	Check Timer Operation		/				
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame		/				
	6	Check & Fitting Support		/				
3 Month	7	Cleanning Air Grill Return		/				
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower		/				

N = NORMAL UN = UNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

CENTRE POINT RATCHADAMRI

GRANDE CENTRE POINT RATCHADAMRI

MONTH 9/69

SMOKE EXHAUST FAN ...M2....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control		/				
		Fitting All Inside Panel Control		/				
		Testing Overload		/				
	2	Check Timer Operation		/				
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame		/				
	6	Check & Fitting Support		/				
3 Month	7	Cleanning Air Grill Return		/				
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower		/				

N = NORMAL

UN = UNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY 

RECHECK BY

CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 9/65

SMOKE EXHAUST FAN ...2-1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					<u>/</u>	
		Cleanning Overall Inside Panel Control		<u>/</u>				
		Fitting All Inside Panel Control		<u>/</u>				
		Testing Overload		<u>/</u>				
	2	Check Timer Operation		<u>/</u>				
	3	Check Motor& Blower		<u>/</u>				
	4	Check Bearing		<u>/</u>				
	5	Check&Cleaned Frame		<u>/</u>				
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support		<u>/</u>				
	7	Cleanning Air Grill Return		<u>/</u>				
	11	Tighting All Bolt/Nut Motor & Blower		<u>/</u>				

N = NORMAL UN = UNORMAL C = CLEANNING A = ADJUST&ADDED
R = REPAIR P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 10/65

SMOKE EXHAUST FAN ...M1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control		/				
		Fitting All Inside Panel Control		/				
		Testing Overload		/				
	2	Check Timer Operation		/				
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame		/				
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support		/				
	7	Cleanning Air Grill Return						
	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY



RECHECK BY

CENTRE POINT RATCHADAMRI

GRANDE CENTRE POINT RATCHADAMRI

MONTH 10/65

SMOKE EXHAUST FAN ...M2....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control		/				
		Fitting All Inside Panel Control		/				
		Testing Overload		/				
	2	Check Timer Operation		/				
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame		/				
	6	Check & Fitting Support		/				
3 Month	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY 

RECHECK BY

CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 10/65

SMOKE EXHAUST FAN ...2-1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/					
		Fitting All Inside Panel Control		/				
		Testing Overload		/				
	2	Check Timer Operation		/				
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame		/				
	6	Check & Fitting Support		/				
3 Month	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY  ..

RECHECK BY

CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 11/65

SMOKE EXHAUST FAN ...M1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control		✓				
		Fitting All Inside Panel Control		✓				
		Testing Overload		✓				
	2	Check Timer Operation		✓				
	3	Check Motor& Blower		✓				
	4	Check Bearing		✓				
	5	Check&Cleaned Frame		✓				
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support		✓				
	7	Cleanning Air Grill Return						
	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY 

RECHECK BY

CENTRE POINT RATCHADAMRI

GRANDE CENTRE POINT RATCHADAMRI

MONTH 11/65.....

SMOKE EXHAUST FAN ...M2....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					✓	
		Cleanning Overall Inside Panel Control		✓				
		Fitting All Inside Panel Control		✓				
		Testing Overload		✓				
	2	Check Timer Operation		✓				
	3	Check Motor& Blower		✓				
	4	Check Bearing		✓				
	5	Check&Cleaned Frame		✓				
3 Month	6	Check & Fitting Support		✓				
	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY 

RECHECK BY

CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 11/15

SMOKE EXHAUST FAN ...2-1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control		/				
		Fitting All Inside Panel Control		/				
		Testing Overload		/				
	2	Check Timer Operation		/				
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame		/				
	6	Check & Fitting Support		/				
3 Month	7	Cleanning Air Grill Return						
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower						

N = NORMAL

UN = UNORMAL

C = CLEANING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....


.....

.....

COMMENT

.....

.....

RECORD BY 

RECHECK BY

CENTRE POINT RATCHADAMRI
MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 19/65

SMOKE EXHAUST FAN ...M1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/			/	
		Testing Overload					/	
	2	Check Timer Operation		/			/	
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame	/	/				
	6	Check & Fitting Support		/				
3 Month	7	Cleanning Air Grill Return	/	/				
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower					/	

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

RECORD BY



RECHECK BY

CENTRE POINT RATCHADAMRI

GRANDE CENTRE POINT RATCHADAMRI

MONTH 12/65

SMOKE EXHAUST FAN ...M2....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/			/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame	/	/				
3 Month Mar,Jun,Sep,Dec	6	Check & Fitting Support		/				
	7	Cleanning Air Grill Return	/	/				
	11	Tighting All Bolt/Nut Motor & Blower					/	

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....

.....

COMMENT

.....

.....

.....

RECORD BY

RECHECK BY

CENTRE POINT RATCHADAMRI

MAINTENANCE REPORT

SYSTEM & SAFETY

MONTH 12/65

SMOKE EXHAUST FAN ...2-1....

TIME

TIME	ITEM	DESCRIPTION MAINTENANCE	WORKING REMARKS			WORKING RESULT		
			C	A	R	P	N	UN
1 Month	1	Testing Control System					/	
		Cleanning Overall Inside Panel Control	/				/	
		Fitting All Inside Panel Control		/			/	
		Testing Overload					/	
	2	Check Timer Operation					/	
	3	Check Motor& Blower		/				
	4	Check Bearing		/				
	5	Check&Cleaned Frame	/	/				
	6	Check & Fitting Support		/				
3 Month	7	Cleanning Air Grill Return	/	/				
Mar,Jun,Sep,Dec	11	Tighting All Bolt/Nut Motor & Blower					/	

N = NORMAL

UN = UNORMAL

C = CLEANNING

A = ADJUST&ADDED

R = REPAIR

P = REPLACED

NOTE

.....

.....


.....

COMMENT

.....

.....

RECORD BY



RECHECK BY