

## ANALYSIS REPORT

**PROJECT NAME** : การตรวจวัดคุณภาพสิ่งแวดล้อม และการตรวจสอบการปฏิบัติตามมาตรฐานการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม  
โครงการ GRANDE CENTRE POINT HOTEL RATCHADAMRI ประจำปี 2565

**CUSTOMER NAME** : L&H HOTEL MANAGEMENT COMPANY LIMITED

**ADDRESS** : 153/2 SOI MAHATLEK LUANG 1 RATCHADAMRI ROAD LUMPHINI PATHUM WAN BANGKOK 10330

**CONTACT INFORMATION** : TEL : 08 1926 3779 e-mail : pornchai.k@gcphotels.com

**SAMPLING SOURCE** : GRANDE CENTRE POINT HOTEL RATCHADAMRI

**SAMPLE TYPE** : WASTEWATER

**SAMPLING DATE** : NOVEMBER 2, 2022

**SAMPLING TIME** : 15:05 HOUR

**SAMPLING METHOD** : GRAB, GRAB AND STERILE TECHNIQUE

**SAMPLING BY** : MR WEERAYUT MOKKAEW

**ANALYZED BY** : MISS AMONRAT PUTTALEE

**RECEIVED DATE** : NOVEMBER 2, 2022

**ANALYTICAL DATE** : NOVEMBER 2-9, 2022

**REPORT NO.** : 2022-U089373

**WORK NO.** : 2021-006040

**ANALYSIS NO.** : T22AV763-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			บ่อปรับสภาพน้ำ T22AV763-0001	
pH <sup>a</sup>	-	ELECTROMETRIC METHOD AT SITE (SM:4500-H <sup>+</sup> B)	7.0 (30°C)	-
BIOCHEMICAL OXYGEN DEMAND <sup>c</sup>	mg/L	AZIDE MODIFICATION METHOD (SM: 4500-O C AND 5210 B)	220	2.0
SUSPENDED SOLIDS <sup>a</sup>	mg/L	SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: 2540 D)	478	5.0
TOTAL DISSOLVED SOLIDS <sup>b</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAO.007 (TOTAL DISSOLVED SOLIDS DRIED AT 103-105 °C); SM 2540 C	316	25
SULPHIDE <sup>b</sup>	mg/L	IODOMETRIC METHOD (SM: 4500-S <sup>2-</sup> F)	1.6	0.50
TOTAL KJELDAHL NITROGEN <sup>b</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: 4500-Norg C	90.9	1.5
FAT, OIL AND GREASE <sup>a</sup>	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: 5520 B)	17	3
<b>MICROBIOLOGY</b>				
COLIFORM BACTERIA <sup>b</sup>	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: 9221 B)	>160,000	1.8
<b>SAMPLE CONDITION</b> WATER'S COLOUR/TURBID SEDIMENT			YELLOW/TURBID BROWN	

<sup>a</sup> : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

<sup>b</sup> : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

<sup>c</sup> : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

IN-HOUSE : BASED ON STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

*Benjawan V.*

(MISS BENJAWAN VIRIYOTHA)  
LABORATORY SUPERVISOR

NOVEMBER 15, 2022



## ANALYSIS REPORT

**PROJECT NAME** : การตรวจวัดคุณภาพสิ่งแวดล้อม และการตรวจสอบการปฏิบัติตามมาตรฐานการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม  
โครงการ GRANDE CENTRE POINT HOTEL RATCHADAMRI ประจำปี 2565

**CUSTOMER NAME** : L&H HOTEL MANAGEMENT COMPANY LIMITED

**ADDRESS** : 153/2 SOI MAHATLEK LUANG 1 RATCHADAMRI ROAD LUMPHINI PATHUM WAN BANGKOK 10330

**CONTACT INFORMATION** : TEL : 08 1926 3779 e-mail : pornchai.k@gcphotels.com

**SAMPLING SOURCE** : GRANDE CENTRE POINT HOTEL RATCHADAMRI

**SAMPLE TYPE** : EFFLUENT **RECEIVED DATE** : NOVEMBER 2, 2022

**SAMPLING DATE** : NOVEMBER 2, 2022 **ANALYTICAL DATE** : NOVEMBER 2-9, 2022

**SAMPLING TIME** : 14:55 HOUR **REPORT NO.** : 2022-U089374

**SAMPLING METHOD** : GRAB, GRAB AND STERILE TECHNIQUE **WORK NO.** : 2021-006040

**SAMPLING BY** : MR WEERAYUT MOKKAEW **ANALYSIS NO.** : T22AV763-0002

**ANALYZED BY** : MISS AMONRAT PUTTALEE

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			ข้อมูลน้ำทิ้ง T22AV763-0002		
pH <sup>a</sup>	-	ELECTROMETRIC METHOD AT SITE (SM:4500-H <sup>+</sup> B)	6.2 (30°C)	5-9	-
BIOCHEMICAL OXYGEN DEMAND <sup>c</sup>	mg/L	AZIDE MODIFICATION METHOD (SM: 4500-O C AND 5210 B)	13.6	≤ 20	2.0
SUSPENDED SOLIDS <sup>a</sup>	mg/L	SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: 2540 D)	36.9	≤ 30	5.0
TOTAL DISSOLVED SOLIDS <sup>b</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAO.007 (TOTAL DISSOLVED SOLIDS DRIED AT 103-105 °C); SM 2540 C	412	500*	25
SETTLABLE SOLIDS <sup>c</sup>	mL/L	IMHOFF CONE (SM: 2540 F)	9.0	≤ 0.5	0.1
SULPHIDE <sup>b</sup>	mg/L	IODOMETRIC METHOD (SM: 4500-S <sup>2-</sup> F)	< 0.50	≤ 1.0	0.50
TOTAL KJELDAHL NITROGEN <sup>b</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: 4500-Norg C	10.7	≤ 35	1.5
FAT, OIL AND GREASE <sup>a</sup>	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: 5520 B)	ND	≤ 20	3
RESIDUAL CHLORINE <sup>c</sup>	mg/L Cl <sub>2</sub>	MODIFIED DPD COLOURIMETRIC METHOD (AT SITE)	ND	-	0.1



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			บ่อสูบน้ำทิ้ง T22AV763-0002		
MICROBIOLOGY					
COLIFORM BACTERIA <sup>b</sup>	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: 9221 B)	>160,000	-	1.8
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			YELLOW/TURBID  BROWN		

<sup>a</sup> : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

<sup>b</sup> : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

<sup>c</sup> : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

IN-HOUSE : BASED ON STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS A, NOTIFICATION OF THE  
MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 122,  
PART 125 D, DATED DECEMBER 29, 2005.

500\* : PERMITTED EXCESS VALUE TO TOTAL DISSOLVED SOLIDS OF ACTUAL TAP WATER USED  
(TOTAL DISSOLVED SOLIDS STANDARD VALUE OF TAP WATER QUALITY IS 1,000 mg/L).

ND : NON-DETECTABLE.

*Benjawan V.*

(MISS BENJAWAN VIRIYOTHAI)  
LABORATORY SUPERVISOR

NOVEMBER 15, 2022



## ANALYSIS REPORT

**PROJECT NAME** : การตรวจวัดคุณภาพสิ่งแวดล้อม และการตรวจสอบการปฏิบัติตามมาตรฐานการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม  
โครงการ GRANDE CENTRE POINT HOTEL RATCHADAMRI ประจำปี 2565  
**CUSTOMER NAME** : L&H HOTEL MANAGEMENT COMPANY LIMITED  
**ADDRESS** : 153/2 SOI MAHATLEK LUANG 1 RATCHADAMRI ROAD LUMPHINI PATHUM WAN BANGKOK 10330  
**CONTACT INFORMATION** : TEL : 08 1926 3779 e-mail : pornchai.k@gcphotels.com  
**SAMPLING SOURCE** : GRANDE CENTRE POINT HOTEL RATCHADAMRI  
**SAMPLE TYPE** : WATER SAMPLE FROM SWIMMING POOL  
**SAMPLING DATE** : NOVEMBER 2, 2022  
**SAMPLING TIME** : 14:50 HOUR  
**SAMPLING METHOD <sup>c</sup>** : GRAB AND STERILE TECHNIQUE  
**SAMPLING BY <sup>c</sup>** : MR WEERAYUT MOKKAEW  
**ANALYZED BY** : MISS ITSARIYAPORN BUATIB

**RECEIVED DATE** : NOVEMBER 2, 2022  
**ANALYTICAL DATE** : NOVEMBER 2-9, 2022  
**REPORT NO.** : 2022-U089375  
**WORK NO.** : 2021-006040  
**ANALYSIS NO.** : T22AV763-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			SWIMMING POOL T22AV763-0003		
MICROBIOLOGY					
COLIFORM BACTERIA <sup>b</sup>	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: 9221 B)	< 1.1	< 10	1.1
<i>E. coli</i> <sup>b</sup>	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: 9221 D AND F)	NOT DETECTED	NOT DETECTED	-
STANDARD PLATE COUNT <sup>b</sup>	CFU/mL	STANDARD PLATE COUNT (SM: 9215 B)	< 1	-	1
SAMPLE CONDITION					
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR		
SEDIMENT			-		

<sup>a</sup> : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

<sup>b</sup> : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

<sup>c</sup> : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIEMENTAL TO HEALTH, B.E. 2530 (1987).

*Chaweevan B.*

(MISS CHAWEEVAN BOONLA)  
LABORATORY SUPERVISOR

NOVEMBER 15, 2022

