

## ANALYSIS REPORT

**CUSTOMER NAME** : AIA SATHORN TOWER  
**ADDRESS** : 11/1 SOUTH SATHORN ROAD YAN NAWA SATHON BANGKOK 10120  
**CONTACT INFORMATION** : TEL : 0 2286 5929 Ext.130 e-mail : Waipoj.thongngam@ap.jll.com  
**SAMPLING SOURCE** : AIA SATHORN TOWER  
**SAMPLE TYPE** : EFFLUENT  
**SAMPLING DATE** : AUGUST 5, 2022  
**SAMPLING TIME** : 11:00 HOUR  
**SAMPLING METHOD** : GRAB, GRAB AND STERILE TECHNIQUE  
**SAMPLING BY** : MR WEERAYUT MOKKAEW  
**ANALYZED BY** : MISS PORNPIMOL WAENTHONG

**RECEIVED DATE** : AUGUST 5, 2022  
**ANALYTICAL DATE** : AUGUST 5-17, 2022  
**REPORT NO.** : 2022-U063920  
**WORK NO.** : 2020-003066  
**ANALYSIS NO.** : T22AP429-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			บ่อพักน้ำสุดท้าย พร้อมตะแกรงดักขยะ T22AP429-0001		
pH <sup>a</sup>	-	ELECTROMETRIC METHOD AT SITE (SM:4500-H <sup>+</sup> B)	7.8 (30°C)	5-9	-
BIOCHEMICAL OXYGEN DEMAND <sup>c</sup>	mg/L	AZIDE MODIFICATION METHOD (SM: 4500-O C AND 5210 B)	11.6	≤ 20	2.0
SUSPENDED SOLIDS <sup>a</sup>	mg/L	SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: 2540 D)	ND	≤ 30	5.0
TOTAL DISSOLVED SOLIDS <sup>b</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAO.007 (TOTAL DISSOLVED SOLIDS DRIED AT 103-105 °C); SM 2540 C	486	500*	25
SETTLEABLE SOLIDS <sup>c</sup>	mL/L	IMHOFF CONE (SM: 2540 F)	< 0.1	≤ 0.5	0.1
SULPHIDE <sup>b</sup>	mg/L	IODOMETRIC METHOD (SM: 4500-S <sup>2-</sup> F)	< 0.50	≤ 1.0	0.50
TOTAL KJELDAHL NITROGEN <sup>b</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: 4500-Norg C	7.2	≤ 35	1.5
FAT, OIL AND GREASE <sup>a</sup>	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: 5520 B)	ND	≤ 20	3



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			บ่อพักน้ำสุดท้าย พร้อมตะแกรงดักขยะ T22AP429-0001		
MICROBIOLOGY					
COLIFORM BACTERIA <sup>b</sup>	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: 9221 B)	5,400	-	1.8
FAECAL COLIFORM BACTERIA <sup>b</sup>	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: 9221 E)	5,400	-	1.8
SAMPLE CONDITION					
WATER'S COLOUR/TURBID			YELLOW/CLEAR		
SEDIMENT			BROWN		

<sup>a</sup> : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

<sup>b</sup> : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

<sup>c</sup> : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

IN-HOUSE : BASED ON STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS A, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 122, PART 125 D, DATED DECEMBER 29, 2005.

500\* : PERMITTED EXCESS VALUE TO TOTAL DISSOLVED SOLIDS OF ACTUAL TAP WATER USED  
(TOTAL DISSOLVED SOLIDS STANDARD VALUE OF TAP WATER QUALITY IS 1,000 mg/L).

ND : NON-DETECTABLE.

*Piyapat S.*

(MRS PIYAPAT SUTTAMANUTWONG)  
LABORATORY SUPERVISOR

AUGUST 17, 2022

## ANALYSIS REPORT

**CUSTOMER NAME** : AIA SATHORN TOWER  
**ADDRESS** : 11/1 SOUTH SATHORN ROAD YAN NAWA SATHON BANGKOK 10120  
**CONTACT INFORMATION** : TEL : 0 2286 5929 Ext.130 e-mail : Waipoj.thongngam@ap.jll.com  
**SAMPLING SOURCE** : AIA SATHORN TOWER  
**SAMPLE TYPE** : WASTEWATER  
**SAMPLING DATE** : AUGUST 5, 2022  
**SAMPLING TIME** : 11:10 HOUR  
**SAMPLING METHOD** : GRAB, GRAB AND STERILE TECHNIQUE  
**SAMPLING BY** : MR WEERAYUT MOKKAEW  
**ANALYZED BY** : MISS PORNPIMOL WAENTHONG

**RECEIVED DATE** : AUGUST 5, 2022  
**ANALYTICAL DATE** : AUGUST 5-17, 2022  
**REPORT NO.** : 2022-U063921  
**WORK NO.** : 2020-003066  
**ANALYSIS NO.** : T22AP429-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			บอกรับสภาพ T22AP429-0002	
pH <sup>a</sup>	-	ELECTROMETRIC METHOD AT SITE (SM:4500-H <sup>+</sup> B)	7.9 (30°C)	-
BIOCHEMICAL OXYGEN DEMAND <sup>c</sup>	mg/L	AZIDE MODIFICATION METHOD (SM: 4500-O C AND 5210 B)	68.0	2.0
SUSPENDED SOLIDS <sup>a</sup>	mg/L	SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: 2540 D)	25.9	5.0
TOTAL DISSOLVED SOLIDS <sup>b</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAO.007 (TOTAL DISSOLVED SOLIDS DRIED AT 103-105 °C); SM 2540 C	486	25
SETTLABLE SOLIDS <sup>c</sup>	mL/L	IMHOFF CONE (SM: 2540 F)	0.1	0.1
SULPHIDE <sup>b</sup>	mg/L	IODOMETRIC METHOD (SM: 4500-S <sup>2-</sup> F)	< 0.50	0.50
TOTAL KJELDAHL NITROGEN <sup>b</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: 4500-Norg C	47.8	1.5
FAT, OIL AND GREASE <sup>a</sup>	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: 5520 B)	ND	3
<b>MICROBIOLOGY</b>				
COLIFORM BACTERIA <sup>b</sup>	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: 9221 B)	>160,000	1.8
FAECAL COLIFORM BACTERIA <sup>b</sup>	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: 9221 E)	>160,000	1.8
<b>SAMPLE CONDITION</b>				
WATER'S COLOUR/TURBID			YELLOW/TURBID	
SEDIMENT			BROWN	

<sup>a</sup> : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

<sup>b</sup> : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

<sup>c</sup> : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

IN-HOUSE : BASED ON STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

ND : NON-DETECTABLE.

*Piyapat S.*

(MRS PIYAPAT SUTTAMANUTWONG)  
LABORATORY SUPERVISOR

AUGUST 17, 2022





## ANALYSIS REPORT

**CUSTOMER NAME** : AIA SATHORN TOWER  
**ADDRESS** : 11/1 SOUTH SATHORN ROAD YAN NAWA SATHON BANGKOK 10120  
**CONTACT INFORMATION** : TEL : 0 2286 5929 Ext.130 e-mail : Waipoj.thongngam@ap.jll.com  
**SAMPLING SOURCE** : AIA SATHORN TOWER  
**SAMPLE TYPE** : EFFLUENT  
**SAMPLING DATE** : AUGUST 5, 2022  
**SAMPLING TIME** : 11:05 HOUR  
**SAMPLING METHOD** : GRAB, GRAB AND STERILE TECHNIQUE  
**SAMPLING BY** : MR WEERAYUT MOKKAEW  
**ANALYZED BY** : MISS PORNPIMOL WAENTHONG

**RECEIVED DATE** : AUGUST 5, 2022  
**ANALYTICAL DATE** : AUGUST 5-17, 2022  
**REPORT NO.** : 2022-U063922  
**WORK NO.** : 2020-003066  
**ANALYSIS NO.** : T22AP429-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			บอพักน้ำใส T22AP429-0003		
pH <sup>a</sup>	-	ELECTROMETRIC METHOD AT SITE (SM:4500-H <sup>+</sup> B)	8.2 (30°C)	5-9	-
BIOCHEMICAL OXYGEN DEMAND <sup>c</sup>	mg/L	AZIDE MODIFICATION METHOD (SM: 4500-O C AND 5210 B)	15.1	≤ 20	2.0
SUSPENDED SOLIDS <sup>a</sup>	mg/L	SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: 2540 D)	6.2	≤ 30	5.0
TOTAL DISSOLVED SOLIDS <sup>b</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAO.007 (TOTAL DISSOLVED SOLIDS DRIED AT 103-105 °C); SM 2540 C	426	500*	25
SETTLABLE SOLIDS <sup>c</sup>	mL/L	IMHOFF CONE (SM: 2540 F)	< 0.1	≤ 0.5	0.1
SULPHIDE <sup>b</sup>	mg/L	IODOMETRIC METHOD (SM: 4500-S <sup>2-</sup> F)	< 0.50	≤ 1.0	0.50
TOTAL KJELDAHL NITROGEN <sup>b</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: 4500-Norg C	35.4	≤ 35	1.5
FAT, OIL AND GREASE <sup>a</sup>	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: 5520 B)	ND	≤ 20	3



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			บ่อพักน้ำใส T22AP429-0003		
MICROBIOLOGY					
FAECAL COLIFORM BACTERIA <sup>b</sup>	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: 9221 E)	5,400	-	1.8
COLIFORM BACTERIA <sup>b</sup>	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: 9221 B)	9,200	-	1.8
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			YELLOW/CLEAR  BROWN		

<sup>a</sup> : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

<sup>b</sup> : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

<sup>c</sup> : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

IN-HOUSE : BASED ON STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS A, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 122, PART 125 D, DATED DECEMBER 29, 2005.

500\* : PERMITTED EXCESS VALUE TO TOTAL DISSOLVED SOLIDS OF ACTUAL TAP WATER USED  
(TOTAL DISSOLVED SOLIDS STANDARD VALUE OF TAP WATER QUALITY IS 1,000 mg/L).

ND : NON-DETECTABLE.

*Piyapat S.*

(MRS PIYAPAT SUTTAMANUTWONG)  
LABORATORY SUPERVISOR

AUGUST 17, 2022

## ANALYSIS REPORT

**CUSTOMER NAME** : AIA SATHORN TOWER  
**ADDRESS** : 11/1 SOUTH SATHORN ROAD YAN NAWA SATHON BANGKOK 10120  
**CONTACT INFORMATION** : TEL : 0 2286 5929 Ext.130 e-mail : Waipoj.thongngam@ap.jll.com  
**SAMPLING SOURCE** : AIA SATHORN TOWER  
**SAMPLE TYPE** : WATER SUPPLY  
**SAMPLING DATE** : AUGUST 5, 2022  
**SAMPLING TIME** : 11:15 HOUR  
**SAMPLING METHOD <sup>c</sup>** : GRAB  
**SAMPLING BY <sup>c</sup>** : MR WEERAYUT MOKKAEW  
**ANALYZED BY** : MISS PORNPIMOL WAENTHONG

**RECEIVED DATE** : AUGUST 5, 2022  
**ANALYTICAL DATE** : AUGUST 5-10, 2022  
**REPORT NO.** : 2022-U062220  
**WORK NO.** : 2021-004258  
**ANALYSIS NO.** : T22AP430-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			WATER SUPPLY T22AP430-0001	
TOTAL DISSOLVED SOLIDS <sup>b</sup>	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: 2540 C)	197	25
<b>SAMPLE CONDITION</b> WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

<sup>a</sup> : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

<sup>b</sup> : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

<sup>c</sup> : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

*Piyapat S.*

(MRS PIYAPAT SUTTAMANUTWONG)  
LABORATORY SUPERVISOR

AUGUST 15, 2022

