

## **ภาคผนวก 7**

**เอกสารรายงานการตรวจสอบคุณภาพสระว่ายน้ำ  
ประจำเดือน กรกฎาคม - ธันวาคม 2565**

เอกสารรายงานการตรวจสอบคุณภาพสระว่ายน้ำประจำเดือน กรกฎาคม - ธันวาคม 2565

FYNN SUKHUMVIT 31		FYNN SUKHUMVIT 31		INFINITE CO		
SUKHUMVIT 31		Check Chlorine Swimming Pool		property management and consultant co.,ltd		
Month :- JUL 2022						
Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	7.6	1.5	7.6	PK	
2	1.5	7.6	1.5	7.6	PK	
3	1.5	7.6	1.5	7.6	PK	
4	1.5	7.6	1.5	7.6	PK	
5	1.5	7.6	1.5	7.6	PK	
6	1.5	7.6	1.5	7.6	PK	
7	1.5	7.6	1.5	7.6	PK	
8	1.5	7.6	1.5	7.6	PK	
9	1.5	7.6	1.5	7.6	PK	
10	1.5	7.6	1.5	7.6	PK	
11	1.5	7.6	1.5	7.6	PK	
12	1.5	7.6	1.5	7.6	PK	
13	1.5	7.6	1.5	7.6	PK	
14	1.5	7.6	1.5	7.6	PK	
15	1.5	7.6	1.5	7.6	PK	
16	1.5	7.6	1.5	7.6	PK	
17	1.5	7.6	1.5	7.6	PK	
18	1.5	7.6	1.5	7.6	PK	
19	1.5	7.6	1.5	7.6	PK	
20					PK	
21					PK	
22					PK	
23					PK	
24					PK	
25					PK	
26					PK	
27					PK	
28					PK	
29	3.0	7.6	3.0	7.6	PK	
30	3.0	7.6	3.0	7.6	PK	
31	3.0	7.6	3.0	7.6	PK	

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C

Month : สิงหาคม 2565

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	3.0	7.6	3.0	7.6		Sign
2	3.0	7.6	3.0	7.6		Sign
3	3.0	7.6	3.0	7.6		Sign
4	3.0	7.6	3.0	7.6		Sign
5	3.0	7.6	3.0	7.6		Sign
6	3.0	7.6	3.0	7.6		Sign
7	3.0	7.6	3.0	7.6		Sign
8	3.0	7.6	3.0	7.6		Sign
9	1.5	7.2	1.5	7.2		Sign
10	1.5	7.2	1.5	7.2		Sign
11	1.5	7.2	1.5	7.2		Sign
12	1.5	7.2	1.5	7.2		Sign
13	1.5	7.2	1.5	7.2		Sign
14	1.5	7.6	1.5	7.6		Sign
15	1.5	7.6	1.5	7.6		Sign
16	1.5	7.6	1.5	7.6		Sign
17	1.5	7.6	1.5	7.6		Sign
18	1.5	7.6	1.5	7.6		Sign
19	1.5	7.6	1.5	7.6		Sign
20	1.5	7.6	1.5	7.6		Sign
21	1.5	7.6	1.5	7.6		Sign
22	1.5	7.6	1.5	7.6		Sign
23	1.5	7.6	1.5	7.6		Sign
24	1.5	7.6	1.5	7.6		Sign
25	1.5	7.6	1.5	7.6		Sign
26	1.5	7.6	1.5	7.6		Sign
27	1.5	7.6	1.5	7.6		Sign
28	1.5	7.6	1.5	7.6		Sign
29	1.5	7.6	1.5	7.6		Sign
30	1.5	7.6	1.5	7.6		Sign
31						

**Remark : Spa and Swimming Pool Water Quality**

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



Month : สิงหาคม 2565

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	7.6	1.5	7.1	Shom	
2	1.5	7.6	1.5	7.6	Shom	
3	1.5	7.6	1.5	7.6	Shom	
4	1.3	7.6	1.5	7.6	Shom	
5	1.5	7.6	1.5	7.6	Shom	
6	1.5	7.6	1.5	7.6	Shom	
7	1.5	7.6	1.5	7.6	Shom	
8	1.5	7.6	1.5	7.6	Shom	
9	1.5	7.6	1.5	7.6	Shom	
10	3.0	7.6	3.0	7.6	Shom	1ตัว/คน/วัน/ลิตร
11	3.0	7.6	3.0	7.6	Shom	จากค่าเฉลี่ย
12	3.0	7.6	3.0	7.6	Shom	11กิโลลิตร
13	3.0	7.6	3.0	7.6	Shom	
14	1.3	7.6	3.0	7.1	Shom	
15	1.5	7.6	1.5	7.6	Shom	
16	1.5	7.6	1.5	7.6	Shom	
17	1.5	7.6	1.5	7.6	Shom	
18	1.3	7.6	1.5	7.6	Shom	
19	1.5	7.6	1.5	7.6	Shom	
20	1.5	7.6	1.5	7.6	Shom	
21	1.5	7.6	1.5	7.6	Shom	
22	3.0	7.6	3.0	7.6	Shom	
23	3.0	7.6	3.0	7.6	Shom	
24	3.0	7.6	3.0	7.6	Shom	
25	3.0	7.6	3.0	7.6	Shom	
26	3+	7.6	3.0	7.6	Shom	
27	3+	7.6	3.0	7.6	Shom	
28	3+	7.6	3+	7.6	Shom	
29	3+	7.6	3+	7.6	Shom	
30	3+	7.6	3+	7.6	Shom	
31						

**Remark : Spa and Swimming Pool Water Quality**

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C

Month : พฤษภาคม 2565

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	3.7	7.2	3.7	7.2	Phon	
2	3.7	7.2	3.7	7.2	Phon	
3	3.7	7.2	3.7	7.2	Phon	
4	3.7	7.2	3.7	7.2	Phon	
5	3.7	7.2	3.7	7.2	Phon	
6	3.7	7.2	3.7	7.2	Phon	
7	3.7	7.2	3.7	7.2	Phon	
8	3.7	7.2	3.7	7.2	Phon	
9	3.7	7.2	3.7	7.2	Phon	
10	3.7	7.2	3.7	7.2	Phon	
11	3.7	7.2	3.7	7.2	Phon	
12	3.0	7.2	3.0	7.2	Phon	
13	3.0	7.2	3.0	7.2	Phon	
14	3.0	7.8	3.0	7.6	Phon	
15	3.0	7.6	3.0	7.6	Phon	
16	3.0	7.6	3.0	7.6	Phon	
17	3.0	7.6	3.0	7.6	Phon	
18	3.0	7.6	3.0	7.6	Phon	
19	3.0	7.6	3.0	7.6	Phon	
20	3.0	7.6	3.0	7.6	Phon	
21	3.0	7.6	3.0	7.6	Phon	
22	3.0	7.6	3.0	7.6	Phon	
23	3.0	7.6	3.0	7.6	Phon	
24	3.0	7.6	3.0	7.6	Phon	
25	3.0	7.6	3.0	7.6	Phon	
26	3.0	7.6	3.0	7.6	Phon	
27	3.0	7.6	3.0	7.6	Phon	
28	3.0	7.6	3.0	7.6	Phon	
29	1.5	7.2	1.5	7.2	Phon	
30	1.5	7.2	1.5	7.2	Phon	
31	1.5	7.2	1.5	7.2	Phon	

**Remark : Spa and Swimming Pool Water Quality**

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



Month : Nov 2015

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	7.6	1.5	7.6	<i>[Signature]</i>	
2	1.5	7.6	1.5	7.6	<i>[Signature]</i>	
3	1.5	7.6	1.5	7.6	<i>[Signature]</i>	
4	1.5	7.6	1.5	7.6	<i>[Signature]</i>	
5	1.5	7.6	1.5	7.6	<i>[Signature]</i>	
6	1.5	7.6	1.5	7.6	<i>[Signature]</i>	
7	1.5	7.6	1.5	7.6	<i>[Signature]</i>	
8	1.5	7.6	1.5	7.6	<i>[Signature]</i>	
9	1.5	7.6	1.5	7.6	<i>[Signature]</i>	
10	3.0	7.2	3.0	7.2	<i>[Signature]</i>	
11	3.0	7.2	3.0	7.2	<i>[Signature]</i>	
12	3.0	7.2	3.0	7.2	<i>[Signature]</i>	
13	3.0	7.2	3.0	7.2	<i>[Signature]</i>	
14	3.0	7.2	3.0	7.2	<i>[Signature]</i>	
15	3.0	7.2	3.0	7.2	<i>[Signature]</i>	
16	3.0	7.2	3.0	7.2	<i>[Signature]</i>	
17	3.0	7.2	3.0	7.2	<i>[Signature]</i>	
18	3.0	7.2	3.0	7.2	<i>[Signature]</i>	
19	3.0	7.6	3.0	7.6	<i>[Signature]</i>	
20	3.0	7.6	3.0	7.6	<i>[Signature]</i>	
21	3.0	7.6	3.0	7.6	<i>[Signature]</i>	
22	3.0	7.6	3.0	7.6	<i>[Signature]</i>	
23	3.0	7.6	3.0	7.6	<i>[Signature]</i>	
24	3.0	7.6	3.0	7.6	<i>[Signature]</i>	
25	3.0	7.6	3.0	7.6	<i>[Signature]</i>	
26	3.0	7.6	3.0	7.6	<i>[Signature]</i>	
27	1.5	7.6	1.5	7.6	<i>[Signature]</i>	
28	1.5	7.6	1.5	7.6	<i>[Signature]</i>	
29	1.5	7.6	1.5	7.6	<i>[Signature]</i>	
30	1.5	7.6	1.5	7.6	<i>[Signature]</i>	
31						

**Remark : Spa and Swimming Pool Water Quality**

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C

Month : สิงหาคม 2565

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine	P.H. Level	Chlorine	P.H. Level		
1	1.5	7.6	1.5	7.6	Thom	
2	1.5	7.6	1.5	7.6	Thom	
3	1.5	7.8	1.5	7.6	Thom	
*4	1.5	7.8	1.5	7.8	Thom	ติดเครื่อง 4
5	1.5	7.8	1.5	7.8	Thom	
6	1.5	7.8	1.5	7.8	Thom	
7	1.5	7.6	1.5	7.8	Thom	
8	1.5	7.8	1.5	7.8	Thom	
9	1.5	7.8	1.5	7.8	Thom	
10	1.5	7.6	1.5	7.6	Thom	
11	1.5	7.6	1.5	7.6	Thom	
12	1.5	7.6	1.5	7.6	Thom	
13	1.5	7.6	1.5	7.6	Thom	
14	1.5	7.6	1.5	7.6	Thom	
15	1.5	7.6	1.5	7.6	Thom	
16	1.5	7.6	1.5	7.6	Thom	
17	1.5	7.6	1.5	7.6	Thom	
18	1.5	7.6	1.5	7.6	Thom	
19	1.5	7.6	1.5	7.6	Thom	
20	1.5	7.6	1.5	7.6	Thom	
21	1.5	7.6	1.5	7.6	Thom	
22	1.5	7.6	1.5	7.6	Thom	
23	1.5	7.6	1.5	7.6	Thom	
24	1.5	7.6	1.5	7.6	Thom	
25	1.5	7.6	1.5	7.6	Thom	
26	1.5	7.6	1.5	7.6	Thom	
27	1.5	7.8	1.5	7.8	Thom	
28	1.5	7.8	1.5	7.8	Thom	
29	1.5	7.8	1.5	7.8	Thom	
30	1.5	7.8	1.5	7.8	Thom	
31	1.5	7.8	1.5	7.8	Thom	

**Remark . Spa and Swimming Pool Water Quality**

The pool water quality should have the following range of values:

- pH of 7.2 to 7.8
- Total alkalinity of 80 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of bacteria.
- for indoor pool the water temperature shall be 29°C