



Analysis / Test Report

TESTING
No.0166

Client : Bangkok Phuket Hospital Co., Ltd.
89/8, 89/9 Moo 2, Vichit, Muang, Phuket Thailand 83000

P/O :

Project Name : Dibuk Hospital

Project Location :

Lot ID: 2276225

Date Received : Jul 07, 2022

Date Reported : Jul 18, 2022

Report Number : 2377647-1

Page 1 of 1

Sample Number	2276225-1
Sampled Date	Jul 06, 2022 11:30 AM
Sample Description	น้ำประปาปลายทาง
Location	อ่างล้างมือแผนก ER เดียง 7
Date Analysis Commenced	Jul 07, 2022
Condition of Sample	Contained in four plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Metals Testing							
Iron	mg/L	0.001	0.005	0.02	≤0.3	Based on APHA (2017), 3125	Songkhla
Manganese	mg/L	0.001	0.005	<0.005	≤0.3	Based on APHA (2017), 3125	Songkhla
Microbiological Testing							
^[A] <i>Escherichia coli</i>	MPN/100mL	-	-	<1.1	<1.1	APHA (2017), 9221 F	Bangkok
^[A] Total Coliform	MPN/100mL	-	-	<1.1	<1.1	APHA (2017), 9221 B	Bangkok
Water Testing							
^[A] Chloride as Cl	mg/L	0.06	0.2	11.7	≤250	APHA (2017), 4110 B	Bangkok
Color (Apparent) *	Color unit	-	5	<5	≤15	APHA (2017), 2120 B	Songkhla
^[A] Nitrate as NO ₃	mg/L	0.3	1.0	<1.0	≤50	APHA (2017), 4110 B	Bangkok
pH at 25 degree C		-	-	7.4	6.5-8.5	Based on APHA (2017), 4500-H (B)	Songkhla
Residual Free Chlorine	mg/L	-	0.1	0.4	No Standard	APHA (2017), 4500-Cl (F)	Songkhla
^[A] Sulfate	mg/L	0.15	0.5	1.1	≤250	APHA (2017), 4110 B	Bangkok
Total Dissolved solids Dried at 180 degree C	mg/L	-	5	92	≤500	APHA (2017), 2540 C	Songkhla
Total Hardness as CaCO ₃	mg/L	-	1	<1	≤300	APHA (2017), 2340 C	Songkhla
Turbidity	NTU	-	0.1	0.59	≤5	APHA (2017), 2130 B	Songkhla

Guideline : เกณฑ์คุณภาพน้ำประปาดื่มได้ ประกาศ กรมอนามัย พ.ศ. 2563

Sampled By : Yuttapong Rattana , Thaksin Aintrom

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- [A] Analysis conducted by ALS Laboratory Group (Thailand) Co., Ltd. Bangkok Branch, DMS Accreditation No. 1031/47.
- The laboratory has been accepted as an accredited laboratory complying with the ISO/IEC 17025.

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Sutthirak T.

Sutthirak Tiprat
Scientist (2)

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER



Analysis / Test Report

TESTING
No.0166

Client : Bangkok Phuket Hospital Co., Ltd.
89/8, 89/9 Moo 2, Vichit, Muang, Phuket Thailand 83000
P/O : 051-4305236170
Project Name : Dibuk Hospital
Project Location :

Lot ID: 2288612
Date Received : Aug 04, 2022
Date Reported : Aug 22, 2022
Report Number : 2410715-1

Page 1 of 1

Sample Number 2288612-1
Sampled Date Aug 03, 2022 10:00 AM
Sample Description น้ำประปาปลายทาง
Location อ่างล้างมือแผนก IMCU
Date Analysis Commenced Aug 04, 2022
Condition of Sample Contained in four plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Metals Testing							
Iron	mg/L	0.001	0.005	0.01	≤0.3	Based on APHA (2017), 3125	Songkhla
Manganese	mg/L	0.001	0.005	<0.005	≤0.3	Based on APHA (2017), 3125	Songkhla
Microbiological Testing							
<i>Escherichia coli</i>	MPN/100mL	-	-	<1.1	<1.1	APHA (2017), 9221 F	Songkhla
Total Coliform	MPN/100mL	-	-	<1.1	<1.1	APHA (2017), 9221 B	Songkhla
Water Testing							
^[A] Chloride as Cl	mg/L	0.06	0.2	19.2	≤250	APHA (2017), 4110 B	Bangkok
Color (Apparent) *	Color unit	-	5	<5	≤15	APHA (2017), 2120 B	Songkhla
^[A] Nitrate as NO ₃	mg/L	0.3	1.0	<1.0	≤50	APHA (2017), 4110 B	Bangkok
pH at 25 degree C		-	-	7.7	6.5-8.5	Based on APHA (2017), 4500-H (B)	Songkhla
Residual Free Chlorine	mg/L	-	0.1	0.3		APHA (2017), 4500-Cl (F)	Songkhla
^[A] Sulfate	mg/L	0.15	0.5	1.9	≤250	APHA (2017), 4110 B	Bangkok
Total Dissolved solids Dried at 180 degree C	mg/L	-	5	82	≤500	APHA (2017), 2540 C	Songkhla
Total Hardness as CaCO ₃	mg/L	-	1	19	≤300	APHA (2017), 2340 C	Songkhla
Turbidity	NTU	-	0.1	0.39	≤5	APHA (2017), 2130 B	Songkhla

Guideline : เกณฑ์คุณภาพน้ำประปาดื่มได้ ประกาศ กรมอนามัย พ.ศ. 2563

Sampled By : Yuttapong Rattana , Thaksin Aintrom

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- [A] Analysis conducted by ALS Laboratory Group (Thailand) Co.,Ltd. Bangkok Branch, DMS Accreditation No. 1031/47.
- The laboratory has been accepted as an accredited laboratory complying with the ISO/IEC 17025.

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Sutthirak T.

Sutthirak Tiprat
Scientist (2)

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER



Analysis / Test Report

Client : Bangkok Phuket Hospital Co., Ltd.
89/8, 89/9 Moo 2, Vichit, Muang, Phuket Thailand 83000

P/O :

Project Name : Dibuk Hospital

Project Location :

TESTING

No.0166

Lot ID: 22103826

Date Received : Sep 08, 2022

Date Reported : Sep 17, 2022

Report Number : 2436816-1

Page 1 of 1

Sample Number	22103826-1
Sampled Date	Sep 07, 2022 9:28 AM
Sample Description	น้ำประปาปลายทาง
Location	อ่างล้างมือแผนก Ward 14
Date Analysis Commenced	Sep 08, 2022
Condition of Sample	Contained in four plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Metals Testing							
Iron	mg/L	0.001	0.005	0.03	≤0.3	Based on APHA (2017), 3125	Songkhla
Manganese	mg/L	0.001	0.005	<0.005	≤0.3	Based on APHA (2017), 3125	Songkhla
Microbiological Testing							
<i>Escherichia coli</i>	MPN/100mL	-	-	<1.1	<1.1	APHA (2017), 9221 F	Songkhla
Total Coliform	MPN/100mL	-	-	<1.1	<1.1	APHA (2017), 9221 B	Songkhla
Water Testing							
^[A] Chloride as Cl	mg/L	0.06	0.2	13.3	≤250	APHA (2017), 4110 B	Bangkok
Color (Apparent) *	Color unit	-	5	<5	≤15	APHA (2017), 2120 B	Songkhla
^[A] Nitrate as NO ₃	mg/L	0.3	1.0	<1.0	≤50	APHA (2017), 4110 B	Bangkok
pH at 25 degree C		-	-	7.2	6.5-8.5	Based on APHA (2017), 4500-H (B)	Songkhla
Residual Free Chlorine	mg/L	-	0.1	0.2		APHA (2017), 4500-Cl (F)	Songkhla
^[A] Sulfate	mg/L	0.15	0.5	2.2	≤250	APHA (2017), 4110 B	Bangkok
Total Dissolved solids Dried at 180 degree C	mg/L	-	5	95	≤500	APHA (2017), 2540 C	Songkhla
Total Hardness as CaCO ₃	mg/L	-	1	21	≤300	APHA (2017), 2340 C	Songkhla
Turbidity	NTU	-	0.1	0.78	≤5	APHA (2017), 2130 B	Songkhla

Guideline : เกณฑ์คุณภาพน้ำประปาดื่มได้ ประกาศ กรมอนามัย พ.ศ. 2563

Sampled By : Yuttapong Rattana , Thaksin Aintrom

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- [A] Analysis conducted by ALS Laboratory Group (Thailand) Co., Ltd. Bangkok Branch, DMS Accreditation No. 1031/47.
- The laboratory has been accepted as an accredited laboratory complying with the ISO/IEC 17025.

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Sutthirak T.

Sutthirak Tiprat
Scientist (2)

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER



Analysis / Test Report

TESTING
No.0166

Client : Bangkok Phuket Hospital Co., Ltd.
89/8, 89/9 Moo 2, Vichit, Muang, Phuket Thailand 83000
P/O : 051-4305329329
Project Name : Dibuk Hospital
Project Location :

Lot ID: 22116279
Date Received : Oct 06, 2022
Date Reported : Oct 17, 2022
Report Number : 2464861-1

Page 1 of 1

Sample Number 22116279-1
Sampled Date Oct 05, 2022 9:00 AM
Sample Description น้ำประปาต้นทาง
Location บ่อเก็บน้ำประปาโรงผลิตน้ำ (Clear Water Tank)
Date Analysis Commenced Oct 06, 2022
Condition of Sample Contained in four plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Metals Testing							
Iron	mg/L	0.001	0.005	0.007	≤0.3	Based on APHA (2017), 3125	Songkhla
Manganese	mg/L	0.001	0.005	Not Detected	≤0.3	Based on APHA (2017), 3125	Songkhla
Microbiological Testing							
<i>Escherichia coli</i>	MPN/100mL	-	-	<1.1	<1.1	APHA (2017), 9221 F	Songkhla
Total Coliform	MPN/100mL	-	-	<1.1	<1.1	APHA (2017), 9221 B	Songkhla
Water Testing							
^[A] Chloride as Cl	mg/L	0.06	0.2	13.4	≤250	APHA (2017), 4110 B	Bangkok
Color (Apparent) *	Color unit	-	5	<5	≤15	APHA (2017), 2120 B	Songkhla
^[A] Nitrate as NO ₃	mg/L	0.3	1.0	<1.0	≤50	APHA (2017), 4110 B	Bangkok
pH at 25 degree C	-	-	-	7.0	6.5-8.5	Based on APHA (2017), 4500-H (B)	Songkhla
Residual Free Chlorine	mg/L	-	0.1	0.7	No Standard	APHA (2017), 4500-Cl (F)	Songkhla
^[A] Sulfate	mg/L	0.15	0.5	1.3	≤250	APHA (2017), 4110 B	Bangkok
Total Dissolved solids Dried at 180 degree C	mg/L	-	5	76	≤500	APHA (2017), 2540 C	Songkhla
Total Hardness as CaCO ₃	mg/L	-	1	17	≤300	APHA (2017), 2340 C	Songkhla
Turbidity	NTU	-	0.1	0.49	≤5	APHA (2017), 2130 B	Songkhla

Guideline : เกณฑ์คุณภาพน้ำประปาดื่มได้ ประกาศ กรมอนามัย พ.ศ. 2563

Sampled By : Yuttapong Rattana , Thaksin Aintrom

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- [A] Analysis conducted by ALS Laboratory Group (Thailand) Co.,Ltd. Bangkok Branch, DMSc Accreditation No. 1031/47.
- The laboratory has been accepted as an accredited laboratory complying with the ISO/IEC 17025.

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Sutthirak T.

Sutthirak Tiprat
Scientist (2)

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER



Analysis / Test Report

TESTING
No.0166

Client : Bangkok Phuket Hospital Co., Ltd.
89/8, 89/9 Moo 2, Vichit, Muang, Phuket Thailand 83000
P/O : 051-4305329329
Project Name : Dibuk Hospital
Project Location :

Lot ID: 22129827
Date Received : Nov 03, 2022
Date Reported : Nov 11, 2022
Report Number : 2490202-1

Page 1 of 1

Sample Number 22129827-1
Sampled Date Nov 02, 2022 1:17 PM
Sample Description น้ำประปาต้นทาง
Location ถังเก็บน้ำอาคารพยาบาล (Service A-B)
Date Analysis Commenced Nov 03, 2022
Condition of Sample Contained in four plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Metals Testing							
Iron	mg/L	0.001	0.005	0.01	≤0.3	Based on APHA (2017), 3125	Songkhla
Manganese	mg/L	0.001	0.005	Not Detected	≤0.3	Based on APHA (2017), 3125	Songkhla
Microbiological Testing							
<i>Escherichia coli</i>	MPN/100mL	-	-	<1.1	<1.1	APHA (2017), 9221 F	Songkhla
Total Coliform	MPN/100mL	-	-	<1.1	<1.1	APHA (2017), 9221 B	Songkhla
Water Testing							
^[A] Chloride as Cl	mg/L	0.06	0.2	12.9	≤250	APHA (2017), 4110 B	Bangkok
Color (Apparent) *	Color unit	-	5	<5	≤15	APHA (2017), 2120 B	Songkhla
^[A] Nitrate as NO ₃	mg/L	0.3	1.0	Not Detected	≤50	APHA (2017), 4110 B	Bangkok
pH at 25 degree C		-	-	7.2	6.5-8.5	Based on APHA (2017), 4500-H (B)	Songkhla
Residual Free Chlorine	mg/L	-	0.1	2.3	No Standard	APHA (2017), 4500-Cl (F)	Songkhla
Sulfate	mg/L	0.15	0.5	2.4	≤250	APHA (2017), 4110 B	Bangkok
Total Dissolved solids Dried at 180 degree C	mg/L	-	5	78	≤500	APHA (2017), 2540 C	Songkhla
Total Hardness as CaCO ₃	mg/L	-	1	20	≤300	APHA (2017), 2340 C	Songkhla
Turbidity	NTU	-	0.1	0.51	≤5	APHA (2017), 2130 B	Songkhla

Guideline : เกณฑ์คุณภาพน้ำประปาดื่มได้ ประกาศ กรมอนามัย พ.ศ. 2563

Sampled By : Yuttapong Rattana

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- [A] Analysis conducted by ALS Laboratory Group (Thailand) Co.,Ltd. Bangkok Branch, DMSc Accreditation No. 1031/47.
- The laboratory has been accepted as an accredited laboratory complying with the ISO/IEC 17025.

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Sutthirak T.

Sutthirak Tiprat
Scientist (2)

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER



Analysis / Test Report

TESTING
No.0166

Client : Bangkok Phuket Hospital Co., Ltd.
89/8, 89/9 Moo 2, Vichit, Muang, Phuket Thailand 83000
P/O : 051-4305329329
Project Name : Dibuk Hospital
Project Location :

Lot ID: 22142429
Date Received : Dec 08, 2022
Date Reported : Dec 17, 2022
Report Number : 2523259-1

Page 1 of 2

Sample Number 22142429-1
Sampled Date Dec 07, 2022 11:00 AM
Sample Description น้ำประปาต้นทาง
Location ถังเก็บน้ำตาดฟ้าอาคาร Tower
Date Analysis Commenced Dec 08, 2022
Condition of Sample Contained in four plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Metals Testing							
Iron	mg/L	0.001	0.005	0.03	≤0.3	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 3125 B, 3030 F	Songkhla
Manganese	mg/L	0.001	0.005	<0.005	≤0.3	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 3125 B, 3030 F	Songkhla
Microbiological Testing							
<i>Escherichia coli</i>	MPN/100mL	-	-	<1.1	<1.1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 9221 B. F	Songkhla
Total Coliform	MPN/100mL	-	-	<1.1	<1.1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 9221 B	Songkhla
Water Testing							
^[A] Chloride as Cl	mg/L	0.06	0.2	31.6	≤250	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4110 B	Bangkok
Color (Apparent) *	Color unit	-	5	<5	≤15	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 2120 B	Songkhla
^[A] Nitrate as NO ₃	mg/L	0.3	1.0	<1.0	≤50	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4110 B	Bangkok
pH at 25 degree C		-	-	7.8	6.5-8.5	In - house method : STM 13-001 based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4500 - H (B)	Songkhla

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Sutthirak T.

Sutthirak Tiprat
Scientist (2)

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER



Analysis / Test Report

TESTING
No.0166

Client : Bangkok Phuket Hospital Co., Ltd.
89/8, 89/9 Moo 2, Vichit, Muang, Phuket Thailand 83000
P/O : 051-4305329329
Project Name : Dibuk Hospital
Project Location :

Lot ID: 22142429
Date Received : Dec 08, 2022
Date Reported : Dec 17, 2022
Report Number : 2523259-1

Page 2 of 2

Sample Number 22142429-1
Sampled Date Dec 07, 2022 11:00 AM
Sample Description น้ำประปาต้นทาง
Location ถังเก็บน้ำตาดฟ้าอาคาร Tower
Date Analysis Commenced Dec 08, 2022
Condition of Sample Contained in four plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Water Testing							
Residual Free Chlorine	mg/L	-	0.1	0.2	No Standard	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4500-Cl (F)	Songkhla
^[A] Sulfate	mg/L	0.15	0.5	1.8	≤250	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4110 B	Bangkok
Total Dissolved solids Dried at 180 degree C	mg/L	-	5	104	≤500	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 2540 C	Songkhla
Total Hardness as CaCO ₃	mg/L	-	1	24	≤300	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 2340 C	Songkhla
Turbidity	NTU	-	0.1	0.61	≤5	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 2130 B	Songkhla

Guideline : เกณฑ์คุณภาพน้ำประปาดื่มได้ ประกาศ กรมอนามัย พ.ศ. 2563

Sampling By :

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- [A] Analysis conducted by ALS Laboratory Group (Thailand) Co.,Ltd. Bangkok Branch, DMSc Accreditation No. 1031/47.
- The laboratory has been accepted as an accredited laboratory complying with the ISO/IEC 17025.

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Sutthirak T.

Sutthirak Tiprat
Scientist (2)

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER