



Analysis / Test Report

TESTING
No.0166

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000
P/O : 005-4305231549
Project Name : Water Testing : BPK
Project Location :

Lot ID: 2294414
Date Received : Aug 04, 2022
Date Reported : Aug 22, 2022
Report Number : 2411735-1

Page 1 of 1

Sample Number 2294414-7
Sampled Date Aug 03, 2022 11:45 AM
Sample Description น้ำในถาด Cooling Tower
Location Cooling Tower
Date Analysis Commenced Aug 04, 2022
Condition of Sample Contained in five plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Metals Testing							
Iron	mg/L	0.001	0.005	0.01	≤1.0	Based on APHA (2017), 3125	Songkhla
Microbiological Testing							
<i>Legionella spp.</i> *	CFU/L	-	-	Not Detected**	Not Detected (1)	ISO 11731 (2017)	Bangkok
Water Testing							
Calcium Hardness as CaCO ₃ *	mg/L	-	1	179	No Standard	Based on APHA (2017), 3500-Ca (B)	Songkhla
^[A] Chloride as Cl	mg/L	0.06	0.2	192	≤300	APHA (2017), 4110 B	Bangkok
Conductivity *	micromhos/cm	-	0.5	1050	≤3000	Based on APHA (2017), 2510 B	Songkhla
pH at 25 degree C		-	-	8.0	7-9	Based on APHA (2017), 4500-H (B)	Songkhla
Phosphate as P *	mg/L	0.15	0.5	Not Detected	≤20	APHA (2017), 4110 B	Bangkok
Silica as SiO ₂ *	mg/L	0.02	0.05	114	≤120	Based on APHA (2017), 4500-SiO ₂ (D)	Bangkok
Total Alkalinity as CaCO ₃ *	mg/L	-	1	102	≤1000	Based on APHA (2017), 2320 B	Songkhla
Total Dissolved solids Dried at 180 degree C	mg/L	-	5	644	≤2000	APHA (2017), 2540 C	Songkhla
Total Hardness as CaCO ₃	mg/L	-	1	238	≤300	APHA (2017), 2340 C	Songkhla

Guideline : หนังสือการปรุงแต่งคุณภาพน้ำ มาตรฐานน้ำใน Cooling Tower ดร.มันสัน ตัณฑเวศน์
(1) ประกาศกรมอนามัย พ.ศ. 2544 เรื่องข้อปฏิบัติการควบคุมเชื้อลีสอีโอเนลลา ในห้องเลี้ยงของอาคารในประเทศไทย

Note : ** Not Detected mean Bacteria not found in agar plate.

Sampled By : Yuttapong Rattana , Thaksin Aintrom

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- [A] Analysis conducted by ALS Laboratory Group (Thailand) Co.,Ltd. Bangkok Branch, DMSc Accreditation No. 1031/47.
- The laboratory has been accepted as an accredited laboratory complying with the ISO/IEC 17025.

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Sutthirak T.

Sutthirak Tiprat
Scientist (2)

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER