



Analysis / Test Report

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000
P/O : 005-4305321797
Project Name : Water Testing : BPK
Project Location :

Lot ID: 22129782

Date Received : Nov 02, 2022
Date Reported : Nov 18, 2022
Report Number : 2491590-1

Page 1 of 1

Sample Number 22129782-13
Sampled Date Nov 01, 2022 10:13 AM
Sample Description น้ำในถาด Cooling Tower
Location Cooling Tower
Date Analysis Commenced Nov 02, 2022
Condition of Sample Contained in two plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Microbiological Testing							
<i>Legionella spp.</i>	CFU/L	-	-	Not Detected**	Not Detected	ISO 11731 (2017)	Bangkok

Guideline : Notification of Department of Health about Legionella Control in Cooling Tower.

Note : ** Not Detected mean Bacteria not found in agar plate.

Sampled By : Yuttapong Rattana

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Tuanjai Thangklang
Manager