



Analysis / Test Report

TESTING
No.0166

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O :

Project Name : Water Testing : BPK

Project Location :

Lot ID: 22103859

Date Received : Sep 07, 2022

Date Reported : Sep 23, 2022

Report Number : 2443535-1

Page 1 of 1

Sample Number	22103859-9
Sampled Date	Sep 06, 2022 10:51 AM
Sample Description	น้ำทิ้งหลังออกจากระบบ (น้ำรวม)
Location	ระบบบำบัดน้ำเสีย - ท่อน้ำทิ้ง
Date Analysis Commenced	Sep 07, 2022
Condition of Sample	Contained in one amber glass bottle and six plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Microbiological Testing							
<i>Escherichia coli</i>	MPN/100mL	-	-	<1.8	No Standard	APHA (2017), 9221 F	Songkhla
Fecal Coliform	MPN/100mL	-	-	<1.8	No Standard	APHA (2017), 9221 E	Songkhla
Total Coliform	MPN/100mL	-	-	<1.8	No Standard	APHA (2017), 9221 B	Songkhla
Water Testing							
BOD *	mg/L	-	2	<2	≤20	Based on APHA (2017), 5210 (B), 4500-O (C)	Songkhla
COD Soluble *	mg/L	-	5	43	No Standard	Based on APHA (2017), 5220 D	Songkhla
Oil & Grease	mg/L	-	3	<3	≤20	Based on APHA (2017), 5520 B	Songkhla
pH at 25 degree C		-	-	7.2	5.0-9.0	Based on APHA (2017), 4500-H (B)	Songkhla
Residual Chlorine *	mg/L	-	0.1	0.3	No Standard	Based on APHA (2017), 4500-Cl (G)	Bangkok
Settleable Solid *	mL/L/hr	-	0.1	<0.1	≤0.5	Based on APHA (2017), 2540 F	Songkhla
Sulfide *	mg/L	-	0.5	0.6	≤1	Based on APHA (2017), 4500-S2 (C), (F)	Songkhla
Total Dissolved solids Dried at 180 degree C	mg/L	-	5	476	No Standard	APHA (2017), 2540 C	Songkhla
Total Kjeldahl Nitrogen as N *	mg/L	0.15	1.0	Not Detected	≤35	Based on APHA (2017), 4500-Norg (C)	Bangkok
Total Suspended Solids	mg/L	-	5	9	≤30	APHA (2017), 2540 D	Songkhla

Guideline : Notification of Ministry of Natural Resources and Environment November, 7, B.E. 2548 on Effluent Control Standard from Types and Sized of Buildings, Type A.

(1) : The values are in addition to the Total Dissolved Solids of the water used not more than 500 mg/L.

Sampled By : Yuttapong Rattana, Thaksin Aintrom

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- The laboratory has been accepted as an accredited laboratory complying with the ISO/IEC 17025.

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Siriluk P.

Siriluk Puengpang
Supervisor

ADDRESS 114/1 Moo 8 Karncanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER