



Analysis / Test Report

TESTING
No.0166

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000
P/O : 005-4305321797
Project Name : Water Testing : BPK
Project Location :

Lot ID: 22142520
Date Received : Dec 07, 2022
Date Reported : Dec 23, 2022
Report Number : 2528675-1

Page 1 of 2

Sample Number	22142520-10
Sampled Date	Dec 06, 2022 10:19 AM
Sample Description	น้ำทิ้งหลังออกจากระบบ (น้ำรวม)
Location	ระบบบำบัดน้ำเสีย - ท่อน้ำทิ้ง
Date Analysis Commenced	Dec 07, 2022
Condition of Sample	Contained in one amber glass bottle and six plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Microbiological Testing							
<i>Escherichia coli</i>	MPN/100mL	-	-	<1.8	No Standard	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 9221 B, F	Songkhla
Fecal Coliform	MPN/100mL	-	-	<1.8	No Standard	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 9221 B, E	Songkhla
Total Coliform	MPN/100mL	-	-	<1.8	No Standard	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 9221 B	Songkhla
Water Testing							
BOD *	mg/L	-	2	<2	≤20	Based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 5210 B	Songkhla
COD Soluble *	mg/L	-	5	19	No Standard	Based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 5220 D	Songkhla
Oil & Grease	mg/L	-	3	<3	≤20	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 5520 B	Songkhla
pH at 25 degree C		-	-	7.2	5.0-9.0	In - house method : STM 13-001 based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4500 - H (B)	Songkhla
Residual Chlorine *	mg/L	-	0.1	0.7	No Standard	Based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4500-CI (G)	Bangkok
Settleable Solid *	mL/L/hr	-	0.1	<0.1	≤0.5	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 2540 F	Songkhla

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Chompoonuch F.

Chompoonuch Funtha
Scientist (4)

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER



Analysis / Test Report

TESTING
No.0166

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000
P/O : 005-4305321797
Project Name : Water Testing : BPK
Project Location :

Lot ID: 22142520
Date Received : Dec 07, 2022
Date Reported : Dec 23, 2022
Report Number : 2528675-1

Page 2 of 2

Sample Number	22142520-10
Sampled Date	Dec 06, 2022 10:19 AM
Sample Description	น้ำทิ้งหลังออกจากระบบ (น้ำรวม)
Location	ระบบบำบัดน้ำเสีย - ท่อน้ำทิ้ง
Date Analysis Commenced	Dec 07, 2022
Condition of Sample	Contained in one amber glass bottle and six plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Water Testing							
Sulfide *	mg/L	-	0.5	0.6	≤1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4500-S2 (C, F)	Songkhla
Total Dissolved solids Dried at 180 degree C	mg/L	-	5	312	No Standard	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 2540 C	Songkhla
Total Kjeldahl Nitrogen as N *	mg/L	0.15	1.0	5.5	≤35	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4500-Norg (C)	Bangkok
Total Suspended Solids	mg/L	-	5	18	≤30	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 2540 D	Songkhla

Guideline : Notification of Ministry of Natural Resources and Environment November, 7, B.E. 2548 on Effluent Control Standard from Types and Sized of Buildings, Type A.

(1) : The values are in addition to the Total Dissolved Solids of the water used not more than 500 mg/L.

Sampling By : Yuttapong Rattana ทะเบียนเลขที่ ๖-204-๖-8610 , Thaksin Aintrom

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- The laboratory has been accepted as an accredited laboratory complying with the ISO/IEC 17025.

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Chompoonuch F.

Chompoonuch Funtha
Scientist (4)

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER