



Accreditation No. 1031/47

## Analysis / Test Report

**Client :** Bangkok Phuket Hospital Co., Ltd.  
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

**P/O :** 005-4305321797

**Project Name :** Water Testing : BPK

**Project Location :**

**Lot ID: 22142520**

Date Received : Dec 07, 2022

Date Reported : Dec 23, 2022

Report Number : 2528683-1

Page 1 of 1

<b>Sample Number</b>	22142520-18
<b>Sampled Date</b>	Dec 06, 2022 9:28 AM
<b>Sample Description</b>	น้ำพุ ร.ทหารไทย
<b>Location</b>	บ่อเก็บ - ไตล่านน้ำพุ
<b>Date Analysis Commenced</b>	Dec 07, 2022
<b>Condition of Sample</b>	Contained in two plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Method	Testing Location
<b>Microbiological Testing</b>						
<i>Legionella spp.</i>	CFU/L	-	-	<1	ISO 11731 (2017)	Bangkok

**Note :** Microbiological Testing Result <1 mean Bacteria not found in agar plate.

**Sampling By :** Yuttapong Rattana ทะเบียนเลขที่ ว-204-จ-8610 , Thaksin Aintrom

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked \* is/are not included in scope of Accreditation ISO/IEC 17025.
- The laboratory has been accepted as an accredited laboratory complying with the ISO/IEC 17025.

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Tuanjai Thangklang  
Manager

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197  
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER