



Analysis / Test Report

TESTING
No.0166

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O :

Project Name : Water Testing : BPK

Project Location :

Lot ID: 2276138

Date Received : Jul 06, 2022

Date Reported : Jul 21, 2022

Report Number : 2381157-1

Page 1 of 1

Sample Number	2276138-9
Sampled Date	Jul 05, 2022 11:17 AM
Sample Description	น้ำเสียก่อนเข้าระบบบำบัด (น้ำรวม)
Location	ระบบบำบัดน้ำเสีย - บ่อรวบรวมน้ำเสีย
Date Analysis Commenced	Jul 06, 2022
Condition of Sample	Contained in one amber glass bottle and five plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Water Testing							
BOD *	mg/L	-	2	94	≤20	Based on APHA (2017), 5210 (B), 4500-O (C)	Songkhla
COD	mg/L	-	5	198	No Standard	Based on APHA (2017), 5220 D	Songkhla
Oil & Grease	mg/L	-	3	5	≤20	Based on APHA (2017), 5520 B	Songkhla
pH at 25 degree C		-	-	7.6	5.0-9.0	Based on APHA (2017), 4500-H (B)	Songkhla
Settleable Solid *	mL/L/hr	-	0.1	0.3	≤0.5	Based on APHA (2017), 2540 F	Songkhla
Sulfide *	mg/L	-	0.5	55.6	≤1	Based on APHA (2017), 4500-S2 (C), (F)	Songkhla
Total Dissolved solids Dried at 180 degree C	mg/L	-	5	608	No Standard	APHA (2017), 2540 C	Songkhla
Total Kjeldahl Nitrogen as N *	mg/L	0.15	1.0	58.2	≤35	Based on APHA (2017), 4500-Norg (C)	Bangkok
Total Suspended Solids	mg/L	-	5	37	≤30	APHA (2017), 2540 D	Songkhla

Guideline : Notification of Ministry of Natural Resources and Environment November, 7, B.E. 2548 on Effluent Control Standard from Types and Sized of Buildings, Type A.

(1) : The values are in addition to the Total Dissolved Solids of the water used not more than 500 mg/L.

Note : สารที่ละลายได้ทั้งหมดในน้ำใช้ = 194 มิลลิกรัมต่อลิตร

Sampled By : Yuttapong Rattana , Thaksin Aintrom

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- The laboratory has been accepted as an accredited laboratory complying with the ISO/IEC 17025.

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Sutthirak T.

Sutthirak Tiprat
Scientist (2)

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068

ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER