

ANALYSIS REPORT

CUSTOMER NAME : SUPALAI LOFT TALAT PHLU STATION JURISTIC PERSON
ADDRESS : 599 RATCHADAPISEK ROAD (THAPRA-TAKSIN) BUKKHALO THON BURI BANGKOK 10600
CONTACT INFORMATION : TEL : 09 2594 4789 e-mail : adul.poongkong@th.knightfrank.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SUPPLY
SAMPLING DATE : JULY 6, 2022
SAMPLING TIME : 11:35 HOUR
SAMPLING METHOD ^c : GRAB
SAMPLING BY ^c : MR ACHITA SAENGJAN
ANALYZED BY : MISS PORNPIMOL WAENTHONG

RECEIVED DATE : JULY 6, 2022
ANALYTICAL DATE : JULY 6-11, 2022
REPORT NO. : 2022-U055916
WORK NO. : 2021-007369
ANALYSIS NO. : T22AN300-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			WATER SUPPLY T22AN300-0002	
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: 2540 C)	155	25
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23rd EDITION, 2017.


(MISS PORNPIMOL WAENTHONG)
LABORATORY SUPERVISOR

JULY 20, 2022



ANALYSIS REPORT

CUSTOMER NAME : SUPALAI LOFT TALAT PHLU STATION JURISTIC PERSON
ADDRESS : 599 RATCHADAPISEK ROAD (THAPRA-TAKSIN) BUKKHALO THON BURI BANGKOK 10600
CONTACT INFORMATION : TEL : 09 2594 4789 e-mail : adul.poongkong@th.knightfrank.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SUPPLY
SAMPLING DATE : AUGUST 5, 2022
SAMPLING TIME : 14:40 HOUR
SAMPLING METHOD ^c : GRAB
SAMPLING BY ^c : MR ACHITA SAENGJAN
ANALYZED BY : MISS PORNPIMOL WAENTHONG

RECEIVED DATE : AUGUST 5, 2022
ANALYTICAL DATE : AUGUST 5-10, 2022
REPORT NO. : 2022-U063934
WORK NO. : 2021-007369
ANALYSIS NO. : T22AP418-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			WATER SUPPLY T22AP418-0002	
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: 2540 C)	154	25
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23rd EDITION, 2017.

(MRS PIYAPAT SUTTAMANUTWONG)
LABORATORY SUPERVISOR

AUGUST 19, 2022



ANALYSIS REPORT

CUSTOMER NAME : SUPALAI LOFT TALAT PHLU STATION JURISTIC PERSON
ADDRESS : 599 RATCHADAPISEK ROAD (THAPRA-TAKSIN) BUKKHALO THON BURI BANGKOK 10600
CONTACT INFORMATION : TEL : 09 2594 4789 e-mail : adul.poongkong@th.knightfrank.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SUPPLY
SAMPLING DATE : SEPTEMBER 7, 2022
SAMPLING TIME : 14:00 HOUR
SAMPLING METHOD ^c : GRAB
SAMPLING BY ^c : MR WEERAYUT MOKKAEW
ANALYZED BY : MISS PORNPIMOL WAENTHONG

RECEIVED DATE : SEPTEMBER 7, 2022
ANALYTICAL DATE : SEPTEMBER 7-9, 2022
REPORT NO. : 2022-U072339
WORK NO. : 2021-007369
ANALYSIS NO. : T22AR577-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			WATER SUPPLY T22AR577-0002	
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: 2540 C)	126	25
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23rd EDITION, 2017.

.....
(MISS PORNPIMOL WAENTHONG)
LABORATORY SUPERVISOR

SEPTEMBER 20, 2022



ANALYSIS REPORT

CUSTOMER NAME : SUPALAI LOFT TALAT PHLU STATION JURISTIC PERSON
ADDRESS : 599 RATCHADAPISEK ROAD (THAPRA-TAKSIN) BUKKHALO THON BURI BANGKOK 10600
CONTACT INFORMATION : TEL : 09 2594 4789 e-mail : adul.poongkong@th.knightfrank.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SUPPLY
SAMPLING DATE : OCTOBER 6, 2022
SAMPLING TIME : 10:30 HOUR
SAMPLING METHOD ^c : GRAB
SAMPLING BY ^c : MR KRIDSANAPONG NAMTHIP
ANALYZED BY : MISS PORNPIMOL WAENTHONG

RECEIVED DATE : OCTOBER 6, 2022
ANALYTICAL DATE : OCTOBER 6-11, 2022
REPORT NO. : 2022-U082080
WORK NO. : 2021-007369
ANALYSIS NO. : T22AT865-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			WATER SUPPLY T22AT865-0004	
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: 2540 C)	163	25
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23rd EDITION, 2017.

[REDACTED SIGNATURE]

LABORATORY SUPERVISOR

OCTOBER 20, 2022



ANALYSIS REPORT

CUSTOMER NAME : SUPALAI LOFT TALAT PHLU STATION JURISTIC PERSON
ADDRESS : 599 RATCHADAPISEK ROAD (THAPRA-TAKSIN) BUKKHALO THON BURI BANGKOK 10600
CONTACT INFORMATION : TEL : 06 3156 4157 e-mail : sarach.thubthimsai@th.knightfrank.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SUPPLY
SAMPLING DATE : NOVEMBER 3, 2022
SAMPLING TIME : 12:15 HOUR
SAMPLING METHOD ^c : GRAB
SAMPLING BY ^c : MR APISIT SRIKONGKAEW
ANALYZED BY : MISS PORNPIMOL WAENTHONG
RECEIVED DATE : NOVEMBER 3, 2022
ANALYTICAL DATE : NOVEMBER 3-9, 2022
REPORT NO. : 2022-U090632
WORK NO. : 2021-007369
ANALYSIS NO. : T22AV857-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			WATER SUPPLY T22AV857-0002	
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: 2540 C)	162	25
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23rd EDITION, 2017.



LABORATORY SUPERVISOR

NOVEMBER 18, 2022



ANALYSIS REPORT

CUSTOMER NAME : SUPALAI LOFT TALAT PHLU STATION JURISTIC PERSON
ADDRESS : 599 RATCHADAPISEK ROAD (THAPRA-TAKSIN) BUKKHALO THON BURI BANGKOK 10600
CONTACT INFORMATION : TEL : 06 3156 4157 e-mail : sarach.thubthimsai@th.knightfrank.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SUPPLY
SAMPLING DATE : DECEMBER 2, 2022
SAMPLING TIME : 13:50 HOUR
SAMPLING METHOD ^c : GRAB
SAMPLING BY ^c : MR KRIDSANAPONG NAMTHIP
ANALYZED BY : MISS PORNPIMOL WAENTHONG
RECEIVED DATE : DECEMBER 2, 2022
ANALYTICAL DATE : DECEMBER 2-7, 2022
REPORT NO. : 2022-U099418
WORK NO. : 2021-007369
ANALYSIS NO. : T22AY096-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			WATER SUPPLY T22AY096-0004	
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: 2540 C)	187	25
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23rd EDITION, 2017.

LABORATORY SUPERVISOR

DECEMBER 19, 2022

