

Request No. LA65-R0940

Report No. R6509-3577 – R6509-3580


TEST REPORT

CUSTOMER : Meyer Aluminium (Thailand) Co., Ltd.
 ADDRESS : 38/32 Moo 5 Laem Chabang Industrial Estate, Sriracha, Chonburi 20230
 SAMPLE SOURCE : Meyer Aluminium (Thailand) Co., Ltd.
 MEASURING DATE : 13/09/2022 SAMPLE NO. : 27656-27659
 RECEIVED DATE : 13/09/2022 REPORTED DATE : 17/09/2022
 SAMPLING INSTRUMENT* : Wind Vane Anemometer

Location	Temperature (°C)	Diameter (m)	Area (m ²)	Velocity (m/s)	Flow Rate (m ³ /s)
1. Hood เต้าพัก No.1	32.1	1.0	0.785714	15.04	11.81400
2. Hood เต้าหลอม No.1	36.4	1.0	0.785714	14.54	11.42271
3. Hood เต้าพัก No.2	30.6	1.0	0.785714	14.93	11.73071
4. Hood เต้าหลอม No.2	32.4	1.0	0.785714	12.76	10.02886

REMARK :

* Parameter Outside The Scope of The Registration of The Department of Industrial Works
 (Measurement By Mr. Teerapong Nualin)



บริษัท อีสเทิร์นไทยคอนซัลติ้ง 1992 จำกัด

Approved By.....



(MR. THONGCHAI BOONSAK)

17/09/2022

REPORTED TEST REFER TO SUBMITTED SAMPLES ONLY

THIS REPORT SHALL NOT REPRODUCED EXCEPT IN FULL

WITHOUT THE WRITTEN APPROVAL LABORATORY