

## ANALYSIS REPORT

**CUSTOMER NAME** : CENTRAL WORLD HOTEL COMPANY LIMITED  
**ADDRESS** : 999/99 RAMA 1 ROAD PATHUMWAN PATHUM WAN BANGKOK 10330  
**CONTACT INFORMATION** : TEL : 02 100 1234 e-mail : saksornsi@chr.co.th  
**SAMPLING SOURCE** : -  
**SAMPLE TYPE** : COOLING WATER  
**MEASURING DATE** : DECEMBER 13, 2022  
**MEASURING TIME** : 12:20 HOUR  
**SAMPLING METHOD** : GRAB  
**MEASURED BY** : MR WEERAYUT MOKKAEW

**RECEIVED DATE** : -  
**ANALYTICAL DATE** : -  
**REPORT NO.** : 2022-U103809  
**WORK NO.** : 2021-008561  
**ANALYSIS NO.** : T22AY840-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			ระบบน้ำหมุนเวียน T22AY840-0001	
RESIDUAL CHLORINE	mg/L Cl <sub>2</sub>	MODIFIED DPD COLOURIMETRIC METHOD (AT SITE)	0.1	0.1
<b>SAMPLE CONDITION</b> WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

DECEMBER 29, 2022



## ANALYSIS REPORT

**CUSTOMER NAME** : CENTRAL WORLD HOTEL COMPANY LIMITED  
**ADDRESS** : 999/99 RAMA 1 ROAD PATHUMWAN PATHUM WAN BANGKOK 10330  
**CONTACT INFORMATION** : TEL : 02 100 1234 e-mail : saksornsi@chr.co.th  
**SAMPLING SOURCE** : -  
**SAMPLE TYPE** : COOLING WATER  
**SAMPLING DATE** : DECEMBER 13, 2022  
**SAMPLING TIME** : 12:15 HOUR  
**SAMPLING METHOD \*** : GRAB  
**SAMPLING BY \*** : MR WEERAYUT MOKKAEW  
**ANALYZED BY** : MISS ITSARIYAPORN BUATIB

**RECEIVED DATE** : DECEMBER 14, 2022  
**ANALYTICAL DATE** : DECEMBER 14-21, 2022  
**REPORT NO.** : 2022-U103810  
**WORK NO.** : 2021-008561  
**ANALYSIS NO.** : T22AY840-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT
			ห่อซองเย็น T22AY840-0002
RESIDUAL CHLORINE *	mg/L Cl <sub>2</sub>	MODIFIED DPD COLOURIMETRIC METHOD (AT SITE)	0.2
MICROBIOLOGY			
Legionella spp. #	CFU/L	ISO 11731:2017-05 (E)	NOT DETECTED
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/CLEAR -

# : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF MEDICAL SCIENCE (DMSC)  
\* : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED



DECEMBER 29, 2022

