

LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01								
Rev. Date: 31/01/2015								
Month: Nov Year: 2565								
BUILDING : The Strand thonglor	Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
			Chlorine (ppm)	pH				
1	Morning	07:00	1.0	7.4	14	[Redacted]		
	Afternoon	15:00	1.0	7.8	18			
2	Morning	07:00	1.0	7.4	14			
	Afternoon	16:00	1.0	7.8	18			
3	Morning	06:00	1.0	7.8	18			
	Afternoon	16:00	1.0	7.8	18			
4	Morning	06:00	1.0	7.8	18			
	Afternoon	16:00	1.0	7.8	18			
5	Morning	06:00	1.0	7.8	18			
	Afternoon	16:00	1.0	7.8	18			
6	Morning	06:00	1.0	7.8	18			
	Afternoon	17:00	1.0	7.8	18			
7	Morning	06:00	3.0	7.8	18			
	Afternoon	17:00	1.0	7.4	14			
Comment: _____ _____ _____								

9, 11, 68

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

BUILDING : The Strand thonglor		Ref No: JLL-OP-SN-004/01					
		Rev. Date: 31/01/2015					
		Month: Nov Year: 2555					
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
1	Morning 05:00	1.5	7.4	14	[Redacted]		
	Afternoon 15:00	1.0	7.8	18			
2	Morning 05:00	1.5	7.4	14			
	Afternoon 16:00	1.5	7.8	18			
3	Morning 06:00	1.0	7.8	18			
	Afternoon 16:00	8.0	7.8	18			
4	Morning 06:00	3.0	7.8	18			
	Afternoon 16:00	15	7.8	18			
5	Morning 06:00	1.5	7.8	18			
	Afternoon 16:00	1.0	7.8	18			
6	Morning 06:00	3.0	7.8	18			
	Afternoon 16:30	1.5	8.4	14			
7	Morning 06:00	3.0	8.8	18			
	Afternoon 17:30	1.5	8.4	14			

9 / 11 / 66

Comment:

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm




LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01

Rev. Date: 31/01/2015

Month: NOV Year: 2015

BUILDING: The Strand thonglor

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
8	Morning	06.00	1.5	7.8			
	Afternoon	14:30	1.0	8.4			
9	Morning	7:00	1.5	7.4			
	Afternoon	16:00	1.0	7.8			
10	Morning	6:00	1.5	7.4			
	Afternoon	16:00	1.0	7.8			
11	Morning	7:00	1.0	7.4			
	Afternoon	16:00	1.0	7.8			
12	Morning	06:20	1.0	7.8			
	Afternoon	14:00	1.0	8.4			
13	Morning	6:06	1.0	7.8			
	Afternoon	14:00	1.0	8.4			
14	Morning	06:00	1.0	7.8			
	Afternoon	14:00	1.0	7.4			

Comment:

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm

95 / 11 / 68





LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01

Rev. Date : 31/01/2015

Month : NOV Year : 2015

Building : The Strand thonglor

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
8	Morning	06.00	3.0	7.8			
	Afternoon	12:30	1.5	7.4			
9	Morning	7.00	3.0	7.4			
	Afternoon	16.00	3.0	7.8			
10	Morning	6.00	3.0	7.8			
	Afternoon	16.00	1.5	7.8			
11	Morning	7.00	1.5	7.4			
	Afternoon	16.00	1.5	7.8			
12	Morning	06:20	1.5	7.8			
	Afternoon	14:00	1.5	7.4			
13	Morning	6.00	1.5	7.8			
	Afternoon	14:00	1.5	7.4			
14	Morning	6.00	1.5	7.8			
	Afternoon	14:00	1.5	7.4			

Comment :

15, 11, 68

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm

LOG SHEET OF SWIMMING POOL / POND

BUILDING : The Strand thonglor		Ref No: JLL-OP-SN-004/01		Rev. Date : 31/01/2015		Month : NOV		Year : 2015			
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark			
			Chlorine (ppm)	pH							
15	Morning	06.00	1.0	7.8	18	[Redacted]					
	Afternoon	14.00	1.0	7.4	14						
16	Morning	06.00	1.0	7.8	18						
	Afternoon	14.00	1.0	7.4	14						
17	Morning	06.00	1.0	7.8	18						
	Afternoon	14.00	1.0	7.4	14						
18	Morning	06.00	1.0	7.8	18						
	Afternoon	14.00	1.0	7.4	14						
19	Morning	06.00	1.0	7.8	18						
	Afternoon	14.00	1.0	7.4	14						
20	Morning	06.00	1.0	7.8	18						
	Afternoon	14.00	1.0	7.4	14						
21	Morning	06.00	1.0	7.8	18						
	Afternoon	14.00	1.0	7.4	14						
Comment: _____ _____ _____											

22/11/18

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01

Rev. Date : 31/01/2015

Month : Nov Year : 2015

BUILDING : The Strand thonglor

Area 1000

Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
			Chlorine (ppm)	pH				
15	Morning	06.00	1.5	7.8	18	[Redacted]	[Redacted]	[Redacted]
	Afternoon	14.00	1.5	7.4	14			
16	Morning	06.00	1.5	7.8	14			
	Afternoon	14.00	1.5	7.8	14			
17	Morning	06.00	1.5	7.8	14			
	Afternoon	14.00	1.5	7.8	14			
18	Morning	06.00	1.5	7.8	14			
	Afternoon	14.00	1.5	7.8	14			
19	Morning	06.00	1.5	7.8	14			
	Afternoon	14.00	1.5	7.8	14			
20	Morning	06.00	1.5	7.8	14			
	Afternoon	14.00	1.5	7.8	14			
21	Morning	06.00	1.5	7.8	14			
	Afternoon	14.00	1.5	7.8	14			

Comment :

12/11/15

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01

Rev. Date: 31/01/2015

BUILDING: The Strand thonglor

5151202

Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
			Chlorine (ppm)	pH				
22	Morning	04:00	1.0	7.4	14	[REDACTED]		
	Afternoon	16:00	1.0	7.8	18			
23	Morning	05:00	1.3	7.8	14			
	Afternoon	16:00	1.0	7.8	18			
24	Morning	06:00	1.3	7.8	18			
	Afternoon	14:00	1.0	7.4	14			
25	Morning	06:00	1.0	7.4	18			
	Afternoon	14:00	1.0	7.4	14			
26	Morning	06:00	1.0	7.8	18			
	Afternoon	18:00	1.0	7.8	18			
27	Morning	06:00	1.0	7.8	18			
	Afternoon	17:30	1.0	7.3	14			
28	Morning	06:00	1.0	7.8	18			
	Afternoon	14:00	1.0	7.4	14			

Comment:

29, 11, 66

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND



Ref No: JLL-OP-SN-004/01

Rev. Date: 31/01/2015

Month: Year:

The Strand thonglor

25/1/15

Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
			Chlorine (ppm)	pH				
22	Morning	07:00	1.5	7.4	14			
	Afternoon	16:00	1.5	7.4	18			
23	Morning	05:00	1.5	7.4	14			
	Afternoon	16:00	1.5	7.4	18			
24	Morning	06:00	1.5	7.4	18			
	Afternoon	14:00	1.5	7.4	18			
25	Morning	06:00	1.5	7.4	18			
	Afternoon	14:00	1.5	7.4	18			
26	Morning	06:00	1.5	7.4	18			
	Afternoon	18:00	1.5	7.4	18			
27	Morning	06:00	1.5	7.4	18			
	Afternoon	17:30	1.0	7.4	18			
28	Morning	06:00	1.5	7.4	18			
	Afternoon	17:30	1.0	7.4	18			

Comment:

BS

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND								Ref No: JLL-OP-SN-004/01		
BUILDING : The Strand thonglor								Rev. Date : 31/01/2015		
Month : NOV Year : 2015										
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark			
		Chlorine (ppm)	pH							
29	Morning	06.00	1.0	7.8	[Redacted]	[Redacted]	* 100% normal 5.2.6.8.7 *			
	Afternoon	14.00	1.0	7.6						
30	Morning	06.15	1.0	7.8						
	Afternoon	17.00	1.0	7.8						
	Morning									
	Afternoon									
	Morning									
	Afternoon									
	Morning									
	Afternoon									
	Morning									
	Afternoon									
	Morning									
	Afternoon									

Comment : _____

BSE : _____

1, 12, 68

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND								Ref No: JLL-OP-SN-004/01		
BUILDING : The Strand thonglor								Rev. Date : 31/01/2015		
Month : NOV Year : 2565										
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark			
		Chlorine (ppm)	pH							
29	Morning	06.00	1.5	7.8	[Redacted]	[Redacted]	* 1/20-20/01/2015 * 22/01/2015 *			
	Afternoon	18.00	1.5	7.4						
30	Morning	06.15	1.0	7.4						
	Afternoon	17.00	5.0	7.9						
	Morning									
	Afternoon									
	Morning									
	Afternoon									
	Morning									
	Afternoon									
	Morning									
	Afternoon									
	Morning									
	Afternoon									

Comment : _____

BSE : _____

1, 12, 68

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: OCT		Year: 2022							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
1	Morning	6.00	7.8	19					
	Afternoon	14:00	8.4	14					
2	Morning	6:00	7.6	19					
	Afternoon	14:00	8.4	14					
3	Morning	6:00	7.8	14					
	Afternoon	17:00	7.8	18					
4	Morning	08:00	8.4	14					
	Afternoon	16:00	7.8	18					
5	Morning	07:00	8.4	14					
	Afternoon	14:00	7.8	18					
6	Morning	06:00	7.8	18					
	Afternoon	16:30	7.9	18					
7	Morning	06:00	8.8	18					
	Afternoon	16:00	7.9	14					

Comment: _____

BSE: _____

11, 10, 68

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01 Rev. Date: 31/01/2015 Month: OCT Year: 2022									
BUILDING: The Strand thonglor (25.10m)									
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
1	Morning	6:00	3.0	7.4	17	[Redacted]			
	Afternoon	14:00	1.5	8.4	14				
2	Morning	6:00	3.0	7.4	19				
	Afternoon	14:00	1.5	8.4	14				
3	Morning	6:00	1.5	7.8	14				
	Afternoon	17:00	1.5	7.8	14				
4	Morning	07:00	1.5	8.4	14				
	Afternoon	16:00	1.0	7.8	18				
5	Morning	04:00	1.5	8.4	14				
	Afternoon	14:00	1.0	7.8	18				
6	Morning	06:00	1.5	8.4	14				
	Afternoon	16:00	1.0	7.8	18				
7	Morning	06:00	3.0	8.8	18				
	Afternoon	16:00	3.0	7.8	18				
Comment: _____ B _____									

11, 10, 66

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
BUILDING: The Strand thonglor		Month: OCT		Year: 2565					
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
8	Morning	06.00	1.0	7.8	[Redacted]				
	Afternoon	16.00	1.0	7.6					
9	Morning	06.00	1.0	7.8					
	Afternoon	16.00	1.0	7.6					
10	Morning	06.00	1.0	7.8					
	Afternoon	16.30	1.0	7.8					
11	Morning	06.00	1.0	7.8					
	Afternoon	16.30	1.0	7.8					
12	Morning	07.00	1.0	7.6					
	Afternoon	16.00	1.0	7.8					
13	Morning	07.00	1.0	7.6					
	Afternoon	16.30	1.0	7.8					
14	Morning	06.00	1.0	7.6					
	Afternoon	16.00	1.0	7.8					
Comment:								18, 10, 68	

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: Oct		Year: 2015							
BUILDING: The Strand thonglor 65/107									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
8	Morning	1.5	7.8	18	[Redacted]				
	Afternoon	1.5	7.8	18					
9	Morning	3.0	7.8	18					
	Afternoon	1.5	7.8	18					
10	Morning	1.5	7.8	18					
	Afternoon	1.5	7.8	18					
11	Morning	1.5	7.8	18					
	Afternoon	1.5	7.8	18					
12	Morning	1.5	7.8	18					
	Afternoon	1.5	7.8	18					
13	Morning	1.5	7.8	18					
	Afternoon	1.5	7.8	18					
14	Morning	1.5	7.8	18					
	Afternoon	1.5	7.8	18					
Comment:								18 / 10 / 18	

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							
BUILDING :		The Strand thonglor		Ref No: JLL-OP-SN-004/01 Rev. Date: 31/01/2015 Month: OCT Year: 2565			
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
15	Morning	1.0	7.8	18			
	Afternoon	1.0	7.8	18			
16	Morning	1.0	7.8	18			
	Afternoon	1.0	7.8	18			
17	Morning	1.0	7.8	18			
	Afternoon	1.0	7.8	18			
18	Morning	1.0	7.8	18			
	Afternoon	1.0	7.8	18			
19	Morning	1.0	7.8	18			
	Afternoon	1.0	7.8	18			
20	Morning	1.0	7.8	18			
	Afternoon	1.0	7.8	18			
21	Morning	1.0	7.8	18			
	Afternoon	1.0	7.8	18			

Comment: _____

20, 10, 60

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							
BUILDING :		The Strand thonglor		252 1007			
Date		Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)
				Chlorine (ppm)	pH		Verified By (Sr. Technician)
15	Morning	06:00	1.5	7.8	18	[Redacted]	Remark
	Afternoon	16:30	1.5	7.8	18		
16	Morning	06:00	1.3	7.8	18		
	Afternoon	17:00	1.5	7.8	18		
17	Morning	06:00	1.5	7.8	18		
	Afternoon	16:45	1.0	7.8	18		
18	Morning	07:00	1.5	7.8	18		
	Afternoon	16:40	1.0	7.8	18		
19	Morning	07:00	1.5	7.8	18		
	Afternoon	16:00	1.5	7.8	18		
20	Morning	06:00	1.0	7.8	18		
	Afternoon	16:00	1.0	7.8	18		
21	Morning	6:00	1.0	7.8	18		
	Afternoon	16:30	3.0	7.8	18		

Comment: _____

20 / 10 / 68

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							
Ref No: JLL-OP-SN-004/01							
Rev. Date: 31/01/2015							
Month: 01		Year: 2022					
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
22	Morning	6.00	7.4	14	[Redacted]	[Redacted]	
	Afternoon	6.00	7.8	18			
23	Morning	6.00	7.4	14			
	Afternoon	6.00	7.8	18			
24	Morning	6.00	7.4	14			
	Afternoon	6.00	7.8	18			
25	Morning	6.00	7.4	14			
	Afternoon	6.30	7.8	18			
26	Morning	7.00	7.8	18			
	Afternoon	6.30	7.8	18			
27	Morning	6.00	7.8	18			
	Afternoon	6.00	7.8	18			
28	Morning	6.00	7.8	18			
	Afternoon	6.00	7.8	18			

Comment: _____

29, 10, 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							
Ref No: JLL-OP-SN-004/01		Rev. Date: 31/01/2015					
Month: OCT		Year: 2022					
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
22	Morning	1.5	7.8	18	[Redacted]		
	Afternoon	1.5	7.8	18			
23	Morning	1.5	7.8	18			
	Afternoon	1.0	7.8	18			
24	Morning	1.5	7.8	18			
	Afternoon	1.5	7.8	18			
25	Morning	1.5	7.8	18			
	Afternoon	1.5	7.8	18			
26	Morning	1.5	7.8	18			
	Afternoon	1.5	7.8	18			
27	Morning	1.0	7.8	18			
	Afternoon	1.0	7.8	18			
28	Morning	1.0	7.8	18			
	Afternoon	1.0	7.8	18			
29	Morning	1.0	7.8	18			
	Afternoon	1.0	7.8	18			

29 / 10 / 66

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date : 31/01/2015									
Month : Oct		Year : 22							
BUILDING : The Strand thonglor		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
Date	Shift / Time	Chlorine (ppm)	pH						
29	Morning	1.0	7.8	18					
	Afternoon	1.0	7.4	14					
30	Morning	1.3	7.8	18					
	Afternoon	1.0	7.4	14					
31	Morning	1.0	7.8	18					
	Afternoon	1.0	7.6	18					
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								

Comment : _____

BSE : _____

A / 11 / 68

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: Oct		Year: 2015							
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
29	Morning	06:00	1.0	7.8	18	[Redacted]	[Redacted]		
	Afternoon	14:00	1.0	7.4	14				
30	Morning	06:00	2.2	7.8	18	[Redacted]	[Redacted]		
	Afternoon	14:00	1.5	7.4	14				
31	Morning	06:00	1.5	7.8	18	[Redacted]	[Redacted]		
	Afternoon	16:00	1.6	7.4	18				
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								

Comment: _____
 BSE: _____
 1 / 11 / 66

Note: pH: normal range 7.2 - 7.8
 Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: Sep		Year: 2022							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
1	Morning	1.5	7.8	18	[Redacted]	[Redacted]			
	Afternoon	1.0	7.4	18					
2	Morning	1.0	7.8	18					
	Afternoon	1.0	7.8	18					
3	Morning	1.0	7.8	18					
	Afternoon	1.0	7.8	18					
4	Morning	1.0	7.8	18					
	Afternoon	1.0	7.8	18					
5	Morning	1.0	7.8	18					
	Afternoon	1.0	7.8	18					
6	Morning	1.0	7.8	18					
	Afternoon	1.0	7.8	18					
7	Morning	1.0	7.8	18					
	Afternoon	1.0	7.8	18					

BSE: 9, 9, 68

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: Sep		Year: 2022							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
1	Morning	1.5	7.8	18					
	Afternoon	1.5	7.4	14					
2	Morning	1.5	7.8	18					
	Afternoon	1.5	7.8	18					
3	Morning	1.5	7.8	18					
	Afternoon	1.5	7.8	14					
4	Morning	1.5	7.8	18					
	Afternoon	1.5	7.8	18					
5	Morning	1.5	7.8	18					
	Afternoon	1.5	7.8	18					
6	Morning	1.5	7.8	18					
	Afternoon	1.5	7.8	18					
7	Morning	1.5	7.8	18					
	Afternoon	1.5	7.8	18					
Comment: _____ _____ _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							
Ref No: JLL-OP-SN-004/01		Rev. Date: 31/01/2015		Month: Sep Year: 2022			
BUILDING: The Strand thonglor		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
Date	Shift / Time	Chlorine (ppm)	pH				
8	Morning	1.0	7.8	18	[Redacted]		
	Afternoon	1.0	7.9	18			
9	Morning	1.0	7.8	18			
	Afternoon	1.0	7.8	18			
10	Morning	1.0	7.8	18			
	Afternoon	1.0	7.9	18			
11	Morning	1.0	7.8	18			
	Afternoon	1.0	7.8	18			
12	Morning	1.0	7.8	18			
	Afternoon	1.0	7.8	18			
13	Morning	1.0	7.8	18			
	Afternoon	1.0	7.8	18			
14	Morning	1.0	7.8	18			
	Afternoon	1.0	7.8	18			

Comment: _____

DSF: 15, 9, 66

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING : The Strand thonglor		Ref No: JLL-OP-SN-004/01		Rev. Date: 31/01/2015		Month: Sep		Year: 2018	
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
8	Morning	06.00	1.5	7.8	18	[Redacted]			
	Afternoon	16.30	3.0	7.8	18				
9	Morning	06.00	1.5	7.8	18				
	Afternoon	16.28	1.5	7.8	18				
10	Morning	06.00	1.5	7.8	18				
	Afternoon	14.30	1.5	7.8	18				
11	Morning	06.00	1.5	7.8	18				
	Afternoon	14.00	1.5	7.8	18				
12	Morning	06.00	1.5	7.8	18				
	Afternoon	14.00	1.5	7.8	18				
13	Morning	06.00	1.5	7.8	18				
	Afternoon	16.30	3.0	7.4	18				
14	Morning	06.00	1.5	7.8	18				
	Afternoon	16.35	3.0	7.4	18				
Comment: _____ _____ _____									

15 / 9 / 68

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01										
Rev. Date: 31/01/2015										
Month: Sep Year: 2022										
BUILDING: The Strand thonglor (C 1st Flr)										
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark			
		Chlorine (ppm)	pH							
15	Morning	06:00	1.0	7.8	[Redacted]	[Redacted]				
	Afternoon	16:31	1.0	7.4						
16	Morning	06:00	1.0	7.8						
	Afternoon	16:10	1.0	7.8						
17	Morning	06:00	1.0	7.8						
	Afternoon	16:30	1.0	7.8						
18	Morning	06:00	1.0	7.8						
	Afternoon	14:00	1.0	7.4						
19	Morning	06:00	1.0	7.8						
	Afternoon	15:00	1.0	7.8						
20	Morning	07:00	1.0	7.4						
	Afternoon	16:00	1.0	7.8						
21	Morning	07:00	1.0	7.4						
	Afternoon	16:30	1.0	7.8						
Comment: _____ _____ 22, 9, 28										

-105+1020 532/005
A 151050

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01					
Rev. Date: 31/01/2015					
Month: Sep Year: 2022					
BUILDING: The Strand thonglor		Recorded By (Technician)		Verified By (Sr. Technician)	Remark
Date	Shift / Time	Water Quality		Filter Pressure (psi)	
		Chlorine (ppm)	pH		
15	Morning 06:00	1.5	7.8	18	
	Afternoon 16:00	1.0	7.9	14	
16	Morning 06:00	1.5	7.8	18	
	Afternoon 16:10	1.5	7.8	18	
17	Morning 06:00	1.5	7.8	18	
	Afternoon 16:30	1.5	7.8	18	
18	Morning 06:00	1.5	7.8	18	
	Afternoon 14:00	1.5	7.8	18	
19	Morning 06:00	1.5	7.8	18	
	Afternoon 16:00	1.5	7.8	18	
20	Morning 07:00	1.5	7.8	18	
	Afternoon 16:00	1.5	7.8	18	
21	Morning 07:00	1.5	7.8	18	
	Afternoon 16:30	1.5	7.8	18	
Comment: <u>22, 9, 60</u> DSE: <u>22, 9, 60</u>					

102011120 1521087
3 151800

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		Ref No: JLL-OP-SN-004/01		Rev. Date : 31/01/2015		Month : Sep Year : 2012	
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
22	Morning	06.00	1.0	7.8	[Redacted]	[Redacted]			
	Afternoon	17.30	1.5	7.6					
23	Morning	06.00	1.0	7.8					
	Afternoon	16.30	1.0	7.4					
24	Morning	06.00	1.0	7.8					
	Afternoon	17.00	1.0	7.6					
25	Morning	06.00	1.0	7.8					
	Afternoon	14.00	1.0	7.4					
26	Morning	06.00	1.0	7.8					
	Afternoon	14.00	1.0	7.4					
27	Morning	06.00	1.5	7.8					
	Afternoon	16.30	1.0	7.4					
28	Morning	6.30	1.0	7.6					
	Afternoon	16.30	1.0	7.8					

Comment : _____

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							
Ref No: JLL-OP-SN-004/01							
Rev. Date: 31/01/2015							
Month: Sep		Year: 2022					
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
22	Morning	06.00	1.5	7.8	[Redacted]		
	Afternoon	17.00	3.0	7.4			
23	Morning	06.00	1.5	7.8			
	Afternoon	16.30	1.5	7.8			
24	Morning	06.00	1.5	7.8			
	Afternoon	17.00	1.5	7.8			
25	Morning	06.00	3.0	7.8			
	Afternoon	14.00	1.5	7.4			
26	Morning	06.00	1.5	7.8			
	Afternoon	14.00	1.5	7.4			
27	Morning	06.00	1.5	7.8			
	Afternoon	16.30	3.0	7.8			
28	Morning	06.30	1.5	7.8			
	Afternoon	16.30	3.0	7.4			

Comment:

29, 9, 68

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		62/24		Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015 Month : SEP Year : 2022			
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
29	Morning	7.00	1.0	7.8	14	[Redacted]	[Redacted]		
	Afternoon	16.10	1.0	7.8	18				
30	Morning	6.00	1.0	7.8	18	[Redacted]	[Redacted]		
	Afternoon	16.10	1.0	7.8	18				
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								

Comment : _____
 BSE : _____
 1, 10, 68

Note: pH: normal range 7.2 - 7.8
 Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: SEP		Year: 2022							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
29	Morning	3.0	7.4	18					
	Afternoon	3.0	7.8	18					
30	Morning	3.0	7.8	18					
	Afternoon	3.0	7.8	18					
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								

Comment: _____

BSE: _____

1, 10, 66

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND								Ref No: JLL-OP-SN-004/01
BUILDING : The Strand thonglor								Rev. Date : 31/01/2015
Month : <u>August</u> Year : <u>2022</u>								
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
		Chlorine (ppm)	pH					
1.	Morning	06.00	1.0	7.8	[Redacted]			
	Afternoon	16.00	1.0	7.8				
2	Morning	06.00	1.0	7.8				
	Afternoon	16.00	1.0	7.8				
3	Morning	06.30	1.0	7.8				
	Afternoon	16.05	1.0	7.9				
4	Morning	06.30	1.0	7.8				
	Afternoon	16.00	1.0	7.8				
5	Morning	07.00	1.0	7.8				
	Afternoon	16.08	1.0	7.9				
6	Morning	07.10	1.0	7.8				
	Afternoon	16.05	1.0	7.8				
7	Morning	07.00	1.0	7.8				
	Afternoon	15.30	1.0	7.8				
Comment : _____ _____ _____								

8 / 8 / 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND								Ref No: JLL-OP-SN-004/01
BUILDING : The Strand thonglor								Rev. Date : 31/01/2015
AS 1010								Month : AUGUST Year : 2022
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
			Chlorine (ppm)	pH				
1	Morning	06.00	1.5	7.8	18	[Redacted]		
	Afternoon	16.00	1.5	7.8	18			
2	Morning	06.00	1.5	7.8	18			
	Afternoon	16.00	1.5	7.8	18			
3	Morning	06.30	1.5	7.8	18			
	Afternoon	16.05	1.0	7.8	18			
4	Morning	06.30	1.5	7.8	18			
	Afternoon	16.08	1.5	7.8	18			
5	Morning	07.16	1.5	7.8	18			
	Afternoon	16.08	1.5	7.8	18			
6	Morning	07.10	1.5	7.4	14			
	Afternoon	16.05	1.0	7.8	18			
7	Morning	07.00	1.5	7.4	14			
	Afternoon	16.00	1.5	7.8	14			
Comment : _____ _____ _____								8 / 8 / 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01

Rev. Date : 31/01/2015

BUILDING : The Strand thonglor

Month : August Year : 2022

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
8	Morning	1.5	7.8	18	[Redacted]	[Redacted]	
	Afternoon	1.5	7.8	18			
9	Morning	1.5	7.8	18			
	Afternoon	1.0	7.6	18			
10	Morning	1.0	7.4	18			
	Afternoon	1.0	7.8	18			
11	Morning	1.0	7.8	18			
	Afternoon	1.0	7.8	18			
12	Morning	1.0	7.8	18			
	Afternoon	1.0	7.8	18			
13	Morning	1.0	7.8	18			
	Afternoon	1.0	7.8	18			
14	Morning	1.0	7.8	18			
	Afternoon	1.0	7.8	18			

Comment :

10 / 8 / 68

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015 Month : Aug Year : 66					
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
8	Morning	07:13	3.0	7.8	[Redacted]				
	Afternoon	15:30	1.5	7.8					
9	Morning	06:57	1.5	7.8					
	Afternoon	16:30	1.5	7.6					
10	Morning	07:50	1.5	7.4					
	Afternoon	16:30	1.5	7.9					
11	Morning	08:00	1.5	7.6					
	Afternoon	16:00	1.5	7.6					
12	Morning	06:00	1.5	7.8					
	Afternoon	16:00	1.5	7.8					
13	Morning	06:30	1.5	7.6					
	Afternoon	16:00	1.5	7.8					
14	Morning	07:00	1.5	7.8					
	Afternoon	16:00	1.5	7.8					
Comment : _____ _____ _____									

16, 8, 66

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		25-107		Ref No: JLL-OP-SN-004/01 Rev. Date: 31/01/2015			
Date		Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Morning		Chlorine (ppm)	pH				
15		06:00		1.5	7.8	18			
		Afternoon		1.5	7.8	18			
16		08:00		1.5	7.4	18			
		Afternoon		1.5	7.8	18			
17		07:11		1.5	7.8	18			
		Afternoon		1.5	7.8	18			
18		06:00		1.5	7.8	18			
		Afternoon		1.5	7.8	18			
19		06:00		1.5	7.8	18			
		Afternoon		3.0	7.8	18			
20		06:00		1.5	7.8	18			
		Afternoon		3.0	7.8	18			
21		06:00		3.0	7.8	18			
		Afternoon		3.0	7.8	18			
Comment: _____ _____ _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm




LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date : 31/01/2015									
Month : <u>AUGUST</u>		Year : <u>2022</u>							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
15	Morning	1.0	7.8	18	[Redacted]				
	Afternoon	1.0	7.8	18					
16	Morning	2.0	7.8	18					
	Afternoon	1.0	7.8	18					
17	Morning	1.0	7.8	18					
	Afternoon	1.0	7.8	18					
18	Morning	1.0	7.8	18					
	Afternoon	1.0	7.8	18					
19	Morning	1.5	7.8	18					
	Afternoon	1.0	7.8	18					
20	Morning	1.5	7.8	18					
	Afternoon	1.0	7.8	18					
21	Morning	1.5	7.8	18					
	Afternoon	1.5	7.8	18					
Comment: _____ _____ _____									

22/ 8 / 68

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		Ref No: JLL-OP-SN-004/01		Rev. Date : 31/01/2015		Month : <u>Aug</u> Year : <u>2022</u>	
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
<u>22</u>	Morning	<u>06:00</u>	<u>1.0</u>	<u>7.8</u>	<u>18</u>				
	Afternoon	<u>16:15</u>	<u>1.0</u>	<u>7.8</u>	<u>18</u>				
<u>23</u>	Morning	<u>06:27</u>	<u>1.5</u>	<u>7.8</u>	<u>16</u>				
	Afternoon	<u>16:00</u>	<u>1.0</u>	<u>7.8</u>	<u>18</u>				
<u>24</u>	Morning	<u>06:10</u>	<u>1.0</u>	<u>7.8</u>	<u>18</u>				
	Afternoon	<u>16:20</u>	<u>1.0</u>	<u>7.8</u>	<u>18</u>				
<u>25</u>	Morning	<u>06:00</u>	<u>1.0</u>	<u>7.8</u>	<u>18</u>				
	Afternoon	<u>16:30</u>	<u>1.0</u>	<u>7.8</u>	<u>18</u>				
<u>26</u>	Morning	<u>06:00</u>	<u>1.0</u>	<u>7.8</u>	<u>18</u>				
	Afternoon	<u>16:20</u>	<u>1.0</u>	<u>7.8</u>	<u>18</u>				
<u>27</u>	Morning	<u>06:00</u>	<u>1.0</u>	<u>7.8</u>	<u>18</u>				
	Afternoon	<u>15:20</u>	<u>1.0</u>	<u>7.8</u>	<u>18</u>				
<u>28</u>	Morning	<u>06:00</u>	<u>1.0</u>	<u>7.8</u>	<u>18</u>				
	Afternoon	<u>16:10</u>	<u>1.0</u>	<u>7.8</u>	<u>18</u>				
Comment : _____ _____ _____									

29 / 8 / 22

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND						
BUILDING :		The Strand thonglor		NSR 1077		
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)
			Chlorine (ppm)	pH		
22	Morning	06:20	1.5	7.8	18	[Redacted]
	Afternoon	16:15	1.5	7.8	18	
23	Morning	06:28	3.0	7.8	16	[Redacted]
	Afternoon	16:00	1.5	7.8	18	
24	Morning	06:10	1.5	7.8	18	[Redacted]
	Afternoon	16:20	1.5	7.8	18	
25	Morning	06:30	1.5	7.8	18	[Redacted]
	Afternoon	16:30	1.5	7.8	18	
26	Morning	06:00	1.5	7.8	16	[Redacted]
	Afternoon	16:20	1.5	7.8	18	
27	Morning	06:00	1.5	7.8	18	[Redacted]
	Afternoon	15:20	1.5	7.8	18	
28	Morning	06:00	1.5	7.8	18	[Redacted]
	Afternoon	16:10	1.5	7.8	18	

Ref No: JLL-OP-SN-004/01

Rev. Date: 31/01/2015

Month: AUG Year: 2022

Verified By (Sr. Technician)

Remark

29, 8, 68

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01

Rev. Date : 31/01/2015

Month : AUG Year : 2022

BUILDING : The Strand thonglor 23-640

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
29	Morning	1.0	7.8	18	[REDACTED]	[REDACTED]	
	Afternoon	1.0	7.8	18			
30	Morning	1.0	7.8	18			
	Afternoon	1.0	7.8	18			
31	Morning	1.0	7.8	18			
	Afternoon	1.0	7.8	18			
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						

Comment :

BSE :

3 / 9 / 60

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		Ref No: JLL-OP-SN-004/01		Rev. Date : 31/01/2015		Month : AUG Year : 2022	
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
29	Morning	1.5	7.8	18	[Redacted]	[Redacted]	[Redacted]		
	Afternoon	1.5	7.8	18					
30	Morning	1.5	7.8	18	[Redacted]	[Redacted]	[Redacted]		
	Afternoon	3.0	7.8	18					
31	Morning	1.0	7.8	18	[Redacted]	[Redacted]	[Redacted]		
	Afternoon	3.0	7.8	18					
	Morning				[Redacted]	[Redacted]	[Redacted]		
	Afternoon								
	Morning				[Redacted]	[Redacted]	[Redacted]		
	Afternoon								
	Morning				[Redacted]	[Redacted]	[Redacted]		
	Afternoon								
	Morning				[Redacted]	[Redacted]	[Redacted]		
	Afternoon								

Comment: _____

BSE : _____

3 / 9 / 26

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015 Month : <u>July</u> Year : <u>2022</u>					
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
1	Morning	0.2	8.2	18	[Redacted]				
	Afternoon	0.2	8.2	18					
2	Morning	0.2	8.2	18					
	Afternoon	0.2	8.2	18					
3	Morning	0.2	8.2	18					
	Afternoon	0.2	8.2	18					
4	Morning	0.2	8.2	18					
	Afternoon	0.2	8.2	18					
5	Morning	0.2	8.2	18					
	Afternoon	0.2	8.2	18					
6	Morning	0.2	8.2	18					
	Afternoon	0.2	8.2	18					
7	Morning	0.2	8.2	18					
	Afternoon	0.2	8.2	18					
Comment : _____ _____ _____									

8 / 7 / 68

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		Fr. 16/11		Ref No: JLL-OP-SN-004/01 Rev. Date: 31/01/2015 Month: July Year: 2015			
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
1	Morning	04:00	1.0	8.2	18	[Redacted]			
	Afternoon	16:00	1.0	8.2	18				
2	Morning	04:00	1.0	8.2	18				
	Afternoon	15:00	1.0	8.2	18				
3	Morning	07:00	1.0	8.2	18				
	Afternoon	15:00	1.0	8.2	18				
4	Morning	09:00	1.0	8.2	18				
	Afternoon	17:00	0.6	8.2	18				
5	Morning	08:00	0.6	8.2	18				
	Afternoon	16:00	1.0	8.2	18				
6	Morning	07:07	1.0	8.2	18				
	Afternoon	16:20	1.0	8.2	18				
7	Morning	08:00	1.0	8.2	18				
	Afternoon	15:00	1.3	8.2	18				
Comment: _____ _____ _____									

6 / 7 / 68

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		Ref No: JLL-OP-SN-004/01		Rev. Date : 31/01/2015		Month : <u>July</u> Year : <u>2015</u>	
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
8	Morning	7.00	1.0	8.0	14	[Redacted]			
	Afternoon	16.20	1.0	8.0	14				
9	Morning	7.00	1.0	8.0	14				
	Afternoon	16.10	1.0	8.0	14				
10	Morning	7.00	1.0	8.0	14				
	Afternoon	16.13	1.0	8.0	14				
11	Morning	7.00	1.0	7.8	14				
	Afternoon	15.57	1.0	7.8	14				
12	Morning	7.00	1.0	7.4	14				
	Afternoon	16.20	1.0	7.4	14				
13	Morning	7.00	1.0	7.4	14				
	Afternoon	16.15	1.0	7.8	14				
14	Morning	7.00	1.5	7.4	14				
	Afternoon	16.05	1.5	7.4	14				
Comment : _____ _____ _____									

14/ 7 / 14

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		Ref No: JLL-OP-SN-004/01		Rev. Date : 31/01/2015		Year : 2022	
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
8	Morning	7.00	1.0	8.0	18	[Redacted]			
	Afternoon	16.07	1.0	8.0	18				
9	Morning	7.00	1.0	8.0	18				
	Afternoon	16.25	1.0	8.0	18				
10	Morning	7.00	1.0	8.0	18				
	Afternoon	16.30	1.0	8.0	18				
11	Morning	7.00	1.0	7.8	18				
	Afternoon	16.05	1.0	7.8	18				
12	Morning	7.00	1.5	7.8	18				
	Afternoon	16.10	1.5	7.8	18				
13	Morning	7.00	1.5	7.8	18				
	Afternoon	16.08	1.5	7.8	18				
14	Morning	7.00	1.5	7.8	18				
	Afternoon	16.30	1.5	7.8	18				
Comment : _____ _____ _____									

18, 2, 65

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm




LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		Ref No: JLL-OP-SN-004/01 Rev. Date: 31/01/2015 Month: <u>July</u> Year: <u>2015</u>					
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
15	Morning	7.00	1.5	7.8	18	[Redacted]			
	Afternoon	16.10	1.6	8.8	18				
16	Morning	7.00	1.5	7.8	18				
	Afternoon	16.30	1.8	8.8	18				
17	Morning	7.00	1.5	7.8	18				
	Afternoon	16.00	2.5	7.8	18				
18	Morning	7.00	3.0	7.8	18				
	Afternoon	16.15	3.0	7.8	18				
19	Morning	7.00	3.0	7.8	18				
	Afternoon	17.00	2.3	7.8	18				
20	Morning	7.00	1.6	7.8	18				
	Afternoon	16.55	1.5	8.8	18				
21	Morning	7.00	1.5	7.8	18				
	Afternoon	15.00	1.5	7.8	18				
Comment: _____ _____ _____									

22 / 7 / 18

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND													
BUILDING :		The Strand thonglor		752167		Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015							
Date		Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark				
		Morning		Chlorine (ppm)	pH								
15	Morning	7.00	1.5	7.4	14								
	Afternoon	16.10	1.5	7.8	18								
16	Morning	7.00	1.5	7.4	14								
	Afternoon	16.30	1.5	7.8	18								
17	Morning	7.00	1.5	7.4	14								
	Afternoon	16.00	1.5	7.8	18								
18	Morning	7.00	1.5	7.4	14								
	Afternoon	16.00	1.5	7.8	18								
19	Morning	7.00	1.0	7.8	14								
	Afternoon	16.50	1.0	7.4	18								
20	Morning	7.00	1.0	7.8	14								
	Afternoon	16.00	1.0	7.8	18								
21	Morning	7.00	1.0	7.8	18								
	Afternoon	15.00	1.0	7.8	18								
Comment : _____ _____ _____													

22, 8, 166

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		Ref No: JLL-OP-SN-004/01		Rev. Date : 31/01/2015		Year : 2565	
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
22	Morning	02:00	1.3	7.8	[Redacted]				
	Afternoon	16:00	1.3	7.8					
23	Morning	07:00	1.3	7.8					
	Afternoon	16:00	1.3	7.8					
24	Morning	07:00	1.3	7.8					
	Afternoon	16:00	1.3	7.8					
25	Morning	07:00	1.3	7.8					
	Afternoon	16:00	1.3	7.8					
26	Morning	07:00	1.0	7.8					
	Afternoon	16:00	1.0	7.8					
27	Morning	07:00	1.0	7.8					
	Afternoon	16:00	1.0	7.8					
28	Morning	07:00	1.0	7.8					
	Afternoon	16:00	1.0	7.8					
Comment : _____ _____ _____									

29 / 7 / 68

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: July		Year: 2015							
BUILDING: The Strand thonglor 85-127		Recorded By (Technician)		Verified By (Sr. Technician)		Remark			
Date	Shift / Time	Water Quality		Filter Pressure (psi)					
		Chlorine (ppm)	pH						
22	Morning 07:00	1.5	7.8	18					
	Afternoon 16:00	1.5	7.8	18					
23	Morning 07:00	1.5	7.8	18					
	Afternoon 16:00	1.5	7.8	18					
24	Morning 07:00	1.5	7.8	18					
	Afternoon 16:00	1.5	7.8	18					
25	Morning 07:00	1.5	7.8	18					
	Afternoon 16:10	1.5	7.8	18					
26	Morning 07:00	1.5	7.8	18					
	Afternoon 16:00	1.5	7.8	18					
27	Morning 07:00	1.5	7.8	18					
	Afternoon 16:00	1.5	7.8	18					
28	Morning 07:00	1.5	7.8	18					
	Afternoon 16:00	1.5	7.8	18					
Comment: _____ _____ _____									

29 / 7 / 18

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		505-2nd		Ref No: JLL-OP-SN-004/01 Rev. Date : July 31/01/2015 Month : July Year : 2022			
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
29	Morning	7:00	1.0	7.8	18				
	Afternoon	16:00	1.0	7.8	18				
30	Morning	7:00	1.0	7.8	18				
	Afternoon	16:00	1.0	7.8	18				
31	Morning	7:00	1.0	7.8	18				
	Afternoon	16:00	1.0	7.8	18				
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								

Comment : _____
 BSE : _____
 9 / 8 / 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		Location		Ref No: JLL-OP-SN-004/01			
						Rev. Date : 31/01/2015			
						Month : July Year : 2022			
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
29	Morning	7:00	1.5	7.8	18	[Redacted]	[Redacted]		
	Afternoon	16:00	1.5	7.8	18				
30	Morning	7:00	1.5	7.8	18				
	Afternoon	16:00	1.5	7.8	18				
31	Morning	7:00	1.5	7.8	18				
	Afternoon	16:00	1.5	7.8	18				
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								

Comment : _____


BSE : _____

9 / 8 / 68

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							
BUILDING :		The Strand thonglor		Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015 Month : <u>May</u> Year : <u>2015</u>			
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
1	Morning	7.00	0.2	8.2			
	Afternoon	14.30	0.2	8.2			
2	Morning	7.00	0.2	8.2			
	Afternoon	14.30	1.0	8.2			
3	Morning	7.00	0.2	8.2			
	Afternoon	14.30	1.0	8.2			
4	Morning	7.00	0.2	8.2			
	Afternoon	14.30	0.2	8.2			
5	Morning	7.00	0.2	8.2			
	Afternoon	14.30	0.2	8.2			
6	Morning	7.00	0.4	8.2			
	Afternoon	14.30	0.2	8.2			
7	Morning	06.20	0.2	8.2			
	Afternoon	14.30	0.2	8.2			

Comment: _____

10/6/15

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm




LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01

Rev. Date : 31/01/2015

Month : 27 Nov Year : 2016

BUILDING : The Strand thonglor 25100

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
1	Morning	1.5	8.2	18			
	Afternoon	0.2	8.2	16			
2	Morning	1.5	8.2	16			
	Afternoon	1.5	8.0	18			
3	Morning	1.5	8.2	18			
	Afternoon	2.0	8.2	16			
4	Morning	1.5	8.2	16			
	Afternoon	0.2	8.2	18			
5	Morning	0.2	8.2	18			
	Afternoon	0.2	8.2	14			
6	Morning	1.3	8.2	16			
	Afternoon	1.3	8.2	17			
7	Morning	0.2	8.2	18			
	Afternoon	0.2	8.2	18			

Comment :

10/ 6 / 16

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015 Month : <u>May</u> Year : <u>2015</u>					
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
8	Morning	7:00	0.2	8.2	[Redacted]	[Redacted]			
	Afternoon	14:30	0.2	8.2					
9	Morning	06:30	0.2	8.2					
	Afternoon	14:30	0.2	8.2					
10	Morning	06:30	0.2	8.2					
	Afternoon	14:30	0.2	8.2					
11	Morning	06:30	0.2	8.2					
	Afternoon	16:00	0.2	8.2					
12	Morning	7:00	0.2	8.2					
	Afternoon	16:00	0.2	8.2					
13	Morning	7:00	0.2	8.2					
	Afternoon	14:30	0.2	8.2					
14	Morning	06:30	0.2	8.2					
	Afternoon	16:30	0.2	8.2					
Comment : _____ _____ _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		25118n		Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015 Month : <u>27 Nov</u> Year : <u>2015</u>			
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
8	Morning	0.2	8.2	18	[Redacted]				
	Afternoon	0.2	8.2	18					
9	Morning	0.2	8.2	18					
	Afternoon	0.2	8.2	18					
10	Morning	0.2	8.2	18					
	Afternoon	0.2	8.2	18					
11	Morning	0.2	8.2	16					
	Afternoon	0.2	8.2	18					
12	Morning	0.2	8.2	18					
	Afternoon	0.2	8.2	18					
13	Morning	1.0	8.2	18					
	Afternoon	1.0	8.2	18					
14	Morning	1.0	8.2	18					
	Afternoon	1.0	8.2	18					
Comment : _____ _____ _____									

21 / 6 / 15

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		Ref No: JLL-OP-SN-004/01		Rev. Date : 31/01/2015			
		Date		Month : 2/2015		Year : 2568			
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
15	Morning	06:30	0.2	8.2	18	[Redacted]		* ปิดเครื่อง	
	Afternoon	14:00	0.2	8.2	18				
16	Morning	06:30	0.2	8.2	18				
	Afternoon	15:30	0.2	8.2	18				
17	Morning	06:30	0.2	8.2	18				
	Afternoon	15:00	0.2	8.2	18				
18	Morning	06:30	0.2	8.2	18				
	Afternoon	15:00	0.2	8.2	18				
19	Morning	06:30	0.2	8.2	18				
	Afternoon	15:00	0.2	8.2	18				
20	Morning	06:30	0.2	8.2	18				
	Afternoon	15:00	0.2	8.2	18				
21	Morning	06:00	0.2	8.2	18				
	Afternoon	14:00	0.2	8.2	18				
Comment : _____ _____ _____									

Note: pH: normal range 7.2 - 7.8
 Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01

Rev. Date : 31/01/2015

Month : 2/10/15 Year : 2568

BUILDING : The Strand thonglor 25180

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
15	Morning 06:30	0.2	8.2	[REDACTED]	[REDACTED]	[REDACTED]	
	Afternoon 14:00	0.2	8.2				
16	Morning 06:30	0.2	8.1				
	Afternoon 15:30	0.2	8.2				
17	Morning 06:30	0.2	8.2				
	Afternoon 15:00	0.2	8.2				
18	Morning 06:30	0.2	8.2				
	Afternoon 15:00	0.2	8.2				
19	Morning 06:30	0.2	8.2				
	Afternoon 15:00	0.2	8.2				
20	Morning 07:00	0.2	8.2				
	Afternoon 15:00	0.2	8.2				
21	Morning 09:00	0.2	8.2				
	Afternoon 14:00	0.2	8.2				

* 25180

Comment :

20, 6, 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		es-Devi		Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015 Month : 27/06 Year : 2015			
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
22	Morning	09.10	0.2	8.2	18	[Redacted]			
	Afternoon	16.13	0.2	8.2	18				
23	Morning	09.00	0.2	8.2	18				
	Afternoon	16.10	0.2	8.2	18				
24	Morning	09.00	0.2	8.2	18				
	Afternoon	16.10	0.2	8.2	18				
25	Morning	09.00	0.2	8.2	18				
	Afternoon	16.10	0.2	8.2	18				
26	Morning	09.00	0.2	8.2	18				
	Afternoon	16.10	0.2	8.2	18				
27	Morning	09.00	0.2	8.2	18				
	Afternoon	15.00	0.2	8.2	18				
28	Morning	09.00	0.1	8.2	17				
	Afternoon	18.59	0.2	8.2	18				
Comment : _____ _____ _____									

29 / 6 / 15

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		S3180		Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015 Month : 27 Nov Year : 2568			
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
22	Morning	09:10	0.4	8.2	18	[Redacted]			
	Afternoon	16:09	0.4	8.2	18				
23	Morning	09:00	0.4	8.2	18				
	Afternoon	16:30	0.4	8.2	18				
24	Morning	09:00	0.4	8.2	18				
	Afternoon	16:30	0.4	8.2	18				
25	Morning	09:00	0.4	8.2	18				
	Afternoon	16:30	0.4	8.2	18				
26	Morning	09:00	0.4	8.2	18				
	Afternoon	16:30	0.4	8.2	18				
27	Morning	09:00	0.4	8.2	18				
	Afternoon	15:00	0.2	8.2	18				
28	Morning	07:00	0.1	8.2	17				
	Afternoon	15:58	0.2	8.2	18				
Comment : _____ _____ _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND										
BUILDING :		The Strand thonglor		Sivay		Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015 Month : <u>27 Nov</u> Year : <u>2015</u>				
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark			
		Chlorine (ppm)	pH							
29	Morning	0.2	8.2	18	[Redacted]	[Redacted]				
	Afternoon	0.2	8.2	18						
30	Morning	0.2	8.2	18				[Redacted]	[Redacted]	
	Afternoon	0.2	8.2	18						
	Morning				[Redacted]	[Redacted]				
	Afternoon									
	Morning							[Redacted]	[Redacted]	
	Afternoon									
	Morning				[Redacted]	[Redacted]				
	Afternoon									
	Morning							[Redacted]	[Redacted]	
	Afternoon									
	Morning				[Redacted]	[Redacted]				
	Afternoon									

Comment : _____
 BSE : _____
4 / 7 / 68

Note: pH: normal range 7.2 - 7.8
 Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01

Rev. Date : 31/01/2015

Month : 27/06 Year : 2018

BUILDING : The Strand thonglor 231180

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
29	Morning	0.2	8.2	18			
	Afternoon	0.2	8.2	18			
30	Morning	0.2	8.2	18			
	Afternoon	0.2	8.2	18			
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						

Comment :

BSE :

4 / 7 / 18

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm

