



## Analysis / Test Report

TESTING  
No.0166

**Client** : Bangkok Phuket Hospital Co., Ltd.  
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000  
**P/O** : 005 - 4305702925  
**Project Name** : Water Testing : BPK  
**Project Location** :

**Lot ID: 2330412**  
Date Received : Apr 05, 2023  
Date Reported : Apr 24, 2023  
Report Number : 2630068-1

Page 1 of 3

**Sample Number** 2330412-1  
**Sampled Date** Apr 04, 2023 11:04 AM  
**Sample Description** น้ำประปาต้นทาง (น้ำบ่อเก็บน้ำใต้ดิน)  
**Location** บ่อเก็บน้ำใต้ดิน - ห้อง Fire Pump  
**Date Analysis Commenced** Apr 05, 2023  
**Condition of Sample** Contained in four plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
<b>Metals Testing</b>							
Arsenic	mg/L	0.001	0.005	Not Detected	≤0.01	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 3125 B, 3030 F	Songkhla
Cadmium	mg/L	0.001	0.005	Not Detected	≤0.003	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 3125 B, 3030 F	Songkhla
Chromium	mg/L	0.001	0.005	Not Detected	≤0.05	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 3125 B, 3030 F	Songkhla
Copper	mg/L	0.001	0.005	Not Detected	≤1.0	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 3125 B, 3030 F	Songkhla
Iron	mg/L	0.001	0.005	<0.005	≤0.3	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 3125 B, 3030 F	Songkhla
Lead	mg/L	0.001	0.005	Not Detected	≤0.01	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 3125 B, 3030 F	Songkhla
Manganese	mg/L	0.001	0.005	<0.005	≤0.3	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 3125 B, 3030 F	Songkhla
Mercury	mg/L	0.0003	0.0005	Not Detected	≤0.001	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 3125 B, 3030 F	Songkhla

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Ananta B.

Ananta Boonphet  
Scientist (2)

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068  
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER



## Analysis / Test Report

TESTING  
No.0166

**Client** : Bangkok Phuket Hospital Co., Ltd.  
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000  
**P/O** : 005 - 4305702925  
**Project Name** : Water Testing : BPK  
**Project Location** :

**Lot ID: 2330412**  
Date Received : Apr 05, 2023  
Date Reported : Apr 24, 2023  
Report Number : 2630068-1

Page 2 of 3

<b>Sample Number</b>	2330412-1
<b>Sampled Date</b>	Apr 04, 2023 11:04 AM
<b>Sample Description</b>	น้ำประปาต้นทาง (น้ำบ่อเก็บน้ำใต้ดิน)
<b>Location</b>	บ่อเก็บน้ำใต้ดิน - ห้อง Fire Pump
<b>Date Analysis Commenced</b>	Apr 05, 2023
<b>Condition of Sample</b>	Contained in four plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
<b>Metals Testing</b>							
Zinc	mg/L	0.001	0.005	<0.005	≤3.0	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 3125 B, 3030 F	Songkhla
<b>Microbiological Testing</b>							
<i>Escherichia coli</i>	MPN/100mL	-	-	<1.1	<1.1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 9221 B. F	Songkhla
Total Coliform	MPN/100mL	-	-	<1.1	<1.1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 9221 B	Songkhla
<b>Water Testing</b>							
<sup>[A]</sup> Chloride as Cl	mg/L	0.06	0.2	29.5	≤250	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4110 B	Bangkok
Color (Apparent) *	Color unit	-	5	<5	≤15	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 2120 B	Songkhla
<sup>[A]</sup> Fluoride as F	mg/L	0.05	0.1	Not Detected	≤0.7	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4110 B	Bangkok
<sup>[A]</sup> Nitrate as NO3	mg/L	0.3	1.0	45.7	≤50	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4110 B	Bangkok
<sup>[A]</sup> Nitrite as NO2	mg/L	0.15	0.4	Not Detected	≤3	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4110 B	Bangkok
pH at 25 degree C		-	-	6.7	6.5-8.5	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4500 - H (B)	Songkhla

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Ananta B.

Ananta Boonphet  
Scientist (2)

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068  
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER



## Analysis / Test Report

TESTING  
No.0166

**Client :** Bangkok Phuket Hospital Co., Ltd.  
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000  
**P/O :** 005 - 4305702925  
**Project Name :** Water Testing : BPK  
**Project Location :**

**Lot ID: 2330412**  
Date Received : Apr 05, 2023  
Date Reported : Apr 24, 2023  
Report Number : 2630068-1

Page 3 of 3

<b>Sample Number</b>	2330412-1
<b>Sampled Date</b>	Apr 04, 2023 11:04 AM
<b>Sample Description</b>	น้ำประปาต้นทาง (น้ำบ่อเก็บน้ำใต้ดิน)
<b>Location</b>	บ่อเก็บน้ำใต้ดิน - ห้อง Fire Pump
<b>Date Analysis Commenced</b>	Apr 05, 2023
<b>Condition of Sample</b>	Contained in four plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
<b>Water Testing</b>							
Residual Free Chlorine	mg/L	-	0.1	0.5	No Standard	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4500-Cl (F)	Songkhla
<sup>[A]</sup> Sulfate	mg/L	0.15	0.5	9.6	≤250	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4110 B	Bangkok
Total Dissolved solids Dried at 180 degree C	mg/L	-	5	257	≤500	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 2540 C	Songkhla
Total Hardness as CaCO <sub>3</sub>	mg/L	-	1	53	≤300	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 2340 C	Songkhla
Turbidity	NTU	-	0.1	0.46	≤5	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 2130 B	Songkhla

**Guideline :** เกณฑ์คุณภาพน้ำประปาดื่มได้ ประกาศ กรมอนามัย พ.ศ. 2563

**Sampling By :** Yuttapong Rattana , Thaksin Aintrom

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked \* is/are not included in scope of Accreditation ISO/IEC 17025.
- [A] Analysis conducted by ALS Laboratory Group (Thailand) Co.,Ltd. Bangkok Branch, DMSc Accreditation No. 1031/47.
- The laboratory has been accepted as an accredited laboratory complying with the ISO/IEC 17025.

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Ananta B.

Ananta Boonphet  
Scientist (2)

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068  
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER