


➤ 22ข

เอกสารขั้นตอนรับเรื่องร้องเรียน




ระยะเวลาในการจัดทำ : ๑ ปี
 ลำดับเอกสาร : ๑
 วันที่ถือผลสัมฤทธิ์ : ๑๖ ธันวาคม ๒๕๖๑

 กลุ่มบริษัท ซีพี ออลล์ จำกัด (มหาชน) บริษัท ซีพี ออลล์ จำกัด (มหาชน)		P-Q-751-004 : Safety Health & Environment (SHE) Compensation and Compliance	
		10-11	5.4.3 เก็บรักษา "รายการควบคุมบัญชี" และ "บัญชี Compensation Form"
		11	- ข้อ 5.4.4 ให้อำนาจ มอบหมาย การจัดการ การควบคุมบัญชี "บัญชี Compensation Form" และ "บัญชี Compensation Form"
		12	ข้อ 5.4.5 ให้อำนาจ มอบหมาย การจัดการ Compensation Form (P-Q-751-004-SHE-001-01)
		14	1. ให้อำนาจ มอบหมาย การจัดการ "บัญชี Compensation Form" และ "บัญชี Compensation Form" 2. ให้อำนาจ มอบหมาย การจัดการ "บัญชี Compensation Form" และ "บัญชี Compensation Form" 3. ให้อำนาจ มอบหมาย การจัดการ "บัญชี Compensation Form" และ "บัญชี Compensation Form" 4. ให้อำนาจ มอบหมาย การจัดการ "บัญชี Compensation Form" และ "บัญชี Compensation Form"
3	22 ธันวาคม 2563	ทศพร	1. ให้อำนาจ มอบหมาย การจัดการ "บัญชี Compensation Form" และ "บัญชี Compensation Form" 2. ให้อำนาจ มอบหมาย การจัดการ "บัญชี Compensation Form" และ "บัญชี Compensation Form" 3. ให้อำนาจ มอบหมาย การจัดการ "บัญชี Compensation Form" และ "บัญชี Compensation Form" 4. ให้อำนาจ มอบหมาย การจัดการ "บัญชี Compensation Form" และ "บัญชี Compensation Form"

ประกาศใช้ครั้งที่ 1
วันที่มีผลบังคับใช้ : 11 ธันวาคม 2561

ทศพร

หน้า 1

 กลุ่มบริษัท ซีพี ออลล์ จำกัด (มหาชน) บริษัท ซีพี ออลล์ จำกัด (มหาชน)		P-Q-751-004 : Safety Health & Environment (SHE) Compensation and Compliance	
---	--	--	--


สารบัญ

1. วัตถุประสงค์	หน้า 1
2. ขอบเขต	หน้า 2
3. วัตถุประสงค์	หน้า 3
4. วัตถุประสงค์	หน้า 5
5. วัตถุประสงค์	หน้า 10
6. วัตถุประสงค์	หน้า 15
7. วัตถุประสงค์	หน้า 15
8. วัตถุประสงค์	หน้า 15
9. วัตถุประสงค์	หน้า 15
10. วัตถุประสงค์	หน้า 15
11. วัตถุประสงค์	หน้า 15
12. วัตถุประสงค์	หน้า 15
13. วัตถุประสงค์	หน้า 15
14. วัตถุประสงค์	หน้า 15
15. วัตถุประสงค์	หน้า 15
16. วัตถุประสงค์	หน้า 15
17. วัตถุประสงค์	หน้า 15
18. วัตถุประสงค์	หน้า 15
19. วัตถุประสงค์	หน้า 15
20. วัตถุประสงค์	หน้า 15

ประกาศใช้ครั้งที่ 1
วันที่มีผลบังคับใช้ : 11 ธันวาคม 2561

ทศพร

หน้า 1

 กลุ่มบริษัท ซีพี ออลล์ จำกัด (มหาชน) บริษัท ซีพี ออลล์ จำกัด (มหาชน)		P-Q-751-004 : Safety Health & Environment (SHE) Compensation and Compliance	
---	--	--	--


1. วัตถุประสงค์

เพื่อให้สามารถจัดการบัญชี Compensation Form และ "บัญชี Compensation Form" ได้อย่างมีประสิทธิภาพและประสิทธิผล
 เพื่อให้สามารถจัดการบัญชี Compensation Form และ "บัญชี Compensation Form" ได้อย่างมีประสิทธิภาพและประสิทธิผล
 เพื่อให้สามารถจัดการบัญชี Compensation Form และ "บัญชี Compensation Form" ได้อย่างมีประสิทธิภาพและประสิทธิผล

ประกาศใช้ครั้งที่ 1
วันที่มีผลบังคับใช้ : 11 ธันวาคม 2561

ทศพร

หน้า 1 จาก 16

 กลุ่มบริษัท ซีพี ออลล์ จำกัด (มหาชน) บริษัท ซีพี ออลล์ จำกัด (มหาชน)		P-Q-751-004 : Safety Health & Environment (SHE) Compensation and Compliance	
---	--	--	--

2. ขอบเขต

พื้นที่ของอาคารสำนักงานและพื้นที่ปฏิบัติงานของกลุ่มบริษัท ซีพี ออลล์ จำกัด (มหาชน)

ประกาศใช้ครั้งที่ 1
วันที่มีผลบังคับใช้ : 11 ธันวาคม 2561

ทศพร

หน้า 2 จาก 16

ប្រែក្រាបពីភាសាខ្មែរ ។ ទំព័រ ១២ នៃ ២៤
 រៀបចំដោយ គណៈកម្មាធិការ ។ ឆ្នាំ ២០២០

๑. ชื่อเรื่อง :
 ๒. ชื่อผู้แต่ง :
 ๓. ชื่อผู้เรียบเรียง :
 ๔. ชื่อผู้แปล :
 ๕. ชื่อผู้พิมพ์ :
 ๖. ชื่อผู้จัดพิมพ์ :
 ๗. ชื่อผู้จำหน่าย :
 ๘. ชื่อผู้จัดจำหน่าย :
 ๙. ชื่อผู้จัดพิมพ์ :
 ๑๐. ชื่อผู้จัดพิมพ์ :

[illegible][illegible]

➤ 23๗


เอกสารบันทึกสรุปข้อร้องเรียน
(ระหว่างเดือน มกราคม-มิถุนายน 2566)



สรุปจำนวนข้อร้องเรียนด้านสิ่งแวดล้อม ประจำปี 2566

ข้อร้องเรียน	จำนวนข้อร้องเรียน(เดือน)												รวม(ปี)
	ม.ค.	ก.พ.	มี.ค.	เม.ย.	พ.ค.	มิ.ย.	ก.ค.	ส.ค.	ก.ย.	ต.ค.	พ.ย.	ธ.ค.	
ด้านกลิ่น	0	0	0	0	0	0	0						0
ด้านเสียง	0	0	0	0	0	0	0						0
ด้านความร้อน	0	0	0	0	0	0	0						0

สรุปจำนวนข้อร้องเรียนด้านสิ่งแวดล้อม ประจำปี 2566



**เอกสารสอบถามข้อร้องเรียนของโครงการ
(ระหว่างเดือน มกราคม-มิถุนายน 2566)**



ที่ รย ๕๒๒๐๖/๒๕๖๖



สำนักงานเทศบาลเมืองมาบตาพุด
๙ ถนนเมืองใหม่มาบตาพุด สาย ๗
อำเภอเมือง จังหวัดระยอง ๒๑๑๕๐

๑๐ มีนาคม ๒๕๖๖

เรื่อง การตรวจสอบข้อร้องเรียนที่เกิดจากบริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน) สาขา ๗

เรียน ผู้จัดการส่วน หน่วยงาน SHE-Utilities

อ้างถึง หนังสือบริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน) สาขา ๗ ที่ ๐๘-Q-SH-๐๐๓๕/๒๕๖๖

ลงวันที่ ๘ มีนาคม ๒๕๖๖

ตามหนังสือที่อ้างถึงบริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน) สาขา ๗ ทำเทียบเรือและคลังผลิตภัณฑ์ ได้เข้าร่วมโครงการส่งเสริมความปลอดภัยและสิ่งแวดล้อมกับหน่วยราชการที่เกี่ยวข้อง การเข้าร่วมโครงการดังกล่าวนี้ ได้กำหนดเกณฑ์การตรวจประเมินในหัวข้อการพิจารณาติดตามข้อเรียนด้านสิ่งแวดล้อมและชุมชนที่เกิดขึ้น และได้ขอให้เทศบาลเมืองมาบตาพุดตรวจสอบข้อร้องเรียนด้านสิ่งแวดล้อมและชุมชนที่เกิดขึ้นจากการดำเนินงานของบริษัทฯ ตั้งแต่วันที่ ๑ มกราคม พ.ศ. ๒๕๖๓ ถึงปัจจุบัน นั้น

เทศบาลฯ ได้ตรวจสอบแล้ว ตั้งแต่วันที่ ๑ มกราคม พ.ศ. ๒๕๖๓ ถึงปัจจุบัน ไม่พบข้อร้องเรียนจากบริษัทฯ แต่อย่างใด

จึงเรียนมาเพื่อทราบ

ขอแสดงความนับถือ

รย

น

สำนักสาธารณสุขและสิ่งแวดล้อม

งานควบคุมมลพิษและเหตุรำคาญ

โทร./โทรสาร ๐-๓๘๖๘-๕๕๖๐

ไปรษณีย์อิเล็กทรอนิกส์ sarabun_04210103@dla.go.th

“ยึดมั่นธรรมาภิบาล บริการเพื่อประชาชน”

➤ 24ข

เอกสารการแต่งตั้งคณะทำงานประสานงาน
ให้คำปรึกษาด้านสิ่งแวดล้อม
ของกลุ่มบริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)
(คณะเดิม)





คำสั่งการนิคมอุตสาหกรรมแห่งประเทศไทย

ที่ ๓๓๕ /๒๕๖๕

เรื่อง แต่งตั้งคณะกรรมการมวลชนสัมพันธ์และสิ่งแวดล้อมของกลุ่มบริษัท
พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)

ตามที่ได้มีคำสั่งการนิคมอุตสาหกรรมแห่งประเทศไทย ที่ ๑๒๗/๒๕๕๖ เรื่อง แต่งตั้งคณะทำงาน
ประสานงานให้คำปรึกษาด้านสิ่งแวดล้อมของกลุ่มบริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน) นั้น

เพื่อให้องค์ประกอบและหน้าที่อำนาจของคณะกรรมการฯ สอดคล้องกับมาตรการป้องกัน
และแก้ไขผลกระทบสิ่งแวดล้อม และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมของโครงการกลุ่มบริษัท
พีทีที โกลบอล เคมิคอล จำกัด (มหาชน) ในพื้นที่นิคมอุตสาหกรรมมาบตาพุด และเป็นไปตามโครงสร้าง
ปัจจุบันขององค์กร อาศัยอำนาจตามความในมาตรา ๒๘ แห่งพระราชบัญญัติการนิคมอุตสาหกรรม
แห่งประเทศไทย พ.ศ. ๒๕๒๒ จึงให้ยกเลิกคำสั่งดังกล่าวข้างต้น และแต่งตั้งคณะกรรมการมวลชนสัมพันธ์
และสิ่งแวดล้อมของกลุ่มบริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน) ขึ้นใหม่ โดยมีองค์ประกอบ
หน้าที่และอำนาจ ดังต่อไปนี้

๑. องค์ประกอบ

- | | | |
|------|--|------------------|
| ๑.๑ | ผู้อำนวยการสำนักงานนิคมอุตสาหกรรมดับบลิวเอชเอ
ตะวันออก (มาบตาพุด) | ประธานกรรมการ |
| ๑.๒ | ผู้อำนวยการสำนักงานนิคมอุตสาหกรรมมาบตาพุด | รองประธานกรรมการ |
| ๑.๓ | ผู้อำนวยการศูนย์ควบคุมมลพิษจังหวัดระยอง
กรมควบคุมมลพิษ | กรรมการ |
| ๑.๔ | สาธารณสุขจังหวัดระยอง | กรรมการ |
| ๑.๕ | ผู้อำนวยการสำนักงานทรัพยากรธรรมชาติและ
สิ่งแวดล้อม จังหวัดระยอง | กรรมการ |
| ๑.๖ | นายกเทศมนตรีเทศบาลเมืองมาบตาพุด | กรรมการ |
| ๑.๗ | นายกเทศมนตรีเทศบาลเมืองบ้านฉาง | กรรมการ |
| ๑.๘ | นายกเทศมนตรีตำบลบ้านฉาง | กรรมการ |
| ๑.๙ | กำนันตำบลบ้านฉาง | กรรมการ |
| ๑.๑๐ | ผู้ใหญ่บ้านหมู่ ๑ ตำบลบ้านฉาง | กรรมการ |
| ๑.๑๑ | ผู้ใหญ่บ้านหมู่ ๒ ตำบลบ้านฉาง | กรรมการ |
| ๑.๑๒ | ประชาชนชุมชนในพื้นที่เทศบาลเมืองมาบตาพุด
จำนวน ๓ คน | กรรมการ |
| ๑.๑๓ | ผู้แทนชุมชนในเขตเทศบาลเมืองมาบตาพุด
จำนวน ๔ คน | กรรมการ |
| ๑.๑๔ | ผู้แทนชุมชนในเขตเทศบาลเมืองบ้านฉาง
จำนวน ๓ คน | กรรมการ |

/๑.๑๕ ผู้แทน...

๑.๑๕ ผู้แทนชุมชนในเขตเทศบาลตำบลบ้านฉาง	กรรมการ
จำนวน ๓ คน	
๑.๑๖ ผู้แทนกลุ่มประมงเรือเล็ก	กรรมการ
๑.๑๗ ผู้แทนสื่อมวลชนท้องถิ่น จังหวัดระยอง	กรรมการ
๑.๑๘ ผู้แทนโครงการกลุ่มบริษัท พีทีที โกลบอล	กรรมการ
เคมีคอล จำกัด (มหาชน)	และเลขานุการ

ให้คณะกรรมการฯ มีวาระการดำรงตำแหน่งคราวละ ๔ ปี และดำรงตำแหน่งติดต่อกันไม่เกิน ๒ วาระ

๒. หน้าที่และอำนาจ

๒.๑ ประสานงานและกำกับดูแลให้โครงการฯ ดำเนินการโดยไม่ส่งผลกระทบต่อสิ่งแวดล้อม

๒.๒ ให้คำปรึกษา เสนอแนะแนวทาง และประสานงานแก้ไขปัญหาสิ่งแวดล้อม และข้อร้องเรียนของชุมชนอันเนื่องมาจากการดำเนินงานของโครงการฯ

๒.๓ พิจารณาและให้ข้อคิดเห็นต่อขั้นตอนและวิธีการดำเนินงานที่อาจก่อให้เกิดผลกระทบต่อสิ่งแวดล้อม ตลอดจนประสานงานกับหน่วยงานอื่นๆ ที่เกี่ยวข้อง

๒.๔ เชิญบุคคลหรือเจ้าหน้าที่ที่เกี่ยวข้อง เพื่อให้ข้อมูล คำปรึกษา หรือขอเสนอแนะได้ตามความจำเป็น

๒.๕ ในกรณีที่มีการก่อสร้างและทดลองเดินเครื่อง ให้บริษัทฯ นำเสนอความก้าวหน้าโครงการฯ ต่อคณะกรรมการฯ ตามความเหมาะสม

๒.๖ จัดให้มีการส่งเสริมความรู้ หรือเสริมสร้างความเข้าใจเกี่ยวกับการจัดการสิ่งแวดล้อมให้แก่ประชาชนและชุมชนอย่างต่อเนื่อง

๒.๗ พิจารณาจัดทำแผนงานประชาสัมพันธ์และความรับผิดชอบต่อสังคมของโครงการฯ ทั้งระยะสั้น ระยะยาว และแบบชั่วคราว ให้เหมาะสมกับชุมชน


๒.๘ พิจารณาการชดเชยและเยียวยา หากเป็นปัญหาที่พิสูจน์แล้วว่าเกิดจากการดำเนินงานของโครงการฯ

๒.๙ จัดให้มีการอบรม ให้ความรู้ การทูลงานภายใน ๖ เดือน นับแต่วันที่คำสั่งนี้มีผลใช้บังคับ และในทุก ๒ ปี เพื่อเพิ่มเติมความรู้ใหม่หรือตามความเหมาะสม

๒.๑๐ กำหนดให้มีวาระการประชุมอย่างน้อยปีละ ๒ ครั้ง หรือมากกว่า หากมีเหตุจำเป็นเร่งด่วน เพื่อติดตามผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบต่อสิ่งแวดล้อม และมาตรการติดตามตรวจสอบผลกระทบต่อสิ่งแวดล้อม และแผนมวลชนสัมพันธ์ของโครงการฯ

ทั้งนี้ ตั้งแต่บัดนี้เป็นต้นไป

สั่ง ณ วันที่ ๑๗ มิถุนายน พ.ศ. ๒๕๖๕



เอกสารสรุปการประชุมคณะทำงานประสานงาน
ให้คำปรึกษาด้านสิ่งแวดล้อม
ของกลุ่มบริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)
(คณะเดิม)







รายงานการประชุมคณะกรรมการมวลชนสัมพันธ์และสิ่งแวดล้อม
กลุ่มบริษัท พีทีที โกลบอล เคมิคอล

เรื่อง ประชุมคณะกรรมการมวลชนสัมพันธ์และสิ่งแวดล้อม กลุ่ม บริษัท พีทีที โกลบอล เคมิคอล
ครั้งที่ 1/2566
วันที่ 17 กุมภาพันธ์ 2566
สถานที่ โรงแรมพูลแมน จังหวัดชลบุรี

รายนามผู้เข้าประชุม



ผู้อำนวยการสำนักงานนิคมอุตสาหกรรมดับบลิวเอชเอตะวันออก
(มาบตาพุด)
ผู้แทน ผู้อำนวยการสำนักงานนิคมอุตสาหกรรมมาบตาพุด
ผู้แทน นายกเทศมนตรีเทศบาลเมืองมาบตาพุด
ผู้แทน นายกเทศมนตรีเทศบาลเมืองบ้านฉาง
ผู้แทน นายกเทศมนตรีตำบลบ้านฉาง
กำนันตำบลบ้านฉาง
ผู้แทน ผู้ใหญ่บ้านหมู่ 1 ตำบลบ้านฉาง
ผู้ใหญ่บ้านหมู่ 2 ตำบลบ้านฉาง
ประธานชุมชนอิสลาม
ผู้แทน ประธานชุมชนมาบชลูด-ชากกลาง
ผู้แทนชุมชนเขต ทม.มาบตาพุด
ผู้แทนชุมชนเขต ทม.มาบตาพุด
ผู้แทนชุมชนเขต ทม.มาบตาพุด
ผู้แทนชุมชนเขต ทม.มาบตาพุด
ผู้แทนชุมชนเขต ทม.มาบตาพุด



ผู้แทนชุมชนเขต ทม.มาบตาพุด

ผู้แทนชุมชนเขต ทม.มาบตาพุด

ผู้แทนชุมชนเขต ทม.บ้านฉาง

ผู้แทนชุมชนเขต ทม.บ้านฉาง

ผู้แทนชุมชนเขต ทม.บ้านฉาง

ผู้แทนชุมชนเขต ทด.บ้านฉาง

ผู้แทนชุมชนเขต ทด. บ้านฉาง

ผู้แทนชุมชนเขต ทด. บ้านฉาง

สมาคมครอบครัวชาวจังหวัดระยอง

กรรมการกิตติมศักดิ์

ผู้ช่วยกรรมการผู้จัดการใหญ่ สายงานคุณภาพ ความปลอดภัย

อาชีพอนามัยและสิ่งแวดล้อม

ผู้จัดการส่วนหน่วยงานชุมชนสัมพันธ์

ผู้จัดการฝ่าย หน่วยงานอาชีพอนามัยและสิ่งแวดล้อม

ผู้จัดการส่วน หน่วยงานอาชีพอนามัยและสิ่งแวดล้อม

ผู้จัดการฝ่ายโรงงาน อีเทนแอกเรเกอร์ (Olefins Plant ๓)

ผู้แทน โรงงาน แอลดีพีอี (LDPE)

ผู้จัดการส่วนโรงงาน จีซีไกลคอล (GC Glycol)

ผู้จัดการฝ่ายโรงงาน ฟีนอล (Phenol) PH-P1

ผู้จัดการฝ่ายโรงงาน จีซีออกซิเรน จำกัด (GC Oxirane)

ผู้จัดการฝ่ายโรงงาน จีซี โพลีเอสเตอร์ จำกัด (GC Polyols)

ผู้จัดการส่วนโรงงาน โพลีสไตรีน (GC Polystyrene)

ผู้จัดการฝ่ายโรงงาน จีซี-เอ็ม พีทีเอ (GC MPTA)

ผู้แทน โรงงาน คุราเร่ จีซี แอดวานซ์ เมททีเรียลส์ จำกัด (KGC)

และคุราเร่ แอดวานซ์ เคมีคอล จำกัด (KAC)

ผู้จัดการส่วน SHE โรงงาน ผลิตไฟฟ้าและสารารูปโภค

ผู้จัดการส่วน SHE โรงงาน อะโรเมติกส์ 1 (สาขา 4)

ผู้จัดการส่วน หน่วยงานบริการสิ่งแวดล้อม

วาระที่ 1 : เรื่องแจ้งเพื่อทราบ

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
	<div style="background-color: black; width: 100%; height: 1.2em; margin-bottom: 0.5em;"></div> รวมค่านางานกลุ่มมาตาดพุด กล่าวเปิดประชุมต้อนรับ คณะทำงานฯทุกท่านในการประชุม ครั้งที่ 1/2566	ทุกท่าน	เพื่อทราบ

วาระที่ 2 : รับรองรายงานการประชุมครั้งที่ 5/2565

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
2.1	มติที่ประชุม : รับรองรายงานการประชุม ครั้งที่ 5/2565	ทุกท่าน	เพื่อทราบ


วาระที่ 3 : เรื่องสืบเนื่องจากการประชุมครั้งที่ 5/2565

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
-	ไม่มีวาระสืบเนื่อง	ทุกท่าน	เพื่อทราบ

วาระที่ 4 : การดำเนินของกลุ่ม PTT Global Chemical





หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
4.1	<u>รายงานการเดินเครื่องโรงงาน กลุ่มบริษัท พีทีที โกลบอล เคมิคอล</u> <u>4.1.1 รายงานการเดินเครื่องโรงงานเอเทนพินส์ 3 (Ethane Cracker)</u> โดยคุณสืบแก้ว เทพคำดี รายงานการเดินเครื่องการผลิต ดังนี้ <ul style="list-style-type: none"> □ ในช่วงเดือนธันวาคม 2565 ถึง วันที่ 31 มกราคม 2566 การเดินเครื่องโรงงานเป็นไปโดยปกติไม่มีอุบัติเหตุและไม่มีผลกระทบต่อสิ่งแวดล้อม 	ทุกท่าน	เพื่อทราบ

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
<p>4.1 (ต่อ)</p>	<p><u>4.1.2 รายงานการเดินเครื่องโรงงาน แอลแอลดีพีอี (LLDPE)</u> โดยเลขานุการที่ประชุม รายงานการเดินเครื่องการผลิต ดังนี้</p> <p><u>โรงงาน LLDPE 1</u></p> <ul style="list-style-type: none"> <input type="checkbox"/> วันที่ 1-21 ธันวาคม 2565 ที่ผ่านมารได้มีการหยุดเดินเครื่องเชิงพาณิชย์ (commercial shutdown) เป็นไปตามแผนการจัดวัตถุดิบ <input type="checkbox"/> วันที่ 22 ธันวาคม 2565 ถึง วันที่ 7 มกราคม 2566 เป็นการเดินเครื่องจักรปกติเช่นกัน <input type="checkbox"/> วันที่ 8-17 มกราคม 2566 ที่ผ่านมามีแผนหยุดเดินเครื่องผลิตเชิงพาณิชย์ <input type="checkbox"/> วันที่ 18 มกราคม 2566 ถึง ปัจจุบัน การเดินเครื่องจักรปกติ <p><u>โรงงาน LLDPE 2</u></p> <ul style="list-style-type: none"> <input type="checkbox"/> วันที่ 1 ธันวาคม 2565 ถึง วันที่ 9 มกราคม 2566 มีการหยุดเดินเครื่องและมีการเดินเครื่องปกติ <input type="checkbox"/> วันที่ 30-31 มกราคม 2566 ที่ผ่านมามีการหยุดเดินเครื่องเชิงพาณิชย์ตามแผนการจัดวัตถุดิบ <p><u>4.1.3 รายงานการเดินเครื่องโรงงาน แอลดีพีอี (LDPE)</u> โดยคุณกิตติศักดิ์ พรหมศรี รายงานการเดินเครื่องการผลิต ดังนี้</p> <ul style="list-style-type: none"> <input type="checkbox"/> วันที่ 8 – 9 ธันวาคม 2565 โรงงานหยุดเดินเครื่องเพื่อตรวจสอบระบบ High Pressure Pump <input type="checkbox"/> วันที่ 10-24 มกราคม 2566 โรงงานเดินเครื่องเป็นปกติตามแผนการผลิต โดยไม่มีอุบัติเหตุ และผลกระทบด้านสิ่งแวดล้อม <input type="checkbox"/> วันที่ 25 มกราคม - 5 กุมภาพันธ์ 2566 โรงงานหยุดเดินเครื่องตามแผนเพื่อซ่อมบำรุงประจำปี 	<p>ทุกท่าน</p>	<p>เพื่อทราบ</p>


หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
4.1 (ต่อ)	<p>4.1.4 รายงานการเดินเครื่องโรงงาน จีซี ไกลคอล (GC Glycol) (GC16)</p> <p>โดยคุณอำพร เกตุจรุง รายงานการเดินเครื่องการผลิต ดังนี้</p> <p><u>หน่วยผลิตเอทิลีนออกไซด์/เอทิลีนไกลคอล (EO/EG Plant)</u></p> <p><input type="checkbox"/> วันที่ 13 มกราคม 2566 หยุดเดินเครื่องเพื่อซ่อมบำรุงเครื่องจักร (Shutdown)</p> <p><u>หน่วยผลิตเอทานอลเอมีน (EA Plant)</u></p> <p><input type="checkbox"/> วันที่ 6 ธันวาคม 2565-12 มกราคม 2566 หยุดเดินเครื่องเชิงพาณิชย์ (Commercial Shutdown)</p> <p><input type="checkbox"/> วันที่ 13 มกราคม-20 มีนาคม 2566 หยุดเพื่อซ่อมบำรุงเครื่องจักร (Shutdown)</p> <p>4.1.5 รายงานการเดินเครื่องโรงงาน ฟีนอล (Phenol) (GC18)</p> <p></p> <p><u>แผนซ่อมบำรุงฟีนอล</u></p> <p><input type="checkbox"/> เดือน ธ.ค. 65-ม.ค. 66 เดินเครื่องการผลิตปกติ โดย</p> <ul style="list-style-type: none"> ○ หยุดซ่อมบำรุงตามแผน ระหว่างวันที่ 9-17 ธ.ค. 65 และกลับมาเดินเครื่องตามปกติ ○ มีแผนหยุดซ่อมบำรุงตามแผน ระหว่างวันที่ 22 ก.พ.- 7 ก.พ. 66 <p><u>หน่วยผลิตสารบิสฟีนอลเอ</u></p> <p><input type="checkbox"/> เดือน ธ.ค. 65-ม.ค. 66 เดินเครื่องการผลิตปกติ โดยมีแผนหยุดซ่อมบำรุงตามแผน ระหว่างวันที่ 21-28 ก.พ. 66</p>	ทุกท่าน	เพื่อทราบ

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
4.1 (ต่อ)	<p><u>4.1.6 รายงานการเดินเครื่องโรงงาน จีซี ออกซิเรน จำกัด</u> (GC Oxirane) (GC19)</p> <p>[REDACTED]</p> <ul style="list-style-type: none"> <input type="checkbox"/> ระหว่างวันที่ 17 ตุลาคม - 15 ธันวาคม 2565 โรงงานหยุดเดินเครื่องเพื่อซ่อมบำรุงใหญ่ (Turnaround) โดยไม่มีอุบัติเหตุและผลกระทบด้านสิ่งแวดล้อม <input type="checkbox"/> ระหว่างวันที่ 16 ธันวาคม 2565 - 24 มกราคม 2566 เดินเครื่องปกติ โดยไม่มีอุบัติเหตุและผลกระทบด้านสิ่งแวดล้อม <input type="checkbox"/> ระหว่างวันที่ 25 มกราคม - 17 มีนาคม 2566 โรงงานมีการหยุดการเดินเครื่องเพื่อการพาสซีว โดยจะปฏิบัติตามมาตรการด้านความปลอดภัยและสิ่งแวดล้อมอย่างเคร่งครัด <p><u>4.1.7 รายงานการเดินเครื่องโรงงาน จีซี โพลีโอลส์ จำกัด</u> (GC Polyols)</p> <p>[REDACTED]</p> <p>พจน</p> <ul style="list-style-type: none"> <input type="checkbox"/> กระบวนการผลิตเดือนธันวาคม 2565 - มกราคม 2566 เดินเครื่องปกติ โดยไม่มีอุบัติเหตุและผลกระทบด้านสิ่งแวดล้อม <input type="checkbox"/> ระหว่างวันที่ 19 มกราคม - 13 มีนาคม 2566 มีการหยุดเดินเครื่องการผลิตเพื่อการพาสซีว และซ่อมบำรุงเครื่องจักร โดยจะปฏิบัติตามมาตรการด้านความปลอดภัยและสิ่งแวดล้อมอย่างเคร่งครัด <p><u>4.1.8 รายงานการเดินเครื่องโรงงานโพลิสไตรีน (สาขา 17)</u> (GC Polystyrene)</p> <p>[REDACTED]</p> <ul style="list-style-type: none"> <input type="checkbox"/> วันที่ 1 ธันวาคม 2565 - 31 มกราคม 2566 มีการเดินเครื่องเป็นปกติ “โดยไม่มีอุบัติเหตุและผลกระทบด้านสิ่งแวดล้อม” 	ทุกท่าน	เพื่อทราบ

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
4.1 (ต่อ)	<p>4.1.9 รายงานการเดินเครื่องโรงงาน จีซี - เอ็ม พีทีเอ จำกัด (GC-MPTA)</p> <p>[REDACTED]</p> <p><input type="checkbox"/> สายการผลิตที่ 1 มีแผนหยุดซ่อมบำรุงตามแผนประจำปี 2566 วันที่ 14 มกราคม ถึง วันที่ 1 กุมภาพันธ์ 2566 ซึ่งได้ดำเนินการแล้วเสร็จและไม่มีอุบัติเหตุและไม่มีผลกระทบด้านสิ่งแวดล้อม</p> <p><input type="checkbox"/> สายการผลิตที่ 2 เดินเครื่องปกติและมีแผนหยุดซ่อมบำรุง วันที่ 1 มีนาคม ถึง วันที่ 4 เมษายน 2566</p> <p>4.1.10 รายงานการเดินเครื่องโรงงาน ไทย อีทอกซีเลท จำกัด (TEX) โดยเลขานุการที่ประชุม รายงานการเดินเครื่องการผลิต ดังนี้</p> <p><input type="checkbox"/> วันที่ 1 ธันวาคม 2565 ถึง วันที่ 12 มกราคม 2566 ที่ผ่านมามีการเดินเครื่องปกติต่อเนื่อง</p> <p><input type="checkbox"/> วันที่ 13 มกราคม ถึง วันที่ 31 มีนาคม 2566 มีแผนการหยุดซ่อมบำรุงตามกำหนดเวลาและมีการแจ้งให้ทางชุมชนรับทราบเรียบร้อยแล้ว</p> <p>4.1.11 รายงานการเดินเครื่อง โรงงาน คุราเร่ จีซี แอคววนซ์ แมททีเรียลส์ จำกัด (KGC) และคุราเร่ แอคววนซ์ เคมีคอล จำกัด (KAC) (KURARE CHEMICALS)</p> <p>[REDACTED]</p> <p><input type="checkbox"/> วันที่ 1 ธันวาคม 2565 - 31 มกราคม 2566 เป็นช่วงหยุดเดินเครื่องการผลิตเพื่อปรับปรุงเครื่องจักรของบริษัท KGC และ KAC</p> <p><input type="checkbox"/> วันที่ 1 ธันวาคม 2565 โรงงานผลิตไอโซพรีนอลและอนุพันธ์ (KAC) หยุดเดินเครื่องผลิต และมีแผนจะกลับมาเดินเครื่องการผลิตประมาณวันที่ 10 มีนาคม 2566</p> <p><input type="checkbox"/> วันที่ 3 ธันวาคม 2565 โรงงานผลิตยางเทอร์โมพลาสติก (KGC) หยุดเดินเครื่องผลิต และมีแผนจะกลับมาเดินเครื่องการผลิตประมาณวันที่ 6 กุมภาพันธ์ 2566</p>	ทุกท่าน	เพื่อทราบ

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
4.1 (ต่อ)	<p><input type="checkbox"/> วันที่ 16 ธันวาคม 2565 โรงงานผลิตพอลิเอไมด์ชนิดพิเศษ (KGC) หยุดเดินเครื่องผลิต และมีแผนจะกลับมาเดินเครื่องการผลิตประมาณวันที่ 7 กุมภาพันธ์ 2566</p> <p>4.1.12. รายงานการเดินเครื่องโรงงาน ผลิตไฟฟ้าและสาธารณูปโภค 1 (PTIGC 2)</p> <p>โดยคุณอนันต์ สุขแท้ รายงานการเดินเครื่องการผลิต ดังนี้</p> <p><input type="checkbox"/> หน่วยงานสาธารณูปโภคมีแผนหยุดเครื่องกำเนิดไฟฟ้า ประจำปีเพื่อตรวจสอบตามกฎหมายโดยมีรายละเอียดดังนี้</p> <p><input type="checkbox"/> H-3704 ระหว่างวันที่ 5-16 ธันวาคม 2565 และ วันที่ 1-20 มกราคม 2566</p> <p><input type="checkbox"/> H-3708 ระหว่างวันที่ 14-15 ธันวาคม 2565 และ วันที่ 21-22 มกราคม 2566</p> <p><input type="checkbox"/> H-3709 ระหว่างวันที่ 23-29 มกราคม 2566</p> <p><input type="checkbox"/> H-3910 ระหว่างวันที่ 1-3 ธันวาคม 2565</p> <p><input type="checkbox"/> H-3711 ระหว่างวันที่ 9-14, 17-23 ธันวาคม 2565</p> <p>ในการปฏิบัติงานไม่มีผลกระทบทางด้านเสียง ด้านสิ่งแวดล้อม ต่างๆและมีความเรียบร้อยเป็นอย่างดี</p> <p></p> <p><input type="checkbox"/> เดือนธันวาคม 2565 ถึงเดือนมกราคม 2566 ดำเนินการได้ปกติไม่มีอุบัติเหตุไม่มีผลกระทบด้านสิ่งแวดล้อม</p> <p><u>ข้อคิดเห็นในที่ประชุม</u></p> <p></p> <p>ถาวรภรณ์ เรืองสงวน</p> <p><input type="checkbox"/> ข้อที่ 1 โรงงาน PE เดิมที่ทำการติดตั้ง Enclose Ground Flare เมื่อก่อนเรามี Flare แบบเดิมและได้รับผลกระทบอยากทราบว่ามี Enclose Ground Flare ขึ้นมาแล้วซึ่งมีการติดตั้งไม่ถี่แห่งในประเทศไทยอยากทราบว่าผลของการของการติดตั้ง ทำให้ลดผลกระทบประมาณกี่เปอร์เซ็นต์ อยากทราบถึงถึงข้อดีและข้อเสียต่างๆพร้อมทั้งขอให้รายงานครั้งหน้า</p>	ทุกท่าน	เพื่อทราบ
	<p></p> <p><input type="checkbox"/> เดือนธันวาคม 2565 ถึงเดือนมกราคม 2566 ดำเนินการได้ปกติไม่มีอุบัติเหตุไม่มีผลกระทบด้านสิ่งแวดล้อม</p> <p><u>ข้อคิดเห็นในที่ประชุม</u></p> <p></p> <p>ถาวรภรณ์ เรืองสงวน</p> <p><input type="checkbox"/> ข้อที่ 1 โรงงาน PE เดิมที่ทำการติดตั้ง Enclose Ground Flare เมื่อก่อนเรามี Flare แบบเดิมและได้รับผลกระทบอยากทราบว่ามี Enclose Ground Flare ขึ้นมาแล้วซึ่งมีการติดตั้งไม่ถี่แห่งในประเทศไทยอยากทราบว่าผลของการของการของการติดตั้ง ทำให้ลดผลกระทบประมาณกี่เปอร์เซ็นต์ อยากทราบถึงถึงข้อดีและข้อเสียต่างๆพร้อมทั้งขอให้รายงานครั้งหน้า</p>	คณะทำงาน GC	เพื่อทราบ

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
4.1 (ต่อ)	<p><input type="checkbox"/> ข้อที่ 2 สาร VOCs ที่โรงงาน Aromatic ใช้ประมาณ 70 ล้านในการติดตั้ง VRU เพื่อลดผลกระทบสิ่งแวดล้อมเกี่ยวกับ VOCs ได้ผลเป็นอย่างไร อยากให้บริษัทนำผลข้อมูลนี้มานำเสนอ เนื่องจากมีผู้ที่ไม่เข้าใจที่อยู่นอกพื้นที่บางส่วนเริ่มพูดเรื่อง VOCs และเรื่องดังกล่าวกำลังจะกลับมา</p> <p>[REDACTED]</p> <p>การทบทวนเรื่องสิ่งแวดล้อมมีรายละเอียดจึงสามารถบอกกล่าวถึงว่าคนภายนอกคิดว่าสารที่ก่อให้เกิดมะเร็งส่วนใหญ่เกิดมาจากทางมาบตาพุดเป็นส่วนใหญ่แต่ที่จริงแล้วมาจากทางแก่งทั้งนี้จึงอยากให้มีการประชาสัมพันธ์ที่จริงจังและต่อเนื่องเพราะสาเหตุที่คนส่วนใหญ่เข้าใจผิดหรือสื่อมีการนำเสนอออกไปนั้นมาจากการที่เราขาดการประชาสัมพันธ์หรือการสื่อสารที่จริงจัง</p>	<p>คณะทำงาน</p> <p>GC</p>	เพื่อทราบ
4.2	<p><u>รายงานความก้าวหน้า EIA โครงการของกลุ่มบริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)</u></p> <p>โดยเลขฯ ที่ประชุม ดังนี้</p> <p><input type="checkbox"/> โครงการการผลิตสารฟีนอล (ส่วนขยาย ครั้งที่ 3)</p> <p>○ อยู่ระหว่างการเพิ่มเติมข้อมูลตามข้อเสนอแนะของคณะกรรมการผู้ชำนาญการ</p>	ทุกท่าน	เพื่อทราบ

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
4.2 (ต่อ)	<input type="checkbox"/> โครงการทำเทียนเรือของ โรงกลั่นน้ำมันระยอง (เปลี่ยนแปลงครั้งที่1) (GC สาขา 6 โรงกลั่นน้ำมัน) <ul style="list-style-type: none"> ○ เสนอรายงานฯ ให้สำนักงานเจ้าท่าภูมิภาคระยอง เมื่อวันที่ 17 มีนาคม 2565 ○ อยู่ระหว่างการพิจารณาของกรมเจ้าท่า <input type="checkbox"/> โครงการโรงงานผลิตสารบิสฟีนอล เอ (ส่วนขยาย ครั้งที่ 2) <ul style="list-style-type: none"> ○ เข้าพิจารณาในคณะกรรมการผู้ชำนาญการ เมื่อ วันที่ 26 ธันวาคม 2565 ได้รับความเห็นชอบแล้ว <input type="checkbox"/> โครงการโรงงานผลิตอีพ็อกซีเรซิน <ul style="list-style-type: none"> ○ ปัจจุบันมีการจัดประชุมความเห็นครั้งที่ 2 ไปแล้ว เมื่อวันที่ 17-19 มกราคม 2566 	ทุกท่าน	เพื่อทราบ
4.3	<p><u>การดำเนินงานด้านมวลชนสัมพันธ์ของกลุ่มบริษัท พีทีที โกลบอล เคมิคอล</u></p> <p></p> <p>สัมพันธ์ ดังนี้</p> <p><u>4.3.1 ด้านการศึกษาและเยาวชน</u></p> <p><input type="checkbox"/> ในช่วงเดือนที่ผ่านมา GC Group จัดกิจกรรมอบรมให้ความรู้ แนวทางการศึกษาผ่าน 4 กิจกรรม ให้แก่ 14 โรงเรียนในพื้นที่ จังหวัดระยอง ได้แก่</p> <ul style="list-style-type: none"> ○ โครงการอบรมสารเคมี ○ โครงการด้านสุขภาพ GC สุขภาพดีใจสารเคมีชีวี ปลอดภัย จัดกิจกรรมต่อเนื่องเป็นปีที่ 6 โดยจัด ร่วมกับโรงงานของ GC และมีการพัฒนาด้าน การศึกษาภายใต้ ○ โครงการ โรงเรียนประชารัฐ ○ โครงการแนะแนวสายอาชีพให้กับน้องๆ ใน โรงเรียนที่ร่วมกับ 	ทุกท่าน	เพื่อทราบ

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
4.3 (ต่อ)	<p>๓ โครงการเพื่อชุมชนคนอาชีวศึกษาปีที่ 4 เพื่อเป็นการแนะแนวสายอาชีพให้กับเด็กในจังหวัดระยอง</p> <p>GC มอบงบประมาณสนับสนุนกิจกรรมและทุนการศึกษา</p> <ul style="list-style-type: none"> ○ ร่วมกับกลุ่ม ปตท. ในการมอบทุนการศึกษาให้กับบุตรหลานที่อยู่ในเขต เทศบาลตำบลบ้านฉาง จำนวน 170 ทุน เป็นจำนวนเงิน 750,000 บาท ○ สนับสนุนโครงการการบรรเทาอุปสมบท 99 รูป เพื่อถวายพระพรชัยองค์ภาาให้หายประชวร ○ สนับสนุนโครงการพัฒนาการด้านกิจกรรมเสริมประสิทธิภาพ 8 กลุ่มสาระและปฐมวัยโรงเรียนเทศบาลมาบตาพุด ○ ร่วมกับกลุ่มปตท.และบริษัทต่างๆของ GC Group เข้าร่วมกิจกรรมในวันเด็กและสนับสนุนของขวัญวันเด็กให้กับหน่วยงานต่างๆในจังหวัดระยองรวมถึงองค์กรปกครองส่วนท้องถิ่นในพื้นที่ 17 เขตเทศบาล, ชุมชน และโรงเรียน นอกจากนี้ยังรวมถึงโรงเรียนต่างๆในพื้นที่ทั้งในเขตและบริเวณรอบนอกที่มีการจัดกิจกรรมในวันเด็กในช่วงที่ผ่านมา <p>4.3.2 ด้านความปลอดภัย</p> <ul style="list-style-type: none"> ๓ อบรมทบทวนแผนป้องกันสาธารณภัยและวางแผนฉุกเฉินให้กับโรงเรียนวัดชากลูกหญ้า, ชุมชนวัดชากลูกหญ้า, ชุมชนซอยลิ้นและชุมชนชากลูกหญ้า ๓ ปรับปรุงภูมิทัศน์ ซ่อมบำรุงระบบไฟฟ้าให้กับทางโรงเรียนบ้านหนองแฟบ ๓ ช่วงเทศกาลปีใหม่ที่ผ่านมาได้มอบน้ำดื่มเพื่อสนับสนุนการปฏิบัติงานให้กับเจ้าหน้าที่ในช่วงวันอันตราย โดยมอบให้ชุมชนนิคมพัฒนาและ สภ.บ้านฉาง 	ทุกท่าน	เพื่อทราบ

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
4.3 (ต่อ)	<p><u>4.3.3 ด้านเศรษฐกิจ</u></p> <ul style="list-style-type: none"> <input type="checkbox"/> โครงการธรรมศาสตร์โมเดล รุ่นที่ 8 โดยร่วมกับสมาคมเพื่อนชุมชน <input type="checkbox"/> จัดกิจกรรมผ่านรายการ @My way จัดทำสื่อประชาสัมพันธ์ร้าน Handmade a Nature Art พื้นที่บ้านฉาง <input type="checkbox"/> โครงการติดตั้ง “โซล่าเซลล์” เพื่อช่วยสนับสนุนโครงการเลี้ยงปูในคอนโด ซึ่งโครงการดังกล่าวได้ดำเนินการร่วมกับท่านเจ้าอาวาสหนองแฟบ <input type="checkbox"/> ส่งมอบโรงเรือนพลาสติก Functional Green House Film ให้แก่กลุ่มวิสาหกิจสวนเกษตรผสมผสานฐานเรียนรู้สวนคุณย่าชุมชน บ้านหนองแฟบ <input type="checkbox"/> โครงการ GC Marketplace ตลาดนัดสัญจร Onsite ในโรงงานจำนวน 2 แห่ง ได้แก่ PPCL , GCM PTA <input type="checkbox"/> ตลาดวันสุข @PTT AuTo OnE เนินสำคัญ ครั้งที่ 3-4 ในวันที่ 9 และ 23 ธันวาคม 2565 	ทุกท่าน	เพื่อทราบ
4.3 (ต่อ)	<p><u>4.3.4 ด้านสุขภาพ</u></p> <ul style="list-style-type: none"> <input type="checkbox"/> สนับสนุนทุนฝึกช่วยฟื้นคืนชีพทารกให้แก่โรงพยาบาลเฉลิมพระเกียรติสมเด็จพระเทพรัตนราชสุดาฯ สยามบรมราชกุมารี ระยอง <input type="checkbox"/> ส่งมอบถุงกระดาษมือสอง แก่ศูนย์บริการสาธารณสุขเนินพยอม (ตึกM) เพื่อใช้เป็นถุงใส่ยาหมอนเวียนให้ผู้ป่วยทดแทนการใช้ถุงพลาสติก <input type="checkbox"/> สนับสนุนงบประมาณโครงการอบรมอาสาสมัครสาธารณสุขประจำหมู่บ้าน (อสม.) ทม.มาบตาพุด <p><u>4.3.5 ด้านสิ่งแวดล้อม</u></p> <ul style="list-style-type: none"> <input type="checkbox"/> จัดกิจกรรมปล่อยพันธุ์สัตว์น้ำ โดยร่วมกับกลุ่มวิสาหกิจประมงมาบตาพุด- บ้านฉาง โดยปล่อยพันธุ์สัตว์น้ำไปทั้งหมด 2,150,000 ตัว 	ทุกท่าน	เพื่อทราบ

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
4.3 (ต่อ)	<input type="checkbox"/> รับคณะเยี่ยมชมและดูงาน โครงการ Community Waste Model โดยมีตัวแทนจากมูลนิธิคีนันแห่งเอเชีย (KENAN) บริษัท NatureWorks กองเรือยุทธการ คณะอาจารย์และนักศึกษาฝรั่งเศสจากสถาบัน ECAM LaSalle <input type="checkbox"/> มอบมอบปฎิบัติได้เดือน และต้นพันธุ์ไผ่ยักษ์ แก่วิสาหกิจชุมชนสวนเกษตรผสมผสานฐานเรียนรู้สวนคุณย่า <input type="checkbox"/> รับมอบประกาศนียบัตรองค์กรภาคเอกชนที่ให้การสนับสนุนกิจกรรมด้านสิ่งแวดล้อมในงานวันสิ่งแวดล้อมไทย	ทุกท่าน	เพื่อทราบ
	<p><u>4.3.6 ด้านการสื่อสารและสร้างความเข้าใจ</u></p> <input type="checkbox"/> ลงพื้นที่สื่อสารชี้แจงข่าวสื่อสารงานซ่อมบำรุง SD Phenol 2 <input type="checkbox"/> ลงพื้นที่แจ้งข่าวสื่อสารงานซ่อมบำรุงร่วมกับบริษัท GC Polyols <input type="checkbox"/> ลงพื้นที่แจ้งข่าวสื่อสารหยุดเดินเครื่องการผลิตร่วมกับบริษัท GC Oxirane <input type="checkbox"/> ลงพื้นที่ชี้แจงความคืบหน้าการสอบสวนภายในกรณีเพลิงไหม้จากครัวด้านใน GCME <input type="checkbox"/> ลงพื้นที่ตรวจสอบผลกระทบเรื่องกลิ่นต่อชุมชน		
	<p><u>4.3.7 สร้างความสัมพันธ์และสนับสนุนกิจกรรมชุมชน</u></p> <input type="checkbox"/> GC มอบงบสนับสนุน ร่วมงานตามประเพณีและร่วมงานแสดงความยินดี ของชุมชนและหน่วยงานราชการต่างๆ ภายในเขตพื้นที่จังหวัดระยอง <input type="checkbox"/> GC มอบงบสนับสนุนมอบเงินสนับสนุน กิจกรรมศึกษาฐานด้านการแปรรูปอาหารกลุ่มแม่บ้านชุมชนหนองน้ำเย็น <input type="checkbox"/> มอบงบประมาณสนับสนุนกิจกรรมวันรวมน้ำใจสู้รู้สธิดา ยะห์ ประจำปี 2565 และมอบงบประมาณสนับสนุนการเดินทางไปประกอบพิธีฮัจย์ ณ ประเทศซาอุดีอาระเบีย <input type="checkbox"/> สนับสนุนกิจกรรมวัด ไชยหิน/วัดกรอกยายชา/วัดชอยคีรี		

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
4.3 (ต่อ)	<p>☐ GC ลงพื้นที่สวัสดิศึปีใหม่ 2566 20 หน่วยงานราชการ 48 ชุมชน</p> <p>☐ GC ร่วมกิจกรรมประเพณีทำบุญข้ามหลาม ประจำปี 2566 45 ชุมชน</p> <p><u>ข้อกิดเห็นในที่ประชุม</u></p> <p>คุณสุทธา เหมสถิต ผู้แทนชุมชนเขตเทศบาลตำบลบ้านฉาง 15 ชุมชน กล่าวขอบคุณทีมงาน CSR ในเรื่องงานมวลชนสัมพันธ์และการจัดงานตลาดหัวปี</p> <p><u>ข้อสำคัญที่ 1</u> ก็คือชุมชนกลับมาให้ความร่วมมือไปในทิศทางเดียวกันทั้ง 15 ชุมชน หลังจากที่เกิดความไม่เข้าใจกันเล็กน้อยอยากแจ้งว่ากระบวนการของการจัดการงานมวลชนสัมพันธ์เป็นสิ่งที่สำคัญและบางเรื่อง ที่ GC Group และ GC จะสังเกตได้ที่ผู้นำกล่าวว่า GC 16, GC 19 เราจำไม่ได้สมัยก่อนจำได้แต่ไกลคอล, ฟีนอล เพราะฉะนั้นเข้าใจในเรื่องของกิจกรรมที่ทางบริษัทรวมกลุ่มดำเนินการจัดกิจกรรมมากมายแต่ในขณะเดียวกันบางโรงที่เป็นโรงใหญ่ๆเช่น ฟีนอล มีความเห็นว่าควรจะดำเนินการในนามของฟีนอล ก็ควรมีการออกมาทำความเข้าใจด้วยตัวของฟีนอลเองเพราะฟีนอลอยู่ภายใต้บริบทข้างนอกและเคมีที่ก่อนรวบรวมฟีนอลเป็นเอกเทศอยู่อย่างนี้ เป็นต้น เสียงสะท้อนของชุมชนที่บอกมา ส่วน GC ที่อยู่ใน Group เดียวกัน GC เดิมต่างๆอันนี้ก็ถือว่าเป็นส่วนหนึ่ง</p> <p><u>ข้อสำคัญที่ 2</u> ในส่วนของเขตตำบลบ้านฉางทั้ง 15 ชุมชนอยากจะบอกว่าขณะนี้ไปดูเรื่องตลาดหัวปีมากำลังหารือกับเทศบาลซึ่งมีพื้นที่อยู่บริเวณถนนบ้านฉาง - บุรพาพัฒน์ เนื้อที่ 40 กว่าไร่กำลังคุยกับเทศบาลว่าถ้าทำโมเดลจำลองเป็นแบบตลาดหัวปีแล้วให้ชุมชนดำเนินการเหมือนที่ทาง GC พาไป “Market Place” พื้นที่ตรงนั้นเป็นพื้นที่ที่มีการสัญจรเยอะมากจะทำให้เศรษฐกิจชุมชนให้เข้มแข็งได้ รวมทั้งก้านันผู้ใหญ่บ้านทั้งท้องที่และท้องถิ่นและเจ้าของพื้นที่มีการปรึกษาหารือมีโอกาสเป็นไปได้อาจจะเรียนว่า “ธรรมชาติโมเดล” ตรงนั้นที่ชุมชนบ้านฉางและเมื่อผลักดันให้แนวทางเกิดขึ้นจริงและจะมีความยั่งยืน</p>	<p>ทุกท่าน</p> <p>คณะทำงาน GC</p>	<p>เพื่อทราบ</p> <p>เพื่อทราบ</p>



วาระที่ 5 เรื่องอื่นๆ

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
5.1	<p>[REDACTED]</p> <p>หยุดเดินเครื่องในกระบวนการ) ต่อคุณเสขสิริ ปิยะเวช ผู้ช่วยกรรมการผู้จัดการใหญ่สายงานคุณภาพ ความปลอดภัย อาชีวอนามัย</p> <p>ว่าอยากให้ทาง GC มีการเก็บข้อมูลของแต่ละโรงงานและนำมาประเมินภาพรวมตอนสิ้นปีของแต่ละโรงงาน เช่น โรงงานแต่ละโรงงานเกิดเหตุอะไรมากที่สุด</p>	<p>คณะกรรมการ</p> <p>GC</p>	เพื่อทราบ
5.2	<p>[REDACTED]</p> <p>ความปลอดภัย อาชีวอนามัย</p> <p>□ ได้กล่าวเพิ่มเติมว่าทางเรามีการรายงานสถานการณ์เดินเครื่องของ GC Groupทุกโรงให้กับทางผู้บริหารตั้งแต่ระดับ CEO ลงมาปีนี้เรามี Plant ขึ้นๆลงๆ ตลอดและปีนี้ที่เกิดขึ้นเป็นเรื่องไฟฟ้าเราจะต้องมีการเข้าไปพูดคุยกับทางกรไฟฟ้าส่วนภูมิภาค ทางเราอมรับว่ามีการเดินเครื่องไม่ราบรื่นจากการรับไฟฟ้าจากภายนอกเข้ามาและโรงงานไหนที่ Shutdown บ่อยๆ พอสิ้นปีมีการประเมินโรงงานผู้จัดการ โรงงานก็จะมีประเด็นเนื่องจากจะมีการเทียบกันว่าโรงงานไหนมีการเดินเครื่องได้ราบรื่นยาวนานมากกว่าแต่ทั้งนี้เราก็จะต้องมาดูด้วยว่าโรงงานที่มีการ Shutdown เกิดจากปัจจัยภายในโรงงานที่ดูแลไม่ดีหรือเป็นเพราะปัจจัยภายนอกเพราะเรามีการซื้อไฟฟ้าไอน้ำจาก เบื้องต้นขอชี้แจงว่าสาเหตุดังกล่าวที่เกิดขึ้นนั้นเกิดจากปัจจัยภายนอกและตัวชีวิตก็ถือว่าเป็นสิ่งที่สำคัญเช่นกัน</p>	ทุกท่าน	เพื่อทราบ

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
5.2 (ต่อ)	<p>▣ ได้กล่าวชื่นชมทั้งคุณสุเมธ นาเจริญ สมาคมครอบครัวชาว จังหวัระยองและคุณสุทธา เหมสถล ผู้แทนชุมชนเทศบาล ตำบลบ้านฉางในเรื่องของสิ่งแวดล้อม ที่ดำเนินการผ่านมา ไม่ว่าจะเป็นเรื่องการจัดตั้ง Enclosure Ground Flare และ Vapor Recovery Unit ที่คุณสุทธากล่าวว่าได้ดำเนินการ จัดตั้งในยุคคลุมบวร โดย Enclose Ground Flare มีการติดตั้ง ที่ GC 11 (Olefins3) และตอนนี้มีการติดตั้งที่ (Olefins1) และ (Olefins2)</p> <p>▣ ได้กล่าวเพิ่มถึงเรื่องสิ่งแวดล้อมที่ทางคุณสุเมธนาเจริญพูด ถึงว่ากรรมการวุฒิสภาท่านพลเอกสุรศักดิ์ กาญจนลักษณ์ ท่านเป็นวุฒิสมาชิกท่านเป็นผู้ที่จัดสัมมนา “Work Shop” เอาคนที่เกี่ยวข้องทางวิชาการสิ่งแวดล้อมสุขภาพมาทำการ ระดมสมองกันและภาพรวมผลตรวจวัดด้านสิ่งแวดล้อมที่ มาबाटพุดที่ผ่านมามีแนวโน้มดีขึ้นจากการที่กรม โรงงาน ออกกฎหมายในเรื่องของการควบคุมการปล่อย VOCs จาก แท็งก์จากการซ่อมบำรุงก่อนซ่อมบำรุงก่อนปลดอุปกรณ์ ต้องทำการติดอุปกรณ์เอาเคมีคอลเข้ามาช่วย Clean ให้มีสาร VOCs เหลือน้อยที่สุดก่อนจะเปิดอุปกรณ์และเรื่องของการ ใ้หาระวังเรื่องของ Flare (หอเผา) เราจะต้องมีการรายงานต่อ กรมโรงงานด้วยและกรมโรงงานจะเข้ามาดูด้วยว่ามีโรงงาน ไหนที่มีการปล่อยบ่อยก็จะเข้ามาควบคุมและดูแลและมี แนวโน้มดีขึ้นนอกจากนี้เคยทำการติดต่อไปยังสถาบัน มะเร็งแห่งชาติและมีการให้นักวิชาการเข้ามาทำข้อมูล เกี่ยวกับอัตราการป่วยโรคมะเร็งของจังหวัดระยองกับ จังหวัดอื่นๆและเทียบกับประเทศไทยซึ่งพบว่าจังหวัด ระยองพบคนที่เป็นโรคมะเร็งน้อยกว่าค่าเฉลี่ยประเทศไทย และน้อยกว่าจังหวัดชลบุรีและจังหวัดจันทบุรีและในครั้ง หน้าจะมีการเอาข้อมูลเชิงวิชาการมาแจ้งให้ทราบ</p>	ทุกท่าน	เพื่อทราบ

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
5.3	<p>เพิ่มเติมวาทะกรรมใหม่การวัดระยะห่างการทำ CSR วาบบงเพาไรและสิ่งที่สะท้อนกลับมาเป็นอย่างไรบ้าง การทำ CSR ไม่หวังผลตอบแทนแต่ในขณะเดียวกันเราต้องมีการพัฒนาก้าวหน้าให้เป็นมีระดับอาชีพในเรื่องของสิ่งแวดล้อมกับเรื่องของงานมวลชนสัมพันธ์ (CSR) ต้องมีการจับมือกันเพื่อให้เกิดความเข้าใจกันตัวแทนของGCหันกลับมาฟังชุมชนว่าชุมชนเกิดปัญหาอะไรและทำงานเชิงลึกอย่างไรทั้งนี้ GC กับ ปตท. เป็นผู้นำด้านเทคโนโลยีเป็นผู้นำด้านอุตสาหกรรม เพราะฉะนั้นควรยกระดับฐานะและยกระดับข้อเท็จจริงให้มากขึ้นและยกระดับฐานะให้เข้มแข็งและเป็นต้นแบบในเรื่องของเชิงสิ่งแวดล้อมในเรื่องของการหมุนลื้อระหว่างชุมชนกับผู้ประกอบการให้ก้าวหน้าขึ้นไปให้ได้</p>	<p>คณะกรรมการ GC</p>	เพื่อทราบ

ปิดประชุม 16.00 น.



ผู้ตรวจทานรายงานการประชุม



รายงานการประชุมคณะกรรมการมวลชนสัมพันธ์และสิ่งแวดล้อม
กลุ่มบริษัท พีทีที โกลบอล เคมิคอล

เรื่อง ประชุมคณะกรรมการมวลชนสัมพันธ์และสิ่งแวดล้อม กลุ่ม บริษัท พีทีที โกลบอล เคมิคอล
ครั้งที่ 2/2566
วันที่ 26 เมษายน 2566
สถานที่ ห้องประชุมทองหลวง บริษัท จีซี เอสเตท จำกัด

รายนามผู้เข้าประชุม

ผู้อำนวยการสำนักงานนิคมอุตสาหกรรมดับบลิวเอชเอตะวันออก
(มาบตาพุด) ประธานคณะกรรมการ
ผู้อำนวยการศูนย์ควบคุมมลพิษจังหวัดระยอง กรมควบคุมมลพิษ
ผู้แทน นายแพทย์สาธารณสุขจังหวัดระยอง
ผู้แทน ผู้อำนวยการสำนักงานทรัพยากรธรรมชาติและสิ่งแวดล้อม
จังหวัดระยอง
ผู้แทน นายกเทศมนตรีเทศบาลเมืองมาบตาพุด
ผู้แทน นายกเทศมนตรีเทศบาลเมืองบ้านฉาง
ผู้แทน กำนันตำบลบ้านฉาง
ผู้แทน ผู้ใหญ่บ้านหมู่ 1 ตำบลบ้านฉาง
ผู้แทน ผู้ใหญ่บ้านหมู่ 2 ตำบลบ้านฉาง
ประธานชุมชนอิสลาม
ประธานชุมชนหนองแฟบ
ผู้แทน ประธานชุมชนมารบขลุ่ย-ซากกลาง
ผู้แทนชุมชน เขตเทศบาลเมืองมาบตาพุด
ผู้แทนชุมชน เขตเทศบาลเมืองมาบตาพุด
ผู้แทนชุมชน เขตเทศบาลเมืองมาบตาพุด
ผู้แทนชุมชน เขตเทศบาลเมืองมาบตาพุด
ผู้แทนชุมชน เขตเทศบาลเมืองมาบตาพุด
ผู้แทนชุมชน เขตเทศบาลเมืองมาบตาพุด
ผู้แทนชุมชน เขตเทศบาลเมืองบ้านฉาง
ผู้แทนชุมชน เขตเทศบาลเมืองบ้านฉาง
ผู้แทนชุมชน เขตเทศบาลเมืองบ้านฉาง

ผู้แทนชุมชน เขตเทศบาลตำบลบ้านฉาง

สมาคมครอบครัวชาวจังหวัดระยอง

กรรมการกิตติมศักดิ์

ผู้แทน กรรมการกิตติมศักดิ์

ผู้ช่วยกรรมการผู้จัดการใหญ่ สายงานคุณภาพ ความปลอดภัย

อาชีวอนามัยและสิ่งแวดล้อม

ผู้จัดการส่วน หน่วยงานชุมชนสัมพันธ์

ผู้จัดการฝ่าย หน่วยงานอาชีวอนามัยและสิ่งแวดล้อม

ผู้แทน โรงงานโอเลฟินส์ 1 (Olefins Plant 1)

ผู้แทน โรงงานโอเลฟินส์ 2 (Olefins Plant 2)

ผู้แทน โรงงานโอเลฟินส์ 3 (Olefins Plant 3)

ผู้แทน โรงงานอะโรแมติกส์ 1 (Aromatics Plant 1)

ผู้แทน โรงงานเอชดีพีอี 1 (HDPE1) /เอชดีพีอี 2 (HDPE2)

ผู้แทน โรงงานเอทิลีนไกลคอล (Ethylene Glycol)

ผู้แทน โรงงานฟีนอล (Phenol)

ผู้แทน โรงงานจีซี โพลีโอลส์ (GC Polyols)

ผู้แทน โรงงานโพลีสไตรีน (Polystyrene)

ผู้แทน โรงงานจีซี-เอ็มพีทีเอ (GC-MPTA)

ผู้แทน โรงงานคูราเร่ จีซี แอดวานซ์ เมททีเรียลส์ จำกัด (KGC)

และโรงงานคูราเร่ แอดวานซ์ เคมีคอล จำกัด (KAC)

ผู้จัดการส่วน หน่วยงานบริการสิ่งแวดล้อม

ผู้แทน หน่วยงานชุมชนสัมพันธ์

ผู้แทน หน่วยงานบริการสิ่งแวดล้อม

ผู้จัดการส่วน หน่วยงานอาชีวอนามัยและสิ่งแวดล้อม และ

เลขานุการ

ผู้เข้าร่วมประชุมออนไลน์ ผ่านระบบ Microsoft Team

ผู้แทน โรงงานแอลแอลดีพีอี (LLDPE)

ผู้จัดการฝ่ายผลิต โรงงานจีซีออกซิเรน (GC Oxirane)

ผู้แทน โรงงานผลิตไฟฟ้าและสาธารณูปโภค (GC2) และ

ท่าเทียบเรือและคลังผลิตภัณฑ์ (GC7)

ผู้จัดการฝ่าย หน่วยงานชุมชนสัมพันธ์

ผู้จัดการฝ่าย บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)

ผู้จัดการฝ่าย บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)

ผู้จัดการฝ่าย บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)

ผู้แทน บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)

ผู้แทน บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)

ผู้แทน บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)

ผู้แทน บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)

วาระที่ 1: เรื่องแจ้งเพื่อทราบ

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
1.1	คณะกรรมการฯ ทุกท่านในการประชุม ครั้งที่ 2/2566	ทุกท่าน	เพื่อทราบ

วาระที่ 2: รับรองรายงานการประชุมครั้งที่ 1/2566

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
2.1	มติที่ประชุม: รับรองรายงานการประชุม ครั้งที่ 1/2566	ทุกท่าน	เพื่อทราบ

วาระที่ 3: เรื่องสืบเนื่องจากการประชุมครั้งที่ 1/2566

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
3.1	การบรรยายให้ความรู้แก่คณะกรรมการฯ		เพื่อทราบ
3.1.1	การบรรยาย “Enclosed Ground Flare” โดย คุณสุชาติา คงธน เกตุสกุล		
3.1.2	การบรรยาย “Vapor Recovery Unit (VRU)” โดย คุณสุรจิต สถาพรวัลย์รัตน์		
	<p>ความเห็นจากที่ประชุม</p> <p>กรรมการฯ มีความกังวลเกี่ยวกับ VOCs ที่มีการระบายออกไปหรือไม่อย่างไร</p> <p>เลขฯ: ให้ข้อมูลเพิ่มเติม ดังนี้</p> <ul style="list-style-type: none"> - ทาง GC แบ่งออกเป็น 2 ชนิด ดังนี้ <ol style="list-style-type: none"> 1. VRU ที่ขนถ่ายน้ำมันทางรถบรรทุก จะควบคุมไอน้ำมันเบนซิน ไม่เกิน 17 มิลลิกรัม 2. VRU สำหรับโรงงานปิโตรเคมี ยังไม่มีมาตรฐานกำหนด แต่ GC จะมีการรายงานให้กับทาง สม.ทราบเกี่ยวกับประสิทธิภาพและผลการตรวจวัด 3. มาตรฐานกรมโรงงานอุตสาหกรรม กำหนดจุดรั่วซึม (fugitive) ไม่เกิน 500 ppm แต่ภายในของ GC ควบคุมให้ไม่เกิน 300 ppm <p>คุณเสขสิริ ปิยะเวช: ชี้แจงเพิ่มเติม ดังนี้</p> <ul style="list-style-type: none"> - ทางกรมโรงงานอุตสาหกรรมควบคุมสาร VOCs รวมกันไม่เกิน 500 ppm แต่ GC ควบคุมที่ 200-300 ppm ซึ่งจะต่ำกว่า 500 ppm 		

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
3. (ต่อ)	<p>ของ</p> <p>หน่วย VRU ดังนี้</p> <ol style="list-style-type: none"> 1. ควบคุมโดยการตรวจวัดคุณภาพอากาศ 2. ควบคุมโดยใช้ระยะเวลาในการฟื้นฟู ซึ่งจะอยู่ประมาณ 6-10 นาที <p>มีคำถามเพิ่มเติมเกี่ยวกับว่าถ้ามีการดูดกลับแล้วมีการนำไปใช้หรือไม่และมีส่วนไหนที่มีการปล่อยระบายออกมา</p> <p>เลขาฯ: ให้ข้อมูลเพิ่มเติม ดังนี้</p> <ul style="list-style-type: none"> - สามารถนำกลับไปได้ โดยส่วนที่เหลือที่มีการปล่อยออกมามีประมาณ 2% 		

วาระที่ 4: การดำเนินของกลุ่มบริษัท PTT Global Chemical

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
4.1	รายงานการเดินเครื่องโรงงาน กลุ่มบริษัท พีทีที โกลบอล เคมิคอล		เพื่อทราบ
4.1.1	<p>รายงานการเดินเครื่องโรงงานโอเลฟินส์ 1 และ โอเลฟินส์ 4</p> <p>วันที่ 21 มกราคม 2566 ถึง วันที่ 5 กุมภาพันธ์ 2566</p> <p>โรงงานโอเลฟินส์ 1 (Cracker Unit) ดำเนินการเดินเครื่อง (Start up) จากการหยุดซ่อมบำรุงย่อย และหยุดเดินเครื่องเชิงพาณิชย์ 1 ตุลาคม 2565 – 20 มกราคม 2566 ปัจจุบันเดินเครื่องปกติ</p> <p>วันที่ 20 กุมภาพันธ์ ถึง วันที่ 3 มีนาคม 2566</p> <p>โรงงานโอเลฟินส์ 1 (Olefins 1) ดำเนินการเดินเครื่อง (Start up) จากการหยุดเดินเครื่องเชิงพาณิชย์ 1 สิงหาคม 2565 – 19 กุมภาพันธ์ 2566 ปัจจุบัน เดินเครื่องปกติ</p> <p>วันที่ 16 กุมภาพันธ์ 2566 ถึง ปัจจุบัน</p> <ul style="list-style-type: none"> - โรงงานโอเลฟินส์ 4 (Olefins 4) เดินเครื่องปกติ 		
4.1.2	<p>วันที่ 15 กุมภาพันธ์ 2566 ถึง วันที่ 31 มีนาคม 2566:</p> <ul style="list-style-type: none"> - โรงผลิตสารโอเลฟินส์ หน่วยผลิตที่ 1: มีการเดินเครื่องเป็นปกติ “โดยไม่มีอุบัติเหตุและผลกระทบด้านสิ่งแวดล้อม” - โรงผลิตสารโอเลฟินส์ หน่วยผลิตที่ 2: หยุดเดินเครื่องเพื่อซ่อมบำรุง และเชื่อมต่อโครงการ Olefins I-4/2 Modification for Propane Feedstock Project (OMP) ในระหว่างวันที่ 5 มกราคม – วันที่ 7 พฤษภาคม 2566 - โรงผลิตบิวทาไดอีนและบิวทีน-1: มีการเดินเครื่องเป็นปกติ “โดยไม่มีอุบัติเหตุและผลกระทบด้านสิ่งแวดล้อม” 		

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
4.1.7	<p>รายงานการเดินเครื่อง โรงงานเอชดีพีอี1 (HDPE1) (GC12) โดย [REDACTED]</p> <p><u>วันที่ 15 กุมภาพันธ์ 2566 ถึง ปัจจุบัน</u></p> <ul style="list-style-type: none"> - โรงงานเดินเครื่องเป็นปกติ ต่อเนื่อง โดยไม่มีอุบัติเหตุและผลกระทบด้านสิ่งแวดล้อม 		
4.1.8	<p>รายงานการเดินเครื่อง โรงงานจีซี ไกลคอล (GC Glycol) (GC16) โดย [REDACTED]</p> <p>หน่วยผลิตเอทิลีนออกไซด์/เอทิลีนไกลคอล (EO/EG Plant)</p> <ul style="list-style-type: none"> - ขอย้ายระยะเวลาการหยุดเดินเครื่องเพื่อซ่อมบำรุงเครื่องจักร (Shutdown) : จากเดิมวันที่ 13 มกราคม 2566 ถึง วันที่ 14 มีนาคม 2566 เป็น ถึงวันที่ 30 มิถุนายน 2566 เนื่องจากบริษัทฯ พบความเสียหายของอุปกรณ์เพิ่มเติม ทำให้ไม่สามารถซ่อมบำรุงให้แล้วเสร็จตามแผนเดิมที่กำหนดไว้ <p>หน่วยผลิตเอทานอลเอมีน (EA Plant)</p> <ul style="list-style-type: none"> - หยุดเดินเครื่องเชิงพาณิชย์ (Commercial Shutdown): วันที่ 6 ธ.ค. 2565 – วันที่ 12 ม.ค. 2566 - ขอย้ายระยะเวลาหยุดเดินเครื่องจักรเพื่อซ่อมบำรุงเครื่องจักร (Shutdown) : จากเดิมวันที่ 13 มกราคม 2566 ถึง วันที่ 20 มีนาคม 2566 เป็นถึงวันที่ 5 กรกฎาคม 2566 		
4.1.9	<p>รายงานการเดินเครื่อง โรงงานฟีนอล (Phenol) (GC18) โดย คุณ [REDACTED]</p> <ul style="list-style-type: none"> - <u>หน่วยผลิตสารฟีนอล:</u> เดินเครื่องการผลิตปกติโดยได้ดำเนินการหยุดซ่อมบำรุงตามแผน ระหว่างวันที่ 22 – วันที่ 27 ก.พ. 2566 และกลับมาเดินเครื่องตามปกติ - <u>หน่วยผลิตสารบิสฟีนอล เอ:</u> เดินเครื่องการผลิตปกติโดยได้ดำเนินการหยุดซ่อมบำรุงตามแผน ระหว่างวันที่ 21 – วันที่ 28 ก.พ. 2566 และกลับมาเดินเครื่องตามปกติ 		
4.1.10	<p>รายงานการเดินเครื่อง โรงงานจีซี ออกซีเรน (GC Oxirane) (GC17) โดยคุณ [REDACTED]</p> <p><u>วันที่ 25 มกราคม 2566 ถึง วันที่ 30 มีนาคม 2566</u></p> <ul style="list-style-type: none"> - โรงงานมีการหยุดการเดินเครื่องเพื่อการพาณิชย์ โดยไม่มีอุบัติเหตุและผลกระทบด้านสิ่งแวดล้อม <p><u>วันที่ 1 เมษายน 2566 ถึง ปัจจุบัน</u></p> <p>โรงงานเดินเครื่องปกติ</p>		

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
4.1.11	<p>รายงานการเดินเครื่อง โรงงานโพลีออลส์ (GC Polyols) โดย คุณ [REDACTED]</p> <p><u>ระหว่างวันที่ 19 มกราคม 2566 ถึง วันที่ 13 มีนาคม 2566</u></p> <ul style="list-style-type: none"> - มีการหยุดเดินเครื่องการผลิตเพื่อการพาณิชย์ และซ่อมบำรุงเครื่องจักร โดยไม่มีอุบัติเหตุและผลกระทบด้านสิ่งแวดล้อม <p><u>วันที่ 14 มีนาคม 2566 ถึง ปัจจุบัน</u></p> <ul style="list-style-type: none"> - โรงงานเดินเครื่องปรกติ 		
4.1.12	<p>รายงานการเดินเครื่อง โรงงานโพลีสไตรีน (GC17) โดย คุณ [REDACTED]</p> <p><u>วันที่ 15 กุมภาพันธ์ 2566 ถึง วันที่ 31 มีนาคม 2566:</u></p> <ul style="list-style-type: none"> - สายการผลิต GPPS มีการเดินเครื่องเป็นปรกติ “โดยไม่มีอุบัติเหตุและผลกระทบด้านสิ่งแวดล้อม” - สายการผลิต HIPS มีการหยุดเดินเครื่อง (commercial shutdown) เนื่องจากสถานการณ์ตลาด ในระหว่างวันที่ 21 กุมภาพันธ์ 2566 ถึง วันที่ 6 มีนาคม 2566 และกลับมาเดินเครื่อง 		
4.1.13	<p>รายงานการเดินเครื่อง โรงงานจีซี-เอ็ม พีทีเอ จำกัด [REDACTED]</p> <p>โรงงานมีการหยุดซ่อมบำรุงตามแผนประจำปี 2566 ดังนี้</p> <ul style="list-style-type: none"> - สายการผลิตที่ 2: วันที่ 1 มีนาคม 2566 ถึง วันที่ 4 เมษายน 2566 <p>“ดำเนินการแล้วเสร็จโดยไม่มีอุบัติเหตุและผลกระทบด้านสิ่งแวดล้อม”</p> <ul style="list-style-type: none"> - แผนหยุดซ่อมบำรุงต่อไปที่ สายการผลิตที่ 3: วันที่ 17 พฤษภาคม 2566 ถึง วันที่ 23 พฤษภาคม 2566 		
4.1.14	<p>รายงานการเดินเครื่อง โรงงานบริษัท ไทย อีทอกซีเลท จำกัด(มหาชน) อุตสาหกรรมดับบลิวเอชเอ ตะวันออก (มาบตาพุด) โดย เลขาฯ</p> <p><u>วันที่ 1 ธันวาคม 2565 ถึง วันที่ 12 มกราคม 2566</u></p> <ul style="list-style-type: none"> - โรงงานเดินเครื่องเป็นปรกติต่อเนื่อง โดยไม่เกิดอุบัติเหตุและผลกระทบด้านสิ่งแวดล้อม <p><u>วันที่ 13 มกราคม 2566 ถึง วันที่ 31 มีนาคม 2566</u></p> <ul style="list-style-type: none"> - หยุดการผลิตและซ่อมบำรุงประจำปีซึ่งมีมาตรการควบคุม โดยไม่ให้เกิดอุบัติเหตุและไม่มีการร้องเรียนจากทางชุมชน <p><u>วันที่ 1 เมษายน 2566 ถึง วันที่ 30 มิถุนายน 2566</u></p> <ul style="list-style-type: none"> - หยุดการผลิตด้วยเหตุผลเชิงพาณิชย์ 		

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
4.1.15	<p>รายงานการเดินเครื่อง โรงงาน ครุแร่ จีซี แอดวานซ์ แมททีเรียลส์ จำกัด (KGC) และครุแร่ แอดวานซ์ เคมีคอล จำกัด (KAC) (ส่วนประกอบของปูนซีเมนต์) (ส่วนประกอบของปูนซีเมนต์)</p> <p><u>วันที่ 15 กุมภาพันธ์ 2566 ถึง วันที่ 31 มีนาคม 2566</u></p> <ul style="list-style-type: none"> - เป็นช่วงเริ่มกลับมาเดินเครื่องเพื่อทดสอบกำลังการผลิตของโรงงาน KGC <p><u>วันที่ 4 มีนาคม 2566</u></p> <ul style="list-style-type: none"> - โรงงานผลิตยางเทอร์โมพลาสติก(KGC) เริ่มเดินเครื่องเพื่อทดสอบกำลังการผลิต แต่พบปัญหาต้องหยุดเดินเครื่องชั่วคราวเพื่อแก้ไขอุปกรณ์ และมีแผนจะกลับมาเดินเครื่องการผลิตอีกครั้งในปลายเดือนเมษายน 2566 <p><u>วันที่ 7 มีนาคม 2566</u></p> <ul style="list-style-type: none"> - โรงงานผลิตพอลิเอไมด์ชนิดพิเศษ (KGC) เริ่มเดินเครื่องผลิตเพื่อทดสอบกำลังการผลิต แต่พบปัญหาต้องหยุดเดินเครื่องชั่วคราวเพื่อแก้ไขอุปกรณ์ และมีแผนจะกลับมาเดินเครื่องการผลิตอีกครั้งในปลายเดือนเมษายน 2566 <p><u>วันที่ 1 ธันวาคม 2565</u></p> <ul style="list-style-type: none"> - โรงงานผลิตไอโซพรีนอลและอนุพันธ์ (KAC) หยุดเดินเครื่องผลิต เพื่อแก้ไขอุปกรณ์เดินเครื่องที่ชำรุด และมีแผนจะกลับมาเดินเครื่องการผลิตอีกครั้งในปลายเดือนเมษายน 2566 		
4.1.16	<p>รายงานการเดินเครื่องโรงงานโรงงานผลิตไฟฟ้า และ</p> <p><u>งานซ่อมบำรุงตามแผน</u></p> <ul style="list-style-type: none"> - H-3705 ระหว่างวันที่ 20 กุมภาพันธ์ 2566 ถึง วันที่ 23 กุมภาพันธ์ 2566 และ วันที่ 22 มีนาคม 2566 ถึง วันที่ 29 มีนาคม 2566 - H-3706 ระหว่างวันที่ 6 มีนาคม 2566 ถึง วันที่ 12 มีนาคม 2566 - H-3711 ระหว่างวันที่ 1 มีนาคม 2566 ถึง วันที่ 3 มีนาคม 2566 		
4.1.17	<p>รายงานการเดินเครื่องท่าเทียบเรือและคลังผลิตภัณฑ์</p> <p><u>ในช่วงวันที่ 15 กุมภาพันธ์ 2566 ถึง วันที่ 31 มีนาคม 2566</u></p> <ul style="list-style-type: none"> - การเดินเครื่องปรกติ 		

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
<p>4.1</p> <p>(ต่อ)</p>	<p>ความเห็นจากที่ประชุม</p> <p>ผู้ [REDACTED]</p> <ul style="list-style-type: none"> - เรื่องการรายงานการเดินเครื่องของโรงงานทุกโรงงาน อยากให้มีการนำเสนอข้อเท็จจริงเกี่ยวกับเรื่องที่จะมีการนำเสนอ โดยอ้างอิงตามข้อมูลที่ทาง EMCC เพราะที่ผ่านมาทาง EMCC มีการรายงานตลอด <p>เลขที่: ชื่นจงเพิ่มเติม ดังนี้</p> <ul style="list-style-type: none"> - จะพิจารณาทบทวนข้อมูลตามที่ได้มีการเสนอแนะมา ในการประชุมครั้งถัดไป <p>[REDACTED]</p> <ul style="list-style-type: none"> - โรงงานที่ไม่ได้มีการเข้าร่วมในการรายงานในที่ประชุม ในการประชุมครั้งถัดไป อยากให้เข้าร่วมการประชุมแทนการรายงานการประชุมผ่านทางระบบออนไลน์ เนื่องจากการสื่อสารจะมีความชัดเจนมากขึ้น <p>[REDACTED]</p> <ul style="list-style-type: none"> - ในการประชุมครั้งถัดไป จะเสนอให้ผู้บริหารเข้าร่วมการรายงานการประชุม แทนการรายงานการประชุมผ่านทางระบบออนไลน์ <p>[REDACTED]</p> <ul style="list-style-type: none"> - เรื่องการเดินเครื่องโรงงานให้มีการรายงานข้อมูลการ Shut down และการปล่อยสาร VOCs ดังกล่าวในครั้งถัดไป <p>[REDACTED]</p> <ul style="list-style-type: none"> - ทางกรมโรงงานอุตสาหกรรม ให้ทางโรงงานมีการเผ่าระวังในเรื่องของ Flare และทุกครั้งจะมีการรายงานข้อมูลให้กับทางกรมโรงงานฯ เกี่ยวกับผลกระทบและมาตรการต่างๆ เป็นต้น 		
<p>4.2</p>	<p>รายงานความก้าวหน้า EIA โครงการของกลุ่มบริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน) โดย เลขที่</p> <p>ในช่วงเดือนกุมภาพันธ์ 2566 ถึง เดือนมีนาคม 2566</p> <p>โครงการโรงผลิตสารฟีนอล (ส่วนขยาย ครั้งที่ 3) สาขา 18 โรงงานฟีนอล</p> <ul style="list-style-type: none"> - เพิ่มกำลังการผลิตของโรงงานฟีนอล ประมาณร้อยละ 5 จากกำลังการผลิตปัจจุบัน - ปรับปรุงและขอแก้ไขรายละเอียดโครงการ ให้สอดคล้องกับการดำเนินการจริง และสอดคล้องกับโรงงานผลิตสารไอโซโพรพิลแอลกอฮอล์ (Isopropyl Alcohol: IPA) ของบริษัทฯ 		

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
4.2 (ต่อ)	<ul style="list-style-type: none"> - อยู่ระหว่างการเพิ่มเติมข้อมูลตามความเห็นของ คณะกรรมการผู้ชำนาญการ <p>โครงการทำเทียบเรือของโรงกลั่นน้ำมันระยอง (เปลี่ยนแปลง ครั้งที่ 1) GC สาขา 6 โรงกลั่นน้ำมัน</p> <ul style="list-style-type: none"> - เพิ่มเติมชนิดผลิตภัณฑ์ที่จะนำมาขนถ่ายที่ทำเทียบเรือ ที่ 1, 2, 3 - ปรับปรุงข้อมูลรายละเอียดโครงการในรายงาน EIA ฉบับ พ.ศ. 2536 และทบทวนมาตรการต่างๆ ให้ สอดคล้องกับผลกระทบและการดำเนินการในปัจจุบัน - กรมเจ้าท่า เสนอรายงานฯ ให้ สผ. พิจารณา ซึ่ง ปัจจุบันอยู่ระหว่างขั้นตอนการพิจารณาของ สผ. <p>โครงการโรงงานผลิตอีพ็อกซีเรซิน GC สาขา 18</p> <ul style="list-style-type: none"> - โรงงานผลิตอีพ็อกซีเรซิน (Epoxy Resin) กำลังการผลิตประมาณ 80,000 ตัน/ปี หรือ 219.18 ตัน/วัน - อยู่ระหว่างการจัดเตรียมรายงานฉบับสมบูรณ์ เพื่อนำเสนอ สผ. 		
4.3	การดำเนินงานด้านมวลชนสัมพันธ์ ของกลุ่มบริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)		
4.3.1	<p>ด้านการศึกษาและเยาวชน</p> <ul style="list-style-type: none"> - GC จัดกิจกรรมอบรมให้ความรู้และแนวทางการศึกษาผ่าน 4 กิจกรรม ให้แก่เยาวชนในพื้นที่จังหวัดระยอง <ol style="list-style-type: none"> 1. โรงเรียนประชารัฐ 2. โครงการพัฒนาศักยภาพชุมชนและเยาวชนในพื้นที่ จังหวัดระยอง ร่วมกับมูลนิธิคีนันแห่งเอเชีย (Kenan) 3. โครงการเพิ่มศักยภาพนักศึกษาหญิงสายช่าง...สู่เส้นทางอาชีพ (Women in STEP) ร่วมกับ มูลนิธิคีนันแห่งเอเชีย (Kenan) 4. โครงการต่อยอดความฝัน ผลักดันสู่อาชีพ" - GC มอบงบประมาณสนับสนุนกิจกรรมและทุนการศึกษา <ol style="list-style-type: none"> 1. สนับสนุนกิจกรรมมอบทุนการศึกษาชมรมแม่บ้านมหาดไทย มอบงบประมาณ 40,000 บาท 2. สนับสนุนมอบทุนการศึกษา อาหารกลางวัน ให้แก่โรงเรียนวัดธรรมสถิต มอบงบประมาณ 50,000 บาท 3. สนับสนุนมอบทุนการศึกษา อาหารกลางวัน และมอบอุปกรณ์การเรียนให้น้องๆ นักเรียน 3. สนับสนุนการศึกษาและร่วมพิธีฉลองรางวัลสถานศึกษาพระราชทาน และพิธีเปิดอาคารเรียนหลังใหม่ โรงเรียนบ้านมาบตาพุด 		

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
4.3.2	ด้านความปลอดภัย <ul style="list-style-type: none"> - ร่วมจัดอบรมทบทวนข้อแผนฉุกเฉิน ชุมชนเขาไผ่ ชุมชนโชดหิน 2 และชุมชนโชดหินมิตรภาพ 		
4.3.3	ด้านสุขภาพ <ul style="list-style-type: none"> - ร่วมสนับสนุนเครื่องอุปโภคบริโภค และกิจกรรมส่งเสริมสุขภาพผู้สูงอายุ สุขกาย สุขใจ เขตพื้นที่เทศบาลเมืองมาบตาพุด - ส่งมอบทุนช่วยเหลือฟื้นฟูคนไข้พาร์ก ให้แก่ โรงพยาบาลเฉลิมพระเกียรติ สมเด็จพระเทพรัตนราชสุดาฯ สยามบรมราชกุมารี ระยอง 		
4.3.4	ด้านเศรษฐกิจ <ul style="list-style-type: none"> - พบผู้ประกอบการ E Commerce แบนด์ ALL LOCAL เพื่อ Matching สินค้าชุมชนกับธุรกิจ - ส่งมอบระบบผลิตไฟฟ้าจากพลังงานแสงอาทิตย์ (Solar Cell) <ol style="list-style-type: none"> 1. ส่งมอบระบบผลิตไฟฟ้าจากพลังงานแสงอาทิตย์ (Solar Cell) เพื่อใช้ในโครงการพัฒนานวัตกรรมเลี้ยงปูทะเลในคอนโด อาคารเลี้ยงปูทะเลในคอนโด ชายหาดหนองแพบ - โครงการธรรมศาสตร์โมเดล รุ่นที่ 8 ร่วมกับนักศึกษาคณะพาณิชยศาสตร์และการบัญชี มหาวิทยาลัยธรรมศาสตร์ พัฒนาวិสาหกิจชุมชนเพื่อการใช้ประโยชน์ทางชีวภาพมาบตาพุด ซึ่งจะช่วยพัฒนา 3 ด้านหลัก ได้แก่ <ol style="list-style-type: none"> 1) การออกแบบ Logo และออกแบบ Packaging 2) การแปรรูปสินค้า 3) การเพิ่มช่องทางจำหน่ายสินค้า - รายได้จากการร่วมออกร้านจำหน่ายสินค้า ผ่านช่องทางต่าง ๆ ของ GC <ol style="list-style-type: none"> 1) โครงการนวัตกรรมพลาสติกคลุมโรงเรือน วิสาหกิจชุมชนสวนเกษตรผสมผสาน ฐานเรียนรู้สวนคุณย่าสร้างรายได้กลับสู่ชุมชน 318,494 บาท 2) รายได้ผ่านการดำเนินการจัดซื้อจัดจ้างผ่านโครงการ CSR <ul style="list-style-type: none"> - ร้านค้าชุมชน ใน 4 เขตเทศบาล 74,129 บาท - ร้านค้ารายย่อยในจังหวัดระยอง นอก 4 เขตเทศบาล 83,394 บาท <p>สร้างรายได้กลับสู่ชุมชน 157,523 บาท</p>		


หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
4.3.5	ด้านสิ่งแวดล้อม <ul style="list-style-type: none"> - โครงการปล่อยพันธุ์สัตว์น้ำ ประจำปี 2566 ร่วมกับกลุ่มประมงเรือเล็กพื้นบ้านพลาอยู่ตะเภาสამัคคี จำนวน 7 แส่น ตัว (แม่ปู 100 ตัว ลูกปู 6 แส่นตัว ปลากระพง 400 ตัว ลูกกุ้ง 1 แส่นตัว) - ด้อนรับคณะเยี่ยมชมและร่วมจัดบูธนิทรรศการ โครงการ Community Waste Model <ol style="list-style-type: none"> 1. ชุมชนในกองเรือยุทธการ 2. งาน Green Your Future 2023: Smart City & Net Zero เท็นทริระยอง - กิจกรรมจิตอาสาเก็บขยะชายหาด Beach Cleaning Days ชายหาดพยุหะ ชายหาดพลา ชายหาดหนองแฟบ และชายหาดบริเวณ BTF JETTY เก็บขยะได้ 356 กก. - กิจกรรม CSR BY ARO “GC Plogging by Aromatics ครั้งที่ 6” เดิน-วิ่ง รักโลก ชุมชนเนินพยอม,ชุมชนบ้านบน เพื่อส่งเสริมการออกกำลังกายเพื่อสุขภาพและใส่ใจสิ่งแวดล้อมในชุมชน เก็บขยะได้ 250 กก. 		
4.3.6	ด้านการสื่อสารและสร้างความเข้าใจ <ul style="list-style-type: none"> - ลงพื้นที่สื่อสารชี้แจงข่าวการซ่อมบำรุงและเดินเครื่องการผลิตของโรงงานในกลุ่ม GC - ลงพื้นที่นำหนังสือเรียนเชิญร่วมประชุมไตรภาคี และประชุมโครงการ ORP - ลงพื้นที่ตรวจสอบผลกระทบชุมชนรอบรั้วโรงงานในช่วงซ่อมบำรุง - ลงพื้นที่ชุมชนรอบรั้วโรงงาน เพื่อชี้แจงทำความเข้าใจกับชุมชน กรณี GC11 (OLE3) การเดินเครื่องผลิตปรกติ - ร่วมประชุมคณะกรรมการมวลชนสัมพันธ์และสิ่งแวดล้อม - GC ร่วมให้ข้อมูลเรื่อง “การดูแลสังคมโดยรอบโรงงานอุตสาหกรรม” การกระจายรายได้ให้กับประชาชน พร้อมต้อนรับ ผู้ตรวจราชการกระทรวงอุตสาหกรรม - โรงงานในกลุ่ม GC เข้าร่วมการตรวจประเมินโรงงานธงชาวดาวเขียว จำนวน 11 โรงงาน 		
4.3.7	สร้างความสัมพันธ์และสนับสนุนกิจกรรมชุมชน <ul style="list-style-type: none"> - GC มอบงบประมาณสนับสนุน ร่วมงานตามประเพณี ร่วมงานแสดงความยินดี และงานกิจกรรมต่างๆ จำนวน 11 ชุมชน 9 หน่วยงานราชการ ในเขตพื้นที่จังหวัดระยอง - มอบงบประมาณสนับสนุนเสื้อชูชีพ และเชือกช่วยชีวิตทางน้ำให้แก่มูลนิธิสว่างพรกุศล 		เพื่อทราบ

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
4.3 (ต่อ)	<ul style="list-style-type: none"> - สนับสนุนสื่อ โครงการอบรมสัมมนาคณะกรรมการชุมชนย่อย เทศบาลเมืองมาบตาพุด - ร่วมกิจกรรมโครงการ Walk & Run for Health จัดโดยองค์การบริหารส่วนจังหวัดระยอง และ สมาคมกีฬาแห่งจังหวัดระยอง - GC ลงพื้นที่สวัสดิ์ปีใหม่ 2566 หน่วยงานราชการและชุมชนต่างๆ ในพื้นที่จังหวัดระยอง - GC ร่วมกิจกรรมประเพณีทำบุญข้ามหลาม ประจำปี 2566 พื้นที่ 4 เขตเทศบาล (เทศบาลเมืองมาบตาพุด เทศบาลเมืองบ้านฉาง เทศบาลตำบลบ้านฉาง เทศบาลตำบลมาบข่า) 		
	<p>ความเห็นจากที่ประชุม</p> <p>[REDACTED] นมอบ [REDACTED] ข้อ</p> <p>อะไรกับทาง GC</p> <ul style="list-style-type: none"> - เรื่องเกี่ยวกับเด็ก มูลนิธิศุภบุญชูเพื่อเด็กพิเศษ โรงเรียนอริยฐาน อยากให้ทาง GC มีส่วนร่วมในการเข้าไปช่วยเหลือดูแล และอยากให้มีการนำไปพิจารณาครั้งถัดไป <p>[REDACTED]</p> <ul style="list-style-type: none"> - เนื่องจากการมอบทุนครั้งนี้ เป็นการมอบทุนของกลุ่มเหล่าภาคชาตจังหวัดระยอง สังกัดกระทรวงมหาดไทย - ได้มีส่วนร่วมในการเข้าไปทำกิจกรรมกับทางเด็ก มูลนิธิศุภบุญชูเพื่อเด็กพิเศษ และทางโรงเรียนอริยฐาน - โรงเรียนอริยฐาน จังหวัดระยอง ที่ได้มีการทำกิจกรรม โดยได้มีการรวบรวมเงินส่วนตัวเพื่อนำไปทำบุญดังกล่าว - มูลนิธิศุภบุญชูเพื่อเด็กพิเศษมีการเข้าไปร่วมกิจกรรมในนามของกลุ่มพนักงาน GC (รวมพลคนเดือนเกิด) - จะนำข้อเสนอแนะที่ได้รับไปพิจารณาต่อไป <p>[REDACTED]</p> <ul style="list-style-type: none"> - อยากให้ทาง GC เข้าไปมีส่วนร่วมในการพัฒนาพื้นที่สีเขียวของทางวัดคีรีภาวนาราม <p>[REDACTED]</p> <ul style="list-style-type: none"> - ทาง GC ได้มีส่วนร่วมในการเข้าไปทำกิจกรรมของทางวัดคีรีภาวนาราม เช่น การทำกิจกรรมเชิงเกษตรอินทรีย์ - ส่วนในการพัฒนาพื้นที่สีเขียวของทางวัดคีรีภาวนารามนั้น ในส่วนนี้จะมีการพิจารณาเข้าไปทำกิจกรรมเพิ่มเติมในครั้งถัดไป 		

วาระที่ 5: เรื่องอื่นๆ

หัวข้อ	เรื่อง	ผู้รับผิดชอบ	กำหนดเวลา
5.	<p>[REDACTED]</p> <ul style="list-style-type: none"> เรื่องสิ่งแวดล้อม เรื่อง PM2.5 ทาง GC มีวิธีการหรือการดำเนินการอะไรที่จะสามารถช่วยลดมลพิษให้น้อยที่สุด <p>[REDACTED]</p> <ul style="list-style-type: none"> เรื่องการรายงานการเดินเครื่องของโรงงานต่างๆ ที่มีความเห็นเช่นเดียวกับทางคุณเสขสิทธิ์ ว่าควรให้ผู้แทนของแต่ละโรงงานเข้ามามีส่วนร่วมในการรายงานการเดินเครื่องของโรงงานต่างๆ ในที่ประชุม แทนการรายงานผ่านทางระบบออนไลน์ ทั้งนี้เพื่อในกรณีที่ข้อมูลส่งสัย จะได้สามารถสอบถามเพิ่มเติมได้ <p>[REDACTED]</p> <ul style="list-style-type: none"> การรายงานการเดินเครื่องของโรงงานต่างๆ กรณีที่มีประเด็น ให้ทางผู้แทนของโรงงาน รายงานตามที่มีประเด็นนั้นๆ และถ้าในกรณีที่ไม่มีประเด็นก็ให้รายงานตามปกติ <p>[REDACTED]</p> <ul style="list-style-type: none"> เรื่องการสื่อสารในที่ประชุม เช่น ไมโครโฟน ควรปรับปรุงให้มีเสียงที่ฟังชัดเจน การรายงานการเดินเครื่องของโรงงานต่างๆ ให้มีการรายงานตามความเป็นจริงที่เกิดขึ้น เอกสารรายงานการประชุมที่นำเสนอให้ใช้วิธีการส่งผ่านทางออนไลน์ เช่น LINE เป็นต้น เพื่อเป็นการลดการใช้กระดาษ <p>[REDACTED]</p> <ul style="list-style-type: none"> เรื่องเอกสารรายงานการประชุมถ้ามีการส่งผ่านทางออนไลน์นั้น ท่านที่มีอินเทอร์เน็ตจะสามารถใช้ได้ ส่วนท่านที่ไม่มีอินเทอร์เน็ตก็จะไม่สามารถเข้าถึงการใช้งานดังกล่าวได้ ดังนั้นจึงอยากให้มีการใช้เอกสารแบบก่อนหน้าด้วยเช่นกัน เรื่องการรายงานการเดินเครื่องของโรงงานต่างๆ อยากเสนอให้ทางผู้บริหารเข้ามารายงานในที่ประชุม เพื่อชี้แจงข้อมูล <p>[REDACTED]</p> <ul style="list-style-type: none"> ขอขอบคุณที่ได้มีการเสนอแนะประเด็นต่างๆ ในการประชุมครั้งนี้ และบริษัทฯ จะนำมาปรับปรุงในการประชุมครั้งต่อไป 		เพื่อพิจารณา

ปิดการประชุม เวลา 12.00 น.



➤ 25๒

เอกสารสรุปจำนวนคนงานในท้องถิ่น
(ระหว่างเดือน มกราคม-มิถุนายน 2566)



ข้อมูลจำนวนพนักงาน

โรงงาน	จำนวนพนักงานที่มีทะเบียนบ้านอยู่ในจังหวัดของ (คน)			จำนวนพนักงานของแต่ละ Plant (คน)		
	2562	2563	2564	2562	2563	2564
GC7	51	50	45	74	74	69

ที่มา : บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน) เดือนธันวาคม 2564

หมายเหตุ : - เป็นพนักงานตาม Indicator ของแต่ละ Plant

- ไม่นับพนักงานสาย Support เช่น Q-SH, H-8P, TEM, TPX, MCS, BSA

➤ 26ข

เอกสารแผนการลงพื้นที่สำรวจความคิดเห็นประชาชน
ประจำปี 2566



➤ 27 ข

เอกสารจัดตั้งคณะกรรมการความปลอดภัยอาชีวอนามัย
และสภาพแวดล้อมในการทำงาน (คปอ.)/
รายงานกิจกรรมด้านความปลอดภัยตามแบบ จป.(ว)



**เอกสารจัดตั้งคณะกรรมการความปลอดภัยอาชีวอนามัยและ
สภาพแวดล้อมในการทำงาน และรายงานการประชุม
ประจำเดือน (คปอ.)**






คำสั่ง บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)

ที่ กม. 001 / 2566

เรื่อง แต่งตั้งคณะกรรมการความปลอดภัย อาชีวอนามัยและสภาพแวดล้อมในการทำงาน (คปอ.)
ประจำพื้นที่ สายงานสาธารณูปโภค

เพื่อให้เป็นไปตามกฎกระทรวงแรงงาน เรื่อง การจัดให้มีเจ้าหน้าที่ความปลอดภัยในการทำงาน
บุคลากร หน่วยงาน หรือคณะบุคคล เพื่อดำเนินการด้านความปลอดภัยในสถานประกอบกิจการ พ.ศ. 2565
จึงมีคำสั่งดังนี้

ข้อ 1. ให้มีคณะกรรมการความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงาน (คปอ.) ประจำ
พื้นที่ สายงานสาธารณูปโภค ประกอบด้วย



ประธานกรรมการ
สาธารณูปโภค

กรรมการ


กรรมการ
ผลิตภัณฑ์ปิโตรเคมี

กรรมการ
สาธารณูปโภค

กรรมการ
สาธารณูปโภค

กรรมการ
ผลิตภัณฑ์ปิโตรเคมี

7. นายกิตติพงษ์ ประยูรกุลกนก กรรมการ
ผู้จัดการส่วน หน่วยงานผลิตสาธารณูปโภค 1
ผู้แทนนายจ้างระดับบังคับบัญชา
8. นายสุมิตร แสงคำ กรรมการ
Skill Specialist หน่วยงานปฏิบัติการบริหารคลัง รับส่งวัตถุดิบ และผลิตภัณฑ์ปิโตรเคมี
ผู้แทนลูกจ้าง
9. นายสกตวรธรณ์ เพื่อนขวัญ กรรมการ
Senior Operator หน่วยงานปฏิบัติการบริหารคลัง รับส่งวัตถุดิบ และผลิตภัณฑ์ปิโตรเคมี



กรรมการ
วัตถุดิบ และผลิตภัณฑ์ปิโตรเคมี

กรรมการ

กรรมการ

บำรุงรักษาสาธารณูปโภค

กรรมการ

บำรุงรักษาสาธารณูปโภค

กรรมการ

gement

กรรมการและเลขานุการ

สิ่งแวดล้อม สายงานสาธารณูปโภค


ข้อ 2. ให้คณะกรรมการฯ มีอำนาจหน้าที่ ดังนี้

1. จัดทำนโยบายด้านความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงานของ สถานประกอบกิจการ เสนอต่อนายจ้าง
2. จัดทำแนวทางการป้องกันและลดการเกิดอุบัติเหตุ การประสบอันตราย การเจ็บป่วยหรือ การเกิดเหตุเดือดร้อนรำคาญอันเนื่องมาจากการทำงานของลูกจ้าง หรือความไม่ปลอดภัยในการทำงานเสนอต่อนายจ้าง

3. รายงานและเสนอแนะมาตรการหรือแนวทางปรับปรุงแก้ไขสภาพการทำงานและสภาพแวดล้อมในการทำงานให้เป็นไปตามกฎหมายเกี่ยวกับความปลอดภัยในการทำงานต่อนายจ้างเพื่อความปลอดภัยในการทำงานของลูกจ้าง ผู้รับเหมา และบุคคลภายนอกที่เข้ามาปฏิบัติงาน หรือเข้ามาใช้บริการในสถานประกอบกิจการ
4. ส่งเสริมและสนับสนุนกิจกรรมด้านความปลอดภัยในการทำงานของสถานประกอบกิจการ
5. พิจารณาคู่มือว่าด้วยความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงานของ สถานประกอบกิจการเพื่อเสนอความเห็นต่อนายจ้าง
6. สำรวจการปฏิบัติการด้านความปลอดภัยในการทำงานและรายงานผลการสำรวจดังกล่าวรวมทั้งสถิติการประสบอันตรายที่เกิดขึ้นในสถานประกอบกิจการนั้นในการประชุมคณะกรรมการความปลอดภัยทุกครั้ง
7. พิจารณาโครงการหรือแผนการฝึกอบรมเกี่ยวกับความปลอดภัยในการทำงาน รวมถึงโครงการหรือแผนการอบรมเกี่ยวกับบทบาทหน้าที่ความรับผิดชอบในด้านความปลอดภัยของลูกจ้างหัวหน้างาน ผู้บริหาร นายจ้าง และบุคลากรทุกระดับเพื่อเสนอความเห็นต่อนายจ้าง
8. จัดวางระบบให้ลูกจ้างทุกคนทุกระดับมีหน้าที่ต้องรายงานสภาพการทำงานที่ไม่ปลอดภัยต่อนายจ้าง
9. ติดตามผลความคืบหน้าเรื่องที่เสนอต่อนายจ้าง
10. รายงานผลการปฏิบัติงานประจำปี รวมทั้งระบุปัญหา อุปสรรค และข้อเสนอแนะในการปฏิบัติหน้าที่ของคณะกรรมการความปลอดภัยเมื่อปฏิบัติหน้าที่ครบหนึ่งปีเสนอต่อนายจ้าง
11. ประเมินผลการดำเนินงานด้านความปลอดภัยในการทำงานของสถานประกอบกิจการ
12. ปฏิบัติงานด้านความปลอดภัยในการทำงานอื่นตามที่นายจ้างมอบหมาย

ทั้งนี้ ตั้งแต่วันที่ 1 กุมภาพันธ์ พ.ศ. 2566 เป็นต้นไป จนครบกำหนดตามวาระในวันที่ 31 มกราคม พ.ศ. 2568 หรือจนกว่าจะมีคำสั่งทดแทน

ตั้ง ณ วันที่ 25 มกราคม พ.ศ. 2566



รายงานกิจกรรมด้านความปลอดภัยตามแบบ จป.(ว)



แบบรายงานผลการดำเนินงานของเจ้าหน้าที่ความปลอดภัยในการทำงานระดับวิชาชีพ

เขียนที่ บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)
วันที่ 17 เดือน มกราคม พ.ศ. 2566

ข้าพเจ้า นายเสขสิริ ปิยะนาท

ตำแหน่ง ผู้ช่วยกรรมการผู้จัดการใหญ่ สายงานคุณภาพ ความปลอดภัย

สถานประกอบการชื่อ บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน) สาขาที่ 7 ท่าเทียบเรือและคลังผลิตภัณฑ์

ประเภทกิจการ ทำเทียบเรือและคลังผลิตภัณฑ์

ตั้งอยู่เลขที่ 19 หมู่ที่ - ถนน โรงป๋วย นิคมอุตสาหกรรมมาบตาพุด ตำบล/แขวง มาบตาพุด

อำเภอ/เขต เมือง จังหวัด ระยอง รหัสไปรษณีย์ 21150

โทรศัพท์ 092-2485464


ขอรายงานผลการดำเนินงานของเจ้าหน้าที่ความปลอดภัยในการทำงานระดับวิชาชีพของ

นายสหพร บุญกันหนัด เลขทะเบียนเลขที่ กสร.จป.ว 221-003776 ในรอบ 6 เดือนตามปฏิทิน ดังต่อไปนี้

☐ รายงานครั้งที่ 1 วันที่ 1 มกราคม - วันที่ 30 มิถุนายน พ.ศ. 2565☒ รายงานครั้งที่ 2 วันที่ 1 กรกฎาคม - วันที่ 31 ธันวาคม พ.ศ. 2565

- 1 ตรวจสอบและเสนอแนะให้นายจ้างปฏิบัติตามกฎหมายว่าด้วยความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงาน (ตามเอกสารแนบ 1)
- 2 วิเคราะห์งานเพื่อชี้บ่งอันตราย รวมทั้งกำหนดมาตรการป้องกัน และขั้นตอนการทำงานอย่างปลอดภัยเสนอต่อนายจ้าง (ตามเอกสารแนบ 2)
- 3 ประเมินความเสี่ยงด้านความปลอดภัย อาชีวอนามัยและสภาพแวดล้อมในการทำงาน (ตามเอกสารแนบ 3)
- 4 วิเคราะห์แผนงานหรือโครงการ และข้อเสนอแนะของหน่วยงานต่างๆ และเสนอแนะมาตรการความปลอดภัยในการทำงานต่อนายจ้าง (ตามเอกสารแนบ 4)
- 5 ตรวจสอบประเมินการปฏิบัติงานของสถานประกอบการให้เป็นไปตามแผนงานโครงการหรือมาตรการความปลอดภัยในการทำงาน (ตามเอกสารแนบ 5)
- 6 แนะนำให้ลูกจ้างปฏิบัติตามคู่มือว่าด้วยความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงานของสถานประกอบการ (ตามเอกสารแนบ 6)
- 7 แนะนำ (ตามเอกสารแนบ 7)

จากเหตุอันจะทำให้เกิดความไม่ปลอดภัยในการทำงาน



แบบรายงานผลการดำเนินงานของเจ้าหน้าที่ความปลอดภัยในการทำงานระดับวิชาชีพ

เขียนที่ บริษัท พีทีที โกลบอล เคมิคอล จำกัด(มหาชน)

วันที่ 17 เดือน มกราคม พ.ศ. 2566

รายงานคุณภาพ ความปลอดภัย

สถานประกอบกิจการชื่อ บริษัท พีทีที โกลบอลเคมิคอล จำกัด (มหาชน) สาขาที่ 7 ท่าเทียบเรือและคลังผลิตภัณฑ์

ประเภทกิจการ ท่าเทียบเรือและคลังผลิตภัณฑ์

ตั้งอยู่เลขที่ 19 หมู่ที่ - ถนน โรงป้อน นิคมอุตสาหกรรมมาบตาพุด ตำบล/แขวง มาบตาพุด

อำเภอ/เขต เมือง จังหวัด ระยอง รหัสไปรษณีย์ 21150

โทรศัพท์ 092-2485464

ขอรายงานผลการดำเนินงานของเจ้าหน้าที่ความปลอดภัยในการทำงานระดับวิชาชีพของ

นายสหพล บุญกำเนิด เลขทะเบียนเลขที่ กสร.จป.ว 221-003776 ในรอบ 6 เดือนตามปีปฏิทิน ดังต่อไปนี้

☐ รายงานครั้งที่ 1 วันที่ 1 มกราคม - วันที่ 30 มิถุนายน พ.ศ. 2565☒ รายงานครั้งที่ 2 วันที่ 1 กรกฎาคม - วันที่ 31 ธันวาคม พ.ศ. 2565

- 1 ตรวจสอบและเสนอแนะให้นายจ้างปฏิบัติตามกฎหมายว่าด้วยความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงาน (ตามเอกสารแนบ 1)
- 2 วิเคราะห์งานเพื่อชี้บ่งอันตราย รวมทั้งกำหนดมาตรการป้องกัน และขั้นตอนการทำงานอย่างปลอดภัยเสนอต่อนายจ้าง (ตามเอกสารแนบ 2)
- 3 ประเมินความเสี่ยงด้านความปลอดภัย อาชีวอนามัยและสภาพแวดล้อมในการทำงาน (ตามเอกสารแนบ 3)
- 4 วิเคราะห์แผนงานหรือโครงการ และข้อเสนอแนะของหน่วยงานต่างๆ และเสนอแนะมาตรการความปลอดภัยในการทำงานต่อนายจ้าง (ตามเอกสารแนบ 4)
- 5 ตรวจสอบการปฏิบัติงานของสถานประกอบกิจการให้เป็นไปตามแผนงานโครงการหรือมาตรการความปลอดภัยในการทำงาน (ตามเอกสารแนบ 5)
- 6 แนะนำให้ลูกจ้างปฏิบัติตามคู่มือว่าด้วยความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงานของสถานประกอบกิจการ (ตามเอกสารแนบ 6)
- 7 แนะนำ ฝึกสอน และอบรมลูกจ้าง เพื่อให้การปฏิบัติงานปลอดภัยจากเหตุอันจะทำให้เกิดความไม่ปลอดภัยในการทำงาน (ตามเอกสารแนบ 7)

- 8 ตรวจสอบและประเมินสภาพแวดล้อมในการทำงานหรือค่านิยม การร่วมกันบุคคลหรือนิติบุคคลที่ขึ้นทะเบียน หรือได้รับใบอนุญาตตามกฎหมายว่าด้วยความปลอดภัย อาชีวอนามัยและสภาพแวดล้อมในการทำงานหรือกฎหมายอื่นที่เกี่ยวข้อง (ตามเอกสารแนบ 8)
- 9 เสนอแนะก่อนยื่นแจ้งเพื่อให้มีการจัดการด้านความปลอดภัยในการทำงาน ที่เหมาะสมกับผลการประกอบกิจการ และพัฒนาให้มีประสิทธิภาพอย่างต่อเนื่อง (ตามเอกสารแนบ 9)
- 10 ตรวจสอบหาสาเหตุ และวิเคราะห์การประสบอันตราย การเจ็บป่วย หรือการเกิดเหตุเดือดร้อนรำคาญอันเนื่อง จากการทำงาน และรายงานผลการตรวจสอบ รวมทั้งเสนอแนะแนวทางแก้ไขปัญหาด้านนายจ้างเพื่อป้องกันการเกิดเหตุโดยไม่ชักช้า (ตามเอกสารแนบ 10)
- 11 รวบรวมสถิติ วิเคราะห์ข้อมูล จัดทำรายงาน และข้อเสนอแนะเกี่ยว กับการประสบอันตราย การเจ็บป่วย หรือการเกิดเหตุเดือดร้อนรำคาญอันเนื่อง จากการทำงานของผู้จ้าง เสนอต่อนายจ้าง (ตามเอกสารแนบ 11)
- 12 ให้ความรู้และอบรมด้านโรคจากการประกอบอาชีพและสิ่งแวดล้อมแก่ลูกจ้างก่อนเข้างาน และระหว่างทำงาน เพื่อทบทวนความรู้อย่างน้อยปีละหนึ่งครั้ง (ตามเอกสารแนบ 12)
- 13 ปฏิบัติงานด้านความปลอดภัยในการทำงาน เหนือตามที่นายจ้างมอบหมาย

[Redacted Signature]

(นายจ้าง)/ผู้รายงาน


[Redacted Signature]

(ขอ.ระดับวิชาชีพ)/ผู้จัดทำรายงาน

➤ 28ข

เอกสารการทำ **Pipe to Soil Potential Survey** ตรวจสอบ
ระดับแรงดันไฟฟ้าที่ใช้ป้องกันการผุกร่อน
(**Cathodic Protection System**)





aurecon

Document control record

Document prepared by:

Aurecon Consulting (Thailand) Co Ltd
Pakia Building, 11th Floor, Unit 1101
9 Ratchadapisek Road
Kwang Dindaeng
Khet Din Daeng
Bangkok 10410
Thailand

T +662 333 3222
F +662 333 3233
E bangkok@aurecongroup.com
W aurecongroup.com

A person using Aurecon documents or data excepts the risk of:
a) Using the documents or data in electronic form without requesting and checking them for accuracy against the original hard copy version.
b) Using the documents or data for any purpose not agreed to in writing by Aurecon.

Document control							aurecon						
Report title		Investigation report											
Document code		Project number		505284									
File path		H:\aurecon\group\an\report\com\deliber002548\Decker Assessment and Test\Report\Site investigation - Scientific Audio Calibration Production (SACP) System at GC OTF Plant Rev 1.docx											
Client		SC Maintenance and Engineering Co., Ltd.											
Client contact		Khun Narongjorn											
Rev		Date		Revision details/status		Author		Reviewer		Verifier of release		Approver	
0		2012-09-03		Draft		PW		OW		UK		SC	
1		2019-09-25		Issued to client		PW		OW		UK		SC	

Contents

1	Introduction	5
1.1	General	5
1.2	Background	5
1.3	Scope of work	5
1.3.1	Phase 1 - SACP System Inspection	7
1.3.2	Phase 2 - Current Drainage Test (CDT)	7
1.4	Abbreviations	7
2	Standards and Protection Criteria	8
3	Methodology	8
3.1	AC potential measurements	8
3.2	Visual inspection	8
3.3	Current output measurements	8
3.4	Soil resistivity measurement	8
3.5	Insulating flanges test	8
3.6	CP potential reading	10
3.7	Current drainage test (CDT)	10
3.8	Test limitations at site and methodology for CP potential reading	12
4	Results and Discussion	13
4.1	Insulating flange testing	13
4.2	Soil resistivity	14
4.3	AC potential measurement	14
4.4	CP system inspection and testing	15
4.4.1	Visual inspection	15
4.4.2	SACP anode current output and anode open potential measurement	15
4.4.3	CP potential reading	16
4.4.4	Current drainage test (CDT)	19
4.4.5	Estimation of current requirements	19
4.5	CP system retrofit concept	21
5	Conclusion and Recommendations	21
5.1	Conclusion	21
5.2	Recommendations	22
Appendices		
Appendix A	Installation details of CDT	
Appendix B	Site data tables and Photographic record	
Appendix C	Plot plan drawings	

Figures

- Figure 1: BTF plant overview
- Figure 2: Potential measurement to assess effectiveness of insulating flange
- Figure 3: Insulation checker to assess effectiveness of insulating flange
- Figure 4: Structure to electrolyte potential measurement
- Figure 5: Diagram of the CDT temporary ICCP system
- Figure 6: Soil resistivity results
- Figure 7: CP potential readings between 1st CP baseline potential and 2nd CP shill results of TPs

Tables

- Table 1: The summary of existing SACP systems of GCT BTF plant
- Table 2: Abbreviations
- Table 3: Equipment list for CDT test
- Table 4: Electrically shunted IF results
- Table 5: Test post (TP) inspection

1 Introduction

1.1 General

The buried metallic pipelines of the GC7 BTF plant have a Sacrificial Anode Cathodic Protection (SACP) system installed to provide protection from corrosion. This SACP system was known to have the following issues:

- CP under-protection of underground pipelines
- Uneven CP protection levels within the plants
- Electrically shorted insulating flanges

Aurcon has been engaged by GOMÉ (GC7 BTF plant's project management) to conduct a comprehensive inspection and performance survey of the existing CP system with the objectives below:

- To inspect and assess the current condition and protection levels provided by the existing SACP system.
- To identify any deterioration of the existing SACP system.
- To identify hot spot areas where the existing SACP system cannot protect the underground pipelines
- To obtain the necessary parameters for CP retrofit design (i.e. soil resistivity and CP current requirement).
- To provide recommendations for a maintenance plan

1.2 Background

GC7 BTF plant is a storage tank farm located in Map Ta Phut, Rayong, as per Figure 1.




Figure 1: BTF plant overview

Based on documents provided by GC7 BTF, the summary of the existing SACP systems is shown in Table 1.

Table 1: The summary of existing SACP systems at GC7 BTF plant

System area	Upstream	PW in BTF plant	TTP / BRE / NPC	Butane Tank T-6382
Protected pipes	▪ 8" hot water pipeline ▪ 4" Propylene pipeline	▪ PW pipeline ▪ 5" A56360 ▪ 4" IF	▪ Gas pipelines ▪ 5" A56360 ▪ 4" IF ▪ 10TF	▪ PW (new) pipeline ▪ PW (existing) pipeline
CP type	SACP	SACP (anode directly welded to pipeline)	SACP	No information
Anode type	Magnesium anode	Magnesium anode	Magnesium anode	Magnesium anode
Installation year	1988 (29 years ago)	1988 (29 years ago)	1983 (25 years ago)	2006 (11 years ago)
TB / TP no.	12	.	18	1
IF no.	4	29	Approx. 8	To be confirmed
Pipe length	2.75 km	In BTF plant	3.65 km	In BTF plant

Notes:

As found at site, there are aboveground facilities for CP inspection and testing as below:

- Test post: 13 TPs
- Insulating flanges: 38 IFs

1.3 Scope of work

The following scope of CP inspections was performed:

- Attend safety induction and obtain contractor badges and Equipment inspection
- Kick off meeting with stakeholders to brief the overview of work
- Visual inspection and photographic record of aboveground CP facilities
- CP Potential reading at:
 - 13 test posts (TPs) of CP potential reading (as found)
 - 38 IFs
- AC potential reading of 81 test points
- Isolation testing of 68 insulating flanges (IFs)
- Sacrificial anode current output measurement (at test posts as available)
- Soil resistivity tests at 3 selected locations
- Current drainage test (CDT)
- Potential reading at 81 test points after energisation of temporary ICCP system
- Reporting and presentation of results
- Basic CP fundamentals session

3.5 Insulating flanges test

This test was conducted to check the effectiveness of insulating flanges at the transition zone between the aboveground and underground pipes.

Test was conducted using 2 methods;

Method

Measure the ON and Instant Off potential of the aboveground side and belowground side of the ranges against portable reference electrode with a voltmeter as shown in the Figure 2 below>Error! Reference source not found". if the ON potential or Instant Off potential reading between the two ranges is more than 130mV difference the insulating flange is deemed to be effective. If less than 100mV, other methods must be used to confirm the effectiveness of IF.




Figure 2: Potential measurement to assess effectiveness of insulating flange

Method 2:

Foundation test using an IF checker at 14000 and bolt/nut as shown in Figure 3.

- Apply the flexible probe to one side and fix the probe to the other side of the flange, ensuring that the probe break through any paint or coating that may be present.
- Press and hold the "TEST" button.




Figure 3: Insulation checker to assess effectiveness of insulating flange

U.S. House of Representatives, Washington, D.C. 20515-5001

3.5 CP potential reading

The "ON" and "Instant OFF" potentials were measured by using a high input impedance volt meter (MC Miller model L04.5) with respect to a Borin Steth.3 portable Cu/CuSO₄ reference electrode (CSE) as shown in Figure 4. Error: Reference source not found..




Figure 4: Structure to electrolyte potential measurement

SOURCE: President's Council on Environmental Quality, AWE, 1994.

3.7 Current drainage test (CDT)

The current drainage test was conducted to assess the amount of CP current required to protect the water/ground pipeline sections. The temporary ICCP system for the CDT was designed and installed as follows:

Refer to Table 3 below for equipment list and diagram of the CDT temporary CCP system in Figure 5:

Table 3: Equipment list for CDT test

1	DC power source; Transformer resistor unit (TRU)	AC 330V, DC 75V/75A	1 Unit
2	Current Interrupter	As built current Interrupter in TRU or Portable current Interrupter 50A model CI-50	1 Unit
3	Anode bed	ICCP Anode catheter with anode cable tail Active length and anode size 1.52m, 0.076m diameter	4 Anodes
4	Feeder positive cable	CV cables minimum 14mm ² size with 50m length	1 Cable
5	Negative cable	CV cables minimum 35mm ² size with 15m length	3 Cables
6	AC power cable	As per TRU specification	1 Set
7	Miscellaneous	Cable lugs, PVC tape, bolt, nut, fitting and temporary barricade (if required)	1 Set




Figure 5: Diagram of the CDT temporary ICCP system

For installation details refer to the Drawing in Appendix A.

Four (4) sacrificial MMO anodes were installed at a depth of 6m at Location T-5045A which has the lowest soil resistivity (refer to Section 4.2). After installation, the CDT temporary ICCP system was run at maximum output (41V/5A) allowing to polarize the underground structures for 3 days.

ON and Instant Off potentials at selected test boxes and insulating flanges were taken after 3 days with the temporary ICCP system interrupted at 12sec ON/ 3sec OFF interval. Polarisation was then calculated and used to estimate the minimum current required for the CP retrofit in future.

Polarisation = Instant Off potential prior to CDT - Instant Off potential after CDT

The following equations from the reference book; "Cathodic Protection Survey Procedures, Second Edition" were used to estimate the CP current required for the CP retrofit.

current necessary to meet the 100-mV/criterion:

$$I_{req} = \frac{(E_{off} - E_{cath})}{(E_{off} - E_{min})} \times I_{on} \quad (6.6)$$

where
 I_{req} current required to achieve -100-mV/criterion (amps)
 E_{cath} active structure-to-electrolyte potential (millivolts)
 E_{off} Instant Off (polarized) structure-to-electrolyte potential (millivolts)
 E_{min} test current applied for E_{off} (amps)

Note: Include polarity of potential readings.
 6.2.2 Equation (6.7) can approximate the current necessary to meet the 100-mV/criterion from the temporary test current:

$$I_{req} = \frac{(-100 \text{ mV})}{(E_{off} - E_{min})} \times I_{on} \quad (6.7)$$

where
 I_{req} current required to achieve the 100-mV/criterion (amps)
 E_{off} Instant Off (polarized) structure-to-electrolyte potential (millivolts)
 E_{min} active structure-to-electrolyte potential (millivolts)
 I_{on} test current applied for E_{off} (amps)

Note: Include polarity of potential readings.

3.8 Test limitations at site and methodology for CP potential reading

This section summarises the test limitations due to site conditions which may directly or indirectly impact the accuracy of test results and complexity of testing:

- True "OFF" potential readings:
 - Where the anode is unable to be disconnected due to being directly welded to U/G pipes no "OFF" potential reading was taken. Only ON potential readings were taken.
 - The existing SACP systems do not have a synchronous interruption function. Therefore for "Instant OFF" survey potential readings, individual anode cables were disconnected manually to obtain the "OFF" potential. The readings could be affected by the directly welded anodes and other anodes from adjacent test points, which remained connected.
 - Concrete areas and concrete pits affected potential reading results when placing the portable reference electrode.

There were no monitoring test holes provided to allow portable CSE to contact the natural soil at test box or selected test points. Therefore, at concrete slab area, a wet sponge was attached to the portable CSE tip for CP potential reading. The presence of reinforced concrete will affect results.

- If JFs are not working, mixed potentials would be obtained showing incorrect protection levels (potentials).
- Soil resistivity
 - Soil resistivity testing was performed using the four-pin Wenner method. It is important that the four metallic pins placed into the soil are equally spaced and in a straight line. The actual test locations and pin spacings were decided on site by the CP tester.
 - Soil resistivity tests can be affected by presence of buried metallic assets such as pipelines, earthing systems or concrete foundations. Whilst care was taken to select test locations, unknown assets could be present or separation to known assets insufficient due to space constraints.
- Current drainage test
 - All underground structures that are connected to the temporary CDT ICCP system are assumed to be electrically continuous. Pipes that are not electrically continuous with ICCP system would not receive CP protection current.
 - If electrical shorts and stray currents may impact the potential readings in overall plant.
 - CP interference / stray current test report from other areas was not recorded or available.

4 Results and Discussion

This section summarises and discusses the results obtained from site work.

4.1 Insulation flange testing

From site inspection results, it was found that 12 of 66 (17%) insulating flanges (IFs) were electrically shorted. This would cause a reduction in protection levels and that the anodes to have shorter life due to CP current loss to other underground structures; e.g. a large group of ground rods, pipe rack foundations etc.

The following shorted IFs are listed in Table 4, and full details of the inspection are included in Table 2 of Appendix B.

Table 4: Electrically shorted IF results

IF		Notes	Result
1	IF2	Refer to Drawing no. 200284-C-001	FW
2	IF4		FW
3	IF22		FW
4	IF23		FW
5	IF25		Unknown
6	IF28		FW
7	IF32		FW
8	IF58		FW
9	IF57		FW
10	IF48		FW
11	IF49		FW
12	IF62		FW

The possible root causes of electrically shorted IFs are:

- Damaged IF kits (e.g. gasket, sleeve and washer components) due to severe environments e.g. UV, moisture, chemical, seawater, plant aging and mechanical force
- The IF kits were not properly installed i.e. due to incorrect size and materials etc. at:
 - IF24
 - IF53
 - IF54
- Some spark gap parts e.g. plastic covers etc. were damaged as per Table 2 of Appendix B.
- Rust product from severe corrosion at the IF pipe flanges form a conductive bridge between the gap, causing an electrical short
- Zinc-rich paint applied in between IF gap
- Lack of maintenance

4.2 Soil resistivity

Soil resistivity test results are provided in Figure 6 (Error! Reference source not found.). Full results are provided in Table 3 of Appendix B.




Figure 6: Soil resistivity results

Calculations and graphs from the 3 test locations show that:

- The overall soil resistivity in the plant is not homogenous or non-uniform, depending on the area
- The soil resistivity at Location T-0345A was high at 1m depth and is significantly lower at 2m to 10m depths
- The soil resistivity at Location 0-FA011F is low and more uniform at different soil depths compared to the other locations.
- Suitable soil resistivity can be found below 5-10m depth.

4.3 AC potential measurement

The AC potentials measured at the CP test facilities prior to performing any CP testing were found to be less than 15V AC versus portable CSE. Refer to Table 1 and 2 of Appendix B for the test post (TPs) and insulating flanges (IFs) test results.

Therefore, it is concluded that the CP system test facilities are safe for the CP tester to touch during the inspection period.

For safety reasons PPE must be used during testing.

4.4 CP system inspection and testing

4.4.1 Visual inspection

The findings from the visual inspection are summarised below. Full details and photographic record are provided in Appendix B:

- Test posts (TPs):
 - Tag and cable labels were missing or not installed
 - Test post components were damaged or broken
 - Corrosion and dirt were observed inside test posts
 - Monitoring test holes through concrete pavement were not installed
- Selected test points at insulation flanges (IFs):
 - IF lot not suitable, air gap at gasket between both flanges
 - Some spark gaps were not installed, and some were broken
 - Coating was damaged at both flanges and flanges were corroded
 - Flanges were installed too close to ground level

The possible root causes of above items could be:

- General plant is aging in conjunction with an aggressive environment e.g. chemical pollution, marine environment etc.
- Incorrect maintenance
- Lack of maintenance

4.4.2 SACP anode current output and anode open potential measurement

The anode current output and open circuit potential vs CSE at some test posts were found to be inadequate. Refer to Table 5.

The SACP current ranged between 0.01 – 0.12A and the anode open potential vs CSE was between -495mV to -1548mV. This is an insufficient level according to Magnesium Anode specification from the manufacturer or standard AS 2239-2003 page 19 (magnesium anode open circuit potential is typically at -1500 mV to -1600mV vs CSE).

The low anode current output is likely due to the magnesium anodes being almost or fully consumed as they are likely to have reached end of the CP design life or have been prematurely depleted as a result of shorted insulating flanges.

Table 5: Test post (TP) inspection

TP1 / TPC	PVC	N/A	-1,307
TP2 / TPC		N/A	-1,295
TP3 / TPC		≈ 0.03	-905
TP4 / IF38	Aluminium	≈ 0.12	-1,441
TP5 / TP 5 APEX		≈ 0.05	-1,300
TP6 / TP 2 APEX		≈ 0.01	-495

TP7 / TP 3 APEX	N/A	N/A	Cables may have been cut
TP8 / TP 4 APEX	≈ 0.03	-1,213	
TP9 / TP 5 APEX	N/A	N/A	Cables may have been cut
TP10 / TP 6 APEX	≈ 0.02	-900	
TP11 / IF31	≈ 0.01	-666	
TP12 / IF30	≈ 0.01	-666	
TP13 / EDC	N/A	-1,548	

The full inspection details are provided in Table 1 of Appendix B.

4.4.3 CP potential reading


Potential reading was conducted twice:

- 1st Potential reading prior to the CDT to obtain the base line On and Instant Off potentials
- 2nd Potential reading after the CDT to obtain the polarisation shift

The mapping of CP potential level for base line potential is in Drawing CP-001 of Appendix C.

The CP potential reading results are illustrated by the graph in Figure 7.

- The 1st Potential readings are given in the base line potential graph (Blue line) and indicate:
 - 75 test points (92%) are significantly underprotected (less negative than -850mV)
 - 5 test points (7%) achieved the CP protection criterion (more negative than -850mV) at IF28, IF29, IF50, IF61 and IF62
 - 1 test point (1%) is overprotected (more negative than -1200mV) at IF64
 - Maximum potential: -1218mV at IF61
 - Minimum potential: -395mV at TP10
- 2nd Potential readings after the CDT are given in the CP shift potential graph (Yellow line):
 - 72 test points (89%) remain significantly underprotected (less negative than -850mV)
 - 8 test points (10%) achieved CP protection (more negative than -850mV) at IF4, IF28, IF29, IF47, IF51, IF60, IF61 and IF62
 - 1 test point (1%) is overprotected (more negative than -1200mV) at IF64
 - Maximum potential: -1209mV at IF61
 - Minimum potential: -417mV at IF25



The possible root causes of underprotection are a result of:

- The likely depletion of the existing SACP system.
- Coating deterioration as a result of aging plant and
- Accelerated anode consumption / Increased current demand as a result of shorted insulating flanges which causes:

- Loss of current to earthing systems
- Mixed potentials between shorted pipelines and earthing systems.

The possible root causes of overprotection could be attributed to:

- New localised galvanic anodes having been installed recently (as advised by BTF team) which are directly bonded to underground product pipelines. It is therefore likely that the potential reading at IF64 was an ON potential between anode and pipeline (indicating an IR drop) and not a true "OFF" pipe potential. (Refer to Section 3.3.)
- Stray current from unknown adjacent CP sources e.g. adjacent plant which might interfere at this test point (unlikely as the location is control to BTF Plant).
- There are some test points which did not receive any or insufficient current from the temporary CDT ICCP system, indicated by no potential change during ICCP system interruption cycles ON and OFF. Most of these pipes are product pipes such as air, treated water, and EDC pipes.

The possible root causes are:

- These pipes are being electrically isolated from the main pipeline network. Therefore, bond cables are required to connect with the main pipeline networking.
- These pipelines are shorted to plant earthing, thus not receiving sufficient protective current to shift the potential.
- Moreover, there are 19 test points listed below with positive potential shift during CDT (CP protection level reduced)
- TP1, TP2, TP3, TP13, IF24, IF28, IF29, IF30, IF38, IF43, IF44, IF53, IF54, IF55, IF57, IF60, IF62, IF63 and IF64

The possible root causes are:

- The pipes at these IFs and TPs are not electrically continuous to the temporary CDT ICCP system and did not receive protection current
- The SACP system was disconnected at all test points prior to the CDT test leading to depolarisation
- These sections of pipeline are disconnected from the pipelines bonded into the trial and were therefore affected by stray current adverse effects.

4.4.4 Current drainage test (CDT)

CDT results from Table 4 and Table 6 of Appendix B are summarized below:

- The output of the system was limited to 5A/41V as soil resistivity is high.
- Significant polarization shift (> 100mV) was only found at IF47 to IF49 near the anode bed location
- Maximum potential shift from base line: 353mV at IF47
- Minimum potential shift from base line: 7mV at IF5

The plot plan (coloured legend) for potential shift is given in Drawing CP-002 of Appendix C.

The following can be concluded from the CDT results:

- A large number of the buried pipes within the plant is not electrically continuous with the main network pipelines and therefore did not received any protection during the CDT (refer Section 4.4.3). Those pipes will need to be made electrically continuous during the CP retrofit in future.
- A significant amount of CP protection current is presently lost due to faulty electrical insulating flanges. A large amount of CP current will be required to protect all pipes and to accommodate this current loss.

4.4.5 Estimation of current requirements

It must be understood that the following estimates are based on field data and include two significant unknown variables:

1. Amount of current required to protect all pipes including all pipes currently not presently bonded into the system.
2. Amount of current which might not be required, if insulating flanges were in working order.

The current estimation using the following equations as per Section 3.7:

$$I_{req} = \frac{E_c - 100mV}{(P_{ind} - P_{un})} \times I_{CDT} \quad (1)$$

$$I_{req} = \frac{E_c - 950 - P_{un}}{(P_{ind} - P_{un})} \times I_{CDT} \quad (2)$$

$$I_{req} = \text{Current requirement (A)}$$

$$I_{CDT} = \text{Current output for CDT (A)}$$

$$P_{un} = 1^{\text{st}} \text{ Potential reading base line potential}$$

$$P_{ind} = 2^{\text{nd}} \text{ Potential reading from CDT test}$$

Two values have been calculated:

1. Current to achieve 100mV polarization
2. Current to achieve -850mV instant off potential.

To assess the risks involved due to the unknowns, the estimation of required CP current to protect the entire plant has been performed using 3 scenarios:

Scenario 1: (Worst Case Scenario) – at TP8 where only 7mV polarization is achieved from the CDT

- To achieve -100mV shift criteria by using equation 1:

$$I_{eq} = \frac{(-100mV) - (-519 - (-512))}{x \ 5A} \quad (3)$$

$$I_{eq} = 71.4A$$

- To achieve -850mV criteria by using equation 2:

$$I_{eq} = \frac{(-850 - (-512)) - (-519 - (-512))}{x \ 5A} \quad (4)$$

$$I_{eq} = 241.4A$$

The significant amount of current required to protect the structure at TP8 by single point anode bed which it is likely overestimated due to the structure being electrically shorted to other structure e.g. copper earthing and/or this test point being located too far from the temporary anode bed, thus receiving insufficient current due to attenuation.

Scenario 2: (Best Case Scenario) – at IF4, IF5, IF15, IF45, IF47, IF48 and IF49 with average of 245mV polarization achieved. The locations are around the CDT ICCP system anode area.

- To achieve -100mV shift criteria by using equation 1:

$$I_{eq} = \frac{(-100mV) - (-909 - (-564))}{x \ 5A} \quad (5)$$

$$I_{eq} = 2.04A$$

- To achieve -850mV criteria by using equation 2:

$$I_{eq} = \frac{(-850 - (-564)) - (-909 - (-564))}{x \ 5A} \quad (6)$$

$$I_{eq} = 5.83A \approx 6A$$

Using these results would lead to a significant underestimation of the current demand. Therefore, next scenario would be discussed.

Scenario 3: (Average based scenario): This scenario uses the following assumptions which have been made based on the test results:

- a) The temporary anode bed affected approximately at 25% of the overall plant only refer to Drawing CP-002 of Appendix C.
- b) In that achieved area, the 5A output from CDT test would achieve at average typically at 80mV polarization or more.
- c) Approximate polarization shift of 300mV is required to achieve the -850mV criterion from the typical baseline potential is approximate at -550-mV).

On these above bases it can be assumed that the total current required is as calculation steps:

- Step 1: If it would like to achieve 80mV polarization for overall plant (100% = 25% x 4 times), the current demand:

$$5A \times 4 = 20A \quad (7)$$

- Step 2: If it would like to achieve 300mV polarization for overall plant (3.75 times = 300mV / 80mV), the current demand:

$$20A \times 3.75 = 75A \quad (8)$$

As this current demand significantly in resulting material and construction costs then consideration should be given to further narrow the risks in establishing current demand. This could be achieved by the following approach:

1. Install all required bonding between all pipelines to be protected,
2. Repair all faulty insulating flanges and confirm insulation from earthing systems, and
3. Repeat the CDT after tasks 1 and 2 have been completed.

If the above options are not feasible to perform, the retrofit CP system should be designed for a minimum 75A output.

4.5 CP system retrofit concept

It is not practical or recommended to use a single point anode bed. It is further desirable to reduce the total current required to protect the plant due to the following reasons:

- Poor CP current distribution
- Difficult to control and balance the CP protection levels within the plant
- Overprotection highly likely to occur at test points that are located near anode bed
- Space limitation for large anode beds being installed
- Significant savings in materials and installation cost
- Significant reduction of risk of stray current and interference problems

In order to achieve a 75A output and minimize the risks above, a distributed anode bed design should be selected, the concept design drawing is enclosed into Drawing CP-003 of Appendix C.

This is a concept only and shall be confirmed in conjunction with other design factors by a CP designer during the detailed design stage.

5 Conclusion and Recommendations

5.1 Conclusion

From the test results and discussion in Section 4, it can be concluded that;

- The existing SAUP system is inadequate with only 8% of the tested TP/IFs are indicating protected levels.
- A new impressed current CP system is required
- 12 of 88 (17%) insulating flanges (IFs) are found to be electrically shored.
- No unsafe AC voltage exceeding 15V vs CSE was found during the inspection period
- Several issues were identified during the site investigation such as corrosion at the IFs, damaged spark gap, damaged test boxes, no cable labels as summarised in Section 4.1.
- A large number of the buried pipes within the plant are not electrically continuous with main network pipelines and therefore did not receive any protection during the CDT (refer Section 4.4.3). These pipes will need to be made electrically continuous during the CP retrofit in future.
- A significant amount of CP protection current is lost due to the electrical isolation issues to other structures (e.g. to copper earthing).
- The approximate total CP current requirement to boost the protection level is estimated to be 75A.
- Overall, the soil in the plant is not homogeneous. Low resistivities, which are more suitable for anode bed installation, were observed at greater depth (prior to Section 4.2)

5.2 Recommendations

Based on the inspection and test results and the conclusions made in this report, the following recommendations are made:

- Consider additional works of Phase 1 and Phase 2 below, prior to finalising of the detailed design:

a) Phase 1: Electrical Isolation and Continuity Works

- Rectify all the electrical short at the IFs
- Install bond cables for the buried pipes that were found to be not electrically continuous with the main network pipe
- Install additional test points as required

b) Phase 2: Current Drainage Test

- Perform another current drainage test after all the electrical isolation and continuity works are completed

If it is not decided to conduct Phase 1 and 2 additional works, use the following approach:

- Conduct detailed design of a retrofit ICCP system.
- Install bonding cables to bond all insulated pipelines into a single system.
- Repair as many damaged insulating flanges as possible.

- Install the retrofit ICCP system.

- Commission the new ICCP system, including interference testing.

- Rectify all punch lists from visual inspection in Section 4.4.1

- Install a new standard IF kit (Full face type E suite to pipe flange diameter and ANSI data) at:


- IF24, IF53 and IF54

- Repair or replace the broken IFs and sparking gap kits with GC's standard specification as per Table 2 of Appendix B.

- Install a concrete pit at the IFs located close to ground level to prevent moisture or water flooding, which may cause electrical shorting in the long term. An alternative option is to install waterproof wrapping e.g. Densmo wrap product at IF section.

- Nominate permanent test points with monitoring test hole of the entire plant to maintain consistency of potential reading for future monitoring

- Implement six-monthly CP performance surveys to ensure satisfactory operation by third party with NACE trained personnel.



Client: GCME
 Project no: SB5214
 Survey by: CW, PW, SC and AV
 Equipment: Potentiometer - 1044-MC Miller, Portable Cu/SuSO4 reference electrode and Clamp meter - Ampprobe LH414
 Appendix B: Survey Data

Location: DTF plant, Baynes
 Weather Condition: 19th and 20th
 Date of survey: 3-6 July 2018

Legend: ✓ = Yes or Good condition
 ✗ = No or Not good condition
 N/A = Not applicable



Table 1: Test Post CPY inspection, visual inspection findings and SACP potential reading

Test / Test post	ENV	Notes to Drawing no. 503214-CP-001	AC potential reading (mV)		CP potential reading (mV)		Adjusted potential criteria	Anodic current output (A)	Open potential reading (mV)	Free of corrosion at surface coating (1)	Free of residue, water and dirt dust inside box (2)	Free of corrosion inside box (3)	Free of damage at test post (4)	Box lid was not disassembled (5)	Permanent tag label installed at cables (6)	Monitoring that hole was provided (7)	
			AC potential (mV)	AC current (A)	CP potential reading (mV)	CP potential reading (mV)											
TP1 / TP2	ENV		0	0.00	-792	-867	X	N/A	-1307	N/A	✓	✓	✓	✓	✓	✓	
TP3 / TP4	ENV		34	0.01	-505	-580	X	0.03	505	✓	✓	✓	✓	✓	✓	✓	
TP5 / TP 1 APEX	ENV		0	0.00	-654	-615	X	0.05	-1300	✓	✓	✓	✓	✓	✓	✓	No dust seal inside box
TP6 / TP 3 APEX	ENV		0	0.00	N/A	N/A	X	N/A	N/A	✓	✓	✓	✓	✓	✓	✓	Probably, cable has been cut
TP7 / TP 5 APEX	ENV		0	0.01	N/A	N/A	X	0.00	N/A	✓	✓	✓	✓	✓	✓	✓	Probably, cables have been cut
TP8 / TP 11	ENV		5	0.00	-575	-558	X	0.01	-665	✓	✓	✓	✓	✓	✓	✓	
TP9 / TP 11	ENV		5	0.00	-575	-558	X	0.01	-665	✓	✓	✓	✓	✓	✓	✓	
TP10 / TP 11	ENV		0	0.00	-655	-662	X	N/A	-1548	✓	✓	✓	✓	✓	✓	✓	

Notes:
 1. Locations of SACP facilities are referred in Drawing no. 503214-CP-001
 2. Where a 'X' is shown in above table, refer to recommendations work in table below.
 Recommendations works for minor defect from visual inspection:

No	Defect	Recommendation	Remarks
1	Damage at surface coating of test post	1. Aggressive environment from petrochemical plant 2. Inappropriate coating system specification	Remove corrosion product and re-coat with coating specification or higher level
2	Corrosion inside box	Overhaul cable condition was not completely satisfied or damaged by time	Clean to remove all dirt and residue dust seal at cable entry hole and test post
3	Box lid was not disassembled	Not applicable	Install new box lid
4	Box lid was not disassembled	Not applicable	Install new box lid
5	Box lid was not disassembled	Not applicable	Install new box lid
6	Box lid was not disassembled	Not applicable	Install new box lid
7	Box lid was not disassembled	Not applicable	Install new box lid

Appendix B Site data tables and Photographic record

Client: GCME
 Project no.: 506284
 Survey by: CW, PW, SC and AV
 Equipment: Potential meter - UC4.5 MC Miller, Portable Cu/CuSO4 reference electrode and IF Checker M.C. Miller Model 601
 Appendix B:
 Table 2: Insulation flange (IF) testing, visual inspection findings and 1st CP Potential reading

Location: BTP plant, Rayong
 Weather Condition: Rain and hot
 Date of survey: 3-6 July 2015

Legend: ✓ = Yes or Good condition
 X = No or Not good condition
 N/A = Not applicable



				A/G Flange					U/G Flange			Electrical Isolation	IF checker testing		Visual inspection			
				A.C. potential (mV)	+ON ^{CP} CP Potential (mV)	+OFF ^{CP} CP Potential (mV)	A.C. potential (mV)	+ON ^{CP} CP Potential (mV)	+OFF ^{CP} CP Potential (mV)	Achieved project criteria	% Shorted at		Flanges, Bolt and nut	Sparking gap installed	Free of damage or corrosion			
															Flange	Bolt and nut	Sparking gap	
IF22	FW	10	0	-582	-583	0	-588	-585	X	Shorted	100%	-	✓	✓	✓	✓	-	
IF23A	FW	1	53	-489	-489	53	-475	-475	X	Isolated	-	-	✓	✓	✓	✓	Gasket is wider than IF diameter	
IF24	Treated Water	2	0	-599	-599	0	-608	-605	X	Isolated	-	-	✓	✓	✓	✓	-	
IF25	Underflow	2	0	-599	-599	0	-608	-605	X	Isolated	-	-	✓	✓	✓	✓	-	
IF26	FW	2	0	-599	-599	0	-608	-605	X	Isolated	-	-	✓	✓	✓	✓	-	
IF27	FW	17	0	-1176	-1176	0	-1185	-1185	✓	Shorted	100%	-	✓	✓	✓	✓	Installed at low level position	
IF28	FW	12	0	-570	-560	0	-576	-565	X	Isolated	-	-	✓	✓	✓	✓	-	
IF29	FW	12	0	-570	-560	0	-576	-565	X	Isolated	-	-	✓	✓	✓	✓	-	
IF30	FW	12	0	-570	-560	0	-576	-565	X	Isolated	-	-	✓	✓	✓	✓	-	
IF31	FW	12	0	-570	-560	0	-576	-565	X	Isolated	-	-	✓	✓	✓	✓	-	
IF32	FW	10	0	-538	-538	0	-540	-540	X	Shorted	100%	-	✓	✓	✓	✓	Installed at low level position	
IF33	FW	10	0	-553	-553	0	-554	-554	X	Isolated	-	-	✓	✓	✓	✓	-	
IF34	FW	9	0	-553	-553	0	-554	-554	X	Isolated	-	-	✓	✓	✓	✓	-	
IF35	FW	12	26	-509	-508	0	-493	-493	X	Isolated	-	-	✓	✓	✓	✓	-	
IF36	FW	12	0	-573	-573	0	-673	-673	X	Shorted	100%	-	✓	✓	✓	✓	-	
IF37	FW	6	0	-573	-573	0	-673	-673	X	Shorted	100%	-	✓	✓	✓	✓	-	
IF38	FW	22	0	-573	-573	0	-673	-673	X	Shorted	100%	-	✓	✓	✓	✓	-	
IF39	FW	12	0	-573	-573	0	-673	-673	X	Shorted	100%	-	✓	✓	✓	✓	-	
IF40	FW	6	0	-573	-573	0	-673	-673	X	Isolated	-	-	✓	✓	✓	✓	-	
IF41	FW	22	0	N/A	N/A	0	-903	-743	X	Isolated	-	-	✓	✓	✓	✓	-	
IF42	FW	22	0	-510	-557	0	-522	-703	X	Isolated	-	-	✓	✓	✓	✓	-	
IF43	FW	22	0	-510	-557	0	-522	-703	X	Isolated	-	-	✓	✓	✓	✓	-	
IF44	FW	22	0	-510	-557	0	-522	-703	X	Isolated	-	-	✓	✓	✓	✓	-	
IF45	FW	22	0	-568	-624	0	-587	-573	X	Isolated	-	-	✓	✓	✓	✓	-	

Refer to Drawing no. 506284-CF-001

Client: GCME
 Project no.: 506284
 Survey by: CW, PW, SC and AV
 Equipment: Potential meter - UC4.5 MC Miller, Portable Cu/CuSO4 reference electrode and IF Checker M.C. Miller Model 601
 Appendix B:
 Table 2: Insulation flange (IF) testing, visual inspection findings and 1st CP Potential reading

Location: BTP plant, Rayong
 Weather Condition: Rain and hot
 Date of survey: 3-6 July 2015

Legend: ✓ = Yes or Good condition
 X = No or Not good condition
 N/A = Not applicable



ID	Type	Size	Location	A/G Flange						U/G Flange			IF checker testing			Visual inspection			Remarks
				AC Range			U/G Range			Electrical Isolation	% Shorted at		Sparking gap installed	Free of damage or corrosion					
				AC potential (mV)	+ON ^{CP} CP Potential (mV)	+OFF ^{CP} CP Potential (mV)	AC potential (mV)	+ON ^{CP} CP Potential (mV)	+OFF ^{CP} CP Potential (mV)		Achieved project criteria	Flanges		Bolt and nut	Flange	Bolt and nut	Sparking gap		
IF1	FW	6	Refer to Drawing no.506/34-CF-002	30	-645	-645	30	-545	-648	X	Isolated	-	-	X	✓	X	N/A	Blind flange	
IF2	FW	4		40	-525	-525	48	-525	-525	X	Isolated	-	-	X	X	✓	N/A	Blind flange	
IF3	FW	6		0	-559	-559	0	-554	-554	X	Isolated	-	-	✓	X	✓	✓	-	
IF4	FW	12		0	-559	-559	0	-554	-554	X	Isolated	-	-	✓	X	✓	✓	-	
IF5	FW	4		0	-521	-521	0	-521	-519	X	Isolated	-	-	✓	X	X	X	Installed at low level position	
IF6	FW	6		0	-551	-551	0	-551	-551	X	Isolated	-	-	✓	✓	✓	✓	-	
IF7	FW	8		0	-551	-551	0	-551	-551	X	Isolated	-	-	✓	✓	✓	✓	-	
IF8	FW	6		0	-551	-551	0	-551	-551	X	Isolated	-	-	✓	✓	✓	✓	-	
IF9	FW	10		24	-582	-582	24	-570	-579	X	Isolated	-	-	✓	X	X	N/A	Installed at low level position	
IF10	FW	6		0	-581	-581	0	-576	-576	X	Isolated	-	-	✓	X	✓	✓	Installed at low level position	
IF11	FW	10		0	-581	-581	0	-576	-576	X	Isolated	-	-	✓	X	✓	✓	-	
IF12	FW	6		0	-506	-506	0	-507	-507	X	Isolated	-	-	✓	X	X	✓	-	
IF13	FW	6		0	-506	-506	0	-507	-507	X	Isolated	-	-	✓	X	X	✓	-	
IF14	FW	4		0	-553	-553	0	-553	-553	X	Isolated	-	-	✓	X	✓	X	-	
IF15	FW	4		0	-553	-553	0	-553	-553	X	Isolated	-	-	✓	X	✓	X	-	
IF16	FW	12	0	-573	-573	0	-673	-673	X	Shorted	100%	-	✓	✓	✓	✓	-		
IF17	FW	4	0	-573	-573	0	-673	-673	X	Shorted	100%	-	✓	✓	✓	✓	-		
IF18	Air	2	0	-573	-573	0	-673	-673	X	Shorted	100%	-	✓	✓	✓	✓	-		
IF19	FW	10	0	-573	-573	0	-673	-673	X	Shorted	100%	-	✓	✓	✓	✓	-		
IF20	FW	1	0	-585	-585	0	-591	-591	X	Isolated	-	-	✓	X	X	✓	-		
IF21	Threaded wheel	3	0	-576	-576	0	-583	-583	X	Isolated	-	-	✓	X	X	✓	-		
IF22	FW	1	0	-576	-576	0	-583	-583	X	Isolated	-	-	✓	X	X	✓	-		
IF23	FW	-50	15	-578	-578	0	-563	-563	X	Isolated	-	-	✓	X	X	✓	-		

Refer to Drawing no. 506284-CF-001



Station	Time	Water	Water								
Station	Time	Water	Water								
1 T6945A	1.00	354.00	2224.25	0.00	-	-	0m	to	1m	2224.25	Sand area
	2.00	98.20	1109.35	0.01	0.01	117.71	1m	to	2m	738.07	
	3.00	57.80	712.51	0.03	0.02	66.15	2m	to	3m	415.63	
	4.00	16.80	422.23	0.06	0.03	30.24	3m	to	4m	199.00	
	5.00	7.30	279.94	0.14	0.08	22.91	4m	to	5m	81.33	
	10.00	-	-	-	-	-	5m	to	10m	N/A	
	15.00	-	-	-	-	-	10m	to	15m	N/A	
2 0-F8211F Near pond water	1.00	9.81	61.64	0.10	-	-	0m	to	1m	61.64	Sand area
	2.00	5.36	57.36	0.19	0.08	11.82	1m	to	2m	74.24	
	3.00	3.71	69.93	0.27	0.08	12.05	2m	to	3m	75.72	
	4.00	3.03	75.65	0.33	0.06	15.95	3m	to	4m	100.24	
	5.00	2.30	72.26	0.43	0.10	9.75	4m	to	5m	61.27	
	10.00	0.77	48.38	1.30	0.86	1.16	5m	to	10m	36.36	
	15.00	-	-	-	-	-	10m	to	15m	N/A	
3 T694G Under pipe rock	1.00	94.50	593.76	0.01	-	-	0m	to	1m	593.76	Sand area
	2.00	31.60	397.10	0.03	0.02	47.48	1m	to	2m	288.30	
	3.00	9.80	284.73	0.10	0.07	16.71	2m	to	3m	89.26	
	4.00	3.19	80.17	0.31	0.21	4.73	3m	to	4m	29.72	
	5.00	1.58	43.35	0.72	0.41	2.43	4m	to	5m	15.28	
	10.00	-	-	-	-	-	5m	to	10m	N/A	
	15.00	-	-	-	-	-	10m	to	15m	N/A	

3. Locations of SACP facilities are referred in Drawing no. 506284-CP-001

5

aurecon

Legend; ✓ = Yes or Good condition
X = No or Not good condition
N/A = Not applicable



Insulation (Range RF) testing, visual inspection findings and 1st QP Potential reading

S/N	Part Name	Qty	U/S Flange							IF checker testing		Visual inspection			Remarks		
			A/S Gp			U/S Flange			Standard Insulation	% Tested at	Spark gap Insulated	Type of damage or corrosion					
			AC Potential (mV)	"ON" CP Potential (mV)	"OFF" CP Potential (mV)	AC potential (mV)	"ON" CP Potential (mV)	"OFF" CP Potential (mV)				Achieved project criteria	Range	Spot and cut		Range	Spot and cut
IF142	FW	32	0	-795	-156	6	-197	-597	X	Shorted	100%	-	✓	X	X	X	Installed at low level position
IF145	FW	32	0	-795	-156	6	-197	-597	X	Shorted	100%	-	✓	X	X	X	Installed at low level position
IF146	FW	4	0	-795	-156	6	-197	-597	X	Shorted	100%	-	✓	X	X	X	Installed at low level position
IF150	FW	4	0	-795	-156	6	-197	-597	X	Shorted	100%	-	✓	X	X	X	Installed at low level position
IF151	eIV	10	0	-795	-156	6	-197	-597	X	Shorted	100%	-	✓	X	X	X	Installed at low level position
IF152	FW	36	52	-577	-577	43	-577	-577	X	Shorted	100%	-	✓	X	X	N/A	No insulation wash: Installation
IF153	Air	2	0	-576	-576	30	-634	-634	X	Isolated	-	-	✓	X	X	✓	Gasket type is not full face type C
IF154	Air	2	0	-576	-576	30	-634	-634	X	Isolated	-	-	✓	X	X	✓	Gasket type is not full face type C
IF155	Unknown	6	0	-576	-576	30	-634	-634	X	Isolated	-	-	✓	X	X	✓	Gasket type is not full face type C
IF156	As	2	0	-573	-573	31	-563	-533	X	Isolated	-	-	✓	X	X	✓	Gasket type is not full face type C
IF157	Sw	2	0	-573	-573	31	-563	-533	X	Isolated	-	-	✓	X	X	✓	Gasket type is not full face type C
IF158	Propylene	4	0	-593	-593	9	-543	-543	X	Isolated	-	-	✓	X	X	✓	Gasket type is not full face type C
IF159	EDC	4	0	-593	-593	9	-543	-543	X	Isolated	-	-	✓	X	X	✓	Gasket type is not full face type C
IF160	Propylene	4	0	-1057	-1057	0	-234.0	-134.0	✓	Isolated	-	-	✓	X	X	✓	Air gap is at flange gasket
IF161	Butene-1	3	0	-1057	-1057	0	-234.0	-134.0	✓	Isolated	-	-	✓	X	X	✓	Air gap is at flange gasket
IF162	EDC	4	0	-1109	-1109	0	-1008	-1008	✓	Isolated	-	-	✓	X	X	N/A	Installed at low level position
IF163	EDC	4	0	-1109	-1109	0	-1008	-1008	✓	Isolated	-	-	✓	X	X	N/A	Installed at low level position
IF164	Styrene	8	40	-1112	-1112	35	-1220	-1215	X	Isolated	-	-	✓	X	X	✓	Air gap is at flange gasket

4

aurecon

Client: GCME Location: BTF plant, Rayong
 Project no.: S06284 Weather Condition: Hot
 Survey by: CW, PW, SC and AV Date of survey: 19-Aug-19
 Equipment: Potential meter - LC4.5 MC Miller and Portable Cu/CuSO4 reference electrode and IF Checker M.C. Miller Model 505
 Appendix A: Survey Data
 Table 5: CP potential readings between 1st CP baseline potential and 2nd CP shift results of IFs

TRU output	41V / 5A
A1	1.31A
A2	1.22A
A3	1.08A
A4	1.41A



			A/G Range			U/G Range			A/G Range			U/G Range		
			AC potential (mV)	"ON" CP Potential (mV)	"OFF" CP Potential (mV)	AC potential (mV)	"ON" CP Potential (mV)	"OFF" CP Potential (mV)	AC potential (mV)	"ON" CP Potential (mV)	"OFF" CP Potential (mV)	AC potential (mV)	"ON" CP Potential (mV)	"OFF" CP Potential (mV)
TP1	PW	6	20	-645	-642	20	-645	-648	46	-714	-704	46	-674	-664
IF3	PW	6	48	-525	-525	48	-525	-525	86	-375	-369	86	-522	-540
IF4A	PW	12	0	-553	-533	0	-554	-554	0	-515	-606	0	-628	-507
IF6	PW	6	0	-521	-521	0	-521	-519	0	-734	-716	66	-753	-713
IF8	PW	8	0	-551	-551	0	-551	-551	0	-609	-640	49	-655	-650
IF13	PW	5	24	-561	-562	24	-579	-579	68	-650	-649	56	-640	-633
IF12	PW	5	2	-581	-581	0	-576	-576	48	-672	-671	48	-673	-660
IF14	PW	3	0	-506	-506	0	-507	-507	0	-504	-504	52	-597	-587
IF15	PW	4	0	-558	-558	0	-559	-559	46	-666	-657	45	-687	-657
IF18	PW	4	0	-573	-565	0	-573	-566	0	-563	-554	47	-597	-556
IF20	PW	10	0	-575	-575	0	-582	-582	25	-600	-600	51	-520	-613
IF21	Treated water	3	0	-583	-585	0	-591	-591	0	-594	-594	32	-520	-513
IF22A	PW	1	0	-578	-578	0	-583	-583	22	-609	-609	36	-623	-614

7



Client: GCME Location: BTF plant, Rayong
 Project no.: S06284 Weather Condition: Hot
 Survey by: CW, PW, SC and AV Date of survey: 19-Aug-19
 Equipment: Potential meter - LC4.5 MC Miller and Portable Cu/CuSO4 reference electrode
 Appendix B: Survey Data

TRU output	41V / 5A
A1	1.31A
A2	1.22A
A3	1.08A
A4	1.41A

Table 6: CP potential readings between 1st CP baseline potential and 2nd CP shift results of TP's

		AC Power		CP potential reading					
		1st survey	2nd survey	1st survey	2nd survey	1st survey	2nd survey		
		AC potential (mV)	AC potential (mV)	"ON" potential reading (mV) P1	"OFF" potential reading (mV) P1	"ON" potential reading (mV) P2	"OFF" potential reading (mV) P2		
TP1	PW	0	96	-792	-667	-772	-660		
TP3	PW	34	41	-566	-589	-602	-595		
TP5	PW	0	23	-664	-585	-576	-567		
TP7	PW	0	N/A	N/A	N/A	N/A	N/A		
TP9	PW	0	N/A	N/A	N/A	N/A	N/A		
TP11	PW	0	39	-575	-565	-588	-579		
TP13	EDC	0	0	-839	-661	-617	-517		Not electrically continue to mat's PW pipe



6



Client: GCME Location: BTF plant, Rayong
 Project no.: SD6284 Weather Condition:
 Survey by: CA, PW, SC and AV Date of survey:
 Equipment: Potentiometer - L64.5 MC Miller and Portable Cu/CuSO4 reference electrode and IF Checker M.C. Miller Model E01
 Appendix A: Survey Data
 Table 5: CP potential readings between 1st CP baseline potential and 2nd CP shift result of 15

TMC output 41V / 5A	
A1	2.31A
A2	2.22A
A3	1.98A
A4	1.41A



Project	No.	Type	Material	1st Survey						2nd Survey						Remarks
				A/G Range			U/G Range			A/G Range			U/G Range			
				AC potential (mV)	"ON" CP Potential (mV)	"OFF" CP Potential (mV)	AC potential (mV)	"ON" CP Potential (mV)	"OFF" CP Potential (mV)	AC potential (mV)	"ON" CP Potential (mV)	"OFF" CP Potential (mV)	AC potential (mV)	"ON" CP Potential (mV)	"OFF" CP Potential (mV)	
IF48	FW	32	0	-786	-486	0	-497	-497	53	-669	-746	-51	-840	-739		
IF50	FW	4	0	-536	-596	39	-508	-598	0	-513	-622	-69	-724	-675		
IF52	FW	16	52	-577	-577	42	-577	-577	258	-650	-650	-258	-550	-650	Not electrically continue to main FW pipelines	
IF54	Air	2	0	-576	-576	33	-634	-634	0	-578	-577	16	-514	-539	Not electrically continue to main FW pipelines	
IF56	Air	2	0	-611	-611	0	-653	-653	52	-690	-690	80	-577	-577	Not electrically continue to main FW pipelines	
IF58	Propylene	4	0	-592	-592	0	-541	-541	49	-578	-577	245	-600	-524		
IF60	Propylene	4	0	-1057	-1057	0	-1140	-1140	35	-1037	-1135	245	-1035	-1093		
IF62	ERC	4	0	-1099	-1109	0	-1086	-1182	0	-1143	-1142	0	-1124	-1120		
IF64	Ethylene	8	80	-1137	-1235	35	-1220	-1216	30	-1227	-1130	300	-1205	-1204		



Client: GCME Location: BTF plant, Rayong
 Project no.: SD6284 Weather Condition:
 Survey by: CA, PW, SC and AV Date of survey:
 Equipment: Potentiometer - L64.5 MC Miller and Portable Cu/CuSO4 reference electrode and IF Checker M.C. Miller Model E01
 Appendix A: Survey Data
 Table 5: CP potential readings between 1st CP baseline potential and 2nd CP shift result of 15

TMC output 41V / 5A	
A1	2.31A
A2	2.22A
A3	2.08A
A4	2.61A




ID	Type	Material	1st Survey						2nd Survey						Remarks
			A/G Range			U/G Range			A/G Range			U/G Range			
			AC potential (mV)	"ON" CP Potential (mV)	"OFF" CP Potential (mV)	AC potential (mV)	"ON" CP Potential (mV)	"OFF" CP Potential (mV)	AC potential (mV)	"ON" CP Potential (mV)	"OFF" CP Potential (mV)	AC potential (mV)	"ON" CP Potential (mV)	"OFF" CP Potential (mV)	
IF28	FW	10	0	-563	-685	0	-585	-585	24	-596	-596	49	-611	-603	
IF24	Y/leaked water	2	53	-435	-439	52	-475	-475	0	-463	-469	99	-461	-461	Not electrically continue to main FW pipelines
IF26	FW	2	0	-545	-593	0	-608	-608	27	-629	-629	52	-647	-639	Not electrically continue to main FW pipelines
IF28	FW	12	0	-1176	-1176	0	-1185	-1185	20	-1192	-1195	74	-1149	-1143	
IF30	FW	17	0	-570	-590	0	-576	-566	0	-552	-552	37	-567	-558	
IF32	FW	10	0	-638	-636	0	-590	-590	0	-632	-519	41	-623	-613	
IF34	FW	3	0	-543	-552	0	-584	-554	0	-650	-660	46	-680	-659	
IF36	FW	12	25	-509	-538	0	-465	-465	20	-522	-529	71	-522	-528	
IF38	FW	12	0	-673	-677	0	-678	-673	93	-625	-632	93	-628	-625	
IF40	FW	6	0	-374	-374	0	-605	-605	85	-705	-695	53	-653	-660	
IF42	FW	12	0	N/A	N/A	0	-503	-743	30	-734	-685	0	-766	-779	
IF44	FW	12	0	-620	-557	0	-612	-703	3	-770	-685	113	-770	-653	
IF46	FW	12	0	-669	-624	0	-587	-575	104	-599	-624	113	-725	-673	




Photographic record

1 AC potential measurements

- AC potential measurements at Test posts




- AC potential measurements at Insulating flanges




2 Visual inspection


- Visual inspection at Test posts




- Visual inspection at Insulating flanges




3 Current output measurements



4 Soil resistivity measurement




5 Insulating flanges test



6 CP potential reading - 1st Potential reading base line potential

- CP potential reading at Test post 1




- CP potential reading at insulating bridge



7 Current drainage test (CDT)


- Current drainage test (CDT), temporary ICCP system installation





8 CP potential reading - 2nd Potential reading from CDT test

1
CP potential reading at insulating flanges



Appendix C

Plot plan drawings


- Colour legend of CP potential level for base line potential - Drawing CP-001
- Colour legend for shift potentials - Drawing CP-002
- Concept design drawing - Drawing CP-003

Aurecon Consulting (Thailand) Co Ltd
Pakin Building, 11th Floor, Unit 1101
9 Ratchadapisek Road
Klong Kwang Dinsoeng
Khet Dinsoeng
Bangkok 10400
Thailand

T +662 333 3222
F +662 333 3239
E bangkok@wurecongroup.com
W wurecongroup.com

purecon
Bringing ideas
to life


Australian offices are located in:
Angola, Australia, Botswana, China,
France, Hong Kong, Indonesia, Kenya,
Lesotho, Macau, Mozambique,
Namibia, New Zealand, Nigeria,
Peru, Philippines, Qatar, Singapore, South Africa,
Swaziland, Tanzania, Thailand, Uganda,
United Arab Emirates, Vietnam.



durecon
www.durecon.com

GCME

FOR INFORMATION ONLY



๑๙๕๗ ปีที่ ๒ ฉบับที่ ๓

10141310 Crisis and Security Management, Site Management

ลำดับ	หน่วยงาน (CPCRU)	ผู้รับผิดชอบ	รศ.	อ.ผ.	อ.ส.	อ.ค.	อ.ด.	อ.ช.	อ.น.	อ.ย.	กษ.	การขอสารเชื่อม	ความถี่รวมหัว
1	G-C2(ATF) : ระดับ 2											วันที่ 26 กรกฎาคม 2566	
2	G-C7(BTF) :ระดับ 2											วันที่ 28 สิงหาคม 2566	
3	G-C7(BTF) Ac(92) : ระดับ 2											วันที่ 30 พฤศจิกายน 2566	
4	G-C8(ATF) : ระดับ 3	ชุดข้อมูล TMS										วันที่ 06 ตุลาคม 2566	
5	G-C5(ATF2) : ระดับ 2 คม RIL											วันที่ 26 พฤษภาคม 2566	90%
6	Interconnecting pipeline : ระดับ 2											วันที่ 07 กรกฎาคม 2566	

79 5 92
401471


1997]

211

➤ 29๒

เอกสารตัวอย่างตรวจสอบอุปกรณ์ป้องกัน
และระงับอัคคีภัยและอุปกรณ์เตือนภัยของโครงการ





८५५ NPC 2457 / 2565

4 May 2013 2565

^๔ เรื่อง รายงานการปฏิบัติงานประจำปี การส่งเสริมการค้าระหว่างประเทศและทุนการเงิน ประจำปี พ.ศ. ๒๕๖๑ หน้า ๓๐-๓๑

၂၀၁၆ ခုနှစ်

^{๖๔}NAN 1. ^{๖๕}ข้อเสนอนี้ได้รับการสนับสนุนจากคณะผู้บริหารระดับสูงของ บริษัท โอลิมปิก เอเชีย จำกัด สาขา 7

ค่าเช่าบ้านและค่าสาธารณูปโภค: 10,000 บาท

[illegible]

นี่ส่งไปยัง...ในสหรัฐอเมริกา...ได้ตั้งโปรแกรมให้...บริการสุขภาพ...คุณการะฮุสเซ็น...และผลการตรวจพบ

นี่คือสิ่งที่ผมอยากเห็น ^{๕๕} (ตอนที่ผมไปหาอาจารย์เจตตบดินทร์แห่งจุฬาลงกรณ์มหาวิทยาลัย)

Mathematics 2022, 10, 1105

গণপ্রজাতন্ত্রী বাংলাদেশ সরকার

កម្ពុជាធិបតេយ្យ សេរីភូមិសាស្ត្រ ឯករាជ្យ ៧២

สมเด็จพระสังฆราชเจ้า กรมหลวงชินวราลงกรณ

038-977798

1400

©2011 Emerson Climate Controls, Inc. All rights reserved. Emerson Climate Controls, Inc. is an Equal Opportunity Employer. All trademarks are the property of their respective owners.

Rond Chetichuk. Barakak 10300. Tlaxiñau

IE : -1000i 2015-91°C Fax :012235-6735

REACTING

© 2006 Blackwell Publishing Ltd, *Journal of Internal Medicine* 260: 101–108

Published by the American Psychological Association

TEL.: +65 (0) 3897-7777 FAX: +65 (0) 3897-7777

COISS=COH • N111185 • CH2CVS

REV. 9-99, 12-11

นางสาวนันทพร บุญชู

การให้บริการควบคุมภาวะฉุกเฉิน (Emergency Control Center)

ประชุมจำเริญ ณ วันที่ ๒๕๖๕

สำหรับ

บริษัท พตท โกลบอล เคมิคอล จำกัด (มหาชน)
สาขาที่ 7 สาขาท่าเทียบเรือและคลังผลิตภัณฑ์

สัญญาให้บริการเลขที่ SVO.190904070

จัดทำโดย



ศูนย์ควบคุมภาวะฉุกเฉิน (Emergency Control Center)
บริษัท เอ็มพีซี เซฟตี้ แอนด์ เอ็นไวรอนเมทัล เซอร์วิส จำกัด จำกัด
NPC Safety and Environmental Service Co.,Ltd.



เรื่อง

สารบัญ

1 ข้อมูลการตรวจสอบและทดสอบอุปกรณ์ดับเพลิง

1.1 ตารางแสดงจำนวนอุปกรณ์ดับเพลิง GC-7

1.2 ตารางแสดงผลการตรวจสอบอุปกรณ์ดับเพลิง GC-7 เดือน ธันวาคม 2565

1.3 กราฟแสดงความพร้อมอุปกรณ์ดับเพลิงในเดือน ธันวาคม 2565

1.4 การติดตามการแก้ไขอุปกรณ์ดับเพลิง

2 ข้อมูลการซ้อมแผนฯ อุปกรณ์

3 ข้อมูลการเตรียมความพร้อมภัยพิบัติทางดับเพลิง

3.1 พยากรณ์ปัจจัยส่วนควบคุมภาวะฉุกเฉิน

3.2 แผนการซ้อมประจำปี 2565

3.3 ข้อมูลการอบรมภายในประจำปีศูนย์ควบคุมภาวะฉุกเฉิน

4 ข้อมูลการเตรียมความพร้อมภัยพิบัติดับเพลิงและอุปกรณ์ประจำศูนย์ควบคุมภาวะฉุกเฉิน

4.1 ข้อมูลดับเพลิง

4.2 สรุปผลการตรวจตราเพื่อตรวจสอบความพร้อมของอุปกรณ์สื่อสารประจำเดือน ธันวาคม 2565

4.3 สรุปข้อมูลอุปกรณ์ชุดดับเพลิง และ SCBA

5. เอกสารแนบ

เอกสารแนบ 1 แผนการตรวจอุปกรณ์ดับเพลิงประจำปี 2565

เอกสารแนบ 2 แบบฟอร์มผลการตรวจอุปกรณ์ดับเพลิงประจำเดือน ธันวาคม 2565



รายงานผลการปฏิบัติงาน

การให้บริการควบคุมภาวะฉุกเฉิน (EOC)


ประจำเดือน ธันวาคม 2565

1. ข้อมูลการตรวจสอบและทดสอบอุปกรณ์ดับเพลิง

1.1 ข้อมูลแสดงจำนวนอุปกรณ์ดับเพลิงประจำบริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน) สาขาที่ 7

ตารางที่ 1 แสดงจำนวนอุปกรณ์ดับเพลิงประจำพื้นที่ GC-7

ลำดับ	อุปกรณ์	จำนวนอุปกรณ์ดับเพลิงแบ่งตามพื้นที่			จำนวนรวม อุปกรณ์ดับเพลิง
		BTF	Jetty1	Jetty2	
1	Portable Dry Chemical	65	14	3	82
2	Portable Carbon Dioxide	19	7	1	27
3	Wheel Dry Chemical 125 lbs.	6	-	2	8
4	Hydrant (HT)	22	3	2	27
5	Hydrant With Monitor (HWM)	27	-	1	28
6	Water Monitor (WMT)	17	-	-	17
7	Foam Hydrant (F-H)	-	2	2	4
8	Hose House	19	-	-	19
9	Hose Box	11	5	2	18
10	Fire Break Glass	45	21	3	69
11	Mobile Foam	3	-	-	3
12	Foam Storage Tank	1	1	1	3
13	Foam Bladder Tank	3	-	-	3
14	Deluge Valve	25	-	-	25
15	Water Spray	47	-	-	47
16	SCBA	6	4	2	12
17	Fire Protection Clothing	6	4	2	12
18	Emergency Escape	-	1	1	2
19	Fire Blanket	-	3	-	3
20	Fire Axe	-	1	1	2



ลำดับ	อุปกรณ์	จำนวนอุปกรณ์ดับเพลิงแบ่งตามพื้นที่			จำนวนรวม อุปกรณ์ดับเพลิง
		BTH	Jetty1	Jetty2	
21	Fixed CO2	1	-	1	2
22	FM200 System	1	-	-	1
23	Inertgas System	1	1	-	2
24	Fixed Dry Chemical	-	2	-	2
25	Water Curtain	-	1	1	2
26	Water Monitor Remote	-	2	1	3
รวม					414


1.2 สรุปผลการตรวจสอบอุปกรณ์ดับเพลิง

ตารางที่ 2 แสดงผลการตรวจสอบอุปกรณ์ดับเพลิงประจำพื้นที่ GC-1

ลำดับ	อุปกรณ์	ผลการตรวจ			ข้อมูลระบบอุปกรณ์ดับเพลิง			วันที่ ตรวจสอบ
		จำนวน ใช้จริง	จำนวน สำรอง	จำนวน รวม	จำนวน ใช้จริง	จำนวน สำรอง	จำนวน รวม	
1	Dry Chemical	51	1	52	51	1	52	
2	CO2 Bottle	27	0	27	27	0	27	
3	Water Dry	3	0	3	3	0	3	
4	Hydrant (H-D)	27	0	27	27	0	27	
5	Hydrant Monitor	28	0	28	28	0	28	
6	Water Tank	17	0	17	17	0	17	
7	Water Tank	17	0	17	17	0	17	
8	Water Tank	17	0	17	17	0	17	
9	Water Tank	17	0	17	17	0	17	
10	Water Tank	17	0	17	17	0	17	
11	Water Tank	17	0	17	17	0	17	
12	Water Tank	17	0	17	17	0	17	
13	Water Tank	17	0	17	17	0	17	
14	Water Tank	17	0	17	17	0	17	
15	Water Tank	17	0	17	17	0	17	
16	Water Tank	17	0	17	17	0	17	
17	Water Tank	17	0	17	17	0	17	
18	Water Tank	17	0	17	17	0	17	
19	Water Tank	17	0	17	17	0	17	
20	Water Tank	17	0	17	17	0	17	
21	Water Tank	17	0	17	17	0	17	
22	Water Tank	17	0	17	17	0	17	
23	Water Tank	17	0	17	17	0	17	
24	Water Tank	17	0	17	17	0	17	
25	Water Tank	17	0	17	17	0	17	
26	Water Tank	17	0	17	17	0	17	
27	Water Tank	17	0	17	17	0	17	
28	Water Tank	17	0	17	17	0	17	
29	Water Tank	17	0	17	17	0	17	
30	Water Tank	17	0	17	17	0	17	
31	Water Tank	17	0	17	17	0	17	
32	Water Tank	17	0	17	17	0	17	
33	Water Tank	17	0	17	17	0	17	
34	Water Tank	17	0	17	17	0	17	
35	Water Tank	17	0	17	17	0	17	
36	Water Tank	17	0	17	17	0	17	
37	Water Tank	17	0	17	17	0	17	
38	Water Tank	17	0	17	17	0	17	
39	Water Tank	17	0	17	17	0	17	
40	Water Tank	17	0	17	17	0	17	
41	Water Tank	17	0	17	17	0	17	
42	Water Tank	17	0	17	17	0	17	
43	Water Tank	17	0	17	17	0	17	
44	Water Tank	17	0	17	17	0	17	
45	Water Tank	17	0	17	17	0	17	
46	Water Tank	17	0	17	17	0	17	
47	Water Tank	17	0	17	17	0	17	
48	Water Tank	17	0	17	17	0	17	
49	Water Tank	17	0	17	17	0	17	
50	Water Tank	17	0	17	17	0	17	
51	Water Tank	17	0	17	17	0	17	
52	Water Tank	17	0	17	17	0	17	
53	Water Tank	17	0	17	17	0	17	
54	Water Tank	17	0	17	17	0	17	
55	Water Tank	17	0	17	17	0	17	
56	Water Tank	17	0	17	17	0	17	
57	Water Tank	17	0	17	17	0	17	
58	Water Tank	17	0	17	17	0	17	
59	Water Tank	17	0	17	17	0	17	
60	Water Tank	17	0	17	17	0	17	
61	Water Tank	17	0	17	17	0	17	
62	Water Tank	17	0	17	17	0	17	
63	Water Tank	17	0	17	17	0	17	
64	Water Tank	17	0	17	17	0	17	
65	Water Tank	17	0	17	17	0	17	
66	Water Tank	17	0	17	17	0	17	
67	Water Tank	17	0	17	17	0	17	
68	Water Tank	17	0	17	17	0	17	
69	Water Tank	17	0	17	17	0	17	
70	Water Tank	17	0	17	17	0	17	
71	Water Tank	17	0	17	17	0	17	
72	Water Tank	17	0	17	17	0	17	
73	Water Tank	17	0	17	17	0	17	
74	Water Tank	17	0	17	17	0	17	
75	Water Tank	17	0	17	17	0	17	
76	Water Tank	17	0	17	17	0	17	
77	Water Tank	17	0	17	17	0	17	
78	Water Tank	17	0	17	17	0	17	
79	Water Tank	17	0	17	17	0	17	
80	Water Tank	17	0	17	17	0	17	
81	Water Tank	17	0	17	17	0	17	
82	Water Tank	17	0	17	17	0	17	
83	Water Tank	17	0	17	17	0	17	
84	Water Tank	17	0	17	17	0	17	
85	Water Tank	17	0	17	17	0	17	
86	Water Tank	17	0	17	17	0	17	
87	Water Tank	17	0	17	17	0	17	
88	Water Tank	17	0	17	17	0	17	
89	Water Tank	17	0	17	17	0	17	
90	Water Tank	17	0	17	17	0	17	
91	Water Tank	17	0	17	17	0	17	
92	Water Tank	17	0	17	17	0	17	
93	Water Tank	17	0	17	17	0	17	
94	Water Tank	17	0	17	17	0	17	
95	Water Tank	17	0	17	17	0	17	
96	Water Tank	17	0	17	17	0	17	
97	Water Tank	17	0	17	17	0	17	
98	Water Tank	17	0	17	17	0	17	
99	Water Tank	17	0	17	17	0	17	
100	Water Tank	17	0	17	17	0	17	



1.3 กราฟแสดงความพร้อมอุปกรณ์ดับเพลิงในเดือน มกราคม - ธันวาคม 2565



1.4 การติดตามผลการดำเนินการแก้ไขอุปกรณ์ดับเพลิงพื้นที่ GC-7 (BTF)

ลำดับที่	รายการอุปกรณ์ที่ชำรุด	วันที่ตรวจพบ	ผู้รับผิดชอบ	ผลการดำเนินการ
1	Dry Chemical (Cartridge operate)			
1.1	- ถังดับเพลิงเคมีแห้ง D-44, D-48, D-53, D-65 ตู้ใต้ถังดับเพลิงไม่ได้ใช้ถังดับเพลิง	6 ก.ค. 65	Q-SH-CM	
1.2	- ถังดับเพลิงเคมีแห้ง D-44, D-22 ตู้ Cartridge ชำรุด	9 ก.ค. 65	Q-SH-CM	
	- ไม่สามารถใช้งานได้			
1.3	- ถังดับเพลิงเคมีแห้ง D-53 1 ถัง	1 ม.ค. 65	Q-SH-CM	
2	Dry Chemical (Storage pressure)			
2.1	- ถังดับเพลิงเคมีแห้ง D-10, D-37 D-54 ตู้ใต้ถังดับเพลิงไม่ได้ใช้ถังดับเพลิง	8 ก.ค. 65	Q-SH-CM	
3	Mobile Foam			
3.1	- ถังดับเพลิงโฟม MSF-03 1 ถัง	8 ก.ค. 65	Q-SH-CM	



ลำดับที่	รายการอุปกรณ์ที่ชำรุด	วันที่ตรวจพบ	ผู้รับผิดชอบ	ผลการดำเนินการ
4	Hydrant With Monitor			
4.1	- FIM-01, 08 Hand wheel valve ยางชำรุด 2.5" อุปกรณ์ 1 ตัว	8 ก.ค. 65	Q-SH-CM	
4.2	- FIM-03 Main valve ปิดไม่ได้	8 ก.ค. 65	Q-SH-CM	
4.3	- HIM-12, FIM-16, FIM-17 หน้าแปลนแก้ไขแล้ว	8 ก.ค. 65	Q-SH-CM	
5	Fixed Monitor			
5.1	- WWT-05 Monitor valve passing	8 ก.ค. 65	Q-SH-CM	
6	Hydrant			
6.1	- HF-05, HF-06, HF-07 Main valve passing	8 ก.ค. 65	Q-SH-CM	
6.2	- HF-18, HF-19, H-20 Main Valve ยางชำรุด 4" ปิดไม่ได้	8 ก.ค. 65	Q-SH-CM	
7	Deluge Valve			
7.1	- DV-TL-01 Deluge valve passing (ปิด Main valve ได้) อุปกรณ์ปิดไม่ได้	1 ม.ค. 65	Q-SH-CM	
8	SCBA			
8.1	- SCBA-01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 45, 46, 47, 48, 49, 50, 51, 52, 53, 54, 55, 56, 57, 58, 59, 60, 61, 62, 63, 64, 65, 66, 67, 68, 69, 70, 71, 72, 73, 74, 75, 76, 77, 78, 79, 80, 81, 82, 83, 84, 85, 86, 87, 88, 89, 90, 91, 92, 93, 94, 95, 96, 97, 98, 99, 100, 101, 102, 103, 104, 105, 106, 107, 108, 109, 110, 111, 112, 113, 114, 115, 116, 117, 118, 119, 120, 121, 122, 123, 124, 125, 126, 127, 128, 129, 130, 131, 132, 133, 134, 135, 136, 137, 138, 139, 140, 141, 142, 143, 144, 145, 146, 147, 148, 149, 150, 151, 152, 153, 154, 155, 156, 157, 158, 159, 160, 161, 162, 163, 164, 165, 166, 167, 168, 169, 170, 171, 172, 173, 174, 175, 176, 177, 178, 179, 180, 181, 182, 183, 184, 185, 186, 187, 188, 189, 190, 191, 192, 193, 194, 195, 196, 197, 198, 199, 200, 201, 202, 203, 204, 205, 206, 207, 208, 209, 210, 211, 212, 213, 214, 215, 216, 217, 218, 219, 220, 221, 222, 223, 224, 225, 226, 227, 228, 229, 230, 231, 232, 233, 234, 235, 236, 237, 238, 239, 240, 241, 242, 243, 244, 245, 246, 247, 248, 249, 250, 251, 252, 253, 254, 255, 256, 257, 258, 259, 260, 261, 262, 263, 264, 265, 266, 267, 268, 269, 270, 271, 272, 273, 274, 275, 276, 277, 278, 279, 280, 281, 282, 283, 284, 285, 286, 287, 288, 289, 290, 291, 292, 293, 294, 295, 296, 297, 298, 299, 300, 301, 302, 303, 304, 305, 306, 307, 308, 309, 310, 311, 312, 313, 314, 315, 316, 317, 318, 319, 320, 321, 322, 323, 324, 325, 326, 327, 328, 329, 330, 331, 332, 333, 334, 335, 336, 337, 338, 339, 340, 341, 342, 343, 344, 345, 346, 347, 348, 349, 350, 351, 352, 353, 354, 355, 356, 357, 358, 359, 360, 361, 362, 363, 364, 365, 366, 367, 368, 369, 370, 371, 372, 373, 374, 375, 376, 377, 378, 379, 380, 381, 382, 383, 384, 385, 386, 387, 388, 389, 390, 391, 392, 393, 394, 395, 396, 397, 398, 399, 400, 401, 402, 403, 404, 405, 406, 407, 408, 409, 410, 411, 412, 413, 414, 415, 416, 417, 418, 419, 420, 421, 422, 423, 424, 425, 426, 427, 428, 429, 430, 431, 432, 433, 434, 435, 436, 437, 438, 439, 440, 441, 442, 443, 444, 445, 446, 447, 448, 449, 450, 451, 452, 453, 454, 455, 456, 457, 458, 459, 460, 461, 462, 463, 464, 465, 466, 467, 468, 469, 470, 471, 472, 473, 474, 475, 476, 477, 478, 479, 480, 481, 482, 483, 484, 485, 486, 487, 488, 489, 490, 491, 492, 493, 494, 495, 496, 497, 498, 499, 500, 501, 502, 503, 504, 505, 506, 507, 508, 509, 510, 511, 512, 513, 514, 515, 516, 517, 518, 519, 520, 521, 522, 523, 524, 525, 526, 527, 528, 529, 530, 531, 532, 533, 534, 535, 536, 537, 538, 539, 540, 541, 542, 543, 544, 545, 546, 547, 548, 549, 550, 551, 552, 553, 554, 555, 556, 557, 558, 559, 560, 561, 562, 563, 564, 565, 566, 567, 568, 569, 570, 571, 572, 573, 574, 575, 576, 577, 578, 579, 580, 581, 582, 583, 584, 585, 586, 587, 588, 589, 590, 591, 592, 593, 594, 595, 596, 597, 598, 599, 600, 601, 602, 603, 604, 605, 606, 607, 608, 609, 610, 611, 612, 613, 614, 615, 616, 617, 618, 619, 620, 621, 622, 623, 624, 625, 626, 627, 628, 629, 630, 631, 632, 633, 634, 635, 636, 637, 638, 639, 640, 641, 642, 643, 644, 645, 646, 647, 648, 649, 650, 651, 652, 653, 654, 655, 656, 657, 658, 659, 660, 661, 662, 663, 664, 665, 666, 667, 668, 669, 670, 671, 672, 673, 674, 675, 676, 677, 678, 679, 680, 681, 682, 683, 684, 685, 686, 687, 688, 689, 690, 691, 692, 693, 694, 695, 696, 697, 698, 699, 700, 701, 702, 703, 704, 705, 706, 707, 708, 709, 710, 711, 712, 713, 714, 715, 716, 717, 718, 719, 720, 721, 722, 723, 724, 725, 726, 727, 728, 729, 730, 731, 732, 733, 734, 735, 736, 737, 738, 739, 740, 741, 742, 743, 744, 745, 746, 747, 748, 749, 750, 751, 752, 753, 754, 755, 756, 757, 758, 759, 760, 761, 762, 763, 764, 765, 766, 767, 768, 769, 770, 771, 772, 773, 774, 775, 776, 777, 778, 779, 780, 781, 782, 783, 784, 785, 786, 787, 788, 789, 790, 791, 792, 793, 794, 795, 796, 797, 798, 799, 800, 801, 802, 803, 804, 805, 806, 807, 808, 809, 810, 811, 812, 813, 814, 815, 816, 817, 818, 819, 820, 821, 822, 823, 824, 825, 826, 827, 828, 829, 830, 831, 832, 833, 834, 835, 836, 837, 838, 839, 840, 841, 842, 843, 844, 845, 846, 847, 848, 849, 850, 851, 852, 853, 854, 855, 856, 857, 858, 859, 860, 861, 862, 863, 864, 865, 866, 867, 868, 869, 870, 871, 872, 873, 874, 875, 876, 877, 878, 879, 880, 881, 882, 883, 884, 885, 886, 887, 888, 889, 890, 891, 892, 893, 894, 895, 896, 897, 898, 899, 900, 901, 902, 903, 904, 905, 906, 907, 908, 909, 910, 911, 912, 913, 914, 915, 916, 917, 918, 919, 920, 921, 922, 923, 924, 925, 926, 927, 928, 929, 930, 931, 932, 933, 934, 935, 936, 937, 938, 939, 940, 941, 942, 943, 944, 945, 946, 947, 948, 949, 950, 951, 952, 953, 954, 955, 956, 957, 958, 959, 960, 961, 962, 963, 964, 965, 966, 967, 968, 969, 970, 971, 972, 973, 974, 975, 976, 977, 978, 979, 980, 981, 982, 983, 984, 985, 986, 987, 988, 989, 990, 991, 992, 993, 994, 995, 996, 997, 998, 999, 1000	1 ม.ค. 65	Q-SH-CM	
9	ชุดดับเพลิง			
9.1	- ชุดดับเพลิงมือถือแบบพกพา 4 ชุด (ถังแก๊ส, แก๊สแรงดันสูง)	1 ม.ค. 65	Q-SH-CM	
10	Wheel Dry			
10.1	- WD-01: ถังแก๊สเต็ม และถังดับเพลิง	1 ม.ค. 65	Q-SH-CM	
10.2	- WD-02: ถังแก๊สเต็ม และถังดับเพลิง	1 ม.ค. 65	Q-SH-CM	
10.3	- WD-03: ถังแก๊สเต็ม และถังดับเพลิง	1 ม.ค. 65	Q-SH-CM	

1.5 การติดตามผลการดำเนินการแก้ไขอุปกรณ์ดับเพลิงพื้นที่ GC-7 (Jetty)

ลำดับที่	รายการอุปกรณ์ที่ชำรุด	วันที่ตรวจพบ	ผู้รับผิดชอบ	ผลการดำเนินการ
1	CO2 Portable			
1.1	ถังแก๊สเลข J1 CO-03 สลากจับเอกสารฯ	7 ก.ค. 65	Q-SH-CM	
2	Dry Chemical (Cartridge operate)			
2.1	ถังแก๊สเลข D-140 ประตูดับเพลิงฯ	7 ก.ค. 65	Q-SH-CM	
2.2	- ถังแก๊สเลข D-143 ประตูดับเพลิงฯ	7 ก.ค. 65	Q-SH-CM	
2.3	- ถังแก๊สเลข D-145 ถังดับเพลิง	7 ก.ค. 65	Q-SH-CM	
2.4	- ถังแก๊สเลข D-149 ที่ใต้ดินซึ่งไม่ได้ติดสติ๊กเกอร์	7 ก.ค. 65	Q-SH-CM	
2.5	- ถังแก๊สเลข D-6712 ถังแก๊สสภาพ (ถังเป็นชิ้น)	1 ก.ค. 65	Q-SH-CM	
3	Manual Fire Alarm Station			
3.1	- ECU-748 ใช้งานชำรุดหักงอไม่พุด	7 ก.ค. 65	Q-SH-CM	
4	Fire Hose Box			
4.1	- J1-HS-05 ไม่พบประตูปิด	14 พ.ย. 65	Q-SH-CM	
4.2	- J2-HS-02 ไม่พบ Reducer 1 นิ้ว	14 พ.ย. 65	Q-SH-CM	
5	Hydrant			
5.1	- J1-HT-02 ข้อต่อทางจ่ายน้ำด้านซ้ายเคลื่อนที่	6 ก.ย. 65	Q-SH-CM	
5.2	- J2-HT-01 ข้อต่อทางจ่ายน้ำอีกด้านอีก 2 ด้าน	6 ก.ย. 65	Q-SH-CM	
5.3	- J2-HT-02 ข้อต่อทางจ่ายน้ำอีกด้าน 1 ด้าน	6 ก.ย. 65	Q-SH-CM	
6	Wheel Dry			
6.1	- WDB-001 ใช้งานไม่สะดวกเป็นสนิม และไม่มี	24 ส.ค. 65	Q-SH-CM	
ถังดับเพลิง				
7	SCBA			
7.1	- SCBA-06 ตรวจสอบ LRV Stop air ไม่ใช้	24 ส.ค. 65	Q-SH-CM	
7.2	- SCBA-01, 02, 03, 04 Head stop ทางซ้ายสุด	1 ก.ค. 65	Q-SH-CM	
8	ชุดดับเพลิง			
8.1	- ชุดดับเพลิงเต็มระบบฯ ทั้ง 6 ชุด (ถัง, รางน้ำ, ขังงัก)	24 ส.ค. 65	Q-SH-CM	
9	Inergen System			
9.1	- ถัง Inergen ชุด Reserve แรงดันต่ำกว่าเกณฑ์	14 พ.ย. 65	Q-SH-CM	
	จำนวน 1 ถัง			

ลำดับที่	รายการอุปกรณ์ที่ชำรุด	วันที่ตรวจพบ	ผู้รับผิดชอบ	ผลการดำเนินการ
10	Hydrant Foam			
10.1	J2-HTE-01 แก๊สคาร์บอนไดออกไซด์	1 ก.ค. 65	Q-SH-CM	
11	CO2 System			
11.1	Manual release ของห้อง LV & HV Room ตัวซ้าย	1 ก.ค. 65	Q-SH-CM	
	สัญญาณตัวซ้ายไม่มี Manual fire alarm			

2. ข้อมูลการซ่อมแผน ๑ อุณหภูมิ

ลำดับ	สถานที่	ระดับ	วันที่	หมายเหตุ
1	- ลาน Buena Vista 1 (ลาน สะลุคิลไฟ)	2	31 ต.ค. 65	
2	- เพลิงป่าที่ 1 (ลาน สะลุคิลไฟ)	2	13 ธ.ค. 65	

3. ข้อมูลการเตรียมความพร้อมพนักงานดับเพลิง

3.1 พนักงานประจำศูนย์ควบคุมภาวะฉุกเฉิน

ลำดับ	สถานี	กำลังพล (คน)	หมายเหตุ
1	ศูนย์ควบคุมภาวะฉุกเฉิน (ECC)	58	Day time 32 คน, A 9 คน, B 8 คน, C 9 คน
2	สถานีดับเพลิง PT GC-2	18	ผลัดละ 6 คน
3	สถานีดับเพลิง PT GC-3	18	ผลัดละ 6 คน
4	สถานีดับเพลิง PT GC-4	9	ผลัดละ 3 คน
5	สถานีดับเพลิง PT GC-5	9	ผลัดละ 3 คน
6	สถานีดับเพลิง PT GC-6	9	ผลัดละ 3 คน
7	สถานีดับเพลิง PT GC-7	18	ผลัดละ 6 คน
8	สถานีดับเพลิง PT GC-8	12	ผลัดละ 4 คน
9	สถานีดับเพลิง PT GC-9	12	ผลัดละ 4 คน
10	สถานีดับเพลิง PT GC-10	12	ผลัดละ 4 คน
11	สถานีดับเพลิง PT GC-11	9	ผลัดละ 3 คน
12	สถานีดับเพลิง PT GC-12	3	ผลัดละ 1 คน
13	สถานีดับเพลิง PT GC-13	9	ผลัดละ 3 คน
14	สถานีดับเพลิง PT GC-14	18	ผลัดละ 6 คน
15	สถานีดับเพลิง PT GC-15	2	ปฏิบัติงาน Day time
16	สถานีดับเพลิง PT GC-16	3	ปฏิบัติงาน Day time
รวมพนักงานดับเพลิง		219	

3.2 แผนการอบรมประจำปี 2565

Item	Training course	Plan for 2022												Remark
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
1	Tank Fire													ฝึกซ้อมและแข่งขัน การดับเพลิงในถังน้ำมัน
2	Confine Space & Rescue													ฝึกซ้อมและแข่งขัน การกู้ชีพในถังปิด
3	Rope and Rescue													ฝึกซ้อมและแข่งขัน การกู้ชีพด้วยเชือก
4	Advance Industrial Fire Fighting													ฝึกซ้อมและแข่งขัน การดับเพลิงในโรงงานอุตสาหกรรม
5	Advance Enclosure Fire													ฝึกซ้อมและแข่งขัน การดับเพลิงในอาคาร
6	First Aid													ฝึกซ้อมและแข่งขัน การปฐมพยาบาล
7	Chemical spill control (Hazard)													ฝึกซ้อมและแข่งขัน การควบคุมการรั่วไหลของสารเคมี
8	Overseas Fire Truck and Fire Pump													ฝึกซ้อมและแข่งขัน การใช้งานรถดับเพลิงและปั๊มดับเพลิง
9	Foam and Technical													ฝึกซ้อมและแข่งขัน การใช้งานโฟมและเทคนิคการดับเพลิง
10	Fire Alarm Systems													ฝึกซ้อมและแข่งขัน การใช้งานระบบแจ้งเหตุเพลิงไหม้
11	Performance Test All Subject													ทดสอบสมรรถภาพการปฏิบัติงาน
12	Performance Test All Subject													ทดสอบสมรรถภาพการปฏิบัติงาน

3.3 ข้อมูลการอบรมภายในประจำปี 2565

วันที่	ชนิด	หัวข้ออบรม	หมายเหตุ
15 ต.ค. 65	C	- Performance Test All Subject	-
16 ต.ค. 65	A	- Performance Test All Subject	-
17 ต.ค. 65	B	- Performance Test All Subject	-
17 ต.ค. 65	D	- Performance Test All Subject	-



4. การเตรียมความพร้อมรถดับเพลิงและอุปกรณ์ฉุกเฉิน ประจำศูนย์ควบคุมภาวะฉุกเฉิน

4.1 ข้อมูลรถดับเพลิง

ลำดับ	ชื่อรถดับเพลิง	ประจำสถานี	ประเภทรถ	ปริมาณสารดับเพลิง		หมายเหตุ
				น้ำ	โฟม / F500	เคมีแห้ง
1	รถดับเพลิง	PTT GC-2	Foam Truck	-	4,900 ลิตร	840 กก.
2	รถดับเพลิง	PTT GC-2	Foam Truck	-	3,785 ลิตร	810 กก.
3	รถดับเพลิง	PTT GC-3	Foam Truck	-	5,678 ลิตร	-
4	สายพาน	PTT GC-3	Water Truck	3,000 ลิตร	-	-
5	รถดับเพลิง	PTT GC-4	Foam Truck	-	3,785 ลิตร	750 กก.
6	รถดับเพลิง	PTT GC-4	Foam Truck	-	3,785 ลิตร	750 กก.
7	รถดับเพลิง	PTT GC-5	Foam Truck	-	3,785 ลิตร	750 กก.
8	รถดับเพลิง	PTT GC-5	Foam Truck	-	7,570 ลิตร	-
9	Tank Car	PTT GC-5	Water Truck	6,000 ลิตร	-	-
10	รถดับเพลิง	PTT GC-6	รถดับเพลิง	-	3,800 ลิตร	-
11	รถดับเพลิง	PTT GC-6	รถดับเพลิง	-	3,800 ลิตร	-
12	รถดับเพลิง	GCC2	รถดับเพลิง	-	3,800 ลิตร	-
13	รถดับเพลิง	PTT GC-6	รถดับเพลิง	-	7,600 ลิตร	-
14	รถดับเพลิง	PTT GC-6	Foam Truck	-	7,571 ลิตร	-
15	รถดับเพลิง	PTT GC-6	รถดับเพลิง	-	500 ลิตร	-
16	รถดับเพลิง	PTT GC-1	Foam Truck	-	5,678 ลิตร	-
17	รถดับเพลิง	PTT GC-1	Water Truck	5,678 ลิตร	-	-
18	รถดับเพลิง	PTT AC	Foam Truck	-	4,900 ลิตร	840 กก.
19	รถดับเพลิง	Dow All	Foam Truck	-	5,678 ลิตร	-
20	รถดับเพลิง	ECC	Foam Truck	-	3,785 ลิตร	810 กก.
21	รถดับเพลิง	ECC	รถดับเพลิง	-	2,000 ลิตร	-
22	รถดับเพลิง	ECC	รถดับเพลิง	4,500 ลิตร	1,500 ลิตร	-
23	Water Tank	ECC	Water Truck	7,000 ลิตร	-	-
24	รถดับเพลิง	Glow	Water Truck	12,000 ลิตร	-	-



ลำดับ	ชื่อรถดับเพลิง	ประจำสถานี	ประเภทรถ	ปริมาณสารดับเพลิง		หมายเหตุ
				น้ำ	โฟม / F500	เคมีแห้ง
25	รถดับเพลิง	ECC	รถดับเพลิง	-	-	-
26	รถดับเพลิง	ECC	รถดับเพลิง	400 ลิตร	20 ลิตร	-
27	รถดับเพลิง	ECC	รถดับเพลิง	-	-	-
28	รถดับเพลิง	ECC	รถดับเพลิง	-	-	-
29	รถดับเพลิง	ECC	รถดับเพลิง	-	-	-
30	รถดับเพลิง	ECC	รถดับเพลิง	-	-	-
31	รถดับเพลิง	ECC	รถดับเพลิง	-	-	-
32	รถดับเพลิง	ECC	รถดับเพลิง	500 ลิตร	12/12 ลิตร	-
33	รถดับเพลิง	ECC	รถดับเพลิง	-	-	-
34	รถดับเพลิง	ECC	รถดับเพลิง	-	-	-
35	รถดับเพลิง	ECC	รถดับเพลิง	-	-	-
36	รถดับเพลิง	ECC	รถดับเพลิง	-	-	-
37	รถดับเพลิง	ECC	รถดับเพลิง	-	-	-
38	รถดับเพลิง	ECC	รถดับเพลิง	-	-	-
39	รถดับเพลิง	ECC	รถดับเพลิง	-	-	-
40	รถดับเพลิง	ECC	รถดับเพลิง	-	-	-
41	รถดับเพลิง	ECC	รถดับเพลิง	300 ลิตร	12/12 ลิตร	-
42	รถดับเพลิง	ECC	รถดับเพลิง	-	-	-
43	รถดับเพลิง	ECC	รถดับเพลิง	-	-	-
44	รถดับเพลิง	ECC	รถดับเพลิง	1,000 ลิตร	-	-
Total				40,578 ลิตร	84,056 ลิตร	5,550 กก.

4.2 สรุปผลการตรวจสอบข้อมูลความพร้อมของอุปกรณ์สื่อสารประจำเดือน ธันวาคม 2565

รายการอุปกรณ์	สถานที่	สถานะ		หมายเหตุ
		พร้อมใช้	ไม่พร้อมใช้	
ระบบ โทรศัพท์				
- เลขหมาย 038-977799	ห้องสื่อสาร	✓		
- เลขหมาย 038-97764	ห้องสื่อสาร	✓		
- เลขหมาย 038-977615	ห้องสื่อสาร	✓		
- เลขหมาย 038-687678	ห้องสื่อสาร	✓		
แฟกซ์ 038-687677	ห้องสื่อสาร	✓		
ระบบวิทยุสื่อสาร และระบบ Integrate สัญญาณ				
- ชุดวิทยุควบคุมระบบสื่อสาร	ห้อง War room	✓		
วิทยุ V/U-F	ห้องสื่อสาร	✓		
วิทยุ U-F	ห้องสื่อสาร	✓		
- ขั้วสาย Tunk	ห้องสื่อสาร	✓		
- ขั้วสาย CR 245	ห้องสื่อสาร	✓		
ระบบ VDO Conference	ห้อง War room	✓		
ระบบ Fire Alarm	ห้องสื่อสาร	✓		
ระบบ CCTV	ห้องสื่อสาร	✓		

4.3 สรุปข้อมูลอุปกรณ์ ชุดดับเพลิง และ SCBA

รายการอุปกรณ์	สถานที่	สถานะ		หมายเหตุ
		พร้อมใช้งาน	ไม่พร้อมใช้งาน	
SCBA	ศูนย์ ECC	✓		
ชุดดับเพลิง	ศูนย์ ECC	✓		
ระบบถังเก็บ และตรวจวัดสภาพอากาศ	ศูนย์ ECC	✓		
อุปกรณ์การกู้ภัยที่สูง	ศูนย์ ECC	✓		

[illegible]



SAP Number

WATER SPRAY (HT) จำนวน 47 ตัว

ที่	No.	สถานที่	มาตรฐานการตรวจ	ผลการตรวจพบ หรือไม่มีข้อบกพร่อง	สิ่งผิดปกติพบ	ผู้ตรวจสอบ
1	T-6940-1	T-6940	1.Main Valve เปิด	✓		
2	T-6940-2	T-6940	2.Water Supply ปิด	✓		
3	T-6945 A/1	T-6945 A	3.Drain Valve 2.5" ปิดไว้	✓		
4	T-6945 A/2	T-6945 A	4.สวิตช์จ่าย น้ำที่สถานี	✓		
5	T-6945 B/1	T-6945 B	5. ไม่มีการรั่วไหล Valve ที่ข้อต่อ	✓		
6	T-6945 B/2	T-6945 B	ข้อต่อ 1	✓		
7	PM-6945 A/08-1	PM-6945		✓		
8	PM-6945 A/08-2	PM-6945		✓		
9	O-FA811A-1	O-FA811A		✓		
10	O-FA811A-2	O-FA811A		✓		
11	O-FA811B-1	O-FA811B		✓		
12	O-FA811B-2	O-FA811B		✓		
13	O-FA811C-1	O-FA811C		✓		
14	O-FA811C-2	O-FA811C		✓		
15	O-FA811D-1	O-FA811D		✓		
16	O-FA811D-2	O-FA811D		✓		
17	O-FA811E-1	O-FA811E		✓		
18	O-FA811E-2	O-FA811E		✓		
19	O-FA811F-1	O-FA811F		✓		
20	O-FA811F-2	O-FA811F		✓		
21	O-FA801A-1	O-FA801A		✓		
22	O-FA801A-2	O-FA801A		✓		
23	O-FA801A-3	O-FA801A		✓		
24	O-FA801A-4	O-FA801A		✓		
25	O-FA801C-1	O-FA801C		✓		
26	O-FA801C-2	O-FA801C		✓		
27	O-FA801C-3	O-FA801C		✓		
28	O-FA801C-4	O-FA801C		✓		
29	O-FA801D-1	O-FA801D		✓		

บันทึกผลการตรวจ

ที่	No.	สถานที่	มาตรฐานการตรวจ	ผลการตรวจพบ หรือไม่มีข้อบกพร่อง	สิ่งผิดปกติพบ	ผู้ตรวจสอบ
1	81	1	Portable Dry chemical	✓		
2	26	2	Portable Carbon Dioxide	✓		
3	8	3	Wheel Dry Chemical	✓		
4	27	4	Hydrant (HT)	✓		
5	28	5	Hydrant With Monitor (HTM)	✓		
6	17	6	Water Monitor (WMT)	✓		
7	4	7	Foam Hydrant (FHT)	✓		
8	52	8	Hose House	✓		
9	6	9	Hose Box	✓		
10	69	10	Fire Break Glass	✓		
11	3	11	Mobile Foam	✓		
12	1	12	Foam Storage Tank	✓		
13	3	13	Foam Bladder Tank	✓		
14	25	14	Deluge Valve	✓		
15	45	15	Water Spray	✓		
16	12	16	SCBA	✓		
17	12	17	Fire Protection Clothing	✓		
18	2	18	Emergency Escape	✓		
19	3	19	Fire Blanket	✓		
20	1	20	Fire Axe	✓		
21	2	21	CO2 System	✓		
22	1	22	FM200 System	✓		
23	2	23	Inergen System	✓		
24	2	24	Fixed Dry Chemical System	✓		
25	2	25	Water Curtain	✓		
26	3	26	Water Monitor Remote	✓		

Note : I = Inspection

W = ด้วยวิธี

F = Flush line & Exercise

T = Test

บันทึกผลการตรวจ PTTGC-7 14-11-2565

SAP Number:

CO₂ PORTABLE (BTF) จำนวน 19 ถัง

SAP Number

Dry Chemical Storage Pressure (BRI) 0.140 0.140

[illegible]

บทที่ ๖ การจัดการทรัพยากร

2000 2001 2002

2000 2001 2002

2000 2001 2002

ที่	No.	สถานที่	หมายเหตุการตรวจพบ	ผลการตรวจพบ ข้อบกพร่อง	ผู้รับผิดชอบ
1	D-02	Meching	1. มี Safety Pin ที่ล็อกไว้และมี Seal Lock ที่ล็อกไว้	✓	
2	D-05	South Metaling	2. ลานจอดไม่ถูกล็อกไปตลอดมา	✓	
3	D-06	O-FA821	3. มีที่เก็บเศษเหล็ก และเศษเหล็กอื่น	✓	
4	D-07	O-FA821	4. มีเศษเหล็ก	✓	
5	D-09	O-FA811A	5. มีเศษเหล็ก	✓	
6	D-10	O-FA811C	6. มีเศษเหล็ก	✓	
7	D-11	O-FA811C	7. มีเศษเหล็ก	✓	
8	D-12	O-FA811C	8. มีเศษเหล็ก	✓	
9	D-13	O-FA811D	9. มีเศษเหล็ก	✓	
10	D-15	O-FA811D	10. มีเศษเหล็ก	✓	
11	D-16	T-6966A	11. มีเศษเหล็ก	✓	
12	D-17	T-6966A	12. มีเศษเหล็ก	✓	
13	D-18	O-FA811C	13. มีเศษเหล็ก	✓	
14	D-21	O-FA811B	14. มีเศษเหล็ก	✓	
15	D-23	O-FA811B	15. มีเศษเหล็ก	✓	
16	D-24	O-FA811D	16. มีเศษเหล็ก	✓	
17	D-36	T-6982	17. มีเศษเหล็ก	✓	
18	D-37	T-6982	18. มีเศษเหล็ก	✓	
19	D-38	O-FA811F	19. มีเศษเหล็ก	✓	
20	D-39	OCH (ถังเก็บน้ำ)	20. มีเศษเหล็ก	✓	
21	D-40	CCR (ถังเก็บน้ำ)	21. มีเศษเหล็ก	✓	
22	D-41	CCB (ถังเก็บน้ำ)	22. มีเศษเหล็ก	✓	
23	D-42	CCR (ถังเก็บน้ำ)	23. มีเศษเหล็ก	✓	
24	D-43	Work Shop	24. มีเศษเหล็ก	✓	
25	D-47	Truck Load	25. มีเศษเหล็ก	✓	
26	D-50	Sea Fire Pump	26. มีเศษเหล็ก	✓	
27	D-51	SOL6903	27. มีเศษเหล็ก	✓	
28	D-54	O-FA811D	28. มีเศษเหล็ก	✓	
29	D-55	T-6949A	29. มีเศษเหล็ก	✓	
30	D-56	T-6949A	30. มีเศษเหล็ก	✓	

๗. ฐานข้อมูลภูมิสารสนเทศ

2000 年 11 月

2000 年 11 月

2000 2001 2002

SAP Number

Dry Chemical Storage Pressure (RTF) จำนวน 40 ถัง

[illegible]

ป้าก็ช่วยหาเงินให้

บันทึกที่นาย/นางแม่/.....
๒๕๕๓ กรุงเทพมหานคร

SAP Number:

Dry Chemical Cartridge Operate (BTR) จำนวน 27 ถึง

ที่	No.	สถานที่	รายการตรวจสอบ	น้ำหนัก Cartridge	น้ำหนัก ถังใส่	ขนาดของหลอด พร้อมถังใส่ ถังพร้อมใช้	สิ่งส่งกลับให้พบ
1	D-01	สถานีไฟฟ้าเขม	1. มี Safety Pin ที่ล็อกและหนี	769 g.		✓	
2	D-01	จุดตั้งเครื่อง	Seat Lock เข็มร้อย	776 g.		✓	
3	D-04	จุดตั้งเครื่อง	2. ถาสีดำไม่ถูกน้ำ/ไม่โดนแดด	737 g.		✓	
4	D-08	O-1A11A	3. มีที่เก็บสายหนี และสายรัดที่เก็บ	758 g.		✓	
5	D-14	T-801C	มีสายร้อย	783 g.		✓	
6	D-19	T-6845B (Top)	4. ถังและสายร้อยอยู่ในเกณฑ์ไม่	812 g.		✓	
7	D-29	T-6945A (Top)	เป็นสมิและสายหนีมีขีดวง	820 g.		✓	
8	D-22	O-FA811B	5. มีน้ำหนัก Cartridge ต้องไม่	804 g.		✓	
9	D-25	T-6945A	น้อยกว่า 667 กรัม (ถัง 20 ปอนด์,	776 g.		✓	
10	D-26	PK-6945B	418 กรัม (ถัง 10 ปอนด์)	783 g.		✓	
11	D-27	T-6940	6. หัวถังเก็บให้คนกรีนหลัง	787 g.		✓	
12	D-28	Camp House	ทุกชั้นแล้ว	755 g.		✓	
13	D-29	Camp House	7. หัวถังและสายร้อยอยู่กับถัง	769 g.		✓	
14	D-30	Camp House	ค้ำยันหลังทงานี่มีขีดวง	758 g.		✓	
15	D-31	Camp House	8. ค้ำยันหลัง Seat Indicator มี	776 g.		✓	
16	D-32	Camp House	ขีดวงต้องไม่ติดตัวถัง (ถังคือตัว	773 g.		✓	
17	D-33	T-6940	เชื่อมสายจากถังกับสายกับหลอด	808 g.		✓	
18	D-34	V-5301	Cartridge เข้าไปแล้ว	787 g.		✓	
19	D-35	T-5301		751 g.		✓	
20	D-34	Tire Pump		773 g.		✓	
21	D-43	Gate-2		780 g.		✓	
22	D-46	Track land		769 g.		✓	
23	D-48	ถนนทาง		761 g.		✓	
24	D-49	Sea Fire Pump		773 g.		✓	
25	D-52	Sea Fire Pump		801 g.		✓	
26	D-53	Gate-5		818 g.		✓	
27	D-65	Gate-2		-		✓	

บันทึกที่หา(ทราบ)มา ๖๕๓ ระบุชื่อ/เลขที่/วันออก

วันที่ ๑๕ กรกฎาคม ๒๕๖๓



SAP Number _____

WHEELED FIRE EXTINGUISHERS (WTF) จำนวน 6 คัน

ที่	No.	ยี่ห้อ	หมายเลขการตรวจรถ	แรงดัน N2	ถังดับ CO2	สภาพความพร้อมใช้งาน		ถังเก็บแก๊ส	ผู้ตรวจสอบ (ตัวหนังสือ)
						พร้อมใช้	ไม่พร้อมใช้		
1	WD-001	FA-SU-A	1. Nitrogen Cylinder แรงดัน 150 บาร์	✓	✓	✓			
2	WD-002	FA-R02	ถังดับ 1,500 PSI หรืออยู่ใน Range ที่กำหนดไว้ในใบ	✓	✓	✓			
3	WD-003	Tank load	ใบ (WFOC-HIT 01, 02, 04, 06)	✓	✓	✓			
4	WD-004	J-5701B	2.5% CO2 ที่น้ำหนักของ	✓	✓	✓			
5	WD-005	Compressor	ใบ 10% (BDC-HIT 02, 05)	✓	✓	✓			
6	WD-006	SVIRO 800	3. Seal Nitrogen Cylinder ไม่						
			พบ						
			4. ตัวถังไม่บุบสดี						
			5. 1. Two Assembly (1.1) x 15						
			04 ไม่ถูกต้อง						
			6. Red Indicator Stem อยู่						
			ด้านข้างถัง						
			7. จอภาพไม่ติด						

บันทึกข้อมูลตามข้อ

ถังเก็บแก๊ส

SCBA FIRE FIGHTING BTH (จำนวน 6 Set)

ที่	No.	ยี่ห้อ	หมายเลขการตรวจรถ	แรงดัน (BAR)	พร้อมใช้	ไม่พร้อมใช้	ถังเก็บแก๊ส	ผู้ตรวจสอบ (ตัวหนังสือ)
1	SCBA-01	CCB	1. ถังและ Valve อยู่ในสภาพที่	✓	✓			
2	SCBA-02	CCB	2. แรงดันไม่ต่ำกว่า 270 Bar	✓	✓			
3	SCBA-03	CCB	3. สายคล้องไม่ขาด	✓	✓			
4	SCBA-04	CCB	4. พกแก๊สไม่รั่วซึมจนเกินไป	✓	✓			
5	SCBA-05	CCB	5. สายรัดข้อมืออยู่ในสภาพพร้อมใช้	✓	✓			
6	SCBA-06	CCB	6. ถังเก็บแก๊สอยู่ในสภาพดี	✓	✓			
			SO Bar จะต้องมี Alarm 44					

ถังเก็บแก๊ส



SAP Number

FIRE HOSE HOUSE (RIF) ချောက် ၁၀ ခု

[illegible]

၂၂။ ယူနိုက်တက်ကမ္ဘာ့ကျန်းမာရေးအဖွဲ့ချုပ်



SAP Number

FIRE HOSE BOX (BTF) จำนวน 1 ชุด

[illegible]

RECEIVED/RECEIVED



SAP Number

Hydrant With Monitor (BTF) จำนวน 27 ตัว

ที่	No.	สถานที่	รายละเอียดการตรวจสอบ	ผลการตรวจสอบ		สิ่งผิดปกติที่พบ	ผู้ตรวจสอบ (ตัวตรวจสอบ)
				ครบ	ไม่ครบ		
1	HTM-01	FEN-FAN	1. Nozzle จะดึงไม่ขึ้น	✓		ดึงขึ้น	
2	HTM-02	O-FAN-11C	อุปกรณ์ครบ	✓		ครบ	
3	HTM-03	T-6980	2. Handle Operation Level จะขึ้น	✓		ขึ้น	
4	HTM-04	V-6923	3. Screw Lock Handle Cummer จะล็อก	✓		ล็อก	
5	HTM-05	FAN-891	4. Battery Valve จะล็อก	✓		ล็อก	
6	HTM-06	T-811-A	5. Main Valve จะล็อก	✓		ล็อก	
7	HTM-07	O-FAN-11C	6. Pumper Connection Valve 4 จะล็อก	✓		ล็อก	
8	HTM-08	O-FAN-11C	7. Connection Valve จะล็อก	✓		ล็อก	
9	HTM-09	T-6940	8. Handle Operation Level จะขึ้น	✓		ขึ้น	
10	HTM-10	Measuring	9. Battery Valve จะล็อก	✓		ล็อก	
11	HTM-11	O-FAN-11D	10. Main Valve จะล็อก	✓		ล็อก	
12	HTM-12	T-6940B	11. Pumper Connection Valve 4 จะล็อก	✓		ล็อก	
13	HTM-13	T-801D	12. Connection Valve จะล็อก	✓		ล็อก	
14	HTM-14	O-FAN-11D	13. Handle Operation Level จะขึ้น	✓		ขึ้น	
15	HTM-15	Measuring	14. Battery Valve จะล็อก	✓		ล็อก	
16	HTM-16	Measuring	15. Main Valve จะล็อก	✓		ล็อก	
17	HTM-17	T-6940B	16. Pumper Connection Valve 4 จะล็อก	✓		ล็อก	
18	HTM-18	T-801D	17. Connection Valve จะล็อก	✓		ล็อก	
19	HTM-19	Measuring	18. Handle Operation Level จะขึ้น	✓		ขึ้น	
20	HTM-20	T-6940B	19. Battery Valve จะล็อก	✓		ล็อก	
21	HTM-21	O-FAN-11D	20. Main Valve จะล็อก	✓		ล็อก	
22	HTM-22	T-6981	21. Pumper Connection Valve 4 จะล็อก	✓		ล็อก	
23	HTM-23	T-6981	22. Connection Valve จะล็อก	✓		ล็อก	
24	HTM-24	T-6981	23. Handle Operation Level จะขึ้น	✓		ขึ้น	
25	HTM-25	T-6983	24. Battery Valve จะล็อก	✓		ล็อก	
26	HTM-26	T-6983	25. Main Valve จะล็อก	✓		ล็อก	
27	HTM-27	T-6983	26. Pumper Connection Valve 4 จะล็อก	✓		ล็อก	

บันทึกผลการตรวจสอบ

บันทึกผลการตรวจสอบ

SAP Number

Fixed Monitor (BTF) จำนวน 17 ตัว

ที่	No.	สถานที่	รายละเอียดการตรวจสอบ	ผลการตรวจสอบ		สิ่งผิดปกติที่พบ	ผู้ตรวจสอบ (ตัวตรวจสอบ)
				ครบ	ไม่ครบ		
1	WMT-01	T-6966A	1. Main Valve ปิด	✓			
2	WMT-02	T-6966A	2. Monitor Nozzle ปรับได้	✓			
3	WMT-03	T-811-F	3. Handle Operation Level จะขึ้น	✓			
4	WMT-04	T-821	4. Battery Valve จะล็อก	✓			
5	WMT-05	T-811-F	5. Main Valve จะล็อก	✓			
6	WMT-06	T-801E	6. Pumper Connection Valve 4 จะล็อก	✓			
7	WMT-07	T-801D	7. Connection Valve จะล็อก	✓			
8	WMT-08	O-FAN-801C	8. Handle Operation Level จะขึ้น	✓			
9	WMT-09	O-FAN-801B	9. Battery Valve จะล็อก	✓			
10	WMT-10	O-FAN-801B	10. Main Valve จะล็อก	✓			
11	WMT-11	BTF	11. Pumper Connection Valve 4 จะล็อก	✓			
12	WMT-12	T-801-A	12. Connection Valve จะล็อก	✓			
13	WMT-13	Tack Load	13. Handle Operation Level จะขึ้น	✓			
14	WMT-14	T-811	14. Battery Valve จะล็อก	✓			
15	WMT-15	T-801-A	15. Main Valve จะล็อก	✓			
16	WMT-16	T-801-A	16. Pumper Connection Valve 4 จะล็อก	✓			
17	WMT-17	T-6966B	17. Connection Valve จะล็อก	✓			

SAP Number

HYDRANT (BTF) จำนวน 22 ตัว

FOAM STORAGE TANK V-6925-04 (BTF) จำนวน : ๓

ที่	No.	ทวนที่	มาตรฐานการตรวจ	อุปกรณ์	ผลการทดสอบ	ผู้ตรวจสอบ (วัน/เวลา)
				ครบ	พร้อมใช้	
1	HT-01	ห้องเก็บ Fire man	1 Valve line discharge 2.5 นิ้ว	✓	✓	
2	HT-02	T-6983 02A	จะตั้งอยู่ปากถังหมักน้ำและยี่	✓	✓	
3	HT-03	T-8 11'	Cap ปิดถัง Line Discharge ที่ถัง	✓	✓	
4	HT-04	หน่วยวัด ความดัน	ไม่ได้ใช้หรือขณะมีไฟ ถัดจากนี้	✓	✓	
5	HT-05	หน่วยวัด ความดัน	2 ชุด	✓	✓	
6	HT-06	หน่วยวัด ความดัน	2 หน่วยภายนอกเตาไม่ใช้งาน	✓	✓	
7	HT-07	หน่วยวัด ความดัน	และ ไม่ใช้เตาเดิม	✓	✓	
8	HT-08	T-811	3 เมตรกับขนาด 1 นิ้วใช้งาน และ	✓	✓	
9	HT-09	CDS ตัว	ไม่ใช่ปกติ	✓	✓	
10	HT-10	T-6980		✓	✓	
11	HT-11	T-6980		✓	✓	
12	HT-12	Fire Pump		✓	✓	
13	HT-13	T-6980		✓	✓	
14	HT-14	T-6980		✓	✓	
15	HT-15	Pd-6980F		✓	✓	
16	HT-16	T-6983A		✓	✓	
17	HT-17	T-6983A		✓	✓	
18	HT-18	ลิฟท์คนลง C		✓	✓	
19	HT-19	ลิฟท์ประตู่ F-5		✓	✓	
20	HT-20	ลิฟท์คนลง R-5		✓	✓	
21	HT-21	Truck Load		✓	✓	
22	HT-22	T-69-6AA/B		✓	✓	

ได้แก่การนำเอา...

บ้างก็คิดขึ้นๆการแต่งใจ

[illegible]

บ้างก็คิดขึ้นๆการแต่งใจ

SAP Number

FOAM BLADDER TANK O-FAS30 (BIF) จำนวน 1 ถัง

[illegible]

มีผลทำให้สุขภาพจิตดีขึ้น.....

SAP Number

Inergen System (CCB)

[illegible]

ข้าพเจ้าทำนุบำรุงการเผย

CO2 System Substation-6914

[illegible]



As of :09/06/65
Rev. 02



As of :09/06/65
Rev. 02

SAP Number

JM-200 System Substation-6914_BT

ที่	No.	สถานที่	หมายเหตุ/รายการตรวจสอบ	สถานะ/Drive (แรงดัน)	พบข้อบกพร่องหรือไม่	ผู้ตรวจสอบ
1. JM200 Cylinder แรงดันในถัง						
1	Main 001 A	DCS Room	ถัง 100 PSI. ตั้งไว้เป็นปกติ	✓		
2	Main 001 B	Battery Room		✓		
3	Reserve 001	DCS Room		✓		
4	Reserve 001	Battery Room		✓		
2. Control Panel						
1	Power on		2. Control Panel Power On ปกติ	✓		
3. Electric Control Head						
1	Main-ECS-01		3. Electric Control Head ปกติ	✓		
2	Main-ECS-02		ไม่พบ SET	✓		
3	Reserve-ECS-01			✓		
4	Reserve-ECS-02			✓		
4. Manual Released						
1	DCS-MR-01		4. Manual Release ปกติพร้อม	✓		
2	BT-MR-01		ใช้ตามใบสั่งชุดตรวจ	✓		
5. Abort Switch						
1	DCS-AB-01		5. Abort Switch สามารถล็อกได้	✓		
2	BT-AB-01		จากใบสั่งชุดตรวจ	✓		
6. Pressure Switch						
1	DCS-PSM-01		6. Pressure Switch สามารถพร้อม	✓		
2	DCS-PSR-01		ใช้ตามใบสั่งชุดตรวจ	✓		
3	BT-PSM-01			✓		
4	BT-PSR-01			✓		

วันที่ผู้ตรวจสอบแก้ไข

วันที่

วันที่

SAP Number

CO2 PORTABLE (Jelly) จำนวน 8 ถัง

ที่	No.	สถานที่	หมายเหตุ/รายการตรวจสอบ	น้ำหนัก (กก.)	ถังมีน้ำ	ผลการตรวจ	ผู้ตรวจสอบ
1. เจลลี่ CO2 ในห้อง							
1	J1-CO-01	JETTY-1 LV-Room	1. เจลลี่ CO2 ในห้อง	33.0	✓		
2	J1-CO-02	JETTY-1 LV-Room	2. เจลลี่ CO2 ในห้อง	26.3	✓		
3	J1-CO-03	JETTY-1 LV-Room	3. เจลลี่ CO2 ในห้อง	33.9	✓		
4	J1-CO-04	JETTY-1 CCR	4. เจลลี่ CO2 ในห้อง	47.7	✓		
5	J1-CO-05	JETTY-1 ห้องทำงาน	5. เจลลี่ CO2 ในห้อง	26.3	✓		
6	J1-CO-06	JETTY-1 ห้องควบคุม	6. เจลลี่ CO2 ในห้อง	26.1	✓		
7	J1-CO-07	JETTY-1 HV-Room	7. เจลลี่ CO2 ในห้อง	26.3	✓		
8	J2-CO-01	JETTY-2 HV-Room	8. เจลลี่ CO2 ในห้อง	44.3	✓		
9			9. เจลลี่ CO2 ในห้อง				
10			10. เจลลี่ CO2 ในห้อง				
11			11. เจลลี่ CO2 ในห้อง				
12			12. เจลลี่ CO2 ในห้อง				
13			13. เจลลี่ CO2 ในห้อง				
14			14. เจลลี่ CO2 ในห้อง				
15			15. เจลลี่ CO2 ในห้อง				
16			16. เจลลี่ CO2 ในห้อง				
17			17. เจลลี่ CO2 ในห้อง				
18			18. เจลลี่ CO2 ในห้อง				
19			19. เจลลี่ CO2 ในห้อง				
20			20. เจลลี่ CO2 ในห้อง				
21			21. เจลลี่ CO2 ในห้อง				
22			22. เจลลี่ CO2 ในห้อง				
23			23. เจลลี่ CO2 ในห้อง				
25			25. เจลลี่ CO2 ในห้อง				
26			26. เจลลี่ CO2 ในห้อง				
27			27. เจลลี่ CO2 ในห้อง				
28			28. เจลลี่ CO2 ในห้อง				
29			29. เจลลี่ CO2 ในห้อง				

วันที่ผู้ตรวจสอบแก้ไข



SAP Number

MANUAL FIRE ALARM STATION (Jelly) จำนวน 24 ตัว

ที่	No.	สถานที่	มาตรฐานการตรวจสอบ	สถานที่ไม่ ปกติ	สังเกต	ผู้ตรวจสอบ (ตัวบรรจง)
1	BGU-734	หน้าห้อง UPS (ICS)	มาตรฐานการตรวจสอบ 1. ตรวจสอบใบตรวจ, ก้อน, ไข่ มีครบ 2. มาตรฐานการติดตั้งไฟส่องสว่าง และไฟฉุกเฉิน 3. ฟ้าตัดสัญญาณแจ้งเตือนใน ห้อง มอสมกัมมสันนิบาต 4. ไข่ไฟส่องสว่างในห้องควบคุม การตัดสินใจ 5. มาตรฐานการติดตั้งตู้ควบคุม Alarm สำรองที่ทำการ ตัวบ่งชี้สถานะ CCS 6. ไข่ไฟส่องสว่างในห้อง ควบคุมการตัดสินใจ 7. ไข่ไฟส่องสว่างในห้อง ควบคุมการตัดสินใจ 8. ไข่ไฟส่องสว่างในห้อง ควบคุมการตัดสินใจ 9. ไข่ไฟส่องสว่างในห้อง ควบคุมการตัดสินใจ 10. ไข่ไฟส่องสว่างในห้อง ควบคุมการตัดสินใจ 11. ไข่ไฟส่องสว่างในห้อง ควบคุมการตัดสินใจ 12. ไข่ไฟส่องสว่างในห้อง ควบคุมการตัดสินใจ 13. ไข่ไฟส่องสว่างในห้อง ควบคุมการตัดสินใจ 14. ไข่ไฟส่องสว่างในห้อง ควบคุมการตัดสินใจ 15. ไข่ไฟส่องสว่างในห้อง ควบคุมการตัดสินใจ 16. ไข่ไฟส่องสว่างในห้อง ควบคุมการตัดสินใจ 17. ไข่ไฟส่องสว่างในห้อง ควบคุมการตัดสินใจ 18. ไข่ไฟส่องสว่างในห้อง ควบคุมการตัดสินใจ 19. ไข่ไฟส่องสว่างในห้อง ควบคุมการตัดสินใจ 20. ไข่ไฟส่องสว่างในห้อง ควบคุมการตัดสินใจ 21. ไข่ไฟส่องสว่างในห้อง ควบคุมการตัดสินใจ 22. ไข่ไฟส่องสว่างในห้อง ควบคุมการตัดสินใจ 23. ไข่ไฟส่องสว่างในห้อง ควบคุมการตัดสินใจ 24. ไข่ไฟส่องสว่างในห้อง ควบคุมการตัดสินใจ	✓		
2	BGU-735	หน้าห้อง Battery (ICS)		✓		
3	BGU-736	ในห้อง Battery (ICS)		✓		
4	BGU-737	หน้าห้อง HV		✓		
5	BGU-739	หน้าห้อง HV		✓		
6	BGU-740	หน้าห้อง HV		✓		
7	BGU-741	หน้าห้อง HV		✓		
8	BGU-742	หน้าห้อง HV		✓		
9	BGU-743	หน้าห้อง HV		✓		
10	BGU-744	หน้าห้อง HV		✓		
11	BGU-745	หน้าห้อง HV		✓		
12	BGU-746	หน้าห้อง HV		✓		
13	BGU-747	หน้าห้อง HV		✓		
14	BGU-748	หน้าห้อง HV		✓		
15	BGU-749	หน้าห้อง HV		✓		
16	BGU-750	หน้าห้อง HV		✓		
17	BGU-751	หน้าห้อง HV		✓		
18	BGU-755	หน้าห้อง HV		✓		
19	BGU-756	หน้าห้อง HV		✓		
20	BGU-757	หน้าห้อง HV		✓		
21	BGU-758	หน้าห้อง HV		✓		
22	BGU-01	Jelly-2		✓		
23	BGU-02	Jelly-2		✓		
24	BGU-03	Jelly-2		✓		

ผู้ตรวจสอบ

ผู้ตรวจสอบ



SAL Number

FIRE HOSE BOX (Jeffy) จำนวน 7 ชุด

SAP Number

HYDRANT (Jelly) จำนวน 5 ตัว

[illegible]

จำนวนที่แสดงบนผิว

60-1017-100

ملک

$\frac{d}{dt} \left(\frac{1}{\rho} \right) = - \frac{1}{\rho^2} \frac{d\rho}{dt}$

1712

[illegible]

เรามีอีกหลายๆคนครับ

ملک

$\frac{d}{dt} \left(\frac{1}{\rho} \right) = - \frac{1}{\rho^2} \frac{d\rho}{dt}$

1712



SAP Number _____

HYDRANT FOAM (Jelly) จำนวน 4 ตัว

ร.ร.	No.	สถานที่	มาตรฐานตรวจสอบ	จุดตรวจ		ผลการตรวจสอบ		ผู้ตรวจสอบ (เซ็นรับรอง)
				ครบ	ไม่ครบ	พร้อมใช้	ไม่พร้อมใช้	
1	31-4TF-01	JETTY-1	1. Valve Line Discharge 2.5 นิ้ว	✓	✓	✓		[Redacted]
2	11-4TF-02	JETTY-1	ตรวจสอบอยู่ในส่วนเก็บน้ำ (ถังเก็บน้ำ)	✓	✓	✓		
3	32-4TF-01	JETTY-2	Cap ปิดสนิท และ discharge มีแรงดัน	✓		✓		
4	17-1TF-02	JETTY-4	ไม่มีน้ำรั่วซึมตามถังเก็บน้ำ	✓		✓		
			2. ถังเก็บน้ำ					
			3. ถังเก็บน้ำ					
			4. ถังเก็บน้ำ					
			5. ถังเก็บน้ำ					
			6. ถังเก็บน้ำ					
			7. ถังเก็บน้ำ					
			8. ถังเก็บน้ำ					
			9. ถังเก็บน้ำ					
			10. ถังเก็บน้ำ					
			11. ถังเก็บน้ำ					
			12. ถังเก็บน้ำ					
			13. ถังเก็บน้ำ					
			14. ถังเก็บน้ำ					
			15. ถังเก็บน้ำ					
			16. ถังเก็บน้ำ					
			17. ถังเก็บน้ำ					
			18. ถังเก็บน้ำ					
			19. ถังเก็บน้ำ					
			20. ถังเก็บน้ำ					
			21. ถังเก็บน้ำ					
			22. ถังเก็บน้ำ					
			23. ถังเก็บน้ำ					
			24. ถังเก็บน้ำ					
			25. ถังเก็บน้ำ					
			26. ถังเก็บน้ำ					
			27. ถังเก็บน้ำ					
			28. ถังเก็บน้ำ					
			29. ถังเก็บน้ำ					
			30. ถังเก็บน้ำ					

บันทึกผลการตรวจ



วันที่

วันที่



SAP Number _____

Hydrant With Monitor (Jelly) จำนวน 1 ตัว

ร.ร.	No.	สถานที่	มาตรฐานตรวจสอบ	จุดตรวจ		ผลการตรวจสอบ	ผู้ตรวจสอบ (เซ็นรับรอง)
				ครบ	ไม่ครบ	พร้อมใช้	
1	HTM-01	Jetty-2	1. Nozzle ตรวจสอบว่ามีแรงดัน	✓		✓	[Redacted]
2			2. Handle Operation Level				
3			3. Securi Lock Handle Control				
4			4. Battery Valve ตรวจสอบไม่				
5			5. Securi Valve ตรวจสอบไม่				
6			6. Securi Valve ตรวจสอบไม่				
7			7. Securi Valve ตรวจสอบไม่				
8			8. Securi Valve ตรวจสอบไม่				
9			9. Securi Valve ตรวจสอบไม่				
10			10. Securi Valve ตรวจสอบไม่				
11			11. Securi Valve ตรวจสอบไม่				
12			12. Securi Valve ตรวจสอบไม่				
13			13. Securi Valve ตรวจสอบไม่				
14			14. Securi Valve ตรวจสอบไม่				
15			15. Securi Valve ตรวจสอบไม่				
16			16. Securi Valve ตรวจสอบไม่				
17			17. Securi Valve ตรวจสอบไม่				
18			18. Securi Valve ตรวจสอบไม่				
19			19. Securi Valve ตรวจสอบไม่				
20			20. Securi Valve ตรวจสอบไม่				
21			21. Securi Valve ตรวจสอบไม่				
22			22. Securi Valve ตรวจสอบไม่				
23			23. Securi Valve ตรวจสอบไม่				
24			24. Securi Valve ตรวจสอบไม่				
25			25. Securi Valve ตรวจสอบไม่				
26			26. Securi Valve ตรวจสอบไม่				
27			27. Securi Valve ตรวจสอบไม่				
28			28. Securi Valve ตรวจสอบไม่				
29			29. Securi Valve ตรวจสอบไม่				
30			30. Securi Valve ตรวจสอบไม่				

บันทึกผลการตรวจ



วันที่

วันที่

SAP Number

Emergency Escape (.fetty) จำนวน 2 Set

[illegible]

Thyristor

SAP Number:

FOAM STORAGE TANK (Jetty) จำนวน 2 ถัง

[illegible]

10. การดำเนินงาน



SAP Number

WATER CURTAIN (Jetty) จำนวน 2 ตัว

ที่	รหัส	สถานที่	หมายเลขการตรวจสอบ	คุณภาพ		ผู้ตรวจสอบ (ตัวตรวจสอบ)
				ข้อบกพร่อง	ผู้สังเกตการณ์	
1	WTC-001	Jetty-1	1. Main Valve ปิด	✓	✓	[Redacted]
2	WTC-002	Jetty-2	2. ถ้ามีข้อบกพร่อง ให้แก้ไข	✓	✓	
			3. ถ้ามีข้อบกพร่อง Nozzle			

บันทึกผู้ตรวจสอบ




SAP Number

Dry Chemical Powder System P-6827 (Jetty-1)

ที่	No.	สถานที่	มาตรฐานการตรวจสอบ	หมายเหตุ	พบข้อบกพร่องหรือไม่	พบข้อบกพร่องหรือไม่	ผู้ตรวจสอบ (ตัวตรวจสอบ)
1. Nitrogen Cylinder							
1	N2-CL-01	Jetty-1	1. Nitrogen Cylinder มีระดับไนโตรเจน เกณฑ์ 50% ขึ้นไป				
2	N2-CL-02	Jetty-1					
3	N2-CL-03	Jetty-1					
4	N2-CL-04	Jetty-1					
5	N2-CL-05	Jetty-1					
6	N2-CL-06	Jetty-1					
7	N2-CL-07	Jetty-1					
8	N2-CL-08	Jetty-1					
9	N2-CL-09	Jetty-1					
10	N2-CL-10	Jetty-1					
2. Nitrogen Cylinder มีระดับไนโตรเจน เกณฑ์ 50% ขึ้นไป							
1	T-NB-01	Jetty-1					
2	T-NB-02	Jetty-1					
3. Hose Reel							
1	P-6833	Jetty-1					
4. Dry Monitor Nozzle							
1	DM-6833	Jetty-1					

บันทึกผู้ตรวจสอบ





SAP Number

Dry Chemical Powder System F-6828 (Jett-I)

ที่	No.	ตามข้อ	หมายเหตุ/ตรวจสอบ	น้ำหนัก/ขนาด/ค่า	ผลการใช้	ผู้ตรวจสอบ
1. Nitrogen Cylinder						
1	N2-CL-01	Jelly-1	1. Nitrogen Cylinder 1 ตามข้อ 1 ไม่ผ่าน ทดสอบ ไม่เป็นระเบียบ	OK	✓	
2	N2-CL-02	Jelly-1		OK	✓	
3	N2-CL-03	Jelly-1		OK	✓	
4	N2-CL-04	Jelly-1		OK	✓	
5	N2-CL-05	Jelly-1		OK	✓	
6	N2-CL-06	Jelly-1		OK	✓	
7	N2-CL-07	Jelly-1		OK	✓	
8	N2-CL-08	Jelly-1		OK	✓	
9	N2-CL-09	Jelly-1		OK	✓	
10	N2-CL-10	Jelly-1		OK	✓	
2. N2 Bomb						
1	T-NS-01	Jelly-1	2. Nitrogen Cylinder 1 ตามข้อ 1 ไม่ผ่าน ทดสอบ ไม่เป็นระเบียบ	OK	✓	
2	IR-NB-02	Jelly-1		OK	✓	
3. Hose Red						
1	P-6832	Jelly-1	3. Hose Red ตามข้อ 1 ไม่ผ่าน ทดสอบ ไม่เป็นระเบียบ	OK	✓	
				OK	✓	
4. Dry Monitor Nozzle						
1	DM-6832	Jelly-1	4. Dry Monitor Nozzle ตามข้อ 1 ไม่ผ่าน ทดสอบ ไม่เป็นระเบียบ	OK	✓	
				OK	✓	
				OK	✓	
				OK	✓	

การให้คำปรึกษา

SAP Number:

Energy System (fatty)

ที่	No.	สถานที่	หมายเหตุในการตรวจสอบ	Argon Cylinder Pressure Gauge ที่อยู่ใน Isomerge ที่ 2,900 PSI	ผลการตรวจสอบ	สิ่งผิดปกติที่พบ	ผู้ตรวจพบ (ตัวอักษร)		
1. Inergen Cylinder (Main)									
1	IN-CL-01	Jetty-1	1. Inergen Cylinder ขนาด 10 ลิตร บรรจุน้ำยา 2,900 PSI. ถ้าไม่บรรจุน้ำยาให้ไปติดต่อช่าง	✓	✓				
2	IN-CL-02	Jetty-1		✓	✓				
3	IN-CL-03	Jetty-1		✓	✓				
4	IN-CL-04	Jetty-1		✓	✓				
5	IN-CL-05	Jetty-1		✓	✓				
6	IN-CL-06	Jetty-1		✓	✓				
7	IN-CL-07	Jetty-1		✓	✓				
8	IN-CL-08	Jetty-1		✓	✓				
9	IN-CL-09	Jetty-1		✓	✓				
10	IN-CL-10	Jetty-1		✓	✓				
2. Inergen Cylinder (Reserve)									
1	IN-CL-01	Jetty-1	1. Inergen Cylinder ขนาด 10 ลิตร บรรจุน้ำยา 2,900 PSI. ถ้าไม่บรรจุน้ำยาให้ไปติดต่อช่าง	✓	✓				
2	IN-CL-02	Jetty-1		✓	✓				
3	IN-CL-03	Jetty-1		✓	✓				
4	IN-CL-04	Jetty-1		✓	✓				
5	IN-CL-05	Jetty-1		X	X	Pressure drop			
6	IN-CL-06	Jetty-1		✓	✓				
7	IN-CL-07	Jetty-1		✓	✓				
8	IN-CL-08	Jetty-1		✓	✓				
9	IN-CL-09	Jetty-1		✓	✓				
10	IN-CL-10	Jetty-1		✓	✓				
2. Control Panel									
1	Control rack room			ไม่พบสถานะการผิดปกติ	ผลการตรวจสอบ	สิ่งผิดปกติที่พบ			
2	LV room				พร้อมใช้				
3	AC room				พร้อมใช้				
4	Battery room				พร้อมใช้				
3. Electric control Bend									
ผลการตรวจพบการผิดปกติ				ผลการตรวจสอบ					
พร้อมใช้				พร้อมใช้					
3. Electric control Bend									
1	ELC-CRR (Main)			1. ELC in Control Head และตู้ในตำแหน่ง SET. และอยู่ในสถานะพร้อมใช้งาน	พร้อมใช้	สิ่งผิดปกติที่พบ			
2	ELC-LV (Main)				✓				
3	ELC-AC (Main)				✓				
4	ELC-Bat (Main)				✓				
5	ELC-CRR (Reserve)				✓				
6	ELC-LV (Reserve)				✓				
7	ELC-AC (Reserve)				✓				



SAP Number _____

Inergen System (Jetty)

S	RLC-Ball (Reserve)	4. Abort Switch (Manual release) จากห้องปล่อยไฟในตู้ควบคุม	การตรวจเช็ค		ผลการตรวจ	ผู้ตรวจ
			ปกติ	ผิดปกติ	พร้อมใช้	ไม่พร้อมใช้
1	Control Rack Room		✓		✓	
2	LV Room		✓		✓	
3	AC Room		✓		✓	
4	Battery Room		✓		✓	
บันทึกผลการตรวจ						

SAP Number _____

CO2 System LV / HV Room Jetty-2

ที่	No.	สถานที่	มาตรฐานการตรวจสอบ	น้ำหนัก (KG) น้ำหนักจริง	ที่ตรวจ	ผลการตรวจ พร้อมใช้	ไม่พร้อมใช้	สิ่งผิดปกติพบ
1. CO2 Cylinder								
1	CI-01	LV Room	1 CO2 Cylinder ไม่เกิน 10% น้ำหนัก	289.0		✓		
2	CI-02	LV Room	ถังว่าง สดใหม่	201.0		✓		
3	CI-03	HV Room	ถังว่าง สดใหม่	293.0		✓		
4	CI-04	HV Room	ถังว่าง สดใหม่	293.0		✓		
2. Control Panel								
1	6700-CO2-CP1		2. Control Panel Power On ตัน	✓		✓		
2	6700-CO2-CP2			✓		✓		
3. Electric Control Panel								
1	LV Room		3. Electric Control Panel ถูกวิธี	✓		✓		
2	HV Room		ในตู้ควบคุม	✓		✓		
4. Manual Release								
1	LV Room		4. Manual Release สามารถใช้ได้	✓		✓		
2	HV Room		จากตู้ควบคุม	✓		✓		
5. Pressure Switch								
1	LV Room		5. Pressure Switch สามารถใช้ได้	✓		✓		
2	HV Room		จากตู้ควบคุม	✓		✓		

บันทึกผลการตรวจ

ผู้ตรวจ

ตำแหน่ง

วันที่

➤ 30 ข

เอกสารแผนฝึกซ้อมเหตุการณ์ฉุกเฉินประจำปี 2566
และขั้นตอนการจัดการงานควบคุมภาวะฉุกเฉิน



เอกสารแผนฝึกซ้อมเหตุการณ์ฉุกเฉิน
ประจำปี 2566





2

Information Crisis and Security Management, SILE Management

ลำดับ	หมายเลขงาน (CPC-BID)	ผู้รับผิดชอบ	วช.	น.พ.	ป.อ.	นาย.	ทส.	นิยล	ผ.ก.	ส.ค.	ภ.บ.	จ.ด.	พ.ย.	ร.ม.	กำหนดการซ่อม	ความถี่ตามหลัก
1	G02(BT) : ระดับ 2														วันที่ 26 ตุลาคม 2566	
2	G07(BTF) : ระดับ 2														วันที่ 25 สิงหาคม 2566	
3	G07(BTF & GY2) : ระดับ 2	ศูนย์บริการ ลูกค้า													วันที่ 30 พฤศจิกายน 2566	
4	G08(ATF) : ระดับ 2														วันที่ 06 ตุลาคม 2566	
5	G09(ATE2) : ระดับ 2 ตาม RIL												15 มิ.ย./2566		วันที่ 26 พฤษภาคม 2566	90%
6	Interconnecting pipeline : ระดับ 2														วันที่ 07 กรกฎาคม 2566	

۱۰۰



บริษัท พีทีที โกลบอล เคมิคอล
จำกัด (มหาชน)

F-(Q-SH-CM)-017: แบบประเมินและปรับปรุง
แก้ไขการฝึกซ้อมแผนฉุกเฉิน

☐ Tabletop

☐ EM1

☒ EM2

☐ EM3

บริษัท/สาขา	PTTGC7	Plant Name	BTF	Unit Name	T-6982
วันที่ (Date)	31 ตุลาคม 2565	Chart (A/B/C/D)	B	Shift (Day / Night)	Day
ผู้จัดทำ	วราวุธ สารจิตต์	ตำแหน่ง	ERS Chief		

Scenario	ขณะรับ Butene-1 จาก I-4 เข้าถึง T-6982 เกิดการ Flash ตัวของ Product ทำให้ Temp. ใต้ถังลดลง เกิดการบิดตัวของหน้าแปลน ส่งผลกระทบต่อประเก็นของท่อระบายด้านล่างหัดตัวทำให้ Butene-1 ในถังรั่วไหลออกจำนวนมากเป็น Vapor Cloud เข้าไปบริเวณงาน Hot work ใกล้เคียง เกิดไฟลุกไหม้รุนแรงจนความร้อนส่งผลกระทบต่อแนวท่อและถังข้างเคียง
----------	--

Rating: (การให้คะแนน)

1 = Emergency response need met (การปฏิบัติเป็นไปตามที่ต้องการ) ผลการประเมิน = Yes

0 = Room for improvement (การปฏิบัติยังมีสิ่งที่ต้องแก้ไขปรับปรุง) ผลการประเมิน = No

CHECK ITEMS กิจกรรม/รายการที่ประเมิน	ผลการประเมิน			ข้อสังเกตที่พบ	RATING
	Yes	No	NA		
ความสอดคล้องของ PIP					
1. Incident (Title)	Y				1
2. Information (Process condition / Applicable data)	Y				1
3. Incident control plan (Objectives / Strategies / Tactics)	Y				1
4. Operation Actions (Control room / Field Operator)	Y				1
5. Fire fighting	Y				1
6. Other recommendations / Concerns	Y				1
ศูนย์ควบคุมการผลิต (Control Center Room): ประเมินบุคคล อุปกรณ์และการสื่อสาร					
7. มีการสั่งการตามหน้าที่ของ EM และมีการกำหนดกลยุทธ์	Y			ดำเนินการตาม PIP	1
8. Boardman มีการทำหน้าที่ตามแผน Operation Emergency Action_Isolation / Bypass / SD / Blow down)	Y				1
9. มีการเปิดสัญญาณแจ้งเหตุ และการประกาศเสียงตามสาย	Y				1
10.มีการติดต่อสื่อสารและการประสานงานกับศูนย์สื่อสาร OC, ECC และหน่วยงานที่เกี่ยวข้อง / การสั่งการให้ส่ง SMS / แฟกซ์ / แจ้งเหตุ	Y				1



บริษัท พีทีที โกลบอล เคมิคอล
จำกัด (มหาชน)

F-(Q-SH-CM)-017: แบบประเมินและปรับปรุง
แก้ไขการฝึกซ้อมแผนฉุกเฉิน

CHECK ITEMS กิจกรรม/รายการที่ประเมิน	ผลการประเมิน			ข้อสังเกตที่พบ	RATING
	Yes	No	NA		
11. อุปกรณ์เครื่องมือสื่อสารและเอกสารต่างๆ เช่น P&ID, SDS, PIP และ แผนสื่อสารอื่นๆ มีพร้อมใช้งาน	Y				1
ศูนย์สื่อสาร (Communication Center): ประเมินบุคคล อุปกรณ์และการสื่อสาร					
12. พนักงานสื่อสารมีการทวนขอความรับแจ้งและทำตามหน้าที่ได้ครบถ้วน	Y				1
13. การติดต่อประสานงานกับผู้เกี่ยวข้อง / การส่ง Fax ให้ กนอ. พื้นที่และ EMCC / การส่ง SMS ถูกต้องครบถ้วน	Y				1
14. แผนสื่อสาร อุปกรณ์สื่อสาร เช่น วิทยุสื่อสาร โทรศัพท์ เครื่อง โทรสาร ใช้งานได้ดี	Y				1
15. มีการติดต่อแจ้งนิคมพื้นที่และ สทร.	Y				1
16. มีการติดต่อแจ้งโรงงานข้างเคียง	Y				1
17. มีการติดต่อแจ้งหน่วยงานราชการท้องถิ่น	Y				1
จุดเกิดเหตุ (Command Post และ TRIAGE AREA): ประเมินบุคคล อุปกรณ์ การสื่อสาร+					
18. การแจ้งเหตุของผู้พบเห็นเหตุการณ์ (ทางโทรศัพท์ วิทยุ สื่อสาร ปุ่มกดแจ้งเหตุเพลิงไหม้) มีการปฏิบัติตามแผน	Y				1
19. มีการตรวจสอบยืนยัน ประเมินสถานการณ์ และรายงานเหตุการณ์ ที่เกิดขึ้นไปยัง SM, SS, Boardman ในขั้นแรก	Y				1
20. FO ของ Unit ที่เกิดเหตุมีการ take initial response ใช้ อุปกรณ์ที่มีอยู่ในพื้นที่ระงับเหตุได้อย่างเหมาะสม	N			เนื่องจาก Fit Team ระงับเหตุ เบื้องต้นยังมีความสับสนอยู่บ้าง	0
21. ทีมตอบโต้เหตุฉุกเฉินสวมชุดดับเพลิง SCBA และ PPE ถูกต้องครบถ้วน	Y				1
22. ทีมดับเพลิงถึงที่เกิดเหตุในเวลาที่เหมาะสมใช้เวลา6.....นาที	Y			ใช้เวลา 4 นาที	1
23. มีการวางแผนร่วมกันของผู้สั่งการ ณ จุดเกิดเหตุกับทีมดับเพลิงก่อนที่จะเข้าทำการระงับเหตุหรือดับเพลิง	Y				1
24. มีการป้องกันการลุกลามหรือป้องกันแหล่งที่จะทำให้ติดไฟ และดูแล Unit ให้ปลอดภัย	Y				1



บริษัท พีทีที โกลบอล เคมิคอล
จำกัด (มหาชน)

F-(Q-SH-CM)-017: แบบประเมินและปรับปรุง
แก้ไขการฝึกซ้อมแผนฉุกเฉิน

CHECK ITEMS กิจกรรม/รายการที่ประเมิน	ผลการประเมิน			ข้อสังเกตที่พบ	RATING
	Yes	No	NA		
25.การใช้วิธีควบคุมเพลิงดับไฟ ควบคุมเหตุการณ์ที่เกิดขึ้นได้อย่างมีประสิทธิภาพ(เลือกใช้น้ำ โฟมหรือสารดับเพลิงอย่างถูกต้อง)	Y				1
26.มีการช่วยเหลือ การคัดกรองและการปฐมพยาบาลผู้บาดเจ็บอย่างเหมาะสม	Y				1
27.การปฏิบัติหน้าที่และการประสานงานของ OC, Fire Chief, FIT team, First Aid Team และทีมจากหน่วยงานภายนอก เช่น NPC S&E, PTTGC Group ทำได้ได้อย่างเหมาะสม	Y			พิจารณาแจ้งทีมพยาบาลปรับช่องวิทยุให้ตรงช่อง 16 Emergency	1
28.การจัดการหลังเกิดเหตุ การปิดกั้นพื้นที่ การตรวจสอบความเสียหายทำได้เหมาะสม	Y				1
29.ระบบและอุปกรณ์ในการตอบโต้ภาวะฉุกเฉินใช้งานได้ อย่างมีประสิทธิภาพ เช่น ระบบดับเพลิง อุปกรณ์ดับเพลิง อุปกรณ์ช่วยชีวิต SCBA, PPE ป้ายแสดงจุด Command post วิทยุสื่อสาร รถดับเพลิง รถพยาบาล และอื่นๆ (ระบุอุปกรณ์ที่มีความบกพร่อง)	Y				1
การประเมินทีมช่วยเหลือทางการแพทย์ (Medical Emergency Response)					
30. Fit Team/ Rescue Team เข้าช่วยเหลือผู้บาดเจ็บได้ภายใน 4 นาที และปฐมพยาบาล/ เคลื่อนย้ายผู้บาดเจ็บอย่างเหมาะสม	Y				1
31.การปฏิบัติหน้าที่และการประสานงานของ OC, MC, FIT team ทีมสนับสนุนรถพยาบาลจาก GC Group และหน่วยงานภายนอก เช่น NPC S&E, กลุ่ม EMAG เป็นต้น ทำได้ได้อย่างเหมาะสม หรือไม่	Y				1
32.พยาบาลสามารถคัดกรอง ประเมินการรักษายาบาลผู้บาดเจ็บได้อย่างเหมาะสมหรือไม่	Y				1
33.มีการจัดตั้ง Triage area และจัดการผู้บาดเจ็บได้อย่างเหมาะสมหรือไม่	Y				1
34.กรณีสารเคมี/รังสี มีการทำ Decontamination ผู้บาดเจ็บก่อนนำส่งรพ.พร้อมข้อมูล SDS หรือไม่	Y				1



บริษัท พีทีที โกลบอล เคมิคอล
จำกัด (มหาชน)

F-(Q-SH-CM)-017: แบบประเมินและปรับปรุง
แก้ไขการฝึกซ้อมแผนฉุกเฉิน

CHECK ITEMS กิจกรรม/รายการที่ประเมิน	ผลการประเมิน			ข้อสังเกตที่พบ	RATING
	Yes	No	NA		
35. รพพยาบาลประจำพื้นที่ เข้าถึงจุดเกิดเหตุได้ภายในเวลา 10 นาที/ รพพยาบาลสนับสนุน เข้าถึงจุดเกิดเหตุได้ภายใน 20 นาที และนำส่งรพ.ได้ภายใน 1 ชม. หรือไม่	Y				1
ศูนย์บัญชาการเหตุฉุกเฉิน (Emergency Command Center): ประเมินบุคคล อุปกรณ์ การสื่อสาร					
36. มีการตั้งศูนย์อำนวยการเหตุฉุกเฉินได้รวดเร็ว ผู้ทำหน้าที่มีรายงานตัวครบในเวลาที่เหมาะสม	Y			Online Microsoft Team Meeting ตามมาตรการ Covid-19	1
37. มีการชี้แจงสรุปสถานการณ์ เหตุการณ์ที่เกิดขึ้น ให้ทุกคนทราบปัญหาของเหตุการณ์ เพื่อให้แต่ละส่วนงานกำหนดแผนปฏิบัติ ประสานงานและสนับสนุนเหตุฉุกเฉิน	Y			Online Microsoft Team Meeting ตามมาตรการ Covid-19	1
38. การจัดการกับผู้ที่ได้รับผลกระทบทั้งภายในและภายนอกโรงงานรวมถึงสิ่งแวดล้อม เช่น โรงงาน ชุมชนใกล้เคียง สิ่งแวดล้อม การจัด การหลังเกิดเหตุ การแจ้งข่าวให้กับพนักงาน ชุมชน หน่วยงานที่เกี่ยวข้องและสื่อมวลชนทราบ เป็นไปอย่างมีประสิทธิภาพ	Y			Online Microsoft Team Meeting ตามมาตรการ Covid-19	1
39. มีผู้บันทึกเหตุการณ์ และมีกัปตันที่ข้อมูลที่สำคัญบน Incident Board ข้อมูลที่บันทึกครบถ้วนและถูกต้อง	Y			Online Microsoft Team Meeting ตามมาตรการ Covid-19	1
40. การสื่อสารติดต่อประสานงานกับทีมตอบโต้ภาวะฉุกเฉิน และหน่วยงานที่เกี่ยวข้อง เช่น การหน่วยงานราชการ ชุมชนและสื่อมวลชน เป็นไปอย่างมีประสิทธิภาพ	Y			Online Microsoft Team Meeting ตามมาตรการ Covid-19	1
41. อุปกรณ์และเอกสารต่างๆ เช่น วิทยุสื่อสาร โทรศัพท์ เครื่องรับส่งโทรสาร เครื่องบันทึกเสียง ระบบ VDO Conference, CCTV, Computer P&ID, SDS, PIP และ หมายเลขโทรศัพท์ติดต่อหน่วยงานที่สำคัญ พร้อมใช้งาน	Y			Online Microsoft Team Meeting ตามมาตรการ Covid-19	1
จุดรวมพล (Assembly Point): ประเมินบุคคล อุปกรณ์และการสื่อสาร					
42. อพยพมาที่จุดรวมพลด้วยความรวดเร็ว เป็นระเบียบ ครบถ้วนและตรวจนับจำนวนที่จุดรวมพลเป็นไปตามแผน	Y				1
43. Assembly Controller และ Area Warden ปฏิบัติหน้าที่ได้ดี	Y			มีการรายงาน Head Count	1



บริษัท พีทีที โกลบอล เคมิคอล
จำกัด (มหาชน)

F-(Q-SH-CM)-017: แบบประเมินและปรับปรุง
แก้ไขการฝึกซ้อมแผนฉุกเฉิน

CHECK ITEMS กิจกรรม/รายการที่ประเมิน	ผลการประเมิน			ข้อสังเกตที่พบ	RATING
	Yes	No	NA		
44. มีการตรวจนับและการรายงานจำนวนผู้อพยพและผู้สูญหายไปยัง ECC ตามแผน	Y			มีการแจ้งมายัง ECC	1
45. ที่จุดรวมพลและอุปกรณ์ที่ใช้ในการติดต่อสื่อสารมีความพร้อมใช้งานได้ดี	Y				1
จุดรับการสนับสนุนจากหน่วยงานภายนอก : ประเมินบุคคล อุปกรณ์ การสื่อสาร					
46. เจ้าหน้าที่ รปภ. ควบคุมการผ่านเข้าออกของยานพาหนะและบุคคลที่ประตู Main gate ตลอดจนการจราจร เป็นไปอย่างมีประสิทธิภาพ	Y				1
47. การทำหน้าที่ของ MC2 การติดต่อสื่อสารและการประสานงานกับผู้เกี่ยวข้อง มีการบันทึกและรายงานข้อมูลของหน่วยงานที่มาช่วยเหลือและทรัพยากรที่นำมาสนับสนุนได้อย่างถูกต้องครบถ้วน	Y				1
48. อุปกรณ์ เครื่องมือสื่อสารและ board จดบันทึก มีความพร้อมใช้งาน	Y				1
อื่นๆ (Other)					
49. การจัดเตรียม (organize) แผนการฝึกซ้อม มีการใช้ PIP, Scenario ที่สมเหตุสมผล มีการปฏิบัติไปตามขั้นตอนที่เสมือนเหตุการณ์จริงได้อย่างเหมาะสม	Y				1
50. การให้ข้อมูลกับชุมชนของ CSR มีการปฏิบัติตามแผน	Y				1
51. มีการสื่อสารกับสื่อมวลชนตามแผน	Y				1
52. มีการติดต่อสื่อสารกับครอบครัวของพนักงานตามแผน			NA		0
53. การช่วยเหลือจากกลุ่ม EMAG มีการทดสอบการปฏิบัติตามแผน			NA	แจ้งเฉพาะ NPC S&E , GC11	-
54. การทำหน้าที่ของหน่วยงานเทศบาลในท้องถิ่น มีการทดสอบการปฏิบัติตามแผน			NA	โทรแจ้ง กนอ.(สนง.มบตาพุด) เพื่อทราบ	-
Sum of Rating					49/51
Effectiveness Score					96%

Calculation of Effectiveness Score % = $\frac{\text{Sum of Total Rating Points}}{\text{Total Rating Points}} \times 100$



บริษัท พีทีที โกลบอล เคมิคอล
จำกัด (มหาชน)

F-(Q-SH-CM)-017: แบบประเมินและปรับปรุง
แก้ไขการฝึกซ้อมแผนฉุกเฉิน

No. of rated items

Effectiveness Scoring

>90 - 100% = Excellent

>80% - 90% = Good

>70% - 80% = Fair

<70% = Review Required

Positive Observations: ข้อดี


1. อุปกรณ์ต่างๆ เช่น Water Spray System ไม่เกิดปัญหาในระหว่างการใช้งาน.....


Improvement Observations: ข้อปรับปรุงแก้ไข

Item	Conclusion / Suggestion	Action by	Target Date	Finish Date
1	Fit Team Area ไม่ได้มารายงานตัวกับ OC ช่วงประกาศแผนฉุกเฉินระดับ 1	Q-SH-CM	15 ธ.ค. 65 ทบทวนและ อบรมหน้าที่ตาม แผนฉุกเฉิน ให้กับ O/P Fit Team	15 ธ.ค. 65
2	เปลเคลื่อนย้ายผู้บาดเจ็บของรถพยาบาล NPC S&E ไม่ได้ผู้กสายรัดตัวผู้บาดเจ็บเตรียมพร้อมใช้งาน	NPC S&E	15 ธ.ค. 65 ให้ NPC S&E เพิ่มมาตรฐาน การตรวจสอบ ประจำวันเพื่อให้ เกิดความพร้อม ก่อนใช้งาน	15 ธ.ค. 65



ภาพถ่ายจากการซ้อมแผน





ขั้นตอนการจัดการงานควบคุมภาวะฉุกเฉิน





บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)

Crisis and Security Management

P-(Q-SH-CM)-OEMS-001
การจัดการบนความต่อเนื่องฉุกเฉิน

จัดทำโดย :

อนุมัติโดย :

รายชื่อผู้ทบทวน

ผู้ทบทวน	ตำแหน่ง	หน่วยงาน
นาย จัณเฑียร หงษ์จรุญ	Division Manager	Q-SH-CM

รายการแก้ไข

ครั้งที่	วันที่มีผลบังคับใช้	รายละเอียด	โดย
0	25/02/2020		
1	17/06/2020		
1	28/10/2020		
1	28/10/2020		
2	05/04/2022		
2	05/05/2023		

หน่วยงานที่เกี่ยวข้อง

รหัสหน่วยงาน	ชื่อหน่วยงาน
Q-SH-CM	Crisis and Security Management
Q-SH	SHE Management

KPI ที่เกี่ยวข้อง

KPI Measure	Description / Calculation	Target (unit)
-------------	---------------------------	---------------

KPI Measure	Description / Calculation	Target (unit)
N/A	N/A	N/A

กฎหมายที่เกี่ยวข้อง

ชื่อกฎหมาย

เอกสารที่เกี่ยวข้องในระบบ

รหัสเอกสาร	ชื่อเอกสาร
P (Q-SH-CM)-003	แผนการบริหารจัดการการปฏิบัติงานและสถานะวิกฤต

เอกสารอ้างอิงภายนอก

ชื่อเอกสาร



บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)

P-(Q-SH-CM)-OEMS-001: การจัดการ
ควบคุมกระบวนการผลิต

สารบัญ


หน้า

1. วัตถุประสงค์	1
2. ขอบเขต	2
3. หน้าที่และความรับผิดชอบ	3
4. WORKFLOW	7
5. รายละเอียดการดำเนินงาน	8
6. ผนวก	33

ประกาศใช้ครั้งที่ 2

เอกสารฉบับนี้จัดทำขึ้น และตรวจสอบแล้วพบว่า สอดคล้องกับข้อกำหนด และเงื่อนไขที่กำหนดไว้ในเอกสารฉบับนี้ และไม่มีข้อผิดพลาดใดๆ
 วันที่ : 15/04/2562
 โดย : วิศวกร


วันที่มีผลบังคับใช้: 05/04/2562



ข้อคิดเห็นที่ ๑๖ : ข้าราชการส่วนกลางและส่วนภูมิภาคควรได้รับการพัฒนาความรู้ ทักษะ และสมรรถนะให้ทันต่อการเปลี่ยนแปลงของสังคม เศรษฐกิจ การเมือง และเทคโนโลยี รวมทั้งมีความรู้ความเข้าใจในบริบทของสังคมไทยและสังคมโลก

การใช้ทรัพยากรอย่างมีประสิทธิภาพและเหมาะสมแก่ความต้องการของสังคม ผลกระทบต่อสิ่งแวดล้อมและสุขภาพของประชาชน

- 6) เพื่อเพิ่มประสิทธิภาพของโรงงานให้กลับสู่สภาวะปกติ



ข้อมูลด้านการดำเนินงานการจัดกิจกรรมตามคุณลักษณะอันพึงประสงค์ในการเตรียมความพร้อมเข้าสู่การศึกษาระดับประถมศึกษาปีที่ 1 ปีการศึกษา 2562

- [illegible]

ขั้นตอนการดำเนินการบริหารความเสี่ยงตามตัวบทของกฎหมายเป็นแนวทางในการควบคุมเหตุการณ์ที่เกิดขึ้น
ทั้งนี้ ในบางกรณีการประเมินความเสี่ยงอาจดำเนินการโดยพิจารณาตามแผนการร่วมกับแผน
เผชิญเหตุ / แผนรับมือเหตุ ซึ่งมีทั้งที่เตรียมไว้ (Pre-Incident Plan : Pre-Pic Plan) หรือที่พัฒนามา
เฉพาะกิจทั้ง หัก เช่น การควบคุมเหตุการณ์ก่อวินาศกรรม (Gm Split Contingency Plan)
ในการเผชิญเหตุที่เกิดขึ้นไม่ให้เกิดเหตุการณ์ผลกระทบอันใดได้เฉพาะ จะมีการผู้ใดเฝ้าระวังสื่อ
ทางวิทยุโทรทัศน์แบบเฉพาะกิจได้ด้วย



P-(Q-SH-CM)-OEMS-001: การศึกษาวิจัย
ควบคุมทางคลินิก

บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)

3. หน้าที่และความรับผิดชอบ

- a. ED (Emergency Director)
- หน้าที่ที่โดย EVP SVP ลงนามที่เกี่ยวข้องของโรงงานที่เกิดเหตุการณ์เหตุฉุกเฉินระดับ 3 หรือ VP โรงงานที่เกิดเหตุการณ์เหตุฉุกเฉินระดับ 2 บุคคลที่ได้รับการมอบหมาย มีหน้าที่ที่โดยสรุปดังที่
- อำนวยความสะดวกตามกฎภาวะฉุกเฉิน
 - กำกับดูแลให้กับการดำเนินการปฏิบัติงานของ EMT, OC และผู้ให้บริการฉุกเฉิน
 - ประเมินสถานะและบังคับการคืนเนินเหตุ
 - ทำการดูแลตรวจสอบนโยบายในที่เกิดเหตุในแผนกสุขภาพความปลอดภัย
- แบบแผน กรณีที่ประสบเหตุฉุกเฉินระดับ 3 หรือ EMT ต้องทำตามขั้นตอนเพื่อให้ข้อมูลเฉพาะสายงานกับศูนย์สุขภาพและศูนย์ทางราชการ (ศบค./สธ.) ให้ดำเนินการต่อไปให้ชัดเจนให้มอบหมายผู้ดำเนินการที่หน้าที่ ECC ในระหว่างที่ ED และ EMT อยู่ข้างหน้ากรณี ECC
- b. ED Duty (Emergency Duty)
- ส่วนหน้าที่โดยทั่วไปมีหน้าที่ที่ตามตาราง ED Role มีหน้าที่โดยสรุปดังนี้
- เป็นผู้บริหารจัดการโรงงานในการควบคุมเหตุการณ์ระดับจนกว่าส่งมอบหน้าที่ให้ EMT หรือ VP โรงงานที่เกี่ยวข้อง
 - ทำหน้าที่ ED เมื่อ EVP หรือ VP โรงงานไม่อยู่
 - อำนวยความสะดวกตามกฎฉุกเฉินของโรงงาน
- EM (Emergency Manager)

- เป็นผู้นำชุมชนเพื่อสุขภาพจิตของโรงเรียนที่รับผิดชอบ

- กำหนดเป้าหมายและการใช้แผนกลยุทธ์ร่วมกัน

- “กำหนดระดับความสำเร็จ”

d. OC (On Scene Commander)

ทำหน้าที่ได้ Skill Supervisor หรือ Sr. Operator หรือ Qualified Persons ของพื้นที่เกิดเหตุ

♦ **ควบคุมสิ่งแวดล้อมการปฏิบัติงาน** ^{๒๕๖๖} **ณ หาดใหญ่**

- ◆ เสือตกเหยตินิกการวุฒิจำเภตวันญญำ ENF

♦ คำขวัญตามสวนแบ่งเป็น ๖ ส่วน ดังนี้

၂။ သဘာဝအားဖြင့် မြန်မာနိုင်ငံ၏ ၂

အကယ်၍ နေရာအသစ်ကို ရွေးချယ်ရာတွင် အသုံးပြုနိုင်သည့် အချက်အလက်များကို အသုံးပြုနိုင်ပါက အသုံးပြုနိုင်ပါသည်။

ประกาศใช้ครั้งที่ 2

เรื่อง : มัคคุเทศน์รายการสั้น และบรรณาธิการรายการสั้น

မျိုး ၄၅၇၆ ၅၃

รวมท้ายเอกสารนี้ไว้: 05:04:2922

ด้วยประการ ดังกล่าว ประกอบ เป็นเหตุให้... จึงได้มี... (The following reasons have been given... therefore...)


ผู้ทำหน้าที่รับผิดชอบของ Response Team

ผู้ทำหน้าที่รับผิดชอบ	Plant Emergency Response Team (Plant ERT) นอกพื้นที่โครงการ	Emergency Duty Team (ทีมสำรองฉุกเฉิน)
Emergency Director นายกิตติ ED	1. OVP / SVP ลงนามอนุมัติและกำกับโครงการฉุกเฉิน 2. VP Plant รองโรงงานพื้นที่โครงการ	ผู้ทำหน้าที่รับผิดชอบ ERT นอกพื้นที่โครงการ
Emergency Manager นายกิตติ EM	1. Shift Manager 2. DM Plant Operation Shift Day Manager 3. EIC (EHS-DM) (พื้นที่ RC) 4. DM (EHS-DM) (พื้นที่ RC) (for IS (Incident))	ไม่มี
On Scene Commander นายกิตติ OC	3. DM Lab Operation (for Lab Center Incident) 1. Shift Supervisor 2. Senior Operator 3. Qualified Persons ของพื้นที่โครงการ 4. พนักงาน EHS-DM ที่ได้รับมอบหมายจาก P-12 5. ERS Chief RC พื้นที่ RC ของ ESI	ไม่มี
Mutual Aid Coordinator นายกิตติ MC	1. DM SHE รองพื้นที่โครงการ (MCI) 2. DM QSIM 3. ผู้รับผิดชอบ EIC (MCI) 4. Senior ERS Chief (MCI)	LSR Duty
Operation Coordinator นายกิตติ Operation Co.	1. DM Plant Operation ของพื้นที่โครงการ 2. DM Asset Utilization 3. DM Plant Technical 4. Day Manager	1. Operation Co. Duty
SHE Coordinator นายกิตติ SHE Co.	1. SHE Engineers ของพื้นที่โครงการ	LSHE Co. Duty
Maintenance Coordinator นายกิตติ Maintenance Co.	1. DM Maintenance นอกพื้นที่โครงการ	1. Maintenance Co. Duty
Services Coordinator นายกิตติ Service Co.	1. พนักงานกู้คืนระบบ Services ของพื้นที่โครงการ	1. Services Co. Duty
CSR Coordinator นายกิตติ CSR Co.	ไม่มี	LCSR Co. Duty

ผู้ทำหน้าที่รับผิดชอบ	Plant Emergency Response Team (Plant ERT) นอกพื้นที่โครงการ	Emergency Duty Team (ทีมสำรองฉุกเฉิน)
Emergency Director นายกิตติ ED	ไม่มี	LSR Co. Duty
Emergency Manager นายกิตติ EM	LSM HR Partner ของพื้นที่โครงการ	LSR Co. Duty
Mutual Aid Coordinator นายกิตติ MC	LSR EHS-DM 2. EHS-DM (Day Manager)	LSM Co. Duty
Operation Coordinator นายกิตติ Operation Co.	LCSR Interconnecting Pipeline and Truck Loading Supervisor	1. P-1 Co. Duty

MANAGEMENT Co. Coordinator

4. Workflow



บทประพันธ์นี้เขียนโดย ร. ๖. และแต่งขึ้นในรัชสมัยของ ร. ๖. และแต่งขึ้นในรัชสมัยของ ร. ๖. และแต่งขึ้นในรัชสมัยของ ร. ๖.




- เมื่อได้รับแจ้งเหตุ ทิวหน้าปฏิบัติการฉุกเฉินทันทีตามแผนเผชิญเหตุที่แจ้งการปฏิบัติการตามขั้นตอนที่เห็นตั้งแต่ต้นต้นและประเมินสถานการณ์
- ผู้ทำหน้าที่ EM ร่วมกับ OC จัดการกำหนดระดับความรุนแรงของภาวะฉุกเฉินระดับที่ 1, 2 หรือ 3 และกำหนด OCC หากไม่สามารถใช้ศูนย์ OCC ปกติลงพื้นที่ได้
- EM ประกาศภาวะฉุกเฉิน จะระดับความรุนแรงของภาวะฉุกเฉิน และสั่งการผู้ที่มีหน้าที่เกี่ยวข้อง ดังนี้

- 1) ประกาศ / สั่งการทางระบบวิทยุเพื่อให้ EM, OCC และทีมที่เกี่ยวข้องกับการจะนำเหตุการณ์ไปใช้ทรัพยากรฉุกเฉิน และกำหนดการเข้าช่วยเหลือ
- 2) ประกาศทางวิทยุหรือสื่อสารด้วยภาษาที่ไม่รุนแรง เช่น การใช้สัญญาณไฟหรือสัญญาณที่รับทราบ และสั่งการให้ทีมที่เกี่ยวข้อง ปิดทางเข้าโรงงานเปิดประกาศ ระดับ 2

- 3) ให้พนักงานสื่อสารส่งโทรสารแจ้ง นาย.ราชโน 10 นาที และส่ง SMS พร้อมทั้งผู้ที่เกี่ยวข้องรับทราบ โดยใช้ขีดความสามารถที่ EM กำหนดให้


- 5) การสื่อสารการแจ้งเตือนฉุกเฉินภายใน PTTGC GROUP ดำเนินการตามแผน ดังนี้



รูปที่ 3 วิธีการสื่อสารการแจ้งเตือนฉุกเฉินภายใน PTTGC GROUP




- 5.4 โครงสร้างองค์กรตามระดับเหตุการณ์
- 5.4.1 โครงสร้างองค์กรตามระดับเหตุการณ์



หมายเหตุ
- โครงสร้างที่ EM Shift Supervisor / Qualified Person หากมีที่ OC
- ED สามารถทำหน้าที่ EM Shift Supervisor / Qualified Person ได้ กรณีที่ EM Shift Supervisor / Qualified Person ไม่สามารถทำหน้าที่ได้
- เมื่อ OCC S&E รับแจ้ง ให้ดำเนินการส่งทีมสนับสนุนทันที
- แผนการปฏิบัติการฉุกเฉิน EM (Q-SH-CM) เป็นไปตามแผน PTTGC ซึ่งเป็น Plan B โดยจะแจ้งให้ทีม PTT Team รับแจ้ง

รูปที่ 4 โครงสร้างองค์กรการแจ้งเตือนฉุกเฉินระดับ 1

5.4.3 การจัดการทรัพยากรเงิน



รูปที่ ๓ โครงสร้างงานของสำนักงานได้ดำเนินการไว้ดังนี้ ๒-๓

[illegible]

แต่การปฏิบัติที่ปรากฏนั้น อาจจะไม่มีข้อจำกัดเฉพาะที่ใดที่ใด เพียงแต่ในทางปฏิบัติที่ปรากฏนั้น อาจจะมีความแตกต่างกันไปบ้าง

[illegible]


- 5.5.2 การปฏิบัติหน้าที่ของ Emergency Duty Team และ Plan ERT
- ข้อปฏิบัติในการปฏิบัติหน้าที่ของ Emergency Duty Team และ Plan ERT กำหนดไว้ดังนี้
- 1) Emergency Duty Team และ Plan ERT จะถูกเรียกเมื่อมีเหตุฉุกเฉินระดับ 2 และ 3
 - 2) Emergency Duty Team มีจำนวนรวมตลอด 24 ชั่วโมง ปฏิบัติหน้าที่ตั้งแต่เวลา 08.00 น. จนถึงเวลา 08.00 น. ของวันรุ่งขึ้นในสัปดาห์ต่อไป และต้องอยู่ในระยะที่สามารถดับเพลิงของโรงงานได้ภายในไม่เกิน 1 ชั่วโมง รายละเอียดตามข้อกำหนด หรือพิมพ์ว่าด้วยเรื่องเงินช่วยเหลือค่ารถเรียกขี้นยานฉุกเฉิน (On Duty และ On Call) พ.ม. 2556
 - 3) เมื่อถูกเรียกให้ปฏิบัติดังนี้
 - ให้ Emergency Duty Team ไปรายงานแล้วที่ ECC ทันที
 - ให้ Plan ERT ไปรายงานตัวที่ ECC เพื่อยืนยันแหล่งจาก Emergency Duty Team (ถ้ามี) ให้ได้
 - เมื่อ Plan ERT บังคับ ECC ให้ Emergency Duty Team ช่วยทางด้านเทคนิคที่ไม่ใช่เจ้าของพื้นที่ ส่งเอกสารให้ให้กับ Plan ERT และให้ผู้ช่วยเหลือ Plan ERT ลงกว่าสถานการณ์และจุดเกิดเหตุ

- 5.6 การปฏิบัติงานผู้ที่เกี่ยวข้องกับระบบฉุกเฉิน
- พนักงาน ผู้รับเหมา ผู้ผลิตผล และผู้ไปเกี่ยวข้องอื่นๆ เมื่อได้รับสัญญาณแจ้งเหตุฉุกเฉิน ให้ปฏิบัติดังนี้
- ปฏิบัติตามคำสั่งของ ชม จากการบริหารความเสี่ยงหรือประกาศภัยพิบัติของระบบ
 - กรณีที่คำสั่งขอพบ ให้ไปยังจุดรวมพลและรายงานตัวด้วยตัวพนักงานหรือผู้เกี่ยวข้องกลุ่มกลุ่ม
 - ที่จุดรวมพล ให้ปฏิบัติตามคำแนะนำของ Assembly Controller และเจ้าหน้าที่ที่เกี่ยวข้องของแผน (Emergency Response Team) ซึ่งกำลังจัดการระงับเหตุ หนึ่งทางให้เหตุหรือประกาศเตือนตามสายที่ให้คำแนะนำการปฏิบัติ
 - นักกรีตที่เป็นคนดูแลเงินระบบ 3 คนมีความจำเป็นที่จะต้องออกไปตั้งแต่เริ่มปิดกั้นโดยไม่ให้ผู้มาเข้าที่ Service Co. ที่ ECC ทำหน้าที่ประสานงานระบบที่มีการที่จุดรวมพล

- หรือตรวจเช็ครายชื่อแล้วให้ขึ้นงานโดยอพยพไปที่ศูนย์ราชการจังหวัดหรือสถานที่อื่นๆตามที่ศูนย์ควบคุมภาวะฉุกเฉินกำหนด
- 5.7 ศูนย์บัญชาการฉุกเฉิน (Emergency Command Center: ECC)
- ให้โรงงานในกลุ่มบริษัท กำหนดสถานที่ที่ใช้เป็น ECC ตามความเหมาะสมของแต่ละพื้นที่ ในกรณีที่ไม่สามารถเข้าถึงผู้ใช้ ECC ตามที่กำหนดไว้ได้ ให้ผู้ปฏิบัติงาน EM เป็นผู้ให้ความช่วยเหลือ ECC ให้พิจารณาและประเมินผลกระทบ ความรุนแรงและทิศทางลม และผลกระทบอื่นที่เกี่ยวข้องในภาวะฉุกเฉินระดับที่ 2 หรือ 3
- ECC เป็นศูนย์กลางในการสั่งการ ติดตามประสานงานระงับเหตุฉุกเฉิน ให้จัดเตรียมอุปกรณ์ต่างๆ ที่จำเป็นให้มีไว้พร้อมตลอดเวลาจนถึง ณ วันที่ 6.10

- 5.8 แนวทางการปฏิบัติเพื่อควบคุมภาวะฉุกเฉิน (Generic Strategies and Tactics for Incident Control)
- การควบคุมเหตุการณ์ไม่พึงประสงค์ของพลไปให้ดูกลาหรือสื่อหาพบเห็นกรณี (Contain the Incident) จะควบคุมเหตุการณ์โดย MIT Team ของโรงงานที่เกิดเหตุ การอธิบายพร้อมระงับเหตุฉุกเฉิน ให้ Q-SH-CM ประเมินที่ กระบวนการตามปฏิบัติการประเมินความเสี่ยง และจัดการตามระดับเหตุ (Incident Level) และจัดทำแผนปฏิบัติการเพื่อลดผลกระทบความเสียหาย โดยพิจารณาใช้แนวทางการกำหนดกลยุทธ์และเทคนิคที่นำไปทางระงับเหตุ ตามความเหมาะสม ดังนี้

- 5.8.1 กรณีเกิดเหตุเพลิงไหม้
- 1) ขึ้นโทรศัพท์แจ้งเตือนไปยังโรงเรือน อุปกรณ์เครื่องจักรที่ตั้ง
 - 2) หากเหตุหรือการรั่วไหลของเหลวเพลิง ก๊าซอันตราย ระบบ หรือ bypass อุปกรณ์อื่นๆ หากจำเป็น ให้พิจารณา Shutdown ระบบ การจัดการอุปกรณ์ สดทวนต้นเหตุเพื่อลดการรั่วไหล
 - 3) หากการดับเพลิงในกรณีที่สามารถดับได้ โดยใช้สารดับเพลิงที่เหมาะสมกับเพลิง
 - 4) กรณี pool fire ให้ใช้โฟมฉีดคลุมคาน้ำของกรรมเชื้อเพลิง และตัดแหล่งการเกิดเพลิงไหม้
 - 5) กรณีไฟไหม้ในอาคาร ให้ใช้ถังดับเพลิงที่มีประสิทธิภาพ และใช้ถังดับเพลิงดับไฟ
 - 6) ไม่ควรหนีเกิดไฟไหม้ไปเร็วเกินไปและคิดไป เช่น PSC ให้หยุดการรั่วไหลให้ลดการดับไฟ
 - 7) ใช้ผ้าคลุมคลุมคลุมไปสำหรับกรณีที่เกิด pressure fire




๑) ปีใดมีฝนแล้งหรือขาดน้ำไปมากที่สุดปีใดมีฝนแล้งมากที่สุด
ตอบ ปีที่

- 2) คอมพิวเตอร์ต้องจะยกไฟให้ประปรายไฟในบริเวณสาขาไฟไว้ให้พอ
- 3) แก้ไขจุดที่เป็นเหตุไฟรั่วไฟไหมไฟโดยใช้วิธีการและอุปกรณ์ที่ปลอดภัย
- 4) ใช้วัสดุที่เป็นสื่อนำไฟฟ้าเพื่อป้องกันของกัมมันต์ของก๊าซไวไฟที่รั่วหรือไฟไหมไฟไม่ให้สารไวไฟรั่วรั่วลงไปในถังเก็บของเหลวหรือหลอดรั่วไวไฟ
- 5) หากพื้นที่ที่มีสภาพทึบแสง ไม่ใช้ข้อบนหรือติดกับ (Fire Alarm) ให้ควบคุมการไหลของสารเคมีไปให้เร็วขึ้น
- 6) ป้องกันการเกิดจุดติดไฟของสารไวไฟที่ติดกับ (Fire Alarm) โดยการระดม
- 7) อุปกรณ์การระดมสารไวไฟออกนอกพื้นที่ได้แก่ถังเก็บที่ปลอดภัย

- 1) วิเคราะห์พื้นที่การปลูกไม้ผลข้างฟาร์มในพื้นแต่ แบ่งไปตามพื้นที่สวนสาธารณะ พื้นที่ป่าดงดิบ
- 2) ตรวจสอบแปลงปลูกพืชเศรษฐกิจที่มีไว้ในสวนสาธารณะ

- 3) เมื่อใช้ไปพบแพทย์ต้องเก็บประวัติทางการแพทย์ (HAZMAT Suit, SCBA, respiratory mask)
 - 4) ถ้าการรั่วซึม : หยุดการรั่วซึมโดย (contain the leak) โดยวิธีที่เหมาะสม
 - 5) จัดตั้งขอบเขต ห้ามให้กลุ่มยंत्रหรือสารเคมีที่รั่วซึมไหล เชื้อของหัวฉีดหรือถังใส่ลมมือ
 - 6) ปฏิบัติตามข้อแนะนำใน MSDS หรือเอกสารที่เกี่ยวข้อง เก็บประวัติเก็บใจกันไปให้ภรรยาเพราะจากทางสาธารณสุขอยู่บริเวณตัวหรือรถออกมาโรงงาน
 - 7) ถ้อยสารเคมีไม่ได้เก็บกักเก็บไว้ตลอด
- หมายเหตุ: สิ่งที่ต้องรู้โดยผู้เกี่ยวข้องของเหตุการณ์ครั้งนี้ ซึ่งพิจารณาไป 1) การแพร่กระจายของสารเคมี 2) การแพร่กระจายของสิ่งส่งผ่าน 3) การแพร่กระจายของสิ่งส่งผ่าน

ในกรณีที่เกิดพิษฝิ่น (Toxic Gas) ปรากฏภายในโรงงาน หรือในพื้นที่สาธารณะทาง
ภายนอก ให้แจ้งเจ้าพนักงานคุ้มครองสุขภาพประชาชน (Toxic Gas) ปรากฏภายในโรงงาน โดย
ดำเนินการ ดังนี้



๑) ประกาศให้สหกรณ์ที่สวัสดิการจะขอขึ้นอยู่กรมมหาดการ ให้เลิกประมุขมนตรี
ซึ่งทางที่กล่าวหาขอถอนสิทธิการขึ้นได้ รวมทั้งเรื่องจำคุกและควบคุมตัว
การขึ้นฟ้องกับคดีความส่วนประเทศ

- 2) สวม SCBA หรือหน้ากากป้องกันก๊าซพิษ และ ใช้เครื่องมือเก็บกู้สารเคมีในบริเวณที่ปนเปื้อน แหล่งที่มาของ ก๊าซพิษ (Toxic Gas) หรือการใช้กระบอกแก๊สไฮโดรเจนเปอร์ออกไซด์ในถังเก็บกู้สารเคมีให้ต้องอาศัยความรู้เกี่ยวกับสารเคมีที่ปนเปื้อน หรืออุปกรณ์เก็บกู้สารเคมีให้ใช้ได้ไม่เกิดอันตรายโดยใส่ชุดป้องกันอย่างเต็มที่
- 3) ใช้เทคนิคการขจัดสารเคมี และใช้วิธีให้พนักงานสวมหน้ากากเพื่อป้องกันมลพิษทางอากาศ

[illegible]

- 1) ประชาชน แบ่งกลุ่มงานให้ทราบทั่วกัน และตระหนักว่าบทบาทที่เกื้อหนุนกับโรงพยาบาลที่ จะทำอะไร
- 2) กำหนดพื้นที่รับผิดชอบตามโดยใช้ survey table และให้หาปริมาณหัวนมเข้า
- 3) แจ้งผู้ดูแลกระบวนการวิจัยต่างๆ (PTTGC, SCO) และผู้ดูแลระดับแต่ละงานหรือเป็นพื้นที่
- 4) ปฏิบัติตาม P-QC-TS-(OH): การทำงานร่วมกับชาวชุมชนนับตั้ง ปีที่ 5.5 กรณีเกิดผลกระทบจากกรณีในชุมชนและต้องจัดให้มีการที่พร้อมแบบแผนป้องกันและระงับอันตรายจากกรณีในภาวะการทำงานปกติ และหาทุนฉุกเฉินทางรังสีหรืออุบัติเหตุร้ายแรง อย่างไรก็ดีที่ละครึ่ง
- 5) ประสานงานกับสำนักงานสาธารณสุขเพื่อสนับสนุนเข้าดำเนินการ โทร.089-200-6243, 065-523-5134 (24 ชม.) สาขาค้น : 1269

5.8.6 การกำกับดูแลการผลิที่เกิดขึ้นกับโครงสร้างและระบบของบริษัทยักษ์ใหญ่
ให้ Q-SH-CM ของแต่ละบริษัทที่ประสานงานกับ หน่วยงาน U-CM-OP และหน่วยปฏิบัติการ
ที่เกี่ยวข้อง ในการกำหนดขอบเขตหน้าที่รับผิดชอบ จัดเตรียมแผนและข้อมูลในการ

ประเทศและต่างประเทศ โดยประสานความร่วมมือกับกรมการนิเทศฯ หรือหน่วยงานในสังกัดกรมการนิเทศฯ ที่เกี่ยวข้องกับการดูแลระบบท่อส่ง จัดทำแผนระงับเหตุ (Pre Incident Plan) และจัดให้มีการฝึกซ้อมตามความเหมาะสม

5.5.6 การควบคุมเหตุฉุกเฉินที่เกิดขึ้นกับการขนส่งผลิตภัณฑ์ทางกายภาพนอกโรงงานของแต่ละสายผลิตภัณฑ์ให้ Q-SH-CM พยายามที่จะแก้ไขปัญหาเบื้องต้นร่วมกับหน่วยปฏิบัติการที่ควบคุมการรับแจ้งเหตุทันทีที่เข้าแจ้งเหตุกับหน่วยควบคุมความปลอดภัย และจัดเตรียมแผนและข้อมูลในการประสานงานฉุกเฉินการระงับเหตุ โดยประสานความร่วมมือกับหน่วยงานที่เกี่ยวข้องจัดให้มีการฝึกซ้อมตามความเหมาะสม

5.5.7 กำหนดแผนการสื่อสารกรณีการอยู่ปฏิบัติงานมีเหตุหรือพบเหตุดังต่อไปนี้

- แจ้งเหตุถึง VP ตลอดทั้งเช้าหรือ Plant ที่เกี่ยวข้อง, Shift Manager, E2D Duty, Q-SH, Q-SH-CM และ SHE ของพื้นที่ เพื่อดำเนินการแจ้งเตือนที่ประเมิน
- ให้รีบประเมินร่วมกับประเมินความรุนแรงและใช้ในการขจัดเหตุ และหากประเมินแล้วว่าจำเป็นต้องดำเนินการขจัดให้ส่งการอพยพผู้ปฏิบัติงานที่อันตรายให้ไปอยู่ในที่ปลอดภัย
- กรณีเป็นเหตุฉุกเฉินที่โรงงานให้ Shift Manager ที่รับผิดชอบอพยพไปอยู่ในที่ปลอดภัย หากกรณีฉุกเฉินมีเหตุฉุกเฉิน และเห็นสมควร
- ให้ E2D ส่งเสริมทีมระงับเหตุให้อยู่ในระยะที่ปลอดภัย และการระงับเหตุโดยพิจารณาความปลอดภัยของชีวิตผู้เกี่ยวข้อง
- ประกาศให้ Q-SH-CM เพื่อพิจารณาและระดับความรุนแรงที่ E2D หรือพิจารณาจาก Health Hazard Standoff Distance Chart 404 NCTC
- ปิดกั้นพื้นที่ห้ามเข้าในรัศมีที่กำหนด
- หากสิ่งกีดขวางใช้วัตถุหรือวัสดุที่เคลื่อนที่ใกล้พื้นที่ที่ส่งตัวจะมีเหตุระเบิด
- ติดต่อกับหน่วยงานของรัฐ (กรม, ตำรวจหรือหน่วยงาน EOC, Explosive Detection Disposal) เพื่อตรวจสอบพื้นที่และทำการอพยพผู้เกี่ยวข้อง

5.5.8 กำหนดแผนการอพยพที่ชัดเจนตามแผนที่ที่ทางทีมคลังพักผู้คนที่เกี่ยวข้องกับสิ่ง ระเบิดหรือพื้นที่ที่ส่งตัวทาง Q-SH-CM ประกาศพื้นที่ร่วมกับหน่วยงานที่เกี่ยวข้องพิจารณาประเมินความเสี่ยงและจัดพื้นที่

ฉุกเฉินเฉพาะสำหรับพื้นที่และแผนระงับเหตุ (pre incident plan) และจัดให้มีการฝึกซ้อมตามความเหมาะสม

5.5.9 กำหนดแผนการอพยพที่ชัดเจนตามแผนที่ที่ทางทีมคลังพักผู้คนที่เกี่ยวข้องกับสิ่ง ระเบิดหรือพื้นที่ที่ส่งตัวทาง Q-SH-CM พยายามที่จะแก้ไขปัญหาเบื้องต้นร่วมกับหน่วยปฏิบัติการที่ควบคุมการรับแจ้งเหตุทันทีที่เข้าแจ้งเหตุกับหน่วยควบคุมความปลอดภัย และจัดเตรียมแผนและข้อมูลในการประสานงานฉุกเฉินการระงับเหตุ โดยประสานความร่วมมือกับหน่วยงานที่เกี่ยวข้องจัดให้มีการฝึกซ้อมตามความเหมาะสม

- แจ้งเหตุถึง VP ตลอดทั้งเช้าหรือ Plant ที่เกี่ยวข้อง, Shift Manager, E2D Duty, Q-SH, Q-SH-CM และ SHE ของพื้นที่ เพื่อดำเนินการแจ้งเตือนที่ประเมิน
- ให้รีบประเมินร่วมกับประเมินความรุนแรงและใช้ในการขจัดเหตุ และหากประเมินแล้วว่าจำเป็นต้องดำเนินการขจัดให้ส่งการอพยพผู้ปฏิบัติงานที่อันตรายให้ไปอยู่ในที่ปลอดภัย
- กรณีเป็นเหตุฉุกเฉินที่โรงงานให้ Shift Manager ที่รับผิดชอบอพยพไปอยู่ในที่ปลอดภัย หากกรณีฉุกเฉินมีเหตุฉุกเฉิน และเห็นสมควร
- ให้ E2D ส่งเสริมทีมระงับเหตุให้อยู่ในระยะที่ปลอดภัย และการระงับเหตุโดยพิจารณาความปลอดภัยของชีวิตผู้เกี่ยวข้อง
- ประกาศให้ Q-SH-CM เพื่อพิจารณาและระดับความรุนแรงที่ E2D หรือพิจารณาจาก Health Hazard Standoff Distance Chart 404 NCTC
- ปิดกั้นพื้นที่ห้ามเข้าในรัศมีที่กำหนด
- หากสิ่งกีดขวางใช้วัตถุหรือวัสดุที่เคลื่อนที่ใกล้พื้นที่ที่ส่งตัวจะมีเหตุระเบิด
- ติดต่อกับหน่วยงานของรัฐ (กรม, ตำรวจหรือหน่วยงาน EOC, Explosive Detection Disposal) เพื่อตรวจสอบพื้นที่และทำการอพยพผู้เกี่ยวข้อง


5.9 การปฐมพยาบาล (First Aid)

ให้ FTT Team หรือทีมที่รับผิดชอบ Rescuer พยายามและเคลื่อนย้ายผู้บาดเจ็บออกจากพื้นที่อันตรายให้เร็วที่สุดเท่าที่จะเป็นไปได้เพื่อลดความเสียหายที่เกิดขึ้น (Emerge Area) หรือส่งมอบแพทย์ เพื่อทำการปฐมพยาบาลหรือหัตถการฉุกเฉิน ในกรณีที่ไม่มีทีมแพทย์เข้าปฏิบัติงานได้จำเป็นต้องส่งผู้บาดเจ็บให้ถึงโรงพยาบาลโดยเร็วที่สุด

กรณีมีผู้ประสบภัยจำนวนมากขอให้ SHE Co. Duty ติดต่อเรียก SHE Engineers ของ Plant ในสถานที่เกิดเหตุเพื่อช่วยเหลือผู้บาดเจ็บ เข้ามาช่วยเหลือ Emerge Area ตามแผนที่ที่ทีมคลังพักผู้คนที่เกี่ยวข้องกับสิ่ง ระเบิดหรือพื้นที่ที่ส่งตัวทาง Q-SH-CM พยายามที่จะแก้ไขปัญหาเบื้องต้นร่วมกับหน่วยงานที่เกี่ยวข้องจัดให้มีการฝึกซ้อมตามความเหมาะสม


5.10 การอพยพ

5.10.1 Area Wardens



- ให้ ED คณะหรือ EW เป็นผู้พิจารณาหากจำเป็นต้องให้ใช้หน่วยผลิตอื่นจากภาคอุตสาหกรรมภายในโรงงาน บริษัทฯ ใช้เพื่อแก้ปัญหาความยากลำบากแก่พนักงานที่เห็นสมควร
- ให้ Assembly Controller/Area Warden ติดตามสถานการณ์การเกิด EM กรณีที่เหตุฉุกเฉินระดับ 1 หรือตาม HCC กรณีฉุกเฉินระดับ 2 และ 3 เพื่อให้ทราบสถานการณ์และการปฏิบัติกับผู้ที่อยู่ในเหตุการณ์ให้ตรงตามโสตติดต่อภายในศูนย์สื่อสาร หรือ MCI
- ประชุมคณะกรรมการผู้เกี่ยวข้องและพิจารณาแผนฉุกเฉินให้ใช้ได้ทันทีตามเวลา 28 แห่งพระราชบัญญัติว่าด้วยการระบอบการคลัง พ.ศ. 2550 เป็นที่เรียบร้อยแล้ว

วันที่ ๒๕-๒๖-๒๗ ธันวาคม ๒๕๖๑ ณ โรงแรมแกรนด์ไฮแอท เอราวัณ กรุงเทพมหานคร



เมื่อมีการประกาศหาอะลูมิเนียมในระดับ 3 แล้ว ED หรือ EM จะสั่งงานให้หมักเบสเพื่อสารซอ
กัลเลินส์บิชนิจนจนตกตะกอนได้แก่ กลุ่ม OMAG และหม่องนาราลา กนท. ทรายาล และ
ปร. โดยในการปฏิบัติงานแล้วร่วกับหมักเบสตามผลจะมี MC เป็นผู้ประสานงาน มดระ OC
ของวิสาหกิจ เป็นผู้แจ้งการ จด เกิดเหตุ และควบคุมการปฏิบัติงานกับ OC ของหน่วยงาน
การรัฐฯ โดยหมักเบสนาราลาจะเป็นตัวนำจากสารกลุ่มหมาก

ထိုသို့ အသုံးပြုမှုများကို အကဲဖြတ်ရာတွင် အောက်ဖော်ပြပါ အချက်များကို ထည့်သွင်းစဉ်းစားရမည်။

“...แล้ว คงจะดี ถ้า...”

การดำเนินงานของศูนย์ฯ ได้ดำเนินการมาตั้งแต่ปี ๒๕๕๓ โดยเน้นการดำเนินงานตามแผนยุทธศาสตร์ของกรมส่งเสริมการค้าระหว่างประเทศ กระทรวงพาณิชย์ และแผนปฏิบัติการของศูนย์ฯ ซึ่งได้ดำเนินการตามแผนปฏิบัติการประจำปี ๒๕๕๓-๒๕๕๔ และแผนปฏิบัติการประจำปี ๒๕๕๔-๒๕๕๕



ราชการทราบ หรือเพื่อเสริมการดำเนินการรับทราบการรับทราบหรือสถานการณ์ โดยหน่วยงานภายนอก ที่อาจเกี่ยวข้องดังนี้

- 1) องค์กรชุมชนใกล้เคียง
- 2) องค์กรปกครองส่วนท้องถิ่นที่เกี่ยวข้อง
- 3) องค์กรปกครองส่วนท้องถิ่นที่เกี่ยวข้อง
- 4) องค์กรปกครองส่วนท้องถิ่นที่เกี่ยวข้อง
- 5) องค์กรปกครองส่วนท้องถิ่นที่เกี่ยวข้อง
- 6) องค์กรปกครองส่วนท้องถิ่นที่เกี่ยวข้อง
- 7) องค์กรปกครองส่วนท้องถิ่นที่เกี่ยวข้อง
- 8) องค์กรปกครองส่วนท้องถิ่นที่เกี่ยวข้อง

5.19 การฝึกซ้อม และการฝึกอบรม

ให้ Q-SH-CM และ H-DV-TM เป็นผู้ประสานงานกับหน่วยงานที่เกี่ยวข้อง จัดทำแผนการฝึกอบรม

5.19.1 พนักงานใหม่

พนักงานใหม่จะต้องได้รับการฝึกอบรมก่อนปฏิบัติงาน

5.19.2 พนักงานปฏิบัติงาน

- พนักงานปฏิบัติงานจะต้องได้รับการฝึกอบรมก่อนปฏิบัติงาน
- พนักงานปฏิบัติงานจะต้องได้รับการฝึกอบรมก่อนปฏิบัติงาน

5.19.3 การซ้อมแผนความปลอดภัยฉุกเฉิน



ให้หน่วยงาน Q-SH-CM ประสานงานกับหน่วยงานที่เกี่ยวข้องวางแผนและฝึกซ้อมแผน ความปลอดภัยฉุกเฉินให้ทุกหน่วยงานที่เกี่ยวข้องมีความรู้ความเข้าใจโดยแผนความปลอดภัย ฉุกเฉิน ดังนี้

- ในแผนฉุกเฉินให้จัดให้มีการซ้อมระดับ 1 ให้ครบทุกกะของแต่ละหน่วยงาน
- ในแผนฉุกเฉินให้จัดให้มีการซ้อมระดับ 2 อย่างน้อยปีละ 1 ครั้ง
- จัดให้มีการฝึกซ้อมระดับสูงและสหสาขาวิชาชีพให้สอดคล้องกับข้อกำหนด
- จัดให้มีการฝึกซ้อม Tabletop Exercise ที่เทียบ Emergency Daily Team เพื่อฝึกซ้อมการ คิดต่อและประสานงานสนับสนุนการควบคุมภาวะฉุกเฉินตามภาวะ
- กรณีฝึกซ้อมระดับ 2 มีจัด Place Out ร่วมฝึกซ้อม โดยรับหน้าที่คล้าย Emergency Daily Team โดยให้ฝึกปฏิบัติเสมือนจริง

5.19.4 การทดสอบแผนฉุกเฉินตามกฎหมาย


ให้ผู้บริหารมีหน้าที่รับผิดชอบการทดสอบแผนฉุกเฉินวันพุธสัปดาห์ละ 1 ครั้ง เวลา 11:30 น. และกรณีเกิดเหตุการณ์ฉุกเฉินปฏิบัติตามขั้นตอนที่

5.20 การตรวจและตรวจสอบพื้นที่

ให้หน่วยงาน SME ประจําพื้นที่ มีหน้าที่ในการตรวจสอบพื้นที่เสี่ยงภัยหรืออันตรายหรือสภาพที่ไม่ปลอดภัย ที่ทำให้เกิดการรั่วไหลของสารเคมี สารไวไฟ หรือเกิดเพลิงไหม้ ให้ พนักงานได้มีส่วนร่วม ตรวจสอบกับแผนตรวจสอบพื้นที่เสี่ยงภัยอันตราย การ จัดทำโครงการแผนมาส่งเสริมการตรวจสอบความปลอดภัยกระบวนการผลิต (PSM), การเดิน ตรวจสอบความปลอดภัย (SWO), การจัดทำกิจกรรม 5 ส. การฝึกอบรมความปลอดภัย การ จัดทำ Safety News และ Safety Lesson Learn หรือการประชุมกลุ่ม เป็นต้น

5.21 การปรับปรุงแก้ไข

ให้ Q-SH-CM เป็นผู้รับผิดชอบในการดำเนินการปรับปรุงขั้นตอนการดำเนินงาน การ ตรวจสอบการปฏิบัติงานให้ทันสถานการณ์ที่เปลี่ยนแปลงใหม่หรือกรณีที่มีการปรับปรุงโครงสร้างองค์กร ที่มีผลกระทบถึงภาระหน้าที่ความรับผิดชอบของหน่วยงานที่สหพันธ์ หรือ จัดตั้งหน่วยงาน หน่วยงานต้นๆ ต้องดำเนินการทบทวนปรับปรุงแก้ไขเอกสารควบคุมให้เสร็จสมบูรณ์ 3 เดือน หรือตามระยะเวลาที่กำหนด



วิชาเคมีพื้นฐาน
P-(Q-SH-CM)-OFMS-001: การจัดการงาน

พิจารณากรณีแรก

61 ग्रंथसंग्रहालयः।

not

ผศ. กิ่งฟ้า วัลลภ

Call 1-800-333-3333

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100
101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200
201
202
203
204
205
206
207
208
209
210
211
212
213
214
215
216
217
218
219
220
221
222
223
224
225
226
227
228
229
230
231
232
233
234
235
236
237
238
239
240
241
242
243
244
245
246
247
248
249
250
251
252
253
254
255
256
257
258
259
260
261
262
263
264
265
266
267
268
269
270
271
272
273
274
275
276
277
278
279
280
281
282
283
284
285
286
287
288
289
290
291
292
293
294
295
296
297
298
299
300
301
302
303
304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
341
342
343
344
345
346
347
348
349
350
351
352
353
354
355
356
357
358
359
360
361
362
363
364
365
366
367
368
369
370
371
372
373
374
375
376
377
378
379
380
381
382
383
384
385
386
387
388
389
390
391
392
393
394
395
396
397
398
399
400
401
402
403
404
405
406
407
408
409
410
411
412
413
414
415
416
417
418
419
420
421
422
423
424
425
426
427
428
429
430
431
432
433
434
435
436
437
438
439
440
441
442
443
444
445
446
447
448
449
450
451
452
453
454
455
456
457
458
459
460
461
462
463
464
465
466
467
468
469
470
471
472
473
474
475
476
477
478
479
480
481
482
483
484
485
486
487
488
489
490
491
492
493
494
495
496
497
498
499
500
501
502
503
504
505
506
507
508
509
510
511
512
513
514
515
516
517
518
519
520
521
522
523
524
525
526
527
528
529
530
531
532
533
534
535
536
537
538
539
540
541
542
543
544
545
546
547
548
549
550
551
552
553
554
555
556
557
558
559
560
561
562
563
564
565
566
567
568
569
570
571
572
573
574
575
576
577
578
579
580
581
582
583
584
585
586
587
588
589
590
591
592
593
594
595
596
597
598
599
600
601
602
603
604
605
606
607
608
609
610
611
612
613
614
615
616
617
618
619
620
621
622
623
624
625
626
627
628
629
630
631
632
633
634
635
636
637
638
639
640
641
642
643
644
645
646
647
648
649
650
651
652
653
654
655
656
657
658
659
660
661
662
663
664
665
666
667
668
669
670
671
672
673
674
675
676
677
678
679
680
681
682
683
684
685
686
687
688
689
690
691
692
693
694
695
696
697
698
699
700
701
702
703
704
705
706
707
708
709
710
711
712
713
714
715
716
717
718
719
720
721
722
723
724
725
726
727
728
729
730
731
732
733
734
735
736
737
738
739
740
741
742
743
744
745
746
747
748
749
750
751
752
753
754
755
756
757
758
759
760
761
762
763
764
765
766
767
768
769
770
771
772
773
774
775
776
777
778
779
780
781
782
783
784
785
786
787
788
789
790
791
792
793
794
795
796
797
798
799
800
801
802
803
804
805
806
807
808
809
810
811
812
813
814
815
816
817
818
819
820
821
822
823
824
825
826
827
828
829
830
831
832
833
834
835
836
837
838
839
840
84

$$\frac{\Gamma_1}{\Delta}$$

ពិសេសបំផុត

1997

ការបំបែកប្រាក់ប្រចាំថ្ងៃ

นายแพทย์

Area Warden

Assembly Controller


การวิจัยนี้มีวัตถุประสงค์เพื่อศึกษา

১১৭৭ ১১ ১১৭৭ ১৭

[illegible]

แต่สำหรับประเทศไทย... คณะกรรมาธิการศึกษาและพัฒนาทรัพยากรมนุษย์ ได้จัดทำโครงการวิจัยเกี่ยวกับ "การพัฒนาทรัพยากรมนุษย์ในเขตเมืองและชนบท" ซึ่งได้ดำเนินการวิจัยตั้งแต่ปี ๒๕๓๖-๒๕๔๐ และได้ตีพิมพ์รายงานผลการวิจัยแล้ว

1. The first part of the paper is devoted to the study of the asymptotic behavior of the solutions of the system (1) as $t \rightarrow \infty$. It is shown that the solutions of the system (1) are bounded and tend to zero as $t \rightarrow \infty$ if the matrix A is stable and the matrix B is non-singular. The second part of the paper is devoted to the study of the asymptotic behavior of the solutions of the system (1) as $t \rightarrow \infty$ if the matrix A is not stable. It is shown that the solutions of the system (1) are bounded and tend to zero as $t \rightarrow \infty$ if the matrix A is not stable and the matrix B is non-singular. The third part of the paper is devoted to the study of the asymptotic behavior of the solutions of the system (1) as $t \rightarrow \infty$ if the matrix A is not stable and the matrix B is singular. It is shown that the solutions of the system (1) are bounded and tend to zero as $t \rightarrow \infty$ if the matrix A is not stable and the matrix B is singular.



12. **หมายเลขเอกสาร** P-Q-SIL-CN-FCIEMS-001; การจัดการงาน

71. GALT, J. W. 1963. 16

ศูนย์บริการความรู้ทางสังคมสู่สังคม (Crisis & Business Continuity Management Center)

อาคารควบคุมการผลิต (Central Control Building)

ให้จัดส่งใบกำกับภาษี(Central Control Room)

ศูนย์ปฏิบัติการวิจัยและติดตามผลกระทบ (Crisis Management)

ที่ประชุมการหลอมรวมฯ จะจัดเกิดเหตุ เป็นพื้นที่ที่ปลอดภัย
ไปกับทุกจุดที่ดูดีของ OC ที่ประชุมมาพบและตั้ง
ปฏิวัติ บอกรู้ให้ทั้งชุมชนทราบกรีกทุกแห่งทุก
ACG ผู้ใช้โปรแกรม

เกิดเหตุ
หน่วยงานนอก ยื่นขอ Fine Runner จะเข้าไปถึงจุด
จุดขึ้น (M22) รถประมาณสิบสิบล้านคัน
จุดตัดกับที่ถนน (เข้าแล้ว) ประสิทธิภาพมาก

นาย 3: ขวัญใจแม่บ้านรักโลก

Emergency Duty Team, ผู้บริหารหรือพนักงานที่รับผิดชอบ
ที่ปรึกษาเพื่อแจ้งหรืออำนวยความสะดวก ประสานงาน และ
ดำเนินการควบคุมดูแลฉุกเฉิน

Emergency Command Center - ICC, ศูนย์บัญชาการเหตุฉุกเฉิน

ทั้งสามบริษัทเหล่านี้ได้พบปะกันและกันที่สำนักงาน NPS และ
ซึ่งอยู่ใกล้กับบริษัท พีทีที โกลบอลคอมมิวนิเคชั่น จำกัด (มหาชน)
เป็นบริษัทชั้นนำระดับโลกด้านเทคโนโลยีโทรคมนาคมที่ใหญ่ที่สุด
ผู้สำรวจสามารถระบุถึงลักษณะของโครงการ (Economic
Director)

ผู้บัญชาการกองบัญชาการป้องกัน (Emergency Director)

ผู้พิทักษ์ความปลอดภัย มีหน้าที่ความปลอดภัยทางกายภาพและจิตใจ
ในการปกป้องระบบสารสนเทศจากผู้บุกรุกโดยไม่ได้รับอนุญาต
โดย (Kriegels, Incident-Management-System)

(b) (6) (4) Emergency Incident-Management System

ผู้พัฒนาภาษาอังกฤษ (Emergent Manager)

หน้า ๒๔๓๘๘๘

เจ้าแม่สุกขาตั้งตัวใหม่ 05:04:2022


นายสมชาย วัฒโนวัฒน์ กรรมการผู้จัดการ บริษัท ไทยพาณิชย์ จำกัด (มหาชน) ได้กล่าวถึงผลการดำเนินงานของบริษัทฯ ในช่วงไตรมาสแรกปีงบประมาณ ๒๕๖๒ ว่า บริษัทฯ ยังคงดำเนินธุรกิจตามแผนอย่างมีประสิทธิภาพ โดยสามารถรักษาระดับการดำเนินงานได้ตามเป้าหมายที่กำหนดไว้


1. *Introduction*

- EMAG
- กลุ่มโรงงานอุตสาหกรรมที่ตกกึ่งทางกันกรณีเหตุฉุกเฉิน (Emergency Mutual Aid Group)
- DMCC
- ศูนย์เฝ้าระวังและควบคุมคุณภาพสิ่งแวดล้อม ที่ตั้งอยู่ข้างใต้เขต อุตสาหกรรมบางปะอิน (Lawinment Monitoring Control Center)
- Emergency Response Team
- หน่วย Plant ERT และ Emergency Duty Team
- ER Duty
- ผู้มีส่วน SUE, Q-SH-CM และ พนักงาน Q-SH-CM ที่ปฏิบัติงานที่ Emergency Duty Team
- Fire Runner
- ผู้ทำหน้าที่เชื่อมกับสถานีวิทยุหน่วยงานภายนอกไปทางศูนย์ (OC หรือ MC3) ที่จุดเกิดเหตุ
- PIT
- ทีมระงับเหตุฉุกเฉิน (First Intervention Team)
- PIT-A
- ERT Team ของโรงงานที่เกิดเหตุ จัดจากกำลังพลภายในกะที่กำลังปฏิบัติงานโดย Shift Manager หรือ Shift Supervisor
- PIT-B
- PIT Team-Backup จากโรงงานที่ไม่ได้เกิดเหตุ จัดจากกำลังพลตามกะกำลังปฏิบัติงานของหน่วยงาน
- PIT-C
- Q-SH-CM
- PIT Team-Off Shift ของโรงงานที่เกิดเหตุที่ไม่กำลังสำรองที่เรียกจากหน่วยงานกะหยุด
- FTD
- Fire Truck Driver
- GEMC
- ศูนย์จัดการเหตุฉุกเฉิน “กลุ่มปลด” (P-VI) Group Emergency Management Center)
- IFAT
- นิคมอุตสาหกรรมแห่งประเทศไทย (Industrial Estate Authority of Thailand)
- DEAT-MTP
- นิคมอุตสาหกรรมบางปะอิน (Map Ta Phut Industrial Estate)
- MC
- ผู้ประสานงานเหตุฉุกเฉิน (Mutual Aid Coordinator)
- MCB
- อาคารควบคุมการเดินที่ ARO1 (Main Control Building)

- MCBA
- อาคารควบคุมการผลิตพื้นที่ ARO1 (Main Control Building)
- OC
- ผู้สั่งการ ณ ที่เกิดเหตุ (On Scene Commander)
- Operational Technology (OT-System)
- เทคโนโลยีระบบควบคุมกระบวนการผลิต DCS, ESO, PLC และ SCADA) ในระบบควบคุมที่โรงงานปิโตรเคมีภัณฑ์
- OSRP
- Oil Spill Response Plan/Contingency Plan
- Plant ERT
- Plant Emergency Response Team เป็นทีมที่ปฏิบัติการของหน่วยปฏิบัติการที่หน้าพื้นที่ตอบโต้ภาวะฉุกเฉินของโรงงานที่เกิดเหตุ
- Q-SH-CM
- หน่วยงานบริหารความมั่นคงและภาวะฉุกเฉิน
- RII
- นิคมอุตสาหกรรม ราย ไอ เดก
- RSO
- เจ้าหน้าที่ความปลอดภัยทางรังสี (Radiation Safety Officer)
- SM
- Shift Manager
- SMS
- ระบบข้อความสั้น (Short Message System)
- SS
- Shift Supervisor
- Triage Area
- จุดคัดกรองผู้บาดเจ็บที่ได้รับบาดเจ็บจากอุบัติเหตุจากภายนอก

6.2. สัญลักษณ์สำหรับวงรี





P-(Q-SII-CM)-OIMS-001: การจัดการงาน
ควบคุมภาวะฉุกเฉิน

■

6.2.3 กัญญาธารแห่งมฤตยู

กลุ่ม	เครื่องมือที่ใช้ หรือช่องทางเผยแพร่	รายละเอียดการเปิดเผย
Emergency Duty Team	SMS	ภายใน 1 ชั่วโมง
Plant EKT Group	SMS	ภายใน 1 ชั่วโมง
GMC (Group Management Committee)	SMS	ภายใน 1 ชั่วโมง
Q-SH-CM + Q-SH	SMS	ภายใน 1 ชั่วโมง
SC-CB, SC-SR, C-CG, F-CF	SMS	ภายใน 1 ชั่วโมง
VPI Group	SMS	ภายใน 1 ชั่วโมง
Community (ชุมชนใกล้โรงงาน)	SMS และโดย CSR	ภายใน 1 ชั่วโมง
ศูนย์สื่อสาร ปตท.	FAX	ภายใน 1 ชั่วโมง
กบอ. EMCC, RII, สมาคมฯ, สหฯ.	FAX หรือโทรศัพท์	ภายใน 1 ชั่วโมง
หน่วยงานในโรงงาน	ประกาศ PA	ภายใน 1 ชั่วโมง
พนักงานที่อยู่ภายในสำนักงาน	Email โดย HR	ภายใน 1 ชั่วโมง
สื่อมวลชน	Press Release โดย SC-CB	ภายใน 1 ชั่วโมง
Board of Director	Press Release โดย C-CG	ภายใน 1 ชั่วโมง
Analyst Investor SET	Press Release โดย P-CF	ภายใน 1 ชั่วโมง
Government Authorities	Press Release โดย SC-EX	ภายใน 1 ชั่วโมง


16M.121.F.23

- [illegible]

๑. รายงานประจำปี ๒๕๖๓

วันที่มีผลบังคับใช้: 05/04/2022

และบริษัท อี.บี.อี. จำกัด



P-(Q-SH-CM)-OEMS-001: การจัดการ
ความคมภาวะลูกสูบ

6.2.4 แบบรายงานผลวิจัยเชิงคุณภาพ



Emergency Incident Report

5142147, 1116-98

ผู้จัดทำเอกสารประกอบคือ ความก้าวหน้า การพัฒนาแผนงาน (SPP-Report)
 แผนที่: 0-2631-1498-0 โทร: 0-2631-2141 0-2631-2333 หรือ 0-2631-0311 (ศูนย์ฯ โทร.) และ 006-85655555 (ศูนย์ฯ)

1b

[illegible]

การประเมินผลของแผนปฏิบัติการประจำปี ๒๕๖๓ ของโรงเรียนวัดบ้านไร่

2. **સામાજિક નિયંત્રણ** : સામાજિક નિયંત્રણ એ એક પ્રકારનું નિયંત્રણ છે જે સમાજના સભ્યો દ્વારા એકબીજાના વર્તણૂકને નિયંત્રિત કરવા માટે વાપરવામાં આવે છે. આ નિયંત્રણ સમાજના સભ્યો દ્વારા એકબીજાના વર્તણૂકને નિયંત્રિત કરવા માટે વાપરવામાં આવે છે.

การปฏิบัติงานตามแผน	จำนวนครั้ง	จำนวนครั้งที่ได้รับ	จำนวนครั้งที่ได้รับ
การปฏิบัติงานตามแผน	1	1	1

$\mathbb{E}[\log_2 \lambda_i] = 1$	$\lambda_i = 2$	$\lambda_i = 2$	$\lambda_i = 2$
$\mathbb{E}[\log_2 \lambda_i] = 1.5$	$\lambda_i = 2, 3$	$\lambda_i = 2, 3$	$\lambda_i = 2, 3$
$\mathbb{E}[\log_2 \lambda_i] = 2$	$\lambda_i = 2, 3, 4$	$\lambda_i = 2, 3, 4$	$\lambda_i = 2, 3, 4$

[illegible]

1
 2
 3
 4
 5
 6
 7
 8
 9
 10
 11
 12
 13
 14
 15
 16
 17
 18
 19
 20
 21
 22
 23
 24
 25
 26
 27
 28
 29
 30
 31
 32
 33
 34
 35
 36
 37
 38
 39
 40
 41
 42
 43
 44
 45
 46
 47
 48
 49
 50
 51
 52
 53
 54
 55
 56
 57
 58
 59
 60
 61
 62
 63
 64
 65
 66
 67
 68
 69
 70
 71
 72
 73
 74
 75
 76
 77
 78
 79
 80
 81
 82
 83
 84
 85
 86
 87
 88
 89
 90
 91
 92
 93
 94
 95
 96
 97
 98
 99
 100
 101
 102
 103
 104
 105
 106
 107
 108
 109
 110
 111
 112
 113
 114
 115
 116
 117
 118
 119
 120
 121
 122
 123
 124
 125
 126
 127
 128
 129
 130
 131
 132
 133
 134
 135
 136
 137
 138
 139
 140
 141
 142
 143
 144
 145
 146
 147
 148
 149
 150
 151
 152
 153
 154
 155
 156
 157
 158
 159
 160
 161
 162
 163
 164
 165
 166
 167
 168
 169
 170
 171
 172
 173
 174
 175
 176
 177
 178
 179
 180
 181
 182
 183
 184
 185
 186
 187
 188
 189
 190
 191
 192
 193
 194
 195
 196
 197
 198
 199
 200
 201
 202
 203
 204
 205
 206
 207
 208
 209
 210
 211
 212
 213
 214
 215
 216
 217
 218
 219
 220
 221
 222
 223
 224
 225
 226
 227
 228
 229
 230
 231
 232
 233
 234
 235
 236
 237
 238
 239
 240
 241
 242
 243
 244
 245
 246
 247
 248
 249
 250
 251
 252
 253
 254
 255
 256
 257
 258
 259
 260
 261
 262
 263
 264
 265
 266
 267
 268
 269
 270
 271
 272
 273
 274
 275
 276
 277
 278
 279
 280
 281
 282
 283
 284
 285
 286
 287
 288
 289
 290
 291
 292
 293
 294
 295
 296
 297
 298
 299
 300
 301
 302
 303
 304
 305
 306
 307
 308
 309
 310
 311
 312
 313
 314
 315
 316
 317
 318
 319
 320
 321
 322
 323
 324
 325
 326
 327
 328
 329
 330
 331
 332
 333
 334
 335
 336
 337
 338
 339
 340
 341
 342
 343
 344
 345
 346
 347
 348
 349
 350
 351
 352
 353
 354
 355
 356
 357
 358
 359
 360
 361
 362
 363
 364
 365
 366
 367
 368
 369
 370
 371
 372
 373
 374
 375
 376
 377
 378
 379
 380
 381
 382
 383
 384
 385
 386
 387
 388
 389
 390
 391
 392
 393
 394
 395
 396
 397
 398
 399
 400
 401
 402
 403
 404
 405
 406
 407
 408
 409
 410
 411
 412
 413
 414
 415
 416
 417
 418
 419
 420
 421
 422
 423
 424
 425
 426
 427
 428
 429
 430
 431
 432
 433
 434
 435
 436
 437
 438
 439
 440
 441
 442
 443
 444
 445
 446
 447
 448
 449
 450
 451
 452
 453
 454
 455
 456
 457
 458
 459
 460
 461
 462
 463
 464
 465
 466
 467
 468
 469
 470
 471
 472
 473
 474
 475
 476
 477
 478
 479
 480
 481
 482
 483
 484
 485
 486
 487
 488
 489
 490
 491
 492
 493
 494
 495
 496
 497
 498
 499
 500
 501
 502
 503
 504
 505
 506
 507
 508
 509
 510
 511
 512
 513
 514
 515
 516
 517
 518
 519
 520
 521
 52

[illegible][illegible][illegible]

5 **NOTES ON CONTRIBUTORS**

[illegible][illegible]

ประเทศไทย

449.149.1171 53

วันที่ ๑๕/๐๕/๖๕ ๐๕:๐๔:๓๐

[illegible]

- 6.3.1.6 การรับมือกับภาวะฉุกเฉินที่เกิดจากเหตุการณ์ของ Emergency Duty Team อยู่ภายใต้การดูแลของ P (Q-SH-CM)-OEMS-001 ซึ่งกำหนดให้หน่วยงานที่เกี่ยวข้องดำเนินการตามแผนการรับมือภาวะฉุกเฉิน
- 6.3.1.7 หน้าที่และความรับผิดชอบทั่วไปของ Emergency Duty Team
 - ปฏิบัติตามที่แจ้งเวลา 08.00 น. ของวันศุกร์ ถึง เวลา 08.00 น. ของวันศุกร์ในสัปดาห์ต่อไป
 - สามารถเดินทางเข้ามายังโรงงานได้ภายในเวลาไม่เกิน 1 ชั่วโมง
 - ส่งมอบอุปกรณ์สื่อสาร ได้แก่ โทรศัพท์มือถือสื่อสาร ยานพาหนะ (ถ้ามี) รวมถึงเอกสารแนะนำแนวทางการปฏิบัติงานรายการให้การให้ครบถ้วน
 - ในการผลิตเหตุการณ์ระดับ 2 ให้ให้ทีมที่รับผิดชอบที่กำหนดในแผนการจัดการภาวะฉุกเฉิน ตามแผน บางสิ่งบางอย่างที่ต้องเข้ามาตั้งแต่ระดับ 1 ได้แก่ ER Duty, SHE Duty และ CSR Duty
 - จัดการ ประสานงาน หรือเข้าร่วมแก้ไขปัญหา และอำนวยความสะดวกในการปฏิบัติงานของหน่วยงานที่เกี่ยวข้องทั้งภายในและภายนอก
 - ไม่ยกย่องหรือลดทอนความสำคัญ
 - มีโทรศัพท์มือถือสำหรับ SMS อยู่กับตัวตลอดเวลาพร้อมทั้งตรวจสอบโทรศัพท์มือถือหรือใช้คอมพิวเตอร์
 - งดเว้นการดื่มเครื่องดื่มที่มีแอลกอฮอล์หรือรับประทานยาที่มีผลต่อการทำงาน
 - 40 มินัต์ก่อนถึงงาน ในระหว่างสัปดาห์ที่ทำงานให้ตาม Emergency Duty Room
 - แจ้งกับ Q-SH-CM หรือศูนย์สื่อสารของพื้นที่ที่เกี่ยวข้องในทันทีหากพบปัญหาในการติดต่อสื่อสาร หรือต้องให้โทรศัพท์มือถือใช้งาน
 - กรณีมีรถรถลงรถขับเปลี่ยนผู้ขับขี่ให้ On Duty ให้แจ้ง EO Duty, หัวหน้างาน Q-SH-CM และ Duty Team ของที่รับผิดชอบ
 - เมื่อได้รับข้อความการทดสอบ SMS ให้โทรศัพท์กลับทันทีเมื่อได้รับข้อความ SMS หรือข้อความส่งถึงในข้อความ SMS โดยศูนย์สื่อสารจะทดสอบ SMS เรียก Duty Team ทุกวันศุกร์ เวลา 1930 น.

6.3.2 Plant ERT (Plant Emergency Response Team)

- Plant ERT ของโรงงานแต่ละโรงงาน / หน่วยงานผลิตประจำโรงงาน / หน่วยงานผลิตต่าง ๆ ดังต่อไปนี้
- 1) VP ของโรงงาน

2) DM Plant Operations

3) DM Plant Asset Utilization

4) DM Plant Technical

5) Day Manager

6) DM SAE ของพื้นที่ (แต่ละกลุ่ม SHE ประจำพื้นที่)

7) EHS Supervisor ของพื้นที่ (แต่ละกลุ่ม Q-SH-CM ประจำพื้นที่)

8) DM Maintenance ของพื้นที่

9) DM HR Partner ของพื้นที่
- Plant ERT เป็นกลุ่มผู้บริหารการปฏิบัติการและการสนับสนุนของหน่วยการผลิตของโรงงาน หน้าที่รับผิดชอบในการปฏิบัติการและสนับสนุนการปฏิบัติงานแต่ละโรงงานโดยตรง (ซึ่งอาจหมายถึงพื้นที่ Emergency Duty Team ด้วย)
- ในกรณีที่ Emergency Duty Team ไม่ได้รับผลของการปฏิบัติการปกติในกรณีที่ศูนย์ปฏิบัติการฉุกเฉินของโรงงานที่เกิดจากเหตุการณ์ที่พบบ่อยในโรงงานที่เกิดโดยตรงจาก Plant ERT อยู่ในพื้นที่หรืออยู่ในระยะทางที่สามารถเดินทางมาถึงได้ในระยะเวลาที่เหตุการณ์ยังคงดำเนินอยู่ให้เดินทางมาทันทีที่สำนักงานรวบรวมเหตุการณ์เฉพาะที่ที่เกี่ยวข้องไปยังสำนักงาน SMS ได้ตามความจาก Emergency Duty Team
- ในการจัดการ SMS เพื่อการแจ้งเตือนเหตุการณ์ฉุกเฉินเฉพาะของโรงงานผู้บริหารของโรงงานอาจกำหนดให้ศูนย์สื่อสารเพิ่มเติมของศูนย์แจ้งเตือน SMS ได้ตามความเหมาะสมของแต่ละพื้นที่
- 6.3.3 แผนภาพปฏิบัติการที่แสดง Emergency Duty Team และ Plant ERT
- ให้ Emergency Duty Team และ Plant ERT ปฏิบัติหน้าที่เมื่อเกิดเหตุการณ์ฉุกเฉินโดยกำหนดแนวทาง ดังนี้
- 1) Emergency Duty Team และ Plant ERT จะปฏิบัติตามเมื่อเกิดเหตุการณ์ระดับ 2 และ 3

2) Emergency Duty Team เป็นทีมพร้อมตลอด 24 ชั่วโมง และตั้งอยู่ในระยะที่สามารถเดินทางมายังโรงงานได้ภายในไม่เกิน 1 ชั่วโมง

- 3) เมื่อถูกเรียกให้ปฏิบัติดังนี้
- ให้ Emergency Duty Team ไปรายงานตัวที่ ECC ทันที
 - ให้ Plant ERT ไปรายงานตัวที่ ECC เพื่อรับหน้าที่ตั้งจาก Emergency Duty Team (หากทำได้)
 - เมื่อ Plant ERT มาถึง ECC ให้ Emergency Duty Team สาขางานเดินเครื่อง ที่ไม่มีเจ้าของเดินส่งมอบหน้าที่ให้กับ Plant ERT และให้ที่อยู่ของห้อง Plant ERT จนกว่าสถานการณ์จะอนุญาตให้กลับที่พัก

- 6.4 แนวทางการปฏิบัติงาน Emergency Support Teams
- Emergency Support Teams หน่วยงานที่สนับสนุนอื่นๆ นอกเหนือจาก Plant ERT และ Emergency Duty Team ให้รับผิดชอบเพื่อให้เข้ามาช่วยสนับสนุนหรือช่วยเหลือการระงับเหตุฉุกเฉิน
- 6.4.1 จัณณะนำทีมปฏิบัติทั่วไปให้ Plant Emergency Support Roles เมื่อได้รับการแจ้งเตือน
- เริ่มทำการรายงานตัวที่ ECC ของโรงงานที่เกิดเหตุฉุกเฉินตามระบบ
 - รายงานตัวและบันทึกชื่อกับ Emergency Response Team ที่เกี่ยวข้องที่ ECC
 - เตรียมพร้อมผู้ที่สามารถแจ้งเตือนของโรงงานที่เกิดเหตุ / หรือสถานที่ที่ใกล้เคียง
 - แจ้ง
 - เตรียมพร้อมสนับสนุนการปฏิบัติงานตามระดับเหตุ หรืองานสนับสนุนตามที่ได้รับมอบหมาย
 - จัดให้ผู้ที่เกี่ยวข้องกับการรายงานของพื้นที่ที่เกี่ยวข้อง มุ่งความ
 - จัดเตรียมยานพาหนะพร้อมสำหรับเดินทางสนับสนุนกรณีเหตุ
- 6.4.2 กรณีเกิดเหตุเกินระดับ 3 หรือมีเหตุการณ์ต่อเนื่องทำให้เกิดความจำเป็นที่อาจต้องปฏิบัติเพิ่มเติม ดังนี้
- ประสานงานเตรียมกำลังพลสำหรับรับมือกับเหตุการณ์ที่เกิดขึ้นที่ปฏิบัติงาน และทีมสนับสนุนที่รองรับทีมงานเหล่านั้น
 - กรณีสถานการณ์ฉุกเฉินเพื่อให้ได้ผลดังต่อไปนี้ 2 ชุด (2 crew) พร้อมปฏิบัติการ
 - ให้เข้ามาช่วยเหลือด้านการเตรียมการสนับสนุนการดับเพลิง (เช่น PPE เครื่องมือ หรืออุปกรณ์การระงับเหตุอื่นๆ ที่จำเป็นเพิ่มเติม
 - เตรียมการสนับสนุนการระงับเหตุฉุกเฉินตามบทบาทหน้าที่ที่เป็นงานประจำ เช่น เกิดสิ่งผิดปกติ Workstop, งานบำรุงรักษาเครื่อง, งานหาหนะอาหาร, น้ำ เครื่องดื่ม
 - จัดเตรียมอุปกรณ์ ICT, อุปกรณ์สื่อสาร, การจัดพนักงานรับโทรศัพท์ที่เร่งรีบส่งผลกระทบต่อ
 - ซ้อม
 - ประสานให้พนักงานในหน่วยงานเตรียมการสนับสนุนเมื่อได้รับการร้องขอจาก ECC
 - จัดเตรียมยานพาหนะเฉพาะที่ได้รับแจ้งจาก ECC

6.5 การประสานงานทำหน้าที่ MC

เมื่อเกิดเหตุฉุกเฉินระดับ 2 หรือ 3 ให้ ER Duty ทำหน้าที่ MC1 จนกว่า DM SHM ของพื้นที่จะมารับหน้าที่ MC1 และให้ติดต่อเรียก Q-SH-CM Group ของพื้นที่มาสนับสนุนการรับมือเหตุ โดยไปช่วยเหลือหน้าที่ MC (MC1, MC2, MC3) ทำหน้าที่ประสานงานการช่วยเหลือภายในกลุ่ม PTTGC, กลุ่ม EMAG และหน่วยงานที่เกี่ยวข้องส่งการป้องกันและระงับเหตุตามระดับและสถานะหน้าที่ที่ Slaging Officer, ER Advisor หรือประกาศแจ้งเตือนกับมือรับเหตุ โดยให้แบ่งหน้าที่ดังนี้

- ให้ DM SHM ของพื้นที่เกิดเหตุ ทำหน้าที่ MC1 เป็นเวลาชุดที่ และ ER Advisor ที่ ECC ให้คำแนะนำกับ HVO, MCC ในการกำหนดวัตถุประสงค์ และกลยุทธ์การระงับเหตุช่วยเหลือในการวางแผนปฏิบัติการ และประสานงานกับศูนย์ควบคุมการระงับเหตุ
- ให้ EMS Supervisor ของพื้นที่เกิดเหตุ ทำหน้าที่ MC-2 เป็นประสานงานกับหน่วยระบบควบคุมฉุกเฉินจากภายนอกที่จุดแหล่งไฟของโรงงาน (Contact Point)
- ให้ EMS Chief ของพื้นที่เกิดเหตุทำหน้าที่ MC3 เป็นผู้ให้คำแนะนำและรับเหตุ OC การได้ปุ๋ยหรือระเบิดชุด และเก็บ Slaging Officer ช่วยเหลือ OC ในการจัดการทรัพยากร ที่มีจำกัด

กอง SHC ของพื้นที่อื่นและ กลุ่ม Q-SH-CM ที่ได้รับการเรียกให้เข้ามาสนับสนุน ให้เพิ่มเติม ให้ MC (MC1, MC2 และ MC3) ประสานงานกับคณะกรรมการบริหารกิจต่าง ๆ ตามความเหมาะสมของสถานการณ์และแผนปฏิบัติการที่กำหนด โดยอาจกำหนดไปทำหน้าที่ ดังนี้

- ให้จัดทีมทำหน้าที่ที่เกี่ยวข้องกับ SHM หรือหน้าที่อื่น ๆ ตามที่ได้รับมอบหมาย
- ให้ทำหน้าที่อยู่ใน FTA Team รับผิดชอบร่วมกับทีมระงับเหตุ /สนับสนุนการควบคุมเก็บดับเพลิง /ควบคุมการ operate งดปล่อยสิ่งปนเปื้อน /สนับสนุนปฏิบัติการควบคุมเก็บ
- ให้ทำหน้าที่ที่ระงับสถานการณ์ที่เกิดขึ้นที่ต้นตอควบคุมการจราจรตามแผนเส้นทางกำหนด /และประสานงานกับเจ้าหน้าที่ตำรวจจราจร
- ประสานงานกับหน่วยงานหน่วยงานภายในหรือภายนอกเพื่อปฏิบัติการกิจด้านทางระงับเหตุที่กำหนดตามแผน
- ประสานงานหรือการจัดการจัดหาและจัดการทรัพยากรระงับเหตุ
- หน้าที่อื่น ๆ ตามที่ได้รับมอบหมาย

6.6 การทำหน้าที่ SHM Coordinator

ให้ SHM Engineers / Senior Engineers ปฏิบัติหน้าที่ เป็น SHM Coordinator ใน Plant ERT และ Duty Team ซึ่งจะมีผู้ทำหน้าที่อยู่ใน Duty Team พร้อมกัน 3 คน มีหน้าที่ดังนี้

- ให้ข้อมูลและคำแนะนำกับ ECC ด้าน SHM
- สื่อสารกับ ปลด. (PTT SHM Duty)
- ตรวจสอบและประเมินผลกระทบด้านสิ่งแวดล้อมที่เกิดจากเหตุการณ์ใช้เครื่อง Pilling Inlet Valve Process (PIV) และ P-O-S-C และควบคุมการปล่อยของเสียให้เหมาะสมหรือไม่
- แจ้งหน่วยงานนอกและโรงงานข้างเคียงเกี่ยวกับ ได้รับผลกระทบ
- ประเมินและให้คำแนะนำควบคุมอันตรายด้านความปลอดภัยและสิ่งแวดล้อมในการปฏิบัติการและการระงับเหตุ
- ดูแลตรวจสอบให้ท่านแนะนำแจ้งการ ใช้และยกเลิก PPE
- ช่วยเหลือ ในกรณีฉุกเฉิน ผู้บาดเจ็บที่จุด Triang การล้อมรอบและการทำทะเบียนผู้บาดเจ็บก่อนส่งต่อและแจ้งข้อมูลผู้บาดเจ็บให้ ECC (HR Co.)ทราบ
- ทำหน้าที่ ผู้เก็บหลักฐานลงในแบบฟอร์มที่กำหนดและพร้อมแสดงข้อมูล
- แจ้งรายงาน หรือขออนุญาต หน่วยงานราชการที่เกี่ยวข้องตามกฎหมาย

บทบาทเมื่อ เมื่อเกิดเหตุฉุกเฉินระดับ 2 และระดับ 3 ให้ผู้รับผิดชอบ SHM คือ SHM On Duty ทั้ง 3 คนและให้ SHM On Duty ผู้ทำหน้าที่วิศวกรหรือ SHM เป็น On Duty ทั้ง 3 คน ให้ไปขอผู้เกี่ยวข้องที่ปฏิบัติงานที่จุดเกิดเหตุและอุปกรณ์ที่เกี่ยวข้อง โดยให้ SHM On Duty ดำเนินการตามขั้นตอนจาก SHM พื้นที่ (SHM ER) และทีมสนับสนุน



เจ้าแก้ว (นางสาวน)

ค่าควบคุมภายใน

6.8 การฟื้นฟูและปรับปรุงสภาพชุมชน

เพื่อให้บัณฑิตในภาควิชาคณิตศาสตร์เป็นผู้แทนของชาวระยองทุกหมู่เหล่าให้รอดพ้นจากผลกระทบจากการ
ใหญ่สามชนที่เกี่ยวพันกับโรงงานที่ผลิตและอุตสาหกรรมพืช กล้วยไม้เป็นการประเพณีที่ดีที่ควรต้อง
กับภาควิชาคณิตศาสตร์และกรมสรรพากร ดังนี้

- บังคับให้บริษัทปูนซีเมนต์ทุกบริษัทที่สกัดกากปูนซีเมนต์จากโรงปูนให้แสดงที่ตั้งและตัวงาน
- ถ้าหากคนร้ายไปเคาะตู้เงินฝาก ให้รัฐบาลจะรับมาไปดูแลเรื่อง
- ให้คนที่จะไปวางตัวทำเงินส่วนนี้ไปดูแลงาน และถ้ามีผู้ยากจนแบบที่ถ้าหมด
- ถ้าเกิดเหตุหรือมอบหมายให้ผู้ที่เกี่ยวข้องจัดการการดำเนินงานเพื่อให้ขึ้นไปตามแผน

ประวัตินักกีฬาและผลการแข่งขันงาน
ให้พิจารณาจากประวัติการฝึกซ้อมแข่งขันต่าง ๆ และภาพ ดังนี้

ประเด็นปัญหาที่ศึกษาเชิงบูรณาการในสัปดาห์ที่	จุดสนใจ
ประเด็นปัญหาที่ศึกษาเชิงบูรณาการในสัปดาห์ที่	จุดสนใจ
1. สภาพความเสียหายของเครื่องมือการวัด	
2. ผลกระทบด้านสิ่งแวดล้อม	
3. ผลกระทบด้านสุขภาพของพนักงาน	
4. ผลกระทบด้านจิตใจของชุมชนและภาคประชาสังคม	
5. ปัญหาด้านการบริหารจัดการทรัพยากรที่ใช้ทุกสัปดาห์	
6. การดำเนินการของคณะกรรมการผู้ประสานงาน	
7. กฎหมาย ประกันภัย และภาษี	
8. การตั้งศูนย์ช่วยเหลือผู้ประสบภัย	
9. ประเด็นปัญหาอื่น ๆ ในส่วนนี้	

2000

8. การตั้งสำนักงานเขตพื้นที่ฯ

● ตั้งที่สำนักงานเขต.....

9. ประเด็นปัญหาอื่น ๆ ในส่วนที่

● ตั้งที่สำนักงานเขต.....

15301171 1995 2


ระเทศาพิทักษ์ (ค.ร.ส. ๒)
หน้า ๕๐ จาก ๕๓
วิทยุสมัครเล่นใช้ 05:04:20.22
๒๕๕๔

[illegible]

สำนักงานส่งเสริมการค้าในต่างประเทศ

วันที่พิมพ์ฉบับนี้: 05/04/2022

ระกาศ (ค.ร. ๕๔)
หน้า ๕๐ จาก ๕๓
วันที่ ๕๔
วันที่ ๕๔
วันที่ ๕๔



6.10 รายการอุปกรณ์ประจําห้องปฏิบัติการ (Inventory Control List)

ที่	รายการ	หมายเหตุ
1	วัสดุตั้งสารเคมี (Toxic Subst.) (YPL)	
2	โทรศัพท์	
3	โทรศัพท์	
4	คอมพิวเตอร์	
5	ระบบเครือข่าย Internet	
6	Desk Top Computer หรือ Note Book สำหรับส่ง SMS	
7	Printer	
8	LCD Projector & Screen	
9	VDO Conference	
10	โทรศัพท์มือถือสองเครื่อง สำหรับใช้ติดต่อประสานงานกับหน่วยงานที่เกี่ยวข้อง	
11	ระบบบันทึกเสียง โทรศัพท์ และวิดีโอในศูนย์	
12	บอร์ดบันทึกสถานการณ์	
13	บอร์ดบันทึกภาพบริเวณตัวอาคาร Emergency Duty Teams	
14	นาฬิกา	
15	วาล์วประตูเหล็กสำหรับปิดกั้นเหตุการณ์ของโรงงาน บริเวณในรั้ว และ EMAG	
16	รายชื่อพนักงานที่ประจำอยู่ในพื้นที่ (Staff List)	
17	เอกสารข้อมูลความปลอดภัยของสารเคมี (Safety Data Sheet, SDS)	
18	Fire Incident Plan	
19	แผนตอบสนองฉุกเฉินสำหรับเหตุการณ์ฉุกเฉิน	
20	แผนผังโรงงานแสดงตำแหน่งอุปกรณ์ป้องกัน ประสิทธิภาพและประจุอุปกรณ์	
21	Process Schematics / P&ID Drawing	
22	CCTV cameras	
23	การเชื่อมโยงสัญญาณ Fire Alarm และ CCTV ไปยัง ECC S&E, ENCO และ EMCT	

* ECC บางศูนย์ที่ใช้ศูนย์กับระบบหลัก ECC เพื่อใช้ศูนย์สื่อสารร่วมกับโรงงานอื่นอาจมีลักษณะโรงงานหนึ่ง
ศูนย์

➤ 31ข

เอกสารตัวอย่าง Pre-fire plan





PTTGC	สาขา 7	PRE INCIDENT PLAN	EQUIPMENT NO.	O-FA-812E									
PLANT	U-CM-OP		UNIT NO.	Tank O-FA-811F									
AREA	BTF												
KEY PLAN: INCIDENT LOCATION		<p>Fire truck setup</p>	THREAT ZONE <table border="1"> <tr> <td>Greater than 10 kW/ (Sq m)</td> <td>64</td> <td>m.</td> </tr> <tr> <td>Greater than 5 kW/ (Sq m)</td> <td>92</td> <td>m.</td> </tr> <tr> <td>Greater than 2 kW/ (Sq m)</td> <td>144</td> <td>m.</td> </tr> </table> <p>Double click to enlarge side view contour</p>		Greater than 10 kW/ (Sq m)	64	m.	Greater than 5 kW/ (Sq m)	92	m.	Greater than 2 kW/ (Sq m)	144	m.
Greater than 10 kW/ (Sq m)	64		m.										
Greater than 5 kW/ (Sq m)	92	m.											
Greater than 2 kW/ (Sq m)	144	m.											

INCIDENT

1	Title (ชื่อเหตุการณ์)	<ชื่อเหตุการณ์ใช้ Front "Cordia New 16" ตัวหนา>		
	Possible cause & effects (สาเหตุ / เหตุการณ์และผลกระทบ)	ขณะที่ทำการ Transfer VCM จาก O-FA-811F to TPC Mech. seal leak ทำให้ VCM จำนวนมากรั่วออกมาเป็น Vapor Cloud ขณะที่ทีมงาน Hot work อยู่บริเวณ pump O-GA 812 E เกิดไฟลุกไหม้รุนแรงจนความร้อนส่งผลกระทบต่อกับท่อนำ Pipe Rack และถังมีอุณหภูมิสูงทำให้เกิด Explosion		
	Exact location (ระบุจุดที่เกิดเหตุของอุปกรณ์)	Pump O-GA 812 E	Equivalent pin hole (ขนาดของรูรั่วโดยประมาณ)	- มม.

INFORMATION

Type of incident		Tank: Choose an incident			
PROCESS CONDITION / APLICABLE DATA (กรอกเฉพาะข้อมูลที่เกี่ยวข้อง)					
Tank number / Location	O-FA 811F		Name of unit	Movement and Dispatching	
Roof type	n/a		Unit No.	O-FA 811F	
Diameter of tank :	21 m	Height	21 m	Equipment / Tag No.	O-FA-812E
Full surface area **	1,385 m ²	Product / Fluid / Component	Vinyl Chloride Monomer		
Height of point of leak	- m	Percent (%)	99.5 %		
Volume / Inventory	5,000 m ³	Boiling point	7 °F (-14 °C)		
Fire detection	n/a	Flash point	-108 °F (-78 °C)		
Isolation	Manual operations	Auto ignition temperature	882 °F (472 °C)		
Fire protection	Water spray	LEL (%vol.)	3.6 % LEL		
Pump out rate	250 m ³	UEL (%vol.)	33.0 % UEL		
Type of vent	n/a	Vapor density (to air)	2.15		
Design temperature	35 °C	Specific gravity (to water)	0.91 @ 25.25 °C		
Tank dike dimension	-	Physical property	Liquid		
Internal dike dimension	-	Water soluble?	Yes		
Health hazard	LIQUID MAY CAUSE FROSTBITE TO EYES AND SKIN. MAY CAUSE CENTRAL NERVOUS SYSTEM EFFECTS. CONTAINS VINYL CHLORIDE, A KNOWN HUMAN CANCER AGENT CAUSES DAMAGE TO LIVER AND PERIPHERAL NERVOUS SYSTEM THROUGH PROLONGED OR REPEATED EXPOSURE. CAUSES DAMAGE TO LUNGS THROUGH PROLONGED OR REPEATED EXPOSURE BY INHALATION. SUSPECTED OF CAUSING GENETIC DEFECTS. REPRODUCTIVE HAZARD		Operating pressure	9 kg/cm ²	
TLV-TWA / TLV-STEL	1 ppm		Operating temperature	35 °C	
Flammability	-		Flow rate	150 Ton/hr.	
Respirator type / Filter type / No	-				



Other information	<บันทึกข้อมูล / คำบรรยายอื่น ๆ ที่เป็นประโยชน์ต่อการวางแผน (ถ้าไม่มีให้ขีด -) กรอกข้อมูลโดยใช้ Cordia New 11>				
รูปที่เกิดเหตุ (Double click เพื่อขยาย)					

INCIDENT CONTROL PLAN

3	<div>1) Objectives (เป้าหมายการระงับเหตุ) (ใช้ Front Cordia New 11)</div> <div>1. ป้องกันการลุกลามไปถึงข้างเคียง</div> <div>2. ป้องกันความเสียหายที่จะเกิดกับโครงสร้าง Structure Pipe Rack</div> <div>3. ลดการรั่วไหล - หยุดการรั่วไหล</div> <div>4. ดับไฟที่ลุกไหม้ให้ได้</div>	<div>2) Strategies (แผนกลยุทธ์)</div> <div>1. ใช้น้ำฉีดหล่อเย็นถังข้างเคียงที่ได้รับผลกระทบจากถังที่มีความร้อน</div> <div>2. ใช้น้ำฉีดหล่อเย็นอุปกรณ์และโครงสร้างข้างเคียงที่ได้รับผลกระทบจากถังที่มีความร้อน</div> <div>3. ห้ามฉีดน้ำเป็นลำตรง ให้ดับเพลิงโดยการฉีดน้ำเป็นฝอย</div> <div>4. Set team เพื่อเข้า isolate - manual isolation</div>																													
	<div>3) Tactics (เทคนิคการปฏิบัติ / แผนปฏิบัติของ OC)</div> <div>1. เปิดน้ำระบบ Cooling ของ O-FA801E/F</div> <div>2. Cooling แนว Pipe Rack โดยใช้ Fixed Monitor</div> <div>3. FIT Team จัดทีมเข้าปิด Isolation Valve</div>	<div>4) ทรัพยากรที่ต้องใช้</div> <table><tr><th></th><th>คน / FIT / Fire Man</th><th>อุปกรณ์ Fire Truck</th><th>Monitor Flow Rate (lpm)</th><th>Foam Con (lire)</th></tr><tr><td>1</td><td>FIT TEAM&OC</td><td>4</td><td>-</td><td>-</td></tr><tr><td>2</td><td>FIRE TRUCK GC6</td><td>1</td><td>3300</td><td>3800</td></tr><tr><td>3</td><td>NPC&SE</td><td>8</td><td>1</td><td>2000</td></tr><tr><td>4</td><td>FIRE TRUCK GC11</td><td>5</td><td>1</td><td>3300</td></tr><tr><td>6</td><td>รวม (sum above)</td><td>18</td><td>3</td><td>8600</td></tr></table>		คน / FIT / Fire Man	อุปกรณ์ Fire Truck	Monitor Flow Rate (lpm)	Foam Con (lire)	1	FIT TEAM&OC	4	-	-	2	FIRE TRUCK GC6	1	3300	3800	3	NPC&SE	8	1	2000	4	FIRE TRUCK GC11	5	1	3300	6	รวม (sum above)	18	3
	คน / FIT / Fire Man	อุปกรณ์ Fire Truck	Monitor Flow Rate (lpm)	Foam Con (lire)																											
1	FIT TEAM&OC	4	-	-																											
2	FIRE TRUCK GC6	1	3300	3800																											
3	NPC&SE	8	1	2000																											
4	FIRE TRUCK GC11	5	1	3300																											
6	รวม (sum above)	18	3	8600																											

OPERATION ACTIONS

4	Control Room (ใช้ Front Cordia New 11) 1. ทำการ Stop pump ทันทีพร้อมทั้งติดต่อลูกค้า TPC และแจ้ง SS ให้รับทราบ การลดความดัน / การหยุดการรั่ว / การควบคุมหน่วยผลิตอื่น ที่ได้รับผลกระทบ ฯ 2. ทำการปิด Valve outlet tank EMV811F 3. ทำการปิด Valve discharge pump FCV-861 4. Monitor pressure loop suction pump PIA812F และรายงาน condition ต่อ SS 5. ประสานงานกับ ERS Team for emergency response	Field Operator (ใช้ Front Cordia New 11) 1. Activate สัญญาณ Local Alarm / แจ้งเหตุการณ์ ต่อ Shift Sup. / DCS Operator 2. Isolate breaker pump ที่ Sub. Station เพื่อตัดไฟที่จ่ายให้ Pump 3. เปิดน้ำระบบ Cooling ของ O-FA-811F, O-FA-801E 4. เปิด Fixed Monitor ข้างถัง O-FA-801E cooling pump 5. ต่อ Hose เข้ากับ Hydrant ข้าง bund wall หรือ ข้างรั้ว กอน. (ขึ้นอยู่กับทิศทางลม) เพื่อ Cooling pipe rack 6. ประสานงานกับ ERS Team for Emergency response				
---	---	--	--	--	--	--

FIRE FIGHTING

5

1.Fire Fighting Response (แผนการระงับเหตุ)

4.1) First Response (ดำเนินการโดย field operator ที่อยู่ในพื้นที่)

1. Operator ทำการควบคุมเหตุในเบื้องต้น ต่อสายดับเพลิงที่ HTM-20 ทำการ Cooling จุดเกิดเหตุ

4.2) Second Response (ดำเนินการโดย FIT Team /กำลังเสริมใน Plant)

ทิศทางลมพัดจากทิศใต้ไปทิศเหนือ

1.รถดับเพลิงคันที่ 1 ใช้ถนน R-10 เข้าประตู G-2 ใช้ถนน R-4 เข้าเข้าจอดบริเวณ HTM No.20ต่อสายน้ำฉีดเปลี่ยนทิศทางเปลวเพลิง และปิดวาล์ว

2.รถดับเพลิงคันที่ 2 ใช้ถนน R-10 เข้าประตู G-2 ใช้ถนน R-4 เข้า R-8 เข้าจอดบริเวณ HTM No. 13 ต่อสายเข้าทำการ Cooling Tank O-FA 811F

ทิศทางลมพัดจากทิศเหนือไปทิศใต้

1. รถดับเพลิงคันที่ 1 ใช้ถนน R-10 เข้าประตู E-2 ใช้ถนน R-9 เข้า R-8 จอดบริเวณ HT. No.806 ต่อสายน้ำฉีดเปลี่ยนทิศทางเปลวเพลิง และปิดวาล์ว

2.รถดับเพลิงคันที่ 2 ใช้ถนน R-10 เข้าประตู E-2 ใช้ถนน R-9 เข้าจอดบริเวณ HT. No. 12 ต่อสายเข้าทำการ Cooling Tank O-FA 811F

4.3) Third Response (การ set team เข้า manual isolate / fire attack)

-Isolate EMV, 811 F,-Stop Pump GA-812 E

2.Foam Discharge Equipment (ชนิดของอุปกรณ์ฉีดโฟมที่ใช้)

2.1) n/a 2.2) n/a 3.3) Flow rate *: - lpm

3.Foam Calculation (คำนวณโฟม) สำหรับ Choose an item

Tank Dia (m.)	0.0 m.
พื้นที่ผิววงกลันที่ที่เกิดเพลิงไหม้	0.0 m ²
อัตราการใช้โฟม solution	0.0 lpm/m ²
Foam solution rate ที่คำนวณได้	0.0 lpm.
Foam solution rate ที่ต้องใช้จริง*	0.0 lpm
Foam solution % *	0.0 %
Foam concentrate ที่ต้องใช้ต่อนาที	0.0 lpm
Application time *	0.0 นาที
ต้องใช้ foam concentrate รวม	0.0 ลิตร

4.Fire Water Application Calculation (คำนวณการใช้น้ำ)

1.Deluge Sys. O-FA811F=17838	17838	lpm
2.Deluge Sys. T-6982=19608	9804	lpm
3.Deluge Sys. O-FA801E=16330	8165	lpm
4.Deluge Sys.O-FA801F=16330	4082	lpm
5. Fixed Monitor2	1600	lpm
รวมปริมาณน้ำดับเพลิงที่ต้องใช้	41489	lpm

Max. water supply29303lpm

Drainage capacity...lpm

รวมปริมาณน้ำดับเพลิงที่ต้องใช้41489lpm



PTT Global Chemical
Public Company Limited

Pre-Incident Plan R-MO-OP: B.O-FA 811F

6

Drainage : Ensure ภายใน Bund ปิด Drain Line 2 นิ้ว

Environmental Issue: - หากVCM สัมผัสกับอากาศโดยตรง อาจทำให้เกิดการระเบิดได้โดย Peroxide เป็นตัวช่วยเร่งปฏิกิริยา

Prepared by
(ผู้ร่วมจัดทำ)

Operation:

Q-SH-CM staff:

Reviewed By (SM /SS / Shift Team)

ERS Supervisor

Final reviewed by Plant Manager

Date: 19 Nov-2020

สำเนา Hard Copy: เก็บที่ ECC ของพื้นที่, Shift Manager ของ Plant, ควบคุม Electronic File โดย Q-SH-CM

➤ 32ข

เอกสารการตรวจสอบสภาพพนักงานประจำปี 2566





ขอเชิญพนักงาน

ตรวจสอบสุขภาพพนักงานที่ปฏิบัติงานในพื้นที่
กระบวนการผลิต ประจำปี 2566



HEALTH CHECK

เพราะร่างกายต้องการ
ความดูแล



รู้ไหม ทำไมต้องตรวจสุขภาพ

- รู้สภาวะสุขภาพของตนเองว่าสมบูรณ์หรือบกพร่องหรือมีความเสี่ยงขนาดไหน เมื่อเทียบกับเพศ วัย อาชีพ
- เป็นการดูแลเชิงป้องกัน รู้เร็ว รักษา ก่อน หรือป้องกันก่อน
- รู้แนวทางในการปรับปรุงคุณภาพชีวิตด้านสุขภาพให้มีความเหมาะสม มีสุขภาพดี



ด้วยความปรารถนาดีจากหน่วยงาน Q-EH



กำหนดการตรวจสอบสภาพ

สำหรับพนักงานที่ปฏิบัติงานในพื้นที่ขบวนการผลิต 2566



Group
1

พนักงานที่ปฏิบัติงาน ณ GC 2, GC 3, GC 11, GC 12 & GC 17,
GC Glycol / Lab Center / GGO / GCP, GC PHENOL

	กะ	วันตรวจสอบสภาพ	เวลา	วันพบแพทย์	เวลา
			ณ อาคาร LAB HDPE2		ณ อาคาร LAB HDPE2
GC2	D	9 กุมภาพันธ์ 2566	06.30 - 14.30 น.	28 กุมภาพันธ์ 2566	08.30 - 16.00 น.
	B	10 กุมภาพันธ์ 2566		1 มีนาคม 2566	
	C	13 กุมภาพันธ์ 2566		3 มีนาคม 2566	
	A	16 กุมภาพันธ์ 2566		7 มีนาคม 2566	
	Day	15 กุมภาพันธ์ 2566		2 มีนาคม 2566	
GC PHENOL	กะ	วันตรวจสอบสภาพ	เวลา	วันพบแพทย์	เวลา
			ณ อาคาร Admin		ณ อาคาร Admin
	D	17 กุมภาพันธ์ 2566	06.30 - 14.30 น.	9 มีนาคม 2566	08.30 - 16.00 น.
	B	20 กุมภาพันธ์ 2566		10 มีนาคม 2566	
	C	23 กุมภาพันธ์ 2566		14 มีนาคม 2566	
	A	24 กุมภาพันธ์ 2566		15 มีนาคม 2566	
GC12 & GC17	กะ	วันตรวจสอบสภาพ	เวลา	วันพบแพทย์	เวลา
			ณ สถานพยาบาล		ณ สถานพยาบาล
	D	28 กุมภาพันธ์ 2566	06.30 - 14.30 น.	17 มีนาคม 2566	08.30 - 16.00 น.
	B	1 มีนาคม 2566		21 มีนาคม 2566	
	C	3 มีนาคม 2566		22 มีนาคม 2566	
	A	7 มีนาคม 2566		16 มีนาคม 2566	
GC11	กะ	วันตรวจสอบสภาพ	เวลา	วันพบแพทย์	เวลา
			ณ สถานพยาบาล		ณ สถานพยาบาล
	D	8 มีนาคม 2566	06.30 - 14.30 น.	28 มีนาคม 2566	08.30 - 16.00 น.
	B	10 มีนาคม 2566		29 มีนาคม 2566	
	C	14 มีนาคม 2566		31 มีนาคม 2566	
	A	15 มีนาคม 2566		3 เมษายน 2566	
GC GLYCOL, Lab Center, GGO, GCP	กะ	วันตรวจสอบสภาพ	เวลา	วันพบแพทย์	เวลา
			ณ อาคาร Work Shop Glycol		ณ อาคาร Work Shop Glycol
	C	23 มีนาคม 2566	06.30 - 14.30 น.	19 เมษายน 2566	08.30 - 16.00 น.
	A	24 มีนาคม 2566		12 เมษายน 2566	
	D	27 มีนาคม 2566		21 เมษายน 2566	
	Day	28 มีนาคม 2566		24 เมษายน 2566	
	B	29 มีนาคม 2566		18 เมษายน 2566	
GC 3	กะ	วันตรวจสอบสภาพ	เวลา	วันพบแพทย์	เวลา
			ณ อาคาร Warehouse		ณ อาคาร Warehouse
	C	20 เมย.	06.00-14.30 น.	17 พค.	8.30 - 16.00 น.
	A	21 เมย.		19 พค.	
	D	25 เมย.		22 พค.	
	B	26 เมย.		16 พค.	

สอบถามข้อมูลเพิ่มเติม กรุณาติดต่อสถานพยาบาลแต่ละแห่ง :

GC GLYCOL GGC/ Lab center # 7002, GC PHENOL # 3804, GC 3 #6004, GC 2 # 5008, GC 12 # 6996, GC 11 #6287

(คุณพิชามญช์ 089-1212742 , คุณวัลย์พร 086-8155076)



**พนักงานที่ปฏิบัติงาน ณ GC 1 (RO) & GC 13 (Innovation), GC 4 (Aro1) & GC7 / GC 8,
GC 5 (Aro2), GC 6 (Refinery)**

	กะ	วันตรวจสอบสุขภาพ	เวลา	วันพบแพทย์	เวลา
			ณ สถานพยาบาล		ณ สถานพยาบาล
GC6 (Refinery)	B	1 กุมภาพันธ์ 2566	07.00 - 14.30 น.	20 มีนาคม 2566	08.30 - 14.30 น.
	C	3 กุมภาพันธ์ 2566		14 มีนาคม 2566	
	A	6 กุมภาพันธ์ 2566		15 มีนาคม 2566	
	Day Staff	7 กุมภาพันธ์ 2566		16 มีนาคม 2566	
	D	8 กุมภาพันธ์ 2566		17 มีนาคม 2566	
GC4 (ARO1) & GC7 / GC8	กะ	วันตรวจสอบสุขภาพ	เวลา	วันพบแพทย์	เวลา
			ณ สถานพยาบาล		ณ สถานพยาบาล
	B	10 กุมภาพันธ์ 2566	07.00 - 13.00 น.	29 มีนาคม 2566	08.30 - 12.00 น.
	C	13 กุมภาพันธ์ 2566		31 มีนาคม 2566	
	A	15 กุมภาพันธ์ 2566		3 เมษายน 2566	
	D	17 กุมภาพันธ์ 2566		28 มีนาคม 2566	
GC5 (Aro2)	กะ	วันตรวจสอบสุขภาพ	เวลา	วันพบแพทย์	เวลา
			ณ สถานพยาบาล		ณ สถานพยาบาล
	B	20 กุมภาพันธ์ 2566	07.00 - 12.00 น.	7 เมษายน 2566	08.30 - 12.00 น.
	C	22 กุมภาพันธ์ 2566		10 เมษายน 2566	
	A	24 กุมภาพันธ์ 2566		4 เมษายน 2566	
	D	27 กุมภาพันธ์ 2566		5 เมษายน 2566	
GC1 (RO) & GC13 (Innovation)	กะ	วันตรวจสอบสุขภาพ	เวลา	วันพบแพทย์	เวลา
			ณ อาคาร L/S		ณ อาคาร L/S
	GC1	28 กุมภาพันธ์ 2566	07.00 - 12.00 น.	11 เมษายน 2566	08.30 - 12.00 น.
	GC1	1 มีนาคม 2566		12 เมษายน 2566	

สอบถามข้อมูลเพิ่มเติม กรุณาติดต่อสถานพยาบาลแต่ละแห่ง :

GC1 # 4777, GC 4 (ARO1) # 2167, GC 5 # 3221, GC6, GC 7 # 1198

(คุณพิชามญช์ 089-1212742 , คุณวลัยพร 086-8155076)

สำหรับให้บริการตามมาตรการป้องกัน COVID-19

- ☐ บุคลากรที่ให้บริการต้องมีการประเมินความเสี่ยงและแจ้งข้อมูลการเดินทางตามแบบประเมินความเสี่ยง COVID
- ☐ บุคลากรมีสุขภาพแข็งแรงไม่มีอาการทางระบบทางเดินหายใจ
- ☐ การตรวจ ATK ตามมาตรการของบริษัท ก่อนเข้าพื้นที่ให้บริการ
- ☐ การเป่าปอดให้มีการตรวจ ATK .ในวันที่ตรวจ พนักงาน Operation ที่ตรวจเข้างานตอนเช้า ให้พนักงานถ่ายรูปไปแสดงกรณีมีอาการคล้ายไข้หวัดหรือสงสัยเสี่ยง covid ให้งดเป่าปอดแพทย์จะใช้ผลตรวจอื่นๆเพื่อออกใบรับรองแพทย์ให้
- ☐ การจัดบริการมีระยะห่าง 2 เมตร
- ☐ บุคลากร สวมใส่ Mask และ Face shield
- ☐ สวมถุงมือระหว่างให้บริการเจาะเลือดและเปลี่ยนทุกครั้งให้บริการคนต่อไป
- ☐ การตรวจพิเศษด้วยรถบริการเคลื่อนที่ ให้มีการทำค + ระอาดฆ่าเชื้อก่อนและหลังให้บริการทุกครั้ง
- ☐ อุปกรณ์ให้มีการทำความสะอาดด้วย แอลกอฮอล์ ให้บริการท่านต่อไป



ขั้นตอนการรับบริการ

Flow การให้บริการออกตรวจสุขภาพนอกสถานที่
ของศูนย์ส่งเสริมสุขภาพและอาชีวเวชศาสตร์โรงพยาบาลกรุงเทพธัญบุรี

มาตรการที่ใช้ในการให้บริการผู้รับบริการ

- Social Distancing
- ขอความร่วมมือผู้รับบริการสวมใส่ mask
- ขอความร่วมมือผู้รับบริการล้างมือบ่อยครั้ง


มาตรการสำหรับเจ้าหน้าที่ให้บริการ

- เจ้าหน้าที่ที่ให้บริการใส่ mask ทุกคนเพื่อป้องกันการแพร่กระจายเชื้อ
- เจ้าหน้าที่ที่ให้บริการใส่หมวกคลุมผมทุกคน
- เจ้าหน้าที่ที่ให้บริการใส่ face shield ทุกคน
- ห้องตรวจที่ให้บริการมีการทำความสะอาดทุกครั้งหลังการใช้
- อุปกรณ์ที่ใช้ในการตรวจมีการทำความสะอาดทุกครั้งหลังการใช้ (เคสเคส)

มาตรการกำหนดคนที่เข้ารับบริการตรวจ

1 ชั่วโมงตรวจพนักงานได้ 25 คน ขอความร่วมมือบริษัทจัดจำนวนพนักงานให้เหมาะสมในแต่ละวันตามจำนวนชั่วโมงการเข้ารับบริการตรวจ

แผนผังและ Flow การให้บริการ





ขอเชิญพนักงานตรวจสอบสุขภาพ



สำหรับพนักงานที่ปฏิบัติงานในพื้นที่ขบวนการผลิต ประจำปี 2566

Group 1

พนักงานที่ปฏิบัติงาน ณ GC 2, GC 3, GC 11, GC 12 & GC 17,
GC Glycol / Lab Center / GCO / GCP, GC PHENOL



	ก	วันตรวจสุขภาพ	เวลา	วันพบแพทย์	เวลา		ก	วันตรวจสุขภาพ	เวลา	วันพบแพทย์	เวลา
			ณ อาคาร LAB HOPE2						ณ อาคาร HOPE2		ณ อาคาร Warehouse
GC2	D	9 กุมภาพันธ์ 2566	06.30 - 14.30 น.	28 กุมภาพันธ์ 2566	06.30 - 14.30 น.	GC11	D	8 มีนาคม 2566	06.30 - 14.30 น.	28 มีนาคม 2566	08.30 - 16.00 น.
	B	10 กุมภาพันธ์ 2566		1 มีนาคม 2566			29 มีนาคม 2566				
	C	13 กุมภาพันธ์ 2566		3 มีนาคม 2566			31 มีนาคม 2566				
	A	16 กุมภาพันธ์ 2566		7 มีนาคม 2566			3 เมษายน 2566				
		Day	15 กุมภาพันธ์ 2566	2 มีนาคม 2566	วันตรวจสุขภาพ		ก	วันตรวจสุขภาพ		วันพบแพทย์	
GC PHENOL	D	17 กุมภาพันธ์ 2566	06.30 - 14.30 น.	วันพบแพทย์	06.30 - 14.30 น.	GC GLYCOL, Lab Center, GGO, GCP	C	23 มีนาคม 2566	06.30 - 14.30 น.	19 เมษายน 2566	08.30 - 16.00 น.
	B	20 กุมภาพันธ์ 2566		9 มีนาคม 2566			A	24 มีนาคม 2566		12 เมษายน 2566	
	C	23 กุมภาพันธ์ 2566		10 มีนาคม 2566			D	27 มีนาคม 2566		21 เมษายน 2566	
	A	24 กุมภาพันธ์ 2566		14 มีนาคม 2566			Day	28 มีนาคม 2566		24 เมษายน 2566	
					15 มีนาคม 2566		B	29 มีนาคม 2566		18 เมษายน 2566	
GC12 & GC17	D	28 กุมภาพันธ์ 2566	06.30 - 14.30 น.	วันพบแพทย์	06.30 - 14.30 น.	GC 3	C	20 เมษายน 2566	06.30 - 14.30 น.	17 พฤษภาคม 2566	08.30 - 16.00 น.
	B	1 มีนาคม 2566		17 มีนาคม 2566			A	21 เมษายน 2566		19 พฤษภาคม 2566	
	C	3 มีนาคม 2566		21 มีนาคม 2566			D	25 เมษายน 2566		22 พฤษภาคม 2566	
	A	7 มีนาคม 2566		16 มีนาคม 2566			B	26 เมษายน 2566		16 พฤษภาคม 2566	

สอบถามข้อมูลเพิ่มเติม กรุณาติดต่อสถานพยาบาลแต่ละแห่ง :

GC GLYCOL GGC/ Lab center # 7002, GC PHENOL # 3804, GC 3 #6004, GC 2 # 5008, GC 12 # 6996 ,GC 11 #6287

(คุณพี่ขามยู่ 089-1212742 , คุณวีย์พร 086-8155076)





ขอเชิญพนักงานตรวจสอบสุขภาพ

สำหรับพนักงานที่ปฏิบัติงานในพื้นที่ขบวนการผลิต ประจำปี 2566



Group 2

พนักงานที่ปฏิบัติงาน ณ GC 1 (RO) & GC 13 (Innovation), GC 4 (Aro1) & GC7 / GC 8,
GC 5 (Aro2), GC 6 (Refinery)

กะ	วันตรวจสุขภาพ	เวลา	วันพบแพทย์	เวลา
		ณ สถานพยาบาล		ณ สถานพยาบาล
GC6 (Refinery)	B	1 กุมภาพันธ์ 2566	20 มีนาคม 2566	08.30 - 14.30 น.
	C	3 กุมภาพันธ์ 2566	14 มีนาคม 2566	
	A	6 กุมภาพันธ์ 2566	15 มีนาคม 2566	
	Day Staff	7 กุมภาพันธ์ 2566	16 มีนาคม 2566	
	D	8 กุมภาพันธ์ 2566	17 มีนาคม 2566	
GC4 (ARO1) & GC7 / GC8	กะ	วันตรวจสุขภาพ	วันพบแพทย์	เวลา
	B	10 กุมภาพันธ์ 2566	29 มีนาคม 2566	07.00 - 13.00 น.
	C	13 กุมภาพันธ์ 2566	31 มีนาคม 2566	
	A	15 กุมภาพันธ์ 2566	3 เมษายน 2566	
	D	17 กุมภาพันธ์ 2566	28 มีนาคม 2566	

กะ	วันตรวจสุขภาพ	เวลา	วันพบแพทย์	เวลา
		ณ สถานพยาบาล		ณ สถานพยาบาล
GC5 (Aro2)	B	20 กุมภาพันธ์ 2566	7 เมษายน 2566	08.30 - 12.00 น.
	C	22 กุมภาพันธ์ 2566	10 เมษายน 2566	
	A	24 กุมภาพันธ์ 2566	4 เมษายน 2566	
	D	27 กุมภาพันธ์ 2566	5 เมษายน 2566	
GC1 (RO) & GC13 (Innovation)	กะ	วันตรวจสุขภาพ	วันพบแพทย์	เวลา
	GC1	28 กุมภาพันธ์ 2566	11 เมษายน 2566	07.00 - 12.00 น.
	GC1	1 มีนาคม 2566	12 เมษายน 2566	

สอบถามข้อมูลเพิ่มเติม กรุณาติดต่อสถานพยาบาลแต่ละแห่ง :
GC1 # 4777, GC 4 (ARO1) # 2167, GC 5 # 3221, GC6, GC 7 # 1198
(คุณพิชิตเมญู 089-1212742 , คุณวัลย์พร 086-8155076)



เอกสารโปรแกรมการตรวจสอบสภาพพนักงาน (Procedure)





เอกสารนี้จัดทำขึ้นเพื่อใช้ประกอบการใช้งาน งานตรวจสุขภาพพนักงานประจำปี
ซึ่งจ้างงาน โดย GC และผู้ที่เกี่ยวข้องให้บริการงานตรวจสุขภาพ “ผู้ให้บริการ” ในเอกสารชุดนี้จะเป็นการกำหนด
รายละเอียดต่างๆ ที่เกี่ยวข้องกับการทำงานซึ่งทั้งหมดมีรายละเอียดดังนี้

1. ลักษณะงาน
2. ข้อกำหนดสถานที่ทำงาน
3. ข้อกำหนดเพิ่มเติม
4. ขอบเขตความรู้รับผิดชอบ
5. ภาวะอันตราย
6. ช่วงเวลาในการเข้าปฏิบัติงาน
7. การส่งมอบงาน
8. การรับประกันผลงาน
9. ข้อกำหนดอื่นๆ

1. ลักษณะงาน

การตรวจสุขภาพประจำปี คือ การตรวจสุขภาพเพื่อสุขภาพความสมบูรณ์ของร่างกายตามความผิดปกติได้
ก่อนที่จะลุกลาม เรื้อรัง จนแสดงอาการ และยังช่วยยืนยันเตือนเบาะแสของร่างกายให้อนุกรมิกมา และการได้รับการรักษา
อย่างทันเวลาที่ การตรวจสุขภาพประจำปีจะช่วยให้ทราบถึงสุขภาพของตัวเอง และการตรวจสุขภาพประจำปี เรื่องเพศ อายุ
และการตรวจตาจะช่วยให้ทราบว่าตาของเรามีปัญหาหรือไม่ หรือมีปัญหาเกี่ยวกับสายตา การตรวจสุขภาพประจำปีจะช่วยให้ทราบถึงสุขภาพของ
พนักงาน โดยการตรวจสุขภาพประจำปี และการตรวจสุขภาพประจำปีจะช่วยให้ทราบถึงสุขภาพของพนักงานประจำปี
ประเมินว่าพนักงานมีสุขภาพเหมาะสมกับการทำงานหรือไม่ หรือมีข้อบกพร่องในการทำงานหรือไม่ ได้รับ
ผลกระทบจากการทำงานหรือไม่

2. ข้อกำหนดการทำงาน

- 2.1 ผู้ให้บริการจะต้องตรวจสุขภาพพนักงานประจำปี ที่ GC กำหนดซึ่งรายละเอียดการตรวจสุขภาพ สามารถ
เปลี่ยนแปลงได้ตามความเหมาะสมของสถานการณ์ โดยเป็นการพิจารณาจาก Q-EH-OH
- 2.2 คุณสมบัติของห้องปฏิบัติการ และบุคลากร :
2.2.1 ได้รับการรับรองมาตรฐานคุณภาพ เช่น ISO 15189 : 2007 / Laboratory accreditation (รายการ
บริการคุณภาพทั้งหมด) ซึ่งได้รับการตรวจพบโดยมาตรฐานงานเทคนิคการแพทย์ (IA) (โดย
สมาคมเทคนิคการแพทย์) / EQAC (โดยคณะกรรมการแพทยสภาวิทยาลัยการแพทย์ หรือสมาคม
ตรวจสอบ และรับรองคุณภาพทั้งปวง) ซึ่งต้องอยู่ภายใต้เงื่อนไขที่ 10 ในรายการ 1 ที่ให้ตาม
BIA (จะพิจารณาเฉพาะ parameter ที่จะให้บริการตรวจค่า แก่ GC group)

- 2.2.2 มีบุคลากรผู้ให้บริการทั้งหมด ไม่ต่ำกว่า 3 คน. เหตุที่ใช้บุคลากรทั้งหมดและตรวจสุขภาพ
ถูกต้องของผลจากห้องปฏิบัติการเช่นเช่นเช่นเช่นเพื่อ ให้การวินิจฉัยมีความถูกต้องและ
ของเครื่องมือ (QA/QC)
- ให้ส่งหลักฐานแสดงคุณสมบัติผู้ให้บริการและมาตรฐานของเครื่องมือที่ใช้กับบริการประกอบการให้บริการ และ
หลักฐานใบรายงานสรุปผลการตรวจที่จัดส่งให้บริษัท

ผู้ให้บริการ ส่งเอกสารยืนยันคุณสมบัติตามข้อ 3.1-3.2 ให้ GC-EH-OH ตรวจสอบว่าพนักงานที่คัดเลือกผู้ที่จะ
ให้บริการ (ผู้ให้บริการ)

- 2.3 บุคลากรทางการแพทย์ และผู้ให้บริการที่เข้ามาให้บริการตรวจ ณ บริษัท ต้องประกอบด้วย :
2.3.1 แพทย์เวชศาสตร์ครอบครัว หรือ แพทย์เวชศาสตร์ครอบครัว / ได้รับการศึกษาที่มีบัตรประกอบโดย
กรรมการแพทย์ กระทรวงสาธารณสุข แสดงว่าผ่านการอบรมหลักสูตร 2 เดือน / หลักสูตร 2
สัปดาห์ เป็นผู้ให้บริการวิชาชีพ และลงทะเบียนในรายงานผลการตรวจสุขภาพและสุขภาพ
2.3.2 เทคนิคการแพทย์ มีใบประกอบวิชาชีพเทคนิคการแพทย์หรือหลักฐานการประกอบวิชาชีพ
ให้บริการ ณ จุดเกิดตัวอย่างเช่นหรือเป็นผู้ที่ลงทะเบียนการตรวจสุขภาพในของภาควิชาการแพทย์
การตรวจทางห้องปฏิบัติการที่รายงานผลโดยวิชาชีพอื่น นอกเหนือจากนี้
2.3.3 พยาบาลวิชาชีพ ที่จบการศึกษาทางด้านพยาบาลหรือพยาบาลวิชาชีพ ระดับปริญญาตรี หรือ โท /
ผ่านการอบรมหลักสูตรเฉพาะทางด้านการพยาบาลหรือพยาบาล หลักสูตร 4 เดือน / 60 ชั่วโมง
เป็นผู้ให้บริการตรวจทางด้านวิชาชีพอื่น และจุดเก็บตัวอย่างเลือด และให้บริการตรวจ
รายการตรวจทางห้องปฏิบัติการ เช่น การตรวจสมรรถภาพทางสายตา การตรวจสมรรถภาพ
ได้ยิน การตรวจสมรรถภาพปอด การตรวจคลื่นไฟฟ้าหัวใจ เป็นต้น

- 2.3.4 รายการตรวจสุขภาพเฉพาะทางอื่นๆ ที่มีความจำเป็นต้องเข้ามาหาพื้นที่ให้บริการอบรมหลักสูตร
เฉพาะทางการตรวจนั้น เช่นการตรวจ Urinalysis ของห้อง x-ray ผู้ให้บริการจะต้องเป็นผู้ที่มี
ระดับการศึกษา ไม่ต่ำกว่า ระดับปริญญาตรี ด้านหลักสูตรการตรวจเฉพาะทางนั้นมีการ
รับรองโดย สถาบัน หรือ สถาบันที่ดูแล โดยหน่วยงานราชการที่เข้าชื่อเข้างานโดยหลักสูตร
ที่เข้ารับการอบรมการมีระยะเวลาของหลักสูตรอย่างน้อย 20 ชั่วโมง หรือมีระยะเวลาในการ
ศึกษาปฏิบัติ ไม่ต่ำกว่า 50 % ของระยะเวลาหลักสูตร และหลังจากเข้าปฏิบัติงานเป็นผู้ที่
การตรวจและมีความรู้พื้นฐานการตรวจเพื่อเพิ่มพูนความรู้ เช่นสามารถตอบคำถาม 5 ปี

ขณะให้บริการปฏิบัติงานปฏิบัติงานที่ให้บริการที่หน่วยงานภายนอกหรือหน่วยงานอื่นที่ผู้ควบคุมการ
บริการ ของเจ้าหน้าที่ ของเจ้าหน้าที่ ณ จุดบริการให้บริการทางการแพทย์ ภายนอก และวินิจฉัย โดย

[illegible][illegible]



4. ขอบเขตความรู้ที่ต้องการ

No.	Description	GC	ผู้ให้บริการ
1.	จัดเตรียมสถานที่ พร้อมสิ่งอำนวยความสะดวกต่าง เช่น มีไฟฟ้า	✓	
2.	เครื่องมือ และ อุปกรณ์ต่าง ๆ สำหรับให้บริการตามมาตรฐานป้องกัน covid-19		✓
	<ul style="list-style-type: none">บุคลากรที่ให้บริการต้องมีการประเมินความเสี่ยงและแจ้งข้อมูลเมื่อผลการตรวจ ATK ตามมาตรฐานกักกันบุคลากรมีสุขภาพแข็งแรงผู้ให้บริการและผู้รับบริการทำมาตรการคัดแยกตัว และตรวจ ATK ก่อนเข้าพื้นที่ให้บริการตามมาตรการของบริษัทการจัดบริการระยะห่าง 2 เมตรบุคลากร สวมใส่ Mask ชุดกันบุคลากร สวมใส่ Mask และ Face shield กรณีที่ให้บริการระยะห่างได้ไม่ถึง 2 เมตรสวมถุงมือระหว่างให้บริการและใส่ถุงมือเมื่อเสร็จสิ้นการตรวจการตรวจคัดแยกโรคระบาดเบื้องต้น เพื่อให้การทำการและลดความเสี่ยงต่อการเกิดโรคอุปกรณ์ให้บริการทำความสะอาดแอลกอฮอล์ 70 % ก่อนให้บริการท่านต่อไป		<div>✓</div> <div>✓</div> <div>✓</div>
3.	สถานที่ให้บริการ		
4.	การเตรียมการขนส่ง		
5	การเตรียมตัวกับเรื่อง wase		

5. การเสนอราคา

ให้ทำการเสนอราคาตามแบบรายการในหมายเหตุ package ในกรณีที่จำเป็นต้องทำการติดตาม ความ เป็นจริง (โดยต้องได้รับการตรวจสอบจากหน่วยงานเจ้าของกิจการ) โดยนำเสนอค่าบริการที่เห็นเป็นประโยชน์

การเสนอราคาแบบเหมาเป็นค่าบริการ

หมายเหตุ : หากผู้ร่วมเสนอราคา ยังไม่มีความเป็นอยู่ดีเกี่ยวกับทาง GC ต้องดำเนินการให้สิทธิ์เสนอราคาในช่วง technical

proposed evaluation ไม่ใช้ส่วนการเสนอราคาของบริษัท

6. ช่วงเวลาในการเข้าปฏิบัติงาน

6.1 การดำเนินการตรวจสุขภาพในแต่ละพื้นที่ที่กำหนดระยะเวลาทั้งหมด 8 วันต่อ 1 plant โดยแบ่งเป็น

- เก็บตัวอย่างชีวภาพ และการตรวจทางยาชีวเคมี 4 วัน
- ตรวจร่างกายโดยแพทย์อีก 4 วัน
- ระยะเวลาให้บริการตั้งแต่เวลา 07.00-16.00 น. ทั้งนี้สามารถเปลี่ยนแปลงได้ตามความเหมาะสมของ สถานการณ์โดยประสานงานกับหน่วยงานผู้แต่งตั้ง Q-EH-OH
- ลำดับขั้นตอนการทำงานต่อเนื่องไปตามที่เอกสารแนบ 2 ทาง TOR

6.2 ช่วงเวลาเข้าปฏิบัติงานตรวจสุขภาพประจำปี

พนักงานประจำพื้นที่ระยะของ : กัญฉะ - คูหาหม

พนักงานประจำพื้นที่กัญฉะ : คูหาหม - พลุคักกาน

7. การส่งมอบงาน

7.1 ผู้ให้บริการจะต้องจัดทำและส่งมอบผล 6 รูปไปทาง ดังนี้

แนบที่ 1 : ผลตรวจสุขภาพ

ผลการตรวจสุขภาพ ผู้รับพนักงานเป็นรายบุคคล ภายใน 21 วันทำการ (3 สัปดาห์) นำจากวันสุดท้าย ของการตรวจ ณ ที่ GC Group โดยประกอบไปด้วย

ลักษณะข้อมูลสุขภาพ ดังนี้

- ผลการตรวจสุขภาพในแต่ละรายการตรวจ โดยเปรียบเทียบผล 2 ปีต่อเนื่อง (หรือผลการตรวจ 4 ครั้งที่ผ่านมา)
- รายงานสรุปผล. ความเห็นของแพทย์ ต้องมีบทสรุปสุขภาพของผู้ที่มีผลกระทบหรือเป็น ผู้ป่วยต่อ ผลการปฏิบัติงานหรือลักษณะงานที่ผู้จ้าง ได้รับมอบหมายและคำวินิจฉัยของแพทย์ผู้เชี่ยวชาญ
- ค่าสมัครสมัครกลางค่าเดินทาง
- ค่าเดินทางระยะใกล้และผลการตรวจสุขภาพในแต่ละรายการตรวจ
- คำแนะนำในการปฏิบัติ โดยเฉพาะสำหรับผู้ที่มีผลตรวจผิดปกติ กรณีที่ผลตรวจเกินมาตรฐาน และในวันที่มีแพทย์มีความเห็นถึงตรวจซ้ำในแพทย์ขึ้นในส่งตรวจค่า ระยะการตรวจและวิธีส่ง ตรวจ (รายการตรวจสุขภาพเฉพาะงานการที่มีอยู่ในรายการตรวจประจำปีเท่านั้น)
- เอกสารใบส่งตรวจค่า



F-Q-EH-OH-001_51
xlsx

ทั้งนี้ในการส่งผลการตรวจสุขภาพตามแนบของแนบนี้



1) งานของและผลของพนักงานประจำ "Contingent" หรือ "ก๊อปปี้" เอกการจ้างจ้างพนักงาน และสำเนาทั้งถึง Q-EI-OI และ SHE แต่ละพื้นที่ที่จะเป็นผู้นำส่งพนักงาน

แบบที่ 2 : ส่วนของงานสุขภาพพร้อม CD

รายงานวิเคราะห์ผลการตรวจสุขภาพไปหาพร้อมของพนักงานประจำ (Summary Report) การจัดเรียงให้เรียงตามพื้นที่กลุ่มงาน จัดส่งภายใน 30 วันทำการ นับจากวันสุดท้ายของการตรวจที่ GC group (นับจากวันสุดท้ายจนสุดท้ายของการพบแพทย์) โดยโรคและภัยคุกคามของข้อมูลภายนอก ดังนี้

ข้อมูลสรุปผลการตรวจสุขภาพของพนักงาน GC group เรียงตามสาขาน (กลุ่มธุรกิจ) โดยแยกเป็นฝ่าย และส่วน

- แสดงแนวโน้มของพฤติกรรมสุขภาพในแต่ละรายการตรวจง ปรอซ์เซ้นความถี่ของแผนตรวจการแพทย์ประจำปีเพื่อป้องกันโรคจากการทำงานตาม pmc/mgsc/et ของการตรวจ
- รายงานกลุ่มโรค วินิจฉัยและข้อเสนอแนะแนวทางป้องกันแก้ไข โดยแพทย์ด้านวิชาชีพที่ทำการรับความรับผิดชอบ 5 อันดับแรก (top five)
- แบบแปล last calibration, standard method ในการเก็บและวิเคราะห์ตัวอย่าง
- เสนอใบสรุปผลการตรวจฯ ว่าพบ / ไม่พบว่าเป็นความผิดปกติใดๆ ซึ่งเกี่ยวข้องกับสุขภาพการทำงาน โดยมีแพทย์ด้านวิชาชีพที่รับผิดชอบมารับทราบ

- แพทย์ด้านวิชาชีพที่รับผิดชอบในการตรวจสุขภาพจะตอบเป็นผลเลือดอีกด้วยว่ามีสำเนาไป Coe/office อยู่ไม่หลักฐานที่แบบมา

- excel file รายงานผลการวิเคราะห์ ถ้าไม่แยกแต่ละระบบตามที่บริษัทกำหนด
- จัดเตรียมผลการตรวจสุขภาพของพนักงานในรูปแบบ excel file (ผล lab ผลการตรวจ) โดยจัดเรียงตามวันที่ทำการ ผลการตรวจสุขภาพตรวจผล lab ผลการวินิจฉัยแยกแยะผลการตรวจอื่นๆ จัดทำเป็น x-cell เรียงผลการตรวจ เรียงๆ จนครบทุกรายการตรวจ และทุกรายการผล lab ของพนักงานแต่ละบุคคลพร้อมจำแนกเป็นระบบ เช่น ระบบเลือดหรือระบบกระดูกไม่ได้ในแต่ละระบบ ทุกระบบที่ทำงาน ต้องจัดเรียงตามรหัสพนักงาน และจัดทำแยก file ตามให้ทีม SME แต่ละพื้นที่

รายงานสรุปผลการตรวจสุขภาพประจำปีจัดทำพร้อมการส่งให้กับ 15 พฤศจิกายน ของทุกปี หรือตามที่ GC กำหนด

ANALYSIS/ANALYSIS REPORT									
NO	NAME	Sex	Age	Height	Weight	BMI	BP	HR	Temp
1	สมชาย ใจดี	Male	35	170	65	22.6	120/80	72	36.5
2	สมชาย ใจดี	Male	35	170	65	22.6	120/80	72	36.5
3	สมชาย ใจดี	Male	35	170	65	22.6	120/80	72	36.5
4	สมชาย ใจดี	Male	35	170	65	22.6	120/80	72	36.5
5	สมชาย ใจดี	Male	35	170	65	22.6	120/80	72	36.5
6	สมชาย ใจดี	Male	35	170	65	22.6	120/80	72	36.5
7	สมชาย ใจดี	Male	35	170	65	22.6	120/80	72	36.5
8	สมชาย ใจดี	Male	35	170	65	22.6	120/80	72	36.5
9	สมชาย ใจดี	Male	35	170	65	22.6	120/80	72	36.5
10	สมชาย ใจดี	Male	35	170	65	22.6	120/80	72	36.5

แบบที่ 3 : ส่วนของตรวจสุขภาพคัด สำหรับ สถานพยาบาล

รายงานสรุปสุขภาพ โดยสรุปผลทั้งหมดจากสุขภาพของพนักงานในกรณีตาม 1 แผน หรือผลงาน โดยแพทย์อาชีวเวชศาสตร์ ส่งให้บริษัท เพื่อดำเนินการต่อไปหรือให้ข้อมูลพยาบาล ภายใน 30 วันทำการ นับจากวันสุดท้ายของการพบแพทย์ ที่ GC group จัดเรียงตามรหัสพนักงานจัดส่งให้แต่ละ SME พื้นที่

แบบที่ 4 : ใบรับรองแพทย์สำหรับงานที่มีความเสี่ยงสูงและไม่รับรอง Fitness Certificate

1. สรุปความเห็นแพทย์เป็นรายบุคคล สำหรับพนักงานกลุ่มเสี่ยงที่สุขภาพ และ ไม่สามารถปฏิบัติงานใน อื่นๆ ได้ โดยแพทย์หรือแพทย์อื่น ๆ พร้อมระบุสาเหตุที่ไม่สามารถปฏิบัติงานได้ (รวมทั้งประวัติของพนักงานที่ ได้เข้ารับการรักษาในครั้ง นี้ แต่ ไม่มีสิทธิทำงาน) ทั้งนี้ ในแพทย์ ยาวี วิชาชีพทางการแพทย์หรือรังสีวิทยา ส่งให้ SME พื้นที่ ภายใน 15 วันทำการ นับจากวันสุดท้ายของการตรวจแต่ละพื้นที่
2. ใบรับรองแพทย์สำหรับงานที่มีความเสี่ยงสูง ลงบันทึกให้พนักงาน
3. สำเนาอยู่ในใบรับรองแพทย์ สำหรับงานที่มีความเสี่ยงสูง - สถานพยาบาล จัดเรียงตามรหัสพนักงานจัดส่งให้แต่ละ SME พื้นที่ ให้ได้รับรองแพทย์สำหรับงานที่ยากที่สุด ต้องการจัดส่งภายใน 15 วันของวันสุดท้ายของการตรวจแต่ละพื้นที่

การตรวจฯ ในแต่ละพื้นที่ตรวจ



แบบที่ 5 : ผลการตรวจสุขภาพ
ให้จัดเรียงผลการตรวจฯ และส่งรายงาน โดยเรียง ตามรหัสพนักงาน ลงในแฟ้มรายงานผลการตรวจสุขภาพ

รายงานผลการตรวจสุขภาพ ซึ่งทำไว้สำหรับนำมาใส่ในแฟ้มประวัติส่วนตัวของพนักงานซึ่งเก็บไว้ในสถานพยาบาล ของแต่ละ SME พื้นที่ โดยรวบรวมผลการตรวจฯ รายการต่างๆ ไว้ด้วยกันและแยกแยะกับแฟ้มประวัติสุขภาพ
• ผลตรวจจาก ให้บันทึก กับกับ basic/ประวัติส่วนตัวกับแฟ้มแพทย์



- ผลการตรวจผลปรมาณภาพปกติ ครรภ์ พร้อมคำวินิจฉัยมีบุตร
- ผลการตรวจคลื่นไฟฟ้าหัวใจ กราฟ พร้อมคำวินิจฉัยแพทย์ ของแพทย์ ราษฎร์ราม รัชกิจ
- ผลการตรวจ การรับสัมผัสสาร และผลการตรวจ โดเนน
- ผลการตรวจร่างกายบุคคลอื่น
- ผลการตรวจของภาพปรมาณผลตรวจรังสีสูงให้พนักงานใน วันพบแพทย์

เลขที่ 15064 จังหวัด น่าน (Q-KEH-011)

UNIT 6: FERNAN E-FILE (E-HEALTH BOOK)

1. ให้นักเรียนหาวิธีพิมพ์เอกสารตรงจากสภาพของพนักงานบริษัทที่มีการตรวจลงนามเอกสาร E-MAIL, E-BOOK ซึ่งประกอบไปด้วย 2 file ภายในได้ download ที่บริษัทข้าง คือ
- 1.1 File employee เฉพาะ ICT บริษัท GC upload
- 1.2 File resume ของตำแหน่งกร สำหรับ E-HEALTH BOOK ให้จัดทำในภาพ ขบโดยไม่มีตรงแต่พื้นที่
- 1.3 รูปแบบ file ที่จะนำข้อมูลภาพไว้ในระบบคอมพิวเตอร์สภาพของบริษัท

สรุปถึงที่ทองเจดีย์

เอกสารราชการชุดที่	ตัวจริง – พันทกาม	ตัวจริง
รายงานผลการปฏิบัติงานและสรุปผลการตรวจราชการ	สำเนา – สถานพินาศ เนมรายชื่ และ File - SHE พันธ์ - ตรวจสุขภาพประจำปี ปี พ.ศ. ๒๕๖๖	
E-File รายงานผลการตรวจราชการ และ พหุคูณเอกสาร มีดราหะ เอกเทศ จะระบบ	File - SHE พันธ์	
ใบรับรองแพทย์ที่ทำงานมีชื่อและชื่อ (สูงและใบรับรอง Fitness Certificate และสรุปผลการตรวจ)	ตัวจริง – พันทกาม สำเนา – สถานพินาศ	
E-Health Book	File ลง Q-EH-OH	
E-File รายงานผลการตรวจราชการ เอกเทศจะระบบ รายงานงาน บุคคล	File - Q-EH-OH	
File ผลการตรวจ กษณ.	File - Q-EH-OH	
Work ๓ ชื่อและชื่อ		ภายใน 1 เดือนแล้วรับทราบเพื่อวันสุดท้ายของการพบแพทย์ ใน File สุดท้าย: เช่น วันสุดท้ายพบแพทย์ 30 มีนาคม ค.ศ. ๒๐๒๖ 1-30 เมษายน walk ๓ ได้ รับ คัดค้านรายงาน ชื่อ วันที่ 30



รายละเอียดการวิจัย : งานตรวจสุขภาพประจำปี

<p>แบบเรียน เทปบันทึกเสียงแบบตัวอักษรที่ส่งหามา ไม่เป็นไปตามระบบ แผนที่ให้ รพ. จัดส่งตัว (อนุรักษ) ไปอยู่โรงพยาบาล แผลและชิ้นที่</p>	<p>นางงามแดงนางสาว ไกรสรพุดผกาพรกอบอรพรหมแพทก 1</p> <p>ภักดิษฐ์ และ รพ สดงจิตต์ทำ book</p> <p>โรงพยาบาล เจ้าได้รับพบแพทย์ จึงไป ผลการตรวจจะไม่ครบ สดงจิตต์ทำ book สดงจิตต์ทำ book สดงจิตต์ทำ book แล้ว ให้ รพ จัดทำประวัติรายบุคคลแยกออกมา</p>	<p>นางไท Q-E-F-QH ดนญ์ชัยที่บริษัทเก่าแพนแด</p> <p>ข้อมูลผลตรวจฉบับเวียนงาน</p> <p>ตรวจสอบประวัติเบื้องต้น</p> <p>ตรวจประวัติ</p> <p>ผลการตรวจตัว</p> <p>อื่นๆ</p>
<p>เอกสารวัดที่โบราณไป book</p>	<p>รูปเล่ม 160 ที่จะนำข้อมูลสุขภาพเข้าไปในระบบคอมพิวเตอร์</p> <p>สุขภาพทางกรังชีพ</p>	

ประเด็นที่ผู้เขียนได้ศึกษาครั้งนี้ ผู้ให้บริการต้องปฏิบัติตาม :

7.2 การวิเคราะห์การถดถอย

รายงานผลสุเคราะห์การควบคุมแบบมีที่ 5 ให้คิดเป็น 4 จุด ภายใน 45 วันทำการ นำผลการวิเคราะห์ผลมาของกรณีจริงที่ PTA GC เพื่อส่งให้แต่ละพื้นที่ให้บริการ ดังนี้

- ชุดที่ 1 : ซังน้ำ - GC 2 Q-SH-O1 รวมเล่ม 1-1
 ชุดที่ 2 : ซังน้ำ - GC 3 Q-SH-O2 รวมเล่ม 1-4
 ชุดที่ 3 : ซังน้ำ - GC 2 Q-SH-O1 รวมเล่ม 1-1
 ชุดที่ 4 : ซังน้ำ Q-SH-PO แยกกัน 3 เล่มดังนี้
 - GC 12 (GC 12: HDPE Plant 1)
 - GC 2 (GC 2: HDPE Plant 2)
 - GC 17 group (Plant (GC'S)
 ชุดที่ 5 : ซังน้ำ Q-SH-EO แยกเป็น 4 เล่มดังนี้
 - GC 16 group (GC Glycol)
 - GC 9 (Lab context)
 - GC 16 (Q-SH-EO)
 ชุดที่ 6 : ซังน้ำ Q-SH-O3 แยกเป็น 4 เล่มดังนี้
 - GC 11 PTTPE (Ethane Cracker)



- GC II PTPPE (LDPE)
- GC II PTPPE (LDPE)
- GC11 (Q-SH-O3)

ชุดที่ 7 : ส่งให้ Q-SH-PH แวนเลนคัง

- BPA
- Phcnol

ชุดที่ 8

- GC9P
- GCCO
- GCCC

รวม วัสดุทางการแพทย์ชุดที่ 2. ฐานโยนการตั้ง

รายงานผลการตรวจการตามแบบที่ 1 ถึง แบบที่ 5 ให้จัดทำเป็น 6 ชุด ภายใน 45 วันทำการนับจากวันสุดท้ายของการตรวจฯ ที่ GC เพื่อส่งให้แต่ละพื้นที่ให้บริการ ดังนี้

ชุดที่ 8 : ส่งให้ REF- ARO

- GC6 (REI)
- GC7
- GC 8 (Tank farm)
- GC 4 (ARO 1)
- GC 5 (ARO 2)

ชุดที่ 9 : สาย TEM & OTHER s

ชุดที่ 10 : GC 1 / GC 13 (RO-Innovation)

รพ. ที่ให้บริการกลุ่มที่ ตรวจในพื้นที่ ENCO ดำเนินการดังนี้
รายงานผลการตรวจการตามแบบที่ 1 ถึง แบบที่ 5 ให้จัดทำเป็น 4 ชุด ภายใน 45 วันทำการ นับจากวันสุดท้ายของการตรวจฯ ที่ GC เพื่อส่งให้แต่ละพื้นที่ให้บริการ ดังนี้

- GC
- GCC
- อื่นๆ

8. การรับประเมินผลงาน

ผู้ให้บริการ ต้องประเมินผลงานเป็นระยะเวลา 1 เดือนหลังจากสิ้นสุดผลงาน โดยจะต้องร่วมกัน
มอบใบรับรองแพทย์ให้ผู้ให้บริการออกไปให้ GC สามารถนำแสดงกล่าวได้ว่าจ้างถึงเขตหน่วยบริการอื่นหรือ
หน่วยงานราชการได้ซึ่งแสดงถึงการยอมรับความมีมาตรฐาน และกลามนำเข้าจัดซื้อในการให้บริการตรวจสุขภาพ

9. ข้อกำหนดอื่นๆ

- 9.1 ให้จัดรูปแบบรายงานผลฯ ให้เป็น Index แบบรายการตรวจฯ ให้ชัดเจนพร้อมระบุเลขหน้าและสารบัญ
- 9.2 รายงานผลการตรวจฯ ต่างๆ ให้ใช้รหัสพนักงาน (ตามการระบุถึงรหัสพนักงานและ Hospital number)
- 9.3 ให้จัดทำแบบ Index เพื่อระบุตำแหน่งสิ่งที่ยกย่องปฏิบัติและข้อบกพร่องการเข้ารับบริการตรวจสุขภาพฯ
แก่พนักงานทราบก่อนถึงปีตรวจฯ 4 อย่างน้อย 2 สัปดาห์
- 9.4 กรณีที่มีความจำเป็นต้องส่งสิ่งตรวจฯ เพื่อทำการ recall ผู้ให้บริการจะต้องจัดพิมพ์หาหาและพร้อม
เจ้าหน้าที่มาติดต่อรับสิ่งส่งตรวจดังกล่าว ณ สถานที่ๆ GC กำหนด
- 9.5 ในกรณีที่ผู้ให้บริการ ไม่สามารถส่งมอบงานที่มีคุณภาพตามเงื่อนไขในข้อที่ 6 และ 7 ได้ GC
Group สงวนสิทธิ์ที่จะปรับในอัตรา 0.1 % / วัน หลังจากกำหนดส่งผลวิเคราะห์การตรวจสุขภาพ

พนักงานเข้า และมูลค่าการปรับสูงสุดไม่เกิน 10% ของมูลค่างาน


- 9.6 การวางใบ และการนำส่งผลการตรวจ ให้ดำเนินการวางใบพร้อมผลการตรวจสุขภาพหรือถ้าเนผล
การตรวจสุขภาพทุกหุ้ร่ง มาพร้อมกับการวางใบ และ จัดส่งเดือนละ 1 ครั้ง
- 9.7 ขั้นตอนการ Scan ผลตรวจสุขภาพโรครักที่ ขึ้น ตามเอกสารแนบ

- 1.1 เกณฑ์การตรวจโรค ไข้ แก่ ผลเกิด EKG การได้กินสมรรถภาพปกติ หายมอเกิน อัตราตรวจ
แบบ มีแกวม มะเร็งปากมดลูก
- 1.2 ในกรณีที่มีการตรวจซ้ำให้ตั้งสัปดาห์ตามรายการตรวจและเพิ่ม (รายละเอียดตามเอกสารแนบ)

วิธี SCAN เอกสาร

1. เปิดคอมพิวเตอร์ Scan ผลตรวจสุขภาพประจำปี

- 1.1 กดปุ่ม Scan ผลตรวจสุขภาพประจำปี
- 1.2 ในกรณีที่มีการตรวจซ้ำให้ตั้งสัปดาห์ตามรายการตรวจและเพิ่ม (รายละเอียดตามเอกสารแนบ)



- 9.8 เมื่อในการถ่ายเงิน 70 % หลังดำเนินการ 30 % หลังส่งมอบรายงานและ E-File รายละเอียดชุดใน
TOR

- 9.9 กรณีที่โรงพยาบาลไม่สามารถดำเนินการได้ตาม TOR หรือมีเหตุเรื่องของการขาดการบริการและอา
และเมื่อผล ทาง GC มีสิทธิ์ยกเลิกก่อนครบกำหนดสัญญาได้

10. โรงพยาบาลผู้สัญญาปฏิบัติตามกฎหมาย PDPA

11. รพ. ที่ให้บริการอยู่ในระหว่างไม่เกิน 25 กิโลเมตร เพื่อสะดวกในการให้บริการและเห็น



5. 2000

1. ពេញវិសាលភាពប្រជាជន រដ្ឋបាលក្រុងស្រីសោភ័ណ

4. X-cell file မရှိဘဲ အချက်အလက်များ




10. ทนายความ
 11. ทนายความ
 12. ทนายความ

สรุป




flow tar. vsd



Time line กระบวนการจัดหา ในการเตรียมข้อมูลสัญญาณงานตรวจสอบสุขภาพประจำปี 2566-2569

งานบริการตรวจสอบสุขภาพพื้นที่ระยอง GC+บริษัทลูก GGC / GCP / GCEC

งานบริการตรวจสอบสุขภาพพื้นที่ระยอง
GC+บริษัทลูก GGC / GCP / GCEC



TOR and clarified scope

1. Hospital distance shall not over 25 Km from GC company.
2. Duration is 8 days per 1 plant Collect biological samples for 4 days Physical examination by a doctor for 4 days total duration of all 19 area about 3-4 months



➤ 33ข

**เอกสารอ้างอิงที่โครงการใช้ในการตรวจสอบแนวท่อ
(Piping Inspection Code)**



1	Repair, Alterations, and Re-lining of Piping Systems	51
1.1	Repairs and Alterations	51
1.2	Welding and Hot Tapping	55
1.3	Re-lining	56
2	Inspection of Buried Piping	57
2.1	General	57
2.2	Types and Methods of Inspection	57
2.3	Frequency and Extent of Inspection	59
2.4	Repair to Buried Piping Systems	60
2.5	Records	61
Appendix A	(Informative) Inspector Certification	62
Appendix B	(Informative) Requests for Inspections	63
Appendix C	(Informative) Examples of Repairs	64
Table 1	Some Typical Piping Damage Types and Mechanisms	65
2	Recommended Maximum Inspection Intervals	65
3	Recommended Interval of Observation Following Visual Inspection	65
4	One Example of the Calculation of RMPV Highlighting the Use of the Canadian Failure Diagram	67
5	Frequency of Inspection for Buried Piping Without Effective Cathodic Protection	69
Figure 1	Typical Injection Point Piping Circuit	66
G.1	Unplanned Repairs	66
G.2	Planned Repairs	66

Piping Inspection Code: In-service Inspection, Rating, Repair, and Alteration of Piping Systems

1 Scope

1.1 General Application

1.1.1 Coverage

API 576 covers inspection, rating, repair, and alteration procedures for existing and designed reinforced plastic (FRP) piping systems and low-pressure metal piping systems that have been placed in service.

1.1.2 Intent

The intent of this code is to specify the minimum inspection and condition-rating program that is needed to determine the integrity of piping. That program should provide reasonably accurate and timely assessments to determine if any damage to the condition of piping could possibly compromise continued safe operation. It is the intent of this code that inspection and condition-rating programs be developed that require corrective actions to ensure the continued safe operation of piping.

API 576 was developed for the petroleum refining and chemical process industries but may be used where needed for other piping systems. It is intended to be used by personnel that maintain or manage piping in an industrial process system, to repair, upgrade, and eventually replace piping equipment, materials, and components as well as involved in design.

1.1.3 Limitations

API 576 shall not be used as a substitute for the original construction requirements governing piping systems unless it is shown otherwise, nor shall it be used in combination with any conflicting regulatory requirements. If the requirements of this code are more stringent than the regulatory requirements, then the requirements of this code shall prevail.

1.2 Specific Applications

The term new installation was a broad definition but in this code refers to the first installation of piping systems constructed by the owner or contractor and FRP (reinforced plastic piping). This includes generally all piping systems installed after 1970 and low-pressure piping systems are excluded. This is API 576's jurisdiction over piping systems installed after 1970.

1.2.1 Included Field Sections

Except as provided in 1.2.2, API 576 applies to piping systems for process fluids, hydrocarbons, and other materials at their full service conditions, including the following:

- new installations and existing installations;
- new installations and existing installations;
- existing lines;
- hydrocarbon, chemical, and other fluids;
- new water and industrial waste systems above ambient level, as defined by jurisdictional regulations.

2	API 576	
1	Inspection, alteration, and repair of piping systems, as defined by jurisdictional regulations	
2	Inspection of piping systems as follows: 1.1.1.1 General Application	
3	High-pressure gas systems (over 100 psig) and 1.1.1.2 GSE, GSE, and GSE	
1.2.1	Optional Piping Systems and Field Sections	
	The field sections and classes of piping systems listed below are optional and subject to the requirements of API 576	
2.1	Field sections and classes of piping systems listed below are optional and subject to the requirements of API 576	
	1) Insulations and coatings below design level, as defined by jurisdictional regulations	
	2) Water carrying low-pressure systems (steam, steam condensate, boiler feed water, and GSE) as defined in ASME B31.3	
	3) Other classes of piping systems listed below are optional and subject to the requirements of API 576	
1.2.2	Excluded Piping Systems and Field Sections (R&I)	
	The inspection code recognizes that certain piping systems are excluded from the scope of the code. The following are excluded from the scope of the code:	
2	Normative References	
	The following references are normative for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.	
API Publication 580	Pressure Vessel Inspection Code: Maintenance, Inspection, Rating, Repair, and Alteration	
API Recommended Practice 571	Damage Mechanisms Affecting Piping Equipment in the Refining Industry	
API Recommended Practice 574	Inspection Procedures for Piping System Components	
API Recommended Practice 576	Inspection of Process-Related Devices	
API Recommended Practice 577	Welding Inspection and Acceptance	
API Recommended Practice 578	Material Verification Program for New and Existing Piping Systems	
API Standard 579-1/ASME FFS-1	Fitness-for-Service	
API Recommended Practice 580	Refractory Inspection	
API Recommended Practice 581	Rock-based Inspection Technology	
ASME Standard B31.3	Process Piping and Field Sections	
API Recommended Practice 581	Rock-based Inspection Technology	

2	API 576	
1	Inspection, alteration, and repair of piping systems, as defined by jurisdictional regulations	
2	Inspection of piping systems as follows: 1.1.1.1 General Application	
3	High-pressure gas systems (over 100 psig) and 1.1.1.2 GSE, GSE, and GSE	
1.2.1	Optional Piping Systems and Field Sections	
	The field sections and classes of piping systems listed below are optional and subject to the requirements of API 576	
2.1	Field sections and classes of piping systems listed below are optional and subject to the requirements of API 576	
	1) Insulations and coatings below design level, as defined by jurisdictional regulations	
	2) Water carrying low-pressure systems (steam, steam condensate, boiler feed water, and GSE) as defined in ASME B31.3	
	3) Other classes of piping systems listed below are optional and subject to the requirements of API 576	
1.2.2	Excluded Piping Systems and Field Sections (R&I)	
	The inspection code recognizes that certain piping systems are excluded from the scope of the code. The following are excluded from the scope of the code:	
2	Normative References	
	The following references are normative for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.	
API Publication 580	Pressure Vessel Inspection Code: Maintenance, Inspection, Rating, Repair, and Alteration	
API Recommended Practice 571	Damage Mechanisms Affecting Piping Equipment in the Refining Industry	
API Recommended Practice 574	Inspection Procedures for Piping System Components	
API Recommended Practice 576	Inspection of Process-Related Devices	
API Recommended Practice 577	Welding Inspection and Acceptance	
API Recommended Practice 578	Material Verification Program for New and Existing Piping Systems	
API Standard 579-1/ASME FFS-1	Fitness-for-Service	
API Recommended Practice 580	Refractory Inspection	
API Recommended Practice 581	Rock-based Inspection Technology	
ASME Standard B31.3	Process Piping and Field Sections	
API Recommended Practice 581	Rock-based Inspection Technology	

3.1.53

Inspection

The internal, external, or non-destructive examination for any condition of the piping condition conducted by the authorized inspector or other competent person.

NOTE: NDE may be conducted by personnel at the discretion of the authorized piping inspector and become part of the inspection process. Inspectors must follow proper NDE techniques and report on the results.

3.1.57

Inspection area

Section of the facility under API 570.

3.1.58

Inspection plan

A documented plan for defining the scope, timing, and timing of the inspection activities for piping systems, which may include a recommended repair and/or modification.

3.1.59

Inspector

An authorized piping inspector.

3.1.60

Inspection operating schedule

Inspection operating schedule: Established time for repairs, upgrades that can affect the integrity of the piping system if the process operates deviates from the established limits for a predetermined amount of time.

3.1.61

Internal inspection

An inspection performed on the inside of a piping system using direct or indirect NDE techniques.

3.1.62

Integrity

A piping system's performance characteristics that may affect its ability to perform its function.

3.1.63

Level indicator

A visual device that provides a means of determining the level.

3.1.64

Licensed technician

Personnel, if a technician who is licensed to perform work on the piping system.

3.1.65

Inspection report

A written report used to document the results of the inspection and provide a record of the inspection results to the authorized piping inspector or other competent person.

3.1.66

Inspection results

Inspection results: The results of the inspection and the condition of the piping system.

3.1.67

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.68

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.69

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.70

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.71

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.72

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.73

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.74

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.75

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.76

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.77

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.78

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.54

Inspection

The internal, external, or non-destructive examination for any condition of the piping condition conducted by the authorized inspector or other competent person.

3.1.57

Inspection area

Section of the facility under API 570.

3.1.58

Inspection plan

A documented plan for defining the scope, timing, and timing of the inspection activities for piping systems, which may include a recommended repair and/or modification.

3.1.59

Inspector

An authorized piping inspector.

3.1.60

Inspection operating schedule

Inspection operating schedule: Established time for repairs, upgrades that can affect the integrity of the piping system if the process operates deviates from the established limits for a predetermined amount of time.

3.1.61

Internal inspection

An inspection performed on the inside of a piping system using direct or indirect NDE techniques.

3.1.62

Integrity

A piping system's performance characteristics that may affect its ability to perform its function.

3.1.63

Level indicator

A visual device that provides a means of determining the level.

3.1.64

Licensed technician

Personnel, if a technician who is licensed to perform work on the piping system.

3.1.65

Inspection report

A written report used to document the results of the inspection and provide a record of the inspection results to the authorized piping inspector or other competent person.

3.1.66

Inspection results

Inspection results: The results of the inspection and the condition of the piping system.

3.1.67

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.68

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.69

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.70

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.71

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.72

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.73

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.74

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.75

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.76

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.77

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

3.1.78

Inspection results

A documented record of the inspection results and the condition of the piping system, including the results of the inspection and the condition of the piping system.

5.2.4 Frequency of RBI Assessments

When RBI is used as the basis for equipment inspection methods, the assessment must be updated after each equipment inspection as defined in API 574. The RBI assessment should also be updated upon any change in equipment design, size, or use or after any event occurs that could significantly affect damage rates or damage mechanisms. The minimum intervals between RBI assessments are defined in API 574, Table 2.

5.3 Preparation for Inspection

5.3.1 General

Safety procedures shall be followed when preparing piping systems for inspection and maintenance activities to eliminate exposure to hazardous fluids, energy sources, and physical hazards. Regulations (e.g., those promulgated by the U.S. Occupational Safety and Health Administration (OSHA)) govern many aspects of piping system inspection and shall be followed where applicable. In addition, the owner's safety procedures shall be reviewed and followed. See API 574 for more information on the safety aspects of piping inspection.

Procedures for preparing piping systems, including block (blow) and testing systems should be an integral part of safety procedures for targeted inspections. Appropriately placed procedures must be taken before any piping system is opened and before any type of manual inspection is performed. In general, the section of piping to be opened should be isolated from all sources of hazardous fluids, gases, or vapors and purged to remove all of such fluids or hazardous gases and vapors.

5.3.2 Inspection Equipment Preparation

All tools, equipment, and personal protective equipment used during piping work (e.g., pressure, RBI, process testing, repair, and alterations) should be checked for damage and/or operability prior to use. RBI equipment and the most appropriate equipment are subject to the owner's safety requirements for electrical equipment. Once equipment has been checked for the piping system status, even at existing installations, all portable equipment should be checked for safety and safety before being used.

During preparation of piping systems for inspection, personal protective equipment shall be worn when required during any preparation, the completion, or the repair operation.

5.3.3 Documentation

Before starting any piping system inspection, the responsible parties, pressure testing, repair, or alteration operations should obtain permission from operating personnel responsible for the piping system in the plant.

When individuals are doing large piping repairs, all parties working on the equipment should be informed that people are working inside the piping. Individuals working inside the piping should be informed that any work is going to be done on the exterior of the piping.

5.3.4 Piping Entry

Prior to entering large piping, the piping system shall be isolated from all sources of energy, gases, vapors, liquids, and other fluids. The piping system should be cleaned, vented, purged, gas tested, and locked out before any work is done.

Procedures to ensure conditions are verified and procedures to ensure safe entry into piping systems are part of the preparation for the piping system. These procedures should be documented in all those required. Documentation of these procedures is required prior to any piping system entry.

Before entering piping systems, individuals shall obtain permission from the responsible operating personnel. While required for certain system entry, personal protective equipment shall be worn that will protect individuals from specific hazards that may exist in the piping system.

5.3.5 Retain a Review

Before performing any of the required inspections, inspectors shall familiarize themselves with prior history of the piping system for which they are responsible. In particular, they should review the piping system prior inspection results, prior repair, current inspection plan, and/or other safety system inspection. Additionally, it is essential to ascertain recent operating history that may affect the inspection plan. The types of damage and failure modes experienced by piping systems are provided in API 574 (Table 1) and API 574-ASME FF-6.

5.4 Inspection for Types and Locations of Damage Modes of Deterioration and Failure

5.4.1 Equipment Damage Types

5.4.1.1 Piping systems are susceptible to various types of damage by several damage mechanisms. Typical damage types and mechanisms are listed in Table 1.

Table 1—Some Typical Piping Damage Types and Mechanisms

Damage Type	Damage Mechanism
Overpressure/low cycle fatigue	Stress corrosion cracking Fatigue Corrosion-fatigue interaction Corrosion-fatigue interaction Fatigue crack growth Corrosion-fatigue interaction
Underpressure/low cycle fatigue	Stress corrosion cracking Fatigue Corrosion-fatigue interaction Fatigue crack growth Corrosion-fatigue interaction
Excessive loading	Stress corrosion cracking Fatigue Corrosion-fatigue interaction Fatigue crack growth Corrosion-fatigue interaction
Excessive vibration	Stress corrosion cracking Fatigue Corrosion-fatigue interaction Fatigue crack growth Corrosion-fatigue interaction
Excessive temperature	Stress corrosion cracking Fatigue Corrosion-fatigue interaction Fatigue crack growth Corrosion-fatigue interaction
Excessive pressure	Stress corrosion cracking Fatigue Corrosion-fatigue interaction Fatigue crack growth Corrosion-fatigue interaction
Excessive corrosion	Stress corrosion cracking Fatigue Corrosion-fatigue interaction Fatigue crack growth Corrosion-fatigue interaction
Excessive erosion	Stress corrosion cracking Fatigue Corrosion-fatigue interaction Fatigue crack growth Corrosion-fatigue interaction
Excessive abrasion	Stress corrosion cracking Fatigue Corrosion-fatigue interaction Fatigue crack growth Corrosion-fatigue interaction
Excessive impact	Stress corrosion cracking Fatigue Corrosion-fatigue interaction Fatigue crack growth Corrosion-fatigue interaction
Excessive bending	Stress corrosion cracking Fatigue Corrosion-fatigue interaction Fatigue crack growth Corrosion-fatigue interaction
Excessive twisting	Stress corrosion cracking Fatigue Corrosion-fatigue interaction Fatigue crack growth Corrosion-fatigue interaction
Excessive vibration	Stress corrosion cracking Fatigue Corrosion-fatigue interaction Fatigue crack growth Corrosion-fatigue interaction
Excessive temperature	Stress corrosion cracking Fatigue Corrosion-fatigue interaction Fatigue crack growth Corrosion-fatigue interaction
Excessive pressure	Stress corrosion cracking Fatigue Corrosion-fatigue interaction Fatigue crack growth Corrosion-fatigue interaction
Excessive corrosion	Stress corrosion cracking Fatigue Corrosion-fatigue interaction Fatigue crack growth Corrosion-fatigue interaction
Excessive erosion	Stress corrosion cracking Fatigue Corrosion-fatigue interaction Fatigue crack growth Corrosion-fatigue interaction
Excessive abrasion	Stress corrosion cracking Fatigue Corrosion-fatigue interaction Fatigue crack growth Corrosion-fatigue interaction
Excessive impact	Stress corrosion cracking Fatigue Corrosion-fatigue interaction Fatigue crack growth Corrosion-fatigue interaction
Excessive bending	Stress corrosion cracking Fatigue Corrosion-fatigue interaction Fatigue crack growth Corrosion-fatigue interaction
Excessive twisting	Stress corrosion cracking Fatigue Corrosion-fatigue interaction Fatigue crack growth Corrosion-fatigue interaction

5.4.1.2 The probability of failure of damage in equipment is determined upon an analysis of construction details, corrosion, and operating conditions. The inspection should be done with these conditions and with the damage and deterioration of piping system and damage mechanisms identified with an equipment being inspected.

5.4.1.3 Detailed information concerning common damage mechanisms (internal erosion, stress corrosion, and fatigue) is provided in API 574 (Table 1) and other sources of information on damage mechanisms are provided in the bibliography. Additional recommended inspection procedures for specific types of damage mechanisms are provided in API 574 (Table 1).

5.4.2 Areas of Deterioration for Piping Systems

Each component shall provide specific attention to the areas of inspection of piping systems and the responsibility for the following specific types and areas of deterioration:

- Welding joints and heat-treated areas
- Flanges
- CDI
- CDI or other devices
- Isolation systems and related equipment
- Process and maintenance areas
- Environmental conditions
- Corrosion beneath flanges and gaskets
- Excess loading
- Excess vibration
- Excess pressure
- Excess corrosion
- Excess erosion
- Excess abrasion
- Excess impact
- Excess bending
- Excess twisting

Refer to API 574 and API 574-ASME for more detailed information concerning these areas and areas of deterioration.

5.5 General Types of Inspection and Surveillance

Different types of inspection and surveillance are appropriate depending on the circumstances and the piping system (see Table 1). These include the following:

- Visual inspection
- Corrosion monitoring
- Thickness measurement inspection
- External visual inspection
- CDI inspection
- Strength testing inspection

5.5.1 Visual Inspection

5.5.1.1 General Visual Inspection

Visual inspection is the most common type of inspection. It is performed by visual observation and is the most common type of inspection. It is performed by visual observation and is the most common type of inspection.

5.5.1.2 Internal Visual Inspection

Internal visual inspection is performed by visual observation of the interior of the piping system. It is performed by visual observation and is the most common type of inspection. It is performed by visual observation and is the most common type of inspection.

An additional opportunity for internal inspection is provided when piping changes are determined. Internal visual inspection of internal systems with or without the use of NDE (depending on section of piping and piping system) is required also provide access to internal systems when there is need for such inspection.

5.5.2 Corrosion Inspection

The corrosion inspection may be required by the inspection plan. All corrosion inspections should be completed by the inspection of the piping system. All corrosion inspections should be completed by the inspection of the piping system. All corrosion inspections should be completed by the inspection of the piping system.

The inspection may include internal NDE techniques to check for various types of damage. Techniques used in corrosion inspections are chosen for their ability to identify various damage mechanisms from the exterior and their capability to perform at the corrosion conditions of the piping system (e.g., media, temperature). The external corrosion measurement inspection described in 5.5.3.1 may be a part of an inspection program.

API 574 provides more information on piping system inspection and should be used when performing on-stream piping inspection.

5.5.3 Thickness Measurement Inspection

Thickness measurements are obtained to verify the thickness of piping components. This data is used to determine corrosion rates and remaining life of the piping system. Thickness measurements should be obtained by the inspection of the piping system. Thickness measurements should be obtained by the inspection of the piping system.

Thickness measurements are taken with the piping in operation. On-stream thickness monitoring is a good tool for monitoring corrosion and assessing potential damage due to process or operational changes.

The inspection should comply with a corrosion specification when the specification is not changed significantly from the previous inspection. The inspection should be done at the same frequency as the previous inspection. The inspection should be done at the same frequency as the previous inspection.

5.5.4 External Visual Inspection

An external visual inspection is performed to determine the condition of the exterior of the piping, insulation, supports, and coating systems, and associated hardware and is done for signs of malfunction, vibration, and leakage. When corrosion product buildup is noted at pipe support contact areas, it may be necessary to inspect the pipe at

Every Girl Should Know | www.pearson.com

Every Girl Should Know | www.pearson.com

- General declaration of CIL and estimation:** *perforis* is necessary to enhance the accuracy and repeatability of the data.

3.7 Generation Identifying Methods

[illegible]

- Figure 1. The effect of the number of nodes on the performance of the proposed algorithm.

© 2004 Blackwell Publishing Ltd, *Journal of Internal Medicine* 255: 109–116

- bioRxiv preprint doi: <https://doi.org/10.1101/000000>; this version posted January 1, 2016. The copyright holder for this preprint (which was not certified by peer review) is the author/funder, who has granted bioRxiv a license to display the preprint in perpetuity. It is made available under aCC-BY-NC-ND 4.0 International license.

bioRxiv preprint doi: <https://doi.org/10.1101/000000>; this version posted January 1, 2016. The copyright holder for this preprint (which was not certified by peer review) is the author/funder, who has granted bioRxiv a license to display the preprint in perpetuity. It is made available under aCC-BY-NC-ND 4.0 International license.

While confusion in a pricing system is inevitable as the estimating business is approaching the minimum required standards, additional business uncertainty may be required. Budgetary or otherwise, estimating and the profession for the future will come.

1. The information in this document is intended to provide a general overview of the information and is not intended to be used as a substitute for professional advice. The information is provided for informational purposes only and is not intended to be used as a substitute for professional advice. The information is provided for informational purposes only and is not intended to be used as a substitute for professional advice.

[illegible]

[1] The authors are grateful to the referees for their valuable comments.

- [1] The authors are grateful to the referees for their valuable comments.

1) ഭക്ഷണത്തിന് പ്രാധാന്യം നൽകിയിട്ടില്ലാത്ത മലയാളം ഭാഷയ്ക്ക് ഉത്തമം പ്രദാനം 10 മുദ്രകൾ സമ്മാനം പ്രദാനം കാണുക

4. ಅಭ್ಯಾಸಗಳು: 10 ಕ್ಕೆರಳಿದವುಗಳಲ್ಲಿ 5 ರಷ್ಟು ಅಗತ್ಯವಿರುತ್ತವೆ.

[illegible]

5.7.3 General Preparation for JND

Asbestos surface preparation is important for proper waste encapsulation and for the satisfactory application of most encapsulation methods, such as those mentioned above. The type of asbestos preparation required depends on the material characteristics and RGE techniques. Key surface preparation tasks as rule brushing, washing, chipping, grinding, or a combination of these procedures may be required.

- Additional team ERM specialists may be needed in order to sustain and operate the proper surface production for each individual HME component.

$$\Gamma(y) = 4\pi y^{-3} (1 + 4/3 y^2 + y^4/3) \exp(-y^2/3), \quad y \geq 0$$

1. The first step is to identify the problem or question that needs to be answered. This involves understanding the context and the specific requirements of the task.

- Application examples for the use of industry qualified IT systems experts include building and using plans; data from the external sources and changing data for Finance-Performance engineering.

Prabhakar, K. S. and K. S. Prasad. 2013. *Journal of the National Science Foundation*. 43(1): 1-10.

It prohibits alterations and repairs, except those that include requirements of the U.S. Coast Guard for certain work plans and requirements of local jurisdictions, after vessel changes or when specified by the inspector. Painting and repair work on structural members shall be by recognized professionals with the requirements of ASME B31.3. All repair construction for pressure piping as provided in API 574, API 575/576/578/579 and ASME B3001. Sample fracture tests, which the vessel owner for lightness of piping systems, may be conducted at pressure designated by the owner/inspector.

Pressure tests are typically performed on an entire piping system. However, when practical, pressure tests of individual components can be performed in lieu of entire tests (e.g., a hydrostatic section of piping). An alternative should be considered when a pressure test of piping components is to be performed including use of section closures if it is suitable for the intended purpose.

[illegible]

Before applying a hydrotreatment unit, the supporting structure and foundation design should be reviewed by an engineer to ensure that they are suitable for the hydrotreatment unit.

NOTE: The permeability coefficient is varied according to 50 % of the SLMs for the reduced weight percentage and regularly by equal amount used in the polymer composite system.

3) distortion and creep of legs and base change and loading.

4) tank bottom piling.

5) critical loads and stresses.

6.3.6.5 Class 4

Devices that are assembly nonremovable and attached to a Class 4, to the most utility service, inspection of Class 4 piping is required and usually based on reliability needs and business impact as reported to safety or environmental impact. Examples of Class 4 service include, but are not necessarily limited to those involving the following:

3) distillation and steam condenser,

4) air

5) nitrogen.

6) water, including leaks for freshwater, stopped sea water.

7) lube oil, used oil.

8) H2S, D2S, Gasolene, Diesel.

9) glycol and steam.

6.4 Extent of Visual External and GUT Inspection

External visual inspection, including inspection for GUT, should be conducted at minimum intervals listed in Table 2 to include items such as those in API 674. Additionally, external visual inspection should be conducted by using a visual GUT inspection technique in accordance with API 674. This external visual inspection for external GUT is also to assess condition and shall be performed on all piping systems susceptible to GUT listed in API 674. This extent of the visual inspection should be documented to facilitate future inspection.

Following the external visual inspection of susceptible systems, additional examination is required for the inspection of GUT. The extent and type of the additional GUT inspection are listed in Table 3. Documented inspection of higher susceptibility items listed in GUT in lower susceptibility items from the same piping system should also be conducted as listed in Table 3. Documented inspection of higher susceptibility items listed in GUT in lower susceptibility items from the same piping system should also be conducted as listed in Table 3. Documented inspection of higher susceptibility items listed in GUT in lower susceptibility items from the same piping system should also be conducted as listed in Table 3. Documented inspection of higher susceptibility items listed in GUT in lower susceptibility items from the same piping system should also be conducted as listed in Table 3.

The extent of the GUT program described in Table 3 should be conducted at least levels (1) piping systems and systems with no GUT inspection requirements. It is recognized that external factors may limit the extent of GUT to include:

1) local climate conditions.

2) detection design and maintenance.

3) maintenance quality.

4) existing condition.

Facilities with GUT inspection requirements may increase or reduce the GUT inspection extent of Table 3. An exact compliance of the GUT inspection extent is not required. The evaluation may define inspection extent with operational history or other documentation.

Piping systems that are known to have a remaining life of over 10 years or that are adequately protected against external corrosion need not be inspected for GUT inspection requirements in Table 3. However, the condition of the existing systems or the piping system, such as an external leak, should be monitored periodically by operating or other personnel. If deterioration is noted, it should be reported to the inspector. The following are examples of these systems:

1) piping systems maintained exclusively to protect the substance of moisture.

2) isolated systems piping systems.

3) piping systems located in a condition in which the remaining life is judged to be over 10 years.

4) piping systems in which the temperature being maintained is sufficiently low or sufficiently high to preclude the formation of scale.

The external visual inspection is also being used to conduct the condition of end and ending systems, to check for external corrosion, and to check for other forms of deterioration.

6.5 Extent of Thickness Measurement Inspection

To satisfy inspection external requirements, and to meet the measurement inspection design thickness minimums required in a representative sampling of GUT in each class (see 6.4). This inspection is required to include data for all the various types of components and connections (horizontal and vertical) located in the piping. This sampling rate shall include Class 4 and Class 5 piping systems and Class 6 and Class 7 piping systems. The data shall be reported for each class, but more accurately the next inspection time will be required. Therefore, a detailed inspection of Class 4 and Class 5 piping systems may be necessary.

The extent of inspection for system items is covered in API 674.

6.6 Extent of Circulation, Auxiliary Piping, and Through-the-Line Inspection

6.6.1 GUT Inspection

GUT should be done in accordance with the requirements in the document.

GUT that is done in accordance with the requirements in the document. This inspection is required to include data for all the various types of components and connections (horizontal and vertical) located in the piping. This sampling rate shall include Class 4 and Class 5 piping systems and Class 6 and Class 7 piping systems. The data shall be reported for each class, but more accurately the next inspection time will be required. Therefore, a detailed inspection of Class 4 and Class 5 piping systems may be necessary.

Inspection of GUT should be done in a systematic way from the mainline piping. These data are to be reported for each class, but more accurately the next inspection time will be required. Therefore, a detailed inspection of Class 4 and Class 5 piping systems may be necessary.

6.6.2 Auxiliary Piping Inspection

Inspection of auxiliary piping associated with the mainline piping should be done in accordance with the requirements in the document. This inspection is required to include data for all the various types of components and connections (horizontal and vertical) located in the piping. This sampling rate shall include Class 4 and Class 5 piping systems and Class 6 and Class 7 piping systems. The data shall be reported for each class, but more accurately the next inspection time will be required. Therefore, a detailed inspection of Class 4 and Class 5 piping systems may be necessary.

1) identification

2) potential for overpressure or leakage

3) potential for external leakage or overpressure

4) potential for GUT

6.6.3 Through-the-Line Inspection

Inspection of through-the-line inspection is required in the requirements listed above for inspection and auxiliary piping. When inspecting GUT in through-the-line inspection, only those that can be inspected during scheduled inspection.

Through-the-line inspection is required in the requirements listed above for inspection and auxiliary piping. When inspecting GUT in through-the-line inspection, only those that can be inspected during scheduled inspection.

1) identification of piping

2) inspection and frequency of inspection

3) extent of inspection

4) current piping condition

5) whether or not the system can be maintained

6) condition

7) maintenance

6.7 Inspection and Maintenance of Pressure-Relieving Devices (PRDs)

6.7.1 General

PRDs should be tested and repaired by a repair organization experienced in pressure maintenance. PRDs should be repaired and maintained in accordance with API 674.

6.7.2 Quality Assurance Program for PRDs

Each equipment repair organization shall have a fully documented quality assurance system. As a minimum, the following GUT should be included in the quality assurance system:

1) GUT.

2) repair log.

Table 2—Recommended Minimum Inspection Intervals

Type of System	Inspection Intervals	Visual External
Class 1	Five years	Five years
Class 2	Five years	Five years
Class 3	Five years	Five years
Class 4	Five years	Five years
Class 5	Five years	Five years
Class 6	Five years	Five years
Class 7	Five years	Five years

NOTE: Inspection intervals apply to systems for which GUT data have been established in accordance with API 674. Inspection intervals for systems for which GUT data have not been established in accordance with API 674 should be established by a valid PRD analysis.

For more information on GUT analysis.

Table 3—Recommended Extent of GUT Inspection Following Visual Inspection

Flow Class	Approximate Amount of Through-the-Line Inspection with GUT Inspection Following Visual Inspection	Approximate Amount of GUT Inspection Following Visual Inspection
1	10%	10%
2	10%	10%
3	10%	10%
4	10%	10%
5	10%	10%
6	10%	10%
7	10%	10%

1) identification

2) identification of piping and components

3) inspection and frequency of inspection

4) extent of inspection

5) current piping condition

6) whether or not the system can be maintained

7) condition

8) maintenance

9) inspection and frequency of inspection

10) extent of inspection

11) current piping condition

12) whether or not the system can be maintained

13) condition

14) maintenance

11

[illegible]

Research systems for justice pricing should be maintained in accordance with 7.6 in preference to systems of the National and state of California or other regulatory agencies that do not maintain them.

B.3. Procedures for Interpretation Negotiations

Responses to previous request for information can be found on the AFI website at <http://www.afimatters.af.mil> or afimatters@af.mil.

Annex C
(informative)
Examples of Repairs

C.1 Repairs

Manual welding of the gas chamber or welded metal gas passages may be used.

When the temperature is below 50 °F (10 °C), low-hydrogen electrodes, AWS E6010 or E6011, shall be used when welding materials conforming to ASTM A-43, Grades A and B; A-106, Grades A and B; A-333, A334, API B, and other grades of material. These electrodes should also be used on low-carbon steels of which the temperature of the material is below 50 °F (10 °C). The preheating should be calculated for each welding of these materials.

When AWS E6010 or E6011 electrodes are used on mild steels of grade 5 (see Figure C.1 below), the layers shall be deposited by starting at the bottom of the assembly and working upwards. The electrode should not exceed 1/8 in. (3.2 mm). Distances between the 1/8 in. (3.2 mm) may be used on mild steels of grade 5 (see Figure C.1), but the electrode should not exceed 1/8 in. (3.2 mm).

The longitudinal welds (number 1, Figure C.1) on the reinforcing sleeve shall be deposited in such a way as to avoid that welding step (see note) to avoid that the weld is too thick at the top.

Note: If the longitudinal welds (number 1) have been welded through by checking methods and it is not allowed, repairs for welding a sleeve shall not be necessary.

Approved welding procedures for on-stream steel shall conform to API 2204.

C.2 Small Repair Patches

The diameter of the repair patch shall not exceed 1/8 in. (3.2 mm). When the length of the hole is more than 1/8 in. (3.2 mm), the repair patch shall be used. The diameter of the hole shall not exceed 1/8 in. (3.2 mm). The diameter of the hole shall not exceed 1/8 in. (3.2 mm).

Approved welding procedures for on-stream steel shall conform to API 2204.

Examples of small repair patches are shown below in Figure C.2.

FIGURE C.1—SHIELDING GAS TIG WELDING OF REPAIR PATCHES




Figure C.1—Shielding Gas TIG Welding of Repair Patches




Figure C.2—Small Repair Patches

THERE'S MORE WHERE THIS CAME FROM.

API provides additional resources and programs to the oil and natural gas industry, which are based on API Standards. For more information, contact:

API HONORARY LICENSING PROGRAM
Phone: 202-682-4701
Fax: 202-682-4070
Email: certification@api.org

API QUALITY REGISTRAR (APIQR)
• ISO 9001 Registration
• ISO/TS 25001 Registration
• ISO 14001 Registration
• API Spec Q1 Registration
Phone: 202-682-4701
Fax: 202-682-4070
Email: certification@api.org

API PERFORATOR DESIGN REGISTRATION PROGRAM
Phone: 202-682-4701
Fax: 202-682-4070
Email: perfdesign@api.org

API TRAINING PROVIDER CERTIFICATION PROGRAM (API TPCP)
Phone: 202-682-4701
Fax: 202-682-4070
Email: tpcp@api.org

API INDIVIDUAL CERTIFICATION PROGRAMS (ICP)
Phone: 202-682-4701
Fax: 202-682-4070
Email: icp@api.org

API ENGINE OIL LICENSING AND CERTIFICATION SYSTEM (EOLCS)
Phone: 202-682-4701
Fax: 202-682-4070
Email: eolcs@api.org

API PETROTEAM (TRAINING, EDUCATION AND MEETINGS)
Phone: 202-682-4701
Fax: 202-682-4070
Email: petroteam@api.org

API UNIVERSITY
Phone: 202-682-4701
Fax: 202-682-4070
Email: training@api.org

Check out the API Publications, Programs, and Services Catalog online at: www.api.org



API is a registered trademark of the American Petroleum Institute. All other trademarks are the property of their respective owners.



1200 L Street, NW
Washington, DC 20004-6070
USA
202-682-4000

Additional copies are available through the following:
Phone Order: 1-800-682-4701 (toll-free in the U.S. and Canada)
Fax Order: 202-682-4070 (toll-free in the U.S. and Canada)
Online Order: www.api.org

For more information, API Publications, Programs and Services
is available on the www.api.org

	Page
1. Repair, Alteration, and Reliability of Piping Systems	51
1.1 Repair and Alteration	51
1.2 Welding and Hot Tapping	51
1.3 Reliability	52
2. Inspection of Buried Piping	57
2.1 General	57
2.2 Types and Methods of Inspection	57
2.3 Frequency and Extent of Inspection	58
2.4 Reporting to Buried Piping Systems	59
2.5 Records	60
Appendix A (Information) Inspection Guidelines	62
Appendix B (Information) Requests for Information	63
Appendix C (Information) Examples of Reports	64
Tables	
Table 1. Some Typical Piping Design Types and Materials	65
Table 2. Recommended Maximum Inspection Intervals	66
Table 3. Recommended Extent of GUT Inspection Following Visual Inspection	67
Table 4. Two Examples of the Calculation of MAWP Maintaining the Use of the Corrosion Allowance	68
Table 5. Frequency of Inspection for Buried Piping Without Effective Cathodic Protection	69
Figure 1. Typical Injection Point Piping Detail	70
Figure 2. Typical Injection Point Piping Detail	71
Figure 3. Small Repair Patches	72

Piping Inspection Code: In-service Inspection, Repair, and Alteration of Piping Systems

1. Scope

1.1 General Application

1.1.1 Coverage

API 570 covers inspection, repair, and alteration procedures for metallic and fibreglass reinforced plastic (FRP) piping systems and their associated pressure retaining devices that have been placed in service.

1.1.2 Intent

The intent of this code is to specify the minimum inspection and maintenance program that is needed to determine the integrity of piping. That program should provide reasonably accurate and timely assessments to determine if any changes in the condition of piping could possibly compromise the integrity of the system. It is also the intent of this code that emergency intervention to any hazardous condition that requires corrective action to prevent the occurrence of a piping failure.

API 570 was developed for the petroleum refining and chemical process industries but may be used where required for any piping system that is required for use by organizations that maintain or have access to an organized inspection agency, a repair organization, and technically qualified piping engineers, inspectors, and welders, as defined in Section 3.

1.1.3 Limitations

API 570 shall not be used as a substitute for the original construction requirements governing a piping system before it is placed in service, nor shall it be used in conjunction with any prevailing regulatory requirements. If the requirements of this code are more stringent than the regulatory requirements, then the requirements of this code shall prevail.

1.2 Specific Applications

This code was developed for a broad application but in this code refers to the three major types of piping systems commonly used by the process industries: FRP (fibreglass-reinforced plastic) and FRP (fibreglass-reinforced plastic). The materials, generally, fibreglass-reinforced plastic, such as FRP and FRP (fibreglass-reinforced plastic) are covered under API 570 for inspection, evaluation, and repair. The materials are associated with FRP piping.

1.2.1 Included Piping Services

Except as provided in 1.2.2, API 570 applies to piping systems that produce fluids, hydrocarbons, and gases, and are subject to internal or external service, such as the following:

- a) low, intermediate, and high-pressure systems;
- b) low, intermediate, and high-temperature systems;
- c) wet and dry;
- d) hydrogen technology, wet and dry systems;
- e) low, intermediate, and high-pressure systems that are subject to internal or external service, such as the following:

	Page
2. Inspection of Buried Piping	57
2.1 General	57
2.2 Types and Methods of Inspection	57
2.3 Frequency and Extent of Inspection	58
2.4 Reporting to Buried Piping Systems	59
2.5 Records	60
Appendix A (Information) Inspection Guidelines	62
Appendix B (Information) Requests for Information	63
Appendix C (Information) Examples of Reports	64
Tables	
Table 1. Some Typical Piping Design Types and Materials	65
Table 2. Recommended Maximum Inspection Intervals	66
Table 3. Recommended Extent of GUT Inspection Following Visual Inspection	67
Table 4. Two Examples of the Calculation of MAWP Maintaining the Use of the Corrosion Allowance	68
Table 5. Frequency of Inspection for Buried Piping Without Effective Cathodic Protection	69
Figure 1. Typical Injection Point Piping Detail	70
Figure 2. Typical Injection Point Piping Detail	71
Figure 3. Small Repair Patches	72

	Page
2. Inspection of Buried Piping	57
2.1 General	57
2.2 Types and Methods of Inspection	57
2.3 Frequency and Extent of Inspection	58
2.4 Reporting to Buried Piping Systems	59
2.5 Records	60
Appendix A (Information) Inspection Guidelines	62
Appendix B (Information) Requests for Information	63
Appendix C (Information) Examples of Reports	64
Tables	
Table 1. Some Typical Piping Design Types and Materials	65
Table 2. Recommended Maximum Inspection Intervals	66
Table 3. Recommended Extent of GUT Inspection Following Visual Inspection	67
Table 4. Two Examples of the Calculation of MAWP Maintaining the Use of the Corrosion Allowance	68
Table 5. Frequency of Inspection for Buried Piping Without Effective Cathodic Protection	69
Figure 1. Typical Injection Point Piping Detail	70
Figure 2. Typical Injection Point Piping Detail	71
Figure 3. Small Repair Patches	72

For the baseline measurements the six randomly chosen animals in group 1 were kept in the same conditions as the other animals in the group. The body weight of the animals was higher than that of the animals in the other groups. However, when taken on average for comparison

During a pressure test, where the test pressure will exceed the set pressure of the pressure relief valve on a system, the direction meter valve of volume should be maintained or isolated for the duration of the test. As a

Flange inspection should be extended visually for corrosion and thread engagement. Fasteners should be fully engaged. Any fastener failing to do so is considered completely unsound if the lack of complete engagement is not more than one thread.

The markings on a representative sample of newly installed fasteners and gaskets should be examined to determine whether they meet the material specification. The markings are identified in the applicable ASME and ASTM standards. Questionable fasteners should be verified or replaced.

Additional questions on the condition of flanged joints can be found in API 570, Part 1, 10.1.

5.4.3 Inspection Organization Analysis

Each personnel organization should be audited periodically to determine if the assigned inspection agency is meeting the requirements of this inspection code. The audit team should consist of people experienced and competent in the application of this code. The audit team should typically be from another chemical plant site or from a third party organization experienced and competent in setting and/or performing periodic plant inspection programs or a combination of both party and other external plant.

The audit team will minimum of all determine that:

- a) the requirements and principles of this inspection code are being met
- b) all inspection responsibilities are being properly discharged
- c) documented inspection plans are in place for covered piping systems
- d) external personnel or suppliers are adequate for various piping systems
- e) all general types of inspection and test methods are being adequately applied
- f) inspection data analysis, evaluation and reporting are adequate
- g) all safety, health and environment comply with this code

The organization should receive a report of the audit team's findings. When nonconformances are found the responsible authorized inspection agency shall take the necessary corrective actions. Each organization should establish a system for tracking and completion of audit findings. The resolution of the audit findings should be made available to the audit team for review. This information should also be reviewed during subsequent audits.

6 Internal Frequency and Extent of Inspection

6.1 General

The existing equipment design, its piping system and the consequences of failure shall be inspected at the intervals specified in this section. Inspection frequencies shall be established on a basis of the size and type of the equipment and the piping system. Inspection frequencies shall be established in accordance with API 575, not found to have been established for an extension of the design shall not be established until the end of the design period. See 5.1.1 for more information and requirements on internal inspection frequencies. Inspection intervals and inspection extent shall be determined.

The appropriate inspection code provides the information necessary to determine that all of the essential sections of equipment and piping are able to operate until the next scheduled inspection. This rule is intended to ensure operational continuity and safety and the possibility of increased equipment failure or equipment failure during the next scheduled inspection should be established when an internal inspection is being planned.

This code is based upon paragraph 2.4.1 of the API 575 inspection code. The inspection code is based upon piping with specific intent to ensure a reasonably accurate assessment of the condition of the piping.

6.2 Inspection During Installation and Service Changes

6.2.1 Piping Installation

Piping shall be inspected at installation with intent of determining requirements at the time of installation. The purpose of installation inspection is to verify that the piping is clean and safe for operation and to ensure that inspection records for the piping system. The minimum installation inspection should include the following items:

- a) verifying that piping is installed correctly, supports are adequate and correct, external attachments such as supports, valves, hangers are secured, insulation is properly installed, tagged and other mechanical connections are properly assembled and the piping is clean and dry.
- b) verifying the pressure-relieving device meets design requirements (correct device and correct set pressure) and are properly installed.

The installation inspection should document baseline thickness measurements to be used as initial thickness readings for corrosion rate calculations on basis of nominal and minimum thickness data in specifications, and design calculations. This will also facilitate the creation of an accurate corrosion rate calculation after the first or better thickness measurements are recorded.

6.2.2 Piping Service Change

If the service conditions of the piping system are changed, the full extent of the initial inspection (except for a process change, material changeover, and the material and thickness existing temperature, inspection records shall be established for the new service conditions.

Both the recording and the position of the piping are changed, the piping shall be inspected before it is moved. Also, the allowable stress condition and the inspection interval shall be established for the new service.

6.3 Piping Inspection Planning

6.3.1 General

The frequency and extent of inspection on piping shall be determined on the basis of the type of equipment and the piping system. The frequency and extent of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency and extent of inspection shall be determined on the basis of the type of equipment and the piping system.

The completed piping inspection schedule in 6.3.1 is based on the consequences of a failure. The classification is used to establish frequency and extent of inspection. The consequences may range from a minor disturbance or failure that may result in a process upset to a major failure that may result in a process shutdown. The consequences of a failure may range from a minor disturbance or failure that may result in a process upset to a major failure that may result in a process shutdown.

After an initial assessment is completed, the results can be used to establish a piping system inspection strategy and develop the following:

- a) the appropriate inspection frequency, scope, type and (frequency) to be applied based on the expected form of degradation.

6.4 Inspection Frequency

6.4.1 General

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

of consequences should also be determined. In general, the higher the consequences of failure, the more frequent the inspection should be. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

The frequency of inspection shall be determined on the basis of the type of equipment and the piping system. The frequency of inspection shall be determined on the basis of the type of equipment and the piping system.

- b) available and proper tags; thermal time change; and reading.
- c) work from piping.
- d) effective odds and coverings.

5.3.4.6 Class 4

Verify that the assembly is nonremovable and remains in Class 4, as the most costly service. Inspection of Class 4 piping is optional and usually based on refinery needs and business reports as opposed to safety or environmental issues. Examples of Class 4 service include, but are not necessarily limited to those containing the following:

- a) safety and process connections,
- b) air
- c) nitrogen,
- d) water, including boiler feed water, steam, and raw water,
- e) low oil, water oil,
- f) ASME B31.3, Category D services
- g) secondary heat exchangers

5.4 Extent of Visual External and CUI Inspections

External visual inspection, including inspection for CUI, should be conducted at inspection intervals listed in Table 2 in relation to those given in API 574. Alternatively, external visual inspection intervals can be established by using a risk-based assessment method in accordance with API 583. This external visual inspection for selected CUI is done to detect corrosion condition and shall be conducted on all piping systems susceptible to CUI listed in API 574. The results of the visual inspection should be documented in facilities reliability reports.

Performing the external visual inspection of susceptible systems, additional consideration is required for the inspection of CUI. The extent and type of the external CUI inspection are listed in Table 3. Damaged condition of higher categories may result in CUI in lower category number from the damage. RST inspection for CUI should also be conducted as listed in Table 3. In addition, inspection of the inspection area is listed in API 574. For condition external and visual inspection is typically required for this inspection or damaged or suspect location. Other RST assessment methods may be used where applicable. If the inspection of the damaged or suspect area has been completed, CUI external areas should be inspected and re-inspected up to 100 percent of the area. Results to be recorded.

The extent of the CUI program described in Table 3 should be conducted on tight levels. If piping systems are installed with no CUI inspection capability, it is recognized that several factors may affect the reliability of CUI inspection.

- a) tight level inspection capability,
- b) detection design and engineering,
- c) available quality.

5.5 Service Connections

Facilities with CUI inspection capabilities may increase or reduce the CUI inspection levels of Table 3. An exact similarity of the CUI inspection levels is not required. The execution may contain inspection steps with specialized history of other disciplines.

Piping systems within Class 4 have a remaining life of over 10 years or that are adequately protected against external corrosion need not be included for the RST inspection requirements in Table 3. However, the condition of the heating system for the area, including, such as a condenser, should be inspected periodically by opening of steam personnel. If deterioration is noted, it should be reported to the inspector. The following are examples of these systems:

- a) piping systems installation effectively to provide the protection of materials
- b) jacketed cryogenic piping systems,
- c) piping systems installed in a tank in which the atmosphere is purged with an inert gas,
- d) piping systems in which the temperature being maintained is sufficiently low or sufficiently high to prevent the presence of water.

The external visual inspection of these piping is to assess the condition of joint and welding systems, to check for external corrosion, and to verify the safety of the piping system.

5.6 Extent of Thickness Measurement Inspection

To verify inspection interval requirements, both thickness measurement inspection should include external and internal as a representative sampling of CUI on each class (see 5.6). This representation sampling should include data for all the system types of components and conditions (pressure and vacuum) found in each class. This sampling also should include CUI with the highest internal corrosion rate of the piping inspection. The more CUI measured for each class, the more accurately the next inspection data will be projected. Therefore, a detailed inspection of similar should be made to determine the next inspection.

The extent of inspection for thickness measurement is covered in API 574.

5.7 Extent of Small-Bore, Auxiliary Piping, and Threaded-End Connections Inspections

5.7.1 SSP Inspection

SSP that is primary process piping should be inspected in accordance with the requirements of this document.

SSP that is secondary process piping has different minimum requirements depending upon service classification. Class 1 secondary SSP should be inspected in accordance with the requirements of primary process piping. Inspection of Class 2 and Class 3 secondary SSP is optional. SSP inspection should be conducted in Class 2 and Class 3 service areas. The inspection of these connections has been experienced as being difficult.

Inspection of CUI should be included in a separate piping class from the main piping. These checks of low level and high level should be included in the inspection. Inspections should include the inspection of a small diameter damage, such as cracks and dents, and CUI on large diameter damage.

5.7.2 Auxiliary Piping Inspection

Inspection of auxiliary SSP inspection with instruments and methodology is optional and the need for such work is primarily for detection of leaks and corrosion. Criteria to consider in determining whether auxiliary SSP will meet some form of inspection include the following:

- a) classification
- b) potential for environmental or fatigue cracking
- c) potential for corrosion based on experience with adjacent primary systems
- d) potential for CUI

5.7.3 Threaded-End Connections Inspection

Inspection of threaded connections will be according to the requirements listed above for secondary and auxiliary piping. When auxiliary CUI is in threaded connections, it should be inspected as well as the main piping. The inspection for such connections should be conducted in the following:

Inspection of connections associated with primary and auxiliary piping should be conducted in accordance with the requirements for primary and auxiliary piping. The inspection for such connections should be conducted in the following:

- a) classification of piping
- b) inspection and frequency of inspection
- c) inspection of connections
- d) inspection of piping and connections
- e) inspection of the piping and connections
- f) inspection rate
- g) inspection rate

5.7.4 Inspection and Maintenance of Pressure-Relieving Devices (PRDs)

5.7.4.1 General

PRDs should be tested and reported by a report organization experienced in related services. PRDs should be reported, tested, and maintained in accordance with API 574.

5.7.4.2 Quality Assurance Process for PRDs

Each equipment report organization that have a fully documented quality assurance system. As a minimum, the following should be included in the quality assurance manual:

- a) objectives,
- b) mission log.

Table 2—Recommended Maximum Inspection Intervals

System Class	Thickness Measurement	Visual External
Class 1	Two years	Two years
Class 2	Two years	Two years
Class 3	Two years	Two years
Class 4	Two years	Two years
Class 5	Two years	Two years
Class 6	Two years	Two years
Class 7	Two years	Two years
Class 8	Two years	Two years
Class 9	Two years	Two years
Class 10	Two years	Two years

NOTE: The inspection intervals apply to systems for which CUI has been established in accordance with 5.7.1.

* Inspection intervals for systems for which CUI has been established in accordance with 5.7.1.

† See API 574 for inspection intervals for CUI.

Table 3—Recommended Extent of CUI Inspection Following Visual Inspection

Pipe Class	Approximate Amount of Thickness Measurement with RST or Inspection Interval at least with damaged insulation	Approximate Amount of CUI Inspection with RST or Inspection Interval at least with damaged insulation
1	75%	50%
2	50%	25%
3	25%	10%
4	Optional	Optional

- a) condition log
- b) inspection of condition and frequency of inspection
- c) inspection of condition
- d) inspection of condition
- e) inspection of condition
- f) inspection of condition
- g) inspection of condition
- h) inspection of condition
- i) inspection of condition
- j) inspection of condition
- k) inspection of condition
- l) inspection of condition
- m) inspection of condition
- n) inspection of condition
- o) inspection of condition
- p) inspection of condition
- q) inspection of condition
- r) inspection of condition
- s) inspection of condition
- t) inspection of condition
- u) inspection of condition
- v) inspection of condition
- w) inspection of condition
- x) inspection of condition
- y) inspection of condition
- z) inspection of condition

d) sample limits

e) testing and qualifications required for repair personnel.

f) requirements for handling of nonconformances

Each repair organization shall also have a fully documented training program that shall ensure that repair personnel are qualified within the scope of the repair.

6.7.3. PRB Testing and Inspection Intervals

6.7.3.1 General

Pressure-relieving devices shall be tested and inspected at intervals that are frequent enough to verify that the device performs reliably in the particular service conditions. Other pressure-relieving devices (e.g., rupture disks and vacuum breakers) shall be inspected at intervals based on service conditions. The inspection interval for all pressure-relieving devices is determined by either the Inspector, Engineer, or other qualified individual per the manufacturer's quality management system.

6.7.3.2 Unless documented experience indicates an RRI assessment indicates that a longer interval is acceptable, test and inspection intervals for pressure-relieving devices subject to process penalties shall not exceed:

- five years for typical process service; and
- 10 years for clean (unfouling) and noncorrosive services.

When a pressure-relieving device is found to be heavily fouled or clogged, the inspection and testing interval shall be reduced. A review shows that the device will perform reliably at the current interval. The review should document the cause of the fouling or the reasons for the pressure-relieving device not operating properly.

7 Inspection Data Evaluation, Analysis, and Recording

7.1 Corrosion Rate Determination

7.1.1 Remaining Life Calculations

The remaining life of the piping system shall be calculated from the following formula:

$$\text{Remaining life (years)} = \frac{\text{Initial thickness} - \text{Corrosion rate (in./yr)}}{\text{Corrosion rate (in./yr)}} \quad (1)$$

Where:

Initial = is the initial thickness (in.) of the pipe or component measured at the time of design or for a given thickness of component as specified in 6.6.

Corrosion = is the required thickness, in inches (millimeters), at the same location or component as the initial measurement, determined by the design formula (e.g., pressure and structural stress analysis, vibration and mechanical stress analysis) or a thickness of a component as added.

The LT measurement of piping shall be calculated from the following formula:

$$\text{Corrosion rate (LT)} = \frac{\text{Initial thickness} - \text{Current thickness}}{\text{Time (years) between } t_1 \text{ and } t_2} \quad (2)$$

The LT corrosion rate of piping shall be calculated from the following formula:

$$\text{Corrosion rate (LT)} = \frac{\text{Initial thickness} - \text{Current thickness}}{\text{Time (years) between } t_1 \text{ and } t_2}$$

Where:

Initial = is the thickness, in inches (millimeters), of the pipe or component initially measured at initial inspection or at the commencement of a first scheduled maintenance.

Current = is the thickness, in inches (millimeters), at the same location as initially measured during one or more subsequent inspections.

The preceding formula may be applied in a statistical approach to assess corrosion rates and remaining life calculations for the piping system. Care shall be taken to ensure that the statistical treatment of data results reflects the actual condition of the piping system components. Statistical analysis employing point measurements is not applicable to piping systems with significant localized corrosion or pitting.

LT and LT corrosion rates should be compared to any other results in the system covering the same part of the data assessment. The statistical approach, in conjunction with a corrosion assessment, shall reflect the corrosion rate that best reflects the current process (see 6.7.3.2 for inspection interval determination).

7.1.2 Newly Installed Piping Systems or Changes in Service

For new piping systems and piping systems for which service conditions are being changed, one of the following methods shall be employed to determine the probable rate of corrosion (with which the remaining life is calculated) at the time of the first inspection to be executed:

- A corrosion rate for a piping system may be estimated from data collected by the manufacturer on piping systems of similar material in comparable service with comparable operating conditions.
- If data for the same or similar piping are not available, a corrosion rate for a piping system may be estimated from the manufacturer's experience or from published data on piping systems in comparable service.

If the probable corrosion rate cannot be determined by other methods listed in item a) or item b), the total remaining life calculation shall be made after no more than three months of service by using nondestructive thickness measurements of the piping system. Corrosion monitoring systems, such as corrosion coupons or corrosion probes, may be useful in establishing the timing of these thickness measurement intervals. Subsequent measurements shall be made when adequate thickness data for the corrosion rate is established.

7.1.3 Replacing Piping Systems

Corrosion rates shall be determined when a piping system is replaced.

Corrosion rates shall be determined for the piping system of the design has been assumed, the rate to be used for the next period shall be adjusted to agree with the actual rate found.

7.2 Repair Determination

The design for the continued use of piping systems shall be established using the applicable code. Determinations may be made for known materials if all the following essential details are known to comply with the provisions of the applicable code:

- specify material limits (specification limits for specific materials).

b) quality of materials and workmanship

c) inspection requirements

d) nonconformance openings

e) any special service requirements

For inspection methods, consideration may be made assuming the lowest grade material and joint efficiency in the applicable code. Where the MAWP is determined, the wall thickness shall be determined for the actual conditions as determined by inspection results. When the MAWP is determined, the wall thickness shall be determined for the actual conditions as determined by inspection results. When the MAWP is determined, the wall thickness shall be determined for the actual conditions as determined by inspection results.

Table 4 contains two examples of calculation of MAWP assuming the least of the corrosion rate and design.

7.3 Required Thickness Determination

The required thickness of a pipe shall be the greater of the pressure design thickness or the required minimum thickness. For sections with high wall, the piping engineer should consider determining the required thickness to provide for upset or reduced or unknown loading or undesigned metal loss. See API 574 for information on design and required minimum thicknesses.

7.4 Assessment of Inspection Findings

Pressure-containing components found to have degradation MAWP could affect both fluid handling capacity (pressure levels and other applicable limits (e.g., weight, wind etc., per API 570-MAWME FFS-1)) shall be evaluated for continued service. Fitness-For-Service inspection, such as those documented in API 570-MAWME FFS-1, Section 4.1, may be used for this evaluation. The Fitness-For-Service methodology used shall be applicable to the specific degradation observed. The following table may be used as a guide.

a) To evaluate existing or future loss of the corrosion allowance, a Fitness-For-Service assessment may be performed in accordance with one of the following sections of API 570-MAWME FFS-1. The assessment requires the use of a future corrosion allowance, which shall be established based on 7.1.

1) Assessment of General Metal Loss—API 570-MAWME FFS-1, Section 4.

2) Assessment of Local Metal Loss—API 570-MAWME FFS-1, Section 5.

3) Assessment of Piping Corrosion—API 570-MAWME FFS-1, Section 6.

b) To evaluate fracture and leak before a Fitness-For-Service assessment should be performed in accordance with API 570-MAWME FFS-1, Section 7. In some cases, the evaluation will require the use of a future corrosion allowance, which shall be established based on 7.1.

c) To evaluate wall misalignment and shell distortion, a Fitness-For-Service assessment should be performed in accordance with API 570-MAWME FFS-1, Section 8.

d) To evaluate crack-like flaws, a Fitness-For-Service assessment should be performed in accordance with API 570-MAWME FFS-1, Section 9.

e) To evaluate the effects of the design, a Fitness-For-Service assessment should be performed in accordance with API 570-MAWME FFS-1, Section 11.

7.5 Piping Stress Analysis

Piping shall be supported and guided to meet:

- to weight to control safety.
- a maximum flexibility for normal expansion or contraction.
- a safe minimum clearance.

Piping flexibility is of increasing concern the larger the diameter of the piping and the greater the difference between ambient and operating temperatures conditions.

Piping stress analysis to assess system flexibility and support adequacy is not normally performed as part of a piping inspection. However, many existing piping systems were analyzed as part of basic original design or as part of an existing or modification, and the results of these analyses can be useful in developing inspection plans. When unexpected misalignment of a piping system is observed, such as during an external vessel inspection (see 6.4.4), the supporting details should be investigated with the piping engineer and flexible the need for conducting a piping stress analysis.

Table 4—Two Examples of the Calculation of MAWP Assuming the Use of the Corrosion Allowance Concept

Example 1	
Design pressure (internal pressure)	500 psig (34.5 MPa)
Pipe specification	ASTM A106, Grade B, 10 in. nominal wall thickness, 100-D
Outside diameter of pipe, D	10 in. (254 mm)
Allowable stress	20,000 psi (1378 MPa)
Corrosion rate (in./yr)	0.001
Thickness of pipe at inspection	0.32 in. (8.13 mm)
Design stress intensity factor, S	0.85 in. (21.59 MPa)
Design stress intensity factor, S	0.85 in. (21.59 MPa)
Estimated corrosion loss by time of next inspection	0.001 in. (0.0254 mm)
MAWP (in./yr) (Corrosion rate)	0.001 in. (0.0254 mm)
MAWP (in./yr) (Corrosion rate)	0.001 in. (0.0254 mm)
Corrosion rate	0.001 in. (0.0254 mm)
Example 2	
Design pressure	500 psig (34.5 MPa)
Estimated corrosion loss by time of next inspection	0.001 in. (0.0254 mm)
MAWP (in./yr) (Corrosion rate)	0.001 in. (0.0254 mm)
MAWP (in./yr) (Corrosion rate)	0.001 in. (0.0254 mm)
Corrosion rate	0.001 in. (0.0254 mm)

NOTE 1—The formula for MAWP is from ASME B31.1, Section 4, where S is allowable stress.

See API 574 for more information on process design, minimum required and standard minimum frequencies, testing frequency, example problems and detail built-in design features.

Piping stress analysis can identify the most highly stressed components in a piping system and predict the thermal movement of the system when it is placed in operation. This information can be used to determine inspection points at the locations most prone to fatigue damage from thermal expansion (shrinkage and expansion) cycles and/or cyclic damage in high-temperature piping. Comparing predicted thermal expansion with observed movements can help identify the existence of unexpected operating conditions and dissipation of gases and vapors. Comparison with the piping engineer may be necessary to confirm observed deviations from the design prediction, particularly for controlled systems involving multiple supports and guides between and joints.

Piping stress analysis also can be employed to help solve vibration problems. The system is analyzed to determine if a piping system will operate as intended by analysis. The system is analyzed to determine if the system is designed to operate as intended by analysis. The system is analyzed to determine if the system is designed to operate as intended by analysis.

7.8 Inspection and Records for Piping System Inspection

7.8.1 Permanent and Progressive Records

Piping system owners and users shall maintain permanent and progressive records of their piping system and progressive inspection records. Permanent records shall be maintained throughout the service life of each piping system. As a part of these records, progressive inspection and maintenance records shall be regularly updated to include new information pertinent to the inspection, inspection and maintenance history of the piping system. See API 574 for more information on piping system records.

7.8.2 Types of Piping Records

Piping system and pressure-relieving device records shall contain the types of information pertinent to maintaining adequate safety as follows:

1. Fabrication, Construction and Design Information for the System Available—for example, NPS, WTS, with design, operating, design, inspection data (piping system capabilities, PDS, records, legal data, design, pressure-relieving device design, construction and construction drawings).
2. Inspection History—for example, inspection report, and data for each inspection conducted (e.g., failure, corrosion, fracture, mechanical failure) and inspection report/records for the piping system. Reports shall document the date of each inspection, inspection results, the date of the next scheduled inspection, the name of the inspector who performed the inspection and the name of the person who approved the inspection. The name of the person who approved the inspection shall be the name of the person who approved the inspection. The name of the person who approved the inspection shall be the name of the person who approved the inspection.
3. Repair, Alteration and Replacement Information—for example:
 - a. repair and alteration history as required
 - b. repairs including both piping system and equipment with other identified deficiencies. Temporary repairs to equipment shall be recorded for continued service until repairs can be completed and
 - c. recording discontinuation, including replacement and new design conditions.

7.8.3 Inspection and Maintenance Records are Described in API 574—API 574—Guidelines for Piping Inspection, Analysis, Repair and Replacement of Piping Systems. Specific inspection requirements for Class 1 and Class 2 piping are provided in the appropriate part of API 574—API 574—Guidelines for Piping Inspection, Analysis, Repair and Replacement of Piping Systems.

7.8.4 Operating and Maintenance Records

Operating and maintenance records, such as operating conditions, including process upsets that may affect mechanical integrity, changes in service, mechanical damage from maintenance should also be retained in the logbook.

7.8.5 Computer Records

The use of a computer-based system for recording, processing, and analyzing data should be considered in view of the volume of data that will be generated as part of a piping inspection program. Computer programs are particularly useful for the following:

- a. storing and analyzing the entire inspection history;
- b. calculating plant and equipment stresses, corrosion rates, RMP, and inspection intervals on a rotating basis by rotating plant data;
- c. highlighting areas of high corrosion rates, piping system changes for inspection, piping close to retirement, pressure, and other information.

7.8.6 Piping Critical Records

The following information should be recorded for each piping class on which Class 1 or Class 2 is required:

- a. material of construction/inspection classification
- b. operating and design conditions/temperature
- c. ASME code used
- d. pressure class
- e. whether the class is a design inspection class, inspection class, or other special class.
- f. the inspection results (including service life of, at least, the primary containment system of the class).
- g. inspection history for each inspection
- h. maintenance history for each inspection, including maintenance history
- i. any other relevant information that shall include inspection results/inspection history
- j. the inspection results (including inspection results) of each inspection class on which Class 1 or Class 2 is required.

7.8.6 Inspection Records Drawings (ISDs)

The primary purpose of inspection records is to identify the location of CILs and to identify the location of the recommended maintenance. Inspection records are recommended for each inspection by the inspector.

- a. an inspection record of the piping system (e.g., all piping, valves, tanks, etc.)
- b. an inspection record for Class 1 (or high-consequence Class 2) piping class
- c. an inspection record for Class 2 (or high-consequence Class 2) piping class
- d. an ISD with appropriate information to locate the CILs
- e. adequate resolution and scale to provide adequate detail
- f. piping—drawings, sketches, and drawings
- g. inspection drawing history
- h. completion of inspection reports

Inspection ISDs are recommended for all piping and all Class 1 (or high-consequence Class 2) piping class piping on which CILs have been identified for detection, maintenance. Adequate resolution for piping class, piping which continuously deteriorates the system (e.g., ISD may be used).

Inspection ISDs are recommended for Class 2 (or high-consequence Class 2) piping with CILs, except that the ISD may be used for all other piping on which CILs have been identified for detection, maintenance.

Inspection ISDs are not used to locate or show dimensions unless necessary to locate CILs.

7.8.7 Inspection Requirements for Repair or Replacement

After repair or replacement recommendations are made, the recommendations for repair or replacement shall be recorded and shall be kept current. The recommendations shall be recorded and shall be kept current.

- a. recommendations for repair or replacement
- b. repair or replacement for recommended action
- c. piping system (including piping system or other system) that the recommendations affect

A management system is required for tracking and following up on recommendations on a periodic basis.

7.8.8 Inspection Records for External Inspection

Records of external piping system inspections shall be documented. A summary of the results is recommended when documentation is required. The results of the inspection shall be documented in the inspection report, including the results of the inspection, including the results of the inspection, including the results of the inspection.

7.9 Piping Failure and Leak Reports

Leak and failure in piping systems are analyzed to determine whether or not the failure should be repaired and recorded in the record book. As with other piping failures, leaks and failures in piping systems shall be investigated to identify and correct the cause of failure. Temporary repairs to piping systems shall be documented in the inspection records.

7.10 Inspection Defined or Identified Events

Any piping event not included within the established interval is considered a piping event. The event is an inspection event. The event is an inspection event. The event is an inspection event.

A failure is a piping event which the piping system is not designed to self-correct in the current given the available data. If an inspection of the piping system is not conducted in a timely manner, the failure is a piping event. The failure is a piping event. The failure is a piping event.

An inspection event is a piping event which the piping system is not designed to self-correct in the current given the available data. If an inspection of the piping system is not conducted in a timely manner, the failure is a piping event. The failure is a piping event. The failure is a piping event.

- a. the piping history and maintenance shall be reviewed by the inspector.

- a. inspection records shall be documented by the inspector and should include the inspection results supporting the classification.

- a. the inspector shall prepare an inspection report or report.

NOTE: If the inspection results are not included in the inspection report, the inspection results shall be included in the inspection report. The inspection results shall be included in the inspection report. The inspection results shall be included in the inspection report.

8 Repair, Alteration, and Relining of Piping Systems

8.1 Repair and Alteration

8.1.1 General

The purpose of API 574 is to ensure that the piping system is maintained in a safe condition. The purpose of API 574 is to ensure that the piping system is maintained in a safe condition. The purpose of API 574 is to ensure that the piping system is maintained in a safe condition.

The purpose and practices of API 574 shall also be followed for all related repairs and modifications.

8.1.2 Authorization

All repair and alteration work shall be done by a repair organization as defined in Section 3 and as approved by the inspection organization. The inspection organization shall be approved by the inspection organization. The inspection organization shall be approved by the inspection organization.

insured. When surface and volumetric examinations are required, they shall be in accordance with ASME BPVC Section V (or equivalent).

A2.7 Pressure Testing

After welding is completed, a pressure test in accordance with this shall be performed if practical and deemed necessary by the Inspector. Procedures for the testing are required after discussion and mutual review. See ASME B31.3 for more information on conducting pressure tests. When a pressure test is not necessary or practical, NDE shall be utilized in any of a pressure test. Discontinuing a pressure test procedure for a pressure test at an inspection, re-inspection, or repair may be done only after consultation with the Inspector and the piping engineer. For testing conducted that shall be testing pressure tested after repair, re-inspection, or replacement, it is not necessary to stop circulation on all existing vessels. Pressure tests with larger hold times and observations of pressure gauges can be conducted for inspection activities when the risk associated with test under the condition are acceptable.

When it is not practical to perform a pressure test of a full closure valve that joins a new or replacement section of piping to an existing system, all of the following requirements shall be satisfied:

- The new or replacement piping & pressure tested and identified in accordance with the applicable code governing the design of the piping system, or if not practical, welds are examined with appropriate NDE, as specified by the applicable piping code.
- The design weld is a full penetration butt joint between any pipe or standard piping component of equal diameter and thickness, evenly spaced from each end, and of equivalent materials, thickness, and dimensions to the design.
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and
- Welds designed for design stresses up to Class 150 and 300 °F (650 °C) and

d) Banded piping systems shall be inspected in accordance with the code to which the piping system is subject for the latest edition of the applicable code for the new service conditions, unless documented evidence indicates a previous full thickness portion of the pipe that was tested to the test pressure for the new condition. An exception to the testing temperature test shall be allowed if the test pressure does not require a full test.

- The piping system is tested to a level that the required pressure relieving devices are present, are set at the appropriate pressure, and have the appropriate capacity relief pressure.

- The piping system testing is completed in the inspection or piping engineer.

- All piping components in the system (such as valves, flanges, tees, elbows, gaskets, bolting, and expansion joints) are subjected to the same combination of pressure and temperature.

- Flange leakage is detected for design temperature changes.

- Appropriate engineering records are updated.

- A maximum maximum operating temperature (MOMOT) record is maintained if required by the applicable code.

- Inspection of Buried Piping

- General

Inspection of buried piping systems (not regulated by the U.S. Department of Transportation) is different from other piping inspection because significant factors of deterioration can be caused by corrosion and erosion and the inspection can be limited by the accessibility of the buried area of the piping system. Recommended inspection techniques for underground piping inspection are API 574 and the following NACE documents: NP010, RP017, and RP027, and API 574 and API 574.

- Types and Methods of Inspection

- Aboveground Visual Inspection

Inspection of buried piping may include a change in the surface condition of the ground, displacement of the soil, a change of ground level, ground movement, building or other structures, or a change of the ground level of the piping system. The inspection of buried piping shall be performed in accordance with the applicable code.

- Close Interval Potential Survey

The close interval potential survey performed at ground level over the buried pipe can be used to locate cathodic protection points on the pipe system.

Corrosion cells can form on both sides of a buried pipe where the pipe does not contact the soil. From the potential of the pipe to the soil, the potential of the pipe can be determined. The potential of the pipe can be determined by the potential of the pipe.

- Pipe Coating Holiday Survey

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems. The pipe coating holiday survey can be used to locate coating defects on buried piping systems and can be used to locate coating defects on buried piping systems.

The external condition of buried piping that is not adequately protected should be determined by other piping, which can maintain its condition, or by determining according to the temporary status in Table 5. Significant external corrosion detected by piping or by other means may require excavation and evaluation even if the piping is adequately protected.

Piping inspected successfully by excavation shall be inspected in lengths of 5 ft (1.5 m) or less (2.5 m) or more (locally) exposed to be inspected (API 570). Damaged piping should be inspected for consideration for the type and extent of corrosion (pitting or general) and the condition of the coating.

If inspection reveals damaged coating or exposed piping, additional piping shall be excavated until the extent of the condition is identified. If the average wall thickness is at or below minimum thickness, it shall be repaired or replaced.

If the piping is contained inside a casing pipe, the condition of the casing should be inspected to determine if water and soil have entered the casing. The inspector should verify the following:

- Integrity of the casing extends beyond the ground line.
- The ends of the casing are sealed if the casing is not self-draining, and
- The pressure-containing pipe is properly coated and wrapped.

6.3.7 Leak Testing Methods

An alternative to a permanent inspection to leak testing with liquid die is pressure testing. It is suitable for minimum operating pressure of 150 psig (10.3 barg) for those shown in Table 5 for piping not continuously protected or at the same frequency as shown in Table 5 for continuously protected piping. The test fluid should be maintained for a period of 8 hours. Four hours after the initial pressurization of the piping system, the pressure should be reduced, if necessary, for the replacement of damaged test hardware and isolated from the pressure source. If during the remainder of the test period, the pressure decreases more than 5%, the piping should be visually inspected externally and/or inspected internally to find the leak and remove the cause of corrosion. Corrosion measurements may be helpful in locating leaks during leak testing.

Leak testing shall not be performed for piping that is not designed for pressure testing. Other alternative leak test methods include acoustic emission and the addition of a tracer fluid to the pressurized fluid. As a tracer fluid or other indication, if the tracer is added to the stream fluid, the detector shall confirm suitability for operation and periodic.

Table 5—Frequency of Inspection for Buried Piping Without Effective Cathodic Protection

Soil Resistivity (ohm-cm)	Inspection Interval (Years)
<1,000	1
1,000 to 10,000	2
>10,000	3

6.4 Repairs to Buried Piping Systems

6.4.1 Repairs to Coatings

Any coating removed for inspection shall be removed and replaced appropriately. For coating repair, the surface should be prepared to the condition of the following items:

- That suitable adhesion to the pipe is maintained and restoration of monolayer.

APPENDIX A (Informative)

Inspector Certification

A.1 Examination

A written examination to certify inspectors when the scope of API 570 shall be based on the current API 570 inspection body of knowledge as determined by API.

A.2 Certification

An API 570 authorized piping inspector certification will be issued when an applicant has successfully passed the API 570 certification exam and satisfied the criteria for experience and education. Education and experience when combined shall be equal to at least one of the following:

- A bachelor's or doctoral degree in engineering or technology plus one year of experience in supervision of inspection activities or performance of inspection activities as described in API 570.
- A bachelor's degree or equivalent in engineering or technology, plus two years of experience in the design, construction, repair, inspection, or operation of piping systems, of which one year must be in supervision of inspection activities or performance of inspection activities as described in API 570.
- A high school diploma or equivalent plus three years of experience in the design, construction, repair, inspection, or operation of piping systems, of which one year must be in supervision of inspection activities or performance of inspection activities as described in API 570.
- A minimum of five years of experience in the design, construction, repair, inspection, or operation of piping systems, of which one year must be in supervision of inspection activities or performance of inspection activities as described in API 570.

A.3 Recertification

A.3.1 Recertification is required three years from the date of issuance of the API 570 authorized piping inspector certificate. Recertification by written examination will be required for authorized piping inspectors who have not been actively engaged in authorized piping inspection within the most recent three-year certification period and for authorized piping inspectors who have not previously passed the exam. Exams will be in accordance with all previous examinations in API 570.

A.3.2 "Actively engaged in an authorized piping inspection" shall be defined as a minimum of 20 h of time spent performing inspection activities in supervision of inspection activities or supervising inspection activities in the API 570, and/or at least one year of inspection period.

NOTE: Inspection activities include all API 570 inspection activities (i.e., visual inspection, review of written documents, and/or field measurements).

A.3.3 Once every three-year certification period (every six years), inspectors actively engaged in an authorized piping inspection shall demonstrate knowledge of revisions to API 570 and demonstrate ability to apply the code to the field. This requirement shall be satisfied by either the inspector's total certification data (inspector who has not been actively engaged in an authorized piping inspection within the most recent three-year certification period) or by the inspector's certification data (inspector who has been actively engaged in an authorized piping inspection within the most recent three-year certification period) as required in A.3.1.

- It is sufficient only during the repair period.

- It is free of holes and cracks in the coating material.

- It has sufficient strength to resist damage due to handling and soil stress.

- It can support any supplemental cathodic protection.

In addition, coating repairs may be tested using a high voltage holiday detector. The detector voltage shall be adjusted to the appropriate value for the coating material and thickness. Any holidays found shall be repaired and retested.

6.4.2 Clamp Repairs

If piping leaks are detected and repaired, the location of the clamp shall be logged in the inspection report and may be surface marked. Both the location and the record shall note the date of installation and the location of the clamp. All clamps shall be considered temporary. The piping should be permanently repaired at the first opportunity.

6.4.3 Welded Repairs

Welded repairs shall be made in accordance with 8.2.

6.5 Records

Records systems for buried piping should be maintained in accordance with 7.6. In addition, a record of the location and date of installation of temporary clamps shall be maintained.

Annex B (Informative)

Requests for Interpretations

B.1 Introduction

API will respond to requests for interpretations of API 570. API will not make such interpretations without their consideration. If necessary, with the appropriate committee officer and the committee membership. The API committee responsible for maintaining API 570 shall regularly be notified when necessary for interpretation and clarification, and to develop new items as dictated by technological developments. The committee's attention in this regard also extends to interpretations of the latest edition of API 570 or to the consideration of revisions to API 570 based on the new data or technology.

As a matter of policy, API does not assume liability, or endorse any form, consultation, proprietary claims, or activity, and accordingly requires requests for interpretation will be returned. However, API does not act as a consultant on specific engineering problems or on the general understanding or application of the code. It based on the inquiry information submitted, it is the opinion of the committee that the inquiry should be interpreted or interpreted differently. The inquiry will be returned with the recommendation that such interpretation be obtained.

API requires that all requests for interpretation needed for full understanding will be returned.

B.2 Inquiry Format

Requests shall be limited solely to requests for interpretation of the latest edition of API 570 or to the consideration of revisions to API 570 based on new data or technology. Inquiries shall be submitted in the following format:

- Scope**—The inquiry shall contain a single subject or closely related subjects. An inquiry letter concerning unrelated subjects will be returned.
- Background**—The inquiry letter shall state the purpose of the inquiry which shall be either to obtain an interpretational API 570 or to propose consideration of a revision to API 570. The inquiry shall provide enough information needed for complete understanding of the inquiry with sketches as necessary and include references to the applicable edition, paragraph, figure, and table.
- Inquiry**—The inquiry shall be stated in a numbered and precise question format, stating verbatim the inquiry and which appropriate, numbered (such as "yes" or "no") (if the inquiry is not provided) shall be a possible reply. This inquiry statement shall be clearly and accurately stated. This inquiry shall state what the inquiry is for. If the inquiry is for a revision to API 570 or needed, the inquiry shall provide recommended wording.

Submit the request for interpretation to the API Request for Interpretation website at <http://api.org>.

B.3 Request for Interpretation Responses

Responses to inquiries for interpretation can be found on the API website at <http://api.org> or by email at api@api.org.

Annex C (informative) Examples of Repairs

C.1 Repairs

Repair welding of the gas nozzles or shielded metal arc processes may be used.

When the temperature is below 50 °F (10 °C), low hydrogen electrodes, AWS E308 or E308L, shall be used when welding materials conforming to ASTM A-24, Grade A and B; A-199, Grade A and B; A-332, A-334, API 5L, and other similar material. These electrodes should also be used on lower grades of material with the temperature of the material at 50 °F (10 °C). The piping engineer should be consulted for cases involving different materials.

When AWS E308 (E308L) electrodes are used on AWS numbers 2 and 3 (see Figure C.1 below), the leads shall be deposited by sticking at the bottom of the groove and welding up side. The diameter of the electrode should not exceed 3/16 in. (4.8 mm). Electrode length shall be 14 in. (356 mm) or less. Electrode number 1 (see Figure C.1), but the diameter should not exceed 3/16 in. (4.8 mm).

The longitudinal welds in Figure C.1 are the minimum sleeve shall be fabricated in a double type weld joint meeting with one root to each side of the weld to the diameter of the pipe.

NOTE: If the original pipe along with number 1 has been checked thoroughly by ultrasonic methods and is in sufficient condition for welding, a cutting step is not necessary.

All repair and welding procedures for gas nozzles shall conform to API 2201.

C.2 Small Repair Patches

The diameter of electrode should not exceed 3/16 in. (4.8 mm). When the temperature of the base metal is below 50 °F (10 °C), low hydrogen electrodes shall be used. Welding of small leaks repaired with low hydrogen electrodes should be avoided.

All repair and welding procedures for gas nozzles shall conform to API 2201.

Examples of small repair patches are shown below in Figure C.2.




Figure C.1—End-to-end Repair Sleeve




Figure C.2—Small Repair Patches

THERE'S MORE WHERE THIS CAME FROM

API provides additional resources and programs to the oil and natural gas industry which are based on API Standards. For more information, contact:

API MONOGRAM™ LICENSING PROGRAM

Phone: 202-682-4793
Fax: 202-682-8670
Email: certification@api.org

API QUALITY REGISTRAR (APIQR)

> ISO 9001 Registration
> ISO/TS 29001 Registration
> ISO 14001 Registration
Phone: 202-682-4793
Fax: 202-682-8670
Email: certification@api.org

API PERFORATOR DESIGN REGISTRATION PROGRAM

Phone: 202-682-8498
Fax: 202-682-8670
Email: perfdesign@api.org

API TRAINING PROVIDER CERTIFICATION PROGRAM (API TPCP™)

Phone: 202-682-8498
Fax: 202-682-8670
Email: tpcp@api.org

API INDIVIDUAL CERTIFICATION PROGRAMS (ICP)

Phone: 202-682-8694
Fax: 202-682-8698
Email: icp@api.org

API ENGINE OIL LICENSING AND CERTIFICATION SYSTEM (EOLCS)

Phone: 202-682-8516
Fax: 202-682-8739
Email: eolcs@api.org

API PETROTEAM TRAINING, EDUCATION AND MEETINGS

Phone: 202-682-8395
Fax: 202-682-8222
Email: petroteam@api.org

API UNIVERSITY™

Phone: 202-682-8195
Fax: 202-682-8223
Email: training@api.org

Check out the API Publications, Programs, and Services Catalog online at www.api.org



Copyright © 2004 API. All rights reserved. API is a registered trademark of the American Petroleum Institute. All other trademarks are the property of their respective owners.



1381 L Street, N.W.
Washington, D.C. 20004-6150
USA

202-682-8000

Additional copies are available through TechSpec
Phone Order: 1-202-682-8777 (toll-free in the U.S. and Canada)
Fax Order: 202-682-8725 (toll-free in the U.S. and Canada)
Online Order: www.api.org

Information on API Publications, Programs and Services
is available on the web at www.api.org

Product No. C22451

**PAE TECHNICAL SERVICE PUBLIC CO.,LTD.**

NDT, TESTING, INSPECTION & ENGINEERING CONSULTANT

Tel : 02) 322-0222 , Fax : 02) 721-2577 , RAYONG : 038) 682208-9

ULTRASONIC THICKNESS MEASUREMENT REPORT

Client : PTT Global Chemical Public Co.,Ltd.		Report No. : PAE-UTM-PTTGC7-001/2021		
Project Name: PTT.GC # 7		Test Date : 11 February 2021		
Written Examination Procedure No. : PAE # 008		Job No. : U-TM-MP		
Line No. 8-MEG-2010-E1P0		Size : 8"		
Material Spec. : A312 TP304		Temp. : 50 °C		
UT MFR : OLYMPUS	Model : 38 DL PLUS	Series No. : 130644805		
Probe Model : D - 790 SM	Series No. : 730694	Probe Angle : 0°		
Couplant : GREASE	Frequency : 5 MHz	Sch / Thk 3.73 mm.		
Material of Stepwedge : CS	Calibration Range : 2.5 - 25 mm.	Velocity : 5920		
Surface Condition : <input checked="" type="checkbox"/> On Paint <input type="checkbox"/> Smooth <input type="checkbox"/> Internal <input checked="" type="checkbox"/> External				
SEE ATTACHED DETAIL & DRAWING				
Completed by	INSPECTED BY	REVIEWED BY	REVIEWED BY	APPROVED BY
Company				PTT GC
Signature				
Name				
Date	11 February 2021	11 February 2021	11 February 2021	

ULTRASONIC THICKNESS REPORT

REPORT No. : PAE-UTM-PTT GC7-001/2021

Equipment / Piping No. : 8-MEG-2010-EIPO		Refer Master Key Point Diag. No. : 8-MEG-2010-EIPO		Corr. Circuit No. :	
Site : PTTSC #7		UNIT : ETT TO TOGCG			

TECHNICAL DATA

Location			Field		Design Condition				Operating Condition				Material		Paint		Insulation		
From	To		Part	Size (inch.)	SCH	Nom. wt.(mm.)	Pressure		Temp.		Pressure		Temp.		CA	SOR	LCR	SRL	LRL
UT Point	Position	kg/cm ² G					Bar	°C	UT date	wt.(mm.)	kg/cm ² G	Bar	°C	UT date					
A312 TP304																			
48																			
1I	A	Elbow 90°	8"	10S	3.76	2.80	4.72												
	C				3.76	2.80	4.51												
	E				3.76	2.80	3.96												
	G				3.76	2.80	4.56												
1II	A	Elbow 90°	8"	10S	3.76	2.80	3.91												
	C				3.76	2.80	4.18												
	E				3.76	2.80	4.68												
	G				3.76	2.80	4.24												
1V	A	Elbow 90°	8"	10S	3.76	2.80	4.26												
	C				3.76	2.80	4.42												
	E				3.76	2.80	4.03												
	G				3.76	2.80	4.25												
2I	A	Elbow 90°	8"	10S	3.76	2.80	4.12												
	C				3.76	2.80	4.26												
	E				3.76	2.80	3.96												
	G				3.76	2.80	4.14												
2II	A	Elbow 90°	8"	10S	3.76	2.80	3.98												
	C				3.76	2.80	4.16												
	E				3.76	2.80	5.03												
	G				3.76	2.80	4.02												
2V	A	Elbow 90°	8"	10S	3.76	2.80	4.68												
	C				3.76	2.80	4.60												

UT Point	Position	Part	Size (Inch.)	SCH	Nom. 1-1/2-06 wt.(mm.)	MAT 11-Feb-21 wt.(mm.)	UT date wt.(mm.)	UT date wt.(mm.)	UT date wt.(mm.)	UT date wt.(mm.)	UT date wt.(mm.)	UT date wt.(mm.)	CA {mm.}	SCR {mm/y.}	LCR {mm/y.}	SRL {yrs.}	LRL {yrs.}
	E				3.76 2.80	4.46							1.66	-0.05	-0.04	-35.68	-45.11
	G				3.76 2.80	4.47							1.67	-0.06	-0.04	-35.37	-45.28
3I	A	Elbow 90°	8"	10S	3.76 2.80	4.20							1.40	-0.03	-0.03	-47.85	-40.40
	C				3.76 2.80	4.15							1.35	-0.03	-0.03	-52.06	-39.43
	E				3.76 2.80	3.93							1.13	-0.01	-0.03	-59.96	-34.85
	G				3.76 2.80	4.33							1.53	-0.04	-0.04	-40.37	-42.83
3II	A	Elbow 90°	8"	10S	3.76 2.80	4.03							1.23	-0.02	-0.03	-48.51	-36.99
	C				3.76 2.80	4.17							1.37	-0.03	-0.03	-50.25	-39.82
	E				3.76 2.80	4.58							1.78	-0.05	-0.04	-32.64	-47.10
	G				3.76 2.80	4.10							1.30	-0.02	-0.03	-57.50	-38.43
3V	A	Elbow 90°	8"	10S	3.76 2.80	4.52							1.72	-0.05	-0.04	-34.03	-46.12
	C				3.76 2.80	4.25							1.45	-0.03	-0.04	-44.50	-41.35
	E				3.76 2.80	4.46							1.66	-0.05	-0.04	-35.88	-45.11
	G				3.76 2.80	4.52							1.72	-0.05	-0.04	-34.03	-46.12
4I	A	Elbow 90°	8"	10S	3.76 2.80	4.83							2.03	-0.07	-0.04	-28.53	-50.94
	C				3.76 2.80	4.75							1.95	-0.07	-0.04	-28.52	-49.78
	E				3.76 2.80	3.90							1.10	-0.01	-0.03	-118.16	-34.18
	G				3.76 2.80	4.72							1.92	-0.06	-0.04	-30.08	-49.20
4II	A	Elbow 90°	8"	10S	3.76 2.80	4.11							1.31	-0.02	-0.03	-56.29	-38.53
	C				3.76 2.80	4.06							1.26	-0.02	-0.03	-53.16	-37.61
	E				3.76 2.80	4.54							1.74	-0.05	-0.04	-33.65	-45.45
	G				3.76 2.80	4.03							1.23	-0.02	-0.03	-58.51	-35.99
4V	A	Elbow 90°	8"	10S	3.76 2.80	4.16							1.36	-0.03	-0.03	-51.13	-39.62
	C				3.76 2.80	4.57							1.77	-0.05	-0.04	-32.86	-46.94
	E				3.76 2.80	3.87							1.07	-0.01	-0.03	-146.28	-33.51
	G				3.76 2.80	4.16							1.36	-0.03	-0.03	-51.13	-39.62
5I	A	Elbow 90°	8"	10S	3.76 2.80	4.37							1.57	-0.04	-0.04	-38.71	-43.54
	C				3.76 2.80	4.27							1.47	-0.03	-0.04	-43.35	-41.72
	E				3.76 2.80	4.10							1.30	-0.02	-0.03	-57.50	-38.43
	G				3.76 2.80	4.63							1.83	-0.06	-0.04	-34.53	-47.80
5II	A	Elbow 90°	8"	10S	3.76 2.80	3.69							0.99	0.00	-0.03	-151.20	-29.23

UT Point	Position	Part	Size (inch.)	SCX	Nom. 1-Feb-06 wt.(mm.)	MAT (mm.)	UT date 11-Feb-21 wt.(mm.)	UT date wt.(mm.)	UT date wt.(mm.)	UT date wt.(mm.)	UT date wt.(mm.)	UT date wt.(mm.)	CA (mm.)	SCR (mm/yr.)	ICR (mm/yr.)	SRL (yr.)	LRL (yr.)
	C				3.76	2.80	4.32						1.52	-0.04	-0.04	-40.82	-42.54
	E				3.76	2.80	4.50						1.70	-0.05	-0.04	-34.55	-45.79
	G				3.76	2.80	4.40						1.60	-0.04	-0.04	-37.00	-44.07
5V	A	Elbow 90°	8"	10S	3.76	2.80	4.48						1.68	-0.05	-0.04	-35.09	-45.45
	C				3.76	2.80	4.43						1.63	-0.04	-0.04	-35.59	-44.80
	E				3.76	2.80	4.07						1.27	-0.02	-0.03	-61.51	-37.82
	G				3.76	2.80	4.44						1.64	-0.05	-0.04	-36.27	-44.77
6I	A	Elbow 90°	6"	10S	3.40	2.80	4.54						1.74	-0.08	-0.04	-22.95	-48.46
	C				3.40	2.80	4.49						1.60	-0.07	-0.04	-23.32	-45.62
	E				3.40	2.80	4.29						1.49	-0.06	-0.04	-25.18	-42.10
	G				3.40	2.80	4.35						1.56	-0.06	-0.04	-24.44	-43.37
6II	A	Elbow 90°	6"	10S	3.40	2.80	4.19						1.39	-0.05	-0.03	-28.46	-40.21
	C				3.40	2.80	4.18						1.38	-0.05	-0.03	-25.51	-40.01
	E				3.40	2.80	4.40						1.60	-0.07	-0.04	-24.05	-44.07
	G				3.40	2.80	4.19						1.39	-0.05	-0.03	-26.46	-40.21
6V	A	Elbow 90°	6"	10S	3.40	2.80	3.97						1.17	-0.04	-0.03	-30.87	-36.72
	C				3.40	2.80	4.25						1.45	-0.05	-0.04	-25.65	-41.36
	E				3.40	2.80	3.83						1.03	-0.03	-0.03	-36.02	-32.59
	G				3.40	2.80	4.20						1.40	-0.05	-0.03	-26.32	-40.40
7I	A	Pipe	6"	10S	3.40	2.80	3.66						0.85	-0.02	-0.03	-49.74	-38.48
	C				3.40	2.80	4.00						1.20	-0.04	-0.03	-30.08	-36.36
	E				3.40	2.80	4.06						1.26	-0.04	-0.03	-28.71	-37.51
	G				3.40	2.80	4.07						1.27	-0.04	-0.03	-28.51	-37.82
8I	A	Elbow 90°	6"	10S	3.40	2.80	3.90						1.10	-0.03	-0.03	-33.08	-34.18
	C				3.40	2.80	4.22						1.42	-0.05	-0.03	-26.04	-40.78
	E				3.40	2.80	3.87						1.07	-0.03	-0.03	-34.24	-33.51
	G				3.40	2.80	4.39						1.59	-0.07	-0.04	-24.15	-43.90
8II	A	Elbow 90°	6"	10S	3.40	2.80	3.83						1.13	-0.04	-0.03	-32.06	-34.85
	C				3.40	2.80	3.67						1.07	-0.03	-0.03	-34.24	-33.51
	E				3.40	2.80	4.37						1.57	-0.06	-0.04	-24.34	-43.54
	G				3.40	2.80	4.26						1.46	-0.05	-0.04	-26.53	-41.54

[illegible]



INSPECTION REPORT

FOR

PTT GLOBAL CHEMICAL

Line No.

8-MEG-2010-E1P0

Inspection By : PAE TECHNICAL SERVICE PUBLIC CO., LTD.
Work Order No. : -
Location : -
Report No. : PAE-UTM-PTT GC7-001/2021
Inspection Date : February 11, 2021
Issue Report Date : March 31, 2021

Item	Description	Total Page
1	Piping Inspection Result	1
2	P&ID	-
3	ISO Drawing	-
4	Checklist	1
5	Thickness Measurement Report	5
6	Picture Report	2



Piping Inspection Result

Report No.

PAE-UTM-PTT GC7-001/2021

Page: 1 of 1

Client Name : PTT GLOBAL CHEMICAL Line no. : 8-MEG-2010-B1P0 Fluid : -
Area/Location : P&ID No. : Inspection Date : 11 February 2021
Acceptance Standard : ASME B31.3 / API 570 ☐ Before used ☐ After used

เหตุผลการตรวจสอบ☒ ตรวจสอบตามแผนการซ่อมบำรุง☐ ขยายผลห้วงเสียหาย☐ CONFIRM การใช้งาน☐ CUI Corrosion Program**Summary :**

ได้ดำเนินการตรวจสอบ Pipe Line No. 8-MEG-2010-B1P0 ตาม Work order no. -
โดยมีการตรวจสอบ ด้วยวิธี Visual Inspection (VT) การตรวจสอบสภาพภายนอกด้วยสายตา เพื่อตรวจสอบและตรวจ
สอบความหนา (UTM) โดยผลการตรวจสอบ มีรายละเอียดดังนี้

Inspection Result :

Item	Picture	Result	Recommendation	Remark
AE	AEI	สภาพทั่วไปปกติ	N/A	

NDE :

- Visual Inspection (VT) :
- Ultrasonic Thickness Measurement (UTM) :

Recommendation :



EXTERNAL INSPECTION CHECKLIST FOR PIPING INSPECTION

Report No.
PAE-UTM-PTT GC7-001/2021
Page : 1 of 1

Client Name : PTT GLOBAL CHEMICAL Line no. : 8-MEG-2010-E1P0 Fluid : -
Area/Location : - P&ID No. : - Inspection Date : 11 February 2021
Acceptance Standard : ASME B31.3 / API 570 ☐ Before used ☐ After used

PART	CONDITION
A. Pressure Containment	
1 Pipe and fitting (Pipe, Elbow, Reducer)	<input type="checkbox"/> N/A <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Abnormal _____
2 Flange connection (Flange, Gasket, Bolt&Nut)	<input type="checkbox"/> N/A <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Abnormal _____
3 Nozzle Connection (Vent, Drain, Pressure Indicator, Temp. Indicator)	<input type="checkbox"/> N/A <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Abnormal _____
4 Branch Connection Point (T-Joint Welded or Threaded)	<input type="checkbox"/> N/A <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Abnormal _____
5 Valves (Valve Flanged, Valve Welded, Valve Threaded)	<input type="checkbox"/> N/A <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Abnormal _____
6 Steam Tracing / Electric Heat Tracing	<input type="checkbox"/> N/A <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Abnormal _____
7 Existing Temporary Stop Leak (Clamping, Wrapping, Patching)	<input checked="" type="checkbox"/> N/A <input type="checkbox"/> Normal <input type="checkbox"/> Abnormal _____
B. Support	
1 Pipe support (Pipe shoe, Brace Clamp, U Bolt, Guide, Leg)	<input type="checkbox"/> N/A <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Abnormal _____
2 Support Structure (Beam)	<input type="checkbox"/> N/A <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Abnormal _____
3 Spring Support (Standing / Hanging)	<input checked="" type="checkbox"/> N/A <input type="checkbox"/> Normal <input type="checkbox"/> Abnormal _____
C. Insulation	
1 Cladding	<input checked="" type="checkbox"/> N/A <input type="checkbox"/> Normal <input type="checkbox"/> Abnormal _____
2 Insulation	<input checked="" type="checkbox"/> N/A <input type="checkbox"/> Normal <input type="checkbox"/> Abnormal _____
3 Sealing (Plastic Plug, Screw, Silicone Sealant)	<input checked="" type="checkbox"/> N/A <input type="checkbox"/> Normal <input type="checkbox"/> Abnormal _____
4 Insulation support	<input checked="" type="checkbox"/> N/A <input type="checkbox"/> Normal <input type="checkbox"/> Abnormal _____
NDE	
1 Thickness Measurement	<input type="checkbox"/> N/A <input checked="" type="checkbox"/> Accept <input type="checkbox"/> Not Accept _____
2 Liquid Penetrant Testing	<input checked="" type="checkbox"/> N/A <input type="checkbox"/> Accept <input type="checkbox"/> Not Accept _____
3 Other _____	<input checked="" type="checkbox"/> N/A <input type="checkbox"/> Accept <input type="checkbox"/> Not Accept _____















Note :










Picture Report

Report No.

PAE-UTM-PTT GC7-001/2021

Page : 1 of 2

Description	Picture	Description	Picture
Picture No. 1 Rack No. :- Description : ไม่พบความเสียหาย		Picture No. 2 Rack No. :- Description : ไม่พบความเสียหาย	
Picture No. 3 Rack No. :068 Description : ไม่พบความเสียหาย		Picture No. 4 Rack No. :089 Description : ไม่พบความเสียหาย	
Picture No. 5 Rack No. :11-BX-1 Description : ไม่พบความเสียหาย		Picture No. 6 Rack No. :179 Description : ไม่พบความเสียหาย	
Picture No. 7 Rack No. :191 Description : ไม่พบความเสียหาย		Picture No. 8 Rack No. :PD-BX-1 Description : ไม่พบความเสียหาย	
Picture No. 9 Rack No. :PD-01 Description : ไม่พบความเสียหาย		Picture No. 10 Rack No. :E03-237 Description : ไม่พบความเสียหาย	
Picture No. 11 Rack No. :E03-201 Description : ไม่พบความเสียหาย		Picture No. 12 Rack No. : E03-196 Description : ไม่พบความเสียหาย	
Picture No. 13 Rack No. :E03-173 Description : ไม่พบความเสียหาย		Picture No. 14 Rack No. :E03-166 Description : ไม่พบความเสียหาย	

		<h1>Picture Report</h1>		Report No. PAE-UTM-PTT GC7-001/2021	
				Page : 2 of 2	
Description Picture No. 15 Rack No. : E3-BX-1 Description : ไม่พบความเสียหาย		Description Picture No. 16 Rack No. : E03-100 Description : ไม่พบความเสียหาย			
Description Picture No. 17 Rack No. : E03-91 Description : ไม่พบความเสียหาย		Description Picture No. 18 Rack No. : E03-061 Description : ไม่พบความเสียหาย			
Description Picture No. 19 Rack No. : E03-054 Description : ไม่พบความเสียหาย		Description Picture No. 20 Rack No. : E03-009 Description : ไม่พบความเสียหาย			
Description Picture No. 21 Rack No. : E03-004 Description : ไม่พบความเสียหาย		Description Picture No. 22 Rack No. : E03-001 Description : ไม่พบความเสียหาย			

Severity Levels

Damage Mode	Damage Mechanism	Severity Level	Description	Recommendation	Condition	Int/Ext	Repair Interval
Thinning	Corrosion (Localized, General etc.), Erosion, pitting, CUI, Mechanical damage: wall loss, Scrub	Low	Leak	Stop leak, Repair or Replace	AE	AE	Immediately
			T < T _{min}	Strengthening, Repair or Replace	SD	AE	Immediately
			RL < 5 Yrs	Strengthening, Repair or Replace	SD	AE	Immediately
			RL > 5 Yrs and T _{min} < T < T _{allow}	Painting	AE	External	Within 1 Month
				Monitoring (Repair or Replace if)	AE	External	Half life
			Depth > 0.5 mm. and T > T _{allow}	Painting	AE	External	Within 4 Months
Thinning Tube HE	Corrosion (Localized, General etc.), Erosion, pitting, CUI, Mechanical damage: wall loss, Scrub	High	Wall Loss > 40% or Retain thickness < 60%	Re-Tube, plug	AE	AE	Immediately
		Medium	Wall Loss 30% - 40%	Re-Tube, plug, Monitoring	AE	AE	Within 5 Year
		Low	Wall Loss 10% - 30%	Monitoring	AE	AE	Within 5 Year
		Very Low	Wall Loss 10% - 20%	Monitoring	AE	AE	Within 10 Year
Halter Crab Creep	Bulging, sagging	High	more than 5 tube diameters	Replace		N/A	Immediately
		Medium	between 3-5 Tube diameters	More Section Test, MAG Evaluation		N/A	Immediately
		Low	less than 3 Tube diameters	Monitoring	AE	N/A	Within 5 Year
		Very Low	more than 5% growth	Replace		N/A	Immediately
		Very Low	between 3-5% growth	More Section Test, MAG Evaluation		N/A	Immediately
		Very Low	less than 3% growth	Monitoring		N/A	Within 5 Year
Cracking	Cracking	High	Crack depth > 0.5 mm	Stop Leak or Repair	AE	AE	Immediately
		Medium	Crack depth > 0.5 mm	Stop Leak or Repair	AE	AE	Immediately
		Low	Crack depth > 0.5 mm	Stop Leak or Repair	AE	AE	Immediately
Painting Deteriorate	Painting Deteriorate	High	Painting Deteriorate	Repaint	AE	AE	Within 1 Year
		Medium	Painting Deteriorate	Repaint	AE	AE	Within 1 Year
		Low	Painting Deteriorate	Repaint	AE	AE	Within 1 Year
Painting Deteriorate	Painting Deteriorate	High	Painting Deteriorate	Repaint	AE	AE	Within 1 Year
		Medium	Painting Deteriorate	Repaint	AE	AE	Within 1 Year
		Low	Painting Deteriorate	Repaint	AE	AE	Within 1 Year
		Very Low	Painting Deteriorate	Repaint	AE	AE	Within 1 Year
		Very Low	Painting Deteriorate	Repaint	AE	AE	Within 1 Year
		Very Low	Painting Deteriorate	Repaint	AE	AE	Within 1 Year
Insulation Damage	Insulation Damage	High	Insulation Damage	Replace	AE	AE	Within 1 Year
		Medium	Insulation Damage	Replace	AE	AE	Within 1 Year
		Low	Insulation Damage	Replace	AE	AE	Within 1 Year
		Very Low	Insulation Damage	Replace	AE	AE	Within 1 Year
		Very Low	Insulation Damage	Replace	AE	AE	Within 1 Year
		Very Low	Insulation Damage	Replace	AE	AE	Within 1 Year
Leak	Leak	High	Leak	Replace/Repair	AE	AE	Immediately
		Medium	Leak	Replace/Repair	AE	AE	Immediately
Crack	Crack	High	Crack	Replace/Repair	AE	AE	Immediately
		Medium	Crack	Replace/Repair	AE	AE	Immediately

* Note:

(1) ขึ้นอยู่กับระดับความเสียหาย และระดับของ การใช้งาน และวิธีการดูแลของ Inspector

(2) Replace Insulation คือการเปลี่ยนวัสดุฉนวนเดิมด้วยวัสดุใหม่ที่มีความเหมาะสมกับการใช้งานเดิม หรือการเปลี่ยนวัสดุฉนวนเดิมด้วยวัสดุใหม่ที่มีความเหมาะสมกับการใช้งานเดิม

Remark: Repair Painting หมายถึงการซ่อมแซมการทาสีเดิมด้วยสีใหม่ที่มีความเหมาะสมกับการใช้งานเดิม

➤ 34ข

เอกสารตัวอย่างการตรวจสอบการรั่วไหลของ
สารเคมีและการตรวจสอบการรั่วไหลของท่อ



รายงานการตรวจสอบการรั่วไหลของท่อ

ประจำเดือน มกราคม พ.ศ. 2566 ครั้งที่ 1

ระหว่าง BIF-Jetty 1 (Girder 01-124)

ลำดับที่	รายการท่อโครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	Ethylene	✓		
2	Propylene	✓		
3	Butene-1	✓		
4	VCM	✓		
5	EDC	✓		
6	Mix C4	✓		
7	MEG	✓		
8	Methanol	✓		
9	Pipe Bridge	✓		

ระหว่าง Jetty 1 – Jetty 2 (Girder 01-18)

ลำดับที่	รายการท่อโครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	VCM	✓		
2	EDC	✓		
3	MEG	✓		
4	Methanol	✓		
5	Pipe Bridge	✓		

รายงานการตรวจสอบการรั่วไหลของท่อ

ประจำเดือน มกราคม พ.ศ. 2566 ครั้งที่ 2

ระหว่าง BTF – Jetty 1 (Girder 01-124)

ลำดับที่	รายการท่อโครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	Ethylene	✓		
2	Propylene	✓		
3	Butene-1	✓		
4	VCM	✓		
5	EDC	✓		
6	Mix C4	✓		
7	MEG	✓		
8	Methanol	✓		
9	Pipe Bridge	✓		

ระหว่าง Jetty 1 – Jetty 2 (Girder 01-18)

ลำดับที่	รายการท่อโครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	VCM	✓		
2	EDC	✓		
3	MEG	✓		
4	Methanol	✓		
5	Pipe Bridge	✓		

รายงานการตรวจสอบการรั่วไหลของท่อ

ประจำเดือน... กุมภาพันธ์... พ.ศ. 2565... ครั้งที่... 1...

ระพ่วง BTF - Jetty 1 (Girder 01-124)

ลำดับที่	รายการท่อโครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	Ethylene	✓		
2	Propylene	✓		
3	Butene-1	✓		
4	VCM	✓		
5	EDC	✓		
6	Mix C4	✓		
7	MEG	✓		
8	Methanol	✓		
9	Pipe Bridge	✓		

รายงานการตรวจสอบการรั่วไหลของท่อ

ประจำเดือน... กุมภาพันธ์... พ.ศ. 2566... ครั้งที่... 2...

ระพ่วง BTF - Jetty 1 (Girder 01-124)

ลำดับที่	รายการท่อโครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	Ethylene	✓		
2	Propylene	✓		
3	Butene-1	✓		
4	VCM	✓		
5	EDC	✓		
6	Mix C4	✓		
7	MEG	✓		
8	Methanol	✓		
9	Pipe Bridge	✓		

ระพ่วง Jetty 1 - Jetty 2 (Girder 01-18)

ลำดับที่	รายการท่อโครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	VCM	✓		
2	EDC	✓		
3	MEG	✓		
4	Methanol	✓		
5	Pipe Bridge	✓		

ระพ่วง Jetty 1 - Jetty 2 (Girder 01-18)

ลำดับที่	รายการท่อโครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	VCM	✓		
2	EDC	✓		
3	MEG	✓		
4	Methanol	✓		
5	Pipe Bridge	✓		

รายงานการตรวจสอบการรั่วไหลของท่อ

ประจำเดือน...พ.ศ. 2566...ครั้งที่ 1...

ระหว่าง BTF -Jetty 1 (Girder 01-124)

ลำดับที่	รายการท่อโครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	Ethylene	✓		
2	Propylene	✓		
3	Butene-1	✓		
4	VCM	✓		
5	EDC	✓		
6	Mix C4	✓		
7	MEG	✓		
8	Methanol	✓		
9	Pipe Bridge	✓		

ระหว่าง Jetty 1-Jetty 2 (Girder 01-18)

ลำดับที่	รายการท่อโครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	VCM	✓		
2	EDC	✓		
3	MEG	✓		
4	Methanol	✓		
5	Pipe Bridge	✓		

รายงานการตรวจสอบการรั่วไหลของท่อ

ประจำเดือน...พ.ศ. 2566...ครั้งที่ 2...

ระหว่าง BTF -Jetty 1 (Girder 01-124)

ลำดับที่	รายการท่อโครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	Ethylene	✓		
2	Propylene	✓		
3	Butene-1	✓		
4	VCM	✓		
5	EDC	✓		
6	Mix C4	✓		
7	MEG	✓		
8	Methanol	✓		
9	Pipe Bridge	✓		

ระหว่าง Jetty 1 -Jetty 2 (Girder 01-18)

ลำดับที่	รายการท่อโครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	VCM	✓		
2	EDC	✓		
3	MFG	✓		
4	Methanol	✓		
5	Pipe Bridge	✓		

รายงานการตรวจสอบการรั่วไหลของท่อ

ประจำเดือน เมษายน พ.ศ. 2565...ครั้งที่...1

ระหว่ง BTF-Jetty 1 (Girder 01-124)

ลำดับที่	รายการท่อโครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	Ethylene	✓		
2	Propylene	✓		
3	Butene-1	✓		
4	VCM	✓		
5	EDC	✓		
6	Mix C4	✓		
7	MEG	✓		
8	Methanol	✓		
9	Pipe Bridge	✓		

ระหว่ง Jetty 1 – Jetty 2 (Girder 01-18)

ลำดับที่	รายการท่อโครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	VCM	✓		
2	EDC	✓		
3	MEG	✓		
4	Methanol	✓		
5	Pipe Bridge	✓		

รายงานการตรวจสอบการรั่วไหลของท่อ

ประจำเดือน เมษายน พ.ศ. 2565...ครั้งที่...2

ระหว่ง BTF - Jetty 1 (Girder 01-124)

ลำดับที่	รายการท่อโครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	Ethylene	✓		
2	Propylene	✓		
3	Butene-1	✓		
4	VCM	✓		
5	EDC	✓		
6	Mix C4	✓		
7	MEG	✓		
8	Methanol	✓		
9	Pipe Bridge	✓		

ระหว่ง Jetty 1 – Jetty 2 (Girder 01-18)

ลำดับที่	รายการท่อโครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	VCM	✓		
2	EDC	✓		
3	MEG	✓		
4	Methanol	✓		
5	Pipe Bridge	✓		

รายงานการตรวจสอบการรั่วไหลของท่อ

ประจำเดือน พฤษภาคม พ.ศ. 2566...ครั้งที่ 1

ระหว่าง BTF - Jetty 1 (Girder 01-124)

ลำดับที่	รายการพบโครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	Ethylene	✓		
2	Propylene	✓		
3	Butene-1	✓		
4	VCN	✓		
5	EDC	✓		
6	Mix C4	✓		
7	MEG	✓		
8	Methanol	✓		
9	Pipe Bridge	✓		

ระหว่าง Jetty 1 -Jetty 2 (Girder 01-18)

ลำดับที่	รายการพบโครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	VCN	✓		
2	EDC	✓		
3	MEG	✓		
4	Methanol	✓		
5	Pipe Bridge	✓		

รายงานการตรวจสอบการรั่วไหลของท่อ

ประจำเดือน พฤษภาคม พ.ศ. 2566...ครั้งที่ 2

ระหว่าง BTF - Jetty 1 (Girder 01-124)

ลำดับที่	รายการพบโครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	Ethylene	✓		
2	Propylene	✓		
3	Butene-1	✓		
4	VCN	✓		
5	EDC	✓		
6	Mix C4	✓		
7	MEG	✓		
8	Methanol	✓		
9	Pipe Bridge	✓		

ระหว่าง Jetty 1 -Jetty 2 (Girder 01-18)

ลำดับที่	รายการพบโครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	VCN	✓		
2	EDC	✓		
3	MEG	✓		
4	Methanol	✓		
5	Pipe Bridge	✓		

รายงานการตรวจสอบการรั่วไหลของท่อ

ประจำเดือน มิถุนายน พ.ศ. 2566 ครั้งที่ 1

ระหว่าง BTF-Jetty 1 (Girder 01-124)

ลำดับที่	รายการท่อ/โครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	Ethylene	✓		
2	Propylene	✓		
3	Butene-1	✓		
4	VCM	✓		
5	EDC	✓		
6	Mix C4	✓		
7	MEG	✓		
8	Methanol	✓		
9	Pipe Bridge	✓		

รายงานการตรวจสอบการรั่วไหลของท่อ

ประจำเดือน มิถุนายน พ.ศ. 2566 ครั้งที่ 2

ระหว่าง BTF-Jetty 1 (Girder 01-124)

ลำดับที่	รายการท่อ/โครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	Ethylene	✓		
2	Propylene	✓		
3	Butene-1	✓		
4	VCM	✓		
5	EDC	✓		
6	Mix C4	✓		
7	MEG	✓		
8	Methanol	✓		
9	Pipe Bridge	✓		

ระหว่าง Jetty 1 – Jetty 2 (Girder 01-18)

ลำดับที่	รายการท่อ/โครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	VCM	✓		
2	EDC	✓		
3	MEG	✓		
4	Methanol	✓		
5	Pipe Bridge	✓		

ระหว่าง Jetty 1 – Jetty 2 (Girder 01-18)

ลำดับที่	รายการท่อ/โครงสร้างที่ตรวจ	ผลการตรวจสอบ		หมายเหตุ
		ปกติ	ผิดปกติ	
1	VCM	✓		
2	EDC	✓		
3	MEG	✓		
4	Methanol	✓		
5	Pipe Bridge	✓		



บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)

Aromatics/Olefins Movement Operation

W-(U-CM-OP)-INTP-001

การตรวจสอบแนวท่อผลิตภัณฑ์ภายนอก

จัดทำโดย :

อนุมัติโดย :



รายชื่อผู้ทบทวน

ผู้ทบทวน	ตำแหน่ง	หน่วยงาน

รายการแก้ไข

ครั้งที่	วันที่มีผลบังคับใช้	รายละเอียด	โดย
0	22/02/2020	Migrated (นำเข้าโดยระบบ)	
1	19/05/2021	ขอเพิ่มรายละเอียดการทำงาน	
2	14/07/2021	ขอปรับปรุงเอกสาร	
3	19/07/2021	แก้ไขเนื้อหา	
3	31/03/2023	ทบทวนโดยไม่แก้ไข/ Review without change :	

หน่วยงานที่เกี่ยวข้อง

รหัสหน่วยงาน	ชื่อหน่วยงาน
U-CM-OP	Aromatics/Olefins Movement Operation

KPI ที่เกี่ยวข้อง

KPI Measure	Description / Calculation	Target (unit)

กฎหมายที่เกี่ยวข้อง

ชื่อกฎหมาย

เอกสารที่เกี่ยวข้องในระบบ

รหัสเอกสาร	ชื่อเอกสาร
W-(U-CM-OP)-INTP-001	การตรวจสอบแนวท่อผลิตภัณฑ์ภายนอก

เอกสารอ้างอิงภายนอก

ชื่อเอกสาร
แผนที่ขอบเขตการตรวจแนวท่อทั้งในและนอกนิคมบาตาหุด

Internal Use Only



บริษัท พีทีที โกลบอล เคมิคอล
จำกัด (มหาชน)

W-(U-CM-OP)-INTP-001: การตรวจสอบแนว
ท่อผลิตภัณฑ์ภายนอก

สารบัญ

หน้า

1.	วัตถุประสงค์.....	1
2.	ขอบเขต	2
3.	หน้าที่และความรับผิดชอบ	3
4.	WORKFLOW.....	4
5.	รายละเอียดการดำเนินงาน	5
6.	ภาคผนวก.....	7

ประกาศใช้ครั้งที่ 3

วันที่มีผลบังคับใช้ : 19/07/2021

เอกสารฉบับนี้เป็นความลับ และการรณสิทธิ์ทางกฎหมายเพื่อใช้ภายในกลุ่มบริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน) และบริษัทในเครือเท่านั้น ห้ามเผยแพร่ ทำซ้ำ
ดัดแปลง ส่งต่อ เผยแพร่งาน. เมื่อได้รับความลับ.ให้กับบุคคลอื่นโดยมิได้รับอนุญาต



1. วัตถุประสงค์

- 1.1 เพื่อตรวจสอบแนวท่อรับส่งผลิตภัณฑ์ที่อยู่บนดิน (Above Ground) และฝังอยู่ใต้ดิน (Under Ground) ซึ่งเชื่อมต่อระหว่าง บริษัท พีทีที โกลบอล เซเมนต์ จำกัด (มหาชน) ไปสู่ ลูกค้า ภายในกลุ่ม GC และลูกค้าภายนอกกลุ่ม GC ที่ติดตั้งอยู่บริเวณนอกโรงงาน ที่อาจได้รับความเสียหายจากการขุดหรือเผาหญ้าบริเวณแนวท่อหรือกระทำการใดๆที่มีผลกระทบกับแนวท่อ อุปกรณ์ ป้ายเตือน
- 1.2 ปฏิบัติตามสำนักนโยบายและแผนทรัพยากรธรรมชาติและสิ่งแวดล้อม
- 1.3 ปฏิบัติตามประกาศกระทรวงอุตสาหกรรม กระทรวงพลังงาน กรมธุรกิจพลังงาน

Internal Use



2. ขอบเขต

- 2.1 ใช้ในการตรวจสอบแนวท่อรับส่งผลิตภัณฑ์ของพนักงานสังกัด U-CM-OP ซึ่งแบ่งออกได้ดังนี้
- 2.1.1 ตรวจสอบแนวท่อรับส่งผลิตภัณฑ์จากบริษัท โกลบอล เคมิคอล จำกัด (มหาชน) ถึงลูกค้านอกกลุ่ม GC และลูกค้านอกกลุ่ม GC บริเวณนิคมมาบตาพุดควบคู่กับบริษัท EFT
 - 2.1.2 ตรวจสอบแนวท่อรับส่งผลิตภัณฑ์จากบริษัท โกลบอล เคมิคอล จำกัด (มหาชน) ลูกค้านอกกลุ่ม GC และลูกค้านอกกลุ่ม GC บริเวณนิคม-RIL นิคมมาบตาพุดควบคู่กับบริษัท RPL
 - 2.1.3 ตรวจสอบแนวท่อส่งผลิตภัณฑ์จากบริษัทภายนอกนิคมมาบตาพุดจากนิคมมาบตาพุดถึงบริษัท IRPC จำนวนสองผลิตภัณฑ์ (Line 4 inch , Line 8 inch) ตามแนวนอนสาย 36 ระยะทางประมาณ 33 ก.ม.



3. หน้าที่และความรับผิดชอบ

3.1 หน่วยงาน U-CM-OP

- GPC Interconnecting pipeline and Truck loading มีหน้าที่ ตรวจสอบแนวท่อรับส่งผลิตภัณฑ์ BEC และแจ้งทีมซ่อมบำรุง พร้อมทั้ง ตอบโต้แผนภาวะฉุกเฉิน

3.2 หน่วยงาน U-TM-CM

- GPC Interconnecting pipeline Maintenance มีหน้าที่ ซ่อมบำรุงรักษา สนับสนุนแผนภาวะฉุกเฉิน

3.3 หน่วยงาน T-II-IP

- Team Inspection มีหน้าที่ ตรวจสอบแนวท่อรับส่งผลิตภัณฑ์ ความหนา อายุการใช้งาน ผิวนท่อ อื่นๆ

3.4 หน่วยงาน R-MN-MO


- Civil มีหน้าที่ ซ่อมบำรุงท่อ โครงสร้าง Pipe rack ขุดดิน
- Scaffolding มีหน้าที่ ติดตั้งนั่งร้าน

3.5 หน่วยงาน Q-SH-CM

- มีหน้าที่ ทีมตอบโต้แผนภาวะฉุกเฉิน



4. WORKFLOW





5. รายละเอียดการดำเนินงาน

5.1 แนวทางการปฏิบัติงานของผู้ตรวจแนวท่อ

- 5.1.1 ติดต่อประสานงานผู้ดูแลพื้นที่
- 5.1.2 ตรวจสอบแนวท่อรับส่งผลิตภัณฑ์ด้วยสายตา เช่น ผิวท่อ, อุปกรณ์ที่ติดกับท่อรับส่งผลิตภัณฑ์, โครงสร้าง, Pipe rack, ป้าย Warning sign, Vent sleeve lapping เป็นต้น
- 5.1.3 ตรวจสอบจุด Vent , Dain , Flange ด้วย Snoop และ Gas detector
- 5.1.4 เมื่อพบผู้ปฏิบัติงานทำงานใกล้กับแนวท่อ
 - 5.1.4.1 เข้าพูดคุยกับผู้ปฏิบัติงาน เพื่อทราบว่าทำงานอะไร บริษัทอะไร ระยะเวลาที่ทำ
- 5.1.5 ออก Request MN เมื่อพบสิ่งผิดปกติกับแนวท่อ
- 5.1.6 ขออนุญาต กนอ. EFT แขวงการทาง หน่วยงานที่เกี่ยวข้อง เพื่อเข้าทำงานในพื้นที่
- 5.1.7 Empty pipeline เพื่อทำการซ่อมบำรุงหรืองานก่อสร้างเพิ่มเติม จะต้องมีการต่อท่อ Hard pipe to flare และมีการป้องกันผลกระทบที่จะเกิดต่อสิ่งแวดล้อมภายนอก อาทิเช่น กลิ่น , เสียง , การปนเปื้อน
- 5.1.8 Commissioning line เมื่อซ่อมเสร็จ

5.2 เส้นทางตรวจสอบแนวท่อ

- 5.2.1 Right of Way Rack PTT-09(หลัง PTT) ถึง PTT-07(ริมคลองซากหมาก)
- 5.2.2 Right of Way Rack PTT-06(ริมคลองซากหมาก) ถึง PTT-05(หลัง TOT)
- 5.2.3 Right of Way Rack PTT-04(หลัง TOT) ถึง PTT-03(ข้าง TPE)
- 5.2.4 Right of Way Rack PTT-02(ข้าง TPE) ถึง PTT-01(ข้าง TPAC)
- 5.2.5 Rack เหมราช E03-BX-1(หลัง PDH/TOL) ถึง TOCGC(ถนน 3092)
- 5.2.6 Rack เหมราช G2-BX-1 ถึง G2-BX-3 ถนน G2 นิคมเหมราช
- 5.2.7 Rack R-1 road (ถนนหน้า PTTGC2)
- 5.2.8 I-1 Road
- 5.2.9 I-2 Road
- 5.2.10 I-4 Road
- 5.2.11 Rack RPL(L5) ข้าง PITGC2 & PTTGC3 คลองซากหมาก
- 5.2.12 Corridor Rack ระหว่าง PITGC3 กับ บริษัทวินิจไทย
- 5.2.13 Rack Asia(PTT-BX-3) ตั้งแต่สี่แยกผาแดง ถึง ด้านหลัง PITGC11
- 5.2.14 Rack PTT-01(ข้าง TPAC) ถึง PITGC7
- 5.2.15 Rack I1-BX-3(ถนนด้านหน้า PTTGC7)



บริษัท พีทีที โกลบอล เคมิคอล
จำกัด (มหาชน)

W-(U-CM-OP)-INTP-001: การตรวจสอบแนว
ท่อผลิตภัณฑ์ภายนอก

- 5.2.16 I-8 Road ตั้งแต่บริษัทไทยเซี่ยงกง ถึง I8-BX-21(East Jetty)
- 5.2.17 Underground to IRPC 3191/36 road
- 5.2.18 RPL Pipe rack
- 5.2.19 Block culvert I-17, Block culvert I-4
- 5.3 ในภาวะฉุกเฉิน
 - 5.3.1 กรณีตรวจแนวท่อรับส่งผลิตภัณฑ์ รั่วไหลในปริมาณมาก
 - 5.3.2 เบื้องต้นติดต่อประสานงาน Super visor GPC-Interconnecting pipeline and Truck loading
 - 5.3.3 แจ้งศูนย์ EFT ปิดกั้นพื้นที่
 - 5.3.4 ติดต่อประสานงาน Duty P-T Team เพื่อดูปipeline ได้ภาวะฉุกเฉิน



6. ภาคนว

6.1 คำจำกัดความ

- 6.1.1 ลูก้าภายนอกกลุ่ม GC หมายถึง บริษัทที่ตกลงซื้อขายผลิตภัณฑ์จาก GC เช่น PTT/SCG/BST/VNT ฯลฯ
- 6.1.2 ลูก้าภายในกลุ่ม GC หมายถึง ผู้จัดส่งหรือรับผลิตภัณฑ์ภายในกลุ่ม GC เช่น GC2/GC3/GC4/GC5/GC6/BPE/BTF ฯลฯ
- 6.1.3 แนวท่อรับส่งผลิตภัณฑ์ หมายถึง แนวท่อที่ฝังอยู่ใต้ (Under Ground) และบนพื้นดิน (Above Ground) ซึ่งเชื่อมต่อกันระหว่างบริษัท โกลบอล เคมิคอล จำกัด (มหาชน) ถึงลูก้า ทั้งภายในโดยรอบพื้นที่นิคมมาบตาพุดและภายนอกนิคมมาบตาพุด
- 6.1.4 ป้ายเตือน หมายถึง ป้ายแสดงแนวท่อที่ปักอยู่เหนือแนวท่อโดยมีข้อความระบุนันตรายจากท่อส่งก๊าซที่วางอยู่ใต้ดิน พร้อมเบอร์โทรศัพท์ติดต่อของบริษัท โกลบอล เคมิคอล จำกัด (มหาชน) และหมายเลขแสดงนัมเบอร์ป้าย
- 6.1.5 รถยนต์ตรวจแนวท่อ หมายถึง รถยนต์ที่ใช้ในการตรวจสอบแนวท่อเป็นการเฉพาะ ซึ่งจำเป็นต้องมีอุปกรณ์ต่างๆ เช่น วิทยุสื่อสาร, เชือกกันเขต, Gas Detector, กรวยจราจร, กล้องถ่ายภาพ, ไฟฉาย, กล้องส่องทางไกล
- 6.1.6 ศูนย์บูรพา หมายถึง ศูนย์ควบคุมระบบการรักษาความปลอดภัยและการติดต่อสื่อสารของบริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)
- 6.1.7 ผู้ตรวจแนวท่อ หมายถึง พนักงานในสังกัดของแผนก U-CM-OP ที่ได้รับมอบหมาย
- 6.1.8 ตรวจทุกวันตั้งแต่เวลา 08:00 – 17:00 น. หากไม่สามารถออกตรวจได้ให้แจ้งผู้บังคับบัญชาเพื่อรอรับคำสั่งการปฏิบัติต่อไป

6.2 ข้อมูลสนับสนุน

- 6.2.1 แบบฟอร์มรายการตรวจสอบแนวท่อส่งก๊าซ
- 6.2.2 แผนที่ขอบเขตการตรวจแนวท่อทั้งในและนอกนิคมมาบตาพุด

6.3 แผนการดำเนินงาน

- 6.3.1 ตรวจทุกวันตั้งแต่เวลา 08:00 – 17:00 น. หากไม่สามารถออกตรวจได้ให้แจ้งผู้บังคับบัญชาเพื่อรอรับคำสั่งการปฏิบัติต่อไป

➤ 35ข

เอกสารการรับรองจากวิศวกรออกแบบการก่อสร้างถังเก็บ
1,3 Butadiene และ Multi-purpose ระบบท่อขนส่งต่าง ๆ





ที่ กค ๐๕๐๒(๙)/ ๗๖๗๗

ด้านศุลกากรมาบตาพุด
อ.เมือง จ.ระยอง ๒๑๑๕๐

๖๗ ธันวาคม ๒๕๕๖

เรื่อง ผ่อนผันให้ใช้ถึงและตารางคำนวณปริมาณความจุประจําถึงพร้อมเครื่องวัดระดับและอุณหภูมิอัตโนมัติ
ประจําถึงหมายเลข T-๖๕๘๓-๐๑A , T-๖๕๘๓-๐๑B ซึ่งผ่านการรับรองจากกรมสรรพสามิต

เรียน กรรมการผู้จัดการ บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)

อ้างถึง หนังสือบริษัทที่ C-EX-๕๓๘/๒๕๕๖ ลงวันที่ ๖ ธันวาคม ๒๕๕๖

ตามหนังสือที่อ้างถึง บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน) ขออนุมัติใช้ถึงและ
ตารางคำนวณปริมาณความจุประจําถึงพร้อมเครื่องวัดระดับและอุณหภูมิอัตโนมัติประจําถึงหมายเลข
T-๖๕๘๓-๐๑A และ T-๖๕๘๓-๐๑B ซึ่งผ่านการรับรองจากกรมสรรพสามิต เพื่อตรวจสอบสําคัญผลิตภัณฑ์
ปิโตรเลียมที่ส่งออกต่างประเทศ นั้น

ด้านศุลกากรมาบตาพุด ได้พิจารณาแล้วผอนผันให้บริษัท ใช้ถึงและตารางคำนวณปริมาณ
ความจุประจําถึงพร้อมเครื่องวัดระดับและอุณหภูมิอัตโนมัติประจําถึงหมายเลข T-๖๕๘๓-๐๑A และ
T-๖๕๘๓-๐๑B ซึ่งผ่านการรับรองจากกรมสรรพสามิต เพื่อตรวจสอบสําคัญผลิตภัณฑ์ปิโตรเลียมต่างประเทศได้
ตามระยะเวลาที่กรมสรรพสามิตได้อนุมัติ จนถึงวันที่ ๒๖ กันยายน ๒๕๖๑

ทั้งนี้ให้บริษัท ปฏิบัติตามประกาศกรมศุลกากรที่ ๖๓/๒๕๕๓ เรื่องการอนุมัติผอนผันใช้ถึงและ
ตารางคำนวณปริมาณความจุประจําถึงที่กรมสรรพสามิตรับรองสำหรับการนำเข้าและส่งออก โดยเคร่งครัด

จึงเรียนมาเพื่อทราบ

ขอแสดงความนับถือ



นายด้านศุลกากรมาบตาพุด

ด้านศุลกากรมาบตาพุด

โทร.๐-๓๘๖๘-๓๓๗๐ ต่อ ๕๑๑๕

โทรสาร.๐-๓๘๖๘-๓๓๖๙

EASTERN FLUID TRANSPORT CO.,LTD.

บริษัท อีสเทิร์น ฟลูอิด ทรานสปอร์ต จำกัด

2 ถนนเมืองใหม่มาบตาพุดสาย 6 ตำบลห้วยโป่ง อำเภอเมืองระยอง จังหวัดระยอง 21150

โทรศัพท์ (038) 687513-4 โทรสาร (038) 687512

ที่ EFT-161/2561



2 ตุลาคม 2561

เรื่อง ขอมติก่อสร้างวางท่อเชื่อมถังผลิตแก๊สของ GC บน PIPERACK GLOW

เรียน



ผู้จัดการฝ่ายหน่วยงานบริหารโครงการของโรงงาน

บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน) (GC)

อ้างถึง หนังสือของบริษัท GC เลขที่ 22-TP-PP-005/2561 ลงวันที่ 5 กันยายน 2561

สิ่งที่ส่งมาด้วย หนังสือของบริษัท GLOW เลขที่ G-MSG-L-18/013 ลงวันที่ 1 ตุลาคม 2561

ความหนังสือที่อ้างถึงบริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน) (GC) ได้ส่งมอบนิทรวรรมมาให้ บริษัท อีสเทิร์น ฟลูอิด ทรานสปอร์ต จำกัด (EFT) เพื่อพิจารณาและประสานงานกับเจ้าของโครงสร้างสำหรับวางท่อ ความละเอียดเชิงแล้วนั้น

บัดนี้ บริษัท โกลว์ ผลิตงาน จำกัด (มหาชน) (GLOW) ในฐานะเจ้าของโครงสร้างสำหรับวางท่อได้เห็นชอบในรูปแบบการก่อสร้างและให้ GC สามารถดำเนินการก่อสร้างวางท่อเชื่อมถังผลิตแก๊สตามแบบที่ขออนุมัติมาได้ รายละเอียดความสิ่งที่ส่งมาด้วย

ในการนี้ EFT ได้พิจารณารายละเอียดแบบก่อสร้างของ GC เรียบร้อยแล้ว ขอเรียนให้ทราบว่าเป็นไปตามมาตรฐานทางวิศวกรรม สามารถดำเนินการก่อสร้างตามรูปแบบดังกล่าวได้ โดยขณะที่ยังดำเนินการก่อสร้าง และหรือภายหลังการก่อสร้าง หากทาง EFT มีความจำเป็นที่จะต้องขอให้ GC ทำการปรับปรุง และ/หรือ ทำการแก้ไขเพิ่มเติมจากแบบที่ได้เสนอมาดังกล่าว ทาง GC จะต้องดำเนินการปรับปรุง และ/หรือ ทำการแก้ไขตามที่ EFT ได้แจ้งไว้

ทั้งนี้ ขอให้ GC ประสานงานกับเจ้าหน้าที่ของ EFT เพื่อชี้แจงรายละเอียดงานและรับทราบมาตรการด้านความปลอดภัย ก่อนที่จะเข้าพื้นที่ทำงานต่อไป

ในการนี้ มีข้อสงสัยหรือต้องการข้อมูลใด ๆ เพิ่มเติมกรุณาติดต่อคุณกนกพงศ์ พิมเสน (ผู้จัดการโครงการ) เบอร์โทรศัพท์ 038 687 513-4 ต่อ 23

จึงเรียนมาเพื่อทราบและโปรดดำเนินการ

ขอแสดงความนับถือ



ผู้จัดการทั่วไป

สำเนาเรียน : ผู้อำนวยการสำนักงานนิคมอุตสาหกรรมมาบตาพุด

คุณเรณิดา จินายน GC



บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)
สำนักงานใหญ่ เลขที่ 555 หมู่ 5 ตำบลคลองเตย อำเภอบางพลี จังหวัดสมุทรปราการ 10540 โทรศัพท์ 02-010-5555 โทรสาร 02-010-5556
สำนักงานเขต เลขที่ 15 หมู่ 5 ตำบลคลองเตย อำเภอบางพลี จังหวัดสมุทรปราการ 10540 โทรศัพท์ 02-010-5555 โทรสาร 02-010-5556
เว็บไซต์ www.pttc.co.th

ที่ 22-TP-PP-005/2561

5 กันยายน 2561

หนังสือที่อ้างถึง " "

เรื่อง ขออนุญาตก่อสร้างวางท่อเพื่อขนส่งผลิตภัณฑ์ของบริษัท GC ไปน PIPERACK

เรียน



ผู้จัดการทั่วไป

บริษัท อีสเทิร์น ฟู้ดส์ ทราเวล คอร์ปอเรชั่น จำกัด (EFT)

อ้างถึง หนังสือขออนุมัติหลักการของบริษัท EFT เลขที่ EFT-107/2561 ลงวันที่ 11 กรกฎาคม 2561

สิ่งที่ส่งมาด้วย 1. แบบสำหรับการก่อสร้างวางท่อขนส่งผลิตภัณฑ์ (IFC) ขนาด A3 จำนวน 2 ชุด

2. รายการคำนวณโครงสร้างวางท่อ (IFC) ขนาด A4 จำนวน 2 ชุด

ตามหนังสือที่อ้างถึง บริษัท อีสเทิร์น ฟู้ดส์ ทราเวล คอร์ปอเรชั่น จำกัด (EFT) ได้ขอหนังสือขออนุมัติในหลักการก่อสร้างวางท่อผลิตภัณฑ์ให้กับบริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน) (PTTGC) จำนวน 1 เส้น มีกำหนดการก่อสร้างจะเริ่มวันที่ 20 กันยายน 2561 และจะแล้วเสร็จวันที่ 31 มีนาคม 2562 มีรายละเอียดต่างๆของผลิตภัณฑ์ ดังนี้

ITEM	DIAMETER (Inch)	INSULATION (mm.)	CONTAINED	FROM	TO
1	3	-	Methanol	PTTGC 7	P.R PTTGC I-1 road

บัดนี้ บริษัทฯ ได้ให้การออกแบบด้านวิศวกรรมเสร็จเป็นที่ยอมรับแล้ว จึงใคร่ขอความอนุเคราะห์จาก EFT ในการประสานงานกับทางช่างของโครงการวางท่อที่เกี่ยวข้อง เพื่อพิจารณาอนุมัติให้บริษัทฯ ดำเนินการก่อสร้างวางท่อขนส่งผลิตภัณฑ์ดังกล่าว รายละเอียดตามสิ่งที่ส่งมาด้วย

ทั้งนี้ บริษัทฯ ได้ขอความอนุเคราะห์ให้บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน) เป็นตัวดำเนินการประสานงานกับโครงการนี้ ในกรณีที่มีข้อสงสัยหรือต้องการทราบข้อมูลเพิ่มเติมเกี่ยวกับโครงการเพิ่มเติม สามารถติดต่อคุณ วราภรณ์ วงศ์ศักดิ์ดำรง เบอร์โทร 089-827-7692 หรือคุณนันทพร ต่อมนจันทร์ โทร 091-719-5359

จึงเรียนมาเพื่อโปรดพิจารณา

ขอแสดงความนับถือ





ผู้จัดการฝ่ายปฏิบัติการโครงการของโรงงาน

หน่วยงานบริหารโครงการของโรงงาน (J.P.PP)

โทรศัพท์ 0 3897 1026 และ โทรสาร 0 3899 4111

สำเนาเรียน :





สิ่งที่ส่งมาด้วย " _ "

Ref. No.: G-MSG-L-18/013

October 1, 2018

Eastern Fluid Transport Company Limited

Attn : General Manager
Eastern Fluid Transport Company Limited

Subject: Permission to access Glow Piperack for Construction of 3 inch Methanol pipeline of GC

Ref. : Letter of Glow SPP3 Company Limited, ref. no. G-MSG-L-18/010 dated July 6, 2018 ("Approves in Principle Letter")

Dear Sir,

Reference to the Approves in Principle Letter, Glow SPP3 Company Limited ("Glow") would like to inform Eastern Fluid Transport Company Limited ("EFT") that PTT Global Chemical Public Company Limited ("GC") has already entered into Piperack Agreement dated October 1, 2018 with Glow ("Agreement") for laying 3 inch Methanol pipeline ("Pipeline") and preliminary information for Glow's insurers as required under the Approves in Principle Letter for such pipeline has been provided to Glow.

Therefore, Glow would like EFT to coordinate with GC for the process of access and permission to construct of Pipeline on Glow's piperack.

During this period, there are many constructions on Glow's piperack. Accordingly, please keep close coordination and communication with Glow in order to ensure that these constructions are going smoothly.

Your cooperation in this matter will highly appreciate.

Sincerely yours,



AVP-Marketing and
Business Planning



Mrs. Sirapapra Samratanachamphri
Chief Commercial Officer &
EVP Human Resources

CC : Mr Chai Khaoan
Mr Wisit Srinanuwong
Mr Apichan Jansuam
Mr Anurachai Nuthalang

EFT
Glow
Glow
Glow


G-MSG-L-18/013

บริษัท โกลว์ เอสพี3 จำกัด

GLOW SPP3 COMPANY LIMITED


15/5 หมู่ 10 ตำบล คลองเตย อำเภอ คลองเตย จังหวัด สงขลา 90110 โทร 09-000-1111 โทร 09-000-1111 โทร 09-000-1111 โทร 09-000-1111

Page 1 of 1

[illegible][illegible]

PLANE VIEW (T-69) 3-01B ONLY)

1000




KEY PAGE

ASSEMBLY

[illegible]




PROJECT TITLE : BUTADIENE STORAGE TANK PROJECT (BV PROJECT OFFSITE AREA)			
OWNER : PTT GLOBAL CHEMICAL PUBLIC COMPANY LIMITED			
LOCATION : PTTGC BRANCH 7 (BTF)		PROJECT CONTRACT NO. : A-1142	
MAP TA PUT INDUSTRIAL ESTATE, RAYONG			
DDC. NO. : T-6983 A/B-001			
<p>Item No. : T-6983 A/B</p> <p>Title : BUTADIENE STORAGE TANK PROJECT</p> <p>Description : SPHERICAL TANK, 19,000 MM</p>			
2	26-Dec-2013	Issued for Construction	Tis
1	17-Oct-2012	Issued for Construction	Tis
0	23-Aug-2012	Issued for Construction	Tis
REV.	DATE	DESCRIPTION	Pr

	USER'S DESIGN SPECIFICATION FOR BUTADIENE STORAGE TANK	Doc. No. : T-6963 A/B -001
		Revision No. : 2
		Page No. : 2 of 8

CONTENTS

1. GENERAL.....	
2. RELATED DOCUMENTS.....	
3. DESIGN CRITERIA.....	
4. MATERIAL SPECIFICATIONS.....	
5. CONSTRUCTION.....	
6. INSPECTION AND PRESSURE TESTS.....	
7. OVERPRESSURE PROTECTION.....	
8. OTHER.....	

	USER'S DESIGN SPECIFICATION FOR BUTADIENE STORAGE TANK	
	Doc. No.	: T-6583 A/B -001
	Revision No.	: 2
	Page No.	: 3 of 8

USER'S DESIGN SPECIFICATION

1. GENERAL

1.1 User is PTT Global Chemical Public Company Limited who will own and/or operate the Spherical Tank

1.2 This specification, together with the related drawings, data sheets, codes and standards, constitutes a complete "User's Design Specification" as required by Part 2, Paragraph 2.2.2 of the ASME Boiler and Pressure Vessel Code, Section VIII, Div.2, 2010 Edition and 2011 addenda.

1.3 Conflicts

1.3.1 If conflicts occur between the User's Design Specification and any other document, drawing, data sheets, specification, code, or standard, it shall be the responsibility of the Spherical Tank Manufacturer to call attention to the discrepancy and request a written ruling or interpretation from the engineer responsible for the User's Design Specification. The Manufacturer is not at liberty to assume which institution shall govern.

1.3.2 All applications for exemptions, exceptions, or Interpretations shall be made in writing and shall clearly state the extent of and the reasons for the relief requested, any proposed deviation from this specification shall be submitted to the engineer responsible for this specification to obtain his written approval and the Owner's concurrence, by a revision of this specification.


1.4 The related data sheets and drawings contain requirements in addition to the rules of the ASME Code, Section VIII Div. 2. Brief supplementary requirements that affect the Manufacturer's Design Report are given in this User's Design Specification.

1.5 The principal documents are the data sheets and drawings listed in Para. 2.1 and 2.2 These documents specify or define the following essential design data.

- a) Spherical Tank configuration and dimensions
- b) Design pressure and temperature
- c) Materials of construction
- d) Sizes, locations and details of nozzles and manholes
- e) Details and locations of attachments
- f) Detail drawings for construction

1.6 Qualification of Engineer

An Engineer that signs and certifies a User's Design Specification and Manufacturer's Design Report shall have the licensing or registering authorities under The Engineering of Institute of Thailand Under H.M. The King's Patronage in the level of Associate Mechanical Engineer or higher level.

	USER'S DESIGN SPECIFICATION FOR BUTADIENE STORAGE TANK	Doc. No. : T-6983 A/B -001
		Revision No. : 2
		Page No. : 4 of 3

2. RELATED DOCUMENTS

2.1 Data sheets;

A1142-DS-ME-001_Rev.A : BUTADIENE STORAGE TANK DATA SHEET

2.2 Drawings

Refer to Contractor's General Assembly for T-6983 A/B

2.3 Design Code

ASME Boiler and Pressure Vessel Code, Section VIII, Div.2, 2010 Edition and 2011 Addenda

ASME Boiler and Pressure Vessel Code, Section II, Part D, 2010 Edition and 2011 Addenda

2.4 Design Specification

PTTCHEM-SP-S-07 : PRESSURE VESSEL

PTTCHEM-SP-S-14 : SPHERICAL STORAGE TANK

PTTCHEM-SP-G-C1 : DESIGN BASIS

PTTCHEM-SP-C-02 : DESIGN LOADS AND CRITERIA

3. DESIGN CRITERIA

3.1 The spherical tank shall be designed in accordance with the ASME Boiler and Pressure Vessel Code, Section VIII, Division 2, 2010 Edition and 2011 Addenda.


3.2 Certification shall be per ASME Code Section VIII, Division 2, Part 2

3.3 Design Data

3.3.1 General Description

Item No. : T-6983 A/B
 Inside Diameter : 10,000 mm
 Type : Spherical Tank

3.3.2 Design Pressure, Internal : 5 kg/cm² G
 External : Full Vacuum
 Design Temperature (Min/Max) : -5 / 65 °C
 Operating Pressure : 0.6 kg/cm² G
 Operating Temperature : 5 °C
 Design Liquid Level : 14,350 mm. from bottom

	USER'S DESIGN SPECIFICATION FOR BUTADIENE STORAGE TANK	Doc. No. : T-8883 A/B -001
		Revision No. : 2
		Page No. : 5 of 8

Design Specific Gravity : 640 kg/cm³

Liquid stored : 1.3 Butadiene

Min. Design Metal Temperature : -5 °C

3.3.3 Environmental condition will be referred to project specification SP-G-01.

3.4 Design Fatigue Life

The intended operation of this spherical tank is such that a fatigue analysis is not required and the intended spherical tank's operation satisfies the requirements of ASME Code, Section VIII, Division 2, paragraph 4.1.1.4.

Cyclic operation conditions are not applicable.

3.5 Corrosion Allowance

3.5.1 Shell and Nozzles : 3.5 mm.

3.5.2 Support Column : 0 mm.

3.6 Loads and Load Case Combination

The loads as listed in paragraph 4.1.5.3, Table 4.1.1 of ASME Section VIII, Division 2 are specified as the followings and the loads are not specified will be not applicable in this project.

3.6.1 Design pressure (P) and Static head (Ps) are specified in design data above and data sheet A1142-DS-ME-001.

3.6.2 Dead load (D) must be considered by calculation and refer to project specification SP-S-14 and SP-G-02.

3.6.3 Live load (L) are specified in project specification SP-C-02.

3.6.4 Wind Loads (W)


a) Code : As per SP-G-01 Standard Specification, Design Basic

b) Basic wind speed : 38 m/s

c) Exposure Category : ASCE-7 Last Edition (Category D)

d) Importance factor (I) : 1.15

f) Force coefficient (Cf) : 0.6

	USER'S DESIGN SPECIFICATION FOR BUTADIENE STORAGE TANK	Doc. No. : T-3583 A/B -001
		Revision No. : 2
		Page No. : 6 of 8

3.6.5 Earthquake Loads (E) : Not applicable

Seismic Zone: U.B.C Zone 0

3.6.6 Snow Loads (S) : Not applicable

3.6.7 Loads due to Deflagration (F) : Not applicable

3.6.8 Load Combination

The design load combination will be considered in paragraph 4.1.5.3, Table 4.1.2 of ASME Section VIII, Division 2 including project specification SP-S-14 and SP-C-02.


3.7 Method of Support

The Spherical tank is to be self supported on columns.

3.8 Lethal Service: No

4. MATERIAL SPECIFICATIONS

SHELL	:	SA516 GR.60
FLANGE	:	SA350 LF2 CL2
FORGED NOZZLE NECK	:	SA350 LF2 CL2
NOZZLE PIPE	:	SA 106-B
INTERNAL PIPE	:	SA 106-B
ELBOWS	:	SA234 WPB
UPPER COLUMN	:	SA516 GR.60
LOWER COLUMN	:	SA516 GR.60
BRACING	:	SA 36 OR EQUAL
BASE PLATE and SLIDING PLATE	:	SA 36 OR EQUAL
TEMPLATE, LINER PLATE	:	SA 36 OR EQUAL
BOLT/NUTS		
External Structure	:	SA 307 GR.B / SA 194 GR.2H (HOT DIP GALV.)
Internal Structure	:	SA 193 GR.B8 CL.1 / SA 194 GR.8
Flange	:	SA193 GR.B7 / SA 194 GR.2H
Anchorage	:	SA 36 (HOT DIP GALV.)
EXTERNAL ATTACHMENT	:	SA516 GR.60

	USER'S DESIGN SPECIFICATION FOR BUTADIENE STORAGE TANK	Doc. No. : T-5889 A/B-001
		Revision No. : 2
		Page No. : 7 of 8

GASKET

Nozzle Flange	:	GROOVED GASKET RF, SS316 + GRAPHITE B9A
Manhole	:	GROOVED GASKET RF, SS316 + GRAPHITE B9A

5. CONSTRUCTION

- 5.1 The mandatory requirements of the ASME Code shall be interpreted as minimum requirements.
- 5.2 The spherical tank fabricator shall furnish and install all attachments welded directly to the spherical tank. All attachment welds of non-pressure parts to the spherical tank shall be made with full penetration ground to a generous and smooth concave contour.
- 5.3 The spherical tank fabricator shall provide full details for shop fabrication. Such details shall be submitted for approval prior to fabrication and should cover:
- a) Welding procedures
 - c) Sequence of fabrication and assemble (including all inspection steps)
 - d) Hydrostatic testing procedure
 - e) Quality control procedures (including extent of NDE)

6. INSPECTION AND PRESSURE TESTS

- 6.1 The spherical tank shall be inspected in accordance with the requirements specified in ASME VIII Div.2 and those procedures listed in Para. 5.3 of this specification.
- 6.2 The extent of NDE and acceptance criteria shall be in accordance with Para. 7.4.3 & 7.5 of ASME VIII Div.2
- 6.3 Hydrostatic Tests
- 6.2.1 The hydrostatically tested pressure shall be held for at least one hour during pressure tests performed at site.

7. OVERPRESSURE PROTECTION

The overprotection system will be responsibility and design by owner that shall be met the requirement of Part 9 of ASME VIII, Div.2

8. OTHER

8.1 LOCATION OF SUPPORT ASME NAMEPLATE

Due to sphere will cover with insulation. Therefore, nameplate needs not to be installed attach with Pressure Retaining. But the location to be installed the nameplate bracket/nameplate which is at sphere leg support.


	USER'S DESIGN SPECIFICATION FOR BUTADIENE STORAGE TANK	Doc. No. : T-6983 A/B-001
		Revision No. : 2
		Page No. : 8 of 8

Table 2-A.1

Typical Certification of Compliance The User's Design Specification

**CERTIFICATION OF COMPLIANCE OF
THE USER'S DESIGN SPECIFICATION**

I (We), the undersigned, being experienced and competent in the applicable field of design related to pressure vessel requirements relative to this User's Design Specification, certify that to the best of my knowledge and belief it is correct and complete with respect to the Design and Service Conditions given and provides a complete basis for construction in accordance with Part 2, paragraph 2.2.2 and other applicable Requirements of the ASME Section VIII, Division 2 Pressure Vessel Code... 2010... Edition with...2011... Addenda and Code Case(s) ...None... This certification is made on behalf of the organization that will Operate these vesselsT-6583 A/B.....

(Company name) PTT Global Chemical Public Company Limited...

Certified by :.....

Title and areas of responsibility: Project Engineer / Certified of Process and Mechanical Design.

Date: 27/12/13

Certified by :.....

Title and areas of responsibility: Project Engineer / Certified of Process and Mechanical Design

Date: 17/12/2013

Professional Engineer Seal: (As required).....

.....Not required.....

Date:.....



**CERTIFICATION OF COMPLIANCE OF
THE MANUFACTURER'S DESIGN REPORT**

I (We), the undersigned, being experienced and competent in the applicable field of design related to pressure vessel construction relative to the certified User's Design Specification, certify that to the best of my knowledge and belief the Manufacturer's Design Report is complete, accurate and complies with the User's Design Specification and with all the other applicable construction requirements of the ASME Section VIII, Division 2 Pressure Vessel Code,....2010....Edition with.....2011....Addenda and Code Case(s).....This certification is made on behalf of the Manufacturer
....Thai ~~Rotary Engineering Public Company~~ Limited,.....(MDR No.T-6983-01AB-85-026-1)

Certified

Title and areas of responsibility:.....

years (Thailand).....

Date:.....

Certified by :.....

Title and areas of responsibility:.....

Date:.....

Professional Engineer Seal: (As required)

.....Not required.....

Date:.....

Authorized Inspector Review:.....

Date:.....

➤ 36ข

เอกสารขั้นตอนการตรวจสอบรอยเชื่อมต่อ
ด้วยวิธีฉายรังสีของโครงการ





PTT Global Chemical Public Company Limited

Integrity and Inspection

W-(T-IQ-012
Inspection of Piping

Created by :
Vice President

Approved by :
Vice President

Reviewer list

Reviewer	Position	Unit Code

Edition records

Rev.	Effective Date	Detail	Updated by
0	25/02/2020	Migrated (Unit Inspection)	System

Related Units

Unit Code	Unit Name
T-II	Integrity and Inspection

Related KPI

KPI Measure	Description / Calculation	Target (unit)
N/A	N/A	N/A

Related Documents

Document ID	Document Name

External Reference Documents

Document Name

Table of Contents

	Page
1. Purpose/Objective.....	1
2. Scope	2
3. Roles and Responsibility	3
4. Workflow	4
5. Detailed Narrative of Workflow.....	5
6. Appendix	14

1. Purpose/Objective

Piping systems are inspected at appropriate intervals to provide information on the condition of the piping and avoid unexpected failures. The objective of such inspection is to confirm the mechanical integrity of the piping. This work instruction serves as a basic guide for the Plant Inspector on planning and performing inspection of piping both on and off streams.

2. Scope

This document gives a scheme of examination for both in-service and out-of-service inspection of piping systems. It applies to all piping subjected to pressure or vacuum conditions at PTT Global Chemical plants, including valves, fittings, supports, etc.

It does not apply to submarine piping, non-metallic piping and non-pressurized piping systems such as drain systems, or any instrumentation piping beyond the first isolation valve.

The document is not a detailed inspection manual, as there are many publications serving that purpose, predominantly the API publications listed in the reference section.

3. Roles and Responsibility

3.1 Inspection Department

- Inspector is a responsible for preparing the scope of the inspection.
- Perform visual inspection execution activities, inspection report, recorded and updated in database after inspection completed.
- Review the inspection results such as RT, P/TMT, UTM and/or DTM for estimating the remaining life of equipment for setting next interval inspection
- Review, advise and approval of specifications for repair procedure to ensure the specific technical, work preparation, and quality control are meet the code requirement.

3.2 Maintenance Department

- Providing scaffolds, insulation removal, power supply etc. that are required for shutdown inspection.
- Ensuring the working condition and preparation for proper safe access before inspection activities.

3.3 Corrosion Engineer

- To advise for degradation mechanisms and special corrosion control/monitoring method(s).

4. Workflow

5. Detailed Narrative of Workflow

5.1 Safety

5.1.1 All necessary permits/clearances in accordance with PTT Global Chemical's Safety Regulations shall be obtained before commencement of inspection activities.

5.1.2 Appropriate Personal Protection Equipment shall be worn in accordance with guidelines in the PTT Global Chemical Plant Safety Regulations.

5.1.3 Proper safe access should be provided for inspection to be conducted.

5.1.4 Hammer testing shall not be carried out on live piping and rigid adherent scales shall not be removed from the pipe surface because of potential leaks.

5.2 Identification of Piping

5.2.1 All pressure piping systems should be readily identifiable by reference to Engineering Flow Diagrams or Piping Schedules, whereby the location, duty and physical characteristics of the system and its components can be ascertained. Such drawings should be available in the refinery & petrochemical plant

5.2.2 It is not essential for all systems to be physically identified on site by a unique number; provided the major equipment items (pressure vessels, heat exchangers, pumps, etc) are so marked that the pressure piping attached to them can be identified.

5.3 Inspection of Piping

The following provides general guidelines for the inspection of piping systems that are an integral part of a plant or facility and are subject to internal and external pressures. Process piping requires at least as much attention as stationary equipment. When the inspection of piping systems is not properly organized, unexpected failures are more likely to occur in piping systems than on stationary equipment.

5.3.1 On stream Inspection (OSI) of Piping

Initial assessment of piping to be monitored using an On-stream Inspection Program which shall be established by Inspector following the procedure indicated in Appendix 8.2.

be localized and is often difficult to detect.

External corrosion on insulated pipelines below 175°C) can give rise to unexpected failures. Hence piping surveys should be over full length. Likely places to corrode include pipe clamps, clamp supports, pipe rest locations, near sea water front, maintained low temperature pipes (sweating pipes), broken insulation locations, interface between heated and unheated sections, etc. Inspection strategy for Corrosion Under Insulation (CUI) is given in Appendix 8.6.

5.3.4 Carbon Steel Piping

Pressure failures have been experienced due to corrosion, erosion or a combination of both. Corrosion frequently occurs at stagnant or low flow locations where deposits have settled e.g. dead ends and bends. Location where a change of direction occurs, e.g. bends, tees, reducers can suffer local erosion by impurities or abrasives carried in the process stream.

Pipe thickness and internal condition can be determined by commonly used NDT techniques such as ultrasonic thickness gauging and radiography.

5.3.5 Stainless Steel Piping

Corrosion rates of these pipes are generally very low. However failures can occur due to internal fatigue, where significant temperature differences exist, or due to aqueous chloride or polyhalide acid stress corrosion cracking. The problem areas are mostly at highly stressed locations e.g. welds, bends, nozzles etc. Additionally Amine and Cl⁻ stress corrosion cracking generally threaten to hot piping as well especially in stagnant locations (e.g. drums, vents); locations where insulation is poor or broken and internal parts exposed to atmosphere without an alkaline wash are particularly conducive to pitting corrosion. Problems often occur during shutdown.

The Area Inspector should generate an OSI piping inspection due list from CMMS approximately 6 months in advance (see also Procedure, On-Stream Inspection).

The Area Inspector, where necessary with the assistance of the Senior Area Inspector, should determine the suitable NDT technique to be applied:

- (1) Ultrasonic Thickness Gauging - depending on operating temperature
- (2) Radiography - wall thickness profile and weld joint evaluation.
- (3) Intelligent Piggling - instrumented pig - carried out on stream - performs simultaneous external and internal wall thickness inspection for piping containing of long radius elbow.

When contract NDT personnel are employed to conduct the work, the Inspector should assist the NDT Contractor to co-ordinate with the Maintenance planning where scaffolds, insulation removal, power supply, etc. are required. Basically, NDT coordinator (contractor representative) will directly conduct with scaffolding and insulation work in accordance to TNDs determined in ITP.

The results are provided to the relevant Area Inspector for further assessment.

5.3.2 External Inspection

External inspection of piping systems for either in-service or out-of-service conditions should include visual checks on the condition of the lines and its components. A checklist is given in Appendix 8.3.

Hammer testing is a useful technique to assess the general condition of piping, however, it must not be applied on live lines.

5.3.3 External Corrosion

Corrosion can be serious where moisture can gather and any protective coating has broken down. Coating breakdown on paintwork, bitumen wrappings, fiberglass wrappings, etc. can

If internally accessible, these locations should be visually inspected and or dye-penetrant tested. If internally inaccessible, radiographic or ultrasonic inspection should be conducted at selected locations.

It is standard practice in PTTGC (Refinery) to coat externally the stainless steel pipes operating in the range up to 400°C, to prevent external stress corrosion cracking (SCC) during shutdown. Prior to coating, the complete assembly should be thoroughly inspected. Locations under clamp-supports should be checked for service corrosion. If the clamped section had not been previously painted or coated, it should be exposed, visually inspected and/or dye penetrant tested.

5.3.6 Piping in Amine Service

In addition to thickness surveys, carbon steel piping in lean amine service and not stress relieved should be selectively split open at weld joints to inspect for amine SCC. Wet fluorescent magnetic particle inspection is the recommended technique.

5.3.7 Piping in Caustic Soda Service

The carbon steel weld joints of piping systems which are operated above 45°C and have not been stress relieved and have been evaluated to be exposed to caustic soda (even trace levels) should be selectively radiographed or ultrasonically examined for possible external cracking.


5.3.8 Piping in Creep Range


Where a piping system is evaluated to be operated in the creep range, regular selective inspection for creep damage is necessary. The applicable modes of inspection are dye-penetrant, magnetic particle and metallographic examination (e.g. Replint) or a

combination of these methods.

5.3.9 Piping in Cyclic Loading

Fatigue is a cracking mechanism that resulted from cyclic loads. These cyclic loads may be associated with pressure fluctuations, resonant loads from machinery mostly a reciprocating type. Since fatigue failures are encountered in the piping system, therefore, inspection with non-destructive techniques should properly be focused where visible shaking. Due to vibration level cannot be examined by visual inspection, special monitoring tools should be applied to confirm its severity based on below figures. Following external inspection and/or site survey when piping vibration detected, MT or PT should be applied at bracketed welds of small bore tapping (vent, drain, and instrument). UT and advanced inspection techniques (such as shear wave UT and eddy current testing) may be used in special situation.





Classification of piping vibration of different zone given in above figures based on vibration amplitude and vibration velocity where the monitoring function is available inspection tools. In case the vibration level is above marginal line, investigation shall be made for original source (pipe may not be resting on support) if simple corrosion required e.g. skimming. Some circumstance that piping vibration is in diagram zone, engineering review is required for modification to reduce vibration, as such NDT inspection shall be carried out.

5.4 Repair Criteria and Rejection Limit

Generally, the acceptable condition of an existing piping system should be such that the remaining corrosion allowance can last till the next planned shutdown, based on the calculated rate of corrosion. (There will be cases where the installed thickness is more than the calculated required thickness plus corrosion. In this instance, the calculated minimum would be used). Otherwise, the piping system shall be replaced.

If the wall of piping has thinned below the minimum calculated thickness required by the design standard, the affected area may be reviewed for fitness-for-purpose for the maximum allowable operating pressure using applicable codes or standards. (For example, criteria are given in ASME B31G, Manual for Determining the Remaining Strength of Corroded Pipelines, to assess localised wall thinning of piping). In such cases, the Area Inspector shall approve recommendations for continued operation.

5.5 Welding Repair

Prior to repair, no welding should be carried out on any piping unless the Area Inspector has accepted a repair procedure including an approved welding procedure. The repair procedure should indicate the extent of visual inspection, MDT testing and hydrostatic testing to be carried out.

5.6 Hydrostatic Pressure Test

Replacement and repaired piping should normally be tested at 1.5 times the design pressure at ambient temperature. Where the design pressure is not known, the piping class design shall at ambient temperature should be used accordingly.

When testing a piping system or when testing with other equipment as a system, the test pressure shall be not greater than 1.5 times the design pressure of the weakest component in the system. In circumstances when a hydrostatic test is not practical, an alternative test is permitted, subject to the approval of the Area Inspector (e.g. Golden with RCB).

Test medium shall be water for general carbon steel pipes, condensate water or water with chlorides content not greater than 30 ppm for stainless steel pipe and approved liquids for specific services. Refer to Procedure (Hydrostatic testing of equipment and piping) and (Witnessing Hydrostatic Pressure Testing of Equipment and Piping), for general requirements.

5.7 Corrosion Review and Setting of Inspection Frequency

5.7.1 Reporting and Data Analysis

For on stream inspection of piping, the thickness data obtained shall be entered into the SAP system or GALLIUM system. Comparison should be made against thick obtained in previous two consecutive shutdowns/OSI where available. Where thicknesses are found to

be reduced, more measurements should be taken both up and downstream of the monitored points.

From a review of these inspection results, the Inspector should then add new or delete inspection points/sketches, as appropriate.

5.7.2 Inspection Frequency

Corrosion Circuit - Piping

The initial inspection frequency shall be established following the procedure indicated in Appendix 6.2. All registered piping shall be inspected within four years after it has been commissioned.

On the basis of the three sets of thickness data (refer 5.7.1) the next inspection date and frequency should be determined and updated in SAP or GALLOM.

Other Piping Systems

Piping systems in the process plants that are in relatively mild service (e.g. non-corrosive hydrocarbon, etc.) and are not included in the Corrosion Manuals should also be inspected at certain frequency to verify their fitness for further service. The frequency for this group of piping system is tentatively set at maximum of 12 years.

Utilities piping such as air, water, steam, fired oil, etc. in the process plants are not inspected at fixed frequency but should be inspected at an ad-hoc basis or when the integrity of the piping is suspected.

Piping systems outside the process plant battery limits should be inspected at maximum frequency of once every 5 years.

5.8 Remarks

5.8.1 OSI registered piping findings and actions taken shall be recorded in CMMS.

In this record, the following are required:

- Component history, if any
- Highlights
- Recommendations and action taken, if any
- Thickness measurements or other NDT results, if any.

For OSI piping, which is replaced, a set of thickness data should be obtained on the new piping as base measurements for future calculation of corrosion rates.

5.8.2 For piping systems suspected on a case-off basis, the Plant Inspector shall compile all findings/actions taken and recommendations in an inspection report.

5.8.3 All sketches, photographs, results and reports of NDT and other inspection activities shall be properly documented and kept in the Inspection Engineering Equipment Imaging files.

All records on the piping systems shall be kept until the piping is permanently removed from service.

6. Appendix

6.1 Terms and Definitions

A piping system includes all pipes and piping components e.g. flanges, elbows, reducers, nozzles, supports, instrument connections up to first block valve, bellows, threaded nipples if any, instrument thermowell nozzles, vents, drains etc.

CCIMS: A computerized inspection data and information management system for refinery piping and equipment.

NDT : Non-Destructive Testing

ANSI : American National Standards Institute

ASME : American Society of Mechanical Engineers

CORROSION CONTROL MANUAL: Manual compiled by Corrosion Engineer in consultation with multidisciplinary team from various departments i.e. Operations Technology and Maintenance Dept's.

6.2 Corrosion Criteria

6.2.1 The prime objective of the Corrosion Criteria is to provide information on the deterioration rate, corrosion mechanism of the selected locations and also to reduce shutdown inspection activities wherever feasible. The Corrosion Engineer in consultation with the Area Inspector determines selection of piping registration and monitoring points. In the selection process, the following factors should be considered:

a) Process Stream

This should include Pressure, Temperature, Flow Velocity, Corrosivity, Erosivity, Phase separation, Phase change, Toxicity and any other factor deemed relevant.

b) Piping System

Material of construction and its reaction with the process medium/media.

c) Consequence

Consequences of failure.

d) Service Life

Minimum service life available.

6.2.2 A process pipe run may be of significant length and involve several changes of direction, branch connections, fittings, etc. The following forms of degradation should be considered to select monitoring points.

a) Run pipe :-

i) general corrosion

ii) groove corrosion due to stratified flow, liquid/vapour or liquid/liquid interface

b) Under components subject to high velocity and local imbalance e.g. downstream of control valve and reducer.

c) Bends, Tees, Reducers - points of change of direction can suffer local erosion or corrosion. These are normally the first components of a piping system to fail.

d) Singlet and dead leg

Operating conditions e.g. stratified flow, phase separation turbulence or singletion at different locations of such piping system may differ significantly, as does the rate of corrosion. The selection of the locations where wall thickness measurements are to be conducted, should take account of which of the circumferential portions of the pipe, elbow or fittings would be most sensitive to internal corrosion or erosion e.g. bottom, side or top, inner or outer radius of an elbow and vent/drain etc.

e) Injection or mixing point

Several corrosion mechanisms associated with injection points have become apparent to refinery operation over the years. Many of these problems have

resulted in highly localized deterioration (corrosion/erosion) and led to piping failure during operation. Therefore it is essential to manage injection points to ensure operation long term in a safe manner in terms of reliability and integrity.

There are three major types of injection points used in refinery and petrochemical plants:

1. Process chemical injection point
2. Wash water injection point
3. Process mixing point

This guideline is setup to be used for implementation in the company. The criteria for assessment is based on NACE practice 34 (1) – “Refinery Injection and process mixing point”. In company, we considered the followings criteria to be the injection point inspection.

- Process mixing points that need special attention are points of joining of process streams of differing composition and/or temperature where defined by
 - Delta T > 100 deg C
 - Difference in media composition or different phases present.
- Wash-water and Chemical injection points all are Injection points requiring special attention.

It is recommended to carry out focused inspection on areas most susceptibility to failure. Set up an inspection circuit to sample/monitor thickness using UT and RT at selected locations in the potential corrosion zone.

Monitoring Scope:

- Defined inspection scopes for pipe & inline mixer are the same scope.
- From upstream 3D or 12" whichever is greater/Downstream to OD or 25H is the inspection area (may extend to next piece of process equipment).
- Carry out UT/M WI every D
- RT every 3D, and one shot for checking quill. If D<6" coverage is all circumference of all 10D, if D>6" coverage every 3D
- Initial inspection interval 3 years based on API-570. After that the inspection interval shall be based on actual CR via REI process.
- 360 deg around the injection point

- Change in direction at <10D needs to be inspected
 - Impingement point opposite the nozzle shall be inspected.
- Recommendations:
- To check that IP installation conforms to design drawing (Extra sol. PWHIT etc.)
 - Marking of quill orientation
 - Register new scope in CMMS against relevant time number.
 - Inspection area see below sketch for details

6.2.3 The Corrosion Manuals should be reviewed by the appropriate study team after each major shutdown to verify whether corrosion points need updating to check if all operating conditions are still relevant to the process units.

6.2.4 Since the corrosion manuals (or RBI) determined only degradation mechanisms in consideration of process. However, some associated piping where connecting to vibration source e.g. reciprocating type machinery may be suffered to vibration failure. Inspector should report in RBI study, and inspection plan is setup with RT or RT check on banded welds (vent, drain and instrument tapping). Intensive measurement for vibration spectrum may be required to evaluate vibration level if re-design or additional support required.

6.2.5 Isometric sketches should be prepared of piping systems that require periodic inspection. The isometric sketch should contain information on piping class, material, operating temperature and pressure, service, direction of flow, pipe number, pipe sizes, drains, vents, control and block valves, reboilers (concentric/eccentric), RV & bellows. The isometric should also indicate whether the pipe is insulated or not and show the equipment to which the pipe is connected. Pipe elevation and means of accessibility should also be indicated

6.2.6 The Area Inspectors will maintain and update all relevant Isometric drawings for their respective areas. They will be responsible for its safe keeping and filing within the Integrity Dept.

6.2.7 Where possible, during construction stage, the provision of inspection windows or insulation covers should be arranged to facilitate future inspection. This should be indicated on marked up isometric sketches.

6.2.8 The relevant information of the registered QSI piping (the isometric sketches) with an initial set of thickness data shall be entered in the CMMS for future reference or completion of corrosion rate.

6.2.9 All registered QSI piping (except representative) should be inspected within 5 years after the plant has been commissioned.

6.3 Checklist for external inspection of piping


1. External corrosion
2. Paint/coating condition/delamination
3. Insulation condition
4. Damaged insulation/insulating
5. Potential for under-bagging corrosion
6. Checklag applied for pressure protection
7. Corrosion at penetrations
8. Small bore fittings – fatigue, cracking, especially for any socket weld, corrosion
9. Screwed fittings
10. Pipe supports/clampers - condition
11. Freedom for expansion
12. Frictional/damage to pipe under supports
13. Pipe hanger function (Hot/Cold set – check)
14. Vibrations
15. Leaks at flanges
16. Clamps – registered?
17. Buried sections/soil build-up
18. Steam tracing leaks and functioning properly

19. Steam traps functioning
 20. House-keeping/cleanliness
 21. Don't-tags/labels used lines/flow points
 22. Stoves/wrapping in use/damaged
- Note: This checklist is intended as a guide for external inspection, covering items that should be considered during inspection of piping. The list is not exhaustive, and the inspector should apply knowledge and experience in the interpretation and application of the inspection findings


6.4 Other Supporting Information

- 1) ASME B31.3: Chemical Plant and Petroleum Refinery Piping
- 2) API RP 570: Piping Inspection Code
- 3) API RP 574: Inspection of piping, tubing, valves and fittings
- 6.5 Implementation Plan

6.6.6 Flow chart to assess OSI applicability for piping inspection



6.7 Sketch for monitoring scheme for injection/mixing point



Note:

UT Grid scan required at spacing "D" or RT profile done over the inspection area.

D = Outside diameter of main process stream.

[illegible]

➤ 37ข

**เอกสารแบบฟอร์มการขออนุญาตเข้าทำงาน
ถ่ายภาพด้วยรังสี (Radiography work Permit)
ของโครงการ**





บริษัท ทีทีที โกลบอล เคมิคอล จำกัด (มหาชน)

F-(Q-TS)-OEMS-017: ใบอนุญาตทำงานถ่ายภาพด้วยรังสี
(Radiography Work Permit)

ใบอนุญาตทำงานถ่ายภาพด้วยรังสี (Radiography Work Permit)



บริษัท ทีทีที โกลบอล เคมิคอล จำกัด (มหาชน)

ใบสั่งงานเลขที่

ใบอนุญาตเลขที่ XXX XXXXX number

ผู้ขออนุญาตทำงานฉายรังสี (ชื่อ-สกุล) : _____ พักที่ _____ โทรศัพท์/ช่องวิทยุสื่อสาร _____

วันที่ปฏิบัติงาน _____ / _____ / _____ ย่างเวลา _____ ถึง _____ จำนวนผู้ปฏิบัติงาน _____ คน

ใบอนุญาตทำงานนี้สำหรับ (ระบุบริษัทผู้รับเหมา) _____ หน่วยงาน PTTGC ที่ควบคุมงาน (ระบุชื่อหน่วยงาน) _____

พื้นที่ปฏิบัติงาน (GPC/BU/Plant) _____ อุปกรณ์บริเวณที่ปฏิบัติงาน _____

ชนิดของต้นกำเนิดรังสี (Source) _____ หมายเลข/รหัส _____ ความแรงรังสี _____ คูรี (curie, Ci) จำนวนฟิล์ม _____

รายการตรวจสอบและรายการควบคุมก่อนดำเนินการถ่ายภาพด้วยรังสี

ใช่	ไม่ใช่	รายการตรวจสอบ	ใช่	ไม่ใช่	รายการตรวจสอบ
		มีหนังสืออนุญาตให้ใช้ในพื้นที่หรือใช้สารเคมีอันตรายตามกฎหมาย			มีเครื่องมือที่ตรวจสอบรังสีแบบพกพา (Survey Meter) หรือมีใบรับรองการสอบเทียบ (Calibration Certification)
		หนังสืออนุญาตเลขที่ _____			หมายเลข/รหัส Survey Meter _____
		หมายเลข/รหัส Projector _____			มีอุปกรณ์บันทึกปริมาณรังสีประจำจุดสำหรับปฏิบัติงานฉายรังสีทุกครั้ง
		- รายละเอียดของ Source ตรงกับหนังสืออนุญาต			มีสัญญาณไฟกระพริบสีแดง อุปกรณ์สำหรับพื้นที่ควบคุมงานฉายรังสี และป้ายเตือนข้อความ "ระวังอันตรายจากรังสี ห้ามเข้า" ด้วยตัวอักษรสีดำบนพื้นสีเหลือง แล้ว
		- รหัสหน่วยงานถูกต้อง			มีเจ้าหน้าที่ความปลอดภัยรังสี (RSO) ของผู้รับเหมา
		- หนังสือขออนุญาตยังไม่หมดอายุ			มีความรู้ความเข้าใจเกี่ยวกับรังสี (RSO) ของผู้รับเหมา
		- หมายเลข/รหัส Projector ตรงกับหนังสืออนุญาต			มีความรู้ความเข้าใจเกี่ยวกับรังสี (RSO) ของผู้รับเหมา
		อุปกรณ์และต้นกำเนิดรังสี (Source)			ผู้ปฏิบัติงานฉายรังสีผ่านการอบรมหลักสูตรความปลอดภัยเกี่ยวกับรังสี และมีการอบรมทบทวนอย่างน้อยปีละ 1 ครั้งแล้ว
		- ผ่านการตรวจสอบคุณภาพอย่างถูกต้อง			ผู้ปฏิบัติงานหญิง ไม่ตั้งครรภ์
		- ใบรับรองการตรวจสภาพยังไม่หมดอายุ			จัดเตรียมแผนป้องกันและระงับอันตรายจากรังสี กรณีเกิดเหตุฉุกเฉินทางรังสีแล้ว
		- มี Source Certification			
		- หมายเลขรหัส Projector ตรงกับใบรับรองการตรวจสภาพ			
		- มี Pre-use inspection ก่อนใช้งาน			
		มีรายการด้านความปลอดภัยและรับรองโดยเจ้าหน้าที่ความปลอดภัยของพื้นที่ปฏิบัติงานแล้ว			
		มี Job Safety Analysis (JSA) แล้ว			

ลงชื่อผู้ควบคุมงานผู้รับเหมา (Contractor Supervisor) _____ วันที่ _____

ลงชื่อผู้ควบคุมงานบริษัท (PTTGC Supervisor) _____ วันที่ _____

ตรวจสอบเอกสารเตรียมความพร้อมแล้ว สามารถอนุญาตทำงานฉายรังสีกับ Area Owner ได้

โดยผู้รับเหมาต้องกั้นพื้นที่ควบคุมงานฉายรังสี และติดตั้งสัญญาณไฟกระพริบสีแดง หรือทาบติดตั้งป้ายเตือนข้อความ "ระวังอันตรายจากรังสี ห้ามเข้า" โดยพื้นที่ควบคุมงานฉายรังสีจะต้อง

- มีระยะห่างจากต้นกำเนิดรังสี (Source) ตามระยะปลอดภัยที่ได้จากการคำนวณ และ
- มีการวัดความแรงรังสี ด้วยเครื่องมือสำหรับวัดรังสีแบบพกพา (Survey Meter) โดยความแรงรังสีที่อนุญาตควบคุมงานฉายรังสี จะต้องไม่เกิน 2 มิลลิเรมต่อชั่วโมง (2mR/hr)

ข้อควรปฏิบัติ ข้อควรระวัง (ถ้ามี) _____

ใบอนุญาตมีใช้ถึงวันที่ _____

ลงชื่อผู้อนุญาตทางเทคนิคด้านรังสี (Radiation Technical Approver) _____ วันที่ _____

ข้าพเจ้าได้ทราบดีว่าหากฝ่าฝืนข้อกำหนดความปลอดภัย ข้อควรปฏิบัติ ข้อควรระวังในการปฏิบัติงานแล้ว และจะต้องรับผิดชอบต่อผู้ปฏิบัติงานและผู้อื่นที่ปฏิบัติงานและถือปฏิบัติอย่างเคร่งครัด

ลงชื่อผู้ควบคุมงานผู้รับเหมา (Contractor Supervisor) _____ วันที่ _____

ลงชื่อเจ้าหน้าที่ความปลอดภัยรังสี (RSO) ของผู้รับเหมา _____ วันที่ _____

Section 1: Permit Request

Section 2: Verification and Approval

➤ 38ข

เอกสารการแต่งตั้งคณะทำงานอนุรักษ์พลังงาน
ประจำพื้นที่





คำสั่ง คณะกรรมการ GC Operational Excellence

ที่ กก.002/ 2565

เรื่อง แต่งตั้งคณะทำงานอนุรักษ์พลังงานประจำพื้นที่

เพื่อให้การดำเนินงานด้านการอนุรักษ์และการจัดการพลังงานของบริษัทฯ และกลุ่มบริษัทฯ เป็นไปอย่างมีประสิทธิภาพ สอดคล้องตามพระราชบัญญัติการส่งเสริมการอนุรักษ์พลังงาน พ.ศ. 2535 (แก้ไขเพิ่มเติม พ.ศ. 2550) อาศัยอำนาจตามคำสั่งบริษัทฯ ที่ กก. 037/2562 เรื่อง แต่งตั้งคณะกรรมการ GC Operational Excellence จึงมีคำสั่ง ดังนี้

ข้อ 1. ให้ยกเลิกคำสั่งคณะกรรมการ GC Operational Excellence ที่ 006/2563 เรื่อง แต่งตั้งคณะทำงานอนุรักษ์พลังงานประจำพื้นที่ ลงวันที่ 30 พฤศจิกายน พ.ศ. 2563

ข้อ 2. แต่งตั้งคณะทำงานอนุรักษ์พลังงานประจำพื้นที่ของแต่ละหน่วยงานผลิต ประกอบด้วย

- | | |
|---|------------------------------------|
| 1. ผู้จัดการฝ่ายหน่วยงานผลิต | ประธานคณะทำงาน |
| 2. ผู้จัดการส่วน Plant Operation | คณะทำงาน |
| 3. ผู้จัดการส่วน Asset Utilization | คณะทำงาน |
| 4. ผู้จัดการส่วน Plant Technical | คณะทำงาน |
| 5. ผู้จัดการส่วน Maintenance | คณะทำงาน |
| 6. ผู้จัดการส่วน Control System Maintenance | คณะทำงาน |
| 7. ผู้จัดการส่วน Major Overhauls Maintenance | คณะทำงาน |
| 8. ผู้จัดการส่วน Reliability | คณะทำงาน |
| 9. ผู้จัดการส่วน Maintenance Planning | คณะทำงาน |
| 10. Day Manager | คณะทำงาน |
| 11. Senior Process Engineer หรือ Process Engineer
ที่ได้รับมอบหมายจากผู้จัดการฝ่ายหน่วยงานผลิต | คณะทำงานและผู้ช่วย EnMR |
| 12. Senior Process Engineer หรือ Process Engineer
ที่ได้รับมอบหมายจากผู้จัดการฝ่ายหน่วยงาน
Process Technology | คณะทำงานและผู้ประสานงานด้านพลังงาน |

ทั้งนี้ หน่วยงานผลิต หมายถึง โรงงานหรือ Production Asset ของบริษัทฯ ที่มีผู้จัดการฝ่ายเป็นผู้ดูแลรับผิดชอบและมีการดำเนินงานด้านการอนุรักษ์และการจัดการพลังงานตามพระราชบัญญัติการส่งเสริมการอนุรักษ์พลังงาน พ.ศ. 2535 (แก้ไขเพิ่มเติม พ.ศ. 2550)

ข้อ 3. แต่งตั้งคณะกรรมการอนุรักษ์พลังงานประจำพื้นที่อาคารสำนักงานระยอง ประกอบด้วย

- | | |
|--|--------------------------------------|
| 1. ผู้จัดการฝ่ายหน่วยงาน General Administration | ประธานคณะกรรมการ |
| 2. ผู้จัดการส่วน Rayong Service | คณะกรรมการ |
| 3. ผู้จัดการส่วน Facilities Service | คณะกรรมการ |
| 4. Senior Building Technician หรือ Building Technician
ที่ได้รับมอบหมายจากผู้จัดการฝ่ายหน่วยงาน
General Administration | คณะกรรมการและผู้ช่วย EnMR |
| 5. Senior Process Engineer หรือ Process Engineer
ที่ได้รับมอบหมายจากผู้จัดการฝ่ายหน่วยงาน
Process Technology | คณะกรรมการและผู้ประสานงานด้านพลังงาน |

ข้อ 4. แต่งตั้งคณะกรรมการอนุรักษ์พลังงานประจำพื้นที่ห้องปฏิบัติการเคมี ประกอบด้วย


- | | |
|--|--------------------------------------|
| 1. ผู้จัดการฝ่ายหน่วยงาน Laboratory Operation Services | ประธานคณะกรรมการ |
| 2. ผู้จัดการส่วน Laboratory Operation ทุกส่วน | คณะกรรมการ |
| 3. ผู้จัดการส่วน Laboratory Service Excellence | คณะกรรมการ |
| 4. ผู้จัดการส่วน Laboratory Operation Services | คณะกรรมการ |
| 5. Laboratory Supervisor, Senior Chemist หรือ Chemist
ที่ได้รับมอบหมายจากผู้จัดการฝ่ายหน่วยงาน
Laboratory Operation Services | คณะกรรมการและผู้ช่วย EnMR |
| 6. Senior Process Engineer หรือ Process Engineer
ที่ได้รับมอบหมายจากผู้จัดการฝ่ายหน่วยงาน
Process Technology | คณะกรรมการและผู้ประสานงานด้านพลังงาน |

ข้อ 5. ให้คณะกรรมการอนุรักษ์พลังงานประจำพื้นที่ ตามข้อ 2 ถึง 4 มีหน้าที่ความรับผิดชอบดังต่อไปนี้

1. ดำเนินการและควบคุมดูแลให้การอนุรักษ์และจัดการพลังงานสอดคล้องกับนโยบายอนุรักษ์พลังงานและวิธีการจัดการพลังงานของโรงงานควบคุมหรืออาคารควบคุม รวมทั้งตามมติที่ประชุม ที่เกี่ยวข้อง
2. ประสานงานกับหน่วยงานที่เกี่ยวข้องเพื่อขอความร่วมมือในการดำเนินงานตามนโยบายอนุรักษ์พลังงานและวิธีการจัดการพลังงาน รวมทั้งจัดการฝึกอบรมหรือกิจกรรมเพื่อสร้างจิตสำนึกแก่บุคลากรของโรงงานควบคุมหรืออาคารควบคุม
3. รายงานผลการอนุรักษ์และการจัดการพลังงานตามนโยบายอนุรักษ์พลังงานและวิธีการจัดการพลังงานของโรงงานควบคุมหรืออาคารควบคุมให้แก่เจ้าของโรงงานควบคุมหรือเจ้าของอาคารควบคุมทราบ
4. เสนอแนะเกี่ยวกับการกำหนดหรือทบทวนนโยบายอนุรักษ์พลังงานและวิธีการจัดการพลังงานให้แก่เจ้าของโรงงานควบคุมหรือเจ้าของอาคารควบคุมพิจารณา

5. สนับสนุนเจ้าของโรงงานควบคุมหรือเจ้าของอาคารควบคุมในการดำเนินการตามกฎหมายกำหนดมาตรฐาน หลักเกณฑ์ และวิธีการจัดการพลังงานในโรงงานควบคุมหรืออาคารควบคุม ให้มีประสิทธิภาพและประสิทธิผลยิ่งขึ้น

ทั้งนี้ ตั้งแต่บัดนี้เป็นต้นไป


ประธานคณะกรรมการ GC Operational Excellence

➤ 39ข

เอกสารสำเนาหนังสือส่งรายงานให้กับ
เทศบาลเมืองมาบตาพุด





บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน)

สำนักงานใหญ่ : เลขที่ 888/1 ศูนย์อำนวยการบริหารพื้นที่พิเศษ เขตพัฒนาพิเศษภาคตะวันออก กรุงเทพฯ 10900 โทรศัพท์ +66(0)2265-8400 โทรสาร +66(0)2265-8600

สำนักงานระยอง : เลขที่ 59 ถนนราษฎร์นิยม ตำบลเนินพระ อำเภอเมืองระยอง จังหวัดระยอง 21150 โทรศัพท์ +66(0)3899-4000 โทรสาร +66(0)3899-4111

นาง. เลวี่ 0107554000257

ที่ 25-006/2566

17 มกราคม 2566

เรื่อง รายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อม ระหว่างเดือนกรกฎาคม - ธันวาคม 2565


เรียน นายกเทศมนตรีเทศบาลเมืองมาบตาพุด

- สิ่งที่ส่งมาด้วย 1. รายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมของบริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน) สาขาที่ 7 โครงการท่าเทียบเรือและคลังผลิตภัณฑ์ ระหว่างเดือนกรกฎาคม - ธันวาคม 2565 จำนวน 1 ฉบับ
2. CD-ROM ที่บันทึกสำเนารายงานตามสิ่งที่ส่งมาด้วย 1. จำนวน 1 แผ่น


บริษัท พีทีที โกลบอล เคมิคอล จำกัด (มหาชน) ขอส่งรายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมของบริษัท สาขาที่ 7 โครงการท่าเทียบเรือและคลังผลิตภัณฑ์ ระหว่างเดือนกรกฎาคม - ธันวาคม 2565 ดังรายละเอียดตามสิ่งที่ส่งมาด้วย

จึงเรียนมาเพื่อโปรดพิจารณา

ขอแสดงความนับถือ



หน่วยงาน SHE - Utilities
โทร. 0-3899-4000 ต่อ 2074



➤ 40ข

เอกสารการบันทึก Shipment Summary
Report for (VCM) ,เอทธิลีนไดคลอไรด์ (EDC)
และสาร 1,3 บิวทาไดอิน



SHIPMENT SUMMARY REPORT

Flux 23 Time: 14:04:55.6 324.13 Hz Line and type 200001

INTERNATIONAL JOURNAL OF

[illegible]

[illegible]

SHIPMENT SUMMARY REPORT

[illegible]

➤ 41ข

เอกสารบันทึกสรุปสถิติอุบัติเหตุ
(ระหว่างเดือน มกราคม-มิถุนายน 2566)



สรุปสถิติการเกิดอุบัติเหตุ

No		Item		ccc7						YTD
				Monthly						
				Jan	Feb	Mar	Apr	May	Jun	
1		<u>Recordable Injury Case</u>								
		1.1 Lost time		0	0	0	0	0	0	0
		1.2 Restricted Work		0	0	0	0	0	0	0
		1.3 Medical Treatment		0	0	0	0	0	0	0

➤ 42ข

เอกสารสรุปบันทึกปริมาณรถที่ผ่านเข้า-ออก
พื้นที่โครงการ (ระหว่างเดือน มกราคม-มิถุนายน 2566)



GC7							
ประเภททรัพย์สิน (คูน.)							
เดือน	รถจักรยานยนต์	รถยนต์ส่วนบุคคล	รถตู้	รถกระบะ	รถบรรทุก		รวม
					6ล้อ	10ล้อ	
มกราคม	931	982	211	1061	2	53	3297
กุมภาพันธ์	916	928	201	1050	3	73	3208
มีนาคม	998	976	224	989	11	57	3295
เมษายน	870	673	224	989	1	23	2796
พฤษภาคม	1036	879	225	1314	22	50	3566
มิถุนายน	708	907	227	1282	12	87	3267
รวม	5459	5345	1312	6685	51	343	19429