ภาคผนวกที่ 1 ข

เอกสารประกอบมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม (ระยะดำเนินการ)

1 ข. สำเนาหนังสือเห็นชอบรายงานการเปลี่ยนแปลงรายละเอียดโครงการ โรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น (ครั้งที่ 3) หนังสือเห็นชอบ เลขที่ ทส 1010.8/18259 ลงวันที่ 22 พฤศจิกายน 2564

2 ข. หนังสือนำส่งรายงานผลการปฏิบัติตามมาตรการฯ เดือนกรกฎาคม-ธันวาคม 2565

3 ข. ผลการศึกษา HAZOP ของโครงการ และนำเสนอตัวอย่างกรณีที่เกิดผลกระทบสูงสุด พร้อมแสดง P&ID

4 ข. หนังสือนำส่งแผนการตรวจวัดคุณภาพสิ่งแวดล้อมตามมาตรการ EIA Monitor ประจำปี 2566

5 ข. เอกสาร Green Turnaround

6 ข. หนังสือแจ้งการหยุดเดินเครื่องจักรและอุปกรณ์ประจำปีและกรณีฉุกเฉิน

7 ข. ฐานข้อมูลสุขภาพของพนักงาน และผลตรวจสุขภาพพนักงานย้อนหลัง 3 ปี

8 ข. การทบทวนเหตุการณ์อุบัติภัย/อุบัติเหตุที่เกิดจากการประกอบกิจการอุตสาหกรรมที่มีการผลิตลักษณะเดียวกันทั้งในประเทศและต่างประเทศ

9 ข. เกณฑ์การคัดเลือกและประเมินคุณภาพห้องปฏิบัติการวิเคราะห์

10 ข. สำเนาหนังสืออนุญาตให้โรงงานมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน

11 ข. แผนบำรุงรักษาเครื่องมือเชิงป้องกัน (Preventive Maintenance Plan) ประจำปี 2566

12 ข. บันทึกการตรวจสอบหอเผาทิ้ง (Flare)

13 ข. เอกสารสถิติการใช้งานหอเผาย้อนหลัง 3 ปี พร้อมระบุสาเหตุการใช้งานหอเผาแต่ละครั้ง

14 ข. แบบรายงานผลการตรวจวัดการรั่วซึมของสารอินทรีย์ระเหยจากอุปกรณ์

15 ข. บันทึกการตรวจสอบสภาพอุปกรณ์ที่ใช้ในการสูบถ่ายสารอินทรีย์ระเหยลงรถบรรทุก

16 ข. บันทึกการตรวจสอบการทำงานของหอดูดซับด้วยถ่านกัมมันต์

17 ข. เกณฑ์ควบคุมของ Stripped Water และน้ำทิ้งที่ออกจากระบบบำบัดแบบ IAF ของเขตประกอบการ

18 ข. ผลการตรวจคุณภาพน้ำโดยโครงการ (Internal Check)

19 ข. เกณฑ์ควบคุมคุณภาพน้ำทิ้งที่ออกจากระบบบำบัดแบบ SCTU

20 ข. สำเนาใบเสร็จค่ากำจัดมูลฝอย เดือนมกราคม-มิถุนายน 2566

21 ข. หนังสือขออนุญาตนำสิ่งปฏิกูลหรือวัสดุที่ไม่ใช้แล้วออกนอกบริเวณโรงงาน (แบบ สก.2)

22 ข. เอกสารใบกำกับการขนส่งกากของเสีย (Manifest)

23 ข. ระเบียบปฏิบัติงานการจัดเก็บเคลื่อนย้ายของเสีย

24 ข. การตรวจประเมินบริษัทที่รับกำจัดของเสีย

25 ข. ตัวอย่างเอกสารการติดตามรถขนส่งของเสียผ่านทางระบบ GPS ที่เชื่อมต่อกับตัวรถขนส่ง

26 ข. การจัดทำโครงการอนุรักษ์การได้ยิน (Hearing Conservation Program)

27 ข. การจัดทำผังแสดงเส้นเสียง (Noise Contour Map)

28 ข. ตัวอย่างบันทึกชนิดและจำนวนยานพาหนะที่เข้า-ออกพื้นที่โรงงาน

29 ข. การอบรมพนักงานขับรถให้มีความรู้เกี่ยวกับสารที่บรรทุก

ภาคผนวกที่ 1 ข (ต่อ)

เอกสารประกอบมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม (ระยะดำเนินการ)

30 ข. คู่มือการระงับอุบัติภัยจากวัตถุอันตราย

31 ข. เอกสารแสดงจำนวนพนักงานท้องถิ่น

32 ข. เอกสารประชาสัมพันธ์เกี่ยวกับระบบการจัดการสิ่งแวดล้อม ผ่านสื่อต่าง ๆ เช่น แผ่นพับ เอกสารข่าวสาร

33 ข. แผนงานประจำปีด้านมวลชนสัมพันธ์หรือกิจกรรมสาธารณประโยชน์

34 ข. ผลการดำเนินงานด้านมวลชนสัมพันธ์ด้านต่าง ๆ

35 ข. แผนการสำรวจทัศนคติชุมชน ปี 2566

36 ข. นโยบายด้านคุณภาพ สิ่งแวดล้อม ความปลอดภัย และอาชีวอนามัย

37 ข. การจัดตั้งคณะกรรมการความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงาน

38 ข. แผนงานด้านอาชีวอนามัยและความปลอดภัย

39 ข. คู่มือความปลอดภัย

40 ข. ผลการตรวจสอบความปลอดภัย (Safety Audit)

41 ข. แผนการตรวจสอบความปลอดภัย ประจำปี 2566

42 ข. แผนงานด้านสุขศาสตร์อุตสาหกรรม ประจำปี 2566

43 ข. เจ้าหน้าที่สุขศาสตร์อุตสาหกรรม

44 ข. กิจกรรมส่งเสริมความปลอดภัย

45 ข. เอกสารขออนุญาตเข้าทำงาน (Work Permit)

46 ข. Work Instruction ในการรับ-จ่ายวัตถุดิบ/ผลิตภัณฑ์

47 ข. เอกสารการอบรมความปลอดภัยด้านเคมีภัณฑ์ให้กับพนักงานที่ทำงานเกี่ยวข้องกับสารเคมี

48 ข. ตัวอย่างเอกสารเกี่ยวกับข้อมูลความปลอดภัยของสารเคมี

49 ข. รายการตรวจสุขภาพพนักงานก่อนเข้าทำงาน

50 ข. แผนการตรวจสุขภาพพนักงาน ประจำปี 2566

51 ข. เกณฑ์การคัดเลือกและประเมินคุณภาพของสถานบริการสุขภาพและห้องปฏิบัติการที่ใช้บริการตรวจสุขภาพพนักงาน

52 ข. แผนฉุกเฉิน

- 52.1 แผนฉุกเฉินกรณีเกิดเพลิงไหม้หรือระเบิด
- 52.2 แผนฉุกเฉินกรณีสารเคมีอันตรายรั่วไหล
- 52.3 แผนฉุกเฉินกรณีรังสีรั่วไหล
- 52.4 แผนฉุกเฉินกรณีโครงการพังทลาย
- 52.5 แผนฉุกเฉินกรณีน้ำมันหกรั่วไหลลงทะเล

53 ข. แผนการฝึกซ้อมปฏิบัติตามแผนฉุกเฉิน ประจำปี 2566

54 ข. เอกสารผลการฝึกซ้อมแผนฉุกเฉิน

55 ข. เอกสารข้อมูลของหน่วยงานราชการ โรงพยาบาลท้องถิ่น และโรงงานข้างเคียงพร้อมช่องทางการติดต่อ

56 ข. ระบบน้ำดับเพลิงและปั๊มดับเพลิงในเขตประกอบการ

ภาคผนวกที่ 1 ข (ต่อ)

เอกสารประกอบมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม (ระยะดำเนินการ)

57 ข. บันทึกสถิติอุบัติเหตุ และเหตุการณ์เกือบเกิดอุบัติเหตุ รวมทั้งสาเหตุ ความสูญเสีย และวิธีป้องกันแก้ไข

58 ข. เอกสารการจัดทำประกันภัยประเภทกรมธรรม์ความรับผิดชอบตามกฎหมายต่อบุคคลภายนอก

59 ข. เอกสารการอบรมเรื่องความปลอดภัย

60 ข. การจัดทำ Pre Startup Safety Review (PSSR)

61 ข. เอกสารการประเมินความเสี่ยง (Risk Assessment)

62 ข. บันทึกการตรวจสอบการกัดกร่อน (Corrosion) และสนิมบริเวณถัง (Vessel) หอ (Column) หรือท่อในกระบวนการผลิต

63 ข. บันทึกการตรวจสภาพระบบท่อบริเวณท่อขนส่ง

64 ข. วิธีปฏิบัติงาน (Procedure) ในการหยุดอุปกรณ์

65 ข. การฝึกอบรมให้พนักงานมีความเข้าใจขั้นตอนการหยุดการผลิต

66 ข. ระเบียบควบคุมผู้รับเหมาที่เข้ามาทำงานในพื้นที่ในช่วงการซ่อมบำรุง

67 ข. เอกสารอบรมคนงานและผู้รับเหมาที่เข้ามาปฏิบัติงานในช่วงซ่อมบำรุง

68 ข. เอกสารขั้นตอนและวิธีการที่จะใช้ในการ Shutdown

69 ข. วิธีปฏิบัติงาน (Operation Procedure) ในช่วงเริ่มเดินการผลิตใหม่

70 ข. วิธีการซ่อมบำรุง (Maintenance Procedures)

71 ข. หนังสือแจ้งแผนการใช้น้ำของโครงการให้หน่วยงานที่เกี่ยวข้อง

72 ข. หน่วยแพทย์เคลื่อนที่

73 ข. เอกสารการให้ความรู้พนักงานในการป้องกันโรคติดต่อ

74 ข. หนังสือแจ้งข้อมูลจำนวนพนักงาน และข้อมูลสารเคมีให้กับหน่วยงานสาธารณสุขในพื้นที่

75 ข. ขั้นตอนการรับเรื่องร้องเรียน

76 ข. บันทึกข้อร้องเรียน

77 ข. เอกสารพื้นที่สีเขียว

78 ข. แผนการดูแลพื้นที่สีเขียว

79 ข. ผลการตรวจวัดความเข้มข้นของมลสารที่ระบายออกจากปล่องอย่างต่อเนื่อง (CEMs)

80 ข. แผนบำรุงรักษาระบบการบันทึกการตรวจวัดมลสารจากปล่องอย่างต่อเนื่อง (CEMs)

81 ข. การประเมินระบบตรวจวัดการระบายมลสารจากปล่องอย่างต่อเนื่องแบบ RATA

82 ข. บันทึกชนิด ปริมาณและวิธีการกำจัดของกากของเสียที่นำไปใช้ใหม่

83 ข. แผนการป้องกันอุบัติภัยเพื่อรองรับเหตุฉุกเฉินในกรณีเกิดเหตุรั่วไหลภายในโครงการ

84 ข. คณะกรรมการพัฒนาศักยภาพโครงการ และพัฒนาชุมชนและสังคมเขตประกอบการอุตสาหกรรม บริษัท ไออาร์พีซี จำกัด (มหาชน) (คพอ.)

85 ข. ระบบมาตรฐานการจัดการด้านอาชีวอนามัยและความปลอดภัย (ISO 45001)

86 ข. รายงานผลการประเมินอันตราย การศึกษาผลกระทบ แผนการดำเนินงานและแผนการควบคุมความเสี่ยง อาชีวอนามัย และสภาพแวดล้อมในการทำงาน พ.ศ. 2554

เอกสารแนบที่ 1 ข

สำเนาหนังสือเห็นชอบรายงานการเปลี่ยนแปลงรายละเอียดโครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น (ครั้งที่ 3) เลขที่ ทส 1010.8/18259 ลงวันที่ 22 พฤศจิกายน 2564



ที่ ทส ๑๐๑๐.๘/ ๑๘๒๕๙

สำนักงานนโยบายและแผน
ทรัพยากรธรรมชาติและสิ่งแวดล้อม
๑๑๘/๑ อาคารทิปโก้ ๒ ถนนพระรามที่ ๖
แขวงพญาไท เขตพญาไท
กรุงเทพฯ ๑๐๔๐๐

๒๒ พฤศจิกายน ๒๕๖๔

เรื่อง แจ้งผลการพิจารณารายงานการเปลี่ยนแปลงรายละเอียดโครงการในรายงานการประเมินผลกระทบสิ่งแวดล้อม โครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น (ครั้งที่ ๓) ของบริษัท ไออาร์พีซี จำกัด (มหาชน)

เรียน กรรมการผู้จัดการบริษัท ไออาร์พีซี จำกัด (มหาชน)

อ้างถึง ๑. หนังสือสำนักงานนโยบายและแผนทรัพยากรธรรมชาติและสิ่งแวดล้อม ที่ ทส ๑๐๑๐.๘/๗๘๑๕ ลงวันที่ ๑ มิถุนายน ๒๕๖๔
๒. หนังสือบริษัท ไออาร์พีซี จำกัด (มหาชน) ที่ IRPC-QIEM146/2564 ลงวันที่ ๒๗ กันยายน ๒๕๖๔

สิ่งที่ส่งมาด้วย มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อม ที่โครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น (ภายหลังการเปลี่ยนแปลงรายละเอียดโครงการในรายงานการประเมินผลกระทบสิ่งแวดล้อม โครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น (ครั้งที่ ๓)) ตั้งอยู่ที่เขตประกอบการอุตสาหกรรมไออาร์พีซี ตำบลเชิงเนิน อำเภอเมืองระยอง จังหวัดระยอง ของบริษัท ไออาร์พีซี จำกัด (มหาชน) ต้องยึดถือปฏิบัติอย่างเคร่งครัด

ตามหนังสือที่อ้างถึง ๑ สำนักงานนโยบายและแผนทรัพยากรธรรมชาติและสิ่งแวดล้อม ได้แจ้งผลการพิจารณาของคณะกรรมการผู้ชำนาญการพิจารณารายงานการวิเคราะห์ผลกระทบสิ่งแวดล้อม โครงการอุตสาหกรรมกลั่นน้ำมันปิโตรเลียม ปิโตรเคมี และแยกหรือแปรสภาพก๊าซธรรมชาติ พิจารณาในการประชุมครั้งที่ ๑๑/๒๕๖๔ เมื่อวันที่ ๒๔ พฤษภาคม ๒๕๖๔ ซึ่งคณะกรรมการผู้ชำนาญการฯ มีมติไม่ให้ความเห็นชอบรายงานการเปลี่ยนแปลงรายละเอียดโครงการในรายงานการประเมินผลกระทบสิ่งแวดล้อม โครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น (ครั้งที่ ๓) ของบริษัท ไออาร์พีซี จำกัด (มหาชน) ตั้งอยู่ที่เขตประกอบการอุตสาหกรรมไออาร์พีซี ตำบลเชิงเนิน อำเภอเมืองระยอง จังหวัดระยอง และตามหนังสือที่อ้างถึง ๒ บริษัท ไออาร์พีซี จำกัด (มหาชน) ได้เสนอรายงานฯ ฉบับแก้ไขเพิ่มเติม ครั้งที่ ๑ ให้สำนักงานนโยบายฯ ดำเนินการตามขั้นตอนการพิจารณารายงาน ความละเอียดแจ้งแล้ว นั้น

สำนักงานนโยบายและแผนทรัพยากรธรรมชาติและสิ่งแวดล้อม ได้เสนอรายงานการประเมินผลกระทบสิ่งแวดล้อมฉบับแก้ไขเพิ่มเติมดังกล่าว ให้คณะกรรมการผู้ชำนาญการพิจารณารายงานการวิเคราะห์ผลกระทบสิ่งแวดล้อม โครงการอุตสาหกรรมปิโตรเลียม ปิโตรเคมี และเคมี พิจารณาในการประชุมครั้งที่ ๖/๒๕๖๔ เมื่อวันที่ ๑๘ ตุลาคม ๒๕๖๔ ซึ่งคณะกรรมการผู้ชำนาญการฯ มีมติให้ความเห็นชอบรายงาน

การเปลี่ยนแปลง...

การเปลี่ยนแปลงรายละเอียดโครงการในรายงานการประเมินผลกระทบสิ่งแวดล้อม โครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น (ครั้งที่ ๓) ของบริษัท ไออาร์พีซี จำกัด (มหาชน) ตั้งอยู่ที่เขตประกอบการอุตสาหกรรมไออาร์พีซี ตำบลเชิงเนิน อำเภอเมืองระยอง จังหวัดระยอง โดยให้บริษัทฯ ปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมที่เสนอไว้ในรายงานฯ อย่างเคร่งครัด รายละเอียดตามสิ่งที่ส่งมาด้วย และให้ประสานบริษัทที่ปรึกษาเพื่อจัดทำรายงานที่ได้รวบรวมรายละเอียดข้อมูลทั้งหมดเรียงตามลำดับการพิจารณา จำนวน ๑ ฉบับ และรายงานฉบับสมบูรณ์ที่ได้แก้ไขเพิ่มเติมตามที่คณะกรรมการผู้ชำนาญการฯ กำหนดแล้ว จำนวน ๑ ฉบับ พร้อมทั้งจัดทำแผ่นบันทึกข้อมูลในรูปแบบ Portable Document Format (PDF) จำนวน ๑ แผ่น และ ๘ แผ่น ตามลำดับ เสนอต่อสำนักงานนโยบายฯ ภายในเวลา ๔๕ วัน เพื่อใช้เป็นเอกสารอ้างอิงและส่งให้หน่วยงานที่เกี่ยวข้องต่อไป และหากได้รับอนุญาตจากหน่วยงานอนุญาตแล้วขอความร่วมมือส่งสำเนาใบอนุญาตพร้อมเงื่อนไขให้สำนักงานนโยบายฯ ทราบด้วย ทั้งนี้ สำนักงานนโยบายฯ ได้มีหนังสือแจ้งบริษัท วิชั่น อี คอนซัลแทนท์ จำกัด เพื่อดำเนินการในส่วนที่เกี่ยวข้องต่อไปด้วยแล้ว

จึงเรียนมาเพื่อโปรดพิจารณา

ขอแสดงความนับถือ

[redacted]

สำนักงานนโยบายและแผนทรัพยากรธรรมชาติและสิ่งแวดล้อม

กองวิเคราะห์ผลกระทบสิ่งแวดล้อม
โทรศัพท์ ๐ ๒๒๖๕ ๖๕๐๐ ต่อ ๖๗๙๕
โทรสาร ๐ ๒๒๖๕ ๖๖๑๖
ไปรษณีย์อิเล็กทรอนิกส์ sarabun@onep.go.th

มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม
และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อม
ที่โครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น
(ภายหลังการเปลี่ยนแปลงรายละเอียดโครงการในรายงานการประเมินผลกระทบสิ่งแวดล้อม โครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น (ครั้งที่ ๓))
ตั้งอยู่ที่เขตประกอบการอุตสาหกรรมไออาร์พีซี ตำบลเชิงเนิน
อำเภอเมืองระยอง จังหวัดระยอง
ของบริษัท ไออาร์พีซี จำกัด (มหาชน) ต้องยึดถือปฏิบัติอย่างเคร่งครัด

ตารางที่ 1
มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม (ช่วงก่อสร้าง)
โครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น
(ภายหลังการเปลี่ยนแปลงรายละเอียดโครงการในรายงานการประเมินผลกระทบสิ่งแวดล้อม โครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น (ครั้งที่ 3))
ของบริษัท ไออาร์พีซี จำกัด (มหาชน)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
1. มาตรการทั่วไป	(1) ปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อมและมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมที่เสนอในรายงานการเปลี่ยนแปลงรายละเอียดโครงการในรายงานการประเมินผลกระทบสิ่งแวดล้อม โครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น (ครั้งที่ 3) ของบริษัท ไออาร์พีซี จำกัด (มหาชน) ตั้งอยู่ที่เขตประกอบการอุตสาหกรรมไออาร์พีซี ตำบลเชิงเนิน อำเภอเมืองระยอง จังหวัดระยอง ซึ่งจัดทำโดยบริษัท วิชั่น อี คอนซัลแทนท์ จำกัด ที่ได้รับความเห็นชอบจากคณะกรรมการผู้ชำนาญการพิจารณารายงานการประเมินผลกระทบสิ่งแวดล้อม (คชก.) อย่างเคร่งครัด	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(2) เมื่อผลการติดตามตรวจสอบได้แสดงให้เห็นถึงปัญหาสิ่งแวดล้อม บริษัท ไออาร์พีซี จำกัด (มหาชน) ต้องดำเนินการปรับปรุงแก้ไขปัญหาเหล่านั้นโดยเร็ว และต้องปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อมและมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมโดยเคร่งครัด เพื่อประโยชน์ในการพิจารณาความเหมาะสมของการกำหนดระยะเวลาการติดตามตรวจสอบต่อไป	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(3) หากเกิดเหตุการณ์ใด ๆ ก็ตามที่อาจก่อให้เกิดผลกระทบต่อคุณภาพสิ่งแวดล้อม บริษัท ไออาร์พีซี จำกัด (มหาชน) ต้องแจ้งให้สำนักงานทรัพยากรธรรมชาติและสิ่งแวดล้อมจังหวัดระยอง สำนักงานอุตสาหกรรมจังหวัดระยอง กรมโรงงานอุตสาหกรรม และสำนักงานนโยบายและแผนทรัพยากรธรรมชาติและสิ่งแวดล้อม (สผ.) ทราบโดยเร็ว เพื่อสำนักงานฯ จะได้ให้ความร่วมมือในการแก้ไขปัญหาดังกล่าว	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(4) บริษัท ไออาร์พีซี จำกัด (มหาชน) ต้องเสนอรายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อมและมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อม โดยสรุปให้หน่วยงานของรัฐซึ่งมีอำนาจอนุญาตตามกฎหมาย ทั้งนี้ การจัดทำรายงานผลการปฏิบัติตามมาตรการฯ และความถี่ในการส่งรายงานผลการปฏิบัติตามมาตรการฯ ให้เป็นไปตามหลักเกณฑ์ วิธีการที่กำหนด ตามประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม เรื่อง หลักเกณฑ์และวิธีการจัดทำรายงานผลการปฏิบัติตามมาตรการที่กำหนดไว้ในรายงานการประเมินผลกระทบสิ่งแวดล้อมซึ่งผู้ดำเนินการ หรือผู้ขออนุญาตจะต้องได้รับอนุญาตให้ดำเนินโครงการหรือกิจการแล้ว พ.ศ. 2561 และกฎหมายที่เกี่ยวข้อง	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 1 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
1. มาตรการทั่วไป (ต่อ)	(5) ในกรณีที่บริษัท ไออาร์พีซี จำกัด (มหาชน) มีความจำเป็นต้องเปลี่ยนแปลงรายละเอียดโครงการ หรือมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม หรือมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อม ให้แตกต่างไปจากที่ได้เสนอไว้ในรายงานการประเมินผลกระทบสิ่งแวดล้อม ตามที่คณะกรรมการผู้ชำนาญการฯ ได้ให้ความเห็นชอบไปแล้ว ให้บริษัท ไออาร์พีซี จำกัด (มหาชน) แจ้งให้หน่วยงานที่มีอำนาจหน้าที่ในการพิจารณาอนุมัติหรืออนุญาตดำเนินการดังนี้ 1) หากหน่วยงานผู้อนุมัติหรืออนุญาตเห็นว่าการแก้ไขเปลี่ยนแปลงดังกล่าวไม่กระทบต่อสาระสำคัญของการประเมินผลกระทบสิ่งแวดล้อมในรายงานการประเมินผลกระทบสิ่งแวดล้อม และเป็นมาตรการที่เกิดผลดีต่อสิ่งแวดล้อมมากกว่าหรือเทียบเท่ามาตรการที่กำหนดไว้ในรายงานการประเมินผลกระทบสิ่งแวดล้อมที่ผ่านการพิจารณาให้ความเห็นชอบจากคณะกรรมการผู้ชำนาญการฯ แล้ว ให้หน่วยงานที่มีอำนาจอนุมัติหรืออนุญาตรับจดแจ้งให้เป็นไปตามหลักเกณฑ์และเงื่อนไขที่กำหนดไว้ในกฎหมายนั้น ๆ พร้อมกับให้จัดทำสำเนาการปรับปรุงแก้ไขมาตรการฯ ที่รับจดแจ้งไว้ ส่งให้สำนักงานนโยบายและแผนทรัพยากรธรรมชาติและสิ่งแวดล้อม เพื่อทราบ 2) หากหน่วยงานผู้อนุมัติหรืออนุญาตเห็นว่าการแก้ไขเปลี่ยนแปลงดังกล่าวอาจกระทบต่อสาระสำคัญในรายงานการประเมินผลกระทบสิ่งแวดล้อมที่ได้รับความเห็นชอบไว้แล้วให้หน่วยงานผู้อนุมัติหรืออนุญาตจัดส่งรายงานการแก้ไขเปลี่ยนแปลงดังกล่าว ให้สำนักงานนโยบายและแผนทรัพยากร ธรรมชาติและสิ่งแวดล้อม เพื่อเสนอให้คณะกรรมการผู้ชำนาญการฯ คณะที่เกี่ยวข้องพิจารณาให้ความเห็นชอบประกอบก่อนการเปลี่ยนแปลง และเมื่อโครงการได้รับอนุมัติหรืออนุญาตให้มีการเปลี่ยนแปลง ให้หน่วยงานอนุมัติหรืออนุญาต แจ้งผลการแก้ไขเปลี่ยนแปลงดังกล่าวให้สำนักงานนโยบายและแผนทรัพยากรธรรมชาติและสิ่งแวดล้อมทราบด้วย	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(6) ว่าจ้างหน่วยงานกลาง (Third Party) เพื่อดำเนินการตรวจสอบผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมของโครงการ ทั้งนี้ ให้แจ้งหน่วยงานอนุญาตทราบอย่างน้อย 2 สัปดาห์ ก่อนดำเนินการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมโดยหน่วยงานกลาง (Third Party)	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(7) กำหนดให้มีการรายงานลักษณะของกิจกรรมต่าง ๆ ที่เกิดขึ้นบริเวณโดยรอบจุดตรวจวัดคุณภาพอากาศขณะทำการตรวจวัด	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 1 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
1. มาตรการทั่วไป (ต่อ)	(8) กำหนดให้มีเกณฑ์การคัดเลือกและประเมินคุณภาพห้องปฏิบัติการการวิเคราะห์และกำหนดให้มีการควบคุมการดำเนินการตรวจวัดคุณภาพสิ่งแวดล้อมของหน่วยงานกลาง (Third Party) ที่มาดำเนินงานให้กับโครงการ เพื่อทวนสอบความน่าเชื่อถือของข้อมูล ทั้งนี้ แนวทางการตรวจสอบและประเมินห้องปฏิบัติการจะเป็นไปตามกระบวนการบริหารคู่ค้า (Supplier Management) เพื่อให้เกิดความโปร่งใสและเป็นธรรม (Corporate Governance) ต่อทั้งโครงการและหน่วยงานกลาง	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
2. คุณภาพอากาศ	(1) ฉีดพรมน้ำบริเวณพื้นที่ก่อสร้าง และเส้นทางการขนส่งภายในพื้นที่โครงการ เพื่อลดการฟุ้งกระจายของฝุ่นละออง อย่างน้อยวันละ 2 ครั้ง (เช้า-บ่าย)	- พื้นที่ก่อสร้าง และเส้นทางการขนส่งภายในพื้นที่โครงการ	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(2) บำรุงรักษาเครื่องยนต์ต่าง ๆ และอุปกรณ์ต่าง ๆ เพื่อลดปริมาณควันเสียที่อาจจะปล่อยออกมาจากอุปกรณ์ก่อสร้างและรถบรรทุกตามแผนการบำรุงรักษาเครื่องยนต์และอุปกรณ์ก่อสร้าง	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(3) ใช้ยานพาหนะที่มีแผ่นกันฝุ่นที่ล้อทั้ง 4 ข้าง	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(4) ทำความสะอาดล้อรถก่อนออกจากพื้นที่โครงการ	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(5) จัดให้มีวัสดุคลุมดิน ทราย หรือวัสดุก่อสร้างอื่น ๆ ที่อาจจะมีการฟุ้งกระจายหรือหล่นบนถนนเพื่อป้องกันปัญหาการฟุ้งกระจายของฝุ่นละออง	- พื้นที่ก่อสร้างและรถที่ใช้ที่ใช้ในการขนส่งวัสดุก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(6) ห้ามเผาทำลายวัสดุหรือมูลฝอยในพื้นที่ก่อสร้าง	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 1 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
3. คุณภาพน้ำ	(1) ห้ามทิ้งขยะมูลฝอย น้ำมัน หรือเศษวัสดุก่อสร้างลงสู่แหล่งน้ำหรือทางระบายน้ำ	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(2) จัดเตรียมพื้นที่สำหรับกองวัสดุอุปกรณ์ให้ห่างจากแหล่งน้ำหรือทางระบายน้ำที่อยู่ใกล้เคียงพื้นที่ก่อสร้าง	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(3) จัดให้มีบ่อรองรับน้ำทิ้งเพื่อตรวจสอบคุณภาพน้ำทิ้งจากการทดสอบถังและระบบท่อ ซึ่งหากไม่พบการปนเปื้อนจะระบายลงรางระบายน้ำของเขตประกอบการอุตสาหกรรมไออาร์พีซี หากพบการปนเปื้อนจะส่งไปบำบัดยังระบบบำบัดน้ำเสียส่วนกลางของเขตประกอบการอุตสาหกรรมไออาร์พีซี	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(4) จัดให้มีห้องน้ำเคลื่อนที่ (Mobile Toilet) สำหรับคนงานในช่วงก่อสร้าง สำหรับน้ำเสียและของเสียที่เกิดขึ้นจะถูกส่งไปกำจัดยังหน่วยงานภายนอกที่ได้รับอนุญาตจากทางราชการ	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
4. เสียง	(1) กำหนดให้ดำเนินกิจกรรมการก่อสร้างที่มีระดับเสียงดังในช่วงเวลากลางวันเท่านั้น (08.00-17.00 น.) และหลีกเลี่ยงกิจกรรมการก่อสร้างที่อาจก่อให้เกิดเสียงดังในช่วงเวลากลางคืนรวมถึงช่วงเวลาอื่น ๆ ในกรณีที่ก่อให้เกิดผลกระทบด้านเสียงต่อชุมชน	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(2) ตรวจสอบสภาพเครื่องจักรก่อนดำเนินงานก่อสร้าง และบำรุงรักษาเครื่องมือและอุปกรณ์ที่ใช้ในการก่อสร้างตลอดจนซ่อมแซมดูแลรักษาให้อยู่ในสภาพดีตลอดเวลาตามแผนงานที่กำหนด	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(3) จัดหาอุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคล เช่น อุปกรณ์อุดหู หรืออุปกรณ์ครอบหู เป็นต้น ให้กับคนงานที่เข้าทำงานในบริเวณที่มีระดับเสียงดังมากกว่าที่กฎหมายกำหนด และควบคุมไม่ให้ผู้ปฏิบัติงานสัมผัสระดับเสียงเกินกว่า 85 เดซิเบลเอ เป็นเวลานานเกินกว่า 8 ชั่วโมง	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(4) เลือกใช้อุปกรณ์และเครื่องจักรในการก่อสร้างที่มีระดับความดังของเสียงไม่เกิน 85 เดซิเบลเอ ที่ระยะ 15 เมตร และให้ทำการตรวจสอบซ่อมบำรุงให้มีประสิทธิภาพในการใช้งานที่ดีตามแผนบำรุงรักษาเครื่องจักร เพื่อลดระดับความดังของเสียงจากการทำงานของเครื่องจักรที่เสื่อมสภาพ กรณีที่เครื่องจักร/อุปกรณ์มีระดับเสียงดังเกิน 85 เดซิเบลเอ ต้องมีการติดตั้งอุปกรณ์ช่วยลดเสียงดัง เช่น Silencer เป็นต้น	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(5) กำหนดระยะเวลาการปฏิบัติงานของคนงานในบริเวณที่มีเสียงดังเกิน 85 เดซิเบลเอ ให้ทำงานได้ไม่เกิน 8 ชั่วโมง/วัน รวมทั้งจัดให้มีการหยุดพักงานชั่วคราวหรือมีระบบหมุนเวียนคนงานที่ปฏิบัติงานในพื้นที่มีเสียงดังไปยังพื้นที่อื่น ๆ	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 1 (ต่อ)


องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
5. การคมนาคม	(1) กำหนดให้พนักงานขับรถปฏิบัติตามกฎจราจรอย่างเคร่งครัด	- พื้นที่ก่อสร้างและถนนภายนอกโครงการ	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(2) ตรวจเช็กสภาพยานพาหนะก่อนการใช้งาน เช่น ระบบเบรก เป็นต้น ตามคู่มือการบำรุงรถ	- รถบรรทุกขนวัสดุอุปกรณ์	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(3) กำหนดให้ผู้รับเหมาวางแผนการใช้เส้นทางคมนาคมขนส่งเครื่องจักรและอุปกรณ์ โดยให้หลีกเลี่ยงเส้นทางที่มีการจราจรหนาแน่น เช่น ทางหลวงหมายเลข 3 ช่วงที่ผ่านเทศบาลนครระยอง เป็นต้น รวมถึงเส้นทางอื่น ๆ ที่พบว่าอาจก่อให้เกิดผลกระทบด้านการจราจรต่อชุมชน เพื่อลดผลกระทบด้านการคมนาคมขนส่งที่อาจเกิดขึ้น และหลีกเลี่ยงการขนส่งในช่วงเวลากลางคืนและช่วงเวลาเร่งด่วน โดยเฉพาะในช่วงเวลา 07.30-8.30 น. และเวลา 16.30-17.30 น. รวมถึงช่วงเวลาอื่น ๆ ที่โครงการพบว่าอาจก่อให้เกิดผลกระทบด้านการจราจรต่อชุมชน	- บริเวณเส้นทางขนส่ง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(4) จัดกลุ่มการขนส่งคนงานตามลักษณะของกิจกรรม โดยแบ่งเป็นชุด ได้แก่ ชุดเข้างานก่อน 07.30 น. และชุดเข้างานหลัง 08.30 น. และคนงานกลุ่มใดเข้างานก่อนให้เลิกงานก่อนเป็นการเหลื่อมเวลาการทำงานเพื่อลดผลกระทบจากการจราจร โดยในการจัดกลุ่มคนงานให้พิจารณาให้สอดคล้องกับลักษณะงาน และผลกระทบจากการจราจรในพื้นที่	- บริเวณเส้นทางขนส่งคนงาน	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(5) กำหนดให้รถบรรทุกที่ขนส่งวัสดุก่อสร้าง และรถขนส่งคนงานที่สัญจรผ่านบริเวณชุมชนหรือพื้นที่ภายนอกโครงการให้ใช้ความเร็วได้ไม่เกินที่กฎหมายกำหนดอย่างเคร่งครัด	- บริเวณเส้นทางขนส่ง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(6) จำกัดความเร็วรถยนต์เข้า-ออกพื้นที่โครงการไม่เกิน 20 กิโลเมตร/ชั่วโมง โดยการแจ้งให้ผู้รับเหมาทราบ พร้อมทั้งติดป้ายจำกัดความเร็วรถในบริเวณพื้นที่ก่อสร้าง	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(7) ควบคุมน้ำหนักในการบรรทุกไม่ให้เกินกฎหมายที่กำหนดในการบรรทุก เพื่อป้องกันความเสียหายของผิวการจราจร	- บริเวณเส้นทางขนส่งวัสดุอุปกรณ์	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(8) ติดตั้งป้ายเตือน สัญญาณไฟกะพริบ หรือสัญลักษณ์บริเวณทางร่วม/ทางแยก ก่อนเข้าพื้นที่โครงการ	- บริเวณถนนเข้า-ออกพื้นที่โครงการ	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(9) ประสานงานกับหน่วยงานจราจรในท้องที่ เพื่ออำนวยความสะดวก เมื่อมีการขนส่งโดยรถบรรทุกขนาดใหญ่	- บริเวณเส้นทางขนส่งวัสดุอุปกรณ์	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 1 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
6. กากของเสีย	(1) กำหนดไม่ให้มีการทิ้งขยะมูลฝอยลงในทางระบายน้ำท่อน้ำทิ้ง และแหล่งน้ำต่าง ๆ ในบริเวณใกล้กับพื้นที่ก่อสร้าง	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(2) ห้ามเผาขยะทุกชนิดในพื้นที่โครงการ	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(3) จัดให้มีภาชนะสำหรับบรรจุขยะและกากของเสียพร้อมทั้งติดฉลากที่ภาชนะ	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(4) รวบรวมขยะมูลฝอยที่เกิดจากการอุปโภคบริโภค (เช่น เศษอาหาร เป็นต้น) ไว้ในภาชนะที่ปิดมิดชิดและติดต่อให้หน่วยงานภายนอกเข้ามารับเพื่อนำไปกำจัดต่อไป	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(5) คัดแยกเศษวัสดุที่เกิดจากกิจกรรมการก่อสร้าง เช่น เศษไม้และเศษโลหะ เพื่อนำไปจำหน่าย สำหรับเศษดินหรือทรายจะพิจารณานำไปใช้ในการณีที่หรือปรับพื้นที่ภายในโครงการ	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
7. การระบายน้ำและการควบคุมน้ำท่วม	(1) จัดให้มีรางระบายน้ำชั่วคราวจากกิจกรรมการก่อสร้างต่อเชื่อมกับรางระบายน้ำปัจจุบันของโครงการ	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(2) ห้ามทิ้งขยะมูลฝอย น้ำมัน หรือเศษวัสดุก่อสร้างลงสู่แหล่งน้ำและรางระบายน้ำโดยเด็ดขาด	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(3) จัดเตรียมพื้นที่สำหรับกองวัสดุอุปกรณ์ให้ห่างจากแหล่งน้ำหรือทางระบายน้ำที่อยู่ใกล้เคียงพื้นที่ก่อสร้าง	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(4) ในกรณีที่ตะกอนดินและเศษวัสดุจากการก่อสร้างตกลงในรางระบายน้ำ ให้บริษัทรับเหมาทำการขุดลอกตะกอนดินและเศษวัสดุออกจากรางระบายน้ำ	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 1 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
8. สังคมและเศรษฐกิจ	(1) แจ้งกำหนดการก่อสร้างและแผนการดำเนินงานก่อสร้างให้คณะกรรมการ EIA Monitoring ซึ่งประกอบด้วย ผู้แทนต่าง ๆ เช่น ผู้แทนหน่วยงานราชการ ผู้ทรงคุณวุฒิ ผู้แทนชุมชน เป็นต้น เพื่อรับทราบ	- คณะกรรมการ EIA Monitoring	- ก่อนการก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(2) กำหนดให้บริษัทผู้รับเหมาพิจารณารับคนงานในท้องถิ่นที่มีความสามารถเหมาะสมตามเกณฑ์กำหนดของโครงการเข้าทำงานเป็นอันดับแรก เพื่อสร้างทัศนคติที่ดีระหว่างชุมชนและโครงการ รวมทั้งเป็นการสร้างงานให้กับประชาชนในท้องถิ่นโดยให้ผู้รับเหมาดำเนินการประชาสัมพันธ์ให้ชุมชนทราบในช่วงที่มีตำแหน่งงานว่าง	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(3) จัดให้มีขั้นตอนการรับเรื่องร้องเรียนและช่องทางการรับเรื่องร้องเรียนจากโครงการ เช่น โทรศัพท์ โดยสามารถติดต่อได้ที่ศูนย์ควบคุมภาวะฉุกเฉิน (Emergency Control Center : ECC) ตลอด 24 ชั่วโมง ทางหมายเลขโทรศัพท์ 0 3880 2560 และ 1800 800 008 ทางจดหมาย หรือแจ้งผ่านเจ้าหน้าที่มวลชนสัมพันธ์โดยตรง เป็นต้น พร้อมทั้งประชาสัมพันธ์ช่องทางการรับเรื่องร้องเรียนให้ชุมชนทราบ	- ชุมชนใกล้เคียง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(4) หากมีข้อร้องเรียนต้องปฏิบัติตามขั้นตอนการรับเรื่องร้องเรียน (**รูปที่ 1**) โดยหากพบว่าข้อร้องเรียนที่เกิดขึ้นเป็นผลกระทบจากการดำเนินงานของโครงการ ทางโครงการจะต้องเร่งแก้ไขโดยเร็วที่สุด พร้อมทั้งกำหนดมาตรการป้องกันไม่ให้เกิดซ้ำ และรายงานผลการแก้ไขต่อผู้ร้องเรียนและฝ่ายบริหารของโครงการ	- ชุมชนใกล้เคียง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(5) กำหนดให้มีการประชาสัมพันธ์ และชี้แจงแผนการก่อสร้างพร้อมทั้งมาตรการด้านสิ่งแวดล้อมให้ชุมชนและโรงงานที่อยู่ใกล้เคียงทราบล่วงหน้าอย่างน้อย 15 วัน ก่อนเริ่มกิจกรรมการก่อสร้างโดยผ่านช่องทางประชาสัมพันธ์ต่าง ๆ เช่น ป้ายประชาสัมพันธ์ เป็นต้น	- พื้นที่ชุมชนและโรงงานที่อยู่ใกล้เคียง	- ก่อนเริ่มกิจกรรมการก่อสร้างอย่างน้อย 15 วัน	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(6) ติดป้ายประชาสัมพันธ์การก่อสร้าง (ขนาด 2.4 เมตร x 4.8 เมตร) ให้ประชาชนและสถานประกอบการในพื้นที่ใกล้เคียงรับทราบ เพื่อให้ประชาชนระมัดระวังการสัญจรผ่านบริเวณพื้นที่ก่อสร้าง	- ชุมชนใกล้เคียง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(7) กำหนดให้มีมาตรการในการชดเชยค่าเสียหาย ในกรณีที่ได้รับผลกระทบจากการก่อสร้างของโครงการต่อผู้ได้รับผลกระทบ ได้แก่ พนักงานบริษัท ผู้รับเหมา และประชาชน	- ชุมชนใกล้เคียง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)



ตารางที่ 1 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
9. อาชีวอนามัย และความปลอดภัย	**เรื่องทั่วไป** (1) จัดทำป้ายเตือนการสวมใส่อุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคล	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(2) จัดให้มีเจ้าหน้าที่ตรวจสอบวิธีการปฏิบัติงาน สภาพของเครื่องจักร/อุปกรณ์ สภาพแวดล้อมในการทำงาน และการสวมใส่อุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคล เพื่อให้การปฏิบัติงานมีความปลอดภัย	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(3) ติดตั้งสัญญาณเตือนภัยให้สามารถได้ยินทั่วถึงทั้งโครงการ	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(4) จัดเก็บเครื่องมือ อุปกรณ์ ให้อยู่ในสภาพดี รวมทั้งบำรุงรักษาและตรวจสอบอย่างสม่ำเสมอ เพื่อลดอุบัติเหตุในการทำงาน	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(5) รวบรวมสถิติอุบัติเหตุ เหตุการณ์เกือบเกิดอุบัติเหตุ สาเหตุและอันตรายจากการทำงาน และเสนอแนะมาตรการป้องกันแก้ไข เพื่อป้องกันไม่ให้เกิดซ้ำ	- พื้นที่ก่อสร้างและเส้นทางที่ต้องขนวัสดุอุปกรณ์	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(6) จัดให้มีอุปกรณ์สำหรับการปฐมพยาบาลเบื้องต้น รวมทั้งขั้นตอนการประสานงานสำหรับจัดส่งผู้บาดเจ็บในกรณีเกิดเหตุรุนแรง เพื่อนำส่งสถานพยาบาลบริเวณใกล้เคียง	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(7) จัดให้มีหน่วยงานปฐมพยาบาล พยาบาล หรือเจ้าหน้าที่พร้อมเวชภัณฑ์ในพื้นที่ และรถยนต์เพื่อใช้งานในกรณีเกิดเหตุฉุกเฉิน	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(8) กำหนดให้มีการจัดทำแผนความปลอดภัยในงานก่อสร้างให้สอดคล้องตามกฎกระทรวง กำหนดมาตรฐานในการบริหาร จัดการ และดำเนินการด้านความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงานเกี่ยวกับงานก่อสร้าง พ.ศ. 2564 ที่กำหนดไว้อย่างเคร่งครัด และได้นำหลักเกณฑ์และมาตรการด้านอาชีวอนามัยและความปลอดภัย มากำหนดเป็นระเบียบปฏิบัติงานและเงื่อนไข/ข้อตกลงกับบริษัทผู้รับเหมาที่เข้ามาปฏิบัติงานให้กับโครงการในสัญญาว่าจ้าง	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(9) จัดให้มีการตรวจสุขภาพคนงานก่อสร้างก่อนเริ่มปฏิบัติงาน ซึ่งกำหนดในสัญญาการปฏิบัติงาน โดยกำหนดให้ผู้รับเหมามีการตรวจสุขภาพทั่วไป และสุขภาพตามปัจจัยเสี่ยง	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 1 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
9. อาชีวอนามัย และความปลอดภัย (ต่อ)	**การควบคุมผู้รับเหมาและบริษัทรับเหมาที่เข้ามาทำงานในพื้นที่** (10) จัดให้มีระเบียบควบคุมผู้รับเหมาและบริษัทรับเหมาที่เข้ามาทำงานในพื้นที่	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(11) ผู้รับเหมาของโครงการต้องปฏิบัติตามกฎหมายออกตามความในพระราชบัญญัติคุ้มครองแรงงาน และกฎกระทรวงและกฎหมายความปลอดภัยอื่น ๆ ที่เกี่ยวข้อง	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(12) ผู้รับเหมาต้องพิจารณาสิ่งที่จะต้องจัดเตรียม จัดหา จัดซื้อ วัสดุอุปกรณ์ บุคลากร ในการปฏิบัติตามระเบียบของบริษัทฯ และ/หรือเงื่อนไขเพิ่มเติมต่าง ๆ เพื่อให้เป็นไปตามสิ่งที่จะต้องรับผิดชอบเมื่อเข้ามาปฏิบัติงานในบริษัทฯ โดยดูจากลักษณะงานและความเสี่ยง	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(13) ผู้รับเหมาต้องผ่านการอบรมและทดสอบความรู้ทางด้านความปลอดภัยจากทางบริษัทฯ ก่อนการเข้าทำงาน	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(14) ผู้รับเหมาต้องจัดเตรียมอุปกรณ์ความปลอดภัยส่วนบุคคล (PPE) พื้นฐาน (หมวกนิรภัย รองเท้านิรภัย และแว่นตานิรภัย) ที่ได้มาตรฐานผลิตภัณฑ์อุตสาหกรรม (มอก.) และอุปกรณ์ PPE ชนิดที่มีมาตรฐานรับรองอื่น ขึ้นอยู่กับลักษณะงาน และเป็นไปตามกฎหมายที่เกี่ยวข้อง ก่อนที่จะเข้าผ่านจุด รปภ. และก่อนเข้าพื้นที่ทำงาน	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(15) ควบคุมให้ผู้รับเหมาปฏิบัติตามเงื่อนไขสัญญาการดำเนินงานด้านอาชีวอนามัยและความปลอดภัย และระเบียบปฏิบัติด้านความปลอดภัยของทางโครงการ	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(16) ห้ามนำบุหรี่ ไฟแช็ก หรืออุปกรณ์สื่อสารที่ไม่ป้องกันการระเบิด หรือมีโอกาสก่อให้เกิดความร้อน/ประกายไฟ เช่น โทรศัพท์มือถือ วิทยุ เป็นต้น เข้าเขตที่ประกาศเป็นพื้นที่ควบคุมประกายไฟ	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(17) เครื่องยนต์ เครื่องจักรที่สันดาปภายใน หรืออุปกรณ์ที่มีการทำงานคล้ายกัน จะต้องสวมท่อป้องกันประกายไฟก่อนเข้าเขตที่ประกาศเป็นพื้นที่ควบคุมประกายไฟ	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(18) ดูแลความสะอาดในพื้นที่ทำงาน พื้นที่ Work Shop เป็นประจำทุกวันโดยแยกของเหลือใช้หรือขยะทั้งที่เป็นอันตราย และไม่เป็นอันตราย โดยพิจารณาแยกหรือกำจัดทิ้งเพื่อมิให้เป็นอันตรายต่อสุขภาพ อนามัย และความปลอดภัยของลูกจ้างโดยต้องขนออกทุกวัน	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 1 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
9. อาชีวอนามัย และความปลอดภัย (ต่อ)	(19) ก่อนการส่งมอบงานต้องรื้อถอนสิ่งก่อสร้างต่าง ๆ ที่ใช้ประกอบในการทำงาน รวมทั้งจัดเก็บเศษวัสดุที่เลิกใช้งานแล้วซึ่งเป็นผลจากการทำงานของผู้รับเหมาให้หมด	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(20) ผู้รับเหมาต้องแต่งตั้งผู้รับผิดชอบในแต่ละโครงการ ได้แก่ ผู้จัดการโครงการ (Site Manager) หัวหน้างาน เจ้าหน้าที่ความปลอดภัยในการทำงาน (จป.) รวมทั้งต้องจัดให้มีผู้เฝ้าระวังไฟ (Fire Watch Man) ในกรณีทำงานที่ทำให้เกิดมีประกายไฟภายนอก (Open Fire) ในพื้นที่อันตราย (Hazardous Area)	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(21) ผู้รับเหมาโดย Site Manager ต้องจัดทำรายงานการชี้บ่งอันตรายและประเมินความเสี่ยงก่อนเริ่มงานด้วยวิธี What if Analysis หรือวิธีการอื่น ๆ ที่เหมาะสมกับลักษณะงาน ในงานทุกงาน	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(22) ทุกครั้งที่มีอุบัติเหตุ หรือเหตุการณ์เกือบเกิดอุบัติเหตุ ให้ Site Manager ดำเนินการทบทวนการชี้บ่งอันตรายและประเมินความเสี่ยงใหม่ และออกมาตรการป้องกันมิให้เกิดซ้ำ รวมทั้งจัดทำเอกสารบันทึก	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(23) กำหนดให้มีระเบียบปฏิบัติสำหรับงานแต่ละประเภทในการก่อสร้างเพื่อให้เกิดความปลอดภัยในการทำงาน เช่น - การใช้อุปกรณ์ไฟฟ้า - งานก่อสร้างหรืองานที่สามารถกั้นบริเวณได้ - การใช้ปั้นจั่นชนิดเคลื่อนที่ได้ (รถเครน) - การใช้รถยก - การทำงานบนที่สูง - งานขุดดิน การใช้น้ำแรงดันสูง (High Pressure Jet Gun) - การถ่ายภาพด้วยรังสี - งานประเภทที่ไม่มีประกายไฟ (Cold Work) - งานประเภทที่มีความร้อนหรือประกายไฟ (Hot Work) - งานในที่อับอากาศ - การใช้ก๊าซในงานติดตั้ง เชื่อม - งานพ่นทราย - การใช้รถยนต์	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 1 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
9. อาชีวอนามัย และความปลอดภัย (ต่อ)	(24) บริษัทผู้รับเหมาที่ไม่ปฏิบัติตามระเบียบควบคุมผู้รับเหมาและบริษัทรับเหมาที่เข้ามาทำงานในพื้นที่จะต้องได้รับโทษตามระเบียบบริษัท IRPC	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(25) ในกรณีที่มีข้อร้องเรียนถึงความเสียหายหรือความเดือดร้อนรำคาญ อันเป็นผลมาจากกิจกรรมภายในที่พักคนงานในพื้นที่ชุมชน โครงการและผู้รับเหมาต้องดำเนินการแก้ปัญหาให้ได้ข้อยุติโดยเร็ว	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	การอบรมด้านความปลอดภัยในการทำงาน (26) ผู้รับเหมาต้องผ่านการอบรมและทดสอบความรู้ทางด้านความปลอดภัยจากทางบริษัทฯ ก่อนการเข้าทำงานโดยหัวข้อการอบรมประกอบด้วย กฎระเบียบ/ข้อควรปฏิบัติด้านความปลอดภัยสำหรับการเข้าทำงาน สัญญาณเตือนภัย และป้ายสัญลักษณ์ความปลอดภัย	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	การขออนุญาตทำงาน (27) การปฏิบัติงานที่มีความเสี่ยง เช่น การทำงานในที่อับอากาศ (Confined Space Entry) เป็นต้น ผู้รับเหมาจะต้องจัดให้มีการบริหารจัดการให้ถูกต้องตามกฎหมายแจ้งขอทำงาน	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(28) พื้นที่ที่มีการขอใบอนุญาตทำงาน (Work Permit) ต้องตรวจสอบอุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคลและตรวจสอบสภาพพื้นที่ก่อนให้เข้าไปทำงาน ก่อนพิจารณาอนุมัติให้เข้าทำงาน รวมทั้งต้องดูแลความปลอดภัยในระหว่างการทำงาน และตรวจสอบหลังปฏิบัติงานแล้วเสร็จ	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	การป้องกันผลกระทบด้านเสียง (29) เลือกใช้อุปกรณ์และเครื่องจักรในการก่อสร้างที่มีระดับความดังของเสียงไม่เกิน 85 เดซิเบลเอ ที่ระยะ 15 เมตร	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(30) จัดหาอุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคล เช่น อุปกรณ์อุดหู หรืออุปกรณ์ครอบ เป็นต้น ให้กับคนงานที่เข้าทำงานในบริเวณที่มีระดับเสียงดังมากกว่าที่กฎหมายกำหนด	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(31) กำหนดระยะเวลาการปฏิบัติงานของคนงานในบริเวณที่มีเสียงดังเกิน 85 เดซิเบลเอ ให้ทำงานได้ไม่เกิน 8 ชั่วโมง/วัน รวมทั้งจัดให้มีการหยุดพักงานชั่วคราวหรือมีระบบหมุนเวียนคนงานที่ปฏิบัติงานในพื้นที่มีเสียงดังไปยังพื้นที่อื่น	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 1 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
9. อาชีวอนามัย และความปลอดภัย (ต่อ)	**อุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคล** (32) ผู้รับเหมาต้องจัดเตรียมอุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคล (PPE) พื้นฐาน (หมวกนิรภัย รองเท้านิรภัย และแว่นตานิรภัย) ที่ได้มาตรฐานผลิตภัณฑ์อุตสาหกรรม (มอก.) และอุปกรณ์ PPE ชนิดที่มีมาตรฐานรับรองอื่น ขึ้นอยู่กับลักษณะงาน และเป็นไปตามกฎหมายที่เกี่ยวข้องและต้องผ่านการตรวจสอบสภาพก่อนการใช้งาน	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(33) จัดอบรมและให้ความรู้แก่คนงานในการใช้อุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคล รวมทั้งตรวจสอบและควบคุมดูแลให้มีการใช้อุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคลอย่างถูกต้องและเหมาะสมกับประเภทของงานอย่างเคร่งครัด	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	กรณีฉุกเฉิน (34) เมื่อเกิดเหตุฉุกเฉินจะมีสัญญาณไซเรนแจ้งเตือนผู้ปฏิบัติงานจะต้องทำตามวิธีปฏิบัติดังต่อไปนี้ - หยุดทำงานทันที เมื่อได้ยินสัญญาณเตือนภัย - ปิดสวิตช์เครื่องจักรที่ใช้งานอยู่ - ผู้ที่ทำงานในที่อับอากาศจะต้องออกจากบริเวณนั้นทันที - ผู้ที่ทำงานบนที่สูง ให้ไต่บันไดลงมาช้า ๆ - เมื่อเกิดก๊าซรั่วให้ออกจากบริเวณนั้นทันที - ผู้ที่กำลังขับขี่ยานพาหนะต้องจอด หรือชิดขอบทางทันที - ให้ผู้รับเหมาอยู่รวมกันที่จุดรวมพลหรือที่ที่ทางบริษัทฯ จัดให้ - ผู้รับผิดชอบเรื่องกระแสไฟ จะต้องปิดกระแสไฟฟ้า - ห้ามมุงดูการดับเพลิงของพนักงานดับเพลิง - หัวหน้าคนงานต้องตรวจสอบว่าพนักงานอยู่ครบหรือไม่ - เมื่อเหตุการณ์เป็นปกติจะมีสัญญาณเตือนภัยดัง 1 ครั้ง ยาว ๆ - เพื่อป้องกันการเกิดอัคคีภัย จะต้องมีการเตรียมพร้อมเสมอ ดังนั้นเมื่อเห็นเหตุไฟไหม้ในโรงงานให้โทรแจ้งที่หมายเลขโทรศัพท์ 77 - ทางบริษัทฯ มีรถพยาบาลคอยให้ความช่วยเหลือตลอด 24 ชั่วโมง ให้โทรแจ้งที่หมายเลข 1111 หรือ 61	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 1 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
9. อาชีวอนามัยและความปลอดภัย (ต่อ)	(35) การระงับเหตุฉุกเฉินที่เกิดขึ้นในช่วงก่อสร้างจะดำเนินงานตามแผนฉุกเฉินโรงงาน IRPC	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	อุบัติเหตุ (36) ควบคุมให้คนงานปฏิบัติตามมาตรการด้านอาชีวอนามัยและความปลอดภัยอย่างเคร่งครัด เพื่อป้องกันอุบัติเหตุ	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(37) ควบคุมให้ปฏิบัติตามมาตรการด้านคมนาคม เพื่อป้องกันอุบัติเหตุที่อาจเกิดขึ้นจากการขนส่งวัสดุอุปกรณ์ก่อสร้าง	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(38) จดบันทึกสถิติอุบัติเหตุ และเหตุการณ์เกือบเกิดอุบัติเหตุ โดยบันทึกสาเหตุ ความสูญเสีย และมาตรการป้องกันแก้ไขเพื่อป้องกันไม่ให้เกิดซ้ำ	- พื้นที่ก่อสร้างและเส้นทางขนวัสดุอุปกรณ์	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
10. สุขภาพ	(1) ส่งข้อมูลคนงานก่อสร้างให้หน่วยงานสาธารณสุขและองค์กรปกครองส่วนท้องถิ่นในพื้นที่ทราบ เพื่อเตรียมความพร้อมในการรองรับด้านบริการสาธารณสุขในพื้นที่	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(2) กำกับให้บริษัทผู้รับเหมาจัดทำข้อมูลการตรวจสุขภาพของคนงานก่อนเข้าปฏิบัติงาน พร้อมทั้งปฏิบัติตามกฎหมายแรงงานว่าด้วยการตรวจสุขภาพร่างกายประจำปี ตรวจสุขภาพตามความเสี่ยง สำหรับคนงานก่อสร้างที่ปฏิบัติงานในพื้นที่ที่มีปัจจัยเสี่ยง เช่น สารเคมีอันตราย เป็นต้น (ถ้ามี) และกำหนดให้มีการเก็บบันทึกข้อมูลการตรวจสุขภาพ โดยเมื่อก่อสร้างโครงการแล้วเสร็จจะมอบบันทึกผลการตรวจสุขภาพให้แก่คนงานก่อสร้าง	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(3) จัดให้มีหน่วยปฐมพยาบาลที่มีพยาบาลประจำในพื้นที่ก่อสร้างของโครงการ พร้อมอุปกรณ์การปฐมพยาบาลให้เป็นไปตามระเบียบหรือกฎหมายที่เกี่ยวข้องเพื่อรองรับคนงานก่อสร้างในพื้นที่ก่อสร้างของโครงการ รวมทั้งจัดให้มีหน่วยส่งต่อผู้ป่วยในกรณีฉุกเฉิน	- พื้นที่ก่อสร้าง	- ตลอดช่วงก่อสร้าง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2
มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม (ช่วงดำเนินการ)
โครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น
(ภายหลังการเปลี่ยนแปลงรายละเอียดโครงการในรายงานการประเมินผลกระทบสิ่งแวดล้อม โครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น (ครั้งที่ 3))
ของบริษัท ไออาร์พีซี จำกัด (มหาชน)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
1. มาตรการทั่วไป	(1) ปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อมและมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมที่เสนอในรายงานการเปลี่ยนแปลงรายละเอียดโครงการในรายงานการประเมินผลกระทบสิ่งแวดล้อม โครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น (ครั้งที่ 3) ของบริษัท ไออาร์พีซี จำกัด (มหาชน) ตั้งอยู่ที่เขตประกอบการอุตสาหกรรมไออาร์พีซี ตำบลเชิงเนิน อำเภอเมืองระยอง จังหวัดระยอง ซึ่งจัดทำโดยบริษัท วิชั่น อี คอนซัลแทนท์ จำกัด ที่ได้รับความเห็นชอบจากคณะกรรมการผู้ชำนาญการพิจารณารายงานการประเมินผลกระทบสิ่งแวดล้อม (คชก) อย่างเคร่งครัด	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(2) เมื่อผลการติดตามตรวจสอบได้แสดงให้เห็นถึงปัญหาสิ่งแวดล้อม บริษัท ไออาร์พีซี จำกัด (มหาชน) ต้องดำเนินการปรับปรุงแก้ไขปัญหาเหล่านั้นโดยเร็ว และต้องปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อมและมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมโดยเคร่งครัด เพื่อประโยชน์ในการพิจารณาความเหมาะสมของการกำหนดระยะเวลาการติดตามตรวจสอบต่อไป	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(3) หากเกิดเหตุการณ์ใด ๆ ก็ตามที่อาจก่อให้เกิดผลกระทบต่อคุณภาพสิ่งแวดล้อม บริษัท ไออาร์พีซี จำกัด (มหาชน) ต้องแจ้งให้สำนักงานทรัพยากรธรรมชาติและสิ่งแวดล้อมจังหวัดระยอง สำนักงานอุตสาหกรรมจังหวัดระยอง กรมโรงงานอุตสาหกรรม และสำนักงานนโยบายและแผนทรัพยากรธรรมชาติและสิ่งแวดล้อม (สผ.) ทราบโดยเร็ว เพื่อสำนักงานฯ จะได้ให้ความร่วมมือในการแก้ไขปัญหาดังกล่าว	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
1. มาตรการทั่วไป (ต่อ)	(4) บริษัท ไออาร์พีซี จำกัด (มหาชน) ต้องเสนอรายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อมและมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อม โดยสรุปให้หน่วยงานของรัฐ ซึ่งมีอำนาจอนุญาตตามกฎหมาย ทั้งนี้ การจัดทำรายงานผลการปฏิบัติตามมาตรการฯ และความถี่ในการส่งรายงานผลการปฏิบัติตามมาตรการฯ ให้เป็นไปตามหลักเกณฑ์ วิธีการที่กำหนด ตามประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม เรื่อง หลักเกณฑ์และวิธีการจัดทำรายงานผลการปฏิบัติตามมาตรการที่กำหนดไว้ในรายงานการประเมินผลกระทบสิ่งแวดล้อมซึ่งผู้ดำเนินการ หรือผู้ขออนุญาตจะต้องได้รับอนุญาตให้ดำเนินโครงการหรือกิจการแล้ว พ.ศ. 2561 และกฎหมายที่เกี่ยวข้อง	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(5) ในกรณีที่บริษัท ไออาร์พีซี จำกัด (มหาชน) มีความจำเป็นต้องเปลี่ยนแปลงรายละเอียดโครงการ หรือมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม หรือมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อม ให้แตกต่างไปจากที่ได้เสนอไว้ในรายงานการประเมินผลกระทบสิ่งแวดล้อม ตามที่คณะกรรมการผู้ชำนาญการฯ ได้ให้ความเห็นชอบไปแล้ว ให้บริษัท ไออาร์พีซี จำกัด (มหาชน) แจ้งให้หน่วยงานที่มีอำนาจหน้าที่ในการพิจารณาอนุมัติหรืออนุญาตดำเนินการดังนี้ 1) หากหน่วยงานผู้อนุมัติหรืออนุญาตเห็นว่าการแก้ไขเปลี่ยนแปลงดังกล่าวไม่กระทบต่อสาระสำคัญของการประเมินผลกระทบสิ่งแวดล้อมในรายงานการประเมินผลกระทบสิ่งแวดล้อม และเป็นมาตรการที่เกิดผลดีต่อสิ่งแวดล้อมมากกว่าหรือเทียบเท่ามาตรการที่กำหนดไว้ในรายงานการประเมินผลกระทบสิ่งแวดล้อมที่ผ่านการพิจารณาให้ความเห็นชอบจากคณะกรรมการผู้ชำนาญการฯ แล้ว ให้หน่วยงานที่มีอำนาจอนุมัติหรืออนุญาตรับจดแจ้งให้เป็นไปตามหลักเกณฑ์และเงื่อนไขที่กำหนดไว้ในกฎหมายนั้น ๆ พร้อมกับให้จัดทำสำเนาการปรับปรุงแก้ไขมาตรการฯ ที่รับจดแจ้งไว้ ส่งให้สำนักงานนโยบายและแผนทรัพยากรธรรมชาติและสิ่งแวดล้อม เพื่อทราบ 2) หากหน่วยงานผู้อนุมัติหรืออนุญาตเห็นว่าการแก้ไขเปลี่ยนแปลงดังกล่าวอาจกระทบต่อสาระสำคัญในรายงานการประเมินผลกระทบสิ่งแวดล้อมที่ได้รับความเห็นชอบไว้แล้วให้หน่วยงานผู้อนุมัติหรืออนุญาตจัดส่งรายงานการแก้ไขเปลี่ยนแปลงดังกล่าว ให้สำนักงานนโยบายและแผนทรัพยากรธรรมชาติและสิ่งแวดล้อม เพื่อเสนอให้คณะกรรมการผู้ชำนาญการฯ คณะที่เกี่ยวข้องพิจารณาให้ความเห็นชอบประกอบก่อนการเปลี่ยนแปลง และเมื่อโครงการได้รับอนุมัติหรืออนุญาตให้มีการเปลี่ยนแปลง ให้หน่วยงานอนุมัติหรืออนุญาต แจ้งผลการแก้ไขเปลี่ยนแปลงดังกล่าวให้สำนักงานนโยบายและแผนทรัพยากรธรรมชาติและสิ่งแวดล้อมทราบด้วย	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
1. มาตรการทั่วไป (ต่อ)	(6) สรุปผลการศึกษา HAZOP ของโครงการและนำเสนอตัวอย่างกรณีที่เกิดผลกระทบสูงสุด พร้อมแสดง P&ID และเหตุผลการนำเสนอตัวอย่างดังกล่าวในเชิงเปรียบเทียบกับหน่วยอื่น	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(7) ว่าจ้างหน่วยงานกลาง (Third Party) เพื่อดำเนินการตรวจสอบผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมของโครงการ ทั้งนี้ ให้แจ้งหน่วยงานอนุญาตทราบอย่างน้อย 2 สัปดาห์ ก่อนดำเนินการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมโดยหน่วยงานกลาง (Third Party)	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(8) เมื่อโครงการดำเนินการผลิตเต็มกำลังการผลิตของเครื่องจักร และมีสภาวะการผลิตคงตัว (Steady State) แล้ว พบว่าอัตราการระบายสารมลพิษทางอากาศข้างต้นมีค่าน้อยกว่าค่าที่ระบุไว้ในรายงาน บริษัท ไออาร์พีซี จำกัด (มหาชน) ต้องยึดถือค่าที่ต่ำนั้นเป็นค่าควบคุม และแจ้งให้สำนักงานนโยบายและแผนทรัพยากรธรรมชาติและสิ่งแวดล้อมทราบ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(9) หากผลการตรวจวัดคุณภาพอากาศในบรรยากาศบริเวณพื้นที่โครงการและบริเวณโดยรอบมีแนวโน้มเข้าใกล้ค่ามาตรฐานคุณภาพอากาศในบรรยากาศ โครงการจะต้องให้ความร่วมมือกับหน่วยงานที่เกี่ยวข้อง ดำเนินการแก้ไขผลกระทบด้านคุณภาพอากาศ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(10) ในกรณีที่ผลการตรวจวัดมลพิษจากแหล่งกำเนิดและผลการตรวจวัดคุณภาพสิ่งแวดล้อมในพื้นที่โครงการมีแนวโน้มสูงขึ้นจากค่าที่ตรวจวัดได้ในช่วงการดำเนินการปกติ แต่ยังไม่เกินค่าควบคุมที่กำหนดไว้ ให้โครงการตรวจสอบหาสาเหตุและทำการเฝ้าระวัง เพื่อเตรียมความพร้อมในการแก้ไขปัญหาที่อาจเกิดขึ้น ทั้งนี้ ให้สรุปรายละเอียดดังกล่าวไว้ในรายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อมและมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมให้ครบถ้วน ชัดเจนด้วย	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(11) ในกรณีที่ผลการตรวจวัดมลพิษจากแหล่งกำเนิดของโครงการมีค่าเกินค่าควบคุมที่กำหนดไว้ ให้โครงการทำการตรวจสอบหาสาเหตุ ทำการแก้ไข และทำการตรวจวัดซ้ำ เพื่อยืนยันประสิทธิภาพในการแก้ไข พร้อมทั้งกำหนดมาตรการเพื่อป้องกันการเกิดปัญหาในลักษณะดังกล่าวให้ครบถ้วน	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(12) กำหนดให้มีการรายงานลักษณะของกิจกรรมต่าง ๆ ที่เกิดขึ้นบริเวณโดยรอบจุดตรวจวัดคุณภาพอากาศขณะทำการตรวจวัด	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
1. มาตรการทั่วไป (ต่อ)	(13) กำหนดให้โครงการแจ้งสำนักงานอุตสาหกรรมจังหวัดระยองทราบก่อนการหยุดการผลิตเพื่อดำเนินการซ่อมบำรุงเครื่องจักรและอุปกรณ์ประจำปี (Shutdown/Turnaround) และในช่วงก่อนการเริ่มกระบวนการผลิต (Pre-Start up)	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(14) ให้ทบทวนเหตุการณ์อุบัติภัย/อุบัติเหตุที่เกิดขึ้นจากการประกอบกิจการอุตสาหกรรมที่มีการผลิตลักษณะเดียวกันทั้งในประเทศและต่างประเทศ โดยเสนอในรายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม ปีละ 1 ครั้ง เพื่อนำข้อมูลมาใช้ในการทบทวนและกำหนดมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อมและมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมของโครงการให้ครบถ้วนสมบูรณ์	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(15) จัดทำฐานข้อมูลสุขภาพของพนักงานเพื่อนำมาใช้ประกอบการวิเคราะห์หาสาเหตุในการเกิดความผิดปกติของผลการตรวจสุขภาพของพนักงานประจำปีในแต่ละพื้นที่ดำเนินงาน โดยเฉพาะพื้นที่เสี่ยง พร้อมระบุอายุงานของคนงานที่ทำงานในพื้นที่นั้น และวิเคราะห์ความเชื่อมโยงผลการตรวจวัดเพื่อเฝ้าระวังการรับสัมผัสสิ่งคุกคามสุขภาพกับฐานข้อมูลสุขภาพด้วย	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(16) กำหนดให้มีการเก็บบันทึกข้อมูลสุขภาพของพนักงานและผู้รับเหมา (เฉพาะผู้รับเหมารายเดือนที่ปฏิบัติหน้าที่อยู่ในพื้นที่ของโรงงานเป็นประจำทุกวัน ซึ่งโครงการเป็นผู้รับผิดชอบในการตรวจสุขภาพเท่านั้น โดยไม่รวมผู้รับเหมาในช่วงที่มีการหยุดการผลิตเพื่อดำเนินการซ่อมบำรุงเครื่องจักรและอุปกรณ์ประจำปี (Shutdown/Turnaround)) ในฐานข้อมูลสุขภาพของโรงงานเป็นระยะเวลา 30 ปี ภายหลังที่พนักงานออกจากการทำงาน ยกเว้นในกรณี ดังนี้ 1) กรณีที่พนักงานหรือผู้รับเหมาทำงานกับโครงการเป็นระยะเวลาน้อยกว่า 1 ปี ให้โครงการมอบบันทึกข้อมูลสุขภาพให้กับพนักงานและผู้รับเหมาเมื่อออกจากการทำงาน 2) กรณีที่โครงการจะเลิกดำเนินกิจการ ให้โครงการส่งบันทึกข้อมูลสุขภาพของพนักงานและผู้รับเหมาให้กับผู้ว่าจ้างของพนักงานและผู้รับเหมารายต่อไป หากไม่มีผู้ว่าจ้างรายต่อไปให้โครงการแจ้งให้พนักงานและผู้รับเหมาทราบสิทธิในการขอบันทึกข้อมูลสุขภาพของตนเองล่วงหน้าอย่างน้อย 3 เดือน ก่อนที่โครงการจะเลิกดำเนินกิจการ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
1. มาตรการทั่วไป (ต่อ)	(17) กำหนดให้มีเกณฑ์การคัดเลือกและประเมินคุณภาพห้องปฏิบัติการการวิเคราะห์และกำหนดให้มีการควบคุมการดำเนินการตรวจวัดคุณภาพสิ่งแวดล้อมของหน่วยงานกลาง (Third Party) ที่มาดำเนินงานให้กับโครงการ เพื่อทวนสอบความน่าเชื่อถือของข้อมูล ทั้งนี้แนวทางการตรวจสอบและประเมินห้องปฏิบัติการจะเป็นไปตามกระบวนการบริหารคู่ค้า (Supplier Management) เพื่อให้เกิดความโปร่งใสและเป็นธรรม (Corporate Governance) ต่อทั้งโครงการและหน่วยงานกลาง	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
2. คุณภาพอากาศ	(1) ควบคุมการระบายมลสารทางอากาศของทุกปล่องไม่ให้เกินค่าที่กำหนดดังตารางที่ 2-1 (คำนวณที่สภาวะ 7% excess O_2 อุณหภูมิ 25 °C สภาวะแห้งความดัน 1 atm) ดังนี้ 1) Reactor Feed Preheater Stack (52B001) - ก๊าซออกไซด์ของไนโตรเจน (NOx) มีค่าความเข้มข้นได้ไม่เกิน 44.9 มิลลิกรัม/ลูกบาศก์เมตร (23.9 ppm) หรือคิดเป็นอัตราการระบาย 0.2117 กรัม/วินาที - ก๊าซออกไซด์ของซัลเฟอร์ (SOx) มีค่าความเข้มข้นได้ไม่เกิน 100.0 มิลลิกรัม/ลูกบาศก์เมตร (38.2 ppm) หรือคิดเป็นอัตราการระบาย 0.4712 กรัม/วินาที - ฝุ่นละออง (TSP) มีค่าความเข้มข้นได้ไม่เกิน 20.0 มิลลิกรัม/ลูกบาศก์เมตร หรือคิดเป็นอัตราการระบาย 0.0942 กรัม/วินาที 2) Recirculation Heater Stack (52B101) - ก๊าซออกไซด์ของไนโตรเจน (NOx) มีค่าความเข้มข้นได้ไม่เกิน 66.0 มิลลิกรัม/ลูกบาศก์เมตร (35.1 ppm) หรือคิดเป็นอัตราการระบาย 0.0884 กรัมต่อวินาที - ก๊าซออกไซด์ของซัลเฟอร์ (SOx) มีค่าความเข้มข้นได้ไม่เกิน 147.0 มิลลิกรัม/ลูกบาศก์เมตร (56.2 ppm) หรือคิดเป็นอัตราการระบาย 0.1968 กรัม/วินาที - ฝุ่นละออง (TSP) มีค่าความเข้มข้นได้ไม่เกิน 20.0 มิลลิกรัม/ลูกบาศก์เมตร หรือคิดเป็นอัตราการระบาย 0.0268 กรัม/วินาที	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2-1
รายละเอียดแหล่งระบายมลสารทางอากาศก่อนและภายหลังการเปลี่ยนแปลงฯ

แหล่งกำเนิด	เชื้อเพลิง	ตำแหน่ง		ความสูงปล่อง (m)	เส้นผ่านศูนย์กลาง (m)	อุณหภูมิ (K)	ความเร็วก๊าซ[1/] (m/s)	%ความชื้น	$\%O_2$ ที่ Wet Basis	อัตราการไหล[2/] (Nm^3/s)	ความเข้มข้นก๊าซออกไซด์ของไนโตรเจน (NOx)				ความเข้มข้นก๊าซออกไซด์ของซัลเฟอร์ (SOx)				ความเข้มข้น TSP[2/] (mg/m^3)	อัตราการระบาย (g/s)			ระบบควบคุมมลพิษ
		x	y								(ppmv)[1/]	(mg/m^3)[1/]	(ppmv)[2/]	(mg/m^3)[2/]	(ppmv)[1/]	(mg/m^3)[1/]	(ppmv)[2/]	(mg/m^3)[2/]		NOx	SOx	TSP	
1. หน่วยปรับปรุงคุณภาพน้ำมันหนักโดยการใช้ไฮโดรเจน (RHDS) - Reactor Feed Preheater Stack (52B001)	ก๊าซเชื้อเพลิง	751697	1402501	60	1.60	666	5.00	18.7	3.00	4.71	25.0	21.05	23.9	44.9	40.0	46.8	38.2	100.0	20.0	0.2117	0.4712	0.0942	Ultra Low NOx Burner
- Recirculation Heater Stack (52B101)	ก๊าซเชื้อเพลิง	751709	1402501	60	1.00	623	5.00	44.7	3.00	1.34	25.0	22.50	35.1	66.0	40.0	50.1	56.2	147.0	20.0	0.0884	0.1968	0.0268	Ultra Low NOx Burner
2. หน่วยเพิ่มมูลค่าน้ำมันหนักโดยใช้ตัวเร่งปฏิกิริยา (RFCCU) - Regeneration System Flue Gas Stack (53A001)	Coke	751789	1402502	60	3.30	477	10.00	18.7	3.00	55.97	6.0	7.05	5.7	10.8	200.0	327.1	191.0	500.0	40.0	0.6034	27.9848	2.2386	SCR/ESP
- Cold Feed Preheater Stack (53B101)	ก๊าซเชื้อเพลิง	751805	1402606	60	1.40	503	5.00	17.9	3.00	4.82	25.0	27.87	23.6	44.5	40.0	62.03	37.8	99.0	20.0	0.2146	0.4776	0.0965	Ultra Low NOx Burner
3. กระบวนการผลิตไฮโดรเจน (HMU) - Steam Reformer Flue Gas (51Z002)	ก๊าซเชื้อเพลิง และ Purge Gas จากหน่วย PSA	751712	1402381	60	2.60	423	10.00	18.7	3.00	39.18	40.0	53.02	38.2	71.9	40.0	73.76	38.2	100.0	20.0	2.8160	3.9179	0.7835	Ultra Low NOx Burner
4. หน่วยปรับปรุงคุณภาพแนฟทา (NHTU) - Hydrodesulfurization Reactor Heater Stack (54B001)	ก๊าซเชื้อเพลิง	751982	1402355	60	0.90	533	5.00	48.2	3.00	1.19	25.0	26.30	37.5	70.5	40.0	58.54	60.0	157.0	20.0	0.0837	0.1863	0.0237	Ultra Low NOx Burner
5. หน่วยบำบัดก๊าซผสมจากปฏิกิริยา (TGTU) - TGTU Stack (73Z401)	ก๊าซเชื้อเพลิง	751879	1402726	60	1.20	573	10.00	18.7	3.00	6.16	30.0	29.35	28.7	53.9	40.0	71.47	50.1	131.3	20.0	0.3321	0.8086	0.1232	Amine Scrubber

ที่มา : บริษัท ไอยาร์พีซี จำกัด (มหาชน), 2564

หมายเหตุ : [1/] สภาวะจริง (Actual Condition) อุณหภูมิสภาวะจริง ความดันสภาวะจริง ออกซิเจนส่วนเกินสภาวะจริง และ Wet Basis
[2/] สภาวะมาตรฐาน (Standard Condition) อุณหภูมิ 25 องศาเซลเซียส ความดัน 1 บรรยากาศ ออกซิเจนร้อยละ 7 และ Dry Basis
ภายหลังการเปลี่ยนแปลงฯ รายละเอียดแหล่งระบายมลสารทางอากาศไม่มีการเปลี่ยนแปลงไปจากเดิม

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
2. คุณภาพอากาศ (ต่อ)	3) Regeneration System Flue Gas Stack (53A001) - ก๊าซออกไซด์ของไนโตรเจน (NOx) มีค่าความเข้มข้นได้ไม่เกิน 10.8 มิลลิกรัม/ลูกบาศก์เมตร (5.7 ppm) หรือคิดเป็นอัตราการระบาย 0.6034 กรัม/วินาที - ก๊าซออกไซด์ของซัลเฟอร์ (SOx) มีค่าความเข้มข้นได้ไม่เกิน 500.0 มิลลิกรัม/ลูกบาศก์เมตร (191.0 ppm) หรือคิดเป็นอัตราการระบาย 27.9848 กรัม/วินาที - ฝุ่นละออง (TSP) มีค่าความเข้มข้นได้ไม่เกิน 40.0 มิลลิกรัม/ลูกบาศก์เมตร หรือคิดเป็นอัตราการระบาย 2.2386 กรัม/วินาที 4) Cold Feed Preheater Stack (53B101) - ก๊าซออกไซด์ของไนโตรเจน (NOx) มีค่าความเข้มข้นได้ไม่เกิน 44.5 มิลลิกรัม/ลูกบาศก์เมตร (23.6 ppm) หรือคิดเป็นอัตราการระบาย 0.2146 กรัม/วินาที - ก๊าซออกไซด์ของซัลเฟอร์ (SOx) มีค่าความเข้มข้นได้ไม่เกิน 99.0 มิลลิกรัม/ลูกบาศก์เมตร (37.8 ppm) หรือคิดเป็นอัตราการระบาย 0.4776 กรัม/วินาที - ฝุ่นละออง (TSP) มีค่าความเข้มข้นได้ไม่เกิน 20.0 มิลลิกรัม/ลูกบาศก์เมตร หรือคิดเป็นอัตราการระบาย 0.0965 กรัม/วินาที 5) Steam Reformer Flue Gas Stack (51Z002) - ก๊าซออกไซด์ของไนโตรเจน (NOx) มีค่าความเข้มข้นได้ไม่เกิน 71.9 มิลลิกรัม/ลูกบาศก์เมตร (38.2 ppm) หรือคิดเป็นอัตราการระบาย 2.8160 กรัม/วินาที - ก๊าซออกไซด์ของซัลเฟอร์ (SOx) มีค่าความเข้มข้นได้ไม่เกิน 100.0 มิลลิกรัม/ลูกบาศก์เมตร (38.2 ppm) หรือคิดเป็นอัตราการระบาย 3.9179 กรัม/วินาที - ฝุ่นละออง (TSP) มีค่าความเข้มข้นได้ไม่เกิน 20.0 มิลลิกรัม/ลูกบาศก์เมตร หรือคิดเป็นอัตราการระบาย 0.7835 กรัม/วินาที			

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
2. คุณภาพอากาศ (ต่อ)	6) Hydrodesulfurization Reactor Heater Stack (54B001) - ก๊าซออกไซด์ของไนโตรเจน (NOx) มีค่าความเข้มข้นได้ไม่เกิน 70.5 มิลลิกรัม/ลูกบาศก์เมตร (37.5 ppm) หรือคิดเป็นอัตราการระบาย 0.0837 กรัม/วินาที - ก๊าซออกไซด์ของซัลเฟอร์ (SOx) มีค่าความเข้มข้นได้ไม่เกิน 157.0 มิลลิกรัม/ลูกบาศก์เมตร (60.0 ppm) หรือคิดเป็นอัตราการระบาย 0.1863 กรัม/วินาที - ฝุ่นละออง (TSP) มีค่าความเข้มข้นได้ไม่เกิน 20.0 มิลลิกรัม/ลูกบาศก์เมตร หรือคิดเป็นอัตราการระบาย 0.0237 กรัม/วินาที 7) TGTU Stack (73Z401) - ก๊าซออกไซด์ของไนโตรเจน (NOx) มีค่าความเข้มข้นได้ไม่เกิน 53.9 มิลลิกรัม/ลูกบาศก์เมตร (28.7 ppm) หรือคิดเป็นอัตราการระบาย 0.3321 กรัม/วินาที - ก๊าซออกไซด์ของซัลเฟอร์ (SOx) มีค่าความเข้มข้นได้ไม่เกิน 131.3 มิลลิกรัม/ลูกบาศก์เมตร (50.1 ppm) หรือคิดเป็นอัตราการระบาย 0.8086 กรัม/วินาที - ฝุ่นละออง (TSP) มีค่าความเข้มข้นได้ไม่เกิน 20.0 มิลลิกรัม/ลูกบาศก์เมตร หรือคิดเป็นอัตราการระบาย 0.1232 กรัม/วินาที			
	(2) ควบคุมการระบายก๊าซไฮโดรเจนซัลไฟด์จากปล่องระบายของหน่วยบำบัดก๊าซผสมจากปฏิกิริยา (TGTU Stack : 73Z401) ให้เป็นไปตามประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม เรื่อง กำหนดมาตรฐานควบคุมการปล่อยทิ้งอากาศเสียจากโรงกลั่นน้ำมันปิโตรเลียม พ.ศ. 2554	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(3) ติดตั้งหัวเผาชนิด Ultra Low NOx Burner ในการควบคุมมลสารที่ระบายออกจากปล่องระบายของโครงการ ดังนี้ - Reactor Feed Preheater Stack (52B001) - Recirculation Heater Stack (52B101) - Cold Feed Preheater Stack (53B101) - Steam Reformer Flue Gas Stack (51Z002) - Hydrodesulfurization Reactor Heater (54B001)	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
2. คุณภาพอากาศ (ต่อ)	(4) ติดตั้งอุปกรณ์ Selective Catalytic Reduction (SCR) เพื่อลดปริมาณก๊าซออกไซด์ของไนโตรเจน และอุปกรณ์ Electrostatic Precipitator (ESP) เพื่อลดปริมาณฝุ่นที่ระบายออกจากปล่อง Regeneration System Flue Gas Stack (53A001) ของหน่วยเพิ่มมูลค่าน้ำมันหนักโดยใช้ตัวเร่งปฏิกิริยา (RFCCU)	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(5) ใช้ระบบจับด้วยสารละลายเอมีน (Amine Scrubber) ในการควบคุมมลสารที่ระบายออกจากปล่อง TGTU Stack (73Z401) ของหน่วยบำบัดก๊าซผสมจากปฏิกิริยา (TGTU)	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(6) ติดตั้งระบบตรวจวัดการระบายมลสารจากปล่องอย่างต่อเนื่อง (Continuous Monitoring of Emissions; CEMs) จำนวน 7 ชุด เพื่อใช้ในการตรวจสอบและควบคุมการระบายมลสารจากปล่องระบายของโครงการ ดังนี้ - ชุดที่ 1 สำหรับปล่องระบายของหน่วยปรับปรุงคุณภาพน้ำมันหนักโดยการใช้ไฮโดรเจน (RHDS) คือ Reactor Feed Preheater Stack (52B001) - ชุดที่ 2 สำหรับปล่องระบายของหน่วยปรับปรุงคุณภาพน้ำมันหนักโดยการใช้ไฮโดรเจน (RHDS) คือ Recirculation Heater Stack (52B101) - ชุดที่ 3 สำหรับปล่องระบายของหน่วยเพิ่มมูลค่าน้ำมันหนักโดยใช้ตัวเร่งปฏิกิริยา (RFCCU) คือ Regeneration System Flue Gas Stack (53A001) - ชุดที่ 4 สำหรับปล่องระบายของหน่วยเพิ่มมูลค่าน้ำมันหนักโดยใช้ตัวเร่งปฏิกิริยา (RFCCU) คือ Cold Feed Preheater Stack (53B101) - ชุดที่ 5 สำหรับปล่องของหน่วยเปลี่ยนโครงสร้างด้วยไอน้ำ คือ Steam Reformer Flue Gas Stack (51Z002) - ชุดที่ 6 สำหรับปล่องของเตาให้ความร้อนในหน่วยกำจัดกำมะถัน คือ Hydrodesulphurization Reactor Heater Stack (54B001) - ชุดที่ 7 สำหรับปล่องของเตาเผาก๊าซ คือ TGTU Stack (73Z401)	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลาดำเนินการ	ผู้รับผิดชอบ
2. คุณภาพอากาศ (ต่อ)	(7) จัดให้มีเจ้าหน้าที่ประจำที่มีความรู้เป็นผู้ควบคุมระบบบำบัดมลพิษทางอากาศ เพื่อควบคุมการทำงานของระบบบำบัดให้มีประสิทธิภาพ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(8) หากพบว่ามีการระบายมลสารสูงกว่าเกณฑ์ที่มาตรฐานกำหนด ทางโครงการต้องรีบดำเนินการแก้ไขโดยทันที	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(9) บำรุงรักษาเครื่องมือ/อุปกรณ์ของระบบบำบัดมลพิษทางอากาศตามที่กำหนดไว้ในแผนการบำรุงรักษาเครื่องมือเชิงป้องกัน (Preventive Maintenance Plan)	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(10) จัดให้มีหอเผาทิ้งระดับเหนือพื้นดิน (Elevated Flare) ที่มีความสามารถในการรองรับก๊าซที่ระบายมาจากกระบวนการผลิตกรณีเกิดเหตุการณ์ผิดปกติ (Emergency) สูงสุดได้ทั้งหมด (Maximum Flare Load) โดยปริมาณก๊าซที่ระบายสูงสุดจากกรณีไฟฟ้าดับ (Power Failure) มีปริมาณรวมประมาณ 680.2 ตัน/ชั่วโมง โดยหอเผาทิ้งระดับเหนือพื้นดินออกแบบตามมาตรฐาน API RP 520, API STD 521, API STD 526, API STD 537 และ API STD 2000 และมีความสามารถในการเผาก๊าซได้สูงสุด 1,490 ตัน/ชั่วโมง	- หอเผาทิ้งระดับเหนือพื้นดิน (Elevated Flare)	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(11) ออกแบบหอเผาทิ้งระดับเหนือพื้นดิน (Elevated Flare) และหอเผาทิ้งระดับพื้นดินแบบปิด (Enclosed Ground Flare) ให้มีความสูงเหมาะสมที่ไม่ทำให้ระดับรังสีความร้อนได้ฐานหอเผาเกิน 6.31 กิโลวัตต์/ตารางเมตร	- หอเผาทิ้งระดับเหนือพื้นดิน และหอเผาทิ้งระดับพื้นดินแบบปิด	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(12) จัดให้มีหอเผาทิ้งระดับพื้นดินแบบปิด (Enclosed Ground Flare) ที่ออกแบบตามมาตรฐาน API RP 520, API STD 521, API STD 526, API STD 537 และ API STD 2000 และมีความสามารถในการเผาก๊าซได้สูงสุด 200 ตัน/ชั่วโมง เพื่อนำมาใช้งานร่วมกับหอเผาทิ้งระดับเหนือพื้นดิน (Elevated Flare) ในปัจจุบัน	- หอเผาทิ้งระดับพื้นดินแบบปิด (Enclosed Ground Flare)	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(13) ก๊าซที่ระบายจากกระบวนการผลิตไปยังหอเผาทิ้งของโครงการที่มีการใช้งานร่วมกันระหว่างหอเผาทิ้งระดับพื้นดินแบบปิดและหอเผาทิ้งระดับเหนือพื้นดินจะมีขั้นตอนการดำเนินการดังนี้ 1) หากก๊าซที่ระบายมาจากกระบวนการผลิตไปยัง Flare Header มีปริมาณน้อยกว่า 200 ตัน/ชั่วโมง หรือความดันน้อยกว่า 0.3 บาร์เกจ ก๊าซทั้งหมดจะถูกส่งมาเผาทำลายยังหอเผาทิ้งระดับพื้นดินแบบปิด (Enclosed Ground Flare) โดยที่ระบบควบคุมการจ่ายก๊าซตามความดันทั้งหมดที่ Staging Control System จะยังไม่มีการทำงาน (Closed position)	- หอเผาทิ้งระดับพื้นดินแบบปิด (Enclosed Ground Flare) และหอเผาทิ้งระดับเหนือพื้นดิน (Elevated Flare)	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลาดำเนินการ	ผู้รับผิดชอบ
2. คุณภาพอากาศ (ต่อ)	2) หากก๊าซที่ระบายจากกระบวนการผลิตไปยัง Flare Header มีปริมาณมากกว่า 200 ตัน/ชั่วโมง มีผลให้ความดันภายใน Flare Header สูงขึ้น ระบบควบคุมความดัน (Pressure Control System) จะสั่งการ ดังนี้ • Pressure Valve (PV-7706301) จะเปิดเมื่อความดันใน Header Flare สูงกว่า 0.30 บาร์เกจ เพื่อระบายก๊าซส่วนที่เหลือจาก 200 ตัน/ชั่วโมง ไปยังหอเผาทิ้งระดับเหนือพื้นดิน (Elevated Flare) โดยหากความดันใน Header Flare ลดลงมาต่ำกว่า 0.30 บาร์เกจ Pressure Vale (PV-7706301) ก็จะปิดกลับ • กรณีความดันใน Flare Header ยังเพิ่มสูงขึ้น เนื่องจากปริมาณก๊าซสูง Shut off valve (XV-7706301) จะเปิดเมื่อความดันใน Header สูงกว่า 0.35 บาร์เกจ โดยระบบ Interlock จะสั่งการให้ Shut off valve เปิดเพื่อระบายก๊าซจาก Header ไปยังหอเผาทิ้งระดับเหนือพื้นดิน (Elevated Flare) • กรณีที่ Shut Off Valve (XV-7706301) ระบายก๊าซไปยังหอเผาทิ้งระดับเหนือพื้นดินไม่ทัน หรือเกิดการผิดพลาดไม่ทำงาน ทำให้ความดันใน Header ยังคงสูงขึ้นเรื่อย ๆ จนถึงระดับ 0.45 บาร์เกจ อุปกรณ์ Non-reclosing Pressure Relief Devices หรือ Buckling pin (BPRV-7706301) จะถูกเปิดออกเพื่อระบายความดันและก๊าซทิ้งไปยังหอเผาทิ้งระดับเหนือพื้นดิน (Elevated Flare)			
	(14) จัดให้มีเจ้าหน้าที่รับผิดชอบ เพื่อคอยตรวจสอบและดำเนินการให้ระบบหอเผาทิ้งมีการเผาไหม้ที่สมบูรณ์ในช่วงการดำเนินงานตามปกติ	- หอเผาทิ้งระดับเหนือพื้นดิน (Elevated Flare) และหอเผาทิ้งระดับพื้นดินแบบปิด (Enclosed Ground Flare)	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
2. คุณภาพอากาศ (ต่อ)	(15) จัดให้มีแผนบำรุงรักษาเชิงป้องกัน (Preventive Maintenance Plan) สำหรับระบบหอเผาทิ้ง	- หอเผาทิ้งระดับเหนือพื้นดิน (Elevated Flare) และหอเผาทิ้งระดับพื้นดินแบบปิด (Enclosed Ground Flare)	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	การจัดการสารอินทรีย์ระเหยง่าย (VOCs)			
	(16) จัดทำแผนป้องกัน/ควบคุมการรั่วซึมของสารอินทรีย์ระเหยจากแหล่งกำเนิด (Fugitive Source) ได้แก่ ปั๊ม (Pumps) เครื่องอัดอากาศ (Compressors) อุปกรณ์ที่ใช้กวนหรือผสมของเหลว (Agitators หรือ Mixers) วาล์ว (Valves) ท่อส่งปลายเปิด (Open-Ended Lines) ข้อต่อหรือหน้าแปลน (Connectors หรือ Flanges) อุปกรณ์ลดความดัน (Pressure Relief Devices) และจุดเก็บตัวอย่างสารเคมี (Sampling Connections)	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(17) จัดทำข้อมูลการระบายสารอินทรีย์ระเหย (VOCs Inventory) ที่มาจากแหล่งกำเนิดของโครงการ โดยให้ดำเนินการตามแนวทางของ US.EPA. ทั้งนี้ การประเมินการรั่วซึมจากแหล่งกำเนิดให้ดำเนินการตามประกาศกระทรวงอุตสาหกรรมที่เกี่ยวข้องให้แล้วเสร็จภายในระยะเวลา 1 ปีหลังจากดำเนินโครงการ หลังจากนั้นให้ดำเนินการตามกฎหมายที่เกี่ยวข้องกำหนด	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(18) กำหนดให้มีการตรวจวัดการรั่วซึมของสารอินทรีย์ระเหย ตามประกาศกระทรวงอุตสาหกรรม เรื่อง กำหนดหลักเกณฑ์ และวิธีการปฏิบัติในการตรวจสอบและควบคุมการรั่วซึมของสารอินทรีย์ระเหยจากอุปกรณ์ในโรงงานอุตสาหกรรม พ.ศ. 2555	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(19) ทำการตรวจวัดข้อต่อหรือหน้าแปลน วาล์วก๊าซ วาล์วของเหลว ท่อส่งปลายเปิดปั๊มสำหรับของเหลว เครื่องอัดอากาศ อุปกรณ์ลดความดันสำหรับก๊าซ อุปกรณ์ลดความดันสำหรับของเหลวจุดเก็บตัวอย่างสารเคมี อุปกรณ์ที่ใช้กวนหรือผสมของเหลว ปีละ 1 ครั้ง	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
2. คุณภาพอากาศ (ต่อ)	(20) ควบคุมการรั่วซึม/รั่วระเหยจากอุปกรณ์กระบวนการผลิตที่สัมผัสเบนซีน (หน่วยเพิ่มมูลค่าน้ำมันหนักโดยใช้ตัวเร่งปฏิกิริยา (RFCCU) และหน่วยปรับปรุงคุณภาพแนฟทา (NHTU)) และ 1,3-บิวทาไดอีน (หน่วยเพิ่มมูลค่าน้ำมันหนักโดยใช้ตัวเร่งปฏิกิริยา (RFCCU) และหน่วยปรับปรุงคุณภาพก๊าซปิโตรเลียมเหลว (LSU)) ให้เข้มงวดกว่าประกาศกระทรวงอุตสาหกรรม เรื่อง กำหนดหลักเกณฑ์ และวิธีการปฏิบัติในการตรวจสอบและควบคุมการรั่วซึมของสารอินทรีย์ระเหยจากอุปกรณ์ในโรงงานอุตสาหกรรม พ.ศ. 2555 ดังนี้ - การรั่วซึม/รั่วระเหยจากเครื่องอัดอากาศ ท่อส่งปลายเปิด จุดเก็บตัวอย่างสารเคมี และอุปกรณ์ลดความดันสำหรับก๊าซจะต้องไม่เกิน 250 ส่วนในล้านส่วน - การรั่วซึม/รั่วระเหยจากอุปกรณ์ลดความดันสำหรับของเหลว วาล์ว (ก๊าซ/ของเหลว) ข้อต่อหรือหน้าแปลนจะต้องไม่เกิน 250 ส่วนในล้านส่วน - การรั่วซึม/รั่วระเหยจากปั๊มสำหรับของเหลวจะต้องไม่เกิน 2,500 ส่วนในล้านส่วน - การรั่วซึม/รั่วระเหยจากอุปกรณ์ที่ใช้กวนหรือผสมของเหลวจะต้องไม่เกิน 5,000 ส่วนในล้านส่วน	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(21) หากพบการรั่วซึมของสารอินทรีย์ระเหยที่อุปกรณ์ต่าง ๆ ให้ทำการปรับปรุงในจุดที่ผลการตรวจวัดเกินค่าควบคุมในระยะเวลาที่กำหนดในกฎหมาย ดังนี้ - หากผลการตรวจวัดสารอินทรีย์ระเหยจากอุปกรณ์เกินจากเกณฑ์ควบคุมการรั่วซึมสารอินทรีย์ระเหยของอุปกรณ์ที่กำหนด ให้ทำการปรับเปลี่ยนไปใช้อุปกรณ์ตัวที่ไม่มีการรั่วซึมหรือซ่อมแซมอุปกรณ์ให้เสร็จภายใน 15 วันนับถัดจากวันที่ตรวจพบ เมื่อดำเนินการแก้ไขเสร็จแล้วให้ตรวจวัดซ้ำและผลการตรวจวัดซ้ำต้องไม่เกินจากเกณฑ์ที่กำหนด - อุปกรณ์ลดความดัน (Pressure Relief Devices) ให้ซ่อมแซมให้เสร็จภายใน 24 ชั่วโมง หรือให้ต่อเข้าระบบบำบัดมลพิษ - หากไม่สามารถซ่อมแซมตามที่กำหนดไว้ ให้กำหนดมาตรการเพื่อป้องกันหรือลดการรั่วซึม โดยระบุเหตุผลและระยะเวลาที่สามารถซ่อมแซมได้ให้ชัดเจน แล้วรายงานต่อกรมโรงงานอุตสาหกรรมหรือหน่วยงานที่กำกับดูแล ภายใน 30 วัน นับจากการตรวจพบจุดรั่วซึมแต่ละจุด	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
2. คุณภาพอากาศ (ต่อ)	(22) การรายงานผลการตรวจวัดและการซ่อมแซมอุปกรณ์ ต้องจัดทำบัญชีรายชื่ออุปกรณ์พร้อมผลการตรวจวัดและการซ่อมแซมให้เป็นปัจจุบันโดยรวบรวมจัดทำสรุปตามแบบรายงานที่กรมโรงงานอุตสาหกรรมกำหนด แล้วจัดส่งให้กรมโรงงานอุตสาหกรรมหรือหน่วยงานที่กำกับดูแลทุก 6 เดือน	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(23) ถังเก็บในลักษณะเป็นถังทรงกลม (Sphere Tank) จะออกแบบเป็นระบบปิด (Closed System) โดยเชื่อมต่อระบบรักษาความดันภายในถังกับระบบหอเผาทิ้ง	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(24) ต้องดูแลและตรวจสอบสภาพอุปกรณ์ที่ใช้ในการสูบถ่ายสารอินทรีย์ระเหยลงรถบรรทุกให้อยู่ในสภาพดีตลอดเวลา เพื่อไม่ให้เกิดการรั่วไหลของสารอินทรีย์ระเหย	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(25) เมื่อทำการเชื่อมต่ออุปกรณ์ที่ใช้ในการสูบถ่ายสารอินทรีย์ระเหยเข้ากับรถบรรทุกแล้ว ให้ทำการตรวจสอบความเรียบร้อยตามวาล์วหน้าแปลน ข้อต่อ และ Loading Arm ด้วยสายตา โดยในระหว่างสูบถ่ายให้ทำการตรวจสอบการรั่วซึมตามวาล์ว หน้าแปลน ข้อต่อ และ Loading Arm ด้วยเครื่องตรวจวัดสารอินทรีย์ระเหยแบบพกพา โดยคุณลักษณะของเครื่องมือและวิธีปฏิบัติให้เป็นไปตามวิธีการตรวจวัดที่ 21 (Method 21 : Determination of Volatile Organic Compound Leaks) ตามที่องค์การพิทักษ์สิ่งแวดล้อมแห่งประเทศสหรัฐอเมริกากำหนด หรือตามประกาศกรมโรงงานอุตสาหกรรม	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(26) จัดให้มีระเบียบการทำงาน เพื่อตรวจสอบระดับสารเคมีภายในรถบรรทุกเป็นระยะ เช่น ที่ร้อยละ 30, 60 และ 80 ของความจุ เพื่อป้องกันการไหลล้น	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)


องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
2. คุณภาพอากาศ (ต่อ)	(27) ป้องกันการรั่วซึมของสารอินทรีย์ระเหยจากอุปกรณ์การผลิตโดยเลือกใช้อุปกรณ์ที่มีการป้องกันการรั่วซึม ดังนี้ - เลือกใช้ปั๊มที่มีระบบป้องกันการรั่วไหล 2 ชั้น (Double Mechanical Seal) ใช้สำหรับงานที่เกี่ยวข้องกับสารที่ระเหยได้ง่าย หรือมีอันตรายสูง ซึ่งระบบ Seal มีการเชื่อมต่อให้สารไฮโดรคาร์บอนที่รั่วไหลระบายไปยังระบบหอเผาทิ้ง - เลือกใช้วาล์วชนิด Bellow Seal Valve ในจุดที่มีความเสี่ยงจะก่อให้เกิดการรั่วไหลได้ง่ายหรือเกี่ยวข้องกับสารอินทรีย์ที่มีความอันตรายสูงเพื่อป้องกันปัญหาการรั่วซึมของวัสดุที่ไหลผ่านวาล์วไม่ให้ออกสู่บรรยากาศ - ออกแบบระบบท่อให้มีการต่อหรือมีปะเก็นให้น้อยที่สุด เพื่อลดโอกาสที่สารอินทรีย์จะรั่วไหลออกมาตามรอยต่อของปะเก็น โดยหากจำเป็นจะต้องมีการเชื่อมต่อของระบบท่อ ทางโครงการจะเลือกใช้วิธีหรือปะเก็นให้เหมาะสมกับสารอินทรีย์และสภาวะของระบบนั้น ๆ เช่น การเชื่อม หรือการเลือกใช้ปะเก็นชนิด Kempchen Gasket หรือ Camprofile Gasket หรือ Grooved Gasket	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(28) ออกแบบระบบบำบัดน้ำเสียให้เป็นระบบปิดและรวบรวมสารอินทรีย์ที่ระเหยจากบ่อบำบัดน้ำเสียไปใช้เป็นอากาศในการเผาไหม้ในกระบวนการผลิต	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(29) ติดตั้งตัวดูดซับด้วยถ่าน (Activated Carbon Canister) ที่บริเวณถังเก็บสารอินทรีย์เพื่อควบคุมปริมาณสารอินทรีย์ระเหยง่ายจากถังเก็บ	พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(30) ควบคุมและตรวจสอบการทำงานของหอดูดซับด้วยถ่านกัมมันต์ ให้ทำงานได้ตลอด 24 ชั่วโมง และมีประสิทธิภาพในการบำบัดสารอินทรีย์ระเหยง่ายไม่ต่ำกว่าร้อยละ 70	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(31) เมื่อประสิทธิภาพของตัวดูดซับด้วยถ่านกัมมันต์มีประสิทธิภาพไม่ถึงค่าที่ได้กำหนดไว้ ทางโครงการจะทำการเปลี่ยนไปใช้ตัวดูดซับชุดที่สำรองไว้ทันที และนำชุดที่ประสิทธิภาพไม่ถึงตามค่าที่กำหนดส่งให้บริษัทที่ได้รับอนุญาตจากทางราชการนำไปฟื้นฟู หรือส่งกำจัดยังหน่วยงานภายนอกที่ได้รับอนุญาตจากทางราชการ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(32) เลือกใช้ก๊าซเหลือจากกระบวนการผลิตเป็นเชื้อเพลิงในการเผาไหม้เพื่อให้ความร้อนแก่กระบวนการผลิต	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(33) จัดให้มีผู้ควบคุมมลพิษทางอากาศตามประกาศกระทรวงอุตสาหกรรมที่เกี่ยวข้อง	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
3. คุณภาพน้ำ	(1) แยกระบบระบายน้ำเสียออกจากระบบระบายน้ำฝนที่ไม่ปนเปื้อน และป้องกันไม่ให้น้ำเสียไหลลงสู่ลำรางสาธารณะ หรือรางระบายน้ำฝนของเขตประกอบการฯ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(2) จัดให้มีระบบบำบัดน้ำเสียเบื้องต้นของโครงการ ประกอบด้วย 1) ระบบบำบัดน้ำเสียแบบแยกน้ำและน้ำมันด้วยตัวกลางแบบแผ่นขนาน (CPI) ออกแบบให้มีขนาดรองรับน้ำเสียได้สูงสุด 85 ลูกบาศก์เมตร/ชั่วโมง โดยจะรับน้ำเสียที่เกิดขึ้นจากน้ำเสียจากการล้างย้อนจากหน่วยปรับปรุงคุณภาพน้ำคอนเดนเสท (Condensate Polishing Back Wash) น้ำล้างย้อนจากหน่วยปรับปรุงคุณภาพเอมีน (ARU) (Carbon Back Wash) น้ำล้างย้อนจากระบบผลิตน้ำลดแร่ และน้ำเสียจากหน่วยผลิตโพลิแนฟทา (PNU) และน้ำฝนปนเปื้อนจากบ่อรวบรวมน้ำฝนปนเปื้อนทั้ง 7 บ่อ โดยจะทำการแยกน้ำมันออกจากน้ำเสียโดยการลดปริมาณน้ำมันในน้ำเสียขาเข้าให้เหลือ 50 มิลลิกรัม/ลิตร ก่อนส่งน้ำเสียไปบำบัดยังระบบบำบัดน้ำเสียแบบใช้อากาศแยกน้ำออกจากน้ำมัน (IAF) ต่อไป 2) ระบบบำบัดน้ำเสียแบบใช้อากาศแยกน้ำออกจากน้ำมัน (IAF) ออกแบบให้มีขนาดรองรับน้ำเสียได้สูงสุด 85 ลูกบาศก์เมตร/ชั่วโมง โดยจะรับน้ำเสียจากระบบบำบัดน้ำเสียแบบแยกน้ำและน้ำมันด้วยตัวกลางแบบแผ่นขนาน (CPI) มาแยกน้ำมันอีกครั้งหนึ่ง เนื่องจากน้ำมันบางส่วนจะมีการแขวนลอยในน้ำ (Suspension) ไม่สามารถแยกออกได้ด้วยระบบบำบัดน้ำเสียแบบ CPI โดยมีความสามารถในการลดปริมาณน้ำมันในน้ำเสียขาเข้าให้เหลือ 10 มิลลิกรัม/ลิตร ก่อนส่งน้ำเสียไปบำบัดต่อยังระบบบำบัดน้ำเสียส่วนกลางของเขตประกอบการฯ ต่อไป 3) ระบบบำบัดน้ำเสียแบบ API (Storm Drain Basin หรือ API Pond) มีขนาดบ่อ 7,700 ลูกบาศก์เมตร ออกแบบให้มีขนาดรองรับน้ำฝนได้สูงสุด 12,850 ลูกบาศก์เมตร เป็นระบบบำบัดชนิด Conventional Gravity Type Oil/Water Separator ซึ่งออกแบบตามมาตรฐาน API421 ซึ่งจะทำการแยกคราบน้ำมันที่ลอยอยู่ด้านบนของผิวน้ำด้วยการกวาดออก (Oil Skimmer) และส่งไปกำจัดยังถังรวบรวมไฮโดรคาร์บอน (Slop Tank) เพื่อรอส่งกลับเข้ากระบวนการผลิตหรือส่งกำจัดยังหน่วยงานภายนอกที่ได้รับอนุญาตจากทางราชการ ส่วนน้ำฝนจะถูกระบายลงบ่อหน่วงน้ำ (Detention Pond) ของเขตประกอบการฯ ต่อไป	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
3. คุณภาพน้ำ (ต่อ)	(3) ควบคุมและจัดการน้ำเสียที่เกิดขึ้นจากโครงการตามแผนผังการจัดการน้ำเสีย (**รูปที่ 2**) โดยมีรายละเอียดดังนี้ 1) น้ำเสียจากอาคารสำนักงาน น้ำเสียจากอาคารสำนักงาน ปริมาณ 9.52 ลูกบาศก์เมตร/วัน จะถูกบำบัดด้วยระบบบำบัดสำเร็จรูปชนิดเติมอากาศ (SATs) จะระบายลงสู่บ่อ Oily Amine Contaminated Water Sump ขนาด 789 ลูกบาศก์เมตร และส่งต่อไปยังบ่อรวบรวมน้ำปนเปื้อนน้ำมัน (Common Oily Water Basin) ขนาด 1,500 ลูกบาศก์เมตร ก่อนส่งไปบำบัดที่ระบบบำบัดเบื้องต้นแบบแยกน้ำและน้ำมันด้วยตัวกลางแบบแผ่นขนาน (CPI) และแบบใช้อากาศแยกน้ำออกจากน้ำมัน (IAF) ก่อนส่งต่อไปบำบัดยังระบบบำบัดน้ำเสียส่วนกลางของเขตประกอบการไออาร์พีซีต่อไป 2) การจัดการน้ำฝนปนเปื้อน • น้ำฝนปนเปื้อนบริเวณหน่วยปรับปรุงคุณภาพน้ำมันหนักโดยการใช้ไฮโดรเจน (RHDS) กระบวนการผลิตไฮโดรเจน (HMU) และหน่วยบำบัดสารละลายโซเดียมไฮดรอกไซด์ที่ผ่านการใช้งานแล้ว (Spent Caustic Treatment Unit : SCTU) ปริมาณ 596 ลูกบาศก์เมตร/ครั้ง จะระบายลงสู่บ่อรวบรวมน้ำฝน (78T010) ขนาด 682 ลูกบาศก์เมตร • น้ำฝนปนเปื้อนบริเวณหน่วยเพิ่มมูลค่าน้ำมันหนักโดยใช้ตัวเร่งปฏิกิริยา (RFCCU) หน่วยปรับปรุงคุณภาพแนฟทา (NHTU) หน่วยผลิตโพลิแนฟทา (PNU) หน่วยปรับปรุงคุณภาพก๊าซปิโตรเลียมเหลว (LSU) และหน่วยแยกโพรพิลีน (PRU) ปริมาณ 905 ลูกบาศก์เมตร/ครั้ง จะระบายลงสู่บ่อรวบรวมน้ำฝน (78T003) ขนาด 1,072 ลูกบาศก์เมตร • น้ำฝนปนเปื้อนบริเวณหน่วยแยกเอทิลีน (ERU) ปริมาณ 547 ลูกบาศก์เมตร/ครั้ง จะระบายลงสู่บ่อรวบรวมน้ำฝน (78T001) ขนาด 575 ลูกบาศก์เมตร • น้ำฝนปนเปื้อนบริเวณหน่วยเสริมการผลิต (Utility) ปริมาณ 288 ลูกบาศก์เมตร/ครั้ง จะระบายลงสู่บ่อรวบรวมน้ำฝน (78T012) ขนาด 289 ลูกบาศก์เมตร • น้ำฝนปนเปื้อนบริเวณลานถังเก็บผลิตภัณฑ์ (Tank Farm) ปริมาณ 641 ลูกบาศก์เมตร/ครั้ง จะระบายลงสู่บ่อรวบรวมน้ำฝน (78T005) ขนาด 1,411 ลูกบาศก์เมตร	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)



รูปที่ 2 แผนผังการจัดการน้ำเสียของโครงการ

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
3. คุณภาพน้ำ (ต่อ)	• น้ำฝนปนเปื้อนบริเวณหน่วยปรับปรุงคุณภาพเอมีน (ARU) หน่วยปรับปรุงคุณภาพน้ำปนเปื้อนก๊าซผสมจากปฏิกิริยา (SWS) หน่วยนำกำมะถันกลับคืน (SRU) และหน่วยบำบัดก๊าซผสมจากปฏิกิริยา (TGTU) ปริมาณ 579 ลูกบาศก์เมตร/ครั้ง จะระบายลงสู่บ่อรวบรวมน้ำฝน (78T004) ขนาด 810 ลูกบาศก์เมตร • น้ำฝนปนเปื้อนบริเวณหอเผาทิ้งระดับพื้นดินแบบปิด (EGF) ปริมาณ 2.62 ลูกบาศก์เมตร/ครั้ง จะระบายลงสู่บ่อรวบรวมน้ำฝน (77T001) ขนาด 30 ลูกบาศก์เมตร น้ำฝนปนเปื้อนดังกล่าวข้างต้นจะส่งต่อไปยังบ่อรวบรวมน้ำปนเปื้อนน้ำมัน (Common Oily Water Basin) ขนาด 1,500 ลูกบาศก์เมตร ก่อนส่งไปบำบัดที่ระบบบำบัดเบื้องต้นแบบแยกน้ำและน้ำมันด้วยตัวกลางแบบแผ่นขนาน (CPI) และแบบใช้อากาศแยกน้ำออกจากน้ำมัน (IAF) เพื่อแยกน้ำมันที่ปะปนให้เหลือน้อยกว่า 10 มิลลิกรัม/ลิตร ก่อนส่งต่อไปบำบัดยังระบบบำบัดน้ำเสียส่วนกลางของเขตประกอบการไออาร์พีซีต่อไป 3) การจัดการน้ำเสียจากกระบวนการผลิต น้ำเสียจากการล้างย้อนจากหน่วยปรับปรุงคุณภาพน้ำคอนเดนเสท (ไม่ต่อเนื่อง) โดยทำการล้างย้อนวันละ 1 ครั้ง เป็นระยะเวลาประมาณ 15 นาที มีปริมาณประมาณ 28.5 ลูกบาศก์เมตร/วัน น้ำล้างย้อนจากหน่วยปรับปรุงคุณภาพเอมีน (ไม่ต่อเนื่อง) ปริมาณประมาณ 48 ลูกบาศก์เมตร/วัน น้ำล้างย้อนจากระบบผลิตน้ำลดแร่ 290.01 ลูกบาศก์เมตร/วัน (ไม่ต่อเนื่อง) และน้ำเสียจากหน่วยผลิตโพลิแนฟทา (PNU) ปริมาณประมาณ 246.216 ลูกบาศก์เมตร/วัน (ต่อเนื่อง) จะถูกส่งเข้าสู่บ่อรวบรวมน้ำปนเปื้อนน้ำมัน (Common Oily Water Basin) ขนาด 1,500 ลูกบาศก์เมตร ก่อนส่งไปบำบัดที่ระบบบำบัดเบื้องต้นแบบแยกน้ำและน้ำมันด้วยตัวกลางแบบแผ่นขนาน (CPI) และแบบใช้อากาศแยกน้ำออกจากน้ำมัน (IAF) เพื่อแยกน้ำมันให้เหลือน้อยกว่า 10 มิลลิกรัม/ลิตร ก่อนส่งน้ำทิ้งบางส่วนปริมาณ 302.232 ลูกบาศก์เมตร/วัน ไปยังระบบบำบัดแบบชีวภาพของหน่วย SCTU และส่งน้ำทิ้งส่วนที่เหลือปริมาณ 310.494 ลูกบาศก์เมตร/วัน ไปยังระบบบำบัดน้ำเสียส่วนกลางของเขตประกอบการฯ ทั้งนี้ ในกรณีที่หน่วย SCTU ขัดข้อง โครงการจะส่งน้ำทิ้งที่ผ่านการบำบัดแล้ว ที่ออกจากหน่วย IAF ทั้งหมดไปยังระบบบำบัดน้ำเสียส่วนกลางของเขตประกอบการฯ แห่งที่ 3			

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
3. คุณภาพน้ำ (ต่อ)	• Stripped Water จากหน่วยปรับปรุงคุณภาพน้ำปนเปื้อนก๊าซผสมจากปฏิกิริยา (SWS) ซึ่งมีปริมาณประมาณ 1,699.848 ลูกบาศก์เมตร/วัน (สูงสุดประมาณ 2,090.64 ลูกบาศก์เมตร/วัน กรณีไม่มีการส่งน้ำกลับไปใช้ใหม่ที่หน่วยปรับปรุงคุณภาพน้ำมันหนัก โดยการใช้ไฮโดรเจน (RHDS)) ไปบำบัดยังระบบบำบัดน้ำเสียแบบชีวภาพ (Bio Reactor) ที่ระบบบำบัดน้ำเสียส่วนกลางของเขตประกอบการฯ • น้ำทิ้งจากระบบผลิตไอน้ำ ปริมาณประมาณ 200.4 ลูกบาศก์เมตร/วัน และน้ำระบายทิ้งจากหอผลิตน้ำหล่อเย็น ปริมาณประมาณ 842.4 ลูกบาศก์เมตร/วัน จะถูกส่งมายังบ่อรวบรวม (Blowdown Sump) ขนาด 8 ลูกบาศก์เมตร ก่อนส่งต่อไปยังบ่อพักน้ำทิ้ง (Effluent Pond 8) ของเขตประกอบการฯ • น้ำล้างย้อนจากระบบผลิตน้ำลดแร่ (Demineralized Water Backwash) ปริมาณ 290.01 ลูกบาศก์เมตร/วัน (ไม่ต่อเนื่อง) โดยจะทำการล้างย้อน วันละ 1 ครั้ง เป็นระยะเวลาประมาณ 7 ชั่วโมง ซึ่งจะถูกส่งเข้าสู่บ่อรวบรวมน้ำปนเปื้อนน้ำมัน (Common Oily Water Basin) ขนาด 1,500 ลูกบาศก์เมตร ก่อนส่งไปบำบัดที่ระบบบำบัดเบื้องต้นแบบแยกน้ำและน้ำมันด้วยตัวกลางแบบแผ่นขนาน (CPI) และแบบใช้อากาศแยกน้ำออกจากน้ำมัน (IAF) เพื่อแยกน้ำมันให้เหลือน้อยกว่า 10 มิลลิกรัม/ลิตร ก่อนส่งต่อไปบำบัดยังระบบบำบัดน้ำเสียส่วนกลางของเขตประกอบการไออาร์พีซีต่อไป ทั้งนี้ โครงการจะควบคุมไม่ให้มีการล้างย้อนระบบผลิตน้ำลดแร่พร้อมกับการล้างย้อนหน่วยปรับปรุงคุณภาพน้ำคอนเดนเสท			

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
3. คุณภาพน้ำ (ต่อ)	(4) ควบคุมลักษณะของ Stripped Water ให้อยู่ในเกณฑ์ที่สามารถระบายเข้าสู่ระบบบำบัดน้ำเสียส่วนกลางของเขตประกอบการฯ ที่กำหนดไว้เบื้องต้น ดังนี้ - pH มีค่าอยู่ในช่วง 9.0-11.0 - Temperature มีค่าไม่เกิน 42 °C - SS มีค่าไม่เกิน 50 mg/L - TDS มีค่าไม่เกิน 200 mg/L - BOD_5 มีค่าไม่เกิน 750 mg/L - COD มีค่าไม่เกิน 750 mg/L - Grease & Oil มีค่าไม่เกิน 10 mg/L - Phenol มีค่าไม่เกิน 270 mg/L - NH_3 มีค่าไม่เกิน 15 ppm - H_2S มีค่าไม่เกิน 5 ppm หมายเหตุ : หากเขตประกอบการฯ มีการเปลี่ยนแปลงเกณฑ์ของ Stripped Water โครงการต้องควบคุมลักษณะของ Stripped Water ให้เป็นไปตามเกณฑ์ที่เขตประกอบการฯ กำหนด	- Stripped Water Tank	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(5) หากพบว่าลักษณะของ Stripped Water ที่โครงการส่งไปบำบัดยังระบบบำบัดน้ำเสียส่วนกลางของเขตประกอบการฯ ไม่อยู่ในเกณฑ์ที่เขตประกอบการฯ กำหนด ทางโครงการต้องส่งกลับไปบำบัดใหม่ที่หน่วยปรับปรุงคุณภาพน้ำปนเปื้อนก๊าซผสมจากปฏิกิริยา (SWS)	- Stripped Water Tank	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
3. คุณภาพน้ำ (ต่อ)	(6) ควบคุมลักษณะของน้ำทิ้งที่ออกจากระบบบำบัดแบบ IAF ให้อยู่ในเกณฑ์ที่สามารถระบายเข้าสู่ระบบบำบัดน้ำเสียส่วนกลางของเขตประกอบการฯ ที่กำหนดไว้เบื้องต้น ดังนี้ - pH มีค่าอยู่ในช่วง 5.5-9.0 - Tempereture มีค่าไม่เกิน 40 °C - SS มีค่าไม่เกิน 200 mg/L - TDS มีค่าไม่เกิน 1,300 mg/L - BOD5 มีค่าไม่เกิน 500 mg/L - COD มีค่าไม่เกิน 1,500 mg/L - Grease & Oil มีค่าไม่เกิน 10 mg/L - Phenol มีค่าไม่เกิน 1 mg/L หมายเหตุ : หากเขตประกอบการฯ มีการเปลี่ยนแปลงเกณฑ์ของน้ำทิ้งที่ออกจากระบบบำบัดแบบ IAF โครงการต้องควบคุมลักษณะของน้ำทิ้งให้เป็นไปตามเกณฑ์ที่เขตประกอบการฯ กำหนด	- ระบบบำบัดน้ำเสีย	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(7) หากพบว่าคุณภาพน้ำในบ่อรองรับน้ำทิ้งจากระบบบำบัดแบบ IAF (IAF Effluent Sump) ไม่อยู่ในเกณฑ์ที่เขตประกอบการฯ กำหนด ทางโครงการต้องส่งกลับไปยังต้นทาง คือ ระบบบำบัดแบบ CPI เพื่อบำบัดใหม่	- ระบบบำบัดน้ำเสีย	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(8) ควบคุมคุณภาพน้ำทิ้งของโครงการจากหน่วย SCTU โดยกำหนดให้มีการตรวจวัดคุณภาพน้ำโดยโครงการ (Internal Check) เพื่อควบคุมการทำงานของระบบบำบัดให้มีประสิทธิภาพในการบำบัดน้ำทิ้งให้มีคุณภาพตามเกณฑ์มาตรฐาน ก่อนส่งเข้าสู่บ่อตรวจสอบคุณภาพน้ำทิ้งของเขตประกอบการฯ ฝั่งทะเล และระบายลงสู่ทะเลต่อไปดังนี้ 1) บริเวณขาออกจากถังรักษาระดับ (Equalization Tank; EQT) ก่อนเข้าระบบบำบัดแบบชีวภาพ (Bio Aeration) ซึ่งจะทำการตรวจวัด - การตรวจวัดแบบต่อเนื่อง (Online) ประกอบด้วย ค่า pH อุณหภูมิ และปริมาณของแข็งละลายทั้งหมด (TDS) กรณีที่พบว่าน้ำที่ออกจากบ่อกักเก็บ (Equalization Tank) มีค่าตรวจวัดสูงกว่าค่าควบคุมที่กำหนด ได้แก่ ค่า TDS มากกว่า 18,500 ส่วนในล้านส่วนหรือค่า pH น้อยกว่า 6.5 หรือมากกว่า 8 หรืออุณหภูมิสูงกว่า 40 องศาเซลเซียสจะทำการตรวจสอบ และปรับสัดส่วน Neutralized Brine และ Spent Water หากค่าตรวจวัดยังคง	- หน่วย SCTU	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
3. คุณภาพน้ำ (ต่อ)	มีค่าสูงขึ้น คือ TDS มากกว่า 19,000 ส่วนในล้านส่วนหรือค่า pH น้อยกว่า 6 หรือมากกว่า 8.5 หรืออุณหภูมิสูงกว่า 45 องศาเซลเซียส จะทำการปิดการป้อนน้ำเข้าระบบบำบัดแบบชีวภาพโดยอัตโนมัติ - ตรวจวัดปริมาณซีโอดี ค่า pH อุณหภูมิ และปริมาณของแข็งละลายทั้งหมด (TDS) สัปดาห์ละ 1 ครั้ง 2) บริเวณขาออกจากระบบบำบัดแบบชีวภาพ (Bio Aeration) โดยตรวจวัดที่ Permeate Tank ก่อนส่งเข้าสู่บ่อตรวจสอบคุณภาพน้ำทิ้งของเขตประกอบการฯ ฝั่งทะเล ซึ่งจะทำการตรวจวัด - การตรวจวัดแบบต่อเนื่อง (Online) ประกอบด้วย ปริมาณซีโอดี (COD) และปริมาณของแข็งละลายทั้งหมด (TDS) กรณีที่พบว่าน้ำที่ออกจาก Permeate Tank มีค่าตรวจวัดสูงกว่าค่าควบคุมที่กำหนด ได้แก่ ค่า TDS มากกว่า 18,500 ส่วนในล้านส่วน และค่า COD มากกว่า 100 มิลลิกรัม/ลิตร จะทำการตรวจสอบ และปรับสัดส่วน Neutralized Brine และ Spent Water หากค่าตรวจวัดยังคงมีค่าสูงขึ้น คือ TDS มากกว่า 19,000 ส่วนในล้านส่วน และค่า COD มากกว่า 110 มิลลิกรัม/ลิตร จะทำการปิดการปล่อยน้ำออกจากระบบบำบัดโดยอัตโนมัติ และวนกลับมาที่บ่อกักเก็บ (Equalization Tank) ซึ่งมีปริมาตรสำรองรองรับได้ประมาณ 3 ชั่วโมง ทั้งนี้ ในกรณีที่บ่อกักเก็บ (Equalization Tank) เต็มจะทำการปิดการป้อน Spent Caustic และ Spent Water เข้าระบบโดยอัตโนมัติซึ่ง Spent Caustic ที่เกิดขึ้นจากกระบวนการผลิตจะถูกเก็บไว้ที่ถังเก็บ Spent Caustic (77T012) ที่มีความจุใช้งาน 80 ลูกบาศก์เมตร ซึ่งสามารถกักเก็บ Spent Caustic ได้ประมาณ 6 ชั่วโมง - ตรวจวัดปริมาณซีโอดี (COD) ค่า pH อุณหภูมิ และปริมาณของแข็งละลายทั้งหมด (TDS) สัปดาห์ละ 1 ครั้ง กรณีที่หน่วย SCTU ขัดข้อง โครงการจะส่ง Spent Caustic ที่เกิดขึ้นไปกำจัดยังหน่วยงานภายนอกที่ได้รับอนุญาตจากหน่วยงานราชการ และส่งน้ำ Spent water กลับไปบำบัดยังระบบบำบัดน้ำเสียส่วนกลางแห่งที่ 3 ของเขตประกอบการฯ			
	(9) ควบคุมลักษณะของน้ำทิ้งที่ออกจากระบบบำบัดแบบ SCTU ที่ส่งเข้าบ่อตรวจสอบคุณภาพน้ำของเขตประกอบการอุตสาหกรรมฯ ให้เป็นไปตามประกาศกระทรวงอุตสาหกรรม เรื่อง กำหนดมาตรฐานควบคุมการระบายน้ำทิ้งจากโรงงาน พ.ศ. 2560	หน่วย SCTU	ตลอดช่วงดำเนินการ	บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
3. คุณภาพน้ำ (ต่อ)	(10) น้ำฝนที่ตกภายในส่วนการผลิตหลังจาก 15 นาทีแรก ซึ่งเป็นน้ำฝนไม่ปนเปื้อน จะถูกระบายลงรางคอนกรีตแบบเปิด และส่งไปยังระบบบำบัดแบบ API (API Pond) ขนาด 7,700 ลูกบาศก์เมตร ก่อนส่งต่อไปยังบ่อหน่วงน้ำ (Detention Pond) ของเขตประกอบการฯ ต่อไป	- ระบบระบายน้ำฝนและระบบบำบัดน้ำเสีย	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(11) น้ำฝนที่ตกนอกพื้นที่กระบวนการผลิต เช่น อาคารสำนักงาน ถนน เป็นต้น จะถูกระบายลงรางคอนกรีตแบบเปิด ก่อนส่งต่อไปยังบ่อหน่วงน้ำของเขตประกอบการฯ ต่อไป	- ระบบระบายน้ำฝน	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(12) ตรวจสอบน้ำจาก Blowdown Sump โดยหากพบว่ามีน้ำมันปนเปื้อน ให้สูบไปยังบ่อรวบรวมน้ำปนเปื้อนน้ำมัน (Common Oily Water Basin) เพื่อบำบัดโดยระบบบำบัดแบบ CPI และ IAF ก่อนส่งไปยังระบบบำบัดน้ำเสียส่วนกลางของเขตประกอบการฯ	- Blowdown Sump	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(13) จัดให้มีการตรวจสอบและซ่อมบำรุงอุปกรณ์ในระบบบำบัดน้ำเสียตามแผนบำรุงรักษาเชิงป้องกัน (Preventive Maintenance Program) เพื่อให้ระบบบำบัดน้ำเสียสามารถทำการบำบัดน้ำเสียได้อย่างมีประสิทธิภาพตลอดเวลา	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(14) จัดให้มีเจ้าหน้าที่ประจำที่มีประสบการณ์เพื่อทำหน้าที่ควบคุมระบบบำบัดน้ำเสียของโครงการ	- ระบบบำบัดน้ำเสีย	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(15) จัดทีมซ่อมบำรุง และจัดเตรียมอะไหล่ หรืออุปกรณ์สำรองของระบบบำบัดน้ำเสียเพื่อให้สามารถดำเนินการแก้ไขซ่อมแซมหรือเปลี่ยนใหม่ได้ทันที	- ระบบบำบัดน้ำเสีย	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(16) พิจารณานำน้ำที่ผ่านการบำบัดแล้ว มาใช้ประโยชน์ให้มากที่สุด เช่น นำไปรดน้ำต้นไม้และสนามหญ้า ใช้ทำความสะอาดพื้น ถนน และลานหรือใช้เป็นแหล่งน้ำสำรองสำหรับการดับเพลิง เป็นต้น	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(17) สารอินทรีย์ระเหยที่เกิดขึ้นจากบ่อรวบรวมน้ำปนเปื้อนน้ำมัน (Common Oily Water Basin) ระบบบำบัดน้ำเสียแบบ CPI และระบบบำบัดน้ำเสียแบบ IAF จะถูกรวบรวมไปใช้เป็นอากาศในการเผาไหม้ในกระบวนการผลิต	- ระบบบำบัดน้ำเสีย	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(18) กำหนดให้จัดทำทิศทางการไหลของน้ำใต้ดินภาคสนามให้แล้วเสร็จก่อนเปิดดำเนินการส่วนที่ขอเปลี่ยนแปลงในครั้งนี้	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(19) กำหนดให้โครงการมีการศึกษาความเป็นไปได้ในการนำน้ำทิ้งกลับมาใช้ใหม่ เช่น น้ำทิ้งจากหอหล่อเย็น น้ำล้างย้อนจากระบบผลิตน้ำลดแร่ เป็นต้น	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
4. การจัดการกากของเสีย	(1) ขยะมูลฝอยจากอาคารสำนักงานจะส่งให้หน่วยงานภายนอกที่รับกำจัด เช่น เทศบาล	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(2) ของเสียจากกระบวนการผลิตซึ่งเป็นกากของเสียอันตรายจะถูกส่งไปกำกัดยังหน่วยงานรับกำจัดของเสียที่ได้รับอนุญาตจากทางราชการ ประกอบด้วย - ตัวเร่งปฏิกิริยาเติมไฮโดรเจน ปริมาณ 771.3 ลบ.ม./4 ปี - ตัวเร่งปฏิกิริยาการเปลี่ยนโครงสร้างโดยใช้ไอน้ำ ปริมาณ 19.38 ลบ.ม./4 ปี - ตัวเร่งปฏิกิริยา High Temperature Shift (HTS) ปริมาณ 15.5 ลบ.ม./4 ปี - ตัวเร่งปฏิกิริยาในหน่วย Premutable Reactor ปริมาณ 426.3 ลบ.ม./ปี - ตัวเร่งปฏิกิริยาแตกโมเลกุล (Cracking (Fine Catalyst)) ปริมาณ 5.4 ตัน/วัน - ตัวเร่งปฏิกิริยาใน Diene Reactor ปริมาณ 18.2 ตัน/4 ปี - ตัวเร่งปฏิกิริยาในหน่วยกำจัดกำมะถัน ปริมาณ 38.8 ตัน/4 ปี - ตัวเร่งปฏิกิริยาในหน่วยปรับปรุงคุณภาพ (Pretreatment Section) ปริมาณ 22.5 ตัน/6 ปี - ตัวเร่งปฏิกิริยาการเกิดโอลิโกเมอร์ (Oligomerization Section) ปริมาณ 139.2 ตัน/8 ปี - ตัวเร่งปฏิกิริยากำจัดอะเซทิลีน ปริมาณ 7.9 ตัน/4ปี - ตัวเร่งปฏิกิริยาคลอส ปริมาณ 64.6 ลบ.ม./4 ปี - สารดูดซับกำมะถันในหน่วยปรับปรุงวัตถุดิบ ปริมาณ 28 ลบ.ม./ปี - สารดูดซับคลอไรด์ในหน่วยปรับปรุงวัตถุดิบ ปริมาณ 9 ลบ.ม./ปี - สารดูดซับในหน่วยทำไฮโดรเจนบริสุทธิ์ (PSA Adsorbent) ปริมาณ 350 ตัน/10 ปี - สารดูดซับความชื้นในอากาศ (Plant Air Dryer) ปริมาณ 1.1 ตัน/ปี - สารดูดซับกำมะถัน (Sulphur Guard Bed) ปริมาณ 5.3 ตัน/7 ปี	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
4. การจัดการกากของเสีย (ต่อ)	- สารดูดซับความชื้นไฮโดรคาร์บอนและไนโตรเจน ปริมาณ 46.8 ตัน/4 ปี - สารดูดซับความชื้น ปริมาณ 117.7 ตัน/4 ปี - สารดูดซับสารประกอบเมอร์แคปแทน (RSH) และคาร์บอนิลซัลไฟด์ (COS) ปริมาณ 69.1 ตัน/4 ปี - สารดูดซับสารอาร์ไซด์ ปริมาณ 30 ตัน/4 ปี - สารดูดซับก๊าซแอมโมเนีย/อาร์ไซด์ ปริมาณ 8.2 ตัน/4 ปี - สารดูดซับของเหลว ปริมาณ 9.0 ตัน/4 ปี - ถ่านกัมมันต์ ปริมาณ 16.1 ลบ.ม./ปี - สารดูดซับในเครื่องดูดซับไอสารไฮโดรคาร์บอน (Carbon Canister) ที่หมดอายุการใช้งาน ปริมาณ 4 ลบ.ม./ปี - ตัวเร่งปฏิกิริยาที่หมดอายุการใช้งานในระบบบำบัดมลสารทางอากาศ (Selective Catalyst Reduction) ปริมาณ 80 ลบ.ม./4 ปี - กากตะกอน (Sludge) จากระบบบำบัดน้ำเสียแบบชีวภาพ (Bio-Aeration) ปริมาณ 268.8 กก./วัน - ตัวกรองถ่านกัมมันต์ (AC Filter) จากระบบบำบัดน้ำเสียแบบชีวภาพ (Bio-Aeration) ปริมาณ 2.25 ตัน/5 ปี			
	(3) น้ำมันที่แยกได้จากระบบบำบัดน้ำเสียเบื้องต้น ประกอบด้วย Waste Oil จากระบบ CPI ปริมาณประมาณ 170 ตัน ส่งไปยังถังรวบรวมน้ำมัน (Slop Tank) และส่งกลับ (Recycle) กลับไปที่โรงกลั่นน้ำมัน และ Scum Oil จากระบบ IAF ปริมาณประมาณ 30 ตัน จะบรรจุในภาชนะที่เหมาะสม ก่อนส่งไปกำจัดยังศูนย์รับกำจัดกากของเสียที่ได้รับอนุญาตจากหน่วยงานราชการ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(4) ของเสียจากการซ่อมบำรุง ประกอบด้วย 1) การซ่อมบำรุงรักษาเชิงป้องกัน (Preventive Maintenance) ได้แก่ ฉนวน เศษโลหะ เศษผ้าเปื้อนสารเคมี/น้ำมัน น้ำมันหล่อลื่นที่ใช้แล้วปริมาณรวมประมาณ 2.35 ตัน/ครั้ง	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
4. การจัดการกากของเสีย (ต่อ)	2) การซ่อมบำรุงใหญ่ (Turnaround) ได้แก่ - ฉนวน เศษโลหะ เศษผ้าเปื้อนสารเคมี/น้ำมัน น้ำมันหล่อลื่นที่ใช้แล้วปริมาณรวมประมาณ 10.05 ตัน/ครั้ง - กากตะกอนจากระบบบำบัดน้ำเสียเบื้องต้นแบบ CPI ปริมาณประมาณ 170 ตัน/ครั้ง - กากตะกอนจากการทำความสะอาดเครื่องแลกเปลี่ยนความร้อนและถังปริมาณประมาณ 20 ตัน/ครั้ง ของเสียจากการซ่อมบำรุงจะรวบรวมในภาชนะที่บรรจุมิดชิด ก่อนส่งไปกำจัดยังศูนย์รับกำจัดกากของเสียที่ได้รับอนุญาตจากหน่วยงานราชการ			
	(5) ของเสียจากระบบผลิตน้ำลดแร่ (Demineralized Water System) ประกอบด้วย 1) ถ่านกัมมันต์ที่หมดอายุการใช้งานปริมาณ 12.6 ลูกบาศก์เมตร/3-5 ปี 2) Cation Exchanger Resin ที่หมดอายุการใช้งานปริมาณ 20.05 ลูกบาศก์เมตร/5 ปี 3) Anion Exchanger Resin ที่หมดอายุการใช้งานปริมาณ 24.40 ลูกบาศก์เมตร/3 ปี 4) สารดูดซับใน Mixed Bed Polisher ที่หมดอายุการใช้งานปริมาณ 6.30 ลูกบาศก์เมตร/3-5 ปี ของเสียจากระบบผลิตน้ำลดแร่จะรวบรวมในภาชนะบรรจุที่ปิดมิดชิดเพื่อส่งไปกำจัดยังศูนย์กำจัดกากของเสียที่ได้รับอนุญาตจากหน่วยงานราชการ หรือส่งไปคืนสภาพที่บริษัทผู้จำหน่าย	- ระบบผลิตน้ำลดแร่	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(6) กำหนดระเบียบปฏิบัติงานการจัดเก็บเคลื่อนย้ายของเสีย และกำหนดให้มีพนักงานรับผิดชอบในการควบคุมและดูแลการจัดเก็บและเคลื่อนย้ายของเสีย	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(7) คัดเลือกบริษัทขนส่งและรับกำจัดของเสียที่ได้รับอนุญาตจากหน่วยงานราชการ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(8) จัดเตรียมภาชนะแยกตามประเภทของขยะมูลฝอยพร้อมทั้งติดฉลากแยกประเภทมูลฝอยที่ภาชนะ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(9) ให้มีการคัดแยกขยะ และมีการจัดการที่เหมาะสม เช่น ขยะที่สามารถนำกลับไปใช้ใหม่ได้ เป็นต้น	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
4. การจัดการกากของเสีย (ต่อ)	(10) จัดให้มีพื้นที่จัดเก็บกากของเสียเป็นอาคารจัดเก็บที่เป็นพื้นที่ที่มีหลังคาปกคลุมมิดชิด รวมทั้งจัดแบ่งพื้นที่ตามประเภทกากของเสียและจัดให้มีคันกั้นโดยรอบพื้นที่จัดเก็บกากของเสีย เพื่อรวบรวมน้ำฝนในพื้นที่จัดเก็บกากของเสีย และจัดให้มีระบบรวบรวมกรณีที่มีสารเคมีหกรั่วไหลและน้ำเสียที่เกิดขึ้นเพื่อรวบรวมและส่งน้ำเสียไปบำบัดยังระบบบำบัดน้ำเสียของโครงการ	พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(11) กำหนดให้รถขนส่งกากของเสียอุตสาหกรรมต้องติดตั้งระบบติดตามยานพาหนะ (Global Positioning System; GPS) และติดเบอร์โทรศัพท์ เพื่อเป็นช่องทางในการแจ้งเรื่องร้องเรียนมายังโครงการ	- บริเวณเส้นทางขนกากของเสีย	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(12) ติดป้ายเตือนอันตรายบนตัวรถที่บรรทุกกากของเสียอันตราย พร้อมทั้งระบุชื่อและหมายเลขโทรศัพท์ของบริษัทที่รับกำจัดของเสียให้สามารถเห็นได้ชัดเจน	- บริเวณเส้นทางขนกากของเสีย	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(13) ตรวจสอบบริษัทที่รับกำจัดของเสียทุกบริษัท อย่างน้อย 1 ครั้ง/ปี	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(14) การจัดการของเสียให้ปฏิบัติตามประกาศกระทรวงอุตสาหกรรม เรื่อง การจัดการสิ่งปฏิกูลหรือวัสดุที่ไม่ใช้แล้ว พ.ศ. 2548 อย่างเคร่งครัด ทั้งนี้ ในกรณีที่มีการส่งของเสียออกนอกประเทศ โครงการจะต้องปฏิบัติตามกฎหมายที่เกี่ยวข้องกำหนด	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(15) จัดให้มีระบบรายงานกากของเสีย (Manifest) เป็นมาตรการรองรับในระบบการกักเก็บ ขนส่ง ลำเลียง และส่งกำจัดกากของเสียออกไปกำจัดภายนอก	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(16) จัดทำแผนการป้องกันอุบัติภัยเพื่อรองรับเหตุฉุกเฉินในกรณีเกิดเหตุรั่วไหล อัคคีภัย การระเบิดของสิ่งปฏิกูลหรือวัสดุที่ไม่ใช้แล้ว หรือเหตุการณ์ที่คาดไม่ถึง และต้องมีอุปกรณ์รักษาความปลอดภัยและอุปกรณ์รองรับเหตุฉุกเฉินภายในบริเวณโรงงาน และมีเส้นทางหนีภัยไปยังที่ปลอดภัย	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
5. เสียง	(1) เครื่องจักร/อุปกรณ์ที่มีเสียงดัง เช่น เครื่องอัดก๊าซไฮโดรเจน ต้องติดตั้งฉนวนเพื่อลดเสียงจากอุปกรณ์	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(2) จัดให้มีอุปกรณ์ป้องกันเสียง ได้แก่ ที่อุดหู หรือที่ครอบหู ให้กับพนักงาน	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(3) ติดป้ายเตือนการสวมใส่อุปกรณ์ป้องกันเสียงในบริเวณพื้นที่ที่มีระดับเสียงดังเกิน 85 เดซิเบลเอ และควบคุมให้พนักงานสวมใส่อุปกรณ์ป้องกันเสียงเมื่อต้องเข้าไปในพื้นที่	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(4) จัดให้มีการอบรมเรื่องความสำคัญของการสวมใส่อุปกรณ์ป้องกันเสียงและผลกระทบจากการสัมผัสเสียงดัง	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(5) ตรวจสอบซ่อมบำรุงรักษาอุปกรณ์ ตามแผนบำรุงรักษาเชิงป้องกัน (Preventive Maintenance Plan) เพื่อป้องกันมิให้เกิดการผิดปกติ หรือเสียงดัง	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(6) กำหนดให้ระดับเสียงที่บริเวณริมรั้วของโครงการต้องมีระดับเสียงไม่เกิน 70 เดซิเบลเอ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(7) จัดทำผังแสดงเส้นเสียง (Noise Contour Map) เพื่อใช้กำหนดพื้นที่ที่มีเสียงดัง	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
6. การคมนาคม	(1) กวดขันให้พนักงานขับรถปฏิบัติตามกฎและเครื่องหมายจราจร	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(2) ติดป้ายจำกัดความเร็วในพื้นที่โครงการ ไม่เกิน 20 กิโลเมตร/ชั่วโมง และจำกัดความเร็วยานพาหนะที่เข้า-ออกพื้นที่โรงงาน	- พื้นที่โครงการและถนนสาธารณะทั่วไป	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(3) หลีกเลี่ยงการขนส่งวัตถุดิบ ผลิตภัณฑ์ และสารเคมี ในชั่วโมงเร่งด่วน (7.30-8.30 น. และ 16.30-17.30 น.)	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(4) จัดพื้นที่โดยเฉพาะสำหรับจอดรถบรรทุกวัตถุดิบ/ผลิตภัณฑ์	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(5) จดบันทึกชนิดและจำนวนยานพาหนะที่เข้า-ออกพื้นที่โรงงาน	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
6. การคมนาคม (ต่อ)	(6) อบรมพนักงานขับรถให้มีความรู้เกี่ยวกับสารที่บรรทุก และกำชับพนักงานขับรถให้มีความระมัดระวังเป็นพิเศษ	- บริเวณเส้นทางขนวัสดุอุปกรณ์	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(7) ควบคุมให้บริษัทผู้รับจ้างขนส่งจัดเตรียมเอกสารกำกับการขนส่งและข้อมูลความปลอดภัยเคมีภัณฑ์ (SDS) พร้อมทั้งติดชื่อสารเคมี สัญลักษณ์ความเป็นอันตรายและเบอร์โทรศัพท์ติดต่อ เพื่อเป็นช่องทางในการแจ้งเรื่องร้องเรียนมายังโครงการรวมทั้งจัดให้มีคู่มือการระงับอุบัติภัยจากวัตถุอันตราย ซึ่งระบุขั้นตอนการตอบโต้เหตุฉุกเฉินไว้อย่างชัดเจน เพื่อใช้เป็นแนวทางปฏิบัติให้กับพนักงานขับรถขนส่งสารเคมี	- บริเวณเส้นทางขนวัสดุอุปกรณ์	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(8) ควบคุมน้ำหนักในการบรรทุกไม่ให้เกินความสามารถสูงสุดในการบรรทุก เพื่อป้องกันความเสียหายของผิวการจราจร	- บริเวณเส้นทางขนวัสดุอุปกรณ์	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(9) ตรวจสอบสภาพรถทุกครั้งก่อนใช้งาน	- รถขนส่งวัตถุดิบ สารเคมี ผลิตภัณฑ์และกากของเสีย	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(10) คัดเลือกบริษัทขนส่งที่มีการติดตั้งระบบ Global Positioning System (GPS) และระบบควบคุมความเร็วรถ	- รถขนส่งวัตถุดิบ สารเคมี ผลิตภัณฑ์และกากของเสีย	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(11) จัดให้มีพนักงานรักษาความปลอดภัยและอำนวยความสะดวกบริเวณถนนทางเข้า - ออกพื้นที่โครงการ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)


องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
7. สังคมและเศรษฐกิจ	(1) พิจารณาจ้างแรงงานท้องถิ่นที่มีคุณสมบัติเหมาะสมตามความต้องการของโรงงานเป็นอันดับแรก เพื่อส่งเสริมสภาพเศรษฐกิจสังคมของคนในชุมชนโดยตรงและเป็นการสร้างความสัมพันธ์อันดีกับชุมชน	- ชุมชนใกล้เคียง	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(2) เนื่องจากโครงการตั้งอยู่ภายในเขตประกอบการอุตสาหกรรมไออาร์พีซี ดังนั้น เพื่อเปิดโอกาสให้ประชาชนเข้ามามีส่วนร่วมให้ได้มากและมีประสิทธิภาพในการทำงาน จึงให้โครงการร่วมกับเขตประกอบการฯ จัดตั้งคณะกรรมการพัฒนาศักยภาพโครงการ และพัฒนาชุมชนและสังคมเขตประกอบการอุตสาหกรรม บริษัท ไออาร์พีซี จำกัด (มหาชน) อำเภอเมืองระยอง จังหวัดระยอง (คพอ.) หรือคณะกรรมการพหุภาคี โดยมีคณะทำงานย่อย คือ คณะกรรมการติดตามตรวจสอบและเฝ้าระวังคุณภาพสิ่งแวดล้อมและสุขภาพ (EIA/EHIA Monitoring Committee) เพื่อให้มีส่วนร่วมในการกำกับ ดูแล ตรวจสอบการปฏิบัติตามมาตรการฯ เสนอแนะเกี่ยวกับแนวทางป้องกันและแก้ไขข้อร้องเรียนจากแต่ละภาคส่วน มีส่วนร่วมในการเสนอแนะกิจกรรมมวลชนสัมพันธ์ และการชดเชยเยียวยา ทั้งนี้ คณะกรรมการพัฒนาศักยภาพโครงการ และพัฒนาชุมชนและสังคม (คพอ.) ประกอบด้วยตัวแทนภาคประชาชน ตัวแทนภาคราชการ และตัวแทนภาคเอกชน โดยมีสัดส่วนผู้แทนชุมชนที่ไม่มีตำแหน่งบริหาร หรือตำแหน่งชุมชนไม่น้อยกว่ากึ่งหนึ่งขององค์ประกอบคณะทำงานฯ ในระยะต้นกำหนดวาระในการดำรงตำแหน่งคราวละ 3 ปี และดำรงตำแหน่งติดต่อกันได้ไม่เกิน 2 วาระ คณะกรรมการฯ อาจพ้นสภาพเมื่อตาย ลาออก ย้ายภูมิลำเนา (กรณีตัวแทนภาคประชาชน) หรือพ้นสภาพจากพนักงานบริษัท หรือหน่วยงานที่เกี่ยวข้อง (กรณีตัวแทนของโครงการ ตัวแทนหน่วยงานราชการ และตัวแทนผู้ทรงคุณวุฒิด้านสิ่งแวดล้อม) และขาดคุณสมบัติของคณะกรรมการฯ หากมีกรรมการท่านใดพ้นสภาพตามเงื่อนไขข้างต้นจะต้องดำเนินการคัดเลือกคณะกรรมการท่านใหม่ทดแทนตามเงื่อนไขที่กำหนดให้แล้วเสร็จภายใน 90 วัน โดยคณะกรรมการมีบทบาทหน้าที่ ดังนี้ - ประสานงานและกำกับดูแลให้โครงการดำเนินการโดยไม่ส่งผลกระทบต่อสิ่งแวดล้อม - ให้คำปรึกษา เสนอแนะแนวทาง และประสานงานแก้ไขปัญหาสิ่งแวดล้อม และข้อร้องเรียนของชุมชนอันเนื่องมาจากการดำเนินงานของโครงการฯ/กลุ่มบริษัท	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
7. สังคมและเศรษฐกิจ (ต่อ)	- พิจารณาและให้ข้อคิดเห็นต่อขั้นตอนและวิธีการดำเนินงานที่อาจก่อให้เกิดผลกระทบสิ่งแวดล้อม ตลอดจนประสานงานกับหน่วยงานอื่น ๆ ที่เกี่ยวข้อง - เชิญบุคคลหรือเจ้าหน้าที่ที่เกี่ยวข้องเพื่อให้ข้อมูล คำปรึกษา หรือข้อเสนอแนะได้ตามความจำเป็น - ในกรณีที่มีการก่อสร้างและทดลองเดินเครื่องให้บริษัทฯ นำเสนอความก้าวหน้าโครงการต่อคณะทำงานฯ ตามความเหมาะสม - จัดให้มีการส่งเสริมความรู้ หรือเสริมสร้างความเข้าใจเกี่ยวกับการจัดการสิ่งแวดล้อมให้แก่ประชาชนและชุมชนอย่างต่อเนื่อง - พิจารณาจัดทำแผนงานประชาสัมพันธ์และความรับผิดชอบต่อสังคมของโครงการฯ ทั้งระยะสั้น ระยะยาว และแบบชั่วคราวให้เหมาะสมกับชุมชน - พิจารณาการชดเชยและเยียวยา หากเป็นปัญหาที่พิสูจน์แล้วว่าเกิดจากการดำเนินการของโครงการ - จัดให้มีการอบรม/ให้ความรู้/การดูงานภายใน 6 เดือน หลังจากการจัดตั้งและทุก 2 ปี เพื่อเพิ่มเติมความรู้ใหม่หรือตามความเหมาะสม องค์ประชุมและความถี่ในการประชุม กำหนดให้มีวาระการประชุมอย่างน้อยปีละ 2 ครั้ง หรือมากกว่านั้นหากมีเหตุจำเป็นเร่งด่วน เพื่อติดตามผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อมและมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมและแผนมวลชนสัมพันธ์			
	(3) ดำเนินการประชาสัมพันธ์เกี่ยวกับระบบการจัดการด้านสิ่งแวดล้อม เช่น ระบบการจัดการน้ำเสีย ระบบการจัดการกากของเสีย ระบบควบคุมการระบายมลพิษทางอากาศจากปล่อง เป็นต้น ให้ชุมชนได้ทราบโดยผ่านสื่อประชาสัมพันธ์ต่าง ๆ เช่น แผ่นพับ เอกสารข่าว หรือจัดให้มีการเข้าเยี่ยมชมโครงการ	- ชุมชนใกล้เคียง	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(4) จัดให้มีแผนงานประจำปีด้านมวลชนสัมพันธ์หรือกิจกรรมสาธารณประโยชน์โดยรวบรวมข้อมูลจากการสำรวจความคิดเห็นของชุมชนมาวิเคราะห์เพื่อกำหนดกิจกรรมที่เหมาะสมและสอดคล้องกับความต้องการของชุมชนซึ่งกิจกรรมดังกล่าวต้องครอบคลุมกลุ่มเป้าหมาย ได้แก่ ชุมชน โรงเรียน ศาสนสถาน และหน่วยงานราชการโดยรอบพื้นที่โครงการ รัศมี 5 กิโลเมตร	- ชุมชนใกล้เคียง และหน่วยงานท้องถิ่นที่เกี่ยวข้อง	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
7. สังคมและเศรษฐกิจ (ต่อ)	(5) จัดให้มีช่องทางรับข้อร้องเรียนจากชุมชน และประชาสัมพันธ์ช่องทางดังกล่าวให้ชุมชนได้ทราบ ซึ่งสามารถยื่นข้อร้องเรียนได้โดยการส่งจดหมาย โทรศัพท์ โทรสาร หรือร้องเรียนโดยตรงกับทางโครงการ	- ชุมชนใกล้เคียง	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(6) ปฏิบัติตามขั้นตอนการรับเรื่องร้องเรียน ดัง**รูปที่ 3** โดยหากพบว่าข้อร้องเรียนที่เกิดขึ้นเป็นผลกระทบจากการดำเนินงานของโครงการ ทางโครงการจะเร่งปรับปรุงแก้ไขโดยเร็วที่สุดและรายงานผลการแก้ไขต่อผู้ร้องเรียนและฝ่ายบริหารของโรงงาน	- ชุมชนใกล้เคียง	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
8. อาชีวอนามัย และความปลอดภัย	**เรื่องทั่วไป**			
	(1) จัดให้มีนโยบายด้านคุณภาพ สิ่งแวดล้อม ความปลอดภัย และอาชีวอนามัย และประกาศให้ทราบโดยทั่วถึง	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(2) จัดตั้งคณะกรรมการความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงาน รวมทั้งจัดให้มีเจ้าหน้าที่ความปลอดภัยในการทำงาน	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(3) จัดให้มีแผนงานด้านอาชีวอนามัยและความปลอดภัยประจำปี รวมทั้งมีการพิจารณาทบทวนทุกปี เพื่อนำไปสู่การดำเนินงานด้านอาชีวอนามัยและความปลอดภัยของโครงการอย่างมีประสิทธิภาพต่อไป	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(4) จัดทำคู่มือความปลอดภัย และมีการอบรมให้ความรู้เกี่ยวกับลักษณะการปฏิบัติงานที่ปลอดภัยให้พนักงานทุกระดับ เช่น การใช้อุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคล ข้อกำหนดและกฎเกณฑ์การทำงานในพื้นที่ที่มีความเสี่ยงต่อการเกิดอันตราย เป็นต้น	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(5) กำหนดให้โครงการดำเนินการจัดทำระบบมาตรฐานการจัดการด้านอาชีวอนามัยและความปลอดภัย (ISO 45001) หรือเป็นไปตามการปรับปรุงมาตรฐานที่กำหนด	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(6) กำหนดให้มีการตรวจสอบความปลอดภัย (Safety Audit) เพื่อประเมินความปลอดภัยของสถานที่ทำงาน ทั้งสภาพการณ์ที่ไม่ปลอดภัย (Unsafe Condition) และการกระทำที่ไม่ปลอดภัย (Unsafe Action) เพื่อหาแนวทางป้องกันอุบัติเหตุที่อาจจะเกิดขึ้นและเสนอแนะแนวทางในการป้องกันอุบัติเหตุ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(7) จัดให้มีแผนการตรวจสอบความปลอดภัยประจำปี และตรวจสอบความปลอดภัยประจำพื้นที่	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)



รูปที่ 3 ขั้นตอนการรับเรื่องร้องเรียน

[redacted]

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
8. อาชีวอนามัยและความปลอดภัย (ต่อ)	(8) จัดให้มีแผนงานด้านสุขศาสตร์อุตสาหกรรม และเจ้าหน้าที่สุขศาสตร์อุตสาหกรรมเพื่อสำรวจและตรวจประเมินสิ่งคุกคามต่อสุขภาพอนามัยของพนักงาน	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(9) จัดกิจกรรมส่งเสริมความปลอดภัยในการปฏิบัติงาน เช่น จัดทำโปสเตอร์ข้อมูลข่าวสารด้านความปลอดภัย เป็นต้น	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(10) จัดให้มีระบบการขออนุญาตทำงาน (Work Permit)	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(11) ดูแลพื้นที่โครงการให้สะอาดและเป็นระเบียบเรียบร้อยตลอดเวลา	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(12) การรับ-จ่ายวัตถุดิบ/ผลิตภัณฑ์ต้องปฏิบัติตาม Work Instruction อย่างเคร่งครัด	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(13) พนักงานที่ทำงานเกี่ยวข้องกับสารเคมีต้องได้รับการอบรมและดำเนินการตามข้อมูลความปลอดภัยด้านเคมีภัณฑ์อย่างเคร่งครัด เพื่อป้องกันและลดผลกระทบที่อาจเกิดขึ้นต่อสุขภาพพนักงานและสภาพแวดล้อมโดยรอบ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(14) จัดเตรียมเอกสารเกี่ยวกับสารเคมีที่ใช้และคำแนะนำในการใช้และปฏิบัติตามอย่างเคร่งครัด	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(15) กำหนดระยะเวลาการสัมผัสเสียงดังของพนักงานไม่ให้สัมผัสระดับเสียงเกินเกณฑ์กฎหมายที่เกี่ยวข้องกำหนด เช่น ประกาศกระทรวงอุตสาหกรรม เรื่อง มาตรการคุ้มครองความปลอดภัยในการประกอบกิจการโรงงานเกี่ยวกับสภาพแวดล้อมในการทำงาน พ.ศ. 2546 และประกาศกรมสวัสดิการและคุ้มครองแรงงาน เรื่อง มาตรฐานระดับเสียงที่ยอมให้ลูกจ้างได้รับเฉลี่ยตลอดระยะเวลาการทำงานในแต่ละวัน พ.ศ. 2561 เป็นต้น	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
8. อาชีวอนามัย และความปลอดภัย (ต่อ)	(16) จัดให้มีมาตรการอนุรักษ์การได้ยิน (Hearing Conservation Program) เพื่อลดโอกาสที่พนักงานจะสัมผัสเสียงดังอย่างต่อเนื่องจากการทำงาน	- พนักงานที่สัมผัสเสียงดังเกิน 85 เดซิเบลเอ อย่างต่อเนื่องเกินกว่า 8 ชั่วโมง - พนักงานที่มีผลการตรวจสมรรถภาพการได้ยิน (Audiometry) ผิดปกติเมื่อเทียบกับ Baseline Audiometry และแพทย์อาชีวเวชศาสตร์วินิจฉัยว่าสัมพันธ์กับการทำงาน	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	การตรวจสุขภาพ (17) กำหนดให้มีการตรวจสุขภาพของพนักงานโดยแพทย์อาชีวเวชศาสตร์ ประกอบด้วย การตรวจสุขภาพก่อนเข้าทำงาน การตรวจสุขภาพประจำปี และการตรวจสุขภาพกรณีโอนย้ายหรือเปลี่ยนหน่วยงาน โดยมีรายการที่ต้องตรวจตามที่มาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อม (ช่วงดำเนินการ) กำหนดไว้ แบ่งเป็นการตรวจสุขภาพโดยทั่วไป และการตรวจสุขภาพตามปัจจัยเสี่ยง	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(18) จัดให้มีสมุดสุขภาพประจำตัวพนักงาน เพื่อรวบรวมและจัดเก็บข้อมูลการตรวจสุขภาพสำหรับใช้เป็นฐานข้อมูลในการเฝ้าระวังผลกระทบด้านสุขภาพที่เกิดขึ้นจากการทำงาน	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(19) กรณีที่ผลการตรวจสุขภาพพนักงานพบว่ามีความผิดปกติ ทางโครงการต้องทำการตรวจซ้ำ โดยให้แพทย์ทางอาชีวศาสตร์หรือแพทย์เฉพาะทางทำการวินิจฉัยและระบุสาเหตุของความผิดปกติดังกล่าว และให้ข้อแนะนำเพิ่มเติม	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(20) ดำเนินการตามแนวทางการตรวจคัดกรองสมรรถภาพการได้ยินและการแปลผล ของสำนักโรคจากการประกอบอาชีพและสิ่งแวดล้อม กรมควบคุมโรค (ฉบับปรับปรุงปี 2560 หรือฉบับล่าสุด) พร้อมทั้งนำเสนอรายละเอียดการดำเนินการในรายงานผลการปฏิบัติตามมาตรการ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)


ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
8. อาชีวอนามัย และความปลอดภัย (ต่อ)	(21) กำกับให้บริษัทรับเหมาช่วงปฏิบัติตามกฎหมายแรงงานว่าด้วยการตรวจสุขภาพร่างกายและสุขภาพตามปัจจัยเสี่ยงตามที่กฎหมายกำหนด	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(22) จัดทำรายงานและวิเคราะห์ผลการตรวจสุขภาพ รวมทั้งระบุสถานพยาบาลที่ใช้ในการตรวจวัดและช่วงเวลาที่ตรวจวัด ทั้งนี้ หน่วยงานที่ทำการตรวจวัดจะต้องเป็นหน่วยงานที่มีคุณภาพและได้รับการรับรอง	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(23) จัดทำฐานข้อมูลสุขภาพของพนักงานเพื่อนำมาใช้ประกอบการวิเคราะห์หาสาเหตุในการเกิดความผิดปกติของผลการตรวจสุขภาพของพนักงานประจำปีในแต่ละพื้นที่ดำเนินงาน โดยเฉพาะพื้นที่เสี่ยง พร้อมระบุอายุงานของคนงานที่ทำงานในพื้นที่นั้น และวิเคราะห์ความเชื่อมโยงผลการตรวจวัด เพื่อเฝ้าระวังการรับสัมผัสสิ่งคุกคามสุขภาพกับฐานข้อมูลสุขภาพด้วย	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(24) กำหนดให้มีเกณฑ์การคัดเลือกและประเมินคุณภาพของสถานบริการสุขภาพและห้องปฏิบัติการวิเคราะห์ที่โครงการใช้บริการตรวจสุขภาพของพนักงานประจำ ทั้งนี้ แนวทางการตรวจสอบและประเมินสถานบริการสุขภาพจะเป็นไปตามกระบวนการบริหารคู่ค้า (Supplier Management) เพื่อให้เกิดความโปร่งใสและเป็นธรรม (Corporate Governance)	- สถานบริการสุขภาพและห้องปฏิบัติการวิเคราะห์ที่โครงการใช้บริการตรวจสุขภาพ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	อุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคล (25) ติดตั้งป้ายเตือนการสวมใส่อุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคล ป้ายเตือนภัยในพื้นที่ที่เสี่ยงต่ออันตราย และเขตพื้นที่ที่ต้องขออนุญาตเข้าทำงานในพื้นที่	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(26) จัดเตรียมอุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคลให้เพียงพอและเหมาะสมกับประเภทงาน เช่น หมวกนิรภัย แว่นตานิรภัย รองเท้านิรภัย หน้ากากป้องกันสารเคมี อุปกรณ์ลดเสียง ที่ครอบหูปลั๊กอุดหู เป็นต้น รวมทั้งตรวจสอบสภาพความพร้อมของอุปกรณ์ก่อนนำไปใช้งาน	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(27) กำกับดูแลให้พนักงานสวมใส่อุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคล ขณะปฏิบัติงานอย่างเคร่งครัด และตรวจสอบให้มีการใช้อย่างถูกต้องและกำหนดวิธีปฏิบัติเมื่อตรวจพบว่าพนักงานไม่สวมใส่อุปกรณ์ขณะที่ปฏิบัติงานในพื้นที่ที่กำหนด	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
8. อาชีวอนามัย และความปลอดภัย (ต่อ)	**การควบคุมภาวะฉุกเฉิน** (28) จัดให้มีแผนฉุกเฉิน ประกอบด้วย แผนฉุกเฉินกรณีเกิดเพลิงไหม้หรือระเบิด แผนฉุกเฉินกรณีสารเคมีอันตรายรั่วไหล แผนฉุกเฉินกรณีรังสีรั่วไหล แผนฉุกเฉินกรณีโครงสร้างพังทลาย และแผนฉุกเฉินกรณีน้ำมันหกรั่วไหลลงทะเล โดยแบ่งระดับความรุนแรงของเหตุฉุกเฉินเป็น 4 ระดับ ดังนี้ - **ระดับ 1** หมายถึง เหตุฉุกเฉินที่เกิดขึ้นในพื้นที่ รวมถึงทรัพย์สินที่อยู่ในความรับผิดชอบของ บริษัท ไออาร์พีซี และบริษัทในเครือ และสามารถควบคุมได้โดยบุคลากรและอุปกรณ์ระงับเหตุฉุกเฉินในพื้นที่หรือทีมระงับเหตุฉุกเฉินและอุปกรณ์สนับสนุนบางส่วนจากส่วนกลาง - **ระดับ 2** หมายถึง เหตุฉุกเฉินที่เกิดขึ้นในพื้นที่ รวมถึงทรัพย์สินที่อยู่ในความรับผิดชอบของ บริษัท ไออาร์พีซี และบริษัทในเครือ ซึ่งผู้สั่งการ ณ ที่เกิดเหตุ (OC) ในขณะนั้นพิจารณาแล้วเห็นว่าเป็นเหตุการณ์ที่รุนแรง ไม่สามารถควบคุมได้ โดยบุคลากรและอุปกรณ์ระงับเหตุฉุกเฉินในพื้นที่ ต้องได้รับความช่วยเหลือจากทีมระงับเหตุฉุกเฉิน และอุปกรณ์สนับสนุนจากส่วนกลางเต็มรูปแบบ - **ระดับ 3** หมายถึง เหตุฉุกเฉินที่เกิดขึ้นในพื้นที่ รวมถึงทรัพย์สินที่อยู่ในความรับผิดชอบของ บริษัท ไออาร์พีซี และบริษัทในเครือที่เกิดขึ้นแล้วไม่สามารถระงับเหตุได้โดยทรัพยากรของ บริษัท ไออาร์พีซี และบริษัทในเครือ ต้องขอความช่วยเหลือจากหน่วยงานภายนอกของภาครัฐระดับท้องถิ่น/อำเภอและจังหวัด รวมถึงเอกชน เช่น กลุ่มบริษัทในเครือ ปตท. กลุ่ม EMAG เป็นต้น - **ระดับ 4** หมายถึง เหตุฉุกเฉินที่เกิดขึ้นในพื้นที่ รวมถึงทรัพย์สินที่อยู่ในความรับผิดชอบของ บริษัท ไออาร์พีซี และบริษัทในเครือ เกิดขึ้นแล้วไม่สามารถระงับเหตุได้โดยทรัพยากรของ บริษัท ไออาร์พีซี และบริษัทในเครือ ต้องขอความช่วยเหลือจากหน่วยงานภายนอกระดับประเทศ/ต่างประเทศ โดยองค์กรแผนฉุกเฉิน แสดงดัง**รูปที่ 4** และขั้นตอนการปฏิบัติในระหว่างเกิดเหตุฉุกเฉินของโครงการ ได้แก่ กรณีเกิดเพลิงไหม้หรือระเบิด กรณีเกิดเหตุสารเคมีอันตรายรั่วไหล กรณีเหตุโครงสร้างพังทลาย และกรณีเหตุน้ำมันหกรั่วไหลลงทะเล แสดงดัง**รูปที่ 5** ถึง**รูปที่ 8**	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)


Vision E. บริษัท วิชั่น อี คอนซัลแทนท์ จำกัด




รูปที่ 4 องค์กรแผนฉุกเฉินบริษัท ไออาร์พีซี จำกัด (มหาชน)

Vision E.


[redacted]



รูปที่ 5 ผังการปฏิบัติตามแผนฉุกเฉินการเมื่อเกิดเพลิงไหม้หรือระเบิด




รูปที่ 6 ผังการปฏิบัติตามแผนฉุกเฉินการมีเกิดเหตุสารเคมีรั่วไหล



รูปที่ 7 ผังการปฏิบัติตามแผนฉุกเฉินกรณีเหตุโครงสร้างพังทลาย

[redacted]



รูปที่ 8 ผังการปฏิบัติตามแผนฉุกเฉินกรณีเหตุน้ำมันหกรั่วไหลลงทะเล

[redacted]

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
8 อาชีวอนามัย และความปลอดภัย (ต่อ)	(29) จัดทำแผนอพยพระดับชุมชน และจัดให้มีช่องทางการแจ้งเหตุฉุกเฉินแก่ชุมชนเพื่อเตรียมความพร้อม และดำเนินการช่วยเหลือกรณีเกิดสาธารณภัย	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(30) จัดให้มีการฝึกซ้อมปฏิบัติการตามแผนฉุกเฉินของโรงงาน เพื่อให้หน่วยงานที่เกี่ยวข้องทราบถึงหน้าที่ ขั้นตอนการปฏิบัติ และการประสานงานเมื่อเกิดเหตุฉุกเฉิน และจดบันทึกรายงานการฝึกซ้อมแผนฉุกเฉิน	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(31) จัดเตรียมระบบสื่อสารที่มีประสิทธิภาพสำหรับกรณีฉุกเฉิน และแจ้งศูนย์ปฏิบัติการฉุกเฉินของเขตประกอบการฯ ให้ทราบถึงแผนในกรณีฉุกเฉินก่อนเริ่มเปิดดำเนินโครงการ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(32) จัดให้มีหน่วยงานปฐมพยาบาล พร้อมทั้งฝึกอบรมบุคลากรให้พร้อมสำหรับการปฐมพยาบาลกรณีฉุกเฉินที่อาจเกิดขึ้น	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(33) จัดให้มีหน่วยงานปฐมพยาบาล พร้อมทั้งฝึกอบรมบุคลากรให้พร้อมสำหรับการปฐมพยาบาลกรณีฉุกเฉินที่อาจเกิดขึ้น	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(34) จัดเตรียมพาหนะสำรองไว้ เพื่อใช้ในกรณีฉุกเฉินได้ทันท่วงที	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(35) จัดให้มีข้อมูลของหน่วยงานราชการ โรงพยาบาลท้องถิ่น และโรงงานข้างเคียง พร้อมช่องทางติดต่อไว้สำหรับกรณีฉุกเฉิน	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	ระบบดับเพลิง (36) ระบบดับเพลิงของโครงการถูกออกแบบให้เป็นไปตามมาตรฐาน NFPA เช่น NFPA 10, NFPA 11, NFPA 13, NFPA 15 เป็นต้น	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(37) จัดให้มีระบบน้ำดับเพลิง ซึ่งประกอบด้วย บ่อเก็บน้ำดับเพลิง เครื่องสูบน้ำดับเพลิงหัวจ่ายน้ำดับเพลิง ตู้เก็บสายฉีดน้ำดับเพลิง ม้วนสายฉีดน้ำดับเพลิง หัวฉีดน้ำดับเพลิง ระบบสเปรย์น้ำดับเพลิง และระบบพ่นน้ำดับเพลิง	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(38) ระบบสเปรย์น้ำดับเพลิงบริเวณถังเก็บก๊าซปิโตรเลียมเหลว LPG หรือสารที่มีลักษณะใกล้เคียง และจะทำงานอัตโนมัติสัมพันธ์กับระบบ Fire Detector	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(39) จัดให้มีระบบดับเพลิงบริเวณพื้นที่ที่มีอันตรายสูง (High Hazard Area) เช่น ห้องเก็บสารเคมี เป็นต้น	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
8. อาชีวอนามัย และความปลอดภัย (ต่อ)	(40) จัดให้มีระบบดับเพลิงด้วยโฟม ซึ่งประกอบด้วย ถังเก็บโฟม สถานีจ่ายโฟม ระบบฉีดโฟม ระบบสเปรย์โฟมและน้ำ และ Mobile Foam	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(41) จัดให้มีระบบฉีดโฟมดับเพลิงเข้าสู่ด้านในของถังเก็บ Flammable Liquid และ Combustible Liquid	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(42) จัดให้มีระบบดับเพลิงด้วยก๊าซ เพื่อดับเพลิงในบริเวณที่เกี่ยวข้องกับอุปกรณ์ทางระบบไฟฟ้าและสายไฟ รวมถึงสถานีไฟฟ้าย่อย	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(43) จัดให้มีเครื่องดับเพลิงติดตั้งในพื้นที่ต่าง ๆ โดยประเภทและจำนวนให้เป็นไปตามมาตรฐานที่กำหนด	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(44) จัดให้มีเครื่องช่วยหายใจพร้อมถังอากาศ เพื่อใช้ในการระงับเหตุเพลิงไหม้ในพื้นที่โรงงานที่อาจจะมีควันหรือก๊าซพิษเกิดขึ้นจากเพลิงไหม้	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	ระบบความปลอดภัย (45) ใช้ศูนย์ควบคุมภาวะฉุกเฉิน (Emergency Control Center) ของกลุ่มบริษัท IRPC เพื่อทำหน้าที่รับผิดชอบในการแจ้งเหตุ ยืนยันการเกิดเหตุ และการติดต่อสื่อสารกับผู้ที่เกี่ยวข้อง	- เขตประกอบการอุตสาหกรรมไออาร์พีซี	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(46) ติดตั้งระบบเตือนภัย ระบบแจ้งเหตุเพลิงไหม้ (Fire Alarm) พร้อมกระดิ่ง (Alarm Bell) เพื่อแจ้งเหตุเพลิงไหม้ ซึ่งสัญญาณจากระบบแจ้งเหตุเพลิงไหม้จะต้องส่งไปแสดงที่แผงควบคุมภายในห้องควบคุมการผลิต (CCR) เพื่อแจ้งเหตุและขอความช่วยเหลือให้ทันการณ์	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(47) ติดตั้งอุปกรณ์ตรวจจับควัน อุปกรณ์ตรวจจับความร้อน และอุปกรณ์ตรวจจับการรั่วไหลของก๊าซ (ก๊าซไวไฟและก๊าซพิษ) โดยสัญญาณจากอุปกรณ์ตรวจจับจะต้องส่งไปแสดงที่แผงควบคุมภายในห้องควบคุมการผลิต และศูนย์ควบคุมภาวะฉุกเฉินของ IRPC	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(48) จัดให้มีเครื่องตรวจวัดไฮโดรคาร์บอนชนิดถือหิ้ว (Portable HC Analyzer) และเครื่องตรวจวัดไฮโดรเจนซัลไฟด์ชนิดถือหิ้ว (Portable H_2S) เพื่อใช้ตรวจสอบหน้างาน	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(49) ติดตั้งไซเรนเพื่อแจ้งระดับของเหตุฉุกเฉิน โดยต้องดังได้ยินชัดเจนทั้งพื้นที่โรงงานและสั่งการทำงานด้วยพนักงานภายในห้องควบคุมการผลิต	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(50) อาคารที่มีลักษณะปิดจะต้องจัดให้มีไฟฉุกเฉินตลอดเส้นทางอพยพและภายในห้องควบคุมการผลิต	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
8. อาชีวอนามัยและความปลอดภัย (ต่อ)	(51) ติดตั้งอ่างล้างตา/ฝักบัว (Eye Washer/Showers) ในบริเวณที่มีการใช้หรือเก็บสารเคมีและติดตั้งสัญญาณเตือนไปยังห้องควบคุมการผลิต (CCR) เพื่อแจ้งเหตุ และขอความช่วยเหลือให้ทันการณ์	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(52) จัดให้มีวิทยุสื่อสาร (Walky-Talky) สำหรับประสานงานภายในโครงการในกรณีปกติและกรณีฉุกเฉิน	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(53) ติดตั้งถุงบอกทิศทางลมไว้ตามพื้นที่ส่วนต่าง ๆ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(54) จัดให้มีแผนการตรวจสอบและบำรุงรักษาเชิงป้องกัน (Preventive Maintenance Plan) สำหรับอุปกรณ์ในระบบเตือนภัย	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	อุบัติเหตุ (55) ควบคุมให้คนงานปฏิบัติตามมาตรการด้านอาชีวอนามัยและความปลอดภัยอย่างเคร่งครัดเพื่อป้องกันอุบัติเหตุ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(56) ควบคุมให้ปฏิบัติตามมาตรการด้านคมนาคม เพื่อป้องกันอุบัติเหตุที่อาจเกิดขึ้นจากการขนส่งวัตถุดิบ สารเคมี และผลิตภัณฑ์	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(57) จดบันทึกสถิติอุบัติเหตุ และเหตุการณ์เกือบเกิดอุบัติเหตุ โดยบันทึกสาเหตุ ความสูญเสีย และมาตรการป้องกันแก้ไข เพื่อป้องกันไม่ให้เกิดซ้ำ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	การชดเชยค่าเสียหาย (58) จัดทำประกันภัยประเภทกรมธรรม์ความรับผิดตามกฎหมายต่อบุคคลภายนอกเพื่อคุ้มครองความเสียหายที่อาจเกิดขึ้นต่อชีวิตและทรัพย์สินของบุคคลภายนอกอันเนื่องมาจากการดำเนินงานของโครงการ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(59) เมื่อเกิดเหตุ ผู้ที่ได้รับผลกระทบ/ผู้เสียหาย สามารถแจ้งไปยังบริษัท ไออาร์พีซี จำกัด (มหาชน) หรือพนักงานฝ่ายปกครองของหน่วยงานปกครองส่วนท้องถิ่นในพื้นที่นั้น ๆ ได้ทันที โดยหากมีผลกระทบอันมีสาเหตุมาจากการดำเนินการโครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่นต่อขุมชนตามที่ได้ศึกษาไว้ในรายงานการวิเคราะห์ผลกระทบสิ่งแวดล้อม กรณีที่เกิดการบาดเจ็บหรือเจ็บป่วย โครงการจะให้การดูแลและรับผิดชอบแก่ผู้ได้รับผลกระทบจนถึงที่สุด	- บุคคลที่ได้รับผลกระทบจากเหตุฉุกเฉินของโครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ลงชื่อ... ผู้จัดการฝ่ายบ และ	ตุลาคม 2564	ลงชื่อ...	VisionE. วิชั่น อี คอนซัลแทนท์ จำกัด หน้า 61/101

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
9. ความเสี่ยงและอันตรายร้ายแรง	**มาตรการทั่วไป** (1) ระบบป้องกันและระงับอัคคีภัย ออกแบบตามมาตรฐานสากล NFPA และ API	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(2) จัดให้มีทีมระงับเหตุฉุกเฉิน พร้อมกับจัดฝึกอบรมเพื่อเตรียมพร้อมในกรณีฉุกเฉิน	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(3) จัดเตรียมระบบสื่อสารที่มีประสิทธิภาพสำหรับกรณีฉุกเฉิน และแจ้งศูนย์ปฏิบัติการฉุกเฉินของเขตประกอบการอุตสาหกรรมไออาร์พีซีให้ทราบถึงแผนฉุกเฉินก่อนเริ่มเปิดดำเนินโครงการ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(4) ศึกษา HAZOP ของโครงการทั้งหน่วยผลิต เพื่อพิจารณาให้มีการออกแบบแก้ไข หากพบว่าอาจทำให้เกิดอันตรายร้ายแรงได้	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(5) จัดให้มีระบบไฟฟ้าสำรองและมีโทรทัศน์วงจรปิด (Closed Circuit Television)	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(6) กำหนดให้มีการรายงานผลการประเมินอันตราย การศึกษาผลกระทบ แผนการดำเนินงานและแผนการควบคุมความเสี่ยง รวมทั้งผลการปฏิบัติตามมาตรการความปลอดภัย และมาตรการลดความเสี่ยงต่าง ๆ ตามหมวด 4 มาตรา 32 แห่งพระราชบัญญัติความปลอดภัย อาชีวอนามัยและสภาพแวดล้อมในการทำงาน พ.ศ. 2554 ให้กับกระทรวงแรงงานทราบทุกปี ทั้งนี้ เมื่อหมวด 4 มาตรา 32 มีข้อกำหนดในการปฏิบัติที่ชัดเจนให้ดำเนินการตามที่กฎหมายกำหนดไว้	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(7) จัดทำการประเมินความเสี่ยง (Risk Assessment) สำหรับหน่วยผลิต/อุปกรณ์ที่มีการปรับปรุง/เปลี่ยนแปลง/ติดตั้งเพิ่มเติม โดยผู้เชี่ยวชาญและวิศวกรที่เกี่ยวข้องของโครงการ และบริษัทผู้ออกแบบเพื่อให้เกิดความปลอดภัยสูงสุด โดยจัดทำในช่วงการออกแบบรายละเอียด Detail Design และส่งให้หน่วยงานอนุญาต เช่น กรมโรงงานอุตสาหกรรม เป็นต้น พิจารณาตามกฎหมายที่เกี่ยวข้องก่อนเดินเครื่องการผลิตใหม่ของการเปลี่ยนแปลงรายละเอียดโครงการครั้งนี้	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(8) การควบคุมกรณีฉุกเฉิน ออกแบบให้มีการ Shutdown โรงงานอย่างปลอดภัยโดยการส่งสารที่ทำปฏิกิริยาไปเผาที่หอเผาทิ้งระดับพื้นดินแบบปิด (Enclosed Ground Flare) และ/หรือหอเผาทิ้งระดับเหนือพื้นดิน (Elevated Flare)	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ลงชื่อ... ผู้จัดการฝ่าย และ	ตุลาคม 2564	ลงชื่อ...	VisionE. วิชั่น อี คอนซัลแทนท์ จำกัด หน้า 62/101

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
9. ความเสี่ยงและอันตรายร้ายแรง (ต่อ)	(9) จัดอบรมในด้านการปฏิบัติงานและมีการตรวจสอบอุปกรณ์ที่เกี่ยวข้องกับความปลอดภัย เพื่อให้แน่ใจว่าการดำเนินงานจะเป็นไปด้วยความปลอดภัย	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(10) จัดให้มีการสอบสวนและบันทึกรายละเอียดการเกิดเหตุการณ์/อุบัติเหตุ พร้อมจัดทำมาตรการแก้ไขไม่ให้เกิดอุบัติเหตุซ้ำอีก	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(11) เมื่อมีสัญญาณเตือนภัยดังขึ้น พนักงานทุกคนจะต้องหยุดปฏิบัติกิจกรรมต่าง ๆ และแจ้งไปยังเจ้าหน้าที่รักษาความปลอดภัย ให้พนักงานออกจากพื้นที่ที่เป็นอันตรายโดยเร็ว	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(12) จัดให้มีกำแพงกั้นโดยรอบบริเวณที่เก็บสำรองสารเคมี ซึ่งอาจเกิดการรั่วไหลพร้อมกำหนดวิธีจัดการกรณีรั่วไหล	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(13) มี Shaft Sealing System สำหรับอุปกรณ์ที่มีการหมุน เพื่อลดโอกาสเกิดการรั่วไหลของสารเคมี	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(14) มีอุปกรณ์ Manual Isolation Valve หรือ Emergency Isolation Valve เพื่อลดปริมาณของสารไฮโดรคาร์บอนที่รั่วไหล	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(15) อุปกรณ์การผลิตที่ติดตั้งในโรงงานต้องมีระยะห่างระหว่างอุปกรณ์อย่างปลอดภัย (Safe Equipment Spacing) และเหมาะสมตามมาตรฐาน	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(16) จัดให้มีแผนฉุกเฉิน และข้อมูลของหน่วยงานราชการ โรงพยาบาลท้องถิ่นและโรงงานข้างเคียง พร้อมช่องทางติดต่อไว้สำหรับกรณีฉุกเฉิน	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(17) จัดให้มีการฝึกซ้อมการปฏิบัติตามแผนฉุกเฉินของโรงงานเป็นระยะ ๆ โดยแบ่งออกเป็น 1) การฝึกซ้อมแผนฉุกเฉินระดับ 1 (EF1 และ EG1) ดำเนินการภายในพื้นที่โครงการ ปีละ 4 ครั้ง 2) การฝึกซ้อมแผนฉุกเฉินระดับ 2 (EF2 และ EG2) ของกลุ่มโรงงานไออาร์พีซี ปีละ 1 ครั้ง ซึ่งขึ้นอยู่กับการสับเปลี่ยนหมุนเวียนของแต่ละโรงงานในเขตประกอบการอุตสาหกรรมไออาร์พีซี ที่จะเข้ามาร่วมซ้อมแผนฉุกเฉิน 3) การฝึกซ้อมแผนฉุกเฉินระดับ 3 (EF3 และ EG3) ดำเนินการร่วมกับทางจังหวัด โดยความถี่ในการซ้อมขึ้นอยู่กับทางจังหวัดกำหนด	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
9. ความเสี่ยงและอันตรายร้ายแรง (ต่อ)	(18) จัดให้มีขั้นตอนการปฏิบัติงานเมื่อรถบรรทุกน้ำมันเกิดอุบัติเหตุระหว่างการขนส่งเพื่อเป็นมาตรฐานขั้นตอนการดำเนินการในการปฏิบัติงานเมื่อรถบรรทุกน้ำมันของผู้ขนส่งน้ำมันเชื้อเพลิง และ/หรือผลิตภัณฑ์ปิโตรเลียมอื่น ๆ และ/หรือผลิตภัณฑ์ที่เกี่ยวเนื่อง เกิดอุบัติเหตุในระหว่างการขนส่งสินค้าหรือผลิตภัณฑ์ให้ลูกค้า	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(19) กำหนดให้บริษัทผู้ขนส่งสารเคมีต้องจัดทำแผนระงับเหตุฉุกเฉินและแผนการซ้อมเหตุฉุกเฉิน และกำกับโดยบริษัท ไออาร์พีซี จำกัด (มหาชน)	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	มาตรการลดผลกระทบที่ถังเก็บก๊าก (20) ติดตั้งอุปกรณ์วัดความดัน (Pressure Indicator) และอุปกรณ์วัดอุณหภูมิ (Temperature Indicator) เพื่อคอยตรวจสอบระดับความดันและอุณหภูมิภายในถังเก็บทรงกระบอกชนิด Floating Roof Tank และชนิด Fixed Roof Tank	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(21) ติดตั้งอุปกรณ์วัดระดับ (Level Indicator) ที่ถังเก็บทรงกระบอกชนิด Floating Roof Tank และชนิด Fixed Roof Tank ทุกถัง พร้อมติดตั้งสัญญาณเตือน (Individual High และ High Level Alarm)	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(22) ติดตั้งวาล์วระบายความดัน (Pressure Relief Valve) ที่ถังเก็บชนิดทรงกลม (Spherical Tank) ทุกถัง	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(23) ติดตั้งเครื่องตรวจจับก๊าซ (Gas Detector) และหัวจ่ายน้ำดับเพลิง (Firewater Hydrant) รอบบริเวณลานถัง	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(24) จัดให้มีระบบฉีดโฟมดับเพลิงเข้าสู่ด้านในของถังเก็บทรงกระบอกชนิด Floating Roof Tank ซึ่งบรรจุ Flammable Liquid และ Combustible Liquid	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(25) ถังทรงกลมเก็บ LPG หรือลักษณะใกล้เคียงกัน พื้นที่ถังเก็บจะต้องออกแบบให้มีพื้นที่กักเก็บ (Remote Impounding Area) ในปริมาณที่เพียงพอตามมาตรฐาน API 2510 และได้ถังเก็บต้องออกแบบมีความชันร้อยละ 1 เพื่อให้ของเหลวไหลออกจากพื้นที่ถังเก็บมาลงยังพื้นที่กักเก็บดังกล่าว	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(26) ก่อสร้างเขื่อน (Dike Wall) ล้อมถังเก็บสารเคมีตามกฎหมายและมาตรฐานที่เกี่ยวข้อง โดยปริมาตรของเขื่อนต้องมีขนาดไม่น้อยกว่าปริมาณของเหลวที่บรรจุไว้ในถังใบใหญ่ที่สุดที่อยู่ภายในเขื่อน	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
9. ความเสี่ยงและอันตรายร้ายแรง (ต่อ)	(27) ติดตั้งเครื่องตรวจจับก๊าซแอมโมเนีย (NH3 Detector) และระบบสเปรย์น้ำ (Water Spray) บริเวณถังเก็บแอมโมเนียที่ อุปกรณ์ Selective Catalytic Reduction (SCR) โดยตั้งค่าเตือนของเครื่องตรวจจับก๊าซแอมโมเนียไว้ที่ 20 ส่วนในล้านส่วน	- บริเวณถังเก็บแอมโมเนียที่อุปกรณ์ Selective Catalytic Reduction (SCR)	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(28) ในกรณีที่ตรวจพบการรั่วไหลของแอมโมเนียจากถังเก็บ ระบบสเปรย์น้ำจะพ่นน้ำอัตโนมัติ เพื่อลดความเข้มข้นของสารละลายแอมโมเนีย และจับไอของสารแอมโมเนียให้อยู่ภายในเขื่อน ก่อนสูบรวบรวมลงถังขนาด 200 ลิตร หรือรถบรรทุกเพื่อนำไปบำบัด	- บริเวณถังเก็บแอมโมเนียที่อุปกรณ์ Selective Catalytic Reduction (SCR)	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	มาตรการลดผลกระทบในพื้นที่กระบวนการผลิต (29) จัดทำ Pre Startup Safety Review (PSSR) ก่อนที่จะเริ่มเดินโรงงาน (Plant Startup)	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(30) ติดตั้งอุปกรณ์วัดอัตราการไหล ความดัน และอุณหภูมิ (Flow Rate/ Pressure/ Pressure/ Temperature Indicator) พร้อมระบบ Interlock และ Shutdown System ในหน่วยการผลิตที่ทำงานอัตโนมัติร่วมกับระบบควบคุม (DCS) เพื่อคอยตรวจสอบระดับอัตราการไหล ความดันและอุณหภูมิตลอดเวลา ซึ่งจะเป็นตัวบ่งชี้สภาวะของการปฏิบัติงาน และสามารถควบคุมให้อยู่ในสภาวะที่เหมาะสมและปลอดภัย	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(31) ติดตั้งอุปกรณ์ตรวจจับควัน อุปกรณ์ตรวจจับความร้อน และอุปกรณ์ตรวจจับการรั่วไหลของก๊าซ (ก๊าซไวไฟและก๊าซพิษ) โดยสัญญาณจากอุปกรณ์ตรวจจับจะต้องส่งไปแสดงที่แผงควบคุมภายในห้องควบคุมการผลิต และศูนย์ควบคุมภาวะฉุกเฉินของ IRPC	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(32) จัดให้มีระบบการสเปรย์น้ำจากหัวจ่ายน้ำดับเพลิง (Water Hydrant) ในพื้นที่กระบวนการผลิต	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(33) จัดให้มีเครื่องระบบไฟฟ้าสำรอง เพื่อจ่ายไฟฟ้าให้กับอุปกรณ์ควบคุมในกรณีไฟฟ้าดับ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
9. ความเสี่ยงและอันตรายร้ายแรง (ต่อ)	(34) ใช้วัสดุทนไฟสำหรับทุกโครงสร้างที่อยู่ภายในพื้นที่เสี่ยงต่อการติดไฟ	พื้นที่โครงการ	ตลอดช่วงดำเนินการ	บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(35) จัดให้มีการประเมินความเสี่ยง (Risk Assessment) เพื่อป้องกันการเกิดสภาวะที่ไม่ปลอดภัย (Unsafe Condition)	พื้นที่โครงการ	ตลอดช่วงดำเนินการ	บริษัท ไออาร์พีซี จำกัด (มหาชน)
	มาตรการป้องกันการกัดกร่อนของท่อในกระบวนการผลิต (36) เลือกใช้ฉนวน (Insulation) ที่เหมาะสมกับอุณหภูมิ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(37) พิจารณาใช้ตะแกรงเหล็ก (Casing Type) แทนการติดตั้งฉนวน เพื่อป้องกันอันตรายต่อพนักงาน (Personnel Protection) ไม่ให้สัมผัสอุปกรณ์	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(38) จัดให้มีการตรวจสอบการกัดกร่อน (Corrosion) และสนิม บริเวณถัง (Vessel) หอ (Column) หรือท่อ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(39) จัดให้มีแผนการตรวจสอบและซ่อมบำรุงเชิงป้องกัน (Preventive Maintenance Program) ถัง (Vessel) หอ (Column) หรือท่อ และฉนวน (Insulation)	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	มาตรการป้องกันการรั่วไหลของสารไฮโดรคาร์บอน (40) ระบบท่อขนส่งออกแบบตามมาตรฐาน เช่น ASME/ANSI B31.8, "Gas Transmission and Distribution Piping Systems", ASME/ANSI B31.4, "Pipeline Transportation Systems for Liquid Hydrocarbons and Other Liquids" และ ASME B31.3, "Process Piping" และมีการทดสอบแรงดัน (Hydro Test) เพื่อให้มีโอกาสเกิดการรั่วไหลน้อยที่สุด	- แนวท่อขนส่งของโครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(41) จำนวนข้อต่อประเภทหน้าแปลน (Flanged Connection) ต้องน้อยที่สุด โดยเฉพาะในส่วนที่มีความดันสูง ส่วนที่เกี่ยวข้องกับก๊าซไฮโดรเจนและสารประกอบไฮโดรคาร์บอนส่วนเบา และส่วนที่ภายในมีสารที่มีอุณหภูมิสูงกว่า Auto-ignition Temperature	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(42) ติดตั้งอุปกรณ์ตรวจสอบสภาวะการผลิตที่มีประสิทธิภาพดี เช่น Low-Low Pressure Trip, High-High Temperature Trip, High-High Level Trip และ Low-Low Level Trip เพื่อป้องกันความผิดพลาดของอุปกรณ์ในกระบวนการผลิต และสภาวะที่จะเกิด Runaway Reaction หากสามารถตรวจสอบความผิดปกติของอุณหภูมิ ความดัน ระดับของสารเคมี	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
9. ความเสี่ยงและอันตรายร้ายแรง (ต่อ)	(43) กำหนดให้มีแผนการตรวจสอบดูแลเส้นท่อที่อยู่ระหว่างการใช้งาน โดยแบ่งประเภทการตรวจสอบออกเป็น 3 ประเภท คือ 1) การตรวจสอบภายนอก (External Inspection) และการตรวจสอบความหนา (Thickness Inspection) 2) การตรวจสอบระบบท่อที่หุ้มฉนวนเพื่อตรวจสอบสภาพของท่อภายใต้ฉนวนโดยการสุ่มแกะฉนวน และใช้วิธีการตรวจสอบในบริเวณที่มีความเสี่ยงที่เหมาะสม 3) การตรวจสอบความหนาจะทำการตรวจสอบด้วยเครื่องวัดความหนา (Ultrasonic Thickness Measurement : UTM)	- บริเวณท่อขนส่ง	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	มาตรการลดผลกระทบบริเวณท่อขนส่ง			
	(44) จัดทำป้ายเตือนตลอดแนวท่อส่งก๊าซของโครงการ พร้อมทั้งระบุหมายเลขโทรศัพท์ที่สามารถติดต่อได้ในกรณีเกิดเหตุฉุกเฉิน	- แนวท่อขนส่งของโครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(45) จัดให้มีการตรวจสอบสภาพระบบท่อทุกเส้นตลอดแนวท่อขนส่งของโครงการ	- แนวท่อขนส่งของโครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(46) หากตรวจสอบพบจุดที่สงสัยว่ามีการรั่วไหล ทางบริษัทจะดำเนินการแจ้งหน่วยซ่อมบำรุงทันที	- แนวท่อขนส่งของโครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(47) จัดให้มี Flow Meter เพื่อวัดอัตราการไหลของสารในท่อ ซึ่งสามารถใช้ตรวจสอบความเปลี่ยนแปลงได้จากห้องควบคุม หากเกิดการรั่วไหล	- แนวท่อขนส่งของโครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(48) มีการติดตั้งวาล์วตัดแยกระบบทั้งบริเวณต้นทางและปลายทาง เพื่อให้สามารถตัดแยกระบบและลดการรั่วไหล	- แนวท่อขนส่งของโครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(49) ในกรณีที่เกิดเหตุฉุกเฉินมีการรั่วไหลของสารเคมี เพลิงไหม้ หรือการระเบิดหากพบว่าเป็นระบบท่อรับ-ส่งของบริษัทฯ จะประสานงานแจ้งหน่วยงานที่เกี่ยวข้องและแจ้งผู้บังคับบัญชาตามลำดับขั้นทราบทันที และเข้าสู่แผนการควบคุมภาวะฉุกเฉิน	- แนวท่อขนส่งของโครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
9. ความเสี่ยงและอันตรายร้ายแรง (ต่อ)	**มาตรการในช่วงการหยุดผลิตเพื่อซ่อมบำรุง (Shutdown/Turnaround)**			
	(50) จัดให้มีวิธีปฏิบัติงาน (Procedure) ในการหยุดอุปกรณ์ หน่วยผลิตแต่ละหน่วยอย่างปลอดภัย และไม่ส่งผลกระทบต่อสิ่งแวดล้อมได้อย่างถูกต้อง	พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(51) กำหนดระบบตรวจสอบและระบบ Safety Interlock เพื่อหยุดการผลิตอย่างปลอดภัย (Safe Shutdown) ของแต่ละหน่วย	พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(52) จัดให้มีการฝึกอบรม (Training) ให้กับพนักงานให้มีความเข้าใจขั้นตอนของการหยุดการผลิต (Shutdown) อย่างสมบูรณ์	พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(53) กำหนดให้มีระเบียบปฏิบัติสำหรับงานแต่ละประเภทในการซ่อมบำรุง เพื่อให้เกิดความปลอดภัยในการทำงาน เช่น การใช้อุปกรณ์ไฟฟ้า งานประเภทที่มีความร้อนหรือประกายไฟ (Hot Work) การใช้ก๊าซในงานติดตั้ง เชื่อม เป็นต้น	พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(54) คนงานและผู้รับเหมาที่เข้ามาปฏิบัติงานในช่วงซ่อมบำรุงภายในพื้นที่บริษัท ไออาร์พีซี จำกัด (มหาชน) จะต้องผ่านการอบรมด้านความปลอดภัยในการทำงานกับเจ้าหน้าที่ของบริษัท ไออาร์พีซี จำกัด (มหาชน) และผ่านการทดสอบก่อนเข้าทำงาน เพื่อให้ทราบและเข้าใจกฎระเบียบ/ข้อปฏิบัติด้านอาชีวอนามัยและความปลอดภัย เพื่อให้เกิดความปลอดภัยในการทำงาน	พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(55) จัดให้มีระเบียบควบคุมผู้รับเหมาและบริษัทรับเหมาที่เข้ามาทำงานในพื้นที่ในช่วงการซ่อมบำรุง โดยมีวัตถุประสงค์เพื่อให้เกิดความปลอดภัยในการปฏิบัติงาน เพื่อควบคุมความเสี่ยงให้อยู่ในระดับที่ยอมรับได้ และเพื่อเป็นหลักเกณฑ์ให้ผู้รับเหมา เจ้าของพื้นที่ และผู้ควบคุมงานหรือผู้ที่เกี่ยวข้องอื่น ๆ ใช้ในการปฏิบัติ	พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(56) ก่อนหยุดผลิตเพื่อซ่อมบำรุงจะต้องมีการประชุมร่วมกันของฝ่ายผลิต (Production) ฝ่ายซ่อมบำรุง (Maintenance) และฝ่ายบริหารแผนการผลิต เพื่อหาช่วงเวลาและระยะเวลาที่เหมาะสมในการ Shutdown	- พื้นที่โครงการ	- ก่อนหยุดผลิตเพื่อซ่อมบำรุง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(57) ฝ่าย Maintenance จะต้องเป็นผู้จัดหาและตระเตรียมอุปกรณ์ที่จะใช้ในการซ่อมบำรุงทั้งหมด รวมทั้งจัดหาผู้รับเหมา (Vendor) ที่มีความชำนาญในการซ่อมบำรุงอุปกรณ์ (Equipment) นั้น ๆ มาเป็นผู้รับผิดชอบการซ่อมบำรุง	- พื้นที่โครงการ	- ก่อนหยุดผลิตเพื่อซ่อมบำรุง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
9. ความเสี่ยงและอันตรายร้ายแรง (ต่อ)	(58) ฝ่าย Operation จะเป็นผู้เตรียมขั้นตอนและวิธีการที่จะใช้ในการ Shutdown ตลอดจนอุปกรณ์สำหรับสนับสนุนเพื่อให้การ Shutdown เป็นไปอย่างรวดเร็วและปลอดภัยเพื่อที่จะส่งมอบงานให้ทางฝ่าย Maintenance	- พื้นที่โครงการ	- ก่อนหยุดผลิตเพื่อซ่อมบำรุง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(59) ฝ่าย Maintenance จะต้องเป็นผู้กำกับดูแลให้การซ่อมบำรุงนั้นเป็นไปตามสัญญาและมาตรฐานของการซ่อมบำรุง	- พื้นที่โครงการ	- ในช่วงหยุดการผลิตและซ่อมบำรุง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(60) ปฏิบัติตามหลักการทำงานหยุดผลิตเพื่อซ่อมบำรุง ประกอบด้วย 1) หยุดการป้อนวัตถุดิบเข้าสู่กระบวนการผลิต เพื่อเป็นการลดปริมาณสารไฮโดรคาร์บอนที่มีอยู่ในระบบ 2) หยุดการทำงานของเครื่องแลกเปลี่ยนความร้อน (Heater/Reboiler) เพื่อลดปริมาณไอของสารและให้โอกลายเป็นของเหลว และจะปั๊มเอาของเหลวออกให้เหลือระดับต่ำที่สุดเท่าที่จะทำได้ โดยจะส่งของเหลวไปเก็บไว้ในถังเก็บไฮโดรคาร์บอน (Slop Tank) หรือถังเก็บที่เตรียมไว้เพื่อรอส่งกลับเข้าสู่กระบวนการผลิตใหม่ภายหลัง Startup 3) ลดความดันในระบบเพื่อระบายไอสารไฮโดรคาร์บอนไปเผาไหม้อย่างปลอดภัยที่หอเผา (Flare) 4) ล้างไล่ (Flush) ด้วยน้ำหรือสารไฮโดรคาร์บอนเบา (Light Hydrocarbon) และล้างด้วยน้ำอีกครั้ง เพื่อกำจัดสารไฮโดรคาร์บอนที่เหลือ ส่วนของเหลวจากการล้างจะส่งไปยังถังเก็บไฮโดรคาร์บอน (Slop Tank) หรือถังที่เตรียมไว้ ใช้ไอน้ำไล่ไอสารไฮโดรคาร์บอนที่ค้างในระบบไปเผาไหม้อย่างปลอดภัยที่หอเผา (Flare) 5) เปิด Manholes ของ Vessel และติดตั้งอุปกรณ์สำหรับดูดอากาศ และ/หรือเติมอากาศ และตรวจวัดความเข้มข้นของสารไฮโดรคาร์บอนในระบบโดยจะต้องมีค่าความเข้มข้นต่ำสุดที่สามารถติดไฟได้ (Lower Flammable Limit, LFL) = 0 % รวมทั้งตรวจวัดความเข้มข้นของสารเคมีซึ่งต้องอยู่ในระดับที่ไม่เป็นอันตรายต่อสุขภาพ 6) เติมก๊าซเฉื่อยเข้าในระบบ (Inert Gas Blanket) เพื่อป้องกันไม่ให้ผลิตภัณฑ์น้ำมันปิโตรเลียมเกิดออกซิเดชัน (Oxidation) กับอากาศ และเกิดติดไฟในระบบ 7) ตัดแยกระบบ (Isolation) เพื่อทำการซ่อมบำรุง ก่อนจะส่งมอบงานต่อให้ฝ่ายซ่อมบำรุงเข้ามาดำเนินงานต่อ	- พื้นที่โครงการ	- ในช่วงหยุดการผลิตและซ่อมบำรุง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
9. ความเสี่ยงและอันตรายร้ายแรง (ต่อ)	(61) ในการทำงานจะต้องคำนึงถึงบรรยากาศรอบ ๆ ไม่ให้มีการระบายสารเคมีต่าง ๆ ที่ใช้ในการผลิต เช่น ผลิตภัณฑ์น้ำมันปิโตรเลียมทุกชนิด รวมถึง ก๊าซ สารเคมี น้ำ ไอน้ำ และหรือสิ่งสกปรกออกมาสู่บรรยากาศภายนอก ซึ่งจะก่อให้เกิด Flammable Gas, Asphyxiated หรืออันตรายต่อสุขภาพ	- พื้นที่โครงการ	- ในช่วงหยุดการผลิตและซ่อมบำรุง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(62) ไม่ทำให้พื้นดินปนเปื้อน หรือ Overload ต่อระบบ Drainage System	- พื้นที่โครงการ	- ในช่วงหยุดการผลิตและซ่อมบำรุง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(63) พยายามหลีกเลี่ยงในการ Venting Hydrocarbons หรือ Hazardous Materials ออกสู่บรรยากาศโดยไม่จำเป็น	- พื้นที่โครงการ	- ในช่วงหยุดการผลิตและซ่อมบำรุง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(64) อย่าเติมน้ำเข้าไปในระบบ หรือ Vessels เกินขีดจำกัด อาจทำให้ Vessels หรือ Structure เสียหายเนื่องจากน้ำหนักของน้ำ	- พื้นที่โครงการ	- ในช่วงหยุดการผลิตและซ่อมบำรุง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(65) อย่าปล่อยให้เกิด Over-Pressure ซึ่งอาจเสียหายต่อโรงงานได้	- พื้นที่โครงการ	- ในช่วงหยุดการผลิตและซ่อมบำรุง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(66) หากอุปกรณ์ไม่ได้ออกแบบมาเพื่อทนต่อสภาวะสุญญากาศ (Vacuum Condition) ต้องระวังไม่ให้เกิดสุญญากาศ (Vacuum) เนื่องจากการควบแน่นของไอน้ำ (Condensation of Steam) มิฉะนั้นแล้วจะเกิดความเสียหายได้	- พื้นที่โครงการ	- ในช่วงหยุดการผลิตและซ่อมบำรุง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(67) อย่าปล่อยให้อากาศเข้าไปในระบบที่มีผลิตภัณฑ์น้ำมันปิโตรเลียมอยู่ภายในซึ่งอาจก่อให้เกิดติดไฟและหรือระเบิดได้	- พื้นที่โครงการ	- ในช่วงหยุดการผลิตและซ่อมบำรุง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(68) กรณีที่จำเป็นต้องมีการระบายก๊าซและไอออกสู่บรรยากาศ จะทำได้ถ้ามีปริมาณไม่มากนัก (Limited Quantity) และได้ทำให้เจือจางอย่างเพียงพอ ณ จุดที่ปล่อยออกเพื่อให้แน่ใจว่าไม่เกิดนัยสำคัญของความเสี่ยง ต่อไปนี้ 1) เกิดติดไฟ (Ignition) จากการที่ Flammable Gas ที่ปล่อยออกมาผสมกับอากาศ 2) ความเข้มข้นของก๊าซที่เป็นอันตรายต่อสุขภาพ 3) มีกลิ่นมาก ยอมรับไม่ได้ และมีผลกระทบต่อสภาวะแวดล้อมทั้งภายในและนอกโรงกลั่น	- พื้นที่โครงการ	- ในช่วงหยุดการผลิตและซ่อมบำรุง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
9. ความเสี่ยงและอันตรายร้ายแรง (ต่อ)	(69) การระบายของเหลวออกจากโรงงานหรืออุปกรณ์ จะต้องหาถาด หรือถังมารองรับหรือต่อท่อเข้าสู่ระบบระบาย (Drainage System) โดยจะต้องเฝ้าดูที่ Drain Valve ตลอดเวลา เพื่อเฝ้าระวังของเหลวที่ออกมาอาจมีไอหรือละอองที่อาจก่อให้เกิดอันตราย หรือหกล้นถังที่รองรับ	- พื้นที่โครงการ	- ในช่วงหยุดการผลิตและซ่อมบำรุง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(70) อาจใช้น้ำในการทำให้เย็นลง ชะล้าง หรือแทนที่ผลิตภัณฑ์น้ำมันปิโตรเลียมออกจากอุปกรณ์ ท่อทาง และระบบต่าง ๆ ซึ่งต้องวางแผนในการระบายน้ำออกโดยที่ไม่ให้เกิดผลกระทบต่อระบบระบาย (Drainage System) และระบบบำบัดน้ำเสีย	- พื้นที่โครงการ	- ในช่วงหยุดการผลิตและซ่อมบำรุง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(71) ในการเติมก๊าซเฉื่อยเข้าในระบบ (Inert Gas Blanket) ต้องระวังดังนี้ 1) ห้ามเข้าไปทำงานในระบบ เช่นที่ Manhole หรือ Vent หากไม่มีเครื่องช่วยหายใจ ให้กั้นเชือกเพื่อล้อมบริเวณเอาไว้ หรือติดป้ายเตือนที่เหมาะสม 2) จะต้องไล่เอา Inert Gas ออก หากจะต้องเข้าไปทำงานโดยที่ไม่มีเครื่องช่วยหายใจ และต้องตรวจสอบปริมาณออกซิเจน โดยที่ความเข้มข้นของออกซิเจนต้องไม่ต่ำกว่า 19.5% จึงจะอนุญาตให้เข้าไปปฏิบัติงานได้	- พื้นที่โครงการ	- ในช่วงหยุดการผลิตและซ่อมบำรุง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(72) เมื่อต้องเข้าไปทำความสะอาดภายใน Vessel จะต้องใช้เครื่องช่วยหายใจ (Breathing Apparatus) รองเท้ายาง ถุงมือยาง แว่นตา และอุปกรณ์อื่นที่เหมาะสมกับกิจกรรมนั้น ๆ	- พื้นที่โครงการ	- ในช่วงหยุดการผลิตและซ่อมบำรุง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(73) เพื่อให้เกิดความปลอดภัย และในการเตรียมความพร้อมทั้งก่อนและระหว่างการปฏิบัติงานที่มีความเสี่ยงในช่วงซ่อมบำรุง เช่น งานใช้สิ่งที่มีประกายไฟ (Hot Work) ผู้รับเหมาจะต้องจัดให้มีการบริหารจัดการให้ถูกต้องตามกฎหมาย โดยเจ้าของพื้นที่จะมีหน้าที่ตรวจสอบอุปกรณ์ความปลอดภัย ตรวจสอบสภาพพื้นที่ก่อนให้เข้าไปทำงาน เพื่อที่จะพิจารณาอนุมัติให้เข้าทำงาน ดูแลความปลอดภัยในระหว่างทำงาน และตรวจสอบหลังปฏิบัติงานแล้วเสร็จ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
9. ความเสี่ยงและอันตรายร้ายแรง (ต่อ)	**มาตรการในช่วงเริ่มเดินการผลิตใหม่ (Startup)**			
	(74) จัดให้มีการฝึกและอบรมให้กับพนักงานควบคุมและพนักงานซ่อมบำรุงให้เข้าใจถึงวิธีการปฏิบัติงานในหน่วยผลิต	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(75) จัดเตรียมเอกสารวิธีปฏิบัติงาน (Operation Procedures) และอัปเดตให้เหมาะสม	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(76) จัดเตรียมเอกสารวิธีการซ่อมบำรุง (Maintenance Procedures) และอัปเดตให้เหมาะสม	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(77) จัดให้มีแผนตอบโต้เหตุการณ์ฉุกเฉิน และอัปเดตให้เหมาะสม	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(78) ในกรณีที่มีการติดตั้งอุปกรณ์การผลิตใหม่หรือปรับปรุงหน่วยผลิตเดิมจะต้องมีการอัปเดต Process Instrument & Diagram (P&ID) ใหม่	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(79) ก่อนที่จะเริ่มเดินการผลิตใหม่ภายหลังจากการหยุดซ่อมบำรุง พนักงานจะต้องตรวจสอบความพร้อมของพื้นที่และหน่วยผลิตตาม Pre Startup Safety Review (PSSR) Checklist ก่อนที่จะเริ่มเดินโรงงาน (Plant Start up)	- พื้นที่โครงการ	- ก่อนเริ่มดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
10. สุขภาพ	**การเปลี่ยนแปลงสภาพและการใช้ทรัพยากรธรรมชาติ** (1) ให้ความร่วมมือกับแผนการจัดสรรน้ำในพื้นที่ภาคตะวันออกของกรมชลประทาน	- หน่วยงานในพื้นที่	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(2) สนับสนุนหน่วยงานในพื้นที่ในการจัดหาน้ำใช้ให้กับชุมชน ในกรณีที่ขาดแคลน	- พื้นที่โครงการและหน่วยงานที่เกี่ยวข้อง	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(3) จัดทำแผนการใช้น้ำของโครงการส่งให้กับหน่วยงานที่เกี่ยวข้อง เช่น กรมชลประทาน เป็นต้น เพื่อใช้ในการวางแผนการจัดสรรน้ำใช้	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	การผลิต ขนส่ง และการจัดเก็บสารเคมี (4) ปฏิบัติตามมาตรการในหัวข้อคุณภาพอากาศ เรื่องการจัดทำข้อมูลการระบายสารอินทรีย์ระเหย (VOCs) เพื่อลดการรั่วซึมของสารอินทรีย์ระเหยจากการผลิต ขนส่ง และการจัดเก็บสารเคมีของโครงการ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(5) ปฏิบัติตามมาตรการในหัวข้อควบคุมการขนส่ง เพื่อป้องกันและลดผลกระทบจากการขนส่งสารเคมีของโครงการ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(6) ปฏิบัติตามมาตรการในหัวข้อความเสี่ยงและอันตรายร้ายแรง เพื่อป้องกันและลดผลกระทบกรณีเกิดเหตุฉุกเฉินบริเวณพื้นที่การผลิต การขนส่ง และถังเก็บวัตถุดิบ ผลิตภัณฑ์และสารเคมีของโครงการ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	การกำเนิดและการปล่อยของเสียและสิ่งคุกคามสุขภาพ (7) ปฏิบัติตามมาตรการในหัวข้อคุณภาพอากาศ คุณภาพน้ำ การกำจัดของเสีย และเสียงดัง เพื่อป้องกันและลดผลกระทบจากการปล่อยของเสียและสิ่งคุกคามสุขภาพ ต่อชุมชนและพนักงาน	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
10. สุขภาพ (ต่อ)	**การรับสัมผัสต่อมลพิษและสิ่งคุกคามสุขภาพ** (8) ปฏิบัติตามมาตรการในหัวข้อคุณภาพอากาศ และความเสี่ยงและอันตรายร้ายแรงเพื่อลดโอกาสที่ชุมชนและพนักงานจะสัมผัสกับสารเคมีและสิ่งคุกคามสุขภาพทั้งในกรณีดำเนินการปกติ และกรณีเกิดเหตุฉุกเฉิน	- ชุมชนในบริเวณพื้นที่ศึกษา	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(9) ให้ความรู้กับชุมชนให้ทราบเกี่ยวกับสารเคมีที่ใช้ในโครงการ รวมทั้งวิธีปฏิบัติตัวกรณีเกิดเหตุฉุกเฉิน	- ชุมชนในบริเวณพื้นที่ศึกษา	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(10) ร่วมมือกับทางชุมชน และหน่วยงานที่เกี่ยวข้องเพื่อปรับปรุงแผนการแจ้งเหตุฉุกเฉินและแผนการอพยพให้มีประสิทธิภาพ รวมถึงจัดให้มีการซ้อมแผนฉุกเฉินและแผนอพยพร่วมกับชุมชนข้างเคียง	- ชุมชน และหน่วยงานที่เกี่ยวข้อง	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(11) จัดให้มีการประกันความรับผิดชอบต่อบุคคลภายนอก เพื่อรักษาผู้ที่ได้รับบาดเจ็บหากเกิดเหตุฉุกเฉินจากทางบริษัทฯ ทั้งในระยะสั้นและระยะยาว เพื่อติดตามเฝ้าระวังผู้ที่เคยได้รับผลกระทบจากการดำเนินโครงการอย่างต่อเนื่อง	- บุคคลที่ได้รับผลกระทบจากเหตุฉุกเฉินของโครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	การเปลี่ยนแปลงและผลกระทบต่ออาชีพ การจ้างงาน และสภาพการทำงานในท้องถิ่นและต่อความสัมพันธ์ของประชาชนและชุมชน (12) พิจารณารับคนในท้องถิ่นที่มีคุณสมบัติเหมาะสมตามความต้องการของบริษัทฯ เข้าทำงานเป็นอันดับแรกเพื่อช่วยให้คนในท้องถิ่นมีงานทำและเพื่อทัศนคติที่ดีต่อโครงการ และลดผลกระทบต่อความสัมพันธ์ของประชาชนและชุมชน	- ชุมชนในบริเวณพื้นที่ศึกษา	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(13) ในช่วงที่มีตำแหน่งงานว่าง ให้ทำการประชาสัมพันธ์ให้ชุมชนรับทราบ	- ชุมชนในบริเวณพื้นที่ศึกษา	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(14) ร่วมมือกับชุมชนและหน่วยงานที่เกี่ยวข้องในการแนะแนวทางการศึกษาให้กับลูกหลานคนในชุมชน เพื่อให้สามารถเข้าทำงานกับโครงการ หรือโรงงานต่าง ๆ	- หน่วยงานที่เกี่ยวข้อง	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(15) สนับสนุนหน่วยงานการศึกษาในพื้นที่ เพื่อปรับปรุงคุณภาพการเรียนการสอน	- ชุมชนในบริเวณพื้นที่ศึกษา	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	การเปลี่ยนแปลงในพื้นที่ที่มีความสำคัญและมรดกทางศิลปวัฒนธรรม (16) สนับสนุนส่งเสริมกิจกรรมทางศาสนาของชุมชน ทุกศาสนา	- ชุมชนในบริเวณพื้นที่ศึกษา	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
10. สุขภาพ (ต่อ)	**ทรัพยากรและความพร้อมของภาคสาธารณสุข**			
	(17) จัดเตรียมหน่วยปฐมพยาบาลพร้อมทั้งฝึกอบรมบุคลากรให้พร้อมสำหรับการปฐมพยาบาล	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(18) ให้ความรู้กับพนักงานในการป้องกันโรคติดต่อ รวมถึงจัดหาภูมิคุ้มกันโรคให้กับพนักงาน	- พื้นที่โครงการและสถานพยาบาลที่กำหนด	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(19) จัดหาสถานพยาบาลให้กับพนักงานของบริษัทฯ เพื่อลดความแออัดของสถานพยาบาลของชุมชน	- หน่วยงานสาธารณสุขในพื้นที่	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(20) สนับสนุนหน่วยงานสาธารณสุขในพื้นที่ทั้งในด้านส่งเสริม การฟื้นฟูป้องกันหรือดูแลรักษา	- หน่วยงานสาธารณสุขในพื้นที่	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(21) บริษัทจัดให้มีแพทย์เข้ามาประจำในพื้นที่กลุ่มโรงงาน IRPC อย่างน้อยสัปดาห์ละ 2 ครั้ง	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(22) สำหรับการจัดการปัญหาในภาพรวมของพื้นที่ โครงการจะจัดส่งข้อมูลจำนวนพนักงาน ข้อมูลสารเคมี (SDS) และข้อมูลที่จำเป็นอื่น ๆ ให้หน่วยงานสาธารณสุขในพื้นที่ เพื่อใช้ในการวางแผนต่อไป	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	อุบัติเหตุ			
	(23) ควบคุมให้พนักงานปฏิบัติตามมาตรการด้านอาชีวอนามัยและความปลอดภัยและมาตรการด้านความเสี่ยงและอันตรายร้ายแรงอย่างเคร่งครัด เพื่อป้องกันอุบัติเหตุ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(24) ควบคุมให้ปฏิบัติตามมาตรการด้านคมนาคม เพื่อป้องกันอุบัติเหตุที่อาจเกิดขึ้นจากการขนส่งวัตถุดิบ ผลิตภัณฑ์ และสารเคมีของโครงการ	- ชุมชนในบริเวณพื้นที่ศึกษา	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(25) จัดทำแผนการให้ข้อมูลแก่ชุมชนเรื่องการเกิดอุบัติเหตุในโรงงานและจัดทำระบบการสื่อสารร่วมกับผู้นำชุมชน	- ชุมชนในบริเวณพื้นที่ศึกษา	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(26) ร่วมมือกับโรงงานอื่น ๆ ในเขตประกอบการอุตสาหกรรมไออาร์พีซี และชุมชนในการจัดทำและอบรมแผนฉุกเฉินส่วนที่เกี่ยวข้องกับชุมชน ให้สามารถรับมือแก้ไขสถานการณ์ฉุกเฉินต่าง ๆ เบื้องต้น	- หน่วยงานที่เกี่ยวข้อง	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
10. สุขภาพ (ต่อ)	(27) ให้ความร่วมมือกับชุมชนในการตรวจสอบมาตรการความปลอดภัยของโครงการ	- ชุมชนและหน่วยงานที่เกี่ยวข้อง	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(28) กำหนดให้มีแผนในการฟื้นฟูหลังจากทำการระงับเหตุฉุกเฉินเสร็จสิ้นแล้ว การจัดทำรายงานเหตุฉุกเฉินที่เกิดขึ้น และการป้องกันการเกิดเหตุซ้ำโดยการสอบสวนเพื่อหาสาเหตุที่แท้จริงของเหตุการณ์ที่เกิดขึ้นนั้นจะมีเจ้าหน้าที่ที่เกี่ยวข้องจากหลาย ๆ ฝ่ายเข้ามาทำการสอบสวน ทั้งจากหน่วยงานภายในและหน่วยงานภายนอก	- พื้นที่โครงการและพื้นที่ที่ได้รับผลกระทบจากเหตุฉุกเฉินของโครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	สังคม			
	(29) ปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อมเพื่อไม่เพิ่มสาเหตุของปัจจัยที่ก่อให้เกิดความเครียดของคนในชุมชน	- ชุมชนในบริเวณพื้นที่ศึกษา	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(30) สรุปผลการดำเนินโครงการ ผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมให้กับชาวบ้านโดยเฉพาะชุมชนใกล้เคียงทราบเป็นระยะ ๆ	- ชุมชนในบริเวณพื้นที่ศึกษา	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(31) เปิดโอกาสให้ชุมชนเข้ามาเยี่ยมชมโรงงาน เพื่อคลายความวิตกกังวล	- ชุมชนในบริเวณพื้นที่ศึกษา	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(32) จัดให้มีนโยบายเสริมสร้างคุณภาพชีวิต สนับสนุนและส่งเสริมธุรกิจชุมชนหรือ เสริมสร้างอาชีพใหม่ที่เกี่ยวข้อง เสริมสร้าง ที่เชื่อมโยงกับธุรกิจของโรงงาน เพื่อลดความเครียดในด้านอาชีพและการเงิน	- ชุมชนในบริเวณพื้นที่ศึกษา	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(33) พิจารณารับคนในท้องถิ่นที่มีคุณสมบัติเหมาะสมตามความต้องการของบริษัทฯ	- ชุมชนในบริเวณพื้นที่ศึกษา	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(34) จัดให้มีแผนประสานงานกับชุมชนในการสนับสนุนธุรกิจของกลุ่มแม่บ้านชุมชน ร้านค้า ร้านอาหาร เพื่อให้ทุนทางสังคมที่มีอยู่ให้เกิดประโยชน์สูงสุด	- ชุมชนในบริเวณพื้นที่ศึกษา	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(35) จัดให้มีนโยบายสนับสนุนกิจกรรมสร้างเสริมความเข้มแข็งร่วมกับชุมชนเพื่อป้องกันและร่วมแก้ไขปัญหาสังคม วัยรุ่นมั่วสุม ยาเสพติด	- ชุมชนในบริเวณพื้นที่ศึกษา	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(36) พิจารณารับคนในชุมชนเข้าทำงานกับบริษัททั้งในรูปพนักงานประจำและพนักงานชั่วคราว	- ชุมชนในบริเวณพื้นที่ศึกษา	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 2 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	มาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม	สถานที่ดำเนินการ	ระยะเวลา	ผู้รับผิดชอบ
11. พื้นที่สีเขียว	(1) จัดให้มีพื้นที่สีเขียว ประมาณ 23 ไร่ (36,800 ตารางเมตร) หรือคิดเป็นร้อยละ 6.97 ของพื้นที่โครงการทั้งหมด ดังรูปที่ 9 โดยปลูกต้นไม้ยืนต้นเป็นสำคัญ	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(2) กำหนดแผนการดูแลบำรุงรักษาพื้นที่สีเขียว และมาตรการการปลูกต้นไม้ทดแทนกรณีต้นไม้ตาย ให้มีสภาพดีอยู่เสมอ โดยจัดให้มีเจ้าหน้าที่ดูแลบำรุงรักษาพื้นที่สีเขียวต้นไม้ ภายในโครงการ เช่น การรดน้ำต้นไม้ พรวนดิน ใส่ปุ๋ย ฉีดยากำจัดวัชพืชและแมลง เป็นต้น ให้มีความสวยงามเป็นระเบียบอยู่เสมอ นอกจากนี้หากมีต้นไม้ได้รับความเสียหายจนไม่สามารถเจริญเติบโตได้ ต้องดำเนินการปลูกใหม่ทดแทนโดยเร็วที่สุด	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	(3) กำหนดให้ปลูกไม้ยืนต้นที่สามารถดูดซับหรือป้องกันมลพิษ และกำหนดให้มีการประเมินผลและแผนงานเพิ่มเติมประจำปี ทั้งนี้ เพื่อปรับปรุงแผนงานในการบำรุงรักษาพื้นที่สีเขียวให้เหมาะสมต่อการปฏิบัติงานจริง	- พื้นที่โครงการ	- ตลอดช่วงดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

หมายเหตุ : มาตรการที่ขีดเส้นใต้ หมายถึง มาตรการที่มีการเพิ่มเติม/เปลี่ยนแปลง

[redacted]

รูปที่ 9	พื้นที่สีเขียวของโครงการ

ตารางที่ 3
มาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อม (ช่วงก่อสร้าง)
โครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น
(ภายหลังการเปลี่ยนแปลงรายละเอียดโครงการในรายงานการประเมินผลกระทบสิ่งแวดล้อม โครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น (ครั้งที่ 3))
ของบริษัท ไออาร์พีซี จำกัด (มหาชน)

องค์ประกอบด้านสิ่งแวดล้อม	ดัชนีที่ใช้ติดตามตรวจสอบ	วิธีวิเคราะห์/ตรวจวัด	สถานีติดตามตรวจสอบ	ความถี่	ผู้รับผิดชอบ
1. คุณภาพอากาศในบรรยากาศ	- ฝุ่นละอองรวม (TSP) 24 ชั่วโมง - ฝุ่นละอองขนาดไม่เกิน 10 ไมครอน (PM10) - ความเร็วและทิศทางลม (Wind Speed and Wind Direction) และบันทึกสภาพทั่วไปที่สังเกตได้ระหว่างการตรวจวัด เพื่อใช้เป็นข้อมูลประกอบ	- US.EPA 802 Gravimetric Method หรือวิธีอื่นตามที่หน่วยงานราชการกำหนด - US.EPA 076 Gravimetric Method หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด - Wind Cup & Wind Vane หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	- บริเวณพื้นที่ก่อสร้าง	- ทุก 6 เดือน ครั้งละ 7 วันต่อเนื่อง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
2. เสียง	- ระดับเสียงสูงสุด (Lmax) - ระดับเสียงเฉลี่ยตลอดระยะเวลาการทำงาน (Equivalent continuous sound pressure level; Leq) (8 hr.)	- Integrated Sound Level Meter หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	- บริเวณพื้นที่ก่อสร้าง	- ทุก 6 เดือน ครั้งละ 7 วันต่อเนื่อง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
3. คมนาคม	- บันทึกสถิติการเกิดอุบัติเหตุจากการคมนาคมขนส่งของโครงการ พร้อมทั้งระบุสาเหตุ การแก้ไข และวิธีการป้องกันไม่ให้เกิดซ้ำ เพื่อใช้เป็นแนวทางในการกำหนดมาตรการลดอุบัติเหตุต่อไป	- บันทึก และรวบรวมข้อมูล	- บริเวณพื้นที่ก่อสร้างและเส้นทางการขนส่งวัสดุ/อุปกรณ์ก่อสร้าง	- ทุกเดือน และรายงานผลทุก 6 เดือน	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- บันทึกปริมาณรถขนส่งเข้า-ออกพื้นที่ก่อสร้าง	- บันทึก และรวบรวมข้อมูล	- บริเวณพื้นที่ก่อสร้าง	- ทุกเดือน และรายงานผลทุก 6 เดือน	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 3 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	ดัชนีที่ใช้ติดตามตรวจสอบ	วิธีวิเคราะห์/ตรวจวัด	สถานีติดตามตรวจสอบ	ความถี่	ผู้รับผิดชอบ
4. กากของเสีย	- จัดทำรายงานสรุปปริมาณกากของเสียแต่ละชนิด พร้อมทั้งบันทึกรายละเอียดเกี่ยวกับปริมาณ การเก็บรวบรวม การจัดส่ง และการจัดการของเสียที่เกิดขึ้นจากการดำเนินงานของโครงการ พร้อมทั้งแนบสำเนาการได้รับอนุญาตนำกากของเสียไปกำจัดประกอบไว้ในรายงาน โดยระบุสัดส่วนกากของเสียที่นำกลับมาใช้ใหม่ (Recycle) ต่อปริมาณกากของเสียทั้งหมด	- บันทึก และรวบรวมข้อมูล	- บริเวณพื้นที่ก่อสร้าง	- ทุกเดือน และรายงานผลทุก 6 เดือน	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
5. สภาพเศรษฐกิจ-สังคม	- รวบรวมข้อมูลการร้องเรียนจากการก่อสร้างโครงการ พร้อมผลการดำเนินการแก้ไขปัญหาและมาตรการที่กำหนดเพิ่มเติมเพื่อป้องกันการเกิดซ้ำไว้ทุกครั้ง	- บันทึกและรวบรวมข้อมูล	- บริเวณพื้นที่ก่อสร้าง	- รวบรวมผลทุกเดือนและเสนอต่อ สผ. ทุก ๆ 6 เดือน	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
6. อาชีวอนามัยและความปลอดภัย	- บันทึกสถิติกรณีเกิดเหตุฉุกเฉิน หรืออุบัติเหตุ โดยระบุสาเหตุ ความสูญเสีย ลักษณะการเกิดความเสียหาย วิธีการแก้ไข และวิธีการป้องกันไม่ให้เกิดเหตุซ้ำ - รวบรวมสถิติการเจ็บป่วยของพนักงาน	- บันทึกและรวบรวมข้อมูล	- บริเวณพื้นที่ก่อสร้าง	- รวบรวมผลทุกเดือนและเสนอต่อ สผ. ทุก ๆ 6 เดือน	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 4
มาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อม (ช่วงดำเนินการ)
โครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น
(ภายหลังการเปลี่ยนแปลงรายละเอียดโครงการในรายงานการประเมินผลกระทบสิ่งแวดล้อม โครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น (ครั้งที่ 3))
ของบริษัท ไออาร์พีซี จำกัด (มหาชน)

องค์ประกอบด้านสิ่งแวดล้อม	ดัชนีที่ใช้ติดตามตรวจสอบ	วิธีวิเคราะห์/ตรวจวัด	สถานีติดตามตรวจสอบ	ความถี่	ผู้รับผิดชอบ
1. คุณภาพอากาศ 1.1 คุณภาพอากาศในบรรยากาศ	- ฝุ่นละอองรวม (TSP) 24 ชั่วโมง - ไนโตรเจนไดออกไซด์ (NO_2) - ซัลเฟอร์ไดออกไซด์ (SO_2) - เบนซีน - 1,3-บิวทาไดอีน - ความเร็วและทิศทางลม	- US.EPA 802 Gravimetric Method หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด - US.EPA RFNA-1194-099 (Chemiluminescense) หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด - ASTM D2914-78 (Pararosaniline) หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด - US.EPA TO-15 หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด - US.EPA TO-15 หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด - ตรวจวัดโดยใช้ Wind Cup & Wind Vane หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	จำนวน 5 สถานี (ดังรูปที่ 10) ได้แก่ - เขาวังม่าน - เขายายดา - โรงเรียนระยองปัญญานุกูล - โรงเรียนวัดปลวกเกตุ - โรงพยาบาลส่งเสริมสุขภาพตำบลบ้านหนองจอก	- ทุก 6 เดือน ครั้งละ 7 วันต่อเนื่อง - สำหรับเบนซีนและ 1,3-บิวทาไดอีน ตรวจวัดทุกเดือน ครั้งละ 24 ชั่วโมงต่อเนื่อง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

[redacted]

ตารางที่ 4 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	ดัชนีที่ใช้ติดตามตรวจสอบ	วิธีวิเคราะห์/ตรวจวัด	สถานีติดตามตรวจสอบ	ความถี่	ผู้รับผิดชอบ
1.2 คุณภาพอากาศจากแหล่งกำเนิด	- ตรวจวัดคุณภาพอากาศจากปล่อง * ฝุ่นละออง (TSP) * ก๊าซออกไซด์ของไนโตรเจน (NOx) * ก๊าซออกไซด์ของซัลเฟอร์ (SOx)	- US.EPA Method 5 หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด - US.EPA Method 7 หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด - US.EPA Method 6 หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	จำนวน 7 ปล่อง (ดังรูปที่ 11) ได้แก่ - Reactor Feed Preheater Stack (52B001) - Recirculation Heater Stack (52B101) - Regeneration System Flue Gas Stack (53A001) - Cold Feed Preheater Stack (53B101) - Steam Reformer Flue Gas Stack (51Z002) - Hydrodesulfurization Reactor Heater Stack (54B001) - TGTU Stack (73Z401)	- ปีละ 2 ครั้ง ในช่วงเดียวกันกับการตรวจวัดคุณภาพอากาศในบรรยากาศ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	* ก๊าซไฮโดรเจนซัลไฟด์ (H_2S)	- US.EPA Method 15 หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	จำนวน 1 ปล่อง (ดังรูปที่ 11) ได้แก่ - TGTU Stack (73Z401)	- ปีละ 2 ครั้ง ในช่วงเดียวกันกับการตรวจวัดคุณภาพอากาศในบรรยากาศ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

[redacted]

รูปที่ 11 จุดตรวจวัดคุณภาพอากาศจากปล่อง คุณภาพน้ำจากระบบบำบัดน้ำเสีย และระดับเสียงในบรรยากาศทั่วไป

ตารางที่ 4 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	ดัชนีที่ใช้ติดตามตรวจสอบ	วิธีวิเคราะห์/ตรวจวัด	สถานีติดตามตรวจสอบ	ความถี่	ผู้รับผิดชอบ
1.2 คุณภาพอากาศจากแหล่งกำเนิด (ต่อ)	- ตรวจวัดความเข้มข้นของมลสารที่ระบายออกจากปล่องของโครงการด้วยเครื่องมือตรวจวัดการระบายมลสารจากปล่องอย่างต่อเนื่อง (Continuous Monitoring of Emissions; CEMs) * ก๊าซออกไซด์ของไนโตรเจน (NOx) * ก๊าซออกไซด์ของซัลเฟอร์ (SOx) * ฝุ่นละออง (TSP) ตรวจวัดในรูปของความทึบแสง (Opacity) * ปริมาณออกซิเจนส่วนเกิน (Excess Oxygen) * ก๊าซไฮโดรเจนซัลไฟด์ (H_2S) (เฉพาะปล่อง 73Z401)	- ระบบตรวจวัดการระบายมลสารจากปล่องอย่างต่อเนื่อง (Continuous Monitoring of Emissions; CEMs)	- CEMs No.1 ปล่อง 52B001 - CEMs No.2 ปล่อง 52B101 - CEMs No.3 ปล่อง 53A001 - CEMs No.4 ปล่อง 53B101 - CEMs No.5 ปล่อง 51Z002 - CEMs No.6 ปล่อง 54B001 - CEMs No.7 ปล่อง 73Z401	- ตรวจวัดแบบต่อเนื่อง - รวบรวมผลและเสนอต่อ สผ. ทุก ๆ 6 เดือน	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
1.3 ระบบตรวจวัดการระบายมลสารจากปล่องอย่างต่อเนื่อง	- จัดเตรียมแผนบำรุงรักษาเชิงป้องกัน (Preventive Maintenance) ดังนี้ * การตรวจสอบสภาพ Sampling Condition System * การตรวจสอบสภาพ Gas Analyzer * การตรวจสอบสภาพ Opacity Analyzer	- แผนบำรุงรักษาเชิงป้องกัน (Preventive Maintenance) และวิธีการตรวจสอบสภาพ Sampling Condition System, Gas Analyzer และ Opacity Analyzer ให้เป็นไปตามคู่มือการใช้งานระบบตรวจวัดการระบายมลสารจากปล่องอย่างต่อเนื่อง (Continuous Monitoring of Emissions; CEMs) ที่กำหนดไว้	- ระบบตรวจวัดการระบายมลสารจากปล่องอย่างต่อเนื่อง (Continuous Monitoring of Emissions; CEMs)	- ทุก ๆ 2 เดือน	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- จัดเตรียมแผนการประเมินระบบตรวจวัดการระบายมลสารจากปล่องอย่างต่อเนื่อง (Continuous Monitoring of Emissions; CEMs) แบบ Relative Accuracy Test Audit (RATA) และรายงานผลการประเมิน	- US.EPA. Code of Federal Regulations, Appendix F to Part 60—Quality Assurance Procedures)	- ระบบตรวจวัดการระบายมลสารจากปล่องอย่างต่อเนื่อง (Continuous Monitoring of Emissions; CEMs)	- ปีละ 1 ครั้ง โดย Third Party	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 4 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	ดัชนีที่ใช้ติดตามตรวจสอบ	วิธีวิเคราะห์/ตรวจวัด	สถานีติดตามตรวจสอบ	ความถี่	ผู้รับผิดชอบ
2. คุณภาพน้ำจากระบบบำบัดน้ำเสีย	- บริเวณ Stripped Water Tank		- Stripped Water Tank (**ดังรูปที่ 11**)	- ทุกเดือน เดือนละ 1 ครั้ง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	* pH	- APHA.AWWA.WEF 4500-H+ B-96 หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด			
	* SS	- APHA.AWWA.WEF 2540 D หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด			
	* TDS	- APHA.AWWA.WEF 2540 C หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด			
	* BOD_5	- APHA.AWWA.WEF 5210 B-97 หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด			
	* COD	- APHA.AWWA.WEF 5220 C-97 หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด			
	* Grease & Oil	- APHA.AWWA.WEF 5220C หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด			
	* Phenol	- ASTM D-2580-94 หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด			
	* H_2S	- APHA.AWWA.WEF 4500-S^{2-} Sulfide หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด			
	* NH_3	- APHA.AWWA.WEF 4500-NH_3 หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด			
	* Temperature	- APHA.AWWA.WEF 2500 B หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด			

ตารางที่ 4 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	ดัชนีที่ใช้ติดตามตรวจสอบ	วิธีวิเคราะห์/ตรวจวัด	สถานีติดตามตรวจสอบ	ความถี่	ผู้รับผิดชอบ
2. คุณภาพน้ำจากระบบบำบัดน้ำเสีย (ต่อ)	- ระบบบำบัดน้ำเสียแบบ IAF * pH * Grease & Oil	- APHA.AWWA.WEF 4500-H+ B-96 หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด - APHA.AWWA.WEF 5220C หรือวิธีอื่น ๆ ตามที่กฎหมายหน่วยงานราชการกำหนด	- IAF Effluent Sump (ดังรูปที่ 11)	- ทุกเดือน - เดือนละ 1 ครั้ง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- ระบบบำบัดน้ำเสียแบบ API * pH * BOD5 * COD * Grease & Oil	- APHA.AWWA.WEF 4500-H+ B-96 หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด - APHA.A WWA.WEF 5210 B-97 หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด - APHAA WWA.WEF 5220 C-97หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด - APHA.AWWA.WEF 5220C หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	- Storm Drain Basin (API Pond (ดังรูปที่ 11)	- ทุกเดือน เดือนละ 1 ครั้ง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- ระบบบำบัดน้ำเสียแบบชีวภาพของหน่วย SCTU บริเวณบ่อ Permeate Tank * pH * SS * TDS * BOD_5	- APHA.AWWA.WEF 4500-H+ B-96 หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด - APHA.AWWA.WEF 2540 D หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด - APHA.AWWA.WEF 2540 C หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด - APHA.AWWA.WEF 5210 B-97 หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	- บ่อ Permeate Tank (ดังรูปที่ 11)	- ทุกเดือน เดือนละ 1 ครั้ง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 4 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	ดัชนีที่ใช้ติดตามตรวจสอบ	วิธีวิเคราะห์/ตรวจวัด	สถานีติดตามตรวจสอบ	ความถี่	ผู้รับผิดชอบ
2. คุณภาพน้ำจากระบบบำบัดน้ำเสีย (ต่อ)	* COD * Grease & Oil * Phenol	- APHAAWWA.WEF 5220 C-97 หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด - APHA.AWWA. WEF 5220C หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด - ASTM D-2580-94 หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด			
3. คุณภาพน้ำใต้ดิน	- จัดทำทิศทางการไหลของน้ำใต้ดิน	- พิจารณาทิศทางการไหลจากลักษณะภูมิประเทศ แหล่งน้ำใกล้เคียง แผนที่อุทกธรณีวิทยา (Hydrogeological Map) หรือข้อมูลการเจาะในพื้นที่ใกล้เคียง หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	- พื้นที่โครงการ	- ก่อนเปิดดำเนินการ	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- สารอินทรีย์ระเหย ได้แก่ • TPH (C5-C8) • TPH (C>8-C16) • TPH (C>16-C25) (พารามิเตอร์ที่ตรวจวัดเป็นไปตามที่กฎหมายกำหนดและเป็นสารที่เกี่ยวข้องกับโครงการ	- Grab Sampling/Gas Chromatography Mass Spectrometer (GC-MS) หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	- ตรวจวัดจำนวน 2 จุด (รูปที่ 12) ได้แก่ • RDCC-G (U) จุดเหนือน้ำ • RDCC-G (D) จุดท้ายน้ำ	- ปีละ 2 ครั้ง หรือตามที่หน่วยงานราชการที่เกี่ยวข้องกำหนด	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- โลหะหนัก (พารามิเตอร์ที่ตรวจวัดเป็นไปตามที่กฎหมายกำหนดและเป็นสารที่เกี่ยวข้องกับโครงการ	- Atomic Absorption Spectrometry หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	- ตรวจวัดจำนวน 2 จุด (รูปที่ 12) ได้แก่ • RDCC-G (U) จุดเหนือน้ำ • RDCC-G (D) จุดท้ายน้ำ	- ปีละ 2 ครั้ง หรือตามที่หน่วยงานราชการที่เกี่ยวข้องกำหนด	- บริษัท ไออาร์พีซี จำกัด (มหาชน)



ตารางที่ 4 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	ตัชนีที่ใช้ติดตามตรวจสอบ	วิธีวิเคราะห์/ตรวจวัด	สถานีติดตามตรวจสอบ	ความถี่	ผู้รับผิดชอบ
4. คุณภาพดิน	- สารอินทรีย์ระเหย ได้แก่ • TPH (C5-C8) • TPH (C>8-C16) • TPH (C>16-C25) (พารามิเตอร์ที่ ตรวจวัดเป็นไปตามที่กฎหมายกำหนดและเป็นสารที่เกี่ยวข้องกับโครงการ	- Grab Sampling/Gas Chromatography Mass Spectrometer (GC-MS) หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	- ตรวจวัดจำนวน 2 จุด (**รูปที่ 12**) ได้แก่ • RDCC-G (U) จุดเหนือน้ำ • RDCC-G (D) จุดท้ายน้ำ	- ทุก ๆ 3 ปี หรือตามที่หน่วยงานราชการที่เกี่ยวข้องกำหนด	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- โลหะหนัก (พารามิเตอร์ที่ตรวจวัดเป็นไปตามที่ กฎหมายกำหนดและเป็นสารที่เกี่ยวข้องกับโครงการ	- Atomic Absorption Spectrometry หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	- ตรวจวัดจำนวน 2 จุด (**รูปที่ 12**) ได้แก่ • RDCC-G (U) จุดเหนือน้ำ • RDCC-G (D) จุดท้ายน้ำ	- ทุก ๆ 3 ปี หรือตามที่หน่วยงานราชการที่เกี่ยวข้องกำหนด	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
5. ระดับเสียงในบรรยากาศทั่วไป	- ระดับเสียงเฉลี่ย 24 ชั่วโมง (Leq 24 hr) - ระดับเสียงเปอร์เซ็นต์ไทล์ที่ 90 (L90) - ระดับเสียงสูงสุด (Lmax)	- Sound Level Meter หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	จำนวน 4 จุด (ดัง**รูปที่ 11**) ได้แก่ - บริเวณกึ่งกลางรั้วด้านทิศเหนือ - บริเวณกึ่งกลางรั้วด้านทิศใต้ - บริเวณกึ่งกลางรั้วด้านทิศตะวันออก - บริเวณกึ่งกลางรั้วด้านทิศตะวันตก	- ทุก 6 เดือน ครั้งละ 7 วันต่อเนื่อง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
6. การจัดการกากของเสีย	- บันทึกชนิด ปริมาณ และวิธีการกำจัด รวมทั้งระบุสัดส่วนและประเภทของกากของเสียที่ นำกลับไปใช้ใหม่ (Recycle) ต่อปริมาณกากของเสียทั้งหมดโดยแสดงรายละเอียดบริษัทผู้ขนส่ง และบริษัทผู้รับกำจัดพร้อมแนบสำเนาใบอนุญาตนำกากของเสียไปกำจัด	- บันทึกข้อมูล	- ภายในโรงงาน	- จดบันทึกทุกเดือน และรวบรวมผลและเสนอต่อสผ. ทุก ๆ 6 เดือน - รายงานกรมโรงงานอุตสาหกรรมทุกเดือน	- บริษัท ไออาร์พีซี จำกัด (มหาชน)


ตารางที่ 4 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	ดัชนีที่ใช้ติดตามตรวจสอบ	วิธีวิเคราะห์/ตรวจวัด	สถานีติดตามตรวจสอบ	ความถี่	ผู้รับผิดชอบ
7. สังคม-เศรษฐกิจ	- สำรวจสภาพเศรษฐกิจและสังคมและภาวะการเปลี่ยนแปลง ปัญหาและความต้องการระดับครัวเรือน ตลอดจนความคิดเห็นของประชาชน ผู้นำชุมชน/ผู้นำท้องถิ่น ผู้แทนหน่วยงานราชการที่เกี่ยวข้องและสถานประกอบการที่อยู่โดยรอบโครงการ พื้นที่อ่อนไหว รวมถึงให้สำรวจดัชนีความพึงพอใจของชุมชน (Community Satisfaction Index) ให้ครบถ้วน พร้อมทั้งแสดงแผนที่การกระจายตัวในการเก็บข้อมูล	- วิธีการสำรวจและจำนวนตัวอย่างเป็นไปตามหลักวิชาการและสถิติ และประเมินผลแยกตามกลุ่มที่สำรวจ พร้อมแสดงค่าเป็นแบบ Scaling และทำการเปรียบเทียบการวิเคราะห์ผลการเปลี่ยนแปลงกับผลการสำรวจที่ผ่านมา	- ชุมชนในพื้นที่ 5 กิโลเมตร โดยรอบโครงการ ชุมชนที่ดำเนินการเก็บดัชนีคุณภาพสิ่งแวดล้อม กลุ่มประมง กลุ่มเพาะเลี้ยงสัตว์น้ำ กลุ่มวิสาหกิจชุมชน ชุมชนที่ได้รับผลกระทบสิ่งแวดล้อม ชุมชนพื้นที่อ่อนไหว เช่น ที่ตั้งสถานพยาบาล สถานที่ราชการ แหล่งโบราณสถาน ศาสนสถาน วัด โรงเรียน ศูนย์กลางหรือสถานที่สำคัญต่าง ๆ เป็นต้น (ดังรูปที่ 13)	- ปีละ 1 ครั้ง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- บันทึกข้อร้องเรียนจากโครงการและจัดทำรายงานสรุปผลข้อมูลการร้องเรียน พร้อมผลการดำเนินการแก้ไข ปัญหา และมาตรการที่กำหนดเพิ่มเติม เพื่อป้องกันการเกิดซ้ำไว้ทุกครั้ง	- บันทึกข้อมูล	- พื้นที่โครงการหรือพื้นที่ภายนอกที่เกี่ยวข้อง	- ปีละ 1 ครั้ง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- ประเมินผลสรุปการดำเนินงานและจากแผนงานชุมชนสัมพันธ์ แผนงานความรับผิดชอบต่อสังคมและสิ่งแวดล้อม และ/หรือแผนงานโครงการ และกิจกรรมที่เกี่ยวข้อง โดยพิจารณาในแง่ผลสัมฤทธิ์ที่เกิดขึ้นและประโยชน์จากการดำเนินงาน ทั้งในแง่ของผลผลิต (Output) ผลลัพธ์ (Outcome) ที่กลุ่มเป้าหมายชุมชนที่ได้รับ รวมทั้งให้ประเมินประสิทธิภาพ/ความเหมาะสมของแผนงาน/กิจกรรมและเสนอแนะแนวทางการปรับปรุงผลงาน/กิจกรรมในอนาคต	- บันทึกข้อมูล	- ชุมชนโดยรอบพื้นที่โครงการ	- รวบรวมผลและเสนอทุก ๆ 6 เดือน	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

[redacted]

ตารางที่ 4 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	ดัชนีที่ใช้ติดตามตรวจสอบ	วิธีวิเคราะห์/ตรวจวัด	สถานีติดตามตรวจสอบ	ความถี่	ผู้รับผิดชอบ
8. **อาชีวอนามัยและความปลอดภัย**	- ระดับเสียงเฉลี่ยตลอดระยะเวลาการทำงาน (Equivalent continuous sound pressure level; Leq)	- Sound Level Meter หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	- บริเวณพื้นที่หน่วยแยกน้ำมันดีเซลของหน่วยปรับปรุงคุณภาพน้ำมันหนักโดยการใช้ไฮโดรเจน (RHDS) (**รูปที่ 14**)	- ตรวจวัดปีละ 2 ครั้ง (เป็นการตรวจวัดเพื่อเฝ้าระวัง ทั้งนี้การเปรียบเทียบกับมาตรฐานจะต้องพิจารณาระยะเวลาสัมผัสเสียงของพนักงานตามประกาศกระทรวงอุตสาหกรรม เรื่อง มาตรการคุ้มครองความปลอดภัยในการประกอบกิจการโรงงานเกี่ยวกับสภาพแวดล้อมในการทำงาน พ.ศ. 2546)	- บริษัท ไออาร์พีซี จำกัด (มหาชน)



รูปที่ 14 จุดตรวจวัดระดับเสียงในสถานประกอบการ

ตารางที่ 4 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	ดัชนีที่ใช้ติดตามตรวจสอบ	วิธีวิเคราะห์/ตรวจวัด	สถานีติดตามตรวจสอบ	ความถี่	ผู้รับผิดชอบ
8. อาชีวอนามัยและความปลอดภัย (ต่อ)	- ระดับเสียงที่พนักงานได้รับเฉลี่ยตลอดระยะเวลาการทำงานในแต่ละวัน (Time Weight Average : TWA)	- Noise Dosimeter และให้เป็นไปตามหลักการ Similar Exposure Group หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	- พนักงานทุกคนที่ปฏิบัติงานในพื้นที่ที่มีเสียงดัง	- ตรวจวัดปีละ 2 ครั้ง (เป็นการตรวจวัดเพื่อเฝ้าระวัง ทั้งนี้การเปรียบเทียบกับมาตรฐานจะต้องพิจารณาระยะเวลาสัมผัสของพนักงานตามประกาศกรมสวัสดิการและคุ้มครองแรงงาน เรื่อง มาตรฐานระดับเสียงที่ยอมให้ลูกจ้างได้รับเฉลี่ยตลอดระยะเวลาการทำงานในแต่ละวัน พ.ศ. 2561)	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- จัดทำแผนผังแสดงเส้นเสียง (Noise Contour Map) เพื่อใช้กำหนดพื้นที่ที่มีเสียงดัง	- Grid Measurement/Sound Level Meter/Integrate Noise to The Project Map หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	- บริเวณกระบวนการผลิตที่มีเสียงดัง	- ทุก ๆ 3 ปี และกรณีที่มีการเปลี่ยนแปลงการผลิต ซึ่งอาจส่งผลให้ระดับเสียงในพื้นที่โครงการมีการเปลี่ยนแปลง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 4 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	ดัชนีที่ใช้ติดตามตรวจสอบ	วิธีวิเคราะห์/ตรวจวัด	สถานีติดตามตรวจสอบ	ความถี่	ผู้รับผิดชอบ
8. อาชีวอนามัยและความปลอดภัย (ต่อ)	- การตรวจวัดคุณภาพอากาศในสถานประกอบการ				
	* Benzene	- NIOSH 1501 (GC/FID) หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	- บริเวณหน่วย RFCCU - บริเวณหน่วย NHTU (ดังรูปที่ 15)	- ปีละ 4 ครั้ง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	* Toluene	- NIOSH 1501 (GC/FID) หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	- บริเวณหน่วย RFCCU - บริเวณหน่วย NHTU (ดังรูปที่ 15)	- ปีละ 4 ครั้ง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	* Xylene	- NIOSH 1501 (GC/FID) หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	- บริเวณหน่วย RFCCU - บริเวณหน่วย NHTU (ดังรูปที่ 15)	- ปีละ 4 ครั้ง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	* 1,3 Butadiene	- NIOSH 1024 (GC/FID) หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	- บริเวณหน่วย RFCCU (ดังรูปที่ 15)	- ปีละ 4 ครั้ง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	* Hydrogen Sulfide (H_2S)	- NIOSH 6013 (Ion Chromatography) หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	- บริเวณหน่วย RHDS - บริเวณกึ่งกลางระหว่างหน่วย SRU กับ TGTU - บริเวณกึ่งกลางระหว่างหน่วย SWS กับ ARU (ดังรูปที่ 15)	- ปีละ 4 ครั้ง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- ความเข้มข้นของเบนซีนที่พนักงานได้รับสัมผัส	- NIOSH Method 1501 หรือวิธีอื่น ๆ ตามที่หน่วยงานราชการกำหนด	- พนักงานที่ปฏิบัติงานในพื้นที่หน่วย RFCCU และหน่วย NHTU	- ปีละ 4 ครั้ง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

[redacted]

ตารางที่ 4 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	ดัชนีที่ใช้ติดตามตรวจสอบ	วิธีวิเคราะห์/ตรวจวัด	สถานีติดตามตรวจสอบ	ความถี่	ผู้รับผิดชอบ
8. อาชีวอนามัยและความปลอดภัย (ต่อ)	- จัดให้มีการตรวจสุขภาพโดยแพทย์อาชีวเวชศาสตร์				
	1) การตรวจสุขภาพพนักงานก่อนเข้าทำงาน ประกอบด้วย * การตรวจสุขภาพทั่วไป * ตรวจตาบอดสี * ตรวจปัสสาวะ * X-Ray ปอด * ตรวจความสมบูรณ์ของเม็ดเลือด CBC * ตรวจประสิทธิภาพของตับ * ตรวจประสิทธิภาพของไต * สมรรถภาพการได้ยิน	- แพทย์อาชีวเวชศาสตร์	- พนักงานใหม่	- ภายใน 30 วัน นับตั้งแต่วันที่ตกลงรับเข้าทำงาน	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	2) การตรวจสุขภาพ พนักงานประจำปีให้แก่พนักงานทุกระดับ แบ่งออกเป็น 2 ส่วน คือ	- แพทย์อาชีวเวชศาสตร์			
	2.1) การตรวจร่างกายทั่วไป (Physical Examination)				
	* การตรวจสุขภาพทั่วไปโดยแพทย์ (Physical Exam)		- พนักงานทุกคน	- ปีละ 1 ครั้ง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	* การถ่ายภาพรังสีทรวงอกฟิล์มใหญ่ (Chest X-Ray Large Film)		- พนักงานทุกคน	- ปีละ 1 ครั้ง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	* การตรวจความสมบูรณ์ของเม็ดเลือด (CBC)		- พนักงานทุกคน	- ปีละ 1 ครั้ง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	* การตรวจการทำงานตับ (SGOT, SGPT)		- พนักงานทุกคน	- ปีละ 1 ครั้ง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	* การตรวจการทำงานของไต (Creatinine, BUN)		- พนักงานทุกคน	- ปีละ 1 ครั้ง	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 4 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	ดัชนีที่ใช้ติดตามตรวจสอบ	วิธีวิเคราะห์/ตรวจวัด	สถานีติดตามตรวจสอบ	ความถี่	ผู้รับผิดชอบ
8. อาชีวอนามัยและความปลอดภัย (ต่อ)	2.2) การตรวจสุขภาพตามปัจจัยเสี่ยง * การตรวจสมรรถภาพปอด (Lung Function) * การตรวจสมรรถภาพการได้ยิน (Audio Test) * การตรวจทางชีวภาพเพื่อตรวจการได้รับสารเคมี • ตรวจ t,t-muconic Acid in Urine สำหรับสารเบนซีน • ตรวจ Hippuric Acid in Urine สำหรับสารโทลูอีน • ตรวจ Methyl Hippuric Acid in Urine สำหรับสารไซลีน • ตรวจ Phenol in urine สำหรับสารฟีนอล		- พนักงานที่สัมผัสปัจจัยเสี่ยง - พนักงานที่สัมผัสปัจจัยเสี่ยง - พนักงานที่สัมผัสปัจจัยเสี่ยง	- ปีละ 1 ครั้ง - ปีละ 1 ครั้ง - ปีละ 1 ครั้ง	- บริษัท ไออาร์พีซี จำกัด (มหาชน) - บริษัท ไออาร์พีซี จำกัด (มหาชน) - บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- บันทึกสถิติอุบัติเหตุ เหตุการณ์เกือบเกิดอุบัติเหตุรวมทั้งสาเหตุ ความสูญเสีย และวิธีป้องกันแก้ไข	- บันทึกข้อมูล	- พื้นที่โครงการ	- ทุกเดือนและรวบรวมผลและเสนอทุก ๆ 6 เดือน	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- บันทึกสถิติการเจ็บป่วยของพนักงาน	- บันทึกข้อมูล	- พื้นที่โครงการ	- ทุกเดือนและรวบรวมผลและเสนอทุก ๆ 6 เดือน	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 4 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	ดัชนีที่ใช้ติดตามตรวจสอบ	วิธีวิเคราะห์/ตรวจวัด	สถานีติดตามตรวจสอบ	ความถี่	ผู้รับผิดชอบ
9. สุขภาพ	- ผลการปฏิบัติตามมาตรการในหัวข้อคุณภาพอากาศเรื่องการจัดทำข้อมูลการระบายสารอินทรีย์ระเหย (VOCs)	- บันทึกข้อมูล	- พื้นที่โครงการ	- รวบรวมผลและเสนอทุก 1 ปี	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- ผลการปฏิบัติตามมาตรการในหัวข้อคมนาคมขนส่ง	- บันทึกข้อมูล	- พื้นที่โครงการ	- รวบรวมผลและเสนอทุก 1 ปี	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- บันทึกการเกิดอุบัติเหตุจากการขนส่งสารเคมี	- บันทึกข้อมูล	- พื้นที่โครงการ	- ทุกเดือนและรวบรวมผลและเสนอทุก ๆ 6 เดือน	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- ผลการปฏิบัติตามมาตรการในหัวข้อความเสี่ยงและอันตรายร้ายแรง	- บันทึกข้อมูล	- พื้นที่โครงการ	- รวบรวมผลและเสนอทุก 1 ปี	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- ผลการปฏิบัติตามมาตรการในหัวข้อคุณภาพอากาศ คุณภาพน้ำ การกำจัดของเสียและเสียงดัง	- บันทึกข้อมูล	- พื้นที่โครงการ	- รวบรวมผลและเสนอทุก 6 เดือน	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- สรุปผลการให้ความรู้กับชุมชนเกี่ยวกับสารเคมีที่ใช้ในโครงการ	- บันทึกข้อมูล	- ชุมชนใกล้เคียง	- รวบรวมผลและเสนอทุก 1 ปี	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- สรุปจำนวนพนักงานที่เป็นคนท้องถิ่นและต่างถิ่น	- บันทึกข้อมูล	- พื้นที่โครงการ	- รวบรวมผลและเสนอทุก 1 ปี	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- สรุปผลการสนับสนุนหน่วยงานการศึกษาในพื้นที่	- บันทึกข้อมูล	- ชุมชนใกล้เคียง	- รวบรวมผลและเสนอทุก 1 ปี	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- สรุปกิจกรรมสนับสนุนส่งเสริมกิจกรรมทางศาสนาของชุมชน	- บันทึกข้อมูล	- ชุมชนใกล้เคียง	- รวบรวมผลและเสนอทุก 1 ปี	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

ตารางที่ 4 (ต่อ)

องค์ประกอบด้านสิ่งแวดล้อม	ดัชนีที่ใช้ติดตามตรวจสอบ	วิธีวิเคราะห์/ตรวจวัด	สถานีติดตามตรวจสอบ	ความถี่	ผู้รับผิดชอบ
9. สุขภาพ (ต่อ)	- รายละเอียดหน่วยปฐมพยาบาลและบุคลากรภายในพื้นที่โครงการ	- บันทึกข้อมูล	- พื้นที่โครงการ	- รวบรวมผลและเสนอทุก 1 ปี	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- สรุปกิจกรรมให้ความรู้กับพนักงานในการป้องกันโรคติดต่อ รวมถึงการจัดหาภูมิคุ้มกันโรคให้พนักงาน	- บันทึกข้อมูล	- พื้นที่โครงการ	- รวบรวมผลและเสนอทุก 1 ปี	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- สรุปกิจกรรมสนับสนุนหน่วยงานสาธารณสุขในพื้นที่	- บันทึกข้อมูล	- ชุมชนใกล้เคียง	- รวบรวมผลและเสนอทุก 1 ปี	- บริษัท ไออาร์พีซี จำกัด (มหาชน)
	- สรุปผลการเยี่ยมชมโรงงาน	- บันทึกข้อมูล	- พื้นที่โครงการ	- รวบรวมผลและเสนอทุก 1 ปี	- บริษัท ไออาร์พีซี จำกัด (มหาชน)

หมายเหตุ : มาตรการที่ขีดเส้นใต้ หมายถึง มาตรการที่มีการเพิ่มเติม/เปลี่ยนแปลง

ลงชื่อ..[redacted] ผู้จัดการฝ่าย และ	ตุลาคม 2564	ลงชื่อ...[redacted]	หน้า 101/101

เอกสารแนบที่ 2 ข

หนังสือนำส่งรายงานผลการปฏิบัติตามมาตรการฯ เดือนกรกฎาคม-ธันวาคม 2565

บริษัท ไออาร์พีซี จำกัด (มหาชน)
IRPC Public Company Limited

กรมโรงงานอุตสาหกรรม
เลขที่ 1797
วันที่ 30 ม.ค. ๒๕๖๖
เวลา 10 ๓๐

ที่ IRPC-INQ.EM019/2566

24 มกราคม 2566

เรื่อง ขอนำส่งรายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมโครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น เดือน กรกฎาคม – ธันวาคม 2565

เรียน อธิบดีกรมโรงงานอุตสาหกรรม

อ้างถึง 1. หนังสือเลขที่ รย.0033(3)/2232 ลงวันที่ 21 มิถุนายน พ.ศ.2560
2. ประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม เรื่อง หลักเกณฑ์ และวิธีการจัดทำรายงานผลการปฏิบัติตามมาตรการที่กำหนดไว้ในรายงานการประเมินผลกระทบสิ่งแวดล้อมซึ่งผู้ดำเนินการหรือผู้ขออนุญาตจะต้องจัดทำเมื่อได้รับอนุญาตให้ดำเนินโครงการหรือกิจการแล้ว พ.ศ.2561

สิ่งที่ส่งมาด้วย 1. รายงานผลการปฏิบัติตามมาตรการลดผลกระทบและมาตรการติดตามตรวจสอบคุณภาพสิ่งแวดล้อม โครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น เดือน กรกฎาคม – ธันวาคม 2565 จำนวน 1 ฉบับ
2. ยูเอสบีแฟลชไดรฟ์ จำนวน 1 อัน

ตามที่ บริษัท ไออาร์พีซี จำกัด (มหาชน) ได้รับความเห็นชอบจากคณะกรรมการผู้ชำนาญการ ในรายงานการประเมินผลกระทบสิ่งแวดล้อมโครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น ตามหนังสือเลขที่ รย.0033(3)/2232 ลงวันที่ 21 มิถุนายน พ.ศ.2560 ซึ่งกำหนดให้ปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมของโครงการฯ (อ้างถึง 1) และนำเสนอรายงานผลการปฏิบัติตามมาตรการฯ ต่อหน่วยงานรัฐที่กำหนดไว้ในประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม (อ้างถึง 2) นั้น

บริษัทฯ ได้จัดทำรายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมโครงการฯ ระหว่างเดือน กรกฎาคม – ธันวาคม 2565 เรียบร้อยแล้ว (สิ่งที่ส่งมาด้วย 1 และ 2) จึงขอนำส่งรายงานฯมายังท่านเพื่อโปรดพิจารณา

จึงเรียนมาเพื่อโปรดพิจารณา

ขอแสดงความนับถือ

[redacted]

ผู้จัดการฝ่ายอาวุโสบริหารคุณภาพ,ความปลอดภัย,อาชีวอนามัยและสิ่งแวดล้อม

ส่วนบริหารจัดการสิ่งแวดล้อม ผู้ประสานงาน : นางชยาวรรณ วิสาขะ E-mail : Chayawan.w@irpc.co.th
โทร.038-611333 ต่อ 37239 โทรสาร 038-618812-3

บริษัท ไออาร์พีซี จำกัด (มหาชน)
IRPC Public Company Limited

ที่ IRPC-INQI. EM020/2566

24 มกราคม 2566

เรื่อง ขอนำส่งรายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมโครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น เดือน กรกฎาคม – ธันวาคม 2565

เรียน อุตสาหกรรมจังหวัดระยอง

อ้างถึง 1. หนังสือเลขที่ รย.0033(3)/2232 ลงวันที่ 21 มิถุนายน พ.ศ.2560
2. ประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม เรื่อง หลักเกณฑ์ และวิธีการจัดทำรายงานผลการปฏิบัติตามมาตรการที่กำหนดไว้ในรายงานการประเมินผลกระทบสิ่งแวดล้อมซึ่งผู้ดำเนินการหรือผู้ขออนุญาตจะต้องจัดทำเมื่อได้รับอนุญาตให้ดำเนินโครงการหรือกิจการแล้ว พ.ศ.2561

สิ่งที่ส่งมาด้วย 1. รายงานผลการปฏิบัติตามมาตรการลดผลกระทบและมาตรการติดตามตรวจสอบคุณภาพสิ่งแวดล้อม โครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น เดือน กรกฎาคม – ธันวาคม 2565 จำนวน 3 ฉบับ
2. ยูเอสบีแฟลชไดรฟ์ จำนวน 3 อัน

ตามที่ บริษัท ไออาร์พีซี จำกัด (มหาชน) ได้รับความเห็นชอบจากคณะกรรมการผู้ชำนาญการ ในรายงานการประเมินผลกระทบสิ่งแวดล้อมโครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่น ตามหนังสือเลขที่ รย.0033(3)/2232 ลงวันที่ 21 มิถุนายน พ.ศ.2560 ซึ่งกำหนดให้ปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมของโครงการฯ (อ้างถึง 1) และนำเสนอรายงานผลการปฏิบัติตามมาตรการฯ ต่อหน่วยงานรัฐที่กำหนดไว้ในประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม (อ้างถึง 2) นั้น

บริษัทฯ ได้จัดทำรายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมโครงการฯ ระหว่างเดือน กรกฎาคม – ธันวาคม 2565 เรียบร้อยแล้ว (สิ่งที่ส่งมาด้วย 1 และ 2) จึงขอนำส่งรายงานฯมายังท่านเพื่อโปรดพิจารณาและรวบรวมรายงานฯ ส่งให้สำนักงานทรัพยากรธรรมชาติและสิ่งแวดล้อมจังหวัดระยอง ต่อไป

จึงเรียนมาเพื่อโปรดพิจารณา

ขอแสดงความนับถือ

[redacted]

ผู้จัดการฝ่ายอาวุโสบริหารคุณภาพ,ความปลอดภัย,อาชีวอนามัยและสิ่งแวดล้อม

ส่วนบริหารจัดการสิ่งแวดล้อม ผู้ประสานงาน : นางชยาวรรณ วิสาขะ E-mail : Chayawan.w@irpc.co.th
โทร.038-611333 ต่อ 37239 โทรสาร 038-618812-3

[redacted]

ยืนยันการรับข้อมูลเข้าสู่ระบบอิเล็กทรอนิกส์

เลขที่ Monitor :	256601-1075
ชื่อโครงการ :	โครงการโรงงานปรับปรุงคุณภาพน้ำมันหนักจากหอกลั่นของบริษัท ไออาร์พีซี จำกัด (มหาชน)
รอบรายงาน :	ก.ค. 65 - ธ.ค. 65
วันที่ยื่นรายงาน :	31/01/2566
เลขที่ IEE/EIA/EHIA :	6805
ผู้ยื่นรายงาน :	บริษัท เอส.พี.เอส. คอนซัลติ้ง เซอร์วิส จำกัด
อีเมล :	monitor@spscon.com
โทรศัพท์ :	029394370

QR Code สำหรับเรียกดูข้อมูลรายงานรายงาน Monitor นี้

โดยท่านสามารถเรียกดูข้อมูลรายงานต่างๆ

ที่เกี่ยวข้องกับโครงการได้ผ่านโมบายแอปพิเคชัน Smart EIA

อีกหนึ่งช่องทาง

สำนักงานนโยบายและแผนทรัพยากรธรรมชาติและสิ่งแวดล้อม

กองพัฒนาระบบการประเมินผลกระทบสิ่งแวดล้อม

Division of Environmental Impact Assessment Development

เอกสารแนบที่ 3 ข

ผลการศึกษา HAZOP ของโครงการ และนำเสนอตัวอย่างกรณีที่เกิดผลกระทบสูงสุด พร้อมแสดง P&ID

ผลการศึกษา วิเคราะห์ และทบทวนการดำเนินงานในโรงงาน เพื่อการชี้บ่งอันตราย และการประเมินความเสี่ยงด้วยวิธี HAZOP

หน่วย Unit 51 หน่วยผลิตไฮโดรเจน

รายละเอียด ท่อ NG เข้า seal 51D001 Node 302

ปัจจัยการผลิต อัตราการไหล / ความดัน / อุณหภูมิ ค่าควบคุม อัตราการไหล 257-858 kg/h , ความดัน 10 BarG, อุณหภูมิ 40 °C แบบแปลนหมายเลข 1801-P-01-51-009-1

ข้อบกพร่อง	สถานการณ์จำลอง	เหตุการณ์ที่เกิดตามมา	มาตรการป้องกัน/ควบคุม/แก้ไข	ข้อเสนอแนะ	การประเมินความเสี่ยง			
					โอกาส	ความรุนแรง	ผลลัพธ์	ระดับความเสี่ยง
more flow	PV5100901A fail open	ทำให้ความดันใน 51D001 สูงเกิน drum อาจแตก มี LPG รั่วตามหน้า flange ออกมาด้านนอกติดไฟได้ (2-RCHS-302-01-01-81)	• มี PIC5100901A/B เป็นตัววัดความดันใน 51D001 2ตัว สามารถดูเปรียบเทียบกันได้ (1) • มี PSV5100901 / 02 เป็น safety valve ระบายความดันออกจาก drum ไป flare เมื่อความดันมากกว่า 18 barG (1) • มี PI5134102 เป็นตัววัดความดัน NG ที่ BL (1) • มี FI5134102 เป็นตัววัดปริมาณการใช้ NG ความดันต่ำใน unit 51 (1) • มีระบบตรวจจับอุณหภูมิที่ drum ถ้ามีอุณหภูมิสูงเกินไป หรือ ไฟไหม้ ระบบจะสั่งฉีดน้ำสเปรย์โดยอัตโนมัติ (1) • มี GDT5100211 / 12/ 14 / 15 เป็น gas detector และส่งสัญญาณ alarm เข้า DCS (1) • มีการทดสอบ gas detector ตามระยะ (2) • มีการทดสอบการทำงานของ safety valve ตามระยะ (2) • ก่อนทำการ start up มีการทำ PSSR (2)		1 (1,1)	3 (2,0,2,3)	3	2

ผลการศึกษา วิเคราะห์ และทบทวนการดำเนินงานในโรงงาน เพื่อการชี้บ่งอันตราย และการประเมินความเสี่ยงด้วยวิธี HAZOP

หน่วย Unit 51 หน่วยผลิตไฮโดรเจน

รายละเอียด ท่อ NG เข้า seal 51D001 Node 302

ปัจจัยการผลิต อัตราการไหล / ความดัน / อุณหภูมิ ค่าควบคุม อัตราการไหล 257-858 kg/h , ความดัน 10 BarG, อุณหภูมิ 40 °C แบบแปลนหมายเลข 1801-P-01-51-009-1

ข้อบกพร่อง	สถานการณ์จำลอง	เหตุการณ์ที่เกิดตามมา	มาตรการป้องกัน/ควบคุม/แก้ไข	ข้อเสนอแนะ	การประเมินความเสี่ยง			
					โอกาส	ความรุนแรง	ผลลัพธ์	ระดับความเสี่ยง
			• มีการ PM อุปกรณ์ Instrument ตามระยะเวลา (2) • มีการจด log sheet ทั้ง CCR และ Local ทุก 2 ชั่วโมง (2) • มีคู่มือปฏิบัติงาน Normal operate unit HMU (4) • มีการฝึกอบรมพนักงาน (5)					
more pressure	PV5100901A fail open	ทำให้ความดันใน 51D001 สูงเกิน drum อาจแตก มี LPG รั่วตามหน้า flange ออกมาด้านนอกติดไฟได้ (2-RCHS-302-02-01-81)	• มี PIC5100901A/B เป็นตัววัดความดันใน 51D001 2ตัว สามารถดูเปรียบเทียบกันได้ (1) • มี PSV5100901 / 02 เป็น safety valve ระบายความดันออกจาก drum ไป flare เมื่อความดันมากกว่า 18 barG (1) • มี PI5134102 เป็นตัววัดความดัน NG ที่ BL (1) • มีระบบตรวจจับอุณหภูมิที่ drum ถ้ามีอุณหภูมิสูงเกินไป หรือ ไฟไหม้ ระบบจะสั่งฉีดน้ำสเปรย์โดยอัตโนมัติ (1) • มี GDT5100211 / 12/ 14 / 15 เป็น gas detector และส่งสัญญาณ alarm เข้า DCS (1) • มีการทดสอบ gas detector ตามระยะ (2)		1 (1,1)	3 (2,0,2,3)	3	2

ผลการศึกษา วิเคราะห์ และทบทวนการดำเนินงานในโรงงาน เพื่อการชี้บ่งอันตราย และการประเมินความเสี่ยงด้วยวิธี HAZOP

หน่วย Unit 51 หน่วยผลิตไฮโดรเจน

รายละเอียด ท่อ NG เข้า seal 51D001 Node 302

ปัจจัยการผลิต อัตราการไหล / ความดัน / อุณหภูมิ ค่าควบคุม อัตราการไหล 257-858 kg/h , ความดัน 10 BarG, อุณหภูมิ 40 °C แบบแปลนหมายเลข 1801-P-01-51-009-1

ข้อบกพร่อง	สถานการณ์จำลอง	เหตุการณ์ที่เกิดตามมา	มาตรการป้องกัน/ควบคุม/แก้ไข	ข้อเสนอแนะ	การประเมินความเสี่ยง			
					โอกาส	ความรุนแรง	ผลลัพธ์	ระดับความเสี่ยง
			• มีการทดสอบการทำงานของ safety valve ตามระยะ (2) • ก่อนทำการ start up มีการทำ PSSR (2) • มีการ PM อุปกรณ์ Instrument ตามระยะเวลา (2) • มีการจด log sheet ทั้ง CCR และ Local ทุก 2 ชั่วโมง (2) • มีคู่มือปฏิบัติงาน Normal operate unit HMU (4) • มีการฝึกอบรมพนักงาน (5)					



เอกสารแนบที่ 4 ข

หนังสือนำส่งแผนการตรวจวัดคุณภาพสิ่งแวดล้อมตามมาตรการ EIA Monitor ประจำปี 2566

SHAPE WHAT'S GOOD FOR TOMORROW

ที่ IRPC-INQI.EM090/2566

5 เมษายน 2566

เรื่อง ขอนำส่งแผนการตรวจวัดคุณภาพสิ่งแวดล้อมตามมาตรการ EIA Monitor ประจำปี 2566

เรียน อุตสาหกรรมจังหวัดระยอง

อ้างถึง การปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมจำนวนทั้งสิ้น 19 โครงการ ในเขตประกอบการอุตสาหกรรมไออาร์พีซี บริษัท ไออาร์พีซี จำกัด(มหาชน)

ตามที่ บริษัท ไออาร์พีซี จำกัด (มหาชน) ได้มีการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมและกำหนดให้แจ้งแผนการตรวจวัดด้านสิ่งแวดล้อมให้หน่วยงานราชการอนุญาตทราบก่อนการดำเนินการตามที่ระบุในมาตรการ บริษัทฯ จึงรวบรวมแผนการตรวจวัดฯ ส่งมายังท่านเพื่อทราบและพิจารณา

ทั้งนี้ บริษัทฯ จะควบคุมและประสานงานกับโครงการฯ ให้ปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมอย่างเคร่งครัด และดำเนินธุรกิจด้วยความระมัดระวังโดยยึดมั่นในหลักการดำเนินธุรกิจควบคู่ไปกับการดูแลสังคมและสิ่งแวดล้อม

จึงเรียนมาเพื่อโปรดทราบ

ขอแสดงความนับถือ

[redacted]

ผู้จัดการฝ่ายอาวุโสบริหารคุณภาพ,ความปลอดภัย,อาชีวอนามัยและสิ่งแวดล้อม

ส่วนบริหารจัดการสิ่งแวดล้อม ผู้ประสานงาน : นางชยาวรรณ วิสาชะ E-mail : Chayawan.w@irpc.co.th

โทร.038-611333 ต่อ 37239 โทรสาร 038-618812-3

[redacted]

เอกสารแนบที่ 5 ข

เอกสาร Green Turnaround



บริษัท ไออาร์พีซี จำกัด (มหาชน)
IRPC Public Company Limited

Green Turnaround

IRT Turnaround Management

ส่วนบริหารจัดการสิ่งแวดล้อม

มาตรการในงานซ่อมบำรุง

CSR



จัดตั้งศูนย์ประสานงานภาคสนาม รถประชาสัมพันธ์และออกสำรวจเฝ้าระวังผลกระทบ

การควบคุมเสียง




หลีกเลี่ยงงานในช่วงเวลาพักผ่อนของชุมชน และตรวจวัดเสียงในชุมชนและบริเวณ flare ต่อเนื่อง

การจราจร



การจราจร : มีการจัดจราจรโบกรถในช่วงเวลาเร่งด่วน กำหนดทางเข้าออก และเหลื่อมเวลาในการเข้างานของผู้รับเหมา เพื่อไม่ให้กระทบกับชีวิตประจำวันของชุมชน

การควบคุม Flare



ควบคุมให้ flare เกิดน้อยและมีขนาดเล็ก ไม่มีควัน และ ประเมินวันที่คาดว่ามีการปล่อย flare เพื่อประชาสัมพันธ์

การควบคุมกลิ่นและ VOCs





ควบคุมตั้งแต่อุปกรณ์ต้นทาง ให้ระบายสารไปยังอุปกรณ์รองรับ ไม่ระบายสู่บรรยากาศ และตรวจวัดเฝ้าระวังที่ริมรั้วและชุมชน

ควบคุม VOCs จากอุปกรณ์ต้นทาง



ตรวจวัด VOCs หลังปิดอุปกรณ์



ระบายสารไปยังอุปกรณ์รองรับไม่ปล่อยสู่บรรยากาศ





ควบคุมปริมาณการใช้น้ำและน้ำเสียในงานทำความสะอาด



ส่งเสริมการแยกขยะที่สามารถรีไซเคิลได้และลดการใช้ขยะพลาสติกแบบใช้ครั้งเดียวทิ้ง



Reuse Insulation

ควบคุมค่า VOCs ในชุมชน

การใช้ประโยชน์จากทรัพยากร

Green Turnaround

Environment + Safety + Health + Security

ข้อร้องเรียนและการทำผิดกฎหมายเป็นศูนย์

ประเมินความเสี่ยง



ควบคุมกลิ่น





Control Dust



Control Noise


Compliance Wastewater



Zero Spill to Environment



Compliance Waste Management



การจราจรและแคมป์ ผรม



มาตรการในการดำเนินการ




แก้ไขป้องกันเรื่องร้องเรียน



การจัดการด้านอากาศ



การจัดการของเสีย



การจัดการน้ำเสีย



การจัดการด้านเสียง



การควบคุมการหกรั่วไหล



การใช้ประโยชน์จากทรัพยากร



ความปลอดภัยและสุขภาพ



การจัดการด้านอากาศ

มาตรการในการดำเนินการ : การจัดการด้านอากาศ

VOCs

ไอสารอินทรีย์ระเหย

- ควบคุมงานให้อยู่ในระบบปิด
- ปิดคลุมอุปกรณ์ด้วย blue sheet
- ควบคุมค่า VOCs < 500 ppm
- ใช้ odor neutralizer (อุปกรณ์ระงับกลิ่น)

ฝุ่น



- ควบคุมงานให้อยู่ในระบบปิด
- ปิดคลุมอุปกรณ์ด้วย blue sheet
- มีอุปกรณ์กรองฝุ่น

มาตรการในการดำเนินการ : การจัดการด้านอากาศ

1. การจัดการด้าน VOCs

Decontamination : ดำเนินการเป็นระบบปิด และมี Activated carbon ในการดูดซับกลิ่น





มาตรการในการดำเนินการ : การจัดการด้านอากาศ

1. การจัดการด้าน VOCs

การทำ Chemical cleaning : ดำเนินการเป็นระบบปิด และมี Activated carbon ในการดูดซับกลิ่น





มาตรการในการดำเนินการ : การจัดการด้านอากาศ

1. การจัดการด้าน VOCs



หลังจากปิดอุปกรณ์

ควบคุม VOCs ที่ข้อต่อ = 0 ppm ในขั้นตอน check leak

ผู้ควบคุมงาน IRPC ตรวจวัดโดยเครื่อง minirae

มาตรการในการดำเนินการ : การจัดการด้านอากาศ

1. การจัดการด้าน VOCs และ กลิ่น






อุปกรณ์ที่ทำการเปิดแล้ว ผู้รับเหมาใช้ blue sheet ปิดคลุมอุปกรณ์ เพื่อป้องกัน VOCs และกลิ่น ที่อาจตกค้าง

มาตรการในการดำเนินการ : การจัดการด้านอากาศ

1. การจัดการด้าน VOCs และ กลิ่น

เตรียมอุปกรณ์ Odor Neutralizer เพื่อใช้ในจุดที่มีกลิ่นจากการเปิดระบบ





มาตรการในการดำเนินการ : การจัดการด้านอากาศ

2. การจัดการด้านฝุ่น

ใช้ Blue sheet กั้นพื้นที่ทำงาน





มาตรการในการดำเนินการ : การจัดการด้านอากาศ

2. การจัดการด้านฝุ่น

การ Load Catalyst ดำเนินการในระบบปิด เพื่อป้องกันการฟุ้งกระจาย







การจัดการของเสีย

มาตรการในการดำเนินการ : การจัดการของเสีย

ของเสียที่ IRPC กำจัดให้

✓ แยกประเภท จัดวางในพื้นที่ที่เตรียมไว้ให้



PTT Group QSHE Target:
Zero Waste to Landfill

ของเสียที่ผู้รับเหมากำจัดเอง

✓ มีเอกสารในการขออนุญาตพื้นที่ก่อนขน waste ออกไปกำจัด

✓ ไม่ใช้วิธีกำจัดแบบฝังกลบ

✓ ส่งไปกำจัดยังบริษัทที่ได้รับอนุญาตจากกรมโรงงาน




มาตรการในการดำเนินการ : การจัดการของเสีย

อุปกรณ์ที่ใช้ในการเก็บ waste บริเวณหน้างาน ก่อนที่จะขนไปลาน waste มีความเหมาะสม แข็งแรง ไม่มีการรั่วซึม



ติดป้ายที่ถุงบรรจุของเสีย ระบุ ชื่อผู้รับเหมา ที่รับผิดชอบ ให้ชัดเจน ทั้งหน้างานและที่ลาน waste ที่จัดไว้ให้




มาตรการในการดำเนินการ : การจัดการของเสีย


Example Label Waste











ส่วนบริหารจัดการสิ่งแวดล้อม

มาตรการในการดำเนินการ : การจัดการของเสีย

Waste หรืออุปกรณ์ ที่มีน้ำมันปนเปื้อน ควรมีผ้าใบรอง เพื่อป้องกันการปนเปื้อนไปยังพื้นกรวดหรือพื้นดิน



ส่วนบริหารจัดการสิ่งแวดล้อม

มาตรการในการดำเนินการ : การจัดการของเสีย

คัดแยกขยะทั่วไปจากขยะที่ปนเปื้อนจากการทำงาน และการจัดการขยะทั่วไป
ห้ามนำไปทิ้งในพื้นที่ชุมชน ที่ทำให้เกิดเรื่องร้องเรียนมายัง IRPC





ของเสียบริเวณหน้างานมีการแยกประเภท
และเขียนชื่อของเสียเอาไว้บนถุง


มาตรการในการดำเนินการ : การจัดการของเสีย



เนื่องด้วยหน้ากากอนามัยใช้แล้ว จัดเป็นขยะติดเชื้อ

จัดเตรียมถุงขยะ/ถังขยะ สำหรับทิ้ง
หน้ากากอนามัยโดยเฉพาะ ไม่ทิ้งรวม
กับขยะประเภทอื่น





การจัดการน้ำเสีย

มาตรการในการดำเนินการ : การจัดการมลพิษด้านน้ำ

น้ำเสียจากการทำความสะอาดเครื่องจักร อุปกรณ์ มีการดักตะกอน ก่อนปล่อยลง Process Plant ของ Plant เพื่อเข้าสู่ระบบบำบัดน้ำเสีย เพื่อตรวจวัดคุณภาพน้ำให้อยู่ในเกณฑ์มาตรฐานก่อนระบาย



- ✓ ต่อท่อช่วย Drain
- ✓ มีภาชนะแข็งแรงรองรับ
- ✓ มีตัวช่วยกรองตะกอน





การจัดการด้านเสียง

มาตรการในการดำเนินการ : การจัดการด้านเสียง



หลีกเลี่ยงกิจกรรมที่มีเสียงดังในช่วงเวลาพักผ่อนของชุมชน






การควบคุม
การหกรั่วไหล

มาตรการในการดำเนินการ : การควบคุมการหกรั่วไหล





มีกรวยรองรับสารเคมีหรือน้ำทำความสะอาดไปยังที่กรองตะกอนโดยตรง

มาตรการในการดำเนินการ : การควบคุมการหกรั่วไหล



อุปกรณ์ที่อยู่ที่สูงมีการกรองตะกอนน้ำทำความสะอาด น้ำที่กรองแล้วจะท่อปล่อยลงสู่รางระบายไปยังระบบบำบัดน้ำเสีย

มาตรการในการดำเนินการ : การควบคุมการหกรั่วไหล

การกั้นพื้นที่ ทำความสะอาดอุปกรณ์



มาตรการในการดำเนินการ : การควบคุมการหกรั่วไหล





- ✓ การปิดฝาถังบรรจุของเสียให้สนิท
- ✓ ใส่ภาชนะที่มีความแข็งแรง
- ✓ ใช้ผ้าใบหรือถาดรองภาชนะ เพื่อป้องกันการรั่วไหลลงสู่พื้นดิน



การใช้ประโยชน์จากทรัพยากร

มาตรการในการดำเนินการ : การจัดการของเสีย

บันทึกปริมาณของ Insulation ที่สามารถ reuse ได้และจัดเก็บแยกจาก insulation ที่ส่งกำจัดให้เรียบร้อย





แยกแผ่นใยแก้ว insulation ออกจาก cladding เพื่อป้องกันถุงฉีกขาด



ความปลอดภัย และสุขภาพ

ส่งเสริมความปลอดภัยและสุขอนามัย






ส่งเสริมสนับสนุนการทำงาน
ตามหลักความปลอดภัย






ดูแลสุขลักษณะของที่พักชั่วคราว ห้องน้ำ การจัดการขยะเทศบาล/น้ำเสีย
จากที่พักผู้รับเหมา และรถรงค์ลดการใช้ขยะพลาสติกและการแยกขยะ

Thank you



Contact
Thicha Suttikul
(QIEM)
เบอร์ภายใน 37251
thicha.su@irpc.co.th

เอกสารแนบที่ 6 ข

หนังสือแจ้งการหยุดเดินเครื่องจักรและอุปกรณ์ประจำปีและกรณีฉุกเฉิน

เรียน อุตสาหกรรมจังหวัดระยอง

ดำเนินการแล้ว
22/05/66

แบบแจ้งการหยุดเดินเครื่องจักรและรายละเอียดในการป้องกัน

แก้ไขปัญหาสิ่งแวดล้อม

1. ชื่อผู้ประกอบกิจการโรงงาน.....บริษัท ไออาร์พีซี จำกัด (มหาชน).....

2. สถานที่ตั้งโรงงาน.....299 หมู่ 5 ถ. สุขุมวิท ต. เชิงเนิน อ. เมือง จ. ระยอง 21000.....

3. ประกอบกิจการ.....แปรรูปน้ำมันหนักให้เป็นผลิตภัณฑ์ปิโตรเลียม.....**ทะเบียนโรงงานเลขที่**.....ข 3-49-1/58 รย.....

4. หยุดเดินเครื่องจักรเนื่องจาก (หยุดเครื่องจักรกรณีฉุกเฉิน) เพื่อตรวจสอบปรับปรุงแก้ไขปัญหาตัวเร่งปฏิกิริยา ของหน่วยผลิตที่ 55 เครื่องจักร 55R001

หยุดเครื่องจักร ระหว่างวันที่ 22 พฤษภาคม 256 เวลา 16.30 น. ถึงวันที่ 28 พฤษภาคม 2566 เวลา 24.00 น.

5 มาตรการป้องกันและแก้ไขปัญหาด้านสิ่งแวดล้อม และความปลอดภัย

5.1) กระบวนการนำวัตถุดิบ ผลิตภัณฑ์ หรือวัสดุอื่นๆ ออกจากระบบ

1.ส่ง hydrocarbon ที่ค้างในระบบบางส่วนกลับสู่ถังเก็บทางท่อที่เป็นระบบปิดบางส่วนเก็บไว้ในกระบวนการผลิต

2.ถ่ายเทตัวเร่งปฏิกริยาที่ใช้อยู่ส่งกลับไปภาชนะที่เป็นระบบปิดเพื่อนำกลับมาใช่ใหม่

5.2) มาตรการป้องกันปัญหาสิ่งแวดล้อมด้านมลพิษทางอากาศ เช่น วิธีการไล่แก๊สเสียออกจากระบบ การใช้เชื้อเพลิง / อัตราส่วนในการเผาทิ้งที่ปล่อง

1.ส่ง hydrocarbon ที่ค้างในระบบบางส่วนกลับสู่ถังเก็บให้มากที่สุดบางส่วนเก็บไว้ในกระบวนการผลิต เพื่อลดการส่งไปเผาที่หอเผาทิ้ง(Flare)

2. ค่อยๆ ปล่อย hydrocarbon เพื่อลดขนาดเปลวไฟและป้องกันการเกิดควันดำ

3.ควบคุมอัตราส่วนไอน้ำที่ช่วยในการเผาไหม้เพื่อป้องกันการเกิดควันดำและลดความดังของเสียง

5.3) มาตรการป้องกันปัญหาสิ่งแวดล้อมด้านน้ำเสีย

เก็บรวบรวมน้ำเสียที่เกิดจากกิจกรรมการซ่อมบำรุงในระบบปิดและส่งไปกำจัดภายนอกโดยบริษัทที่ได้รับอนุญาตจากกรมโรงงาน

5.4) มาตรการป้องกันปัญหาสิ่งแวดล้อมด้านกากอุตสาหกรรม

เก็บรวบรวมกากอุตสาหกรรมที่เกิดขึ้นส่งไปกำจัดภายนอกโดยบริษัทที่ได้รับอนุญาตจากกรมโรงงาน

6. ชื่อผู้รับผิดชอบและประสานงาน [redacted] โทร 0819490282

ผู้รายงาน [redacted]

ตำแหน่ง

เอกสารแนบที่ 7 ข

ฐานข้อมูลสุขภาพของพนักงาน และผลการตรวจสุขภาพของพนักงานย้อนหลัง 3 ปี



ระบบ E-Healthbook

ตารางเปรียบเทียบข้อมูลผลการตรวจสุขภาพพนักงานประจำปี 2563-2565

ลักษณะการตรวจสุขภาพ	ประจำปี 2563			ประจำปี 2564			ประจำปี 2565		
	จำนวนลูกจ้างทั้งหมด (ราย)	จำนวนลูกจ้างที่ตรวจ (ราย)	จำนวนลูกจ้างที่ป่วยจากการทำงาน (ราย)	จำนวนลูกจ้างทั้งหมด (ราย)	จำนวนลูกจ้างที่ตรวจ (ราย)	จำนวนลูกจ้างที่ป่วยจากการทำงาน (ราย)	จำนวนลูกจ้างทั้งหมด (ราย)	จำนวนลูกจ้างที่ตรวจ (ราย)	จำนวนลูกจ้างที่ป่วยจากการทำงาน (ราย)
1.การตรวจสุภาพทั่วไป	159	158	0	159	159	0	168	168	0
2.X-Ray ทรวงอก	159	158	0	159	159	0	168	168	0
3.ความสมบูรณ์ของเม็ดเลือด	159	158	0	159	159	0	168	168	0
4.การทำงานของตับ	159	158	0	159	159	0	168	168	0
5.การทำงานของไต	159	158	0	159	159	0	168	168	0
6.สมรรถภาพปอด	159	157	0	159	159	0	0	0	0
7.สมรรถภาพการได้ยิน	159	158	0	155	155	0	159	159	0
8.ตรวจ Benzene (t,t Muconic acid in urine)	95	91	0	93	91	0	93	93	0
9.ตรวจ Toluene (hippuric acid in urine)	95	91	0	93	91	0	93	93	0
10.ตรวจ Xylene (methyl hippuric acid in urine)	95	91	0	93	91	0	93	93	0
11.ตรวจ Phenol in urine	32	32	0	63	61	0	63	63	0

เอกสารแนบที่ 8 ข

การทบทวนเหตุการณ์อุบัติภัย/อุบัติเหตุที่เกิดจากการประกอบกิจการอุตสาหกรรมที่มีการผลิตลักษณะเดียวกันทั้งในประเทศและต่างประเทศ

บทเรียนในอดีต
PASS LESSONS

Styrene รั่วจากท่อ

12 เมษายน พ.ศ. 2562

พบกลิ่น Styrene บริเวณ Pipe rack ระหว่างอาคาร Warehouse A และ Warehouse B จากการตรวจสอบพบว่า มี Styrene รั่วจากท่อ (Pipe rack) ลงรางระบายน้ำสาเหตุเกิดจาก Drain Valve ที่ส่ง Styrene จาก Plant A ไป Plant B เกิดการผุกร่อน



สิ่งที่ได้เรียนรู้

ขยายผลตรวจสอบ CUI ท่อที่มี Cold Insulation ทั้งหมด

Emergency
EG

จัดทำโดย อาชีวอนามัยและสุขศาสตร์อุตสาหกรรม (QIHI)

Safety Moment : สารเคมีรั่วไหลลันออกจากถัง






การจัดเก็บสารเคมี ในถังเก็บ ที่มีองค์ประกอบ ของ Styrene Ethylbenzene และ ACN จะมีระบบใบกวนและระบบ Cooling ในถัง เพื่อลดอุณหภูมิ พร้อมอุปกรณ์ Instrument ในการวัดระดับของการจัดเก็บในถังเก็บ

เหตุการณ์ที่เกิด

1. มีการจัดเก็บสารเคมีในถังเกินกว่าระดับที่กำหนดในคู่มือการจัดเก็บ ค่าควบคุมกำหนดให้จัดเก็บไม่เกิน 75% และค่า Level Alarm High มีการแก้ไขจาก LAHH 85% เป็น 98%
2. การจัดเก็บในขณะที่เกิดเหตุการณ์ ระดับอยู่ที่ 96%
3. เมื่อระดับสูงขึ้นทำให้ พื้นที่ด้านบนถัง มีปริมาณไอสารเคมีร้อน เพราะไม่สามารถ Cool down ได้ จึงทำให้มีการเกิดปฏิกิริยาในถัง เพราะอุณหภูมิด้านบนสูง เกิดไอสารเคมีออกมาทาง Line vent เป็นจำนวนมาก
4. ต้องทำการเติมสารเคมี เพื่อลดการเกิดปฏิกิริยา และลดระดับถัง พร้อม Cool down ถังด้วยการ Spray น้ำ

วิเคราะห์สาเหตุที่ทำให้เกิดเหตุการณ์ :




สิ่งที่ IRPC ได้ทบทวนจากเหตุการณ์ครั้งนี้

1. ปรับปรุงเรื่องการบริหารการเปลี่ยนแปลง (Management of Change; MOC)
   - การ identify change ต่างๆ ต้องทบทวนด้าน Technical ให้ครอบคลุม
   - จัดทำเอกสารประเด็นการเปลี่ยนแปลงต่างๆ ให้ครบถ้วน
   - ติดตามผลการปฏิบัติ ที่ต้องปฏิบัติตามคู่มืออย่างเตร่งครัด และ monitor ผลที่เกิดขึ้นอย่างต่อเนื่อง

2. การวิเคราะห์อันตรายในกระบวนการ (Process Hazard Analysis; PHA)
   - การประเมินอันตรายที่อาจจะเกิดขึ้น โดยบุคลากรที่มีความรู้ ความชำนาญ

3. เอกสารวิธีการปฏิบัติงาน (Operating Procedure)
   - เอกสารวิธีการปฏิบัติงานต้องมีความถูกต้อง เข้าใจได้ง่าย มีการทบทวนเป็นระยะ หรือเมื่อมีการเปลี่ยนแปลงกระบวนการ และฝึกอบรมให้ผู้ปฏิบัติงานอย่างทั่วถึง
   - ต้องปฏิบัติตามคู่มืออย่างเตร่งครัด

Safety Moment ; ผู้เสียชีวิตจากการตรวจสอบงาน NDT



- **แนวทางแก้ไขปัญหา**



- **เหตุการณ์**

เมื่อวันที่ 18 ตุลาคม 2563 พบผู้เสียชีวิตขณะทำการตรวจสอบงาน NDE โดยสาเหตุเกิดจากขณะที่ทำการ เตรียมงานอยู่นั้นได้มีช่างเทคนิคด้านการตรวจสอบงาน NDE เข้าไปในท่อขนาด 30 นิ้ว ในขณะที่มีการเชื่อมงานบริเวณนั้น ซึ่งต่อมาเขาได้หมดสติและเงียบลง เพื่อนร่วมงานที่อยู่ภายนอกของท่อได้พยายามติดต่อผู้ประสบเหตุแต่ไม่มีการ ตอบโต้กลับมาแต่อย่างใดจึงรีบทำการติดต่อทีมฉุกเฉินเพื่อมายังจุดเกิดเหตุ เมื่อทีมฉุกเฉินมาถึงจึงได้รีบต่อสายอากาศเข้าไปเพื่อช่วยเหลือผู้ประสบเหตุในขณะเดียวกันที่ผู้รับเหมาช่วงก็พยายามที่ จะตัดท่อบริเวณใกล้จุดเกิดเหตุออกเพื่อที่จะได้เข้าไปช่วยเหลือผู้ประสบเหตุได้ซึ่งต่อมาพบว่าเสียชีวิตแล้ว

- **สาเหตุ**

ไม่ได้ยื่นขออนุญาตเข้าพื้นที่อับอากาศ ก่อนเริ่มงาน ตามโครงการและไม่มีการกล่าวถึงงานดังกล่าวใน JSA และทีมงานไม่ได้พิจารณาอันตรายจากการเข้าไปในพื้นที่อับโดยจงใจฝ่าฝืนกฎการเข้าพื้นที่อับอากาศเพื่อประหยัดเวลาในการถ่ายภาพรังสีในระหว่างการดำเนินกิจกรรม NDT (กะกลางคืน) ไม่มีการกำกับดูแลโดยผู้รับเหมาช่วงหรือผู้รับเหมา

- **สิ่งที่ IRPC ได้เรียนรู้จากเหตุการณ์ครั้งนี้...**

กิจกรรมที่มีความเสี่ยงสูง หรือกิจกรรมใหม่ เกี่ยวกับงานที่อับอากาศ ควรมีผู้เชี่ยวชาญทบทวนทุกครั้งผู้ควบคุมงาน จะต้องลงไปตรวจสอบขั้นตอนที่หน้างานจริง ว่าเป็นไปตามขั้นตอนที่ระบุไว้หรือไม่ ควรมีการซ้อมแผนช่วยชีวิต ฉุกเฉินเกี่ยวกับงาน ที่อับอากาศ ก่อนเริ่มงานจริง หรือ กิจกรรมใหม่ๆ



Safety Moment ; Aligning spool pipe / การจัดตำแหน่งท่อ



เมื่อวันที่ วันที่ 11 กันยายน 2564 เวลาประมาณ 16.20 น. ช่างประกอบของบริษัทผู้เหมา ได้ดึงรอกโซ่ขนาด 3 ตันที่แขวนท่ออยู่เพื่อหมุนท่อสำหรับการจัดท่อเพื่อให้ตัวรองท่อวางบนคานเหล็กในขณะที่ช่างประกอบ ดึงรอกโซ่ ท่อลอยขึ้นนและแกว่งมาโดนหน้าแข้งด้านซ้ายของตัวเอง ทำให้หน้าแข้งด้านซ้ายได้รับบาดเจ็บและได้นำส่งผู้บาดเจ็บส่งโรงพยาบาลและตรวจเอ็กเรย์หน้าแข้งสรุปว่าหน้าแข้งไม่หักแต่มีฟกช้ำและกลับมาทำงานได้ปกติ (ท่อขนาด 16 นิ้ว, ยาว 11 เมตร, น้ำหนักประมาณ 2-3 ตัน)



✓ <u>สาเหตุ</u>

- ❑ ช่างประกอบนั่งอยู่ในวิถีอันตรายขณะดึงรอกโซ่
- ❑ การผูกมัดสลิงผ้าใบหลวม ทำให้แวลาดึงรอกโซ่สลิงผ้าใบรูดทำให้ท่อสวิง
- ❑ ตำแหน่งจุดแขวนรอกเอียง พอเวลาดึงรอกโซ่ขึ้นทำให้ท่อสวิงเข้าหาช่างประกอบ

✓ <u>วิธีการป้องกัน</u>

- ➢ ประชุมชี้แจง พูดคุยก่อนเริ่มงาน เวลาทำงานจะต้องไม่อยู่ในวิถีอันตราย
- ➢ ก่อนจะดึงรอกโซ่จะต้องตรวจสอบการผูกรัดก่อนทำการยกว่าผูกรัดถูกต้องและปลอดภัยหรือไม่
- ➢ ไม่ใช้รอกดึงชิ้นงานโดยที่จุดแขวนรอกไม่ได้อยู่ในแนวดิ่ง 90 องศา

✓ สิ่งที่ IRPC ได้เรียนรู้และต้องกำกับดูแล

1. ทางพื้นที่ควรมีการทบทวนและ **“สาธิตการยกอย่างปลอดภัย”** สำหรับผู้รับเหมาหรือกิจกรรมใหม่ๆที่เข้ามา
2. ผู้ควบคุมงาน จะต้องลงไปตรวจสอบขั้นตอนที่หน้าจริง ว่าเป็นไปตามขั้นตอนที่ระบุไว้หรือไม่



Safety Moment ; งานซ่อมเตาหลอมโลหะระเบิด



วันที่ 17 กุมภาพันธ์ 2565 เวลา 11.30 น. เกิดอุบัติเหตุ เตาหลอมโลหะ ประกอบกิจการ การนำวัสดุที่ใช้แล้วกลับมาใช้ใหม่ ทำให้ผู้มีเสียชีวิต จำนวน 1 ราย และบาดเจ็บ จำนวน 4 ราย พนักงานตรวจความปลอดภัย จึงได้เข้าตรวจสถานประกอบกิจการ พบว่าผู้รับเหมา (ผู้เสียชีวิต) กำลังซ่อมแซมเตาหลอม ขณะที่เชื่อมท่อส่งก๊าซของเตาหลอม ภายในอาคารของบริษัทฯ เตาหลอมได้เกิดระเบิดขึ้นเนื่องจากยังมีก๊าซอยู่ภายในท่อส่งก๊าซ ส่งผลให้ผู้รับเหมา เสียชีวิตในที่เกิดเหตุ และมีผู้ได้รับบาดเจ็บอีกจำนวน 4 คน เป็นชาวเมียนม่าร์ จำนวน 3 คน และชาวจีน 1 คน (ซึ่งเป็นลูกจ้างของบริษัทฯ) ขณะนี้ผู้บาดเจ็บได้ส่งไปรักษาตัวที่โรงพยาบาล

✓ **สิ่งที่ IRPC ได้เรียนรู้และต้องกำกับดูแล...**

1. ในการทำงานเกี่ยวกับความร้อน(Hot work) ต้องมั่นใจว่าผู้ที่เกี่ยวข้องทุกคนเข้าใจขั้นตอนการปฏิบัติงานเป็นอย่างดี
2. ในการทำงานซ่อมบำรุงด้วยความร้อนกับ แท้งส์ ท่อ ต้องมั่นใจว่ามีการ Purged และทำความสะอาด ตัดแยกระบบ และทำการตรวจวัดอากาศเรียบร้อย
3. ต้องให้ข้อมูลด้านสารเคมีกับผู้รับเหมา เพื่อจะได้จัดทำการประเมินความเสี่ยง และผู้รับเหมาจะได้ตระหนักถึงอันตรายที่อาจจะเกิดขึ้นได้
4. ผู้มีหน้าที่ในการอนุญาตในการทำงาน ต้องทำการตรวจสอบที่หน้างาน และตรวจตามขั้นตอนที่ใบอนุญาตการทำงานกำหนด รวมถึงการจัดเตรียมอุปกรณ์ฉุกเฉิน

✓ **<u>สาเหตุ</u>**

1. ขาดการวางแผนงานที่ดี รวมถึงการประเมินความเสี่ยงก่อนการเริ่มงาน
2. พนักงานที่เกี่ยวข้องโดยตรงไม่ปฏิบัติตามหน้าที่รับผิดชอบ และขาดความตระหนักถึงอันตรายที่อาจเกิดขึ้น
3. ขาดการเตรียมระบบให้ปลอดภัยอย่างเพียงพอ
4. ไม่ปฏิบัติตามกฎระเบียบความปลอดภัย

✓ **<u>มาตรการแก้ไขไม่ให้เกิดซ้ำ และการเรียนรู้อุบัติเหตุ</u>**

1. การเตรียมระบบให้ปลอดภัยโดยเจ้าของพื้นที่
2. การตรวจวัดแก๊สก่อนให้เริ่มทำงาน
3. การให้ข้อมูลอันตรายในพื้นที่ทำงาน กับช่างที่เข้ามาซ่อมแซม
4. ความรู้ ความเข้าใน เกี่ยวกับอันตรายในพื้นที่ ของช่าง

Safety Moment : REACTOR ระเบิด





เหตุการณ์

พนักงานทำการทดลองคิดค้นผลิตภัณฑ์ใหม่ในเครื่องแก้ว ขนาด1ลิตร โดยใช้ก๊าซ CO2 จากถังความดันสูง (High Pressure Cylinder) เติมเข้าไปเพื่อเป็นตัวทำละลาย ขณะทำงานมีผู้ช่วย 2 คน คอยสังเกตแรงดัน เมื่อแรงดันเพิ่มเป็น 2 บาร์ พนักงานผู้ช่วยได้ยินเสียงลมออกมาจากรูน๊อต และเกิดการระเบิด ส่งผลให้พนักงานคนที่ 1 และคนที่ 2 ถูกเศษแก้วบาดใบหน้า ลำคอ และแขนรวม 30 เข็มและ 19 เข็มตามลำดับ

ข้อมูลเพิ่มเติมจากผู้บาดเจ็บ

1. พนักงานแจ้งว่าพยายามหาชุดควบคุมแรงดัน(Pressure Regulator) แต่ไม่สามารถหาได้
2. ผู้บังคับบัญชาต้องการงานด่วน
3. เกจวัดแรงดันกระจกแตก(ก่อนเกิดเหตุ)มีสภาพไม่พร้อมใช้งาน
4. เครื่องแก้วที่ใช้งานทนแรงดันได้ 6 บาร์ ใช้งานมา 2 ปี
5. ผู้ปฏิบัติงานสวมใส่แว่นตานิรภัยขณะเกิดเหตุ แว่นตามีร่องรอยถูกเศษแก้วกระเด็นใส่

หมายเหตุ: ถัง CO2 ที่ใช้งานมีแรงดันมากกว่า 100 บาร์เกจ



วิเคราะห์สาเหตุที่ทำให้เกิดเหตุการณ์

1. ด้านการจัดการ(Management)
   - ไม่มีมาตรฐาน คู่มือในการทำงานกับถังแรงดันสูง
2. ผู้ปฏิบัติงาน
   - ผู้ปฏิบัติงานทำงานด้วยความรีบเร่ง
   - ผู้ปฏิบัติไม่ทราบขนาดความรุนแรงหรือประเมินความเป็นอันตรายจากถังความดันสูงน้อยกว่าความเป็นจริง



สิ่งที่ IRPC ได้ทบทวนจากเหตุการณ์ครั้งนี้

1. ต้องจัดทำมาตรฐาน คู่มือในการทำงานกับถังแรงดันสูง (Operating Procedure ;OP)

2. การวิเคราะห์อันตรายในกระบวนการ (Process Hazard Analysis ; PHA) เพื่อให้เห็นภาพ ขนาดและลักษณะของความรุนแรงกรณีอุบัติเหตุที่เกิดกับถังแรงดันสูง

3. อบรมผู้ปฏิบัติเกี่ยวกับการทำงานกับถังแรงดันสูง(Training ; TR)

Safety Moment ; T2 LABORATORIES RUNAWAY REACTION






T2 Laboratory, inc.เป็นบริษัทผู้ผลิตเมทิลไซโคลเพนทาไดเอนิลแมงกานีสไตรคาร์บอนิล (MCMT) Methyl Cyclopentadienyl Manganese Tri-carbonyl และในระหว่างกระบวนการผลิตเดินเครื่องถึง Batch ที่ 175 เมื่อถึงเวลา 13:23 น. พนักงานฝ่ายผลิตในห้อง Control room ได้โทรแจ้ง Supervisor เพื่อรายงานปัญหาในกระบวนการผลิต เพราะพบว่ามีปัญหาที่ระบบทำความเย็นของ Cooling และขอให้กลับมาที่ห้อง Control room เพื่อช่วยแก้ไขปัญหา เมื่อ Supervisor กลับเข้ามาและกำลังทำการตรวจสอบที่ระบบ Cooling จนถึงเวลา 13.33 Reactor ได้เกิดการระเบิดขึ้น และต่อเนื่องไปยังอุปกรณ์อื่นๆ โดยการระเบิดครั้งนี้เกิดจาก"ปฏิกิริยาคายความร้อน"ที่ไม่สามารถควบคุมได้ ซึ่งเกิดขึ้นในระหว่างขั้นตอนแรกของการหลอมโลหะ (Metalation) ในกระบวนการ (MCMT) ซึ่งมีความเย็นที่ไม่เพียงพอในการ Cool down ในระหว่างกระบวนการ จึงส่งผลให้เกิดปฏิกิริยา Run-Away Reaction นี้ และนำไปสู่ความดันที่สูงขึ้นจนไม่สามารถควบคุมได้และอุณหภูมิความร้อนที่เพิ่มขึ้นใน Reactor ทำให้เกิดแรงดันและเกิดระเบิด

ผลกระทบ 1. มีพนักงานเสียชีวิต 4 คน ได้รับบาดเจ็บ 32 คน
2. โรงงานได้รับความเสียหายอย่างมาก

✓ **สิ่งที่ IRPC ได้เรียนรู้และต้องกำกับดูแล...**

1. ศึกษาในขบวนการผลิต ที่สามารถเกิดปฏิกริยาได้ และทำการประเมินความเสี่ยงเพื่อป้องกัน
2. ตรวจสอบขบวนผลิต เกี่ยวกับระบบสำรองที่สามารถรองรับเหตุฉุกเฉินในขบวนการผลิตที่เกิดขึ้น
3. มีแผนงานตรวจสอบอุปกรณ์ เช่น Reactor อย่างจริงจัง
4. ตรวจสอบระบบ Emergency Shut Down ในขบวนการผลิต เพื่อป้องกันการเกิดเหตุรุนแรง

✓ **สาเหตุ**

1. ไม่ได้ประเมินความเสี่ยงอันตรายจากปฏิกิริยา ที่เกี่ยวข้องกับ MCMT ที่กำลังผลิต
2. Colling system เป็นระบบ Single point ทำให้เกิดความล้มเหลวได้ง่าย และขาดการออกแบบให้มีระบบสำรองรองรับ
3. Reactor ไม่สามารถรับแรงปฏิกริยา ซึ่งเกิดจากแรงดันของ runaway reaction.

✓ **การแก้ไข**

1. ศึกษา และจัดทำประเมินความเสี่ยงให้ครอบคลุม การเกิดปฏิกริยา ที่เกี่ยวข้องกับ MCMT
2. ทำการออกแบบ ให้เป็นระบบ แบบสำรอง ซึ่งสามารถใช้ได้ในกรณีเกิดเหตุฉุกเฉินในขบวนการผลิต
3. ออกแบบให้ Reactor สามารถรับแรงปฏิกริยา จากแรงดัน Runaway reaction ได้
4. ออกแบบระบบ ให้เกิดการ Emergency Shut Down

เอกสารแนบที่ 9 ข

เกณฑ์การคัดเลือกและประเมินคุณภาพห้องปฏิบัติการวิเคราะห์

บริษัท ไออาร์พีซี จำกัด (มหาชน)
IRPC Public Company Limited

TERM OF REFERENCE

ขอบเขตของงานในการเสนอราคา

งานจ้างตรวจวัดคุณภาพอากาศ
ในบรรยากาศและคุณภาพเสียง

บริษัท ไออาร์พีซี จำกัด (มหาชน)
เลขที่ 299 หมู่ที่ 5 ถนนสุขุมวิท ตำบลเชิงเนิน อำเภอเมืองระยอง จังหวัดระยอง 21000
โทรศัพท์ 038-611 333, 038-613 571-80
โทรสาร 038-612812-3

ผู้จัดทำเอกสาร	ผู้ตรวจสอบเอกสาร	ผู้อนุมัติ
[redacted]		

คณะกรรมการจัดหาฯ มอบหมายให้ กรรมการและเลขานุการ เป็นผู้ลงนามรับรองเอกสารนี้แทน
สำหรับเพื่อใช้ในการเสนอราคา

..
([redacted])

[redacted]

ส่วนที่ 3 – ขอบเขตของงาน และรายละเอียดด้านเทคนิค (Scope of Work and Technical Specification)

ขอบเขตงาน

1. ผู้รับจ้างจะต้องดำเนินการเก็บตัวอย่างและวิเคราะห์คุณภาพอากาศในบรรยากาศและคุณภาพเสียง ตามช่วงเวลา สถานที่ตรวจวัด ตามข้อกำหนดของผู้ว่าจ้างโดยครบถ้วน ซึ่งรายละเอียด ความถี่ จะต้องเป็นไปตามเอกสารใบเสนอราคา ยกเว้น กรณีที่บริษัทไออาร์พีซี จำกัด (มาหาชน) จะมีการแจ้งเปลี่ยนหรือยกเลิกตามความเหมาะสม

2. ผู้รับจ้างจะต้องดำเนินการจัดทำรายงานผลการวิเคราะห์คุณภาพอากาศในบรรยากาศและเสียง รวมถึงพารามิเตอร์ที่ตรวจวัดให้สอดคล้องตามข้อกำหนดของโครงการ EIA / EHIA , EIR ,IEE และอื่นๆ ตามเงื่อนไขที่ผู้ว่าจ้างกำหนดให้มีการจัดทำในแต่ละเดือน

3. การเก็บตัวอย่างคุณภาพในบรรยากาศและคุณภาพเสียง ต้องสอดคล้องกับการตรวจวัด ในทุกสถานี พร้อมกันในช่วงเวลาเดียวกัน ทุกครั้ง (หากมีการเปลี่ยนแปลง ผู้ว่าจ้างจะแจ้งให้ทราบเป็นคราวๆไป)

4. การเก็บตัวอย่างคุณภาพในบรรยากาศ คุณภาพเสียงและวิธีการการรายงานผลการวิเคราะห์

4.1 การเก็บตัวอย่างและการวิคราะห์คุณภาพอากาศในบรรยากาศ

1. การเสนอราคาด้านการเก็บตัวอย่าง และหลักการตรวจวิเคราะห์คุณภาพอากาศในบรรยากาศ ต้องเป็นผู้ได้รับการขึ้นทะเบียนห้องปฏิบัติการวิเคราะห์ตามมาตรฐานอุตสาหกรรมด้านสากลหรือมอก 17025 ให้ปฏิบัติตามมาตรฐานวิธีการวิเคราะห์ และเก็บตัวอย่างตามมาตรฐาน และข้อกำหนดของกรมโรงงานฯ กรมควบคุมมลพิษ และองค์กรพิทักษ์สิ่งแวดล้อมแห่งสหรัฐอเมริกา (US.EPA)

2. การวิเคราะห์คุณภาพอากาศในบรรยากาศ ให้ปฏิบัติตามมาตรฐานวิธีการวิเคราะห์ และเก็บตัวอย่างตามมาตรฐาน และข้อกำหนดของกรมโรงงานฯ กรมควบคุมมลพิษ และองค์กรพิทักษ์สิ่งแวดล้อมแห่งสหรัฐอเมริกา (US.EPA) ซึ่งประกอบด้วยพารามิเตอร์หลัก ดังนี้

2.1 การตรวจวัดวิเคราะห์ฝุ่นละอองทั้งหมด (TSP) ให้ใช้วิธีการตรวจวัดตามระบบกราวิเมตริก (High Volume / Gravimetric Method) หรือระบบอื่นที่กรมควบคุมมลพิษเห็นชอบ

2.2 การตรวจวัดวิเคราะห์ฝุ่นละอองที่มีขนาดไม่เกิน 10 ไมครอน และ 2.5 ไมครอน ให้ใช้วิธีการตามระบบกราวิเมตริก และหรือวิธีตรวจวัดตามมาตรฐาน Federal Reference Method (FRM) ตามที่องค์กรพิทักษ์สิ่งแวดล้อมโลก แห่งประเทศสหรัฐอเมริกา (US.EPA) กำหนด

2.3 การตรวจวัดซัลเฟอร์ไดออกไซด์ (SO2) ให้ใช้วิธีการวิเคราะห์ตามวิธีการยูวีฟลูออเรสเซ็นส์ (UV-Fluorescence Method)

2.4 การตรวจวัดก๊าซไนโตรเจนไดออกไซด์ (NO2) ให้ใช้วิธีการวิเคราะห์ตามวิธีการเคมีลูมิเนสเซ็นส์ (Chemiluminescence Method)

2.5 การตรวจวัดก๊าซคาร์บอนมอนอกไซด์ (CO) วิธีการวิเคราะห์ตามวิธีการนันดีสเปอร์ซีฟ อินฟราเรด ดีเทคชั่น

2.6 การตรวจวัดก๊าซนันมีเทน ไฮโดรคาร์บอน (NMHC) และไฮโดรคาร์บอนทั้งหมด (THC) ให้ใช้วิธีการวิเคราะห์เก็บตัวอย่างและตรวจวัดโดยวิธีการเฟรม ไอออรไนเซชั่น ดีเทคชั่น

2.7 การตรวจวัดไฮโดรเจนซัลไฟล์ (H2S) พื้นที่ปฏิบัติงานให้ใช้วิธีการเก็บตัวอย่างแบบ Gas Sampling Bag หรือ Charcoal Tube และวิเคราะห์ตามวิธีการ US.EPA หรือ OSHA

2.8 การตรวจวัดสารอินทรีย์ระเหยง่าย ในบรรยากาศ ในเวลา 24 ชั่วโมง ให้ใช้วิธีการเก็บตัวอย่างและวิเคราะห์ด้วยวิธีการตาม Method US.EPA TO-14A และ TO-15

[redacted]

2.9 การตรวจวัดสารอินทรีย์ระเหยง่ายทั้งหมด (TVOC) ให้ใช้วิธีการเก็บตัวอย่างแบบ Gas Sampling Bag หรือ Charcoal Tube และวิเคราะห์ตามวิธีการ US.EPA หรือ OSHA หรือ ตามมาตรฐานการเก็บตามประกาศตามกฎหมายในปัจจุบัน

2.10 การตรวจวัดสารเอทิลีน (C2H6) ให้ใช้วิธีการวิเคราะห์/ตรวจวัดแบบ OSHA CSI

2.11 การตรวจวัดสารเฮกเซน (C6H14) ให้ใช้วิธีการวิเคราะห์/ตรวจวัดแบบ US.EPA Compendium Method TO-14A หรือ TO-15

2.12 การตรวจวัดสารโพรพิลีน (C3H6) ให้ใช้วิธีการวิเคราะห์/ตรวจวัดแบบ US.EPA Compendium Method TO-14A หรือ TO-15

2.13 การตรวจวัดและวิเคราะห์พารามิเตอร์อื่นๆ ให้ปฏิบัติตามมาตรฐาน หรือวิธีการสากลที่เป็นที่ยอมรับโดยทั่วไป เช่น OSHA, NIOSH

2.14 การตรวจวัดทิศทางและความเร็วลม (WS/WD) ให้ใช้เครื่องวัดความเร็วลม ด้วยหลักการแบบ 3 CUP Anemometer และเครื่องวัดทิศทางลม แบบ VANE หรือดีกว่า

215. ผู้รับจ้างจะต้องมีเครื่องตรวจวัดคุณภาพอากาศในบรรยากาศ (SO2/NO2/CO/TSP/PM10/PM2.5&Wind) ที่เป็นไปตามหลักเกณฑ์ตามเทคนิคการวิธีวิเคราะห์ในข้อที่ 2 และมีจำนวนไม่ต่ำกว่า 20 เครื่อง สำหรับการตรวจวัดช่วงเวลาเดียวกันของทุกสถานี แบบ 7 วันต่อเนื่อง และให้มีการบันทึกผลการตรวจวัดลงใน excel file ตามแบบฟอร์มที่ผู้ว่าจ้างกำหนด ความถี่ของข้อมูลการตรวจวัดไม่ต่ำกว่า 1 ชั่วโมง ยกเว้น TSP, PM10 ,PM2.5 ให้ใช้ความถี่ของข้อมูลการตรวจวัดไม่ต่ำกว่า 24 ชั่วโมง

2.16 ผู้รับจ้างจะต้องมีอุปกรณ์เก็บตัวอย่าง VOCs โดยวิธีคาร์นิสเตอร์ ไม่ต่ำกว่า 20 ชุด สำหรับการตรวจวัดช่วงเวลาเดียวกันของทุกสถานี และให้มีการบันทึกผลการตรวจวัดลงใน excel file ตามแบบฟอร์มที่ผู้ว่าจ้างกำหนด ความถี่ของข้อมูลการไม่ต่ำกว่า 24 ชั่วโมง

2.18 การตรวจวัดอนุภาค ประกอบด้วย ฝุ่นรวม และฝุ่นขนาดเล็ก ,Coal Dust , Carbon Black ประกาศกรมสวัสดิการและคุ้มครองแรงงาน เรื่อง ขีดจำกัดความเข้มข้นของสารเคมีอันตราย หรือ ACGIH

2.19 ให้แสดงจำนวนเครื่องมือด้านคุณภาพอากาศ ในบรรยากาศ และเอกสารการสอบเทียบเครื่องมือ ฉบับล่าสุด

การรายงานผลคุณภาพในบรรยากาศ

1. เมื่อมีการยืนยันผลการตรวจวัดแล้ว ขอให้ผู้รับจ้างจัดส่งผลการตรวจวัดเป็นไฟล์ pdf (ที่ไม่ใช่ไฟล์ scan รูปภาพ) และ Excel File และจัดทำผลล่าสุดและผลย้อนหลัง 3 ปี เป็นรูปแบบไฟล์ power point แยกตามเลขทะเบียนโรงงาน มาที่เจ้าหน้าที่สิ่งแวดล้อม คุณอนุชา เพ็ชรรัตน์ e-mail: anucha.pe@irpc.co.th, คุณกัญญารัตน์ ทิพย์พินิจ e-mail : kanyarat.b@irpc.co.th, คุณธิชา สุทธิกุลe-mail: thicha.su@irpc.co.th และ คุณณัฐชนน เอกพงศ์ไพสิฐ e-mail : natchanon.ak@irpc.co.th

2. การจัดทำรายงานผลการตรวจวัดคุณภาพอากาศ ในบรรยากาศ ที่ใช้ประกอบการรายงานผลกระทบผลกระทบด้านสิ่งแวดล้อม (EIA) ต้องสอดคล้องกับข้อกำหนดของแต่ละโครงการที่ผู้ว่าจ้างกำหนด ซึ่งอาจมีมากกว่า 1 โครงการในช่วงเวลาเดียวกัน

4.2 การวิเคราะห์คุณภาพเสียงและการรายงานผลการวิเคราะห์

1. การตรวจวัดคุณภาพเสียง ให้ปฏิบัติตามมาตรฐานวิธีการตรวจวัดตามมาตรฐานความดังเสียง กระบวนการวัดและประมวลผล ต้องเป็นไปตามตามประกาศคณะกรรมการสิ่งแวดล้อมแห่งชาติและประกาศคณะกรรมการควบคุมมลพิษ

2. วิธีวิเคราะห์ /การตรวจวัดคุณภาพเสียง ใช้วิธี Integrated Sound Level Measurement หรือใช้วิธีการที่กำหนดจากหน่วยงานราชการที่เกี่ยวข้อง

3. เครื่องมือวัด ต้องเป็นไปตามมาตรฐานคณะกรรมาธิการระหว่างประเทศว่าด้วยเทคนิคไฟฟ้า (International Electro technical Commission: IEC) หมายเลข IEC 61672-1 Electroacoustic Sound level meters - Part 1: Specifications ที่กฎหมายกำหนด สามารถวัดและให้ค่าที่ถูกต้อง

4. เครื่องวัดระดับเสียง (Sound Level Meter) เป็นไปตามมาตรฐานคณะกรรมาธิการระหว่างประเทศว่าด้วยเทคนิคไฟฟ้า (International Electro technical Commission: IEC) หมายเลข IEC 61672-1 Electroacoustic Sound level meters - Part 1: Specifications

หมายเหตุ : ใช้เครื่องวัดระดับเสียงในชุมชนที่ มีระดับความแม่นยำ (accuracy) Class I เท่านั้น

: ใช้เครื่องวัดระดับเสียงในพื้นที่ Work Place ที่มีระดับความแม่นยำ (accuracy) Class II

5. เครื่องมือตรวจวัดต้องได้รับการสอบเทียบโดยห้องปฏิบัติการที่ได้รับการรับรองคุณภาพ ISO/IEC 17025

6. ผู้วัด ต้องมีความสามารถใช้เครื่องมือวัดและดำเนินการตามกระบวนการวัดและประมวลผลได้อย่างถูกต้อง

7. ผู้รับจ้างจะต้องมีเครื่องตรวจวัดคุณภาพเสียง ที่เป็นไปตามหลักเกณฑ์ตามเทคนิคการวิธีวิเคราะห์ในข้อที่ 1 และมีจำนวนไม่ต่ำกว่า 20 เครื่อง สำหรับการตรวจวัดช่วงเวลาเดียวกันของทุกสถานี แบบ 7 วันต่อเนื่อง และให้มีการบันทึกผลการตรวจวัดลงใน excel file ตามแบบฟอร์มที่ผู้ว่าจ้างกำหนด

8. ให้แสดงจำนวนเครื่องมือด้านคุณภาพเสียงและเอกสารการสอบเทียบเครื่องมือ ฉบับล่าสุด

การรายงานผลคุณภาพเสียง

1. เมื่อมีการยืนยันผลการตรวจวัดแล้ว ขอให้ผู้รับจ้างจัดส่งผลการตรวจวัดเป็นไฟล์ pdf (ที่ไม่ใช่ไฟล์ scan รูปภาพ) และ Excel File และจัดทำผลล่าสุดและผลย้อนหลัง 3 ปี เป็นรูปแบบไฟล์ power point แยกตามเลขทะเบียนโรงงาน มาที่เจ้าหน้าที่สิ่งแวดล้อม คุณอนุชา เพ็ชรรัตน์ e-mail: anucha.pe@irpc.co.th, คุณกัญญารัตน์ ทิพย์พินิจ e-mail : kanyarat.b@irpc.co.th, คุณธิชา สุทธิกุลe-mail: thicha.su@irpc.co.th และ คุณณัฐชนน เอกพงศ์ไพสิฐ e-mail : natchanon.ak@irpc.co.th

2. การจัดทำรายงานผลการตรวจวัดคุณภาพเสียง ที่ใช้ประกอบการรายงานผลกระทบผลกระทบด้านสิ่งแวดล้อม (EIA) ต้องสอดคล้องกับข้อกำหนดของแต่ละโครงการที่ผู้ว่าจ้างกำหนด ซึ่งอาจมีมากกว่า 1 โครงการ ในช่วงเวลาเดียวกัน

5. กรณีที่การปฏิบัติการเก็บตัวอย่างอยู่ในเขตผลิต เขตควบคุมประกายไฟของเขตประกอบการไออาร์พีซี ต้องปฏิบัติงานในพื้นที่ควบคุมประกายไฟ

ทีมเก็บตัวอย่าง ของผู้รับจ้าง ต้องประกอบด้วยบุคคลากร ดังต่อไปนี้ ทุกครั้งที่มีการเข้าปฏิบัติงาน

1. เจ้าหน้าที่ จป.เทคนิค ผู้รับจ้าง 1 ท่าน (ห้ามปฏิบัติงานและต้องเฝ้าระวังอยู่ตลอดเวลาที่มีการปฏิบัติงาน)
2. เจ้าหน้าที่ หัวหน้างาน ผู้รับจ้าง 1 ท่าน (สามารถปฏิบัติงานร่วมกับทีมเก็บตัวอย่างได้ เดินเอกสารได้)
3. บุคลากรที่มีเก็บตัวอย่าง ที่มีชื่ออยู่ในทะเบียนอนุญาต ห้องปฏิบัติการวิเคราะห์ อย่างน้อย 1 ท่าน

หมายเหตุ : ก่อนการเริ่มงานจะต้องมีการขออนุญาตทำงาน และจัดทำรายงานประเมินความเสี่ยง ส่งให้ทางผู้ควบคุมงาน IRPC ทุกครั้งก่อนเริ่มงาน และมีการตรวจสอบสภาพอุปกรณ์ไฟฟ้าทุกครั้ง รวมถึงการดำเนินการขออนุญาตถ่ายภาพการปฏิบัติงาน โดยผู้รับเหมาต้องดำเนินการเอกสารทั้งหมดให้เรียบร้อยก่อนการเริ่มงานอย่างน้อย 1 วัน

6. หลักเกณฑ์การอบรมก่อนการปฏิบัติงานในเขตผลิตของ ไออาร์พีซี (ไม่รวมพื้นที่ในแหล่งชุมชน)

6.1 ผู้รับจ้างที่เข้าปฏิบัติงานในพื้นที่เขตประกอบการฯ ต้องผ่านการอบรมและทดสอบความรู้ทางด้านความปลอดภัยจากทางบริษัท ไออาร์พีซี ก่อนเข้าปฏิบัติงาน โดยติดต่อผ่านทางวิทยาลัยเทคโนโลยี ไออาร์พีซี ซึ่งเป็นผู้รับผิดชอบและดูแลด้านนี้โดยเฉพาะ

6.2 ต้องจัดเตรียมอุปกรณ์ป้องกันอันตรายส่วนบุคคลพื้นฐาน (หมวกนิรภัย, รองเท้านิรภัยและแว่นตานิรภัย) และอุปกรณ์ PPE ชนิดอื่นขึ้นอยู่กับลักษณะงาน ก่อนที่จะเข้าผ่านจุด รปภ. และก่อนเข้าพื้นที่ทำ

ไม่มีจุด รปภ.) งานซ่อมแซมต่างๆ งานทำสวนที่ไม่มีโอกาสที่จะเกิดอันตรายกับศีรษะ และดวงตาที่อยู่นอกเขตผลิตที่ไม่เข้าข่ายงานในหัวข้ออื่นๆ ในระเบียบนี้ให้ใช้ PPE พื้นฐาน ได้แก่ รองเท้านิรภัย และ ให้เจ้าหน้าที่ความปลอดภัย ไออาร์พีซี ที่รับผิดชอบ และผู้ควบคุมงานในพื้นที่นั้น เป็นผู้พิจารณา PPE พื้นฐานเพิ่มเติมได้ตามความเหมาะสมด้านความปลอดภัยของโรงงาน

6.3 ต้องปฏิบัติตามเงื่อนไขสัญญาการดำเนินงานด้านอาชีวอนามัย ความปลอดภัย และระเบียบปฏิบัติด้านความปลอดภัยของโรงงาน

6.4 ห้ามนำบุหรี่ ไฟแช็ค หรืออุปกรณ์สื่อสารที่ไม่ป้องกันการระเบิด เช่น โทรศัพท์มือถือ, วิทยุ เข้าเขตควบคุมประกายไฟ

6.5 เครื่องยนต์ เครื่องจักรที่สันดาปภายใน หรืออุปกรณ์ที่มีการทำงานคล้ายกัน จะต้องสวมท่อป้องกันประกายไฟก่อนเข้าพื้นที่เขตผลิตหรือเขตควบคุมประกายไฟ โดยผู้รับจ้าง ต้องจัดเตรียมมา ตามมาตรฐาน IRPC. พร้อมทั้งพ่นสีน้ำเงิน หรือสีดำ และก่อนนำมาใช้งานต้องส่งให้ IRPC ตรวจสอบก่อน และต้องทำการตรวจสอบซ้ำทุก 6 เดือน และต้องสวมก่อนผ่านเข้าจุดตรวจ รปภ. จุด 22B, จุด 2, จุด 7, จุด I4, จุด I5, จุด I16C, จุด T13, จุด T1 และ จุด PO2

6.6 งานเจาะในเขต Hazardous area ซึ่งอยู่บนถังเก็บสารไวไฟ ที่มี Vent Drain หรืองานที่ห่างจากจุด Vent Drain ของวัตถุที่ติดไฟได้ง่าย ไม่เกิน 3 เมตร ต้องใช้สว่านลม หรือสว่านมือ หรือพิจารณาใช้เครื่องมืออื่นใดที่ไม่ก่อให้เกิดประกายไฟ

6.7 งานที่ต้องใช้ค้อนในพื้นที่ Hazardous area ต้องเป็นค้อนทองแดง หรือทองเหลือง, ค้อนยาง, ค้อนพลาสติก เพื่อป้องกันประกายไฟจากการตอก

6.8 ห้ามมีสิ่งของวางขวางประตูฉุกเฉิน, ทางเดิน, บันได หรือทางออกต่างๆ เนื่องจาก ในกรณีฉุกเฉิน เช่น เพลิงไหม้ จะทำให้เสียเวลาในการอพยพพนักงาน

6.9 การทำงานหรือวางสิ่งของกีดขวางการจราจร หรือวางของกีดขวางถนน หรือประตูทางเข้า – ออก ต้องขอใบอนุญาตปิดถนนทุกครั้ง

6.10 ต้องจัดเตรียมห้องน้ำ, ห้องสัวมให้เพียงพอต่อพนักงาน (ไม่เกิน 20 คนต่อห้องสัวม, ห้องน้ำ 1 ห้อง)

6.11 ห้ามมิให้มีการทำงานที่ต้องใช้อุปกรณ์ไฟฟ้า หรือการทำงานบนที่สูง เช่น บน Pipe rack, Column, นั่งร้าน, Flare ในขณะฝนตก หรือมีลมแรง ยกเว้น อุปกรณ์ไฟฟ้าได้ผ่านการตรวจสอบจากทาง IRPC เป็นที่เรียบร้อยแล้ว

6.12 การปฏิบัติงานในช่วงเวลากลางคืนต้องมีแสงสว่างเพียงพอ

6.13 ให้ผู้รับเหมาจัดส่ง M-H (จำนวนชั่วโมงการทำงาน) ให้กับ Safety IRPC ไม่เกินวันที่ 3 ของเดือน

6.14 การใช้สารเคมี, แก๊สต่างๆ ต้องมีสิ่งบ่งชี้ที่ภาชนะว่าเป็นสารเคมีชนิดใด และมี Diamond Diagram พร้อมรายละเอียดให้เห็นชัดเจน ตามความเหมาะสมของบรรจุภัณฑ์

6.15 การแต่งกายสำหรับพนักงานผู้รับจ้าง ต้องปฏิบัติตามระเบียบดังนี้

6.15.1 ต้องใช้เสื้อแขนยาว และกางเกงขายาวเท่านั้น

6.15.2 ผ้าที่ใช้ต้องเป็นผ้าฝ้าย (100% Cotton)

6.15.3 สีของเสื้อให้ใช้สีโทนเดียวกัน หรือลายเดียวกันทั้งบริษัท

6.15.4 มีสิ่งบ่งบอกว่าเป็นบริษัทอะไรให้เห็นชัดเจนทั้งด้านหน้า และด้านหลัง

6.15.5 แถบสะท้อนแสงกว้าง 1 นิ้ว ติดด้านหลังบริเวณไหล่เป็นแนวนอนตลอดแนว ไหล่ และมีตาข่ายคลุมผมให้รัดกุม (กรณีผมยาว)

6.16 จป. หรือ เจ้าหน้าที่ความปลอดภัยของผู้รับจ้าง จะต้องติดปลอกแขนกว้าง 4 นิ้ว มีสัญลักษณ์เป็นพื้นสีเขียว และปักข้อความ "ปลอดภัยไว้ก่อน" ด้วยสีขาว ไว้ที่ต้นแขนด้านซ้าย และต้องสวมหมวกนิรภัยสีเขียวตลอดเวลาในขณะปฏิบัติงาน

6.17 ผู้เฝ้าระวังไฟ (Fire Watch Man) ต้องติดปลอกแขนสีแดงกว้าง 4 นิ้ว ปักข้อความ "Fire W[redacted] ขาว ไว้ที่ต้นแขนขวาตลอดเวลาขณะปฏิบัติงาน

6.18 หัวหน้างาน ต้องติดปลอกแขนสีส้มกว้าง 4 นิ้ว ปักข้อความ "หัวหน้างาน" ด้วยสีดำไว้ที่ต้นแขนขวาตลอดเวลาขณะปฏิบัติงาน

6.19 สีหมวกนิรภัย กำหนดให้ผู้รับจ้างทุกบริษัทปฏิบัติ ดังนี้

6.19.1 หมวกสีเขียว สำหรับเจ้าหน้าที่ความปลอดภัย (จป.)

6.19.2 หมวกสีแดง สำหรับผู้เฝ้าระวังไฟ (Fire Watch Man)

6.19.3 หมวกสีขาว สำหรับระดับหัวหน้างานขึ้นไป

6.19.4 หมวกสีเหลือง สำหรับผู้ปฏิบัติงานทั่วไป

หมายเหตุ 1. ให้บริษัทผู้รับจ้างติดชื่อบริษัทที่หมวกนิรภัยที่พนักงานสวมทุกใบ

2. กรณีที่บริษัทผู้รับจ้าง เป็นผู้รับจ้างช่วง (Sub-Contractor) ให้ติดชื่อบริษัทตาม ชื่อบริษัทหลัก (Main Contractor) ที่หมวกนิรภัย

6.20 ผู้รับจ้างต้องดูแลความสะอาดในพื้นที่ทำงาน พื้นที่ Work Shop เป็นประจำทุกวันโดยแยกของเหลือใช้หรือขยะทั้งที่เป็นอันตราย และไม่เป็นอันตราย โดยพิจารณาแยกหรือกำจัดทิ้งเพื่อมิให้เป็นอันตรายต่อสุขภาพอนามัย และความปลอดภัยของลูกจ้าง และต้องรื้อถอนสิ่งก่อสร้างต่างๆ ที่ใช้ประกอบในการทำงานรวมทั้งจัดเก็บเศษวัสดุที่เลิกใช้งานแล้ว ซึ่งเป็นผลจากการทำงานของผู้รับเหมาให้หมดก่อนการส่งมอบงาน

6.21 จัดให้มีที่จัดเก็บสิ่งของส่วนตัวของพนักงานผู้รับเหมาก่อนเข้าเขตควบคุมประกายไฟ เช่น บุหรี่, ไฟแช็ค, โทรศัพท์มือถือ เพื่อให้ผู้ปฏิบัติงานปฏิบัติตามระเบียบของ IRPC อาจพิจารณาจัดรถรับ – ส่งผู้ปฏิบัติงานในช่วงเวลาของการพักสูบบุหรี่ โทรศัพท์ โดยมีการจัดเวลาพักเป็นช่วงๆ อันจะเป็นการลดโอกาสในการฝ่าฝืนระเบียบต่างๆ ให้น้อยลง

6.22 ผู้รับจ้างต้องปฏิบัติงานตามระเบียบการบริหารการจัดการผู้รับเหมาด้านความปลอดภัย อย่างเคร่งครัด (รายละเอียดภาคผนวกแนบท้าย)

6.23 ก่อนการเข้าทำงานจะต้องมีการส่งแผนงานการตรวจ และการทำงานจริงหากเป็นการปฏิบัติงานในเขตผลิตจะต้องมีการส่งรายงานประเมินความเสี่ยงส่งให้กับทางผู้เกี่ยวข้อง ล่วงหน้าอย่างน้อย 7 วัน โดยส่ง e-mail มาที่ คุณกัณญารัตน์ ทิพย์พินิจ: kanyarat.b@irpc.co.th , คุณอนุชา เพ็ชรรัตน์: anucha.pe@irpc.co.th

7. ผู้เสนอบริการต้องศึกษาข้อกำหนดทั่วไป เงื่อนไข และขอบเขตงาน รวมทั้งกระบวนการควบคุมคุณภาพงานและความปลอดภัย ให้เข้าใจอย่างถี่ถ้วนก่อนยื่นข้อเสนอบริการ หากมีข้อสงสัยประการใด ให้ซักถามเพิ่มเติมได้ในช่วงเวลาหลังจากผู้เสนอบริการรับทราบเอกสารข้อกำหนดจนถึงวันก่อนวันยื่นข้อเสนอให้บริการ เพื่อผู้เสนอบริการจะได้เข้าใจในเนื้อหาของงาน และทราบขอบเขตงานก่อนยื่นข้อเสนอบริการ ความผิดพลาดในการวางแผนการปฏิบัติงาน และความล่าช้าในการให้บริการ

8. ข้อกำหนด หรือเอกสารอื่นใดที่ได้ทำขึ้นเพื่อวัตถุประสงค์ในการเชิญชวนเสนอบริการนี้ ผู้เสนอบริการจะต้องไม่เปิดเผยข้อมูลใดๆ ที่อยู่ในเอกสารดังกล่าว หรือข้อมูลที่ได้ให้แก่ผู้เสนอบริการโดยวิธีการอื่นใดให้แก่บุคคลที่สาม เว้นแต่เพื่อเป็นการจัดเตรียมเอกสารข้อมูลให้บริการของตนเท่านั้น ผู้เสนอบริการจะต้องเก็บรักษาข้อมูลไว้เป็นความลับตลอดระยะเวลาการพิจารณาในกรณีที่มีการฝ่าฝืนข้อห้ามเกี่ยวกับการรักษาความลับดังกล่าว บริษัทฯ อาจปฏิเสธไม่รับข้อเสนอให้บริการนั้น บริษัทฯ สงวนลิขสิทธิ์แต่ผู้เดียวในบรรดาข้อมูล แบบแปลน และในเอกสารอื่นๆ ทั้งหมดที่ส่งให้แก่ผู้เสนอบริการ

9. ผู้เสนอบริการจำเป็นต้องเสนอค่าบริการสำหรับการจัดทำรายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมของโรงงานในเขตประกอบการไออาร์พีซี

10. การติดต่อ การรับรอง หรือการให้คำชี้แจงใดๆ ของพนักงานบริษัทฯ หรือตัวแทนของบริษัทฯ ไม่ว่าเป็นลายลักษณ์อักษรหรือด้วยวาจา ไม่ถือว่าผูกพันกับบริษัทฯ หรือตัวแทนของบริษัทฯ เว้นแต่จะได้มีคำชี้แจงเป็นลายลักษณ์อักษรจากบริษัทฯ ซึ่งได้ระบุเป็นการชัดแจ้ง

11. ผู้เสนอบริการพึงรับทราบว่าบริษัทฯ อาจจะออกคำแนะนำสำหรับผู้เสนอบริการ หรือภาคผนวกของข้อกำหนดเพิ่มเติมได้ในระหว่างระยะเวลาการยื่นข้อเสนอบริการ และโดยที่ไม่เป็นการกระทบถึงลำดับแห่งเอกสารทั่วไป ให้บทบัญญัติในเอกสารที่ออกเพิ่มเติมนี้อยู่ในลำดับที่เหนือกว่าข้อกำหนดที่ได้ออกไปก่อนหน้านี้

12. ผู้เสนอบริการจะต้องตรวจสอบความถูกต้องของข้อมูล โดยรวมถึงความถูกต้องด้านงานพิมพ์ รูปภาพ และสัญลักษณ์ต่างๆ ให้ถูกต้องชัดเจน

13. ข้อกำหนดฉบับนี้ มีจุดมุ่งหมายเพื่อใช้เป็นแนวทางในการดำเนินการเท่านั้น บริษัทฯ หรือตัวแทนของบริษัทฯ ไม่จำเป็นต้องรับผิดชอบต่อคำรับรองใดๆ หรือข้อมูลใดๆ ในเอกสารดังกล่าวเหล่านี้

14. ผู้เสนอบริการพึงรับทราบว่า ในการจัดทำรายงานผลการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม และมาตรการติดตามตรวจสอบคุณภาพสิ่งแวดล้อม จะต้องเสนอรายงานฯ ภายในวันที่ 31 กรกฎาคม และ 31 มกราคม (กรณีที่วันดังกล่าวตรงกับวันหยุดให้ดำเนินการในวันทำการถัดไป) ดังนั้น ผู้เสนอบริการจะต้องประสานงานกับบริษัทฯ อย่างใกล้ชิดเพื่อติดตามผลการดำเนินงานและรายงานให้กับบริษัทฯ รับทราบอย่างต่อเนื่อง

15. ให้ผู้เสนอบริการเสนอค่าใช้จ่ายที่เกิดขึ้นในขอบเขตของงานการจัดทำเล่มรายงานมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อมและมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อมตามจริง ทั้งนี้ ให้เสนอค่าบริการจัดทำเล่มรายงานฯ เป็นราคาต่อโครงการตามที่ได้รับมอบหมายให้ดำเนินการ

[redacted]

เอกสารแนบที่ 10 ข

สำเนาหนังสืออนุญาตให้โรงงานมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน



ที่ อก ๐๓๑๓/ ๑๐๖๐๐

กรมโรงงานอุตสาหกรรม
ถนนพระรามที่ ๖ เขตราชเทวี
กรุงเทพฯ ๑๐๔๐๐

๐๒ สิงหาคม ๒๕๖๒

เรื่อง หนังสือรับแจ้งการมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน

เรียน ผู้รับใบอนุญาตประกอบกิจการโรงงาน บริษัท ไออาร์พีซี จำกัด (มหาชน)

อ้างถึง คำขอเลขที่ ๐๙๔๖ ลงรับวันที่ ๒๖ กรกฎาคม ๒๕๖๒

ตามคำขอที่อ้างถึง ท่านแจ้งการมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน ของ บริษัท ไออาร์พีซี จำกัด (มหาชน) ทะเบียนโรงงานเลขที่ ข๓-๔๙-๑/๕๘ รย ประกอบกิจการแปรรูปน้ำมันหนักให้เป็นผลิตภัณฑ์ปิโตรเลียม ตั้งอยู่ ณ เลขที่ ๒๙๙ หมู่ที่ ๕ เขตประกอบการอุตสาหกรรมบริษัท ไออาร์พีซี จำกัด (มหาชน) ถนนสุขุมวิท ตำบลเชิงเนิน อำเภอเมืองระยอง จังหวัดระยอง โทรศัพท์ ๐ ๓๘๖๑ ๑๓๓๓

กรมโรงงานอุตสาหกรรมพิจารณาแล้ว รับแจ้งการให้มีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน และให้ท่านยื่นคำขอแจ้งการมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงานครั้งต่อไป ภายในวันที่ ๑๖ สิงหาคม ๒๕๖๕ โดยมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน ดังนี้

ผู้จัดการสิ่งแวดล้อม	นายไพโรจน์ ไชยวงค์

ลำดับ	ผู้ควบคุมระบบบำบัด	เลขทะเบียน	มลพิษน้ำ	มลพิษอากาศ	มลพิษกากอุตสาหกรรม
๑	นายประวิทย์ ศรีวาณิชรักษ์	๑๐๓-๕๑-๐๐๖๗๕	✓		✓
๒	นายธนพล เมาลานนท์	๑๒๐-๕๑-๐๐๒๗๔	✓	✓	
๓	นายไพโรจน์ อภิวัฒนานนท์	๐๒๐-๕๑-๐๐๓๔๙		✓	
๔	ว่าที่ ร.ต. ชวณัฐ น้อยอาษา	๐๒๐-๕๘-๐๐๓๗๕		✓	
๕	นายเอกชัย ปรางปราสาท	๐๐๓-๕๘-๐๐๑๙๕			✓
๖	นายเกรียงศักดิ์ วรสุนทรากร	๐๐๓-๕๘-๐๐๒๐๘			✓
๗	นายสุภาพ ภูบัวดวง	๑๐๐-๕๘-๐๐๕๐๔	✓		

ลำดับ	ผู้ปฏิบัติงานประจำระบบบำบัด	มลพิษน้ำ	มลพิษอากาศ	มลพิษกากอุตสาหกรรม
๑	นายจักร์ แซ่หลาย	✓	✓	✓
๒	นายศราวุธ แซ่ตั้น	✓	✓	
๓	นายธวัชชัย คัดไธสง	✓		✓
๔	นายสนธยา ปลื้มเกษร	✓	✓	✓
๕	นายฐาปนา ฮอสูงเนิน	✓		✓
๖	นายกฤษฎา นาคนาคา	✓		
๗	นายวีระพงษ์ หอมชู	✓		
๘	นายธนะรัฐ ช่างปลูก	✓		
๙	นายสุวิทย์ มณีเทพ	✓		
๑๐	นายอิทธิฤทธิ์ สิริมหาไชยกุล	✓		
๑๑	นายภานุวัฒน์ ตุ้มเงิน	✓		

ลำดับ ๑๒...

ลำดับ	ผู้ปฏิบัติงานประจำระบบบำบัด	มลพิษน้ำ	มลพิษอากาศ	มลพิษกากอุตสาหกรรม
๑๒	นายชาญณรงค์ ครองราช	✓		
๑๓	นายสังวาลย์ ฟูเต็มวงค์	✓	✓	
๑๔	นายรัตตินันท์ ภู่ประสม	✓		
๑๕	นายนรินทร์ แซ่ลิ้ม	✓		
๑๖	นายอณุกร พ่อค้าทอง	✓	✓	
๑๗	นายจักรพงษ์ ภิญโญชนม์	✓		
๑๘	นายบัณฑิต ระดาดาษ	✓		
๑๙	นายจิตรกร อัมพรมหา	✓		
๒๐	นายธนา รังไสว	✓		
๒๑	นายชัชวาลย์ สุขถนอม	✓		
๒๒	นายสมศักดิ์ เกลี้ยกล่อม	✓		
๒๓	นายกัมพล อัฐษร	✓	✓	
๒๔	นายศิริชัย สว่างฉาย	✓		
๒๕	นายอภิเชษฐ์ ถนอมจิตร์	✓		
๒๖	นายธวัชชัย วรรณเวช	✓		
๒๗	นายอิศเรศ งามจิตสากล	✓		
๒๘	นายพงษ์ศักดิ์ แก้วประดับ		✓	✓
๒๙	นายเกรียงศักดิ์ แก้วกอ		✓	✓
๓๐	นายวราทร พูลสุข		✓	✓
๓๑	นายวันชัย พฤษผล		✓	
๓๒	นายธีระพัฒน์ จารุวรรณาภรณ์		✓	
๓๓	นายนพดล นามจำรัส		✓	
๓๔	นายสุรเชษฐ รักซื่อ		✓	
๓๕	นายวีรยุทธ สุขสวัสดิ์		✓	
๓๖	นายคมกฤษ ศรีวะรมย์		✓	
๓๗	นายกมลสิทธิ์ นิพันรัมย์		✓	
๓๘	นายพงษ์เทพ วังเวง		✓	
๓๙	นายคุณนิธิ ใจเผิน		✓	
๔๐	นายรณรงค์ พรหมแสง		✓	
๔๑	นายศุภวุฒิ งามสุวรรณ์		✓	
๔๒	นายภานุวัฒน์ ทองคำ		✓	
๔๓	นายธนเดช ทิพม่อม		✓	
๔๔	นายสมปอง กะสัน		✓	
๔๕	นายเอกสิทธิ์ ศรีเงิน		✓	
๔๖	นายเอกวัฒน์ รัตนเสถียร		✓	
๔๗	นายศักดิ์ชัย ระดมสุข		✓	

ลำดับ ๔๘ ...

ลำดับ	ผู้ปฏิบัติงานประจำระบบบำบัด	มลพิษน้ำ	มลพิษอากาศ	มลพิษกากอุตสาหกรรม
๔๘	นายอรรคพงศ์ บุญสมพงศ์			✓
๔๙	นายประมวล ใยพันธ์			✓
๕๐	นายบุรินทร์ ศรีสนอง			✓
๕๑	นายสรศักดิ์ หงส์ษา			✓
๕๒	นายยงยศ ดังก้อง			✓
๕๓	นายกิตติพศ พวงรอด			✓
๕๔	นายพงศ์ประสิทธิ์ เรี่ยมทอง			✓
๕๕	นายโชคชัย วิริยะภาพ			✓
๕๖	นายสมชาย สำฮวน			✓
๕๗	นายฐาวณิช วารนิช			✓
๕๘	นายเชิดศักดิ์ มิกขุนทด		✓	✓
๕๙	นายนิทัศน์ มณฑาทอง			✓
๖๐	นายเณศรา คีรีแลง			✓
๖๑	นายกิตติพงษ์ ชัยมีแรง			✓
๖๒	นายอนุชิต มาเมือง			✓
๖๓	นายวุฒิพงษ์ เรืองศรี			✓
๖๔	นายนพดล แก้วรุ่งเรือง			✓
๖๕	นายมานะ ปิติวงษ์			✓
๖๖	นายจรัญ แกว่นกสิกรณ์		✓	
๖๗	นายทรงพล อินทร์นาง		✓	

หมายเหตุ ๑. การแจ้งการมี/ยกเลิก/เพิ่มเติม/เปลี่ยนแปลง บุคลากรด้านสิ่งแวดล้อมประจำโรงงาน ต้องส่งหนังสือฉบับนี้ด้วย
๒. ยกเลิกหนังสือรับแจ้งการมีบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน ที่ อก ๐๓๑๓/๙๒๒๔ ลงวันที่ ๓ กรกฎาคม ๒๕๖๒

จึงเรียนมาเพื่อโปรดทราบ

ขอแสดงความนับถือ

[redacted]

รักษาการนักวิทยาศาสตร์เชี่ยวชาญ รักษาราชการแทน
ผู้อำนวยการกองส่งเสริมเทคโนโลยีสิ่งแวดล้อมโรงงาน
ปฏิบัติราชการแทนอธิบดีกรมโรงงานอุตสาหกรรม

กองส่งเสริมเทคโนโลยีสิ่งแวดล้อมโรงงาน
กลุ่มกำกับบุคลากรด้านสิ่งแวดล้อมประจำโรงงาน
โทร. ๐ ๒๒๐๒ ๓๙๖๑ โทรสาร ๐ ๒๒๐๒ ๔๑๗๐
http://www.diw.go.th

เอกสารแนบที่ 11 ข

แผนบำรุงรักษาเครื่องมือเชิงป้องกัน (Preventive Maintenance Plan) ประจำปี 2566

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1	ERU		VB. INSP & ANALY M/C ERU PLANT	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	150293	
2	ERU -54 -54B001		FIRE HEATER ON-STREAM INSPECTION#54B001	PMT	1Y				I									IRI	IRI-INRC	150297	A
3	ERU -54 -GRD_LIGHTN		PM GND SYS (LOOP) (UNIT 54)	PMT	1Y	P												RRC	RRC-ERCP	140342	
4	ERU -54 -GRD_LIGHTN		VISUAL GROUNDING SYS (UNIT 54)	PMT	4M	P				P				P				RRC	RRC-ERCP	141702	
5	ERU -57 -GRD_LIGHTN		PM GND SYS (LOOP) (UNIT 57)	PMT	1Y		P											RRC	RRC-ERCP	140343	
6	ERU -57 -GRD_LIGHTN		VISUAL GROUNDING SYS (UNIT 57)	PMT	4M		P				P				P			RRC	RRC-ERCP	141703	
7	ERU -58 -GRD_LIGHTN		PM GND SYS (LOOP) (UNIT 58)	PMT	1Y		P											RRC	RRC-ERCP	140344	
8	ERU -58 -GRD_LIGHTN		VISUAL GROUNDING SYS (UNIT 58)	PMT	4M		P				P				P			RRC	RRC-ERCP	141704	
9	ERU -54 -PIPING	1-AII-54020001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164152	C
10	ERU -54 -PIPING	1-AII-54020002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164156	C
11	ERU -54 -PIPING	1-AIP-54361011	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164159	C
12	ERU -54 -PIPING	1-AIP-54361012	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164160	C
13	ERU -54 -PIPING	1-AIP-54361013	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164161	C
14	ERU -54 -PIPING	1-AIP-54361014	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164162	C
15	ERU -54 -PIPING	1-AIP-54361015	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164163	C
16	ERU -54 -PIPING	1-AIP-54361701	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164164	C
17	ERU -54 -PIPING	1-AIP-54361702	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164165	C
18	ERU -54 -PIPING	1-AIP-54361703	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164166	C
19	ERU -54 -PIPING	1-AIP-54361704	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164167	C
20	ERU -54 -PIPING	1-AIP-54361705	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164168	C
21	ERU -54 -PIPING	1-AIP-54361706	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164169	C
22	ERU -54 -PIPING	1-AIP-54361707	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164170	C
23	ERU -54 -PIPING	1-AIP-54361708	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164171	C
24	ERU -54 -PIPING	1-AIP-54361709	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164172	C
25	ERU -54 -PIPING	1-AIP-54361721	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164173	C
26	ERU -54 -PIPING	1-AIP-54361722	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164174	C
27	ERU -54 -PIPING	1-AIP-54361723	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164175	C
28	ERU -54 -PIPING	1-AIP-54361724	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164176	C
29	ERU -54 -PIPING	1-P-54007020	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164090	B
30	ERU -54 -PIPING	1-P-54007301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164140	B
31	ERU -54 -PIPING	1-P-54008008	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163969	B
32	ERU -54 -PIPING	1-P-54008009	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163992	B
33	ERU -54 -PIPING	1-P-54008010	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163995	B
34	ERU -54 -PIPING	1-P-54008011	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164008	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
35	ERU -54 -PIPING	1-P-54008012	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164024	B
36	ERU -54 -PIPING	1-P-54008013	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164028	B
37	ERU -54 -PIPING	1-P-54008014	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164042	B
38	ERU -54 -PIPING	1-P-54008015	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164049	B
39	ERU -54 -PIPING	1-P-54008016	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164059	B
40	ERU -54 -PIPING	1-P-54008017	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164066	B
41	ERU -54 -PIPING	1-P-54008018	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164077	B
42	ERU -54 -PIPING	1-P-54008019	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164083	B
43	ERU -54 -PIPING	1-P-54008020	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164093	B
44	ERU -54 -PIPING	1-P-54008021	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164096	B
45	ERU -54 -PIPING	1-P-54009009	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163991	B
46	ERU -54 -PIPING	1-P-54009301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164138	B
47	ERU -54 -PIPING	1-P-54009302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164142	B
48	ERU -54 -PIPING	1-P-54010011	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164012	B
49	ERU -54 -PIPING	1-P-54011030	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164129	B
50	ERU -54 -PIPING	1-P-54011302	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164143	B
51	ERU -54 -PIPING	1-P-54012008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163980	B
52	ERU -54 -PIPING	1-P-54014013	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164031	B
53	ERU -54 -PIPING	1-P-54017014	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164038	B
54	ERU -54 -PIPING	1-P-54017015	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164050	B
55	ERU -54 -PIPING	1-P-54017018	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164078	B
56	ERU -54 -PIPING	1-P-54017020	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164091	B
57	ERU -54 -PIPING	1/2-AII-54009001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164151	C
58	ERU -54 -PIPING	1/2-AII-54009002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164155	C
59	ERU -54 -PIPING	1/2-P-54002014	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164045	B
60	ERU -54 -PIPING	1/2-P-54002021	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164100	B
61	ERU -58 -PIPING	1/2-P-58005008	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166752	B
62	ERU -58 -PIPING	1/2-P-58005009	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166753	B
63	ERU -58 -PIPING	1/2-P-58005014	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166757	B
64	ERU -58 -PIPING	1/2-P-58005015	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166758	B
65	ERU -54 -PIPING	10-P-54010002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163883	B
66	ERU -57 -PIPING	10-P-57002026	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164605	B
67	ERU -57 -PIPING	10-P-57002027	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164606	B
68	ERU -57 -PIPING	10-P-57002028	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164607	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
69	ERU -57 -PIPING	10-P-57002029	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164608	B
70	ERU -57 -PIPING	10-P-57002030	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164609	B
71	ERU -57 -PIPING	10-P-57002031	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164610	B
72	ERU -57 -PIPING	10-P-57002032	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164611	B
73	ERU -57 -PIPING	10-P-57002033	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164612	B
74	ERU -57 -PIPING	10-P-57002034	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164613	B
75	ERU -57 -PIPING	10-P-57002035	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164614	B
76	ERU -57 -PIPING	10-P-57002036	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164615	B
77	ERU -57 -PIPING	10-P-57002037	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164616	B
78	ERU -57 -PIPING	10-P-57002038	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164617	B
79	ERU -57 -PIPING	10-P-57002039	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164618	B
80	ERU -57 -PIPING	10-P-57002040	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164619	B
81	ERU -57 -PIPING	10-P-57002041	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164620	B
82	ERU -57 -PIPING	10-P-57002042	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164621	B
83	ERU -57 -PIPING	10-P-57002043	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164622	B
84	ERU -57 -PIPING	10-P-57003027	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164670	B
85	ERU -57 -PIPING	10-P-57003028	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164671	B
86	ERU -57 -PIPING	10-P-57003029	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164672	B
87	ERU -57 -PIPING	10-P-57003030	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164673	B
88	ERU -57 -PIPING	10-P-57003031	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164674	B
89	ERU -57 -PIPING	10-P-57003032	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164675	B
90	ERU -57 -PIPING	10-P-57003033	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164676	B
91	ERU -57 -PIPING	10-P-57003034	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164677	B
92	ERU -57 -PIPING	10-P-57003035	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164678	B
93	ERU -57 -PIPING	10-P-57003036	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164679	B
94	ERU -57 -PIPING	10-P-57003037	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164680	B
95	ERU -57 -PIPING	10-P-57003038	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164681	B
96	ERU -57 -PIPING	10-P-57003039	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164682	B
97	ERU -57 -PIPING	10-P-57003040	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164683	B
98	ERU -57 -PIPING	10-P-57003041	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164684	B
99	ERU -57 -PIPING	10-P-57003042	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164685	B
100	ERU -57 -PIPING	10-P-57003043	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164686	B
101	ERU -57 -PIPING	10-P-57003044	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164687	B
102	ERU -57 -PIPING	10-P-57014007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165118	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
103	ERU -57 -PIPING	10-P-57015002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165134	B
104	ERU -57 -PIPING	10-P-57015003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165135	B
105	ERU -57 -PIPING	10-P-57015004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165136	B
106	ERU -57 -PIPING	10-P-57015005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165137	B
107	ERU -57 -PIPING	10-P-57015006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165138	B
108	ERU -57 -PIPING	10-P-57016002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165150	B
109	ERU -57 -PIPING	10-P-57016003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165151	B
110	ERU -57 -PIPING	10-P-57017001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165176	B
111	ERU -57 -PIPING	10-P-57017002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165177	B
112	ERU -57 -PIPING	10-P-57017003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165178	B
113	ERU -57 -PIPING	10-P-57017004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165179	B
114	ERU -57 -PIPING	10-P-57017005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165180	B
115	ERU -57 -PIPING	10-P-57017006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165181	B
116	ERU -54 -PIPING	12-P-54005001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163872	B
117	ERU -54 -PIPING	12-P-54005003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163902	B
118	ERU -54 -PIPING	12-P-54005004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163912	B
119	ERU -54 -PIPING	12-P-54005005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163934	B
120	ERU -54 -PIPING	12-P-54005007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163955	B
121	ERU -54 -PIPING	12-P-54006001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163878	B
122	ERU -54 -PIPING	12-P-54007001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163874	B
123	ERU -54 -PIPING	12-P-54007002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163882	B
124	ERU -54 -PIPING	12-P-54010003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163904	B
125	ERU -54 -PIPING	12-P-54013003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163901	B
126	ERU -54 -PIPING	12-P-54013006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163946	B
127	ERU -57 -PIPING	12-P-57014003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165115	B
128	ERU -57 -PIPING	12-P-57014008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165119	B
129	ERU -57 -PIPING	12-P-57015001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165133	B
130	ERU -57 -PIPING	12-P-57016001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165149	B
131	ERU -54 -PIPING	14-P-54003004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163918	B
132	ERU -54 -PIPING	14-P-54005010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163996	B
133	ERU -54 -PIPING	14-P-54006002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163879	B
134	ERU -54 -PIPING	14-P-54007012	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164017	B
135	ERU -54 -PIPING	14-P-54012003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163899	B
136	ERU -57 -PIPING	14-P-57014001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165113	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
137	ERU -57 -PIPING	14-P-57014002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165114	B
138	ERU -54 -PIPING	16-P-54013001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163864	B
139	ERU -54 -PIPING	16-P-54014001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163876	B
140	ERU -54 -PIPING	2-AII-54012001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164153	C
141	ERU -54 -PIPING	2-AII-54017001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164154	C
142	ERU -54 -PIPING	2-GCH-54017001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164227	C
143	ERU -54 -PIPING	2-P-54001004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163913	B
144	ERU -54 -PIPING	2-P-54001007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163966	B
145	ERU -54 -PIPING	2-P-54001013	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164032	B
146	ERU -54 -PIPING	2-P-54001015	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164054	B
147	ERU -54 -PIPING	2-P-54004009	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163988	B
148	ERU -54 -PIPING	2-P-54004012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164020	B
149	ERU -54 -PIPING	2-P-54004013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164029	B
150	ERU -54 -PIPING	2-P-54004014	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164041	B
151	ERU -54 -PIPING	2-P-54004015	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164053	B
152	ERU -54 -PIPING	2-P-54007007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163954	B
153	ERU -54 -PIPING	2-P-54007008	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163974	B
154	ERU -54 -PIPING	2-P-54007009	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163982	B
155	ERU -54 -PIPING	2-P-54007013	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164037	B
156	ERU -54 -PIPING	2-P-54008004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163911	B
157	ERU -54 -PIPING	2-P-54008006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163950	B
158	ERU -54 -PIPING	2-P-54008007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163953	B
159	ERU -54 -PIPING	2-P-54009005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163927	B
160	ERU -54 -PIPING	2-P-54009006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163952	B
161	ERU -54 -PIPING	2-P-54009007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163965	B
162	ERU -54 -PIPING	2-P-54009012	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164018	B
163	ERU -54 -PIPING	2-P-54009015	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164055	B
164	ERU -54 -PIPING	2-P-54009016	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164060	B
165	ERU -54 -PIPING	2-P-54009018	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164074	B
166	ERU -54 -PIPING	2-P-54009019	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164084	B
167	ERU -54 -PIPING	2-P-54009020	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164089	B
168	ERU -54 -PIPING	2-P-54009021	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164094	B
169	ERU -54 -PIPING	2-P-54009023	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164108	B
170	ERU -54 -PIPING	2-P-54009024	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164113	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
171	ERU -54 -PIPING	2-P-54011007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163956	B
172	ERU -54 -PIPING	2-P-54011009	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163990	B
173	ERU -54 -PIPING	2-P-54011010	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163997	B
174	ERU -54 -PIPING	2-P-54011011	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164016	B
175	ERU -54 -PIPING	2-P-54011015	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164047	B
176	ERU -54 -PIPING	2-P-54011031	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164130	B
177	ERU -54 -PIPING	2-P-54012007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163960	B
178	ERU -54 -PIPING	2-P-54014003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163906	B
179	ERU -54 -PIPING	2-P-54014012	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164019	B
180	ERU -54 -PIPING	2-P-54015006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163945	B
181	ERU -54 -PIPING	2-P-54016005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163937	B
182	ERU -54 -PIPING	2-P-54016007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163963	B
183	ERU -54 -PIPING	2-P-54017001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163873	B
184	ERU -54 -PIPING	2-P-54017002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163884	B
185	ERU -54 -PIPING	2-P-54017003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163903	B
186	ERU -54 -PIPING	2-P-54017004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163919	B
187	ERU -54 -PIPING	2-P-54017005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163929	B
188	ERU -54 -PIPING	2-P-54017006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163942	B
189	ERU -54 -PIPING	2-P-54017007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163957	B
190	ERU -54 -PIPING	2-P-54017010	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164002	B
191	ERU -54 -PIPING	2-P-54017011	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164009	B
192	ERU -54 -PIPING	2-P-54017012	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164025	B
193	ERU -54 -PIPING	2-P-54017013	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164033	B
194	ERU -54 -PIPING	2-P-54017021	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164097	B
195	ERU -57 -PIPING	2-P-57016006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165154	B
196	ERU -57 -PIPING	2-P-57016009	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165156	B
197	ERU -58 -PIPING	2-P-58005002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166746	B
198	ERU -58 -PIPING	2-P-58005003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166747	B
199	ERU -58 -PIPING	2-P-58012002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166763	B
200	ERU -58 -PIPING	2-P-58060001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166765	B
201	ERU -58 -PIPING	2-P-58060002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166766	B
202	ERU -54 -PIPING	20-P-54013004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163921	B
203	ERU -54 -PIPING	3-AII-54351001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164150	C
204	ERU -54 -PIPING	3-AIP-54361001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164158	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
205	ERU -54 -PIPING	3-P-54001002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163885	B
206	ERU -54 -PIPING	3-P-54001005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163940	B
207	ERU -54 -PIPING	3-P-54001008	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163973	B
208	ERU -54 -PIPING	3-P-54002007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163961	B
209	ERU -54 -PIPING	3-P-54002008	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163972	B
210	ERU -54 -PIPING	3-P-54002016	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164062	B
211	ERU -54 -PIPING	3-P-54003010	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163998	B
212	ERU -54 -PIPING	3-P-54004008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163979	B
213	ERU -54 -PIPING	3-P-54004010	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163993	B
214	ERU -54 -PIPING	3-P-54004011	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164010	B
215	ERU -54 -PIPING	3-P-54006003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163900	B
216	ERU -54 -PIPING	3-P-54006004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163920	B
217	ERU -54 -PIPING	3-P-54006005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163930	B
218	ERU -54 -PIPING	3-P-54008001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163868	B
219	ERU -54 -PIPING	3-P-54008002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163881	B
220	ERU -54 -PIPING	3-P-54010010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163999	B
221	ERU -54 -PIPING	3-P-54011003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163898	B
222	ERU -54 -PIPING	3-P-54011005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163938	B
223	ERU -54 -PIPING	3-P-54011012	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164027	B
224	ERU -54 -PIPING	3-P-54011014	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164040	B
225	ERU -54 -PIPING	3-P-54011016	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164058	B
226	ERU -54 -PIPING	3-P-54013008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163976	B
227	ERU -54 -PIPING	3-P-54013009	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163981	B
228	ERU -54 -PIPING	3-P-54014011	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164011	B
229	ERU -54 -PIPING	3-P-54015001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163867	B
230	ERU -54 -PIPING	3-P-54015003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163905	B
231	ERU -54 -PIPING	3-P-54015004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163924	B
232	ERU -54 -PIPING	3-P-54015005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163933	B
233	ERU -54 -PIPING	3-P-54015007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163962	B
234	ERU -54 -PIPING	3-P-54015008	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163968	B
235	ERU -54 -PIPING	3-P-54015009	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163989	B
236	ERU -54 -PIPING	3-P-54015022	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164101	B
237	ERU -54 -PIPING	3-P-54015023	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164110	B
238	ERU -54 -PIPING	3-P-54016004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163923	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
239	ERU -54 -PIPING	3-P-54016006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163947	B
240	ERU -54 -PIPING	3-P-54016008	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163970	B
241	ERU -54 -PIPING	3-P-54016010	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164005	B
242	ERU -58 -PIPING	3-P-58004001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166741	B
243	ERU -58 -PIPING	3-P-58004002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166742	B
244	ERU -58 -PIPING	3-P-58005001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166745	B
245	ERU -58 -PIPING	3-P-58005004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166748	B
246	ERU -58 -PIPING	3-P-58005005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166749	B
247	ERU -54 -PIPING	3/4-AIP-54017001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164157	C
248	ERU -54 -PIPING	3/4-P-54001017	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164068	B
249	ERU -54 -PIPING	3/4-P-54002015	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164046	B
250	ERU -54 -PIPING	3/4-P-54002017	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164064	B
251	ERU -54 -PIPING	3/4-P-54002018	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164073	B
252	ERU -54 -PIPING	3/4-P-54002019	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164079	B
253	ERU -54 -PIPING	3/4-P-54002020	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164088	B
254	ERU -54 -PIPING	3/4-P-54002022	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164105	B
255	ERU -54 -PIPING	3/4-P-54002023	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164106	B
256	ERU -54 -PIPING	3/4-P-54002024	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164111	B
257	ERU -54 -PIPING	3/4-P-54002025	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164117	B
258	ERU -54 -PIPING	3/4-P-54002026	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164120	B
259	ERU -54 -PIPING	3/4-P-54002027	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164122	B
260	ERU -54 -PIPING	3/4-P-54002028	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164126	B
261	ERU -54 -PIPING	3/4-P-54002301	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164137	B
262	ERU -54 -PIPING	3/4-P-54002302	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164145	B
263	ERU -54 -PIPING	3/4-P-54004301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164133	B
264	ERU -54 -PIPING	3/4-P-54004303	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164149	B
265	ERU -54 -PIPING	3/4-P-54007018	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164071	B
266	ERU -54 -PIPING	3/4-P-54007302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164146	B
267	ERU -54 -PIPING	3/4-P-54009013	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164034	B
268	ERU -54 -PIPING	3/4-P-54009014	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164044	B
269	ERU -54 -PIPING	3/4-P-54009022	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164103	B
270	ERU -54 -PIPING	3/4-P-54009025	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164116	B
271	ERU -54 -PIPING	3/4-P-54011017	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164065	B
272	ERU -54 -PIPING	3/4-P-54011018	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164072	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
273	ERU -54 -PIPING	3/4-P-54011019	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164085	B
274	ERU -54 -PIPING	3/4-P-54011020	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164092	B
275	ERU -54 -PIPING	3/4-P-54011021	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164095	B
276	ERU -54 -PIPING	3/4-P-54011022	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164102	B
277	ERU -54 -PIPING	3/4-P-54011023	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164107	B
278	ERU -54 -PIPING	3/4-P-54011024	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164112	B
279	ERU -54 -PIPING	3/4-P-54011025	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164118	B
280	ERU -54 -PIPING	3/4-P-54011026	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164121	B
281	ERU -54 -PIPING	3/4-P-54011027	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164124	B
282	ERU -54 -PIPING	3/4-P-54011028	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164125	B
283	ERU -54 -PIPING	3/4-P-54011029	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164128	B
284	ERU -54 -PIPING	3/4-P-54011301	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164136	B
285	ERU -54 -PIPING	3/4-P-54011303	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164148	B
286	ERU -54 -PIPING	3/4-P-54012301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164139	B
287	ERU -54 -PIPING	3/4-P-54012302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164147	B
288	ERU -54 -PIPING	3/4-P-54014014	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164043	B
289	ERU -54 -PIPING	3/4-P-54014015	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164051	B
290	ERU -54 -PIPING	3/4-P-54014016	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164061	B
291	ERU -54 -PIPING	3/4-P-54014017	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164069	B
292	ERU -54 -PIPING	3/4-P-54014018	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164075	B
293	ERU -54 -PIPING	3/4-P-54014019	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164081	B
294	ERU -54 -PIPING	3/4-P-54014020	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164087	B
295	ERU -54 -PIPING	3/4-P-54014021	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164099	B
296	ERU -54 -PIPING	3/4-P-54014022	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164104	B
297	ERU -54 -PIPING	3/4-P-54014023	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164109	B
298	ERU -54 -PIPING	3/4-P-54014024	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164114	B
299	ERU -54 -PIPING	3/4-P-54014025	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164115	B
300	ERU -54 -PIPING	3/4-P-54014026	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164119	B
301	ERU -54 -PIPING	3/4-P-54015010	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164006	B
302	ERU -54 -PIPING	3/4-P-54015011	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164015	B
303	ERU -54 -PIPING	3/4-P-54015012	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164023	B
304	ERU -54 -PIPING	3/4-P-54015013	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164036	B
305	ERU -54 -PIPING	3/4-P-54015014	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164039	B
306	ERU -54 -PIPING	3/4-P-54015015	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164048	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
307	ERU -54 -PIPING	3/4-P-54015016	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164063	B
308	ERU -54 -PIPING	3/4-P-54015017	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164070	B
309	ERU -54 -PIPING	3/4-P-54015018	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164076	B
310	ERU -54 -PIPING	3/4-P-54015019	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164080	B
311	ERU -54 -PIPING	3/4-P-54015020	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164086	B
312	ERU -54 -PIPING	3/4-P-54015021	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164098	B
313	ERU -54 -PIPING	3/4-P-54015301	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164135	B
314	ERU -54 -PIPING	3/4-P-54015302	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164141	B
315	ERU -54 -PIPING	3/4-P-54016301	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164134	B
316	ERU -54 -PIPING	3/4-P-54016302	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164144	B
317	ERU -54 -PIPING	3/4-P-54017008	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163978	B
318	ERU -54 -PIPING	3/4-P-54017016	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164056	B
319	ERU -54 -PIPING	3/4-P-54017017	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164067	B
320	ERU -57 -PIPING	3/4-P-57001001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164558	B
321	ERU -57 -PIPING	3/4-P-57001002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164559	B
322	ERU -57 -PIPING	3/4-P-57009001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164881	B
323	ERU -57 -PIPING	3/4-P-57009002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164882	B
324	ERU -57 -PIPING	3/4-P-57009003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164883	B
325	ERU -57 -PIPING	3/4-P-57009004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164884	B
326	ERU -57 -PIPING	3/4-P-57009005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164885	B
327	ERU -57 -PIPING	3/4-P-57009006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164886	B
328	ERU -57 -PIPING	3/4-P-57011001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165026	B
329	ERU -57 -PIPING	3/4-P-57011002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165027	B
330	ERU -57 -PIPING	3/4-P-57011003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165028	B
331	ERU -57 -PIPING	3/4-P-57011004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165029	B
332	ERU -57 -PIPING	3/4-P-57011005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165030	B
333	ERU -57 -PIPING	3/4-P-57011006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165031	B
334	ERU -57 -PIPING	3/4-P-57012001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165059	B
335	ERU -57 -PIPING	3/4-P-57012002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165060	B
336	ERU -57 -PIPING	3/4-P-57012003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165061	B
337	ERU -57 -PIPING	3/4-P-57012004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165062	B
338	ERU -57 -PIPING	3/4-P-57014301	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165120	B
339	ERU -57 -PIPING	3/4-P-57014303	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165121	B
340	ERU -57 -PIPING	3/4-P-57016008	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165155	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
341	ERU -57 -PIPING	3/4-P-57016301	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165157	B
342	ERU -57 -PIPING	3/4-P-57016302	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165158	B
343	ERU -57 -PIPING	3/4-P-57017010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165184	B
344	ERU -57 -PIPING	3/4-P-57017011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165185	B
345	ERU -57 -PIPING	3/4-P-57501001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165525	B
346	ERU -57 -PIPING	3/4-P-57501002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165526	B
347	ERU -57 -PIPING	3/4-P-57501003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165527	B
348	ERU -57 -PIPING	3/4-P-57508001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	165535	B
349	ERU -57 -PIPING	3/4-P-57508002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165536	B
350	ERU -57 -PIPING	3/4-P-57508003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165537	B
351	ERU -58 -PIPING	3/4-P-58004003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166743	B
352	ERU -58 -PIPING	3/4-P-58004004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166744	B
353	ERU -58 -PIPING	3/4-P-58005006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166750	B
354	ERU -58 -PIPING	3/4-P-58005007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166751	B
355	ERU -58 -PIPING	3/4-P-58005010	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166754	B
356	ERU -58 -PIPING	3/4-P-58005011	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166755	B
357	ERU -58 -PIPING	3/4-P-58005012	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166756	B
358	ERU -58 -PIPING	3/4-P-58005016	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166759	B
359	ERU -58 -PIPING	3/4-P-58005017	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166760	B
360	ERU -58 -PIPING	3/4-P-58005018	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166761	B
361	ERU -58 -PIPING	3/4-P-58060003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	166767	B
362	ERU -54 -PIPING	4-P-54001001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163875	B
363	ERU -54 -PIPING	4-P-54001003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163896	B
364	ERU -54 -PIPING	4-P-54001006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163944	B
365	ERU -54 -PIPING	4-P-54001009	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163986	B
366	ERU -54 -PIPING	4-P-54001010	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164001	B
367	ERU -54 -PIPING	4-P-54001011	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164013	B
368	ERU -54 -PIPING	4-P-54001012	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164022	B
369	ERU -54 -PIPING	4-P-54002004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163922	B
370	ERU -54 -PIPING	4-P-54002005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163935	B
371	ERU -54 -PIPING	4-P-54002006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163949	B
372	ERU -54 -PIPING	4-P-54002009	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163987	B
373	ERU -54 -PIPING	4-P-54002013	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164030	B
374	ERU -54 -PIPING	4-P-54007010	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164003	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
375	ERU -54 -PIPING	4-P-54007016	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164057	B
376	ERU -54 -PIPING	4-P-54008003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163908	B
377	ERU -54 -PIPING	4-P-54009010	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163994	B
378	ERU -54 -PIPING	4-P-54009011	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164007	B
379	ERU -54 -PIPING	4-P-54012004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163917	B
380	ERU -54 -PIPING	4-P-54012005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163941	B
381	ERU -54 -PIPING	4-P-54013002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163880	B
382	ERU -54 -PIPING	4-P-54014005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163932	B
383	ERU -54 -PIPING	4-P-54016009	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163985	B
384	ERU -57 -PIPING	4-P-57000001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164515	B
385	ERU -57 -PIPING	4-P-57014004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165116	B
386	ERU -57 -PIPING	4-P-57014006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165117	B
387	ERU -57 -PIPING	4-P-57016004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165152	B
388	ERU -54 -PIPING	6-P-54002010	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164004	B
389	ERU -54 -PIPING	6-P-54002012	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164021	B
390	ERU -54 -PIPING	6-P-54003002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163886	B
391	ERU -54 -PIPING	6-P-54003003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163909	B
392	ERU -54 -PIPING	6-P-54003011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164014	B
393	ERU -54 -PIPING	6-P-54004001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163865	B
394	ERU -54 -PIPING	6-P-54004002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163891	B
395	ERU -54 -PIPING	6-P-54004003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163895	B
396	ERU -54 -PIPING	6-P-54004004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163914	B
397	ERU -54 -PIPING	6-P-54004005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163939	B
398	ERU -54 -PIPING	6-P-54004006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163948	B
399	ERU -54 -PIPING	6-P-54004007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163959	B
400	ERU -54 -PIPING	6-P-54007015	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164052	B
401	ERU -54 -PIPING	6-P-54010006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163943	B
402	ERU -54 -PIPING	6-P-54011001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163877	B
403	ERU -54 -PIPING	6-P-54011002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163893	B
404	ERU -54 -PIPING	6-P-54011004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163925	B
405	ERU -54 -PIPING	6-P-54011032	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164131	B
406	ERU -54 -PIPING	6-P-54011033	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164132	B
407	ERU -54 -PIPING	6-P-54013005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163936	B
408	ERU -54 -PIPING	6-P-54013007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163964	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
409	ERU -54 -PIPING	6-P-54014008	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163977	B
410	ERU -54 -PIPING	6-P-54015002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163889	B
411	ERU -57 -PIPING	6-P-57016005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165153	B
412	ERU -57 -PIPING	6-P-57017013	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165187	B
413	ERU -54 -PIPING	8-P-54002001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163871	B
414	ERU -54 -PIPING	8-P-54002002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163888	B
415	ERU -54 -PIPING	8-P-54002003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163907	B
416	ERU -54 -PIPING	8-P-54005008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163971	B
417	ERU -54 -PIPING	8-P-54005009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163983	B
418	ERU -54 -PIPING	8-P-54005012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	164026	B
419	ERU -54 -PIPING	8-P-54007003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163897	B
420	ERU -54 -PIPING	8-P-54007004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163926	B
421	ERU -54 -PIPING	8-P-54007005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163931	B
422	ERU -54 -PIPING	8-P-54007006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163951	B
423	ERU -54 -PIPING	8-P-54007019	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164082	B
424	ERU -54 -PIPING	8-P-54009001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163869	B
425	ERU -54 -PIPING	8-P-54009002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163890	B
426	ERU -54 -PIPING	8-P-54009003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163894	B
427	ERU -54 -PIPING	8-P-54009004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163915	B
428	ERU -54 -PIPING	8-P-54009008	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163975	B
429	ERU -54 -PIPING	8-P-54010001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163866	B
430	ERU -54 -PIPING	8-P-54010004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163916	B
431	ERU -54 -PIPING	8-P-54010005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163928	B
432	ERU -54 -PIPING	8-P-54010007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163958	B
433	ERU -54 -PIPING	8-P-54011013	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164035	B
434	ERU -54 -PIPING	8-P-54012001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163870	B
435	ERU -54 -PIPING	8-P-54012002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	163887	B
436	ERU -54 -PIPING	8-P-54014002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163892	B
437	ERU -54 -PIPING	8-P-54014004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163910	B
438	ERU -54 -PIPING	8-P-54014007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163967	B
439	ERU -54 -PIPING	8-P-54014009	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	163984	B
440	ERU -54 -PIPING	8-P-54014010	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164000	B
441	ERU -54 -PIPING	8-P-54014027	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164123	B
442	ERU -54 -PIPING	8-P-54014028	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	164127	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
443	ERU -57 -PIPING	8-P-57017007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165182	B
444	ERU -57 -PIPING	8-P-57017008	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165183	B
445	ERU -57 -PIPING	8-P-57017012	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	165186	B
446	ERU -54 -AIR	ERU-54-CEMS-001	PM TYPE OF AIR 54-CEMS-001 (Large 2,8)	PMT	2M				P		P				P		P	RRC	RRC-ERCP	138253	A
447	ERU -54 -AIR	ERU-54-CEMS-001	PM TYPE OF AIR 54-CEMS-001 (Large 2,8)	PMT	6M		P						P					RRC	RRC-ERCP	138253	A
448	ERU -54 -DVA5401	ERU-54DV001	TEST LINEAR HEAT DETECTOR ERU-54DV001	PMT	6M			P						P				RRC	RRC-ERCP	150061	B
449	ERU -54 -DVA5401	ERU-54DV002	TEST LINEAR HEAT DETECTOR ERU-54DV002	PMT	6M			P						P				RRC	RRC-ERCP	150062	B
450	ERU -54 -DVA5401	ERU-54DV003	TEST LINEAR HEAT DETECTOR ERU-54DV003	PMT	6M			P						P				RRC	RRC-ERCP	150063	B
451	ERU -54 -DVA5401	ERU-54DV004	TEST LINEAR HEAT DETECTOR ERU-54DV004	PMT	6M			P						P				RRC	RRC-ERCP	150064	B
452	ERU -54 -DVA5401	ERU-54DV005	TEST LINEAR HEAT DETECTOR ERU-54DV005	PMT	6M			P						P				RRC	RRC-ERCP	150065	B
453	ERU -54 -DVA5401	ERU-54DV006	TEST LINEAR HEAT DETECTOR ERU-54DV006	PMT	6M			P						P				RRC	RRC-ERCP	150066	B
454	ERU -54 -54E005	ERU-54E005A-K01A	VB. INSP & ANALY M/C 54E005A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130240	C
455	ERU -54 -54E005	ERU-54E005A-K01A	PM INSP OF M/C NO. 54E005A-K01A	PMT	3M	I			I			I		I				RRC	RRC-MRCP	129641	C
456	ERU -54 -54E005	ERU-54E005A-K01A	REGREASING BRG OF 54E005A-K01A	PMT	3M	L			L			L		L				RRC	RRC-MRCP	129994	C
457	ERU -54 -54E005	ERU-54E005A-K01A-M	Regreasing Mot BRG of 54E005A-K01A-MD1	PMT	4M	L				L			L					RRC	RRC-ERCP	139579	C
458	ERU -54 -54E005	ERU-54E005A-K01B	VB. INSP & ANALY M/C 54E005A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130241	C
459	ERU -54 -54E005	ERU-54E005A-K01B	PM INSP OF M/C NO. 54E005A-K01B	PMT	3M	I			I			I		I				RRC	RRC-MRCP	129642	C
460	ERU -54 -54E005	ERU-54E005A-K01B	REGREASING BRG OF 54E005A-K01B	PMT	3M	L			L			L		L				RRC	RRC-MRCP	129995	C
461	ERU -54 -54E005	ERU-54E005A-K01B-M	Regreasing Mot BRG of 54E005A-K01B-MD1	PMT	4M				L				L			L		RRC	RRC-ERCP	139580	C
462	ERU -54 -54E005	ERU-54E005B-K01A	VB. INSP & ANALY M/C 54E005B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130242	C
463	ERU -54 -54E005	ERU-54E005B-K01A	PM INSP OF M/C NO. 54E005B-K01A	PMT	3M	I			I			I		I				RRC	RRC-MRCP	129643	C
464	ERU -54 -54E005	ERU-54E005B-K01A	REGREASING BRG OF 54E005B-K01A	PMT	3M	L			L			L		L				RRC	RRC-MRCP	129996	C
465	ERU -54 -54E005	ERU-54E005B-K01A-M	Regreasing Mot BRG of 54E005B-K01A-MD1	PMT	4M	L				L			L					RRC	RRC-ERCP	139581	C
466	ERU -54 -54E005	ERU-54E005B-K01B	VB. INSP & ANALY M/C 54E005B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130243	C
467	ERU -54 -54E005	ERU-54E005B-K01B	PM INSP OF M/C NO. 54E005B-K01B	PMT	3M	I			I			I		I				RRC	RRC-MRCP	129644	C
468	ERU -54 -54E005	ERU-54E005B-K01B	REGREASING BRG OF 54E005B-K01B	PMT	3M	L			L			L		L				RRC	RRC-MRCP	129997	C
469	ERU -54 -54E005	ERU-54E005B-K01B-M	Regreasing Mot BRG of 54E005B-K01B-MD1	PMT	4M				L				L			L		RRC	RRC-ERCP	139582	C
470	ERU -54 -54E007	ERU-54E007-K01A	VB. INSP & ANALY M/C 54E007-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130244	B
471	ERU -54 -54E007	ERU-54E007-K01A	PM INSP OF M/C NO. 54E007-K01A	PMT	3M		I			I			I					RRC	RRC-MRCP	129645	B
472	ERU -54 -54E007	ERU-54E007-K01A	REGREASING BRG OF 54E007-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCP	129998	B
473	ERU -54 -54E007	ERU-54E007-K01A-M	Regreasing Mot BRG of 54E007-K01A-MD1	PMT	4M	L				L			L					RRC	RRC-ERCP	139583	B
474	ERU -54 -54E007	ERU-54E007-K01B	VB. INSP & ANALY M/C 54E007-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130245	B
475	ERU -54 -54E007	ERU-54E007-K01B	PM INSP OF M/C NO. 54E007-K01B	PMT	3M		I			I			I					RRC	RRC-MRCP	129646	B
476	ERU -54 -54E007	ERU-54E007-K01B	REGREASING BRG OF 54E007-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCP	129999	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
477	ERU -54 -54E007	ERU-54E007-K01B-M	Regreasing Mot BRG of 54E007-K01B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139584	B
478	ERU -54 -54E010	ERU-54E010A-E01	PM INSP OF M/C NO. 54E010A	PMT	3M		I			I			I			I		RRC	RRC-MRCP	148890	C
479	ERU -54 -54E010	ERU-54E010A-E01	REGREASING BRG OF 54E010A	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148892	C
480	ERU -54 -54E010A	ERU-54E010A-K01A	VB. INSP & ANALY M/C 54E010A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130246	C
481	ERU -54 -54E010A	ERU-54E010A-K01A	PM INSP OF M/C NO. 54E010A-K01A	PMT	3M		I			I			I			I		RRC	RRC-MRCP	129647	C
482	ERU -54 -54E010A	ERU-54E010A-K01A	REGREASING BRG OF 54E010A-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCP	130000	C
483	ERU -54 -54E010	ERU-54E010A-K01A-M	Regreasing Mot BRG of 54E010A-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139585	C
484	ERU -54 -54E010A	ERU-54E010A-K01B	VB. INSP & ANALY M/C 54E010A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130247	C
485	ERU -54 -54E010A	ERU-54E010A-K01B	PM INSP OF M/C NO. 54E010A-K01B	PMT	3M		I			I			I			I		RRC	RRC-MRCP	129648	C
486	ERU -54 -54E010A	ERU-54E010A-K01B	REGREASING BRG OF 54E010A-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCP	130001	C
487	ERU -54 -54E010	ERU-54E010A-K01B-M	Regreasing Mot BRG of 54E010A-K01B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139586	C
488	ERU -54 -54E010	ERU-54E010B-E01	PM INSP OF M/C NO. 54E010B	PMT	3M		I			I			I			I		RRC	RRC-MRCP	148891	C
489	ERU -54 -54E010	ERU-54E010B-E01	REGREASING BRG OF 54E010B	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148893	C
490	ERU -54 -54E010B	ERU-54E010B-K01A	VB. INSP & ANALY M/C 54E010B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130248	C
491	ERU -54 -54E010B	ERU-54E010B-K01A	PM INSP OF M/C NO. 54E010B-K01A	PMT	3M			I			I			I			I	RRC	RRC-MRCP	129649	C
492	ERU -54 -54E010B	ERU-54E010B-K01A	REGREASING BRG OF 54E010B-K01A	PMT	3M			L			L			L			L	RRC	RRC-MRCP	130002	C
493	ERU -54 -54E010	ERU-54E010B-K01A-M	Regreasing Mot BRG of 54E010B-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139587	C
494	ERU -54 -54E010B	ERU-54E010B-K01B	VB. INSP & ANALY M/C 54E010B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130249	C
495	ERU -54 -54E010B	ERU-54E010B-K01B	PM INSP OF M/C NO. 54E010B-K01B	PMT	3M			I			I			I			I	RRC	RRC-MRCP	129650	C
496	ERU -54 -54E010B	ERU-54E010B-K01B	REGREASING BRG OF 54E010B-K01B	PMT	3M			L			L			L			L	RRC	RRC-MRCP	130003	C
497	ERU -54 -54E010	ERU-54E010B-K01B-M	Regreasing Mot BRG of 54E010B-K01B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139588	C
498	ERU -54 -54E012	ERU-54E012-K01A	VB. INSP & ANALY M/C 54E012-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130250	C
499	ERU -54 -54E012	ERU-54E012-K01A	PM INSP OF M/C NO. 54E012-K01A	PMT	3M			I			I			I			I	RRC	RRC-MRCP	129651	C
500	ERU -54 -54E012	ERU-54E012-K01A	REGREASING BRG OF 54E012-K01A	PMT	3M			L			L			L			L	RRC	RRC-MRCP	130004	C
501	ERU -54 -54E012	ERU-54E012-K01A-M	Regreasing Mot BRG of 54E012-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139589	C
502	ERU -54 -54E012	ERU-54E012-K01B	VB. INSP & ANALY M/C 54E012-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130251	C
503	ERU -54 -54E012	ERU-54E012-K01B	PM INSP OF M/C NO. 54E012-K01B	PMT	3M			I			I			I			I	RRC	RRC-MRCP	129652	C
504	ERU -54 -54E012	ERU-54E012-K01B	REGREASING BRG OF 54E012-K01B	PMT	3M			L			L			L			L	RRC	RRC-MRCP	130005	C
505	ERU -54 -54E012	ERU-54E012-K01B-M	Regreasing Mot BRG of 54E012-K01B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139590	C
506	ERU -54 -54H001	ERU-54H001-H01	Over Head Crane Inspection By	INT	1Y				I									IRI	IRI-INSS	130561	B
507	ERU -54 -54H001	ERU-54H001-H01	PM OF 54H001	PMT	6M	P						P						RRC	RRC-MRCP	146805	B
508	ERU -54 -54H001	ERU-54H001-H01	PM INSP OF M/C NO. 54H001	PMT	4M		I			I			I			I		RRC	RRC-MRCP	148876	B
509	ERU -54 -54K001A	ERU-54K001A-K01	PM COMPRESSOR NO. 54K001A -K01	PMT	1Y							P						CRE	CRE-OHIP	131154	A
510	ERU -54 -54K001A	ERU-54K001A-K01	OIL INSP & ANALYSIS M/C 54K001A -K01	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INDL	130074	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
511	ERU -54 -54K001A	ERU-54K001A-M	STAND BY CHECK MV. MOT 54K001A-MD1	PMT	1Y								T					RRC	RRC-ERCP	138899	A
512	ERU -54 -54K001A	ERU-54K001A-M	Change BRG Lube Oil of Mot 54K001A-MD1	PMT	1Y				L									RRC	RRC-ERCP	139398	A
513	ERU -54 -54K001A	ERU-54K001A-M	STAND BY CHECK MV. MOT 54K001A-MD1	PMT	1Y				T									RRC	RRC-ERCP	154224	A
514	ERU -54 -54K001A	ERU-54K001A-P01	PM INSP OF M/C NO.ERU-54K001A -P01	PMT	4M		I			I			I			I		RRC	RRC-MRCP	155809	A
515	ERU -54 -54K001A	ERU-54K001A-P02	PM INSP OF M/C NO.ERU-54K001A -P02	PMT	4M	I				I			I			I		RRC	RRC-MRCP	155810	A
516	ERU -54 -54K001B	ERU-54K001B-K01	PM COMPRESSOR NO. 54K001B -K01	PMT	1Y						P							CRE	CRE-OHIP	129952	A
517	ERU -54 -54K001B	ERU-54K001B-K01	OIL INSP & ANALYSIS M/C 54K001B -K01	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INDL	130075	A
518	ERU -54 -54K001B	ERU-54K001B-M	STAND BY CHECK MV. MOT 54K001B-MD1	PMT	6M			T						T				RRC	RRC-ERCP	138900	A
519	ERU -54 -54K001B	ERU-54K001B-M	Change BRG Lube Oil of Mot 54K001B-MD1	PMT	1Y				L									RRC	RRC-ERCP	139399	A
520	ERU -54 -54K001B	ERU-54K001B-P01	PM INSP OF M/C NO.ERU-54K001B -P01	PMT	4M				I				I			I		RRC	RRC-MRCP	155811	A
521	ERU -54 -54K001B	ERU-54K001B-P02	PM INSP OF M/C NO.ERU-54K001B -P02	PMT	4M				I				I			I		RRC	RRC-MRCP	155812	A
522	ERU -54 -54P001A	ERU-54P001A-M	STAND BY CHECK MV. MOT 54P001A-MD1	PMT	1Y								T					RRC	RRC-ERCP	138901	A
523	ERU -54 -54P001A	ERU-54P001A-M	Regreasing Mot BRG of 54P001A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139400	A
524	ERU -54 -54P001A	ERU-54P001A-M	STAND BY CHECK MV. MOT 54P001A-MD1	PMT	1Y				T									RRC	RRC-ERCP	154225	A
525	ERU -54 -54P001A	ERU-54P001A-P01	PM INSP OF M/C NO. 54P001A -P01	PMT	4M	I				I			I			I		RRC	RRC-MRCP	129653	A
526	ERU -54 -54P001A	ERU-54P001A-P01	PM OF 54P001A -P01	PMT	4M				P				P			P		RRC	RRC-MRCP	130696	A
527	ERU -54 -54P001B	ERU-54P001B-M	STAND BY CHECK MV. MOT 54P001B-MD1	PMT	6M			T						T				RRC	RRC-ERCP	138902	A
528	ERU -54 -54P001B	ERU-54P001B-M	Regreasing Mot BRG of 54P001B-MD1	PMT	4M				L				L			L		RRC	RRC-ERCP	139401	A
529	ERU -54 -54P001B	ERU-54P001B-P01	PM INSP OF M/C NO. 54P001B -P01	PMT	4M				I				I			I		RRC	RRC-MRCP	129654	A
530	ERU -54 -54P001B	ERU-54P001B-P01	PM OF 54P001B -P01	PMT	4M	P				P			P			P		RRC	RRC-MRCP	130697	A
531	ERU -54 -54P002A	ERU-54P002A-M	STAND BY CHECK LV. MOT 54P002A-M	PMT	1Y								T					RRC	RRC-ERCP	138903	B
532	ERU -54 -54P002A	ERU-54P002A-M	STAND BY CHECK LV. MOT 54P002A-M	PMT	1Y				T									RRC	RRC-ERCP	154226	B
533	ERU -54 -54P002A	ERU-54P002A-P	PM INSP OF M/C NO. 54P002A -P01	PMT	4M	I				I			I			I		RRC	RRC-MRCP	129655	B
534	ERU -54 -54P002A	ERU-54P002A-P01	VB. INSP & ANALY M/C 54P002A	INT	4M	I				I			I			I		IRI	IRI-INVB	130254	B
535	ERU -54 -54P002A	ERU-54P002A-P01	VB. INSP & ANALY M/C 54P002A -P01	INT	4M		I				I			I			I	IRI	IRI-INVB	131008	B
536	ERU -54 -54P002A	ERU-54P002A-P01	VB. INSP & ANALY M/C 54P002A -P01	INT	4M			I				I			I		I	IRI	IRI-INVB	131235	B
537	ERU -54 -54P002B	ERU-54P002B-M	STAND BY CHECK LV. MOT 54P002B-M	PMT	6M			T						T				RRC	RRC-ERCP	138904	B
538	ERU -54 -54P002B	ERU-54P002B-P	PM INSP OF M/C NO. 54P002B -P01	PMT	4M				I				I			I		RRC	RRC-MRCP	129656	B
539	ERU -54 -54P002B	ERU-54P002B-P01	VB. INSP & ANALY M/C 54P002B	INT	4M				I				I			I		IRI	IRI-INVB	130255	B
540	ERU -54 -54P002B	ERU-54P002B-P01	PM OF 54P002B -P01	PMT	4M	P				P			P			P		RRC	RRC-MRCP	130699	B
541	ERU -54 -54P003A	ERU-54P003A-M	STAND BY CHECK LV. MOT 54P003A-MD1	PMT	1Y								T					RRC	RRC-ERCP	138905	C
542	ERU -54 -54P003A	ERU-54P003A-M	STAND BY CHECK LV. MOT 54P003A-MD1	PMT	1Y				T									RRC	RRC-ERCP	154227	C
543	ERU -54 -54P003A	ERU-54P003A-P01	VB. INSP & ANALY M/C 54P003A	INT	4M	I				I			I			I		IRI	IRI-INVB	130256	C
544	ERU -54 -54P003A	ERU-54P003A-P01	VB. INSP & ANALY M/C 54P003A -P01	INT	4M		I				I			I			I	IRI	IRI-INVB	131009	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
545	ERU -54 -54P003A	ERU-54P003A-P01	VB. INSP & ANALY M/C 54P003A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131236	C
546	ERU -54 -54P003A	ERU-54P003A-P01	PM INSP OF M/C NO. 54P003A -P01	PMT	4M	I				I				I				RRC	RRC-MRCP	129657	C
547	ERU -54 -54P003A	ERU-54P003A-P01	PM OF 54P003A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130700	C
548	ERU -54 -54P003B	ERU-54P003B-M	STAND BY CHECK LV. MOT 54P003B-M01	PMT	6M			T				T						RRC	RRC-ERCP	138906	C
549	ERU -54 -54P003B	ERU-54P003B-P01	VB. INSP & ANALY M/C 54P003B	INT	4M				I				I				I	IRI	IRI-INVB	130257	C
550	ERU -54 -54P003B	ERU-54P003B-P01	PM INSP OF M/C NO. 54P003B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129658	C
551	ERU -54 -54P003B	ERU-54P003B-P01	PM OF 54P003B -P01	PMT	4M	P				P				P				RRC	RRC-MRCP	130701	C
552	ERU -54 -54P004A	ERU-54P004A-M	STAND BY CHECK LV. MOT 54P004A-M	PMT	1Y								T					RRC	RRC-ERCP	138907	C
553	ERU -54 -54P004A	ERU-54P004A-M	STAND BY CHECK LV. MOT 54P004A-M	PMT	1Y				T									RRC	RRC-ERCP	154228	C
554	ERU -54 -54P004A	ERU-54P004A-P	PM INSP OF M/C NO. 54P004A -P01	PMT	4M	I				I				I				RRC	RRC-MRCP	129659	B
555	ERU -54 -54P004A	ERU-54P004A-P01	VB. INSP & ANALY M/C 54P004A	INT	4M	I				I				I				IRI	IRI-INVB	130258	C
556	ERU -54 -54P004A	ERU-54P004A-P01	VB. INSP & ANALY M/C 54P004A -P01	INT	4M		I				I				I			IRI	IRI-INVB	131010	C
557	ERU -54 -54P004A	ERU-54P004A-P01	VB. INSP & ANALY M/C 54P004A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131237	C
558	ERU -54 -54P004B	ERU-54P004B-M	STAND BY CHECK LV. MOT 54P004B-M	PMT	6M			T						T				RRC	RRC-ERCP	138908	C
559	ERU -54 -54P004B	ERU-54P004B-P	PM INSP OF M/C NO. 54P004B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129660	B
560	ERU -54 -54P004B	ERU-54P004B-P01	VB. INSP & ANALY M/C 54P004B	INT	4M				I				I				I	IRI	IRI-INVB	130259	C
561	ERU -54 -54P004B	ERU-54P004B-P01	PM OF 54P004B -P01	PMT	4M	P				P				P				RRC	RRC-MRCP	130703	C
562	ERU -54 -54P005A	ERU-54P005A-M	STAND BY CHECK LV. MOT 54P005A-M01	PMT	1Y								T					RRC	RRC-ERCP	138909	B
563	ERU -54 -54P005A	ERU-54P005A-M	STAND BY CHECK LV. MOT 54P005A-M01	PMT	1Y				T									RRC	RRC-ERCP	154229	B
564	ERU -54 -54P005A	ERU-54P005A-P01	VB. INSP & ANALY M/C 54P005A	INT	4M	I				I				I				IRI	IRI-INVB	130260	B
565	ERU -54 -54P005A	ERU-54P005A-P01	VB. INSP & ANALY M/C 54P005A -P01	INT	4M		I				I				I			IRI	IRI-INVB	131011	B
566	ERU -54 -54P005A	ERU-54P005A-P01	VB. INSP & ANALY M/C 54P005A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131238	B
567	ERU -54 -54P005A	ERU-54P005A-P01	PM INSP OF M/C NO. 54P005A -P01	PMT	4M	I				I				I				RRC	RRC-MRCP	129661	B
568	ERU -54 -54P005A	ERU-54P005A-P01	PM OF 54P005A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130704	B
569	ERU -54 -54P005B	ERU-54P005B-M	STAND BY CHECK LV. MOT 54P005B-M01	PMT	6M			T						T				RRC	RRC-ERCP	138910	B
570	ERU -54 -54P005B	ERU-54P005B-P01	VB. INSP & ANALY M/C 54P005B	INT	4M				I				I				I	IRI	IRI-INVB	130261	B
571	ERU -54 -54P005B	ERU-54P005B-P01	PM INSP OF M/C NO. 54P005B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129662	B
572	ERU -54 -54P005B	ERU-54P005B-P01	PM OF 54P005B -P01	PMT	4M	P				P				P				RRC	RRC-MRCP	130705	B
573	ERU -54 -54P006A	ERU-54P006A-M	STAND BY CHECK LV. MOT 54P006A-M	PMT	1Y								T					RRC	RRC-ERCP	138911	A
574	ERU -54 -54P006A	ERU-54P006A-M	STAND BY CHECK LV. MOT 54P006A-M	PMT	1Y				T									RRC	RRC-ERCP	154230	A
575	ERU -54 -54P006A	ERU-54P006A-P	PM INSP OF M/C NO. 54P006A -P01	PMT	4M	I				I				I				RRC	RRC-MRCP	129663	A
576	ERU -54 -54P006A	ERU-54P006A-P01	VB. INSP & ANALY M/C 54P006A	INT	4M	I				I				I				IRI	IRI-INVB	130262	A
577	ERU -54 -54P006A	ERU-54P006A-P01	VB. INSP & ANALY M/C 54P006A -P01	INT	4M		I				I				I			IRI	IRI-INVB	131012	A
578	ERU -54 -54P006A	ERU-54P006A-P01	VB. INSP & ANALY M/C 54P006A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131239	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
579	ERU -54 -54P006B	ERU-54P006B-M	STAND BY CHECK LV. MOT 54P006B-M	PMT	6M			T						T				RRC	RRC-ERCP	138912	A
580	ERU -54 -54P006B	ERU-54P006B-P	PM INSP OF M/C NO. 54P006B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129664	A
581	ERU -54 -54P006B	ERU-54P006B-P01	VB. INSP & ANALY M/C 54P006B	INT	4M				I				I				I	IRI	IRI-INVB	130263	A
582	ERU -54 -54P006B	ERU-54P006B-P01	PM OF 54P006B -P01	PMT	4M	P				P			P				P	RRC	RRC-MRCP	130707	A
583	ERU -54 -54P007A	ERU-54P007A-M	STAND BY CHECK LV. MOT 54P007A-M01	PMT	1Y								T					RRC	RRC-ERCP	138913	A
584	ERU -54 -54P007A	ERU-54P007A-M	Regreasing Mot BRG of 54P007A-M01	PMT	4M	L				L			L					RRC	RRC-ERCP	139599	A
585	ERU -54 -54P007A	ERU-54P007A-M	STAND BY CHECK LV. MOT 54P007A-M01	PMT	1Y				T									RRC	RRC-ERCP	154231	A
586	ERU -54 -54P007A	ERU-54P007A-P01	VB. INSP & ANALY M/C 54P007A	INT	4M	I				I			I					IRI	IRI-INVB	130264	A
587	ERU -54 -54P007A	ERU-54P007A-P01	VB. INSP & ANALY M/C 54P007A -P01	INT	4M		I				I				I			IRI	IRI-INVB	131013	A
588	ERU -54 -54P007A	ERU-54P007A-P01	VB. INSP & ANALY M/C 54P007A -P01	INT	4M				I			I				I		IRI	IRI-INVB	131240	A
589	ERU -54 -54P007A	ERU-54P007A-P01	PM INSP OF M/C NO. 54P007A -P01	PMT	4M	I				I			I					RRC	RRC-MRCP	129665	A
590	ERU -54 -54P007A	ERU-54P007A-P01	PM OF 54P007A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130708	A
591	ERU -54 -54P007B	ERU-54P007B-M	STAND BY CHECK LV. MOT 54P007B-M01	PMT	6M			T					T					RRC	RRC-ERCP	138914	A
592	ERU -54 -54P007B	ERU-54P007B-M	Regreasing Mot BRG of 54P007B-M01	PMT	4M				L				L				L	RRC	RRC-ERCP	139600	A
593	ERU -54 -54P007B	ERU-54P007B-P01	VB. INSP & ANALY M/C 54P007B	INT	4M				I				I				I	IRI	IRI-INVB	130265	A
594	ERU -54 -54P007B	ERU-54P007B-P01	PM INSP OF M/C NO. 54P007B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129666	A
595	ERU -54 -54P007B	ERU-54P007B-P01	PM OF 54P007B -P01	PMT	4M		P				P			P				RRC	RRC-MRCP	130709	A
596	ERU -54 -54P009A	ERU-54P009A-M	STAND BY CHECK LV. MOT 54P009A-M01	PMT	1Y						T							RRC	RRC-ERCP	162057	B
597	ERU -54 -54P009A	ERU-54P009A-M	STAND BY CHECK LV. MOT 54P009A-M01	PMT	1Y								T					RRC	RRC-ERCP	162064	B
598	ERU -54 -54P009A	ERU-54P009A-P	PM OF ERU-54P009A-P	PMT	4M					P			P				P	RRC	RRC-MRCP	162090	B
599	ERU -54 -54P009A	ERU-54P009A-P	PM INSP OF M/C NO. ERU-54P009A-P	PMT	4M	I					I				I			RRC	RRC-MRCP	162104	B
600	ERU -54 -54P009B	ERU-54P009B-M	STAND BY CHECK LV. MOT 54P009B-M01	PMT	6M						T						T	RRC	RRC-ERCP	162073	B
601	ERU -54 -54P009B	ERU-54P009B-P	PM OF ERU-54P009B-P	PMT	4M	P					P				P			RRC	RRC-MRCP	162091	B
602	ERU -54 -54P009B	ERU-54P009B-P	PM INSP OF M/C NO. ERU-54P009B-P	PMT	4M					I			I				I	RRC	RRC-MRCP	162105	B
603	ERU -54 -54X001	ERU-54X001-P01A	PM INSP OF M/C NO. 54X001 -P01A	PMT	4M				I				I				I	RRC	RRC-MRCP	148886	B
604	ERU -54 -54X001	ERU-54X001-P01B	PM OF 54X001 -P01B	PMT	4M				P				P				P	RRC	RRC-MRCP	146816	B
605	ERU -54 -54X001	ERU-54X001-P01B	PM INSP OF M/C NO. 54X001 -P01B	PMT	4M				I				I				I	RRC	RRC-MRCP	148887	B
606	ERU -57 -AIR	ERU-57-AH-001	PM ALL TYPE OF AIR 57-AH-001 (Large 2,8)	PMT	2M					P		P				P		RRC	RRC-ERCP	138224	A
607	ERU -57 -AIR	ERU-57-AH-001	PM ALL TYPE OF AIR 57-AH-001 (Large 2,8)	PMT	6M		P						P					RRC	RRC-ERCP	138224	A
608	ERU -57 -DVA5701	ERU-57DV001	TEST LINEAR HEAT DETECTOR ERU-57DV001	PMT	6M				P					P				RRC	RRC-ERCP	150067	B
609	ERU -57 -DVA5701	ERU-57DV002	TEST LINEAR HEAT DETECTOR ERU-57DV002	PMT	6M				P					P				RRC	RRC-ERCP	150068	B
610	ERU -57 -DVA5701	ERU-57DV003	TEST LINEAR HEAT DETECTOR ERU-57DV003	PMT	6M				P					P				RRC	RRC-ERCP	150069	B
611	ERU -57 -DVA5701	ERU-57DV004	TEST LINEAR HEAT DETECTOR ERU-57DV004	PMT	6M				P					P				RRC	RRC-ERCP	150070	B
612	ERU -57 -DVA5701	ERU-57DV005	TEST LINEAR HEAT DETECTOR ERU-57DV005	PMT	6M				P					P				RRC	RRC-ERCP	150071	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
613	ERU -57 -DVA5701	ERU-57DV006	TEST LINEAR HEAT DETECTOR ERU-57DV006	PMT	6M			P						P				RRC	RRC-ERCP	150072	B
614	ERU -57 -DVA5701	ERU-57DV007	TEST LINEAR HEAT DETECTOR ERU-57DV007	PMT	6M			P						P				RRC	RRC-ERCP	150073	B
615	ERU -57 -57E006A	ERU-57E006A	PM HEAT EXCHANGER FOR 57E006A	PMT	5Y										R			RRC	RRC-MRCP	155760	C
616	ERU -57 -57E006B	ERU-57E006B	PM HEAT EXCHANGER FOR 57E006B	PMT	5Y										R			RRC	RRC-MRCP	155761	C
617	ERU -57 -57E006C	ERU-57E006C	PM HEAT EXCHANGER FOR 57E006C	PMT	5Y										R			RRC	RRC-MRCP	155762	C
618	ERU -57 -57E006D	ERU-57E006D	PM HEAT EXCHANGER FOR 57E006D	PMT	5Y										R			RRC	RRC-MRCP	155763	C
619	ERU -57 -57E006E	ERU-57E006E	PM HEAT EXCHANGER FOR 57E006E	PMT	5Y										R			RRC	RRC-MRCP	155764	C
620	ERU -57 -57E006F	ERU-57E006F	PM HEAT EXCHANGER FOR 57E006F	PMT	5Y										R			RRC	RRC-MRCP	155765	C
621	ERU -57 -57E006G	ERU-57E006G	PM HEAT EXCHANGER FOR 57E006G	PMT	5Y										R			RRC	RRC-MRCP	155766	C
622	ERU -57 -57E006H	ERU-57E006H	PM HEAT EXCHANGER FOR 57E006H	PMT	5Y										R			RRC	RRC-MRCP	155767	C
623	ERU -57 -57H001	ERU-57H001-HD1	Over Head Crane Inspection By	INT	6M				I						I			IRI	IRI-INSS	130562	C
624	ERU -57 -57H001	ERU-57H001-HD1	PM OF 57H001	PMT	6M	P						P						RRC	RRC-MRCP	146806	C
625	ERU -57 -57H001	ERU-57H001-HD1	PM INSP OF M/C NO. 57H001	PMT	4M		I			I				I				RRC	RRC-MRCP	148877	C
626	ERU -57 -57K001	ERU-57K001-K01	PM COMPRESSOR NO. 57K001 -K01	PMT	1Y							P						CRE	CRE-OHIP	131153	B
627	ERU -57 -57K001	ERU-57K001-K01	OIL INSP & ANALYSIS M/C 57K001 -K01	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INDL	130024	B
628	ERU -57 -57K001	ERU-57K001-M	STAND BY CHECK MV. MOT 57K001-K01	PMT	6M		T					T						RRC	RRC-ERCP	138915	B
629	ERU -57 -57K001	ERU-57K001-M	Regreasing Mot BRG of 57K001-M01	PMT	4M	L				L				L				RRC	RRC-ERCP	139404	B
630	ERU -57 -57K001	ERU-57K001-P01	VB. INSP & ANALY M/C 57K001 -P01	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	131040	B
631	ERU -57 -57K001	ERU-57K001-P01	PM INSP OF M/C NO. 57K001 -P01	PMT	4M		I			I				I				RRC	RRC-MRCP	129719	B
632	ERU -57 -57K001	ERU-57K001-PLC	INSPECT PLC SYSTEM	PMT	3M		I				I		I			I		CCS	CCS-SYS	246451	A
633	ERU -57 -57K001	ERU-57K001-PLC	BACKUP PLC SYSTEM	PMT	6M		I						I					CCS	CCS-SYS	246452	A
634	ERU -57 -57K002	ERU-57K002-K01	PM COMPRESSOR NO. 57K002 -K01	PMT	1Y						P							CRE	CRE-OHIP	129718	B
635	ERU -57 -57K002	ERU-57K002-K01	OIL INSP & ANALYSIS M/C 57K002 -K01	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INDL	130025	B
636	ERU -57 -57K002	ERU-57K002-M	STAND BY CHECK MV. MOT 57K002-K01	PMT	6M			T						T				RRC	RRC-ERCP	138916	B
637	ERU -57 -57K002	ERU-57K002-M	Regreasing Mot BRG of 57K002-M01	PMT	4M	L				L				L				RRC	RRC-ERCP	139405	B
638	ERU -57 -57K002	ERU-57K002-P01	VB. INSP & ANALY M/C 57K002 -P01	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130319	B
639	ERU -57 -57K002	ERU-57K002-P01	PM INSP OF M/C NO. 57K002 -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129720	B
640	ERU -57 -57K002	ERU-57K002-PLC	INSPECT PLC SYSTEM	PMT	3M		I			I			I			I		CCS	CCS-SYS	246453	A
641	ERU -57 -57K002	ERU-57K002-PLC	BACKUP PLC SYSTEM	PMT	6M		I						I					CCS	CCS-SYS	246454	A
642	ERU -57 -57P001A	ERU-57P001A-M	STAND BY CHECK MV. MOT 57P001A-M01	PMT	1Y								T					RRC	RRC-ERCP	138917	C
643	ERU -57 -57P001A	ERU-57P001A-M	Regreasing Mot BRG of 57P001A-M01	PMT	4M	L				L				L				RRC	RRC-ERCP	139406	C
644	ERU -57 -57P001A	ERU-57P001A-M	STAND BY CHECK MV. MOT 57P001A-M01	PMT	1Y				T									RRC	RRC-ERCP	154232	C
645	ERU -57 -57P001A	ERU-57P001A-P01	VB. INSP & ANALY M/C 57P001A	INT	4M	I				I				I				IRI	IRI-INVB	130320	C
646	ERU -57 -57P001A	ERU-57P001A-P01	VB. INSP & ANALY M/C 57P001A -P01	INT	4M		I				I				I			IRI	IRI-INVB	131041	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
647	ERU -57 -57P001A	ERU-57P001A-P01	VB. INSP & ANALY M/C 57P001A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131268	C
648	ERU -57 -57P001A	ERU-57P001A-P01	PM INSP OF M/C NO. 57P001A -P01	PMT	4M		I				I				I			RRC	RRC-MRCP	129721	C
649	ERU -57 -57P001A	ERU-57P001A-P01	PM OF 57P001A -P01	PMT	4M			P				P				P		RRC	RRC-MRCP	130743	C
650	ERU -57 -57P001B	ERU-57P001B-M	STAND BY CHECK MV. MOT 57P001B-M01	PMT	6M		T						T					RRC	RRC-ERCP	138918	C
651	ERU -57 -57P001B	ERU-57P001B-M	Regreasing Mot BRG of 57P001B-M01	PMT	4M	L				L				L				RRC	RRC-ERCP	139407	C
652	ERU -57 -57P001B	ERU-57P001B-P01	VB. INSP & ANALY M/C 57P001B	INT	4M	I				I				I				IRI	IRI-INVB	130321	C
653	ERU -57 -57P001B	ERU-57P001B-P01	VB. INSP & ANALY M/C 57P001B -P01	INT	4M		I				I				I			IRI	IRI-INVB	131042	C
654	ERU -57 -57P001B	ERU-57P001B-P01	VB. INSP & ANALY M/C 57P001B -P01	INT	4M			I				I				I		IRI	IRI-INVB	131269	C
655	ERU -57 -57P001B	ERU-57P001B-P01	PM INSP OF M/C NO. 57P001B -P01	PMT	4M		I				I				I			RRC	RRC-MRCP	129722	C
656	ERU -57 -57P001B	ERU-57P001B-P01	PM OF 57P001B -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130744	C
657	ERU -57 -57P001C	ERU-57P001C-M	STAND BY CHECK MV. MOT 57P001C-M01	PMT	6M		T						T					RRC	RRC-ERCP	138919	C
658	ERU -57 -57P001C	ERU-57P001C-M	Regreasing Mot BRG of 57P001C-M01	PMT	4M				L				L				L	RRC	RRC-ERCP	139408	C
659	ERU -57 -57P001C	ERU-57P001C-P01	VB. INSP & ANALY M/C 57P001C	INT	4M				I				I				I	IRI	IRI-INVB	130322	C
660	ERU -57 -57P001C	ERU-57P001C-P01	PM INSP OF M/C NO. 57P001C -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129723	C
661	ERU -57 -57P001C	ERU-57P001C-P01	PM OF 57P001C -P01	PMT	4M		P				P				P			RRC	RRC-MRCP	130745	C
662	ERU -57 -57P002A	ERU-57P002A-M	STAND BY CHECK MV. MOT 57P002A-M01	PMT	1Y								T					RRC	RRC-ERCP	138920	C
663	ERU -57 -57P002A	ERU-57P002A-M	Regreasing Mot BRG of 57P002A-M01	PMT	4M	L				L				L				RRC	RRC-ERCP	139409	C
664	ERU -57 -57P002A	ERU-57P002A-M	STAND BY CHECK MV. MOT 57P002A-M01	PMT	1Y				T									RRC	RRC-ERCP	154233	C
665	ERU -57 -57P002A	ERU-57P002A-P01	VB. INSP & ANALY M/C 57P002A	INT	4M	I				I				I				IRI	IRI-INVB	130323	C
666	ERU -57 -57P002A	ERU-57P002A-P01	VB. INSP & ANALY M/C 57P002A -P01	INT	4M		I				I				I			IRI	IRI-INVB	131043	C
667	ERU -57 -57P002A	ERU-57P002A-P01	VB. INSP & ANALY M/C 57P002A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131270	C
668	ERU -57 -57P002A	ERU-57P002A-P01	PM INSP OF M/C NO. 57P002A -P01	PMT	4M		I				I				I			RRC	RRC-MRCP	129724	C
669	ERU -57 -57P002A	ERU-57P002A-P01	PM OF 57P002A -P01	PMT	4M	P				P				P				RRC	RRC-MRCP	130746	C
670	ERU -57 -57P002B	ERU-57P002B-M	STAND BY CHECK MV. MOT 57P002B-M01	PMT	6M		T						T					RRC	RRC-ERCP	138921	C
671	ERU -57 -57P002B	ERU-57P002B-M	Regreasing Mot BRG of 57P002B-M01	PMT	4M	L				L				L				RRC	RRC-ERCP	139410	C
672	ERU -57 -57P002B	ERU-57P002B-P01	VB. INSP & ANALY M/C 57P002B	INT	4M	I				I				I				IRI	IRI-INVB	130324	C
673	ERU -57 -57P002B	ERU-57P002B-P01	VB. INSP & ANALY M/C 57P002B -P01	INT	4M		I				I				I			IRI	IRI-INVB	131044	C
674	ERU -57 -57P002B	ERU-57P002B-P01	VB. INSP & ANALY M/C 57P002B -P01	INT	4M			I				I				I		IRI	IRI-INVB	131271	C
675	ERU -57 -57P002B	ERU-57P002B-P01	PM INSP OF M/C NO. 57P002B -P01	PMT	4M		I				I				I			RRC	RRC-MRCP	129725	C
676	ERU -57 -57P002B	ERU-57P002B-P01	PM OF 57P002B -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130747	C
677	ERU -57 -57P002C	ERU-57P002C-M	STAND BY CHECK MV. MOT 57P002C-M01	PMT	6M			T					T					RRC	RRC-ERCP	138922	C
678	ERU -57 -57P002C	ERU-57P002C-M	Regreasing Mot BRG of 57P002C-M01	PMT	4M				L				L				L	RRC	RRC-ERCP	139411	C
679	ERU -57 -57P002C	ERU-57P002C-P01	VB. INSP & ANALY M/C 57P002C	INT	4M				I				I				I	IRI	IRI-INVB	130325	C
680	ERU -57 -57P002C	ERU-57P002C-P01	PM INSP OF M/C NO. 57P002C -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129726	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
681	ERU -57 -57P002C	ERU-57P002C-P01	PM OF 57P002C -P01	PMT	4M		P				P				P			RRC	RRC-MRCP	130748	C
682	ERU -57 -57P003A	ERU-57P003A-M	STAND BY CHECK LV. MOT 57P003A-M01	PMT	1Y								T					RRC	RRC-ERCP	138923	A
683	ERU -57 -57P003A	ERU-57P003A-M	Regreasing Mot BRG of 57P003A-M01	PMT	4M	L				L				L				RRC	RRC-ERCP	139637	A
684	ERU -57 -57P003A	ERU-57P003A-M	STAND BY CHECK LV. MOT 57P003A-M01	PMT	1Y				T									RRC	RRC-ERCP	154234	A
685	ERU -57 -57P003A	ERU-57P003A-P01	VB. INSP & ANALY M/C 57P003A	INT	4M	I				I				I				IRI	IRI-INVB	130326	A
686	ERU -57 -57P003A	ERU-57P003A-P01	VB. INSP & ANALY M/C 57P003A -P01	INT	4M		I				I				I			IRI	IRI-INVB	131045	A
687	ERU -57 -57P003A	ERU-57P003A-P01	VB. INSP & ANALY M/C 57P003A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131272	A
688	ERU -57 -57P003A	ERU-57P003A-P01	PM INSP OF M/C NO. 57P003A -P01	PMT	4M		I				I				I			RRC	RRC-MRCP	129727	A
689	ERU -57 -57P003A	ERU-57P003A-P01	PM OF 57P003A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130749	A
690	ERU -57 -57P003B	ERU-57P003B-M	STAND BY CHECK LV. MOT 57P003B-M01	PMT	6M			T						T				RRC	RRC-ERCP	138924	A
691	ERU -57 -57P003B	ERU-57P003B-M	Regreasing Mot BRG of 57P003B-M01	PMT	4M				L				L				L	RRC	RRC-ERCP	139638	A
692	ERU -57 -57P003B	ERU-57P003B-P01	VB. INSP & ANALY M/C 57P003B	INT	4M				I				I				I	IRI	IRI-INVB	130327	A
693	ERU -57 -57P003B	ERU-57P003B-P01	PM INSP OF M/C NO. 57P003B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129728	A
694	ERU -57 -57P003B	ERU-57P003B-P01	PM OF 57P003B -P01	PMT	4M		P				P				P			RRC	RRC-MRCP	130750	A
695	ERU -57 -57P004A	ERU-57P004A-M	STAND BY CHECK MV. MOT 57P004A-M01	PMT	1Y								T					RRC	RRC-ERCP	138925	C
696	ERU -57 -57P004A	ERU-57P004A-M	Regreasing Mot BRG of 57P004A-M01	PMT	4M	L				L				L				RRC	RRC-ERCP	139412	C
697	ERU -57 -57P004A	ERU-57P004A-M	STAND BY CHECK MV. MOT 57P004A-M01	PMT	1Y				T									RRC	RRC-ERCP	154235	C
698	ERU -57 -57P004A	ERU-57P004A-P01	VB. INSP & ANALY M/C 57P004A	INT	4M	I				I				I				IRI	IRI-INVB	130328	C
699	ERU -57 -57P004A	ERU-57P004A-P01	VB. INSP & ANALY M/C 57P004A -P01	INT	4M		I				I				I			IRI	IRI-INVB	131046	C
700	ERU -57 -57P004A	ERU-57P004A-P01	VB. INSP & ANALY M/C 57P004A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131273	C
701	ERU -57 -57P004A	ERU-57P004A-P01	PM INSP OF M/C NO. 57P004A -P01	PMT	4M		I				I				I			RRC	RRC-MRCP	129729	C
702	ERU -57 -57P004A	ERU-57P004A-P01	PM OF 57P004A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130751	C
703	ERU -57 -57P004B	ERU-57P004B-M	STAND BY CHECK MV. MOT 57P004B-M01	PMT	6M			T						T				RRC	RRC-ERCP	138926	C
704	ERU -57 -57P004B	ERU-57P004B-M	Regreasing Mot BRG of 57P004B-M01	PMT	4M				L				L				L	RRC	RRC-ERCP	139413	C
705	ERU -57 -57P004B	ERU-57P004B-P01	VB. INSP & ANALY M/C 57P004B	INT	4M	I				I				I				IRI	IRI-INVB	130329	C
706	ERU -57 -57P004B	ERU-57P004B-P01	VB. INSP & ANALY M/C 57P004B -P01	INT	4M		I				I				I			IRI	IRI-INVB	145569	C
707	ERU -57 -57P004B	ERU-57P004B-P01	VB. INSP & ANALY M/C 57P004B -P01	INT	4M			I				I				I		IRI	IRI-INVB	145570	C
708	ERU -57 -57P004B	ERU-57P004B-P01	PM INSP OF M/C NO. 57P004B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129730	C
709	ERU -57 -57P004B	ERU-57P004B-P01	PM OF 57P004B -P01	PMT	4M	P				P				P				RRC	RRC-MRCP	130752	C
710	ERU -57 -57P004C	ERU-57P004C-K01	FUNCTION TEST TURBINE NO.57PK004C -K01	PMT	1Y		F											CRE	CRE-OHIP	155808	B
711	ERU -57 -57P004C	ERU-57P004C-K01	PM TURBINE DRIVE PUMP NO.57PK004C -K01	PMT	1Y		P											CRE	CRE-OHIP	155828	B
712	ERU -57 -57P004C	ERU-57P004C-P01	VB. INSP & ANALY M/C 57P004C	INT	4M				I				I				I	IRI	IRI-INVB	130330	B
713	ERU -57 -57P004C	ERU-57P004C-P01	PM INSP OF M/C NO. 57P004C -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129731	B
714	ERU -57 -57P004C	ERU-57P004C-P01	PM OF 57P004C -P01	PMT	4M		P				P				P			RRC	RRC-MRCP	130754	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
715	ERU -57 -57X002	ERU-57X002A-P01A	PM INSP OF M/C NO. 57X002 -P01A	PMT	4M			I				I				I		RRC	RRC-MRCP	148880	B
716	ERU -57 -57X002	ERU-57X002A-P01B	PM INSP OF M/C NO. 57X002 -P01B	PMT	4M			I				I				I		RRC	RRC-MRCP	148881	B
717	ERU -57 -57X002	ERU-57X002B-P01A	PM INSP OF M/C NO. 57X002 -P01A	PMT	4M			I				I				I		RRC	RRC-MRCP	148882	B
718	ERU -57 -57X002	ERU-57X002B-P01B	PM INSP OF M/C NO. 57X002 -P01B	PMT	4M			I				I				I		RRC	RRC-MRCP	148883	B
719	ERU -57 -57X002	ERU-57X002C-P01A	PM INSP OF M/C NO. 57X002 -P01A	PMT	4M			I				I				I		RRC	RRC-MRCP	148884	B
720	ERU -57 -57X002	ERU-57X002C-P01B	PM INSP OF M/C NO. 57X002 -P01B	PMT	4M			I				I				I		RRC	RRC-MRCP	148885	B
721	ERU -58 -AIR	ERU-58-AH-001	PM ALL TYPE OF AIR 58-AH-001 (Large 2,8)	PMT	2M				P		P				P		P	RRC	RRC-ERCP	138225	A
722	ERU -58 -AIR	ERU-58-AH-001	PM ALL TYPE OF AIR 58-AH-001 (Large 2,8)	PMT	6M		P						P					RRC	RRC-ERCP	138225	A
723	ERU -58 -DVA5801	ERU-58DV001	TEST LINEAR HEAT DETECTOR ERU-58DV001	PMT	6M			P						P				RRC	RRC-ERCP	150074	B
724	ERU -58 -DVA5801	ERU-58DV002	TEST LINEAR HEAT DETECTOR ERU-58DV002	PMT	6M			P						P				RRC	RRC-ERCP	150075	B
725	ERU -58 -DVA5801	ERU-58DV003	TEST LINEAR HEAT DETECTOR ERU-58DV003	PMT	6M			P						P				RRC	RRC-ERCP	150076	B
726	ERU -58 -DVA5801	ERU-58DV004	TEST LINEAR HEAT DETECTOR ERU-58DV004	PMT	6M			P						P				RRC	RRC-ERCP	150077	B
727	ERU -58 -58H001	ERU-58H001-H01	Over Head Crane Inspection By	INT	1Y				I									IRI	IRI-INSS	130563	C
728	ERU -58 -58H001	ERU-58H001-H01	PM OF 58H001	PMT	6M	P						P						RRC	RRC-MRCP	146804	C
729	ERU -58 -58H001	ERU-58H001-H01	PM INSP OF M/C NO. 58H001	PMT	4M		I				I				I			RRC	RRC-MRCP	148875	C
730	ERU -58 -58H002	ERU-58H002-H01	Over Head Crane Inspection By	INT	6M				I						I			IRI	IRI-INSS	130564	C
731	ERU -58 -58H002	ERU-58H002-H01	PM OF 58H002	PMT	6M	P						P						RRC	RRC-MRCP	146807	C
732	ERU -58 -58H002	ERU-58H002-H01	PM INSP OF M/C NO. 58H002	PMT	4M		I				I				I			RRC	RRC-MRCP	148878	C
733	ERU -58 -58H003	ERU-58H003-H01	Over Head Crane Inspection By	INT	1Y				I									IRI	IRI-INSS	130565	C
734	ERU -58 -58H003	ERU-58H003-H01	PM OF 58H003	PMT	6M	P						P						RRC	RRC-MRCP	146808	C
735	ERU -58 -58H003	ERU-58H003-H01	PM INSP OF M/C NO. 58H003	PMT	4M		I				I				I			RRC	RRC-MRCP	148879	C
736	ERU -58 -58K001	ERU-58K001-K01	PM COMPRESSOR NO. 58K001 -K01	PMT	1Y					I								CRE	CRE-OHIP	129953	A
737	ERU -58 -58K001	ERU-58K001-K01	OIL INSP & ANALYSIS M/C 58K001 -K01	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INDL	130076	A
738	ERU -58 -58K001	ERU-58K001-M	STAND BY CHECK MV. MOT 58K001-K01	PMT	6M			T						T				RRC	RRC-ERCP	138927	A
739	ERU -58 -58K001	ERU-58K001-P01	PM INSP OF M/C NO.ERU-58K001 -P01	PMT	4M	I				I				I				RRC	RRC-MRCP	155813	A
740	ERU -58 -58K001	ERU-58K001-P02	PM INSP OF M/C NO.ERU-58K001 -P02	PMT	4M	I				I				I				RRC	RRC-MRCP	155814	A
741	ERU -58 -58K101	ERU-58K101-K01	PM COMPRESSOR NO. 58K101 -K01	PMT	1Y								I					CRE	CRE-OHIP	129954	B
742	ERU -58 -58K101	ERU-58K101-PLC	INSPECT PLC SYSTEM	PMT	3M		I			I			I			I		CCS	CCS-SYS	246455	A
743	ERU -58 -58K101	ERU-58K101-PLC	BACKUP PLC SYSTEM	PMT	6M		I						I					CCS	CCS-SYS	246456	A
744	ERU -58 -58K401	ERU-58K401-K01	PM COMPRESSOR NO. 58K401 -K01	PMT	1Y				I									CRE	CRE-OHIP	129955	A
745	ERU -58 -58K401	ERU-58K401-K01	OIL INSP & ANALYSIS M/C 58K401 -K01	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INDL	130078	A
746	ERU -58 -58K401	ERU-58K401-M	STAND BY CHECK MV. MOT 58K401-K01	PMT	6M			T						T				RRC	RRC-ERCP	138928	A
747	ERU -58 -58K401	ERU-58K401-P01	PM INSP OF M/C NO.ERU-58K401 -P01	PMT	4M				I				I					RRC	RRC-MRCP	155815	A
748	ERU -58 -58K401	ERU-58K401-P02	PM INSP OF M/C NO.ERU-58K401 -P02	PMT	4M				I				I					RRC	RRC-MRCP	155816	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
749	ERU -58 -58K501	ERU-58K501-K01	PM COMPRESSOR NO. 58K501 -K01	PMT	1Y								I					CRE	CRE-OHIP	129956	A
750	ERU -58 -58K501	ERU-58K501-K01	PM;OVERHAUL FOR 58K501	PMT	5Y									P				CRE	CRE-OHIP	154099	A
751	ERU -58 -58K501	ERU-58K501-K01	OIL INSP & ANALYSIS M/C 58K501 -K01	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INDL	130079	A
752	ERU -58 -58K501	ERU-58K501-M	STAND BY CHECK MV. MOT 58K501-K01	PMT	6M			T						T				RRC	RRC-ERCP	138929	A
753	ERU -58 -58K501	ERU-58K501-P01	PM INSP OF M/C NO.ERU-58K501 -P01	PMT	4M			I				I			I			RRC	RRC-MRCP	155817	A
754	ERU -58 -58K501	ERU-58K501-P02	PM INSP OF M/C NO.ERU-58K501 -P02	PMT	4M			I				I			I			RRC	RRC-MRCP	155818	A
755	ERU -58 -58P001A	ERU-58P001A-M	STAND BY CHECK LV. MOT 58P001A-M01	PMT	1Y								T					RRC	RRC-ERCP	138930	B
756	ERU -58 -58P001A	ERU-58P001A-M	STAND BY CHECK LV. MOT 58P001A-M01	PMT	1Y				T									RRC	RRC-ERCP	154236	B
757	ERU -58 -58P001A	ERU-58P001A-P01	VB. INSP & ANALY M/C 58P001A	INT	4M	I				I				I				IRI	IRI-INVB	130331	B
758	ERU -58 -58P001A	ERU-58P001A-P01	VB. INSP & ANALY M/C 58P001A -P01	INT	4M		I				I				I			IRI	IRI-INVB	131047	B
759	ERU -58 -58P001A	ERU-58P001A-P01	VB. INSP & ANALY M/C 58P001A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131274	B
760	ERU -58 -58P001A	ERU-58P001A-P01	PM INSP OF M/C NO. 58P001A -P01	PMT	4M		I				I				I			RRC	RRC-MRCP	129732	B
761	ERU -58 -58P001A	ERU-58P001A-P01	PM OF 58P001A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130755	B
762	ERU -58 -58P001B	ERU-58P001B-M	STAND BY CHECK LV. MOT 58P001B-M01	PMT	6M			T						T				RRC	RRC-ERCP	138931	B
763	ERU -58 -58P001B	ERU-58P001B-P01	VB. INSP & ANALY M/C 58P001B -P02	INT	4M				I				I				I	IRI	IRI-INVB	130332	B
764	ERU -58 -58P001B	ERU-58P001B-P01	PM INSP OF M/C NO. 58P001B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129733	B
765	ERU -58 -58P001B	ERU-58P001B-P01	PM OF 58P001B -P01	PMT	4M			P				P				P		RRC	RRC-MRCP	130756	B
766	ERU -58 -58P002A	ERU-58P002A-M	STAND BY CHECK LV. MOT 58P002A-M01	PMT	1Y								T					RRC	RRC-ERCP	138932	C
767	ERU -58 -58P002A	ERU-58P002A-M	STAND BY CHECK LV. MOT 58P002A-M01	PMT	1Y				T									RRC	RRC-ERCP	154237	C
768	ERU -58 -58P002A	ERU-58P002A-P01	VB. INSP & ANALY M/C 58P002A	INT	4M	I				I				I				IRI	IRI-INVB	130333	C
769	ERU -58 -58P002A	ERU-58P002A-P01	VB. INSP & ANALY M/C 58P002A -P01	INT	4M		I				I				I			IRI	IRI-INVB	131048	C
770	ERU -58 -58P002A	ERU-58P002A-P01	VB. INSP & ANALY M/C 58P002A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131275	C
771	ERU -58 -58P002A	ERU-58P002A-P01	PM INSP OF M/C NO. 58P002A -P01	PMT	4M			I				I				I		RRC	RRC-MRCP	129734	C
772	ERU -58 -58P002A	ERU-58P002A-P01	PM OF 58P002A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130757	C
773	ERU -58 -58P002B	ERU-58P002B-M	STAND BY CHECK LV. MOT 58P002B-M01	PMT	6M			T						T				RRC	RRC-ERCP	138933	C
774	ERU -58 -58P002B	ERU-58P002B-P01	VB. INSP & ANALY M/C 58P002B	INT	4M				I				I				I	IRI	IRI-INVB	130334	C
775	ERU -58 -58P002B	ERU-58P002B-P01	PM INSP OF M/C NO. 58P002B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129735	C
776	ERU -58 -58P002B	ERU-58P002B-P01	PM OF 58P002B -P01	PMT	4M			P				P				P		RRC	RRC-MRCP	130758	C
777	ERU -58 -58P004A	ERU-58P004A-M	STAND BY CHECK LV. MOT 58P004A-M01	PMT	1Y								T					RRC	RRC-ERCP	138934	C
778	ERU -58 -58P004A	ERU-58P004A-M	STAND BY CHECK LV. MOT 58P004A-M01	PMT	1Y				T									RRC	RRC-ERCP	154238	C
779	ERU -58 -58P004A	ERU-58P004A-P01	VB. INSP & ANALY M/C 58P004A	INT	4M	I				I				I				IRI	IRI-INVB	130335	C
780	ERU -58 -58P004A	ERU-58P004A-P01	VB. INSP & ANALY M/C 58P004A -P01	INT	4M		I				I				I			IRI	IRI-INVB	131049	C
781	ERU -58 -58P004A	ERU-58P004A-P01	VB. INSP & ANALY M/C 58P004A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131276	C
782	ERU -58 -58P004A	ERU-58P004A-P01	PM INSP OF M/C NO. 58P004A -P01	PMT	4M			I				I				I		RRC	RRC-MRCP	129736	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
783	ERU -58 -58P004A	ERU-58P004A-P01	PM OF 58P004A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130759	C
784	ERU -58 -58P004B	ERU-58P004B-M	STAND BY CHECK LV. MOT 58P004B-M01	PMT	6M			T						T				RRC	RRC-ERCP	138935	C
785	ERU -58 -58P004B	ERU-58P004B-P01	VB. INSP & ANALY M/C 58P004B -P02	INT	4M				I				I				I	IRI	IRI-INVB	130336	C
786	ERU -58 -58P004B	ERU-58P004B-P01	PM INSP OF M/C NO. 58P004B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129737	C
787	ERU -58 -58P004B	ERU-58P004B-P01	PM OF 58P004B -P01	PMT	4M			P				P			P			RRC	RRC-MRCP	130760	C
788	ERU -58 -58P006A	ERU-58P006A-M	STAND BY CHECK LV. MOT 58P006A-M01	PMT	1Y								T					RRC	RRC-ERCP	138936	B
789	ERU -58 -58P006A	ERU-58P006A-M	STAND BY CHECK LV. MOT 58P006A-M01	PMT	1Y					T								RRC	RRC-ERCP	154239	B
790	ERU -58 -58P006A	ERU-58P006A-P01	VB. INSP & ANALY M/C 58P006A	INT	4M	I					I			I				IRI	IRI-INVB	130337	B
791	ERU -58 -58P006A	ERU-58P006A-P01	VB. INSP & ANALY M/C 58P006A -P01	INT	4M		I					I			I			IRI	IRI-INVB	131050	B
792	ERU -58 -58P006A	ERU-58P006A-P01	VB. INSP & ANALY M/C 58P006A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131277	B
793	ERU -58 -58P006A	ERU-58P006A-P01	PM INSP OF M/C NO. 58P006A -P01	PMT	4M			I				I				I		RRC	RRC-MRCP	129738	B
794	ERU -58 -58P006A	ERU-58P006A-P01	PM OF 58P006A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130761	B
795	ERU -58 -58P006B	ERU-58P006B-M	STAND BY CHECK LV. MOT 58P006B-M01	PMT	6M			T						T				RRC	RRC-ERCP	138937	B
796	ERU -58 -58P006B	ERU-58P006B-P01	VB. INSP & ANALY M/C 58P006B	INT	4M				I				I				I	IRI	IRI-INVB	130338	B
797	ERU -58 -58P006B	ERU-58P006B-P01	PM INSP OF M/C NO. 58P006B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129739	B
798	ERU -58 -58P006B	ERU-58P006B-P01	PM OF 58P006B -P01	PMT	4M			P				P			P			RRC	RRC-MRCP	130762	B
799	ERU -58 -58P201A	ERU-58P201A-M	STAND BY CHECK LV. MOT 58P201A-M01	PMT	1Y								T					RRC	RRC-ERCP	138938	C
800	ERU -58 -58P201A	ERU-58P201A-M	STAND BY CHECK LV. MOT 58P201A-M01	PMT	1Y					T								RRC	RRC-ERCP	154240	C
801	ERU -58 -58P201A	ERU-58P201A-P01	VB. INSP & ANALY M/C 58P201A	INT	4M	I					I			I				IRI	IRI-INVB	130339	C
802	ERU -58 -58P201A	ERU-58P201A-P01	VB. INSP & ANALY M/C 58P201A -P01	INT	4M		I					I			I			IRI	IRI-INVB	131051	C
803	ERU -58 -58P201A	ERU-58P201A-P01	VB. INSP & ANALY M/C 58P201A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131278	C
804	ERU -58 -58P201A	ERU-58P201A-P01	PM INSP OF M/C NO. 58P201A -P01	PMT	4M			I				I				I		RRC	RRC-MRCP	129740	C
805	ERU -58 -58P201A	ERU-58P201A-P01	PM OF 58P201A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130763	C
806	ERU -58 -58P201B	ERU-58P201B-M	STAND BY CHECK LV. MOT 58P201B-M01	PMT	6M			T						T				RRC	RRC-ERCP	138939	C
807	ERU -58 -58P201B	ERU-58P201B-P01	VB. INSP & ANALY M/C 58P201B -P02	INT	4M				I				I				I	IRI	IRI-INVB	130340	C
808	ERU -58 -58P201B	ERU-58P201B-P01	PM INSP OF M/C NO. 58P201B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129741	C
809	ERU -58 -58P201B	ERU-58P201B-P01	PM OF 58P201B -P01	PMT	4M			P				P			P			RRC	RRC-MRCP	130764	C
810	ERU -58 -58P401A	ERU-58P401A-M	STAND BY CHECK LV. MOT 58P401A-M01	PMT	1Y								T					RRC	RRC-ERCP	138940	A
811	ERU -58 -58P401A	ERU-58P401A-M	Regreasing Mot BRG of 58P401A-M01	PMT	4M	L				L				L				RRC	RRC-ERCP	139657	A
812	ERU -58 -58P401A	ERU-58P401A-M	STAND BY CHECK LV. MOT 58P401A-M01	PMT	1Y				T									RRC	RRC-ERCP	154241	A
813	ERU -58 -58P401A	ERU-58P401A-P01	VB. INSP & ANALY M/C 58P401A	INT	4M	I				I			I					IRI	IRI-INVB	130341	A
814	ERU -58 -58P401A	ERU-58P401A-P01	VB. INSP & ANALY M/C 58P401A -P01	INT	4M		I				I			I				IRI	IRI-INVB	131052	A
815	ERU -58 -58P401A	ERU-58P401A-P01	VB. INSP & ANALY M/C 58P401A -P01	INT	4M			I				I			I			IRI	IRI-INVB	131279	A
816	ERU -58 -58P401A	ERU-58P401A-P01	PM INSP OF M/C NO. 58P401A -P01	PMT	4M			I				I			I			RRC	RRC-MRCP	129742	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
817	ERU -58 -58P401A	ERU-58P401A-P01	PM OF 58P401A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130765	A
818	ERU -58 -58P401B	ERU-58P401B-M	STAND BY CHECK LV. MOT 58P401B-M01	PMT	6M			T						T				RRC	RRC-ERCP	138941	A
819	ERU -58 -58P401B	ERU-58P401B-M	Regreasing Mot BRG of 58P401B-M01	PMT	4M				L			L				L		RRC	RRC-ERCP	139658	A
820	ERU -58 -58P401B	ERU-58P401B-P01	VB. INSP & ANALY M/C 58P401B	INT	4M				I			I		I		I		IRI	IRI-INVB	130342	A
821	ERU -58 -58P401B	ERU-58P401B-P01	PM INSP OF M/C NO. 58P401B -P01	PMT	4M				I			I		I		I		RRC	RRC-MRCP	129743	A
822	ERU -58 -58P401B	ERU-58P401B-P01	PM OF 58P401B -P01	PMT	4M			P				P				P		RRC	RRC-MRCP	130766	A
823	ERU -58 -58T001	ERU-58T001-T01	Storage tank inspection	PMT	5Y					I								IRI	IRI-INRC	163741	B
824	ERU -58 -58X001	ERU-58X001-P01A	PM OF CRANK CASE	PMT	6M			P						P				RRC	RRC-MRCP	146796	B
825	ERU -58 -58X001	ERU-58X001-P01A	PM OF HYDRAULIC FLUID	PMT	6M			P						P				RRC	RRC-MRCP	146797	B
826	ERU -58 -58X001	ERU-58X001-P01A	REGREASING BRG OF 58X001-P01A	PMT	4M	L				L				L				RRC	RRC-MRCP	148871	B
827	ERU -58 -58X001	ERU-58X001-P01B	PM OF CRANK CASE	PMT	6M			P						P				RRC	RRC-MRCP	146798	B
828	ERU -58 -58X001	ERU-58X001-P01B	PM OF HYDRAULIC FLUID	PMT	6M			P						P				RRC	RRC-MRCP	146799	B
829	ERU -58 -58X001	ERU-58X001-P01B	REGREASING BRG OF 58X001-P01B	PMT	4M	L				L				L				RRC	RRC-MRCP	148872	B
830	ERU -58 -58X003	ERU-58X003-P01A	PM OF CRANK CASE	PMT	6M			P						P				RRC	RRC-MRCP	146800	B
831	ERU -58 -58X003	ERU-58X003-P01A	PM OF HYDRAULIC FLUID	PMT	6M			P						P				RRC	RRC-MRCP	146801	B
832	ERU -58 -58X003	ERU-58X003-P01A	REGREASING BRG OF 58X003-P01A	PMT	4M		L				L				L			RRC	RRC-MRCP	148873	B
833	ERU -58 -58X003	ERU-58X003-P01B	PM OF CRANK CASE	PMT	6M			P						P				RRC	RRC-MRCP	146802	B
834	ERU -58 -58X003	ERU-58X003-P01B	PM OF HYDRAULIC FLUID	PMT	6M			P						P				RRC	RRC-MRCP	146803	B
835	ERU -58 -58X003	ERU-58X003-P01B	REGREASING BRG OF 58X003-P01B	PMT	4M		L				L				L			RRC	RRC-MRCP	148874	B
836	ERU -78 -78P009A	ERU-78P009A-M	STAND BY CHECK LV. MOT 78P009A-M01	PMT	1Y							T						RRC	RRC-ERCP	138942	C
837	ERU -78 -78P009A	ERU-78P009A-M	STAND BY CHECK LV. MOT 78P009A-M01	PMT	1Y					T								RRC	RRC-ERCP	154242	C
838	ERU -78 -78P009A	ERU-78P009A-P01	VB. INSP & ANALY M/C 78P009A-P01	INT	4M	I				I				I				IRI	IRI-INVB	150229	C
839	ERU -78 -78P009A	ERU-78P009A-P01	VB. INSP & ANALY M/C 78P009A-P01	INT	4M		I				I				I			IRI	IRI-INVB	150230	C
840	ERU -78 -78P009A	ERU-78P009A-P01	VB. INSP & ANALY M/C 78P009A-P01	INT	4M			I				I				I		IRI	IRI-INVB	150231	C
841	ERU -78 -78P009A	ERU-78P009A-P01	PM INSP OF M/C NO. 78P009A -P01	PMT	4M			I				I				I		RRC	RRC-MRCP	148888	C
842	ERU -78 -78P009A	ERU-78P009A-P01	PM; LUBRICANT REGREASE(1Hr.)	PMT	3M			L			L			L			L	RRC	RRC-MRCP	155819	C
843	ERU -78 -78P009B	ERU-78P009B-M	STAND BY CHECK LV. MOT 78P009B-M01	PMT	6M			T						T				RRC	RRC-ERCP	138943	C
844	ERU -78 -78P009B	ERU-78P009B-P01	VB. INSP & ANALY M/C 78P009B-P01	INT	4M				I			I				I		IRI	IRI-INVB	150232	C
845	ERU -78 -78P009B	ERU-78P009B-P01	PM INSP OF M/C NO. 78P009B -P01	PMT	4M				I			I				I		RRC	RRC-MRCP	148889	C
846	ERU -78 -78P009B	ERU-78P009B-P01	PM; LUBRICANT REGREASE(1Hr.)	PMT	3M		L			L		L			L			RRC	RRC-MRCP	155820	C
847	ERU -78 -78T011	ERU-78T011-T01	Storage tank inspection	PMT	5Y						I							IRI	IRI-INRC	163742	C
848	ERU -54 -QMI_GAS	ERU-AT5401201	VERIFY Total Sulfur AT5401201	PMT	4M		V				V				V			CAN	CAN-QUHV	140804	A
849	ERU -54 -QMI_GAS	ERU-AT5401202	VERIFY SO2-NO_X AT5401202	PMT	4M		V				V				V			CAN	CAN-QUHV	204787	B
850	ERU -54 -QMI_GAS	ERU-AT5401204	VERIFY Total Sulfur / N2 AT5401204	PMT	4M		V				V				V			CAN	CAN-QUHV	140805	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
851	ERU -54 -QMI_GAS	ERU-AT5402001	VERIFY DLBT AT5402001	PMT	6M				V						V			CAN	CAN-QUHV	140807	B
852	ERU -54 -QMI_GAS	ERU-AT5402002	VERIFY CEMS AT5402002	PMT	2M	V		V		V		V		V		V		CAN	CAN-QUHV	140803	B
853	ERU -54 -QMI_GAS	ERU-AT5402003	VERIFY OXYGEN AT5402003	PMT	2M	V		V		V		V		V		V		CAN	CAN-QUHV	140806	B
854	ERU -57 -QMI_GAS	ERU-AT5700201A	VERIFY MOISTURE AT5700201A	PMT	6M	V						V						CAN	CAN-QUHV	140765	C
855	ERU -57 -QMI_GAS	ERU-AT5700201B	VERIFY MOISTURE AT5700201B	PMT	6M	V						V						CAN	CAN-QUHV	140766	C
856	ERU -57 -QMI_GAS	ERU-AT5700202	VERIFY MOISTURE AT5700202	PMT	6M	V						V						CAN	CAN-QUHV	140767	C
857	ERU -57 -QMI_GC	ERU-AT5700401	VERIFY GC AT5700401	PMT	4M		V				V				V			CAN	CAN-QUHV	140768	B
858	ERU -57 -QMI_GAS	ERU-AT5700402	VERIFY Total Sulfur / N2 AT5700402	PMT	4M			V				V				V		CAN	CAN-QUHV	140769	B
859	ERU -57 -QMI_GC	ERU-AT5700501	VERIFY GC AT5700501	PMT	4M		V				V				V			CAN	CAN-QUHV	140770	A
860	ERU -57 -QMI_LIQ	ERU-AT5700801	VERIFY TOC AT5700801	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	140771	C
861	ERU -57 -QMI_GC	ERU-AT5701301	VERIFY GC AT5701301	PMT	4M		V				V				V			CAN	CAN-QUHV	140772	A
862	ERU -57 -QMI_GAS	ERU-AT5701701	VERIFY HCL AT5701701	PMT	6M			V						V				CAN	CAN-QUHV	140773	C
863	ERU -58 -QMI_GC	ERU-AT5800101	VERIFY GC AT5800101	PMT	4M		V				V				V			CAN	CAN-QUHV	140745	B
864	ERU -58 -QMI_GC	ERU-AT5800401	VERIFY GC AT5800401	PMT	4M		V				V				V			CAN	CAN-QUHV	140746	B
865	ERU -58 -QMI_GAS	ERU-AT5801301AA	VERIFY MOISTURE AT5801301AA	PMT	6M			V						V				CAN	CAN-QUHV	140747	C
866	ERU -58 -QMI_GAS	ERU-AT5801301AB	VERIFY MOISTURE AT5801301AB	PMT	6M			V						V				CAN	CAN-QUHV	204893	C
867	ERU -58 -QMI_GAS	ERU-AT5801301AC	VERIFY MOISTURE AT5801301AC	PMT	6M			V						V				CAN	CAN-QUHV	204894	C
868	ERU -58 -QMI_GAS	ERU-AT5801301BA	VERIFY MOISTURE AT5801301BA	PMT	6M			V						V				CAN	CAN-QUHV	140748	C
869	ERU -58 -QMI_GAS	ERU-AT5801301BB	VERIFY MOISTURE AT5801301BB	PMT	6M			V						V				CAN	CAN-QUHV	204895	C
870	ERU -58 -QMI_GAS	ERU-AT5801301BC	VERIFY MOISTURE AT5801301BC	PMT	6M			V						V				CAN	CAN-QUHV	204896	C
871	ERU -58 -QMI_GC	ERU-AT5801311	VERIFY TOTAL_HYDROCARBON AT5801311	PMT	4M	V				V				V				CAN	CAN-QUHV	140749	B
872	ERU -58 -QMI_GAS	ERU-AT5801312	VERIFY MOISTURE AT5801312	PMT	6M			V						V				CAN	CAN-QUHV	140750	B
873	ERU -58 -QMI_GC	ERU-AT5801401	VERIFY GC AT5801401	PMT	4M			V				V				V		CAN	CAN-QUHV	140751	B
874	ERU -58 -QMI_GC	ERU-AT5801501	VERIFY GC AT5801501	PMT	4M	V				V				V				CAN	CAN-QUHV	140752	A
875	ERU -58 -QMI_GC	ERU-AT5801601	VERIFY GC AT5801601	PMT	4M		V				V				V			CAN	CAN-QUHV	140753	B
876	ERU -58 -QMI_GAS	ERU-AT5801701AA	VERIFY MOISTURE AT5801701AA	PMT	6M			V						V				CAN	CAN-QUHV	140754	C
877	ERU -58 -QMI_GAS	ERU-AT5801701AB	VERIFY MOISTURE AT5801701AB	PMT	6M			V						V				CAN	CAN-QUHV	204897	C
878	ERU -58 -QMI_GAS	ERU-AT5801701AC	VERIFY MOISTURE AT5801701AC	PMT	6M			V						V				CAN	CAN-QUHV	204898	C
879	ERU -58 -QMI_GAS	ERU-AT5801701BA	VERIFY MOISTURE AT5801701BA	PMT	6M			V						V				CAN	CAN-QUHV	140755	C
880	ERU -58 -QMI_GAS	ERU-AT5801701BB	VERIFY MOISTURE AT5801701BB	PMT	6M			V						V				CAN	CAN-QUHV	204899	C
881	ERU -58 -QMI_GAS	ERU-AT5801701BC	VERIFY MOISTURE AT5801701BC	PMT	6M			V						V				CAN	CAN-QUHV	204900	C
882	ERU -58 -QMI_GC	ERU-AT5801712	VERIFY GC AT5801712	PMT	4M				V				V				V	CAN	CAN-QUHV	140756	B
883	ERU -58 -QMI_GC	ERU-AT5802501	VERIFY GC AT5802501	PMT	4M			V			V				V			CAN	CAN-QUHV	140757	B
884	ERU -58 -QMI_GC	ERU-AT5802502	VERIFY GC AT5802502	PMT	4M				V			V				V		CAN	CAN-QUHV	140758	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
885	ERU -58 -QMI_GC	ERU-AT5802701	VERIFY GC AT5802701	PMT	4M			V				V				V		CAN	CAN-QUHV	140759	B
886	ERU -58 -QMI_GC	ERU-AT5803201	VERIFY GC AT5803201	PMT	4M			V				V				V		CAN	CAN-QUHV	140760	B
887	ERU -58 -QMI_GC	ERU-AT5803401	VERIFY GC AT5803401	PMT	4M				V				V				V	CAN	CAN-QUHV	140761	B
888	ERU -58 -QMI_GC	ERU-AT5803501	VERIFY GC AT5803501	PMT	4M	V				V				V				CAN	CAN-QUHV	140762	A
889	ERU -58 -QMI_GC	ERU-AT5803502	VERIFY GC AT5803502	PMT	4M				V				V				V	CAN	CAN-QUHV	140763	B
890	ERU -59 -QMI_GC	ERU-AT5900101	VERIFY GC AT5900101	PMT	4M	V				V				V				CAN	CAN-QUHV	140741	B
891	ERU -STR-BUILDING	ERU-BDG-54K001A-B	INSPECTION BUILDING FOR RCPR	INT	6Y						I							ENE	ENE-ENQS	204433	A
892	ERU -STR-BUILDING	ERU-BDG-57K001-2	INSPECTION BUILDING FOR RCPR	INT	6Y						I							ENE	ENE-ENQS	204434	A
893	ERU -STR-BUILDING	ERU-BDG-58K001	INSPECTION BUILDING FOR RCPR	INT	6Y						I							ENE	ENE-ENQS	204436	A
894	ERU -STR-BUILDING	ERU-BDG-58K101	INSPECTION BUILDING FOR RCPR	INT	6Y						I							ENE	ENE-ENQS	204437	A
895	ERU -STR-BUILDING	ERU-BDG-58K401	INSPECTION BUILDING FOR RCPR	INT	6Y						I							ENE	ENE-ENQS	204438	A
896	ERU -STR-BUILDING	ERU-BDG-A-54D001	INSPECTION BUILDING FOR RCPR	INT	6Y						I							ENE	ENE-ENQS	204428	A
897	ERU -STR-BUILDING	ERU-BDG-B-54R003	INSPECTION BUILDING FOR RCPR	INT	6Y						I							ENE	ENE-ENQS	204429	A
898	ERU -STR-BUILDING	ERU-BDG-C-54R001	INSPECTION BUILDING FOR RCPR	INT	6Y						I							ENE	ENE-ENQS	204430	A
899	ERU -STR-BUILDING	ERU-BDG-CHEM	INSPECTION BUILDING FOR RCPR	INT	6Y						I							ENE	ENE-ENQS	204435	A
900	ERU -STR-BUILDING	ERU-BDG-D-54E009	INSPECTION BUILDING FOR RCPR	INT	6Y						I							ENE	ENE-ENQS	204431	A
901	ERU -STR-BUILDING	ERU-BDG-E-54E011	INSPECTION BUILDING FOR RCPR	INT	6Y						I							ENE	ENE-ENQS	204432	A
902	ERU -STR-BUILDING	ERU-BDG-SUB-002	INSPECTION BUILDING FOR RCPR	INT	6Y						I							ENE	ENE-ENQS	204427	A
903	ERU -54 -DCS	ERU-DCS	INSPECT DCS SYSTEM	PMT	3M		I			I			I			I		CCS	CCS-SYS	246442	A
904	ERU -54 -DCS	ERU-DCS	BACKUP DCS SYSTEM	PMT	6M		I						I					CCS	CCS-SYS	246443	A
905	ERU -54 -DCS	ERU-DCS	UPDATE ANTIVIRUS DCS SYSTEM	PMT	3M		U			U			U			U		CCS	CCS-SYS	246444	A
906	ERU -54 -FIRE_ALARM	ERU-FA-MCP-54	PM F/A PUSH BUTTON (###) (UNIT 54)	PMT	3M		P			P			P			P		RRC	RRC-ERCP	140381	A
907	ERU -57 -FIRE_ALARM	ERU-FA-MCP-57	PM F/A PUSH BUTTON (###) (UNIT 57)	PMT	3M		P			P			P			P		RRC	RRC-ERCP	140384	A
908	ERU -58 -FIRE_ALARM	ERU-FA-MCP-58	PM F/A PUSH BUTTON (###) (UNIT 58)	PMT	3M		P			P			P			P		RRC	RRC-ERCP	140385	A
909	ERU -54 -FGS	ERU-FGS	INSPECT FGS SYSTEM	PMT	3M		I			I			I			I		CCS	CCS-SYS	246448	A
910	ERU -54 -FGS	ERU-FGS	BACKUP FGS SYSTEM	PMT	6M		I						I					CCS	CCS-SYS	246449	A
911	ERU -54 -FGS	ERU-FGS	UPDATE ANTIVIRUS FGS SYSTEM	PMT	3M		U			U			U			U		CCS	CCS-SYS	246450	A
912	ERU -54 -FLOW	ERU-FT5400101	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134702	C
913	ERU -54 -FLOW	ERU-FT5400102	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134703	C
914	ERU -54 -FLOW	ERU-FT5400103	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134704	C
915	ERU -54 -FLOW	ERU-FT5400104	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134705	C
916	ERU -54 -FLOW	ERU-FT5400106	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134706	C
917	ERU -54 -FLOW	ERU-FT5400107	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134707	C
918	ERU -54 -FLOW	ERU-FT5400201	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134708	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
919	ERU -54 -FLOW	ERU-FT5400202	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134709	C
920	ERU -54 -FLOW	ERU-FT5400203A	INSP. FIELD INST. (#ครุปกรณ์)	INS	1Y	I												RRC	RRC-IRCP	134710	C
921	ERU -54 -FLOW	ERU-FT5400203A	FT5400203A-FULLFLN TEST FLOW T	PMT	5Y										F			RRC	RRC-IRCP	260391	C
922	ERU -54 -FLOW	ERU-FT5400203B	INSP. FIELD INST. (#ครุปกรณ์)	INS	1Y	I												RRC	RRC-IRCP	134711	C
923	ERU -54 -FLOW	ERU-FT5400203B	FT5400203B-FULLFLN TEST FLOW T	PMT	5Y										F			RRC	RRC-IRCP	260392	C
924	ERU -54 -FLOW	ERU-FT5400203C	INSP. FIELD INST. (#ครุปกรณ์)	INS	1Y	I												RRC	RRC-IRCP	134712	C
925	ERU -54 -FLOW	ERU-FT5400203C	FT5400203C-FULLFLN TEST FLOW T	PMT	5Y										F			RRC	RRC-IRCP	260393	C
926	ERU -54 -FLOW	ERU-FT5400204	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134713	C
927	ERU -54 -FLOW	ERU-FT5400301	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134714	C
928	ERU -54 -FLOW	ERU-FT5400302	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134715	C
929	ERU -54 -FLOW	ERU-FT5400303	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134716	C
930	ERU -54 -FLOW	ERU-FT5400401	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134717	C
931	ERU -54 -FLOW	ERU-FT5400502	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134718	C
932	ERU -54 -FLOW	ERU-FT5400601	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134719	C
933	ERU -54 -FLOW	ERU-FT5400602	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134720	C
934	ERU -54 -FLOW	ERU-FT5400701	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134721	C
935	ERU -54 -FLOW	ERU-FT5400801	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134722	C
936	ERU -54 -FLOW	ERU-FT5400802	INSP. FIELD INST. (#ครุปกรณ์)	INS	1Y	I												RRC	RRC-IRCP	134723	C
937	ERU -54 -FLOW	ERU-FT5400802	FT5400802-FULLFLN TEST FLOW TR	PMT	5Y										F			RRC	RRC-IRCP	260394	C
938	ERU -54 -FLOW	ERU-FT5400803	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134724	C
939	ERU -54 -FLOW	ERU-FT5400901	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134725	C
940	ERU -54 -FLOW	ERU-FT5400902A	INSP. FIELD INST. (#ครุปกรณ์)	INS	1Y	I												RRC	RRC-IRCP	134726	C
941	ERU -54 -FLOW	ERU-FT5400902A	FT5400902A-FULLFLN TEST FLOW T	PMT	5Y										F			RRC	RRC-IRCP	260395	C
942	ERU -54 -FLOW	ERU-FT5400902B	INSP. FIELD INST. (#ครุปกรณ์)	INS	1Y	I												RRC	RRC-IRCP	134727	C
943	ERU -54 -FLOW	ERU-FT5400902B	FT5400902B-FULLFLN TEST FLOW T	PMT	5Y										F			RRC	RRC-IRCP	260396	C
944	ERU -54 -FLOW	ERU-FT5400902C	INSP. FIELD INST. (#ครุปกรณ์)	INS	1Y	I												RRC	RRC-IRCP	134728	C
945	ERU -54 -FLOW	ERU-FT5400902C	FT5400902C-FULLFLN TEST FLOW T	PMT	5Y										F			RRC	RRC-IRCP	260397	C
946	ERU -54 -FLOW	ERU-FT5400903	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134729	C
947	ERU -54 -FLOW	ERU-FT5401001	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134730	C
948	ERU -54 -FLOW	ERU-FT5401101	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134731	C
949	ERU -54 -FLOW	ERU-FT5401102	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134732	C
950	ERU -54 -FLOW	ERU-FT5401104	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134734	C
951	ERU -54 -FLOW	ERU-FT5401201	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134735	C
952	ERU -54 -FLOW	ERU-FT5401501	INSP. FIELD INST. (#ครุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCP	134696	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
953	ERU -54 -FLOW	ERU-FT5401601	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134697	C
954	ERU -54 -FLOW	ERU-FT5401602	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134741	C
955	ERU -54 -FLOW	ERU-FT5401701	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134742	C
956	ERU -54 -FLOW	ERU-FT5401702	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134743	C
957	ERU -54 -FLOW	ERU-FT5430102	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134748	C
958	ERU -54 -FLOW	ERU-FT5431101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134749	C
959	ERU -54 -FLOW	ERU-FT5431102	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134750	C
960	ERU -54 -FLOW	ERU-FT5431103	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134751	C
961	ERU -54 -FLOW	ERU-FT5431104	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134752	C
962	ERU -54 -FLOW	ERU-FT5432101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134753	C
963	ERU -54 -FLOW	ERU-FT5432102	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134754	C
964	ERU -54 -FLOW	ERU-FT5432103	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134755	C
965	ERU -54 -FLOW	ERU-FT5433101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134756	C
966	ERU -54 -FLOW	ERU-FT5434101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134757	C
967	ERU -54 -FLOW	ERU-FT5435101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134758	C
968	ERU -54 -FLOW	ERU-FT5436101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134759	C
969	ERU -54 -FLOW	ERU-FT5437101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134760	C
970	ERU -57 -FLOW	ERU-FT5700101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134761	C
971	ERU -57 -FLOW	ERU-FT5700102	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134762	C
972	ERU -57 -FLOW	ERU-FT5700103	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134763	C
973	ERU -57 -FLOW	ERU-FT5700301	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134764	C
974	ERU -57 -FLOW	ERU-FT5700302	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134765	C
975	ERU -57 -FLOW	ERU-FT5700401	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134766	C
976	ERU -57 -FLOW	ERU-FT5700501	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134698	C
977	ERU -57 -FLOW	ERU-FT5700601	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134767	C
978	ERU -57 -FLOW	ERU-FT5700701	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134768	C
979	ERU -57 -FLOW	ERU-FT5700801	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134769	C
980	ERU -57 -FLOW	ERU-FT5700802	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134770	C
981	ERU -57 -FLOW	ERU-FT5700902	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134771	C
982	ERU -57 -FLOW	ERU-FT5700903	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134772	C
983	ERU -57 -FLOW	ERU-FT5700904	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134773	C
984	ERU -57 -FLOW	ERU-FT5700905	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134774	C
985	ERU -57 -FLOW	ERU-FT5701002	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134775	C
986	ERU -57 -FLOW	ERU-FT5701101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134776	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
987	ERU -57 -FLOW	ERU-FT5701102	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134777	C
988	ERU -57 -FLOW	ERU-FT5701103	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134778	C
989	ERU -57 -FLOW	ERU-FT5701104	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134779	C
990	ERU -57 -FLOW	ERU-FT5701105	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134780	C
991	ERU -57 -FLOW	ERU-FT5701106	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134781	C
992	ERU -57 -FLOW	ERU-FT5701301	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134699	C
993	ERU -57 -57K001	ERU-FT5701701	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134859	B
994	ERU -57 -FLOW	ERU-FT5701702	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134785	C
995	ERU -57 -FLOW	ERU-FT5701802	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134786	C
996	ERU -57 -FLOW	ERU-FT5701803	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134787	C
997	ERU -57 -FLOW	ERU-FT5701804	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134788	C
998	ERU -57 -FLOW	ERU-FT5701805	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134789	C
999	ERU -57 -FLOW	ERU-FT5730101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134790	C
1,000	ERU -57 -FLOW	ERU-FT5730102	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134791	C
1,001	ERU -57 -FLOW	ERU-FT5731101A	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134792	C
1,002	ERU -57 -FLOW	ERU-FT5731101B	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134793	C
1,003	ERU -57 -FLOW	ERU-FT5732101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134794	C
1,004	ERU -57 -FLOW	ERU-FT5732102	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134795	C
1,005	ERU -57 -FLOW	ERU-FT5733101A	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134796	C
1,006	ERU -57 -FLOW	ERU-FT5734101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134797	C
1,007	ERU -57 -FLOW	ERU-FT5734102	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134798	C
1,008	ERU -57 -FLOW	ERU-FT5735101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134799	C
1,009	ERU -57 -FLOW	ERU-FT5736101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134800	C
1,010	ERU -57 -FLOW	ERU-FT5737101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134801	C
1,011	ERU -57 -57K002	ERU-FT5751001	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134860	B
1,012	ERU -58 -FLOW	ERU-FT5800101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134693	C
1,013	ERU -58 -FLOW	ERU-FT5800102	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134694	C
1,014	ERU -58 -FLOW	ERU-FT5800103	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134802	C
1,015	ERU -58 -FLOW	ERU-FT5800301	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134695	C
1,016	ERU -58 -FLOW	ERU-FT5800401	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134803	C
1,017	ERU -58 -FLOW	ERU-FT5800501	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134804	C
1,018	ERU -58 -FLOW	ERU-FT5802101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134809	C
1,019	ERU -58 -FLOW	ERU-FT5802301	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134810	C
1,020	ERU -58 -FLOW	ERU-FT5802401	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134811	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,021	ERU -58 -FLOW	ERU-FT5802501	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134812	C
1,022	ERU -58 -FLOW	ERU-FT5802502	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134813	C
1,023	ERU -58 -FLOW	ERU-FT5802802	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134814	C
1,024	ERU -58 -FLOW	ERU-FT5803201	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134815	C
1,025	ERU -58 -FLOW	ERU-FT5803205	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134816	C
1,026	ERU -58 -FLOW	ERU-FT5803401	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134817	C
1,027	ERU -58 -FLOW	ERU-FT5803402	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134818	C
1,028	ERU -58 -FLOW	ERU-FT5803403	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134819	C
1,029	ERU -58 -FLOW	ERU-FT5803501	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134820	C
1,030	ERU -58 -FLOW	ERU-FT5803502	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134821	C
1,031	ERU -58 -FLOW	ERU-FT5803503	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134822	C
1,032	ERU -58 -FLOW	ERU-FT5803601	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134823	C
1,033	ERU -58 -FLOW	ERU-FT5804701	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134824	C
1,034	ERU -58 -FLOW	ERU-FT5804702	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134825	C
1,035	ERU -58 -FLOW	ERU-FT5804801	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134700	C
1,036	ERU -58 -FLOW	ERU-FT5804901	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134826	C
1,037	ERU -58 -FLOW	ERU-FT5804902	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134827	C
1,038	ERU -58 -58K501	ERU-FT5805301	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134858	C
1,039	ERU -58 -FLOW	ERU-FT5805901	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134828	C
1,040	ERU -58 -FLOW	ERU-FT5805902	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134829	C
1,041	ERU -58 -FLOW	ERU-FT5805903	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134830	C
1,042	ERU -58 -FLOW	ERU-FT5805904	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134831	C
1,043	ERU -58 -FLOW	ERU-FT5806001	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134832	C
1,044	ERU -58 -FLOW	ERU-FT5830101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134833	C
1,045	ERU -58 -FLOW	ERU-FT5830102	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134834	C
1,046	ERU -58 -FLOW	ERU-FT5831101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134835	C
1,047	ERU -58 -FLOW	ERU-FT5831102	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134836	C
1,048	ERU -58 -FLOW	ERU-FT5831103	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134837	C
1,049	ERU -58 -FLOW	ERU-FT5831104	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134838	C
1,050	ERU -58 -FLOW	ERU-FT5832101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134839	C
1,051	ERU -58 -FLOW	ERU-FT5832102	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134840	C
1,052	ERU -58 -FLOW	ERU-FT5833101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134841	C
1,053	ERU -58 -FLOW	ERU-FT5834101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134842	C
1,054	ERU -58 -FLOW	ERU-FT5834102	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134843	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,055	ERU -58 -FLOW	ERU-FT5834103	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134844	C
1,056	ERU -58 -FLOW	ERU-FT5835101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134845	C
1,057	ERU -58 -FLOW	ERU-FT5836101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134846	C
1,058	ERU -58 -FLOW	ERU-FT5837101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134847	C
1,059	ERU -58 -58K101	ERU-FT5850707	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134853	C
1,060	ERU -59 -FLOW	ERU-FT5900101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134848	C
1,061	ERU -59 -FLOW	ERU-FT5900104	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y	I												RRC	RRC-IRCP	134701	C
1,062	ERU -54 -CV	ERU-FV5400107	INSPECT CONTROL VALVE NO. FV54	PMT	1Y									I				RRC	RRC-IRCP	135755	C
1,063	ERU -54 -CV	ERU-FV5400201	INSPECT CONTROL VALVE NO. FV54	PMT	1Y									I				RRC	RRC-IRCP	135756	C
1,064	ERU -54 -CV	ERU-FV5400202	INSPECT CONTROL VALVE NO. FV54	PMT	1Y									I				RRC	RRC-IRCP	135757	C
1,065	ERU -54 -CV	ERU-FV5400301	INSPECT CONTROL VALVE NO. FV54	PMT	1Y									I				RRC	RRC-IRCP	135758	C
1,066	ERU -54 -CV	ERU-FV5400302	INSPECT CONTROL VALVE NO. FV54	PMT	1Y									I				RRC	RRC-IRCP	135759	C
1,067	ERU -54 -CV	ERU-FV5400502	INSPECT CONTROL VALVE NO. FV54	PMT	1Y									I				RRC	RRC-IRCP	135760	C
1,068	ERU -54 -CV	ERU-FV5400601	INSPECT CONTROL VALVE NO. FV54	PMT	1Y									I				RRC	RRC-IRCP	135761	C
1,069	ERU -54 -CV	ERU-FV5400602	INSPECT CONTROL VALVE NO. FV54	PMT	1Y									I				RRC	RRC-IRCP	135762	C
1,070	ERU -54 -CV	ERU-FV5400701	INSPECT CONTROL VALVE NO. FV54	PMT	1Y									I				RRC	RRC-IRCP	135763	C
1,071	ERU -54 -CV	ERU-FV5400801	INSPECT CONTROL VALVE NO. FV54	PMT	1Y									I				RRC	RRC-IRCP	135764	C
1,072	ERU -54 -CV	ERU-FV5400901	INSPECT CONTROL VALVE NO. FV54	PMT	1Y									I				RRC	RRC-IRCP	135765	C
1,073	ERU -54 -CV	ERU-FV5401001	INSPECT CONTROL VALVE NO. FV54	PMT	1Y									I				RRC	RRC-IRCP	135766	C
1,074	ERU -54 -CV	ERU-FV5401101	INSPECT CONTROL VALVE NO. FV54	PMT	1Y									I				RRC	RRC-IRCP	135767	C
1,075	ERU -54 -CV	ERU-FV5401201	INSPECT CONTROL VALVE NO. FV54	PMT	1Y									I				RRC	RRC-IRCP	135768	C
1,076	ERU -54 -CV	ERU-FV5401301	INSPECT CONTROL VALVE NO. FV54	PMT	1Y									I				RRC	RRC-IRCP	135769	C
1,077	ERU -54 -CV	ERU-FV5401302	INSPECT CONTROL VALVE NO. FV54	PMT	1Y									I				RRC	RRC-IRCP	135770	C
1,078	ERU -54 -CV	ERU-FV5401501	INSPECT CONTROL VALVE NO. FV54	PMT	1Y									I				RRC	RRC-IRCP	135771	C
1,079	ERU -54 -CV	ERU-FV5401601	INSPECT CONTROL VALVE NO. FV54	PMT	1Y									I				RRC	RRC-IRCP	135772	C
1,080	ERU -54 -CV	ERU-FV5401702	INSPECT CONTROL VALVE NO. FV54	PMT	1Y									I				RRC	RRC-IRCP	135773	C
1,081	ERU -57 -CV	ERU-FV5700301	INSPECT CONTROL VALVE NO. FV57	PMT	1Y									I				RRC	RRC-IRCP	135774	C
1,082	ERU -57 -CV	ERU-FV5700302	INSPECT CONTROL VALVE NO. FV57	PMT	1Y									I				RRC	RRC-IRCP	135775	C
1,083	ERU -57 -CV	ERU-FV5700501	INSPECT CONTROL VALVE NO. FV57	PMT	1Y									I				RRC	RRC-IRCP	135776	C
1,084	ERU -57 -CV	ERU-FV5700601	INSPECT CONTROL VALVE NO. FV57	PMT	1Y										I			RRC	RRC-IRCP	135792	C
1,085	ERU -57 -CV	ERU-FV5700701	INSPECT CONTROL VALVE NO. FV57	PMT	1Y										I			RRC	RRC-IRCP	135793	C
1,086	ERU -57 -CV	ERU-FV5700801	INSPECT CONTROL VALVE NO. FV57	PMT	1Y									I				RRC	RRC-IRCP	135777	C
1,087	ERU -57 -CV	ERU-FV5700802	INSPECT CONTROL VALVE NO. FV57	PMT	1Y									I				RRC	RRC-IRCP	135778	C
1,088	ERU -57 -CV	ERU-FV5700902	INSPECT CONTROL VALVE NO. FV57	PMT	1Y										I			RRC	RRC-IRCP	135796	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,089	ERU -57 -CV	ERU-FV5700903	INSPECT CONTROL VALVE NO. FV57	PMT	1Y									I				RRC	RRC-IRCP	135779	C
1,090	ERU -57 -CV	ERU-FV5700904	INSPECT CONTROL VALVE NO. FV57	PMT	1Y									I				RRC	RRC-IRCP	135780	C
1,091	ERU -57 -CV	ERU-FV5700905	INSPECT CONTROL VALVE NO. FV57	PMT	1Y									I				RRC	RRC-IRCP	135781	C
1,092	ERU -57 -CV	ERU-FV5701101	INSPECT CONTROL VALVE NO. FV57	PMT	1Y									I				RRC	RRC-IRCP	135782	C
1,093	ERU -57 -CV	ERU-FV5701102	INSPECT CONTROL VALVE NO. FV57	PMT	1Y										I			RRC	RRC-IRCP	135801	C
1,094	ERU -57 -CV	ERU-FV5701104	INSPECT CONTROL VALVE NO. FV57	PMT	1Y									I				RRC	RRC-IRCP	135783	C
1,095	ERU -57 -CV	ERU-FV5701105	INSPECT CONTROL VALVE NO. FV57	PMT	1Y									I				RRC	RRC-IRCP	135784	C
1,096	ERU -57 -CV	ERU-FV5701106	INSPECT CONTROL VALVE NO. FV57	PMT	1Y									I				RRC	RRC-IRCP	135785	C
1,097	ERU -57 -CV	ERU-FV5701301	INSPECT CONTROL VALVE NO. FV57	PMT	1Y									I				RRC	RRC-IRCP	135786	C
1,098	ERU -57 -CV	ERU-FV5701302	INSPECT CONTROL VALVE NO. FV57	PMT	1Y									I				RRC	RRC-IRCP	135787	C
1,099	ERU -57 -CV	ERU-FV5701402	INSPECT CONTROL VALVE NO. FV57	PMT	1Y										I			RRC	RRC-IRCP	135788	C
1,100	ERU -57 -CV	ERU-FV5701702	INSPECT CONTROL VALVE NO. FV57	PMT	1Y										I			RRC	RRC-IRCP	135789	C
1,101	ERU -57 -CV	ERU-FV5701802	INSPECT CONTROL VALVE NO. FV57	PMT	1Y										I			RRC	RRC-IRCP	135790	C
1,102	ERU -57 -CV	ERU-FV5701803	INSPECT CONTROL VALVE NO. FV57	PMT	1Y										I			RRC	RRC-IRCP	135791	C
1,103	ERU -57 -CV	ERU-FV5701804	INSPECT CONTROL VALVE NO. FV57	PMT	1Y										I			RRC	RRC-IRCP	135794	C
1,104	ERU -58 -CV	ERU-FV5800401	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135795	C
1,105	ERU -58 -CV	ERU-FV5800501	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135797	C
1,106	ERU -58 -CV	ERU-FV5800502	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135798	C
1,107	ERU -58 -CV	ERU-FV5801201	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135815	C
1,108	ERU -58 -CV	ERU-FV5801501	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135799	C
1,109	ERU -58 -CV	ERU-FV5802101	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135800	C
1,110	ERU -58 -CV	ERU-FV5802301	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135802	C
1,111	ERU -58 -CV	ERU-FV5802401	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135803	C
1,112	ERU -58 -CV	ERU-FV5802502	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135804	C
1,113	ERU -58 -CV	ERU-FV5803201	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135805	C
1,114	ERU -58 -CV	ERU-FV5803401	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135806	C
1,115	ERU -58 -CV	ERU-FV5803402	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135807	C
1,116	ERU -58 -CV	ERU-FV5803403	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135808	C
1,117	ERU -58 -CV	ERU-FV5803502	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135809	C
1,118	ERU -58 -CV	ERU-FV5803503	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135810	C
1,119	ERU -58 -CV	ERU-FV5803601	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135811	C
1,120	ERU -58 -CV	ERU-FV5804701	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135812	C
1,121	ERU -58 -CV	ERU-FV5804702	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135813	C
1,122	ERU -58 -CV	ERU-FV5805901	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135814	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,123	ERU -58 -CV	ERU-FV5805902	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135816	C
1,124	ERU -58 -CV	ERU-FV5805903	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135817	C
1,125	ERU -58 -CV	ERU-FV5805904	INSPECT CONTROL VALVE NO. FV58	PMT	1Y										I			RRC	RRC-IRCP	135818	C
1,126	ERU -54 -QMI_GD	ERU-GDT5400101	VERIFY GAS_DETECTOR GDT5400101	PMT	4M					V			V				V	CAN	CAN-QUHV	140784	C
1,127	ERU -54 -QMI_GD	ERU-GDT5400102	VERIFY GAS_DETECTOR GDT5400102	PMT	4M					V			V				V	CAN	CAN-QUHV	140785	C
1,128	ERU -54 -QMI_GD	ERU-GDT5400201	VERIFY GAS_DETECTOR GDT5400201	PMT	4M					V			V				V	CAN	CAN-QUHV	204788	C
1,129	ERU -54 -QMI_GD	ERU-GDT5400202	VERIFY GAS_DETECTOR GDT5400202	PMT	4M					V			V				V	CAN	CAN-QUHV	204789	C
1,130	ERU -54 -QMI_GD	ERU-GDT5400203	VERIFY GAS_DETECTOR GDT5400203	PMT	4M					V			V				V	CAN	CAN-QUHV	204790	C
1,131	ERU -54 -QMI_GD	ERU-GDT5400204	VERIFY GAS_DETECTOR GDT5400204	PMT	4M					V			V				V	CAN	CAN-QUHV	204791	C
1,132	ERU -54 -QMI_GD	ERU-GDT5400205	VERIFY GAS_DETECTOR GDT5400205	PMT	4M					V			V				V	CAN	CAN-QUHV	204792	C
1,133	ERU -54 -QMI_GD	ERU-GDT5400206	VERIFY GAS_DETECTOR GDT5400206	PMT	4M					V			V				V	CAN	CAN-QUHV	204793	C
1,134	ERU -54 -QMI_GD	ERU-GDT5400207	VERIFY GAS_DETECTOR GDT5400207	PMT	4M					V			V				V	CAN	CAN-QUHV	204794	C
1,135	ERU -54 -QMI_GD	ERU-GDT5400208	3RIFY GAS_DETECTOR GDT5400208	PMT	4M					V			V				V	CAN	CAN-QUHV	204795	C
1,136	ERU -54 -QMI_GD	ERU-GDT5400209	VERIFY GAS_DETECTOR GDT5400209	PMT	4M					V			V				V	CAN	CAN-QUHV	204796	C
1,137	ERU -54 -QMI_GD	ERU-GDT5400210	VERIFY GAS_DETECTOR GDT5400210	PMT	4M					V			V				V	CAN	CAN-QUHV	204797	C
1,138	ERU -54 -QMI_GD	ERU-GDT5400211	VERIFY GAS_DETECTOR GDT5400211	PMT	4M					V			V				V	CAN	CAN-QUHV	204798	C
1,139	ERU -54 -QMI_GD	ERU-GDT5400212	VERIFY GAS_DETECTOR GDT5400212	PMT	4M					V			V				V	CAN	CAN-QUHV	204799	C
1,140	ERU -54 -QMI_GD	ERU-GDT5400213	VERIFY GAS_DETECTOR GDT5400213	PMT	4M					V			V				V	CAN	CAN-QUHV	204800	C
1,141	ERU -54 -QMI_GD	ERU-GDT5400214	3RIFY GAS_DETECTOR GDT5400214	PMT	4M					V			V				V	CAN	CAN-QUHV	204801	C
1,142	ERU -54 -QMI_GD	ERU-GDT5400215	VERIFY GAS_DETECTOR GDT5400215	PMT	4M					V			V				V	CAN	CAN-QUHV	204802	C
1,143	ERU -54 -QMI_GD	ERU-GDT5400216	VERIFY GAS_DETECTOR GDT5400216	PMT	4M					V			V				V	CAN	CAN-QUHV	204803	C
1,144	ERU -54 -QMI_GD	ERU-GDT5400217	VERIFY GAS_DETECTOR GDT5400217	PMT	4M					V			V				V	CAN	CAN-QUHV	204804	C
1,145	ERU -54 -QMI_GD	ERU-GDT5400218	VERIFY GAS_DETECTOR GDT5400218	PMT	4M					V			V				V	CAN	CAN-QUHV	204805	C
1,146	ERU -54 -QMI_GD	ERU-GDT5400219	VERIFY GAS_DETECTOR GDT5400219	PMT	4M					V			V				V	CAN	CAN-QUHV	204806	C
1,147	ERU -54 -QMI_GD	ERU-GDT5400220	VERIFY GAS_DETECTOR GDT5400220	PMT	4M					V			V				V	CAN	CAN-QUHV	204807	C
1,148	ERU -54 -QMI_GD	ERU-GDT5400221	VERIFY GAS_DETECTOR GDT5400221	PMT	4M					V			V				V	CAN	CAN-QUHV	204808	C
1,149	ERU -54 -QMI_GD	ERU-GDT5400222	VERIFY GAS_DETECTOR GDT5400222	PMT	4M					V			V				V	CAN	CAN-QUHV	204809	C
1,150	ERU -54 -QMI_GD	ERU-GDT5400223	VERIFY GAS_DETECTOR GDT5400223	PMT	4M					V			V				V	CAN	CAN-QUHV	204810	C
1,151	ERU -54 -QMI_GD	ERU-GDT5400224	VERIFY GAS_DETECTOR GDT5400224	PMT	4M					V			V				V	CAN	CAN-QUHV	204811	C
1,152	ERU -54 -QMI_GD	ERU-GDT5400225	VERIFY GAS_DETECTOR GDT5400225	PMT	4M					V			V				V	CAN	CAN-QUHV	204812	C
1,153	ERU -54 -QMI_GD	ERU-GDT5400226	VERIFY GAS_DETECTOR GDT5400226	PMT	4M					V			V				V	CAN	CAN-QUHV	204813	C
1,154	ERU -54 -QMI_GD	ERU-GDT5400227	VERIFY GAS_DETECTOR GDT5400227	PMT	4M					V			V				V	CAN	CAN-QUHV	204814	C
1,155	ERU -54 -QMI_GD	ERU-GDT5400228	VERIFY GAS_DETECTOR GDT5400228	PMT	4M					V			V				V	CAN	CAN-QUHV	204815	C
1,156	ERU -54 -QMI_GD	ERU-GDT5400229	VERIFY GAS_DETECTOR GDT5400229	PMT	4M					V			V				V	CAN	CAN-QUHV	204816	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,157	ERU -54 -QMI_GD	ERU-GDT5400230	VERIFY GAS_DETECTOR GDT5400230	PMT	4M				V				V				V	CAN	CAN-QUHV	204817	C
1,158	ERU -54 -QMI_GD	ERU-GDT5400231	VERIFY GAS_DETECTOR GDT5400231	PMT	4M				V				V				V	CAN	CAN-QUHV	204818	C
1,159	ERU -54 -QMI_GD	ERU-GDT5400232	VERIFY GAS_DETECTOR GDT5400232	PMT	4M				V				V				V	CAN	CAN-QUHV	204819	C
1,160	ERU -54 -QMI_GD	ERU-GDT5400301	VERIFY GAS_DETECTOR GDT5400301	PMT	4M				V				V				V	CAN	CAN-QUHV	140786	C
1,161	ERU -54 -QMI_GD	ERU-GDT5400302	VERIFY GAS_DETECTOR GDT5400302	PMT	4M				V				V				V	CAN	CAN-QUHV	140787	C
1,162	ERU -54 -QMI_GD	ERU-GDT5400303	VERIFY GAS_DETECTOR GDT5400303	PMT	4M				V				V				V	CAN	CAN-QUHV	140788	C
1,163	ERU -54 -QMI_GD	ERU-GDT5400304	VERIFY GAS_DETECTOR GDT5400304	PMT	4M				V				V				V	CAN	CAN-QUHV	140789	C
1,164	ERU -54 -QMI_GD	ERU-GDT5400305	VERIFY GAS_DETECTOR GDT5400305	PMT	4M				V				V				V	CAN	CAN-QUHV	140790	C
1,165	ERU -54 -QMI_GD	ERU-GDT5400306	VERIFY GAS_DETECTOR GDT5400306	PMT	4M				V				V				V	CAN	CAN-QUHV	140791	C
1,166	ERU -54 -QMI_GD	ERU-GDT5400307	VERIFY GAS_DETECTOR GDT5400307	PMT	4M				V				V				V	CAN	CAN-QUHV	140792	C
1,167	ERU -54 -QMI_GD	ERU-GDT5400308	VERIFY GAS_DETECTOR GDT5400308	PMT	4M				V				V				V	CAN	CAN-QUHV	140793	C
1,168	ERU -54 -QMI_GD	ERU-GDT5400309	VERIFY GAS_DETECTOR GDT5400309	PMT	4M				V				V				V	CAN	CAN-QUHV	140794	C
1,169	ERU -54 -QMI_GD	ERU-GDT5400310	VERIFY GAS_DETECTOR GDT5400310	PMT	4M				V				V				V	CAN	CAN-QUHV	140795	C
1,170	ERU -54 -QMI_GD	ERU-GDT5400311	VERIFY GAS_DETECTOR GDT5400311	PMT	4M				V				V				V	CAN	CAN-QUHV	140796	C
1,171	ERU -54 -QMI_GD	ERU-GDT5400312	VERIFY GAS_DETECTOR GDT5400312	PMT	4M				V				V				V	CAN	CAN-QUHV	140797	C
1,172	ERU -54 -QMI_GD	ERU-GDT5400313	VERIFY GAS_DETECTOR GDT5400313	PMT	4M				V				V				V	CAN	CAN-QUHV	140798	C
1,173	ERU -54 -QMI_GD	ERU-GDT5400314	VERIFY GAS_DETECTOR GDT5400314	PMT	4M				V				V				V	CAN	CAN-QUHV	140799	C
1,174	ERU -54 -QMI_GD	ERU-GDT5400314	Function test GDT5400314 For HVAC	PMT	1Y								F					CAN	CAN-QUHV	156020	C
1,175	ERU -54 -QMI_GD	ERU-GDT5400315	VERIFY GAS_DETECTOR GDT5400315	PMT	4M				V				V				V	CAN	CAN-QUHV	140800	C
1,176	ERU -57 -QMI_GD	ERU-GDT5700201	VERIFY GAS_DETECTOR GDT5700201	PMT	4M				V				V				V	CAN	CAN-QUHV	204858	C
1,177	ERU -57 -QMI_GD	ERU-GDT5700202	VERIFY GAS_DETECTOR GDT5700202	PMT	4M				V				V				V	CAN	CAN-QUHV	204859	C
1,178	ERU -57 -QMI_GD	ERU-GDT5700203	VERIFY GAS_DETECTOR GDT5700203	PMT	4M				V				V				V	CAN	CAN-QUHV	204860	C
1,179	ERU -57 -QMI_GD	ERU-GDT5700204	VERIFY GAS_DETECTOR GDT5700204	PMT	4M				V				V				V	CAN	CAN-QUHV	204861	C
1,180	ERU -57 -QMI_GD	ERU-GDT5700205	VERIFY GAS_DETECTOR GDT5700205	PMT	4M				V				V				V	CAN	CAN-QUHV	204862	C
1,181	ERU -57 -QMI_GD	ERU-GDT5700206	VERIFY GAS_DETECTOR GDT5700206	PMT	4M				V				V				V	CAN	CAN-QUHV	204863	C
1,182	ERU -57 -QMI_GD	ERU-GDT5700207	VERIFY GAS_DETECTOR GDT5700207	PMT	4M				V				V				V	CAN	CAN-QUHV	204864	C
1,183	ERU -57 -QMI_GD	ERU-GDT5700208	VERIFY GAS_DETECTOR GDT5700208	PMT	4M				V				V				V	CAN	CAN-QUHV	204865	C
1,184	ERU -57 -QMI_GD	ERU-GDT5700209	VERIFY GAS_DETECTOR GDT5700209	PMT	4M				V				V				V	CAN	CAN-QUHV	204866	C
1,185	ERU -57 -QMI_GD	ERU-GDT5700210	VERIFY GAS_DETECTOR GDT5700210	PMT	4M				V				V				V	CAN	CAN-QUHV	204867	C
1,186	ERU -57 -QMI_GD	ERU-GDT5700211	VERIFY GAS_DETECTOR GDT5700211	PMT	4M				V				V				V	CAN	CAN-QUHV	204868	C
1,187	ERU -57 -QMI_GD	ERU-GDT5700212	VERIFY GAS_DETECTOR GDT5700212	PMT	4M				V				V				V	CAN	CAN-QUHV	204869	C
1,188	ERU -57 -QMI_GD	ERU-GDT5700213	VERIFY GAS_DETECTOR GDT5700213	PMT	4M				V				V				V	CAN	CAN-QUHV	204870	C
1,189	ERU -57 -QMI_GD	ERU-GDT5700214	VERIFY GAS_DETECTOR GDT5700214	PMT	4M				V				V				V	CAN	CAN-QUHV	204871	C
1,190	ERU -57 -QMI_GD	ERU-GDT5700215	VERIFY GAS_DETECTOR GDT5700215	PMT	4M				V				V				V	CAN	CAN-QUHV	204872	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,191	ERU -57 -QMI_GD	ERU-GDT5700216	VERIFY GAS_DETECTOR GDT5700216	PMT	4M				V				V				V	CAN	CAN-QUHV	204873	C
1,192	ERU -57 -QMI_GD	ERU-GDT5700217	VERIFY GAS_DETECTOR GDT5700217	PMT	4M				V				V				V	CAN	CAN-QUHV	204874	C
1,193	ERU -57 -QMI_GD	ERU-GDT5700218	VERIFY GAS_DETECTOR GDT5700218	PMT	4M				V				V				V	CAN	CAN-QUHV	204875	C
1,194	ERU -57 -QMI_GD	ERU-GDT5700219	VERIFY GAS_DETECTOR GDT5700219	PMT	4M				V				V				V	CAN	CAN-QUHV	204876	C
1,195	ERU -57 -QMI_GD	ERU-GDT5700220	VERIFY GAS_DETECTOR GDT5700220	PMT	4M				V				V				V	CAN	CAN-QUHV	204877	C
1,196	ERU -57 -QMI_GD	ERU-GDT5700221	VERIFY GAS_DETECTOR GDT5700221	PMT	4M				V				V				V	CAN	CAN-QUHV	204878	C
1,197	ERU -57 -QMI_GD	ERU-GDT5700222	VERIFY GAS_DETECTOR GDT5700222	PMT	4M				V				V				V	CAN	CAN-QUHV	204879	C
1,198	ERU -57 -QMI_GD	ERU-GDT5700223	VERIFY GAS_DETECTOR GDT5700223	PMT	4M				V				V				V	CAN	CAN-QUHV	204880	C
1,199	ERU -57 -QMI_GD	ERU-GDT5700224	VERIFY GAS_DETECTOR GDT5700224	PMT	4M				V				V				V	CAN	CAN-QUHV	204881	C
1,200	ERU -57 -QMI_GD	ERU-GDT5700225	VERIFY GAS_DETECTOR GDT5700225	PMT	4M				V				V				V	CAN	CAN-QUHV	204882	C
1,201	ERU -57 -QMI_GD	ERU-GDT5700226	VERIFY GAS_DETECTOR GDT5700226	PMT	4M				V				V				V	CAN	CAN-QUHV	204883	C
1,202	ERU -57 -QMI_GD	ERU-GDT5700227	VERIFY GAS_DETECTOR GDT5700227	PMT	4M				V				V				V	CAN	CAN-QUHV	204884	C
1,203	ERU -57 -QMI_GD	ERU-GDT5700228	VERIFY GAS_DETECTOR GDT5700228	PMT	4M				V				V				V	CAN	CAN-QUHV	204885	C
1,204	ERU -57 -QMI_GD	ERU-GDT5700229	VERIFY GAS_DETECTOR GDT5700229	PMT	4M				V				V				V	CAN	CAN-QUHV	204886	C
1,205	ERU -57 -QMI_GD	ERU-GDT5700231	VERIFY GAS_DETECTOR GDT5700231	PMT	4M				V				V				V	CAN	CAN-QUHV	204887	C
1,206	ERU -57 -QMI_GD	ERU-GDT5700232	VERIFY GAS_DETECTOR GDT5700232	PMT	4M				V				V				V	CAN	CAN-QUHV	204888	C
1,207	ERU -57 -QMI_GD	ERU-GDT5700233	VERIFY GAS_DETECTOR GDT5700233	PMT	4M				V				V				V	CAN	CAN-QUHV	204889	C
1,208	ERU -57 -QMI_GD	ERU-GDT5700240	VERIFY GAS_DETECTOR GDT5700240	PMT	4M				V				V				V	CAN	CAN-QUHV	204890	C
1,209	ERU -57 -QMI_GD	ERU-GDT5700241	VERIFY GAS_DETECTOR GDT5700241	PMT	4M				V				V				V	CAN	CAN-QUHV	204891	C
1,210	ERU -57 -QMI_GD	ERU-GDT5700242	VERIFY GAS_DETECTOR GDT5700242	PMT	4M				V				V				V	CAN	CAN-QUHV	204892	C
1,211	ERU -58 -QMI_GD	ERU-GDT5800101	VERIFY GAS_DETECTOR GDT5800101	PMT	4M				V				V				V	CAN	CAN-QUHV	140742	C
1,212	ERU -58 -QMI_GD	ERU-GDT5800101	Function test GDT5800101 For HVAC	PMT	1Y								F					CAN	CAN-QUHV	156014	C
1,213	ERU -58 -QMI_GD	ERU-GDT5800201	VERIFY GAS_DETECTOR GDT5800201	PMT	4M				V				V				V	CAN	CAN-QUHV	204901	C
1,214	ERU -58 -QMI_GD	ERU-GDT5800202	VERIFY GAS_DETECTOR GDT5800202	PMT	4M				V				V				V	CAN	CAN-QUHV	204902	C
1,215	ERU -58 -QMI_GD	ERU-GDT5800203	VERIFY GAS_DETECTOR GDT5800203	PMT	4M				V				V				V	CAN	CAN-QUHV	204903	C
1,216	ERU -58 -QMI_GD	ERU-GDT5800204	VERIFY GAS_DETECTOR GDT5800204	PMT	4M				V				V				V	CAN	CAN-QUHV	204904	C
1,217	ERU -58 -QMI_GD	ERU-GDT5800205	VERIFY GAS_DETECTOR GDT5800205	PMT	4M				V				V				V	CAN	CAN-QUHV	204905	C
1,218	ERU -58 -QMI_GD	ERU-GDT5800206	VERIFY GAS_DETECTOR GDT5800206	PMT	4M				V				V				V	CAN	CAN-QUHV	204906	C
1,219	ERU -58 -QMI_GD	ERU-GDT5800207	VERIFY GAS_DETECTOR GDT5800207	PMT	4M				V				V				V	CAN	CAN-QUHV	204907	C
1,220	ERU -58 -QMI_GD	ERU-GDT5800208	VERIFY GAS_DETECTOR GDT5800208	PMT	4M				V				V				V	CAN	CAN-QUHV	204908	C
1,221	ERU -58 -QMI_GD	ERU-GDT5800209	VERIFY GAS_DETECTOR GDT5800209	PMT	4M				V				V				V	CAN	CAN-QUHV	204909	C
1,222	ERU -58 -QMI_GD	ERU-GDT5800210	VERIFY GAS_DETECTOR GDT5800210	PMT	4M				V				V				V	CAN	CAN-QUHV	204910	C
1,223	ERU -58 -QMI_GD	ERU-GDT5800211	VERIFY GAS_DETECTOR GDT5800211	PMT	4M				V				V				V	CAN	CAN-QUHV	204911	C
1,224	ERU -58 -QMI_GD	ERU-GDT5800212	VERIFY GAS_DETECTOR GDT5800212	PMT	4M				V				V				V	CAN	CAN-QUHV	204912	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,225	ERU -58 -QMI_GD	ERU-GDT5800213	VERIFY GAS_DETECTOR GDT5800213	PMT	4M				V				V				V	CAN	CAN-QUHV	204913	C
1,226	ERU -58 -QMI_GD	ERU-GDT5800214	VERIFY GAS_DETECTOR GDT5800214	PMT	4M				V				V				V	CAN	CAN-QUHV	204914	C
1,227	ERU -58 -QMI_GD	ERU-GDT5800215	VERIFY GAS_DETECTOR GDT5800215	PMT	4M				V				V				V	CAN	CAN-QUHV	204915	C
1,228	ERU -58 -QMI_GD	ERU-GDT5800216	VERIFY GAS_DETECTOR GDT5800216	PMT	4M				V				V				V	CAN	CAN-QUHV	204916	C
1,229	ERU -58 -QMI_GD	ERU-GDT5800217	VERIFY GAS_DETECTOR GDT5800217	PMT	4M				V				V				V	CAN	CAN-QUHV	204917	C
1,230	ERU -58 -QMI_GD	ERU-GDT5800218	VERIFY GAS_DETECTOR GDT5800218	PMT	4M				V				V				V	CAN	CAN-QUHV	204918	C
1,231	ERU -58 -QMI_GD	ERU-GDT5800219	VERIFY GAS_DETECTOR GDT5800219	PMT	4M				V				V				V	CAN	CAN-QUHV	204919	C
1,232	ERU -58 -QMI_GD	ERU-GDT5800220	VERIFY GAS_DETECTOR GDT5800220	PMT	4M				V				V				V	CAN	CAN-QUHV	204920	C
1,233	ERU -58 -QMI_GD	ERU-GDT5800221	VERIFY GAS_DETECTOR GDT5800221	PMT	4M				V				V				V	CAN	CAN-QUHV	204921	C
1,234	ERU -58 -QMI_GD	ERU-GDT5800222	VERIFY GAS_DETECTOR GDT5800222	PMT	4M				V				V				V	CAN	CAN-QUHV	204922	C
1,235	ERU -58 -QMI_GD	ERU-GDT5800223	VERIFY GAS_DETECTOR GDT5800223	PMT	4M				V				V				V	CAN	CAN-QUHV	204923	C
1,236	ERU -58 -QMI_GD	ERU-GDT5800224	VERIFY GAS_DETECTOR GDT5800224	PMT	4M				V				V				V	CAN	CAN-QUHV	204924	C
1,237	ERU -58 -QMI_GD	ERU-GDT5800225	3RIFY GAS_DETECTOR GDT5800225	PMT	4M				V				V				V	CAN	CAN-QUHV	204925	C
1,238	ERU -58 -QMI_GD	ERU-GDT5800226	VERIFY GAS_DETECTOR GDT5800226	PMT	4M				V				V				V	CAN	CAN-QUHV	204926	C
1,239	ERU -58 -QMI_GD	ERU-GDT5800227	3RIFY GAS_DETECTOR GDT5800227	PMT	4M				V				V				V	CAN	CAN-QUHV	204927	C
1,240	ERU -58 -QMI_GD	ERU-GDT5800228	VERIFY GAS_DETECTOR GDT5800228	PMT	4M				V				V				V	CAN	CAN-QUHV	204928	C
1,241	ERU -58 -QMI_GD	ERU-GDT5800229	VERIFY GAS_DETECTOR GDT5800229	PMT	4M				V				V				V	CAN	CAN-QUHV	204929	C
1,242	ERU -58 -QMI_GD	ERU-GDT5800230	VERIFY GAS_DETECTOR GDT5800230	PMT	4M				V				V				V	CAN	CAN-QUHV	204930	C
1,243	ERU -58 -QMI_GD	ERU-GDT5800231	VERIFY GAS_DETECTOR GDT5800231	PMT	4M				V				V				V	CAN	CAN-QUHV	204931	C
1,244	ERU -58 -QMI_GD	ERU-GDT5800232	VERIFY GAS_DETECTOR GDT5800232	PMT	4M				V				V				V	CAN	CAN-QUHV	204932	C
1,245	ERU -58 -QMI_GD	ERU-GDT5800233	VERIFY GAS_DETECTOR GDT5800233	PMT	4M				V				V				V	CAN	CAN-QUHV	204933	C
1,246	ERU -58 -QMI_GD	ERU-GDT5800235	VERIFY GAS_DETECTOR GDT5800235	PMT	4M				V				V				V	CAN	CAN-QUHV	204934	C
1,247	ERU -58 -QMI_GD	ERU-GDT5800236	VERIFY GAS_DETECTOR GDT5800236	PMT	4M				V				V				V	CAN	CAN-QUHV	204935	C
1,248	ERU -58 -QMI_GD	ERU-GDT5800240	VERIFY GAS_DETECTOR GDT5800240	PMT	4M				V				V				V	CAN	CAN-QUHV	204936	C
1,249	ERU -58 -QMI_GD	ERU-GDT5800241	VERIFY GAS_DETECTOR GDT5800241	PMT	4M				V				V				V	CAN	CAN-QUHV	204937	C
1,250	ERU -58 -QMI_GD	ERU-GDT5800242	3RIFY GAS_DETECTOR GDT5800242	PMT	4M				V				V				V	CAN	CAN-QUHV	204938	C
1,251	ERU -58 -QMI_GD	ERU-GDT5800301	VERIFY GAS_DETECTOR GDT5800301	PMT	4M				V				V				V	CAN	CAN-QUHV	140743	C
1,252	ERU -58 -QMI_GD	ERU-GDT5800301	Function test GDT5800301 For HVAC	PMT	1Y				F									CAN	CAN-QUHV	156015	C
1,253	ERU -58 -QMI_GD	ERU-GDT5800302	VERIFY GAS_DETECTOR GDT5800302	PMT	4M				V				V				V	CAN	CAN-QUHV	140744	C
1,254	ERU -58 -QMI_GD	ERU-GDT5800302	Function test GDT5800302 For HVAC	PMT	1Y				F									CAN	CAN-QUHV	156012	C
1,255	ERU -58 -QMI_GD	ERU-GDT5802101	VERIFY GAS_DETECTOR GDT5802101	PMT	4M				V				V				V	CAN	CAN-QUHV	204939	C
1,256	ERU -54 -CV	ERU-HV5400301	INSPECT CONTROL VALVE NO. HV54	PMT	1Y										I			RRC	RRC-IRCP	135819	C
1,257	ERU -54 -CV	ERU-HV5400302	INSPECT CONTROL VALVE NO. HV54	PMT	1Y										I			RRC	RRC-IRCP	135820	C
1,258	ERU -54 -CV	ERU-HV5400501	INSPECT CONTROL VALVE NO. HV54	PMT	1Y										I			RRC	RRC-IRCP	135821	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,259	ERU -54 -CV	ERU-HV5401101	INSPECT CONTROL VALVE NO. HV54	PMT	1Y										I			RRC	RRC-IRCP	135822	C
1,260	ERU -57 -CV	ERU-HV5700101	INSPECT CONTROL VALVE NO. HV57	PMT	1Y										I			RRC	RRC-IRCP	135823	C
1,261	ERU -57 -CV	ERU-HV5700102	INSPECT CONTROL VALVE NO. HV57	PMT	1Y										I			RRC	RRC-IRCP	135824	C
1,262	ERU -57 -CV	ERU-HV5700103	INSPECT CONTROL VALVE NO. HV57	PMT	1Y										I			RRC	RRC-IRCP	135825	C
1,263	ERU -57 -CV	ERU-HV5700301	INSPECT CONTROL VALVE NO. HV57	PMT	1Y										I			RRC	RRC-IRCP	135826	C
1,264	ERU -57 -CV	ERU-HV5700302	INSPECT CONTROL VALVE NO. HV57	PMT	1Y										I			RRC	RRC-IRCP	135827	C
1,265	ERU -57 -CV	ERU-HV5700601	INSPECT CONTROL VALVE NO. HV57	PMT	1Y										I			RRC	RRC-IRCP	135828	C
1,266	ERU -57 -CV	ERU-HV5701002	INSPECT CONTROL VALVE NO. HV57	PMT	1Y										I			RRC	RRC-IRCP	135829	C
1,267	ERU -57 -CV	ERU-HV5701302	INSPECT CONTROL VALVE NO. HV57	PMT	1Y										I			RRC	RRC-IRCP	135830	C
1,268	ERU -57 -CV	ERU-HV5701304	INSPECT CONTROL VALVE NO. HV57	PMT	1Y										I			RRC	RRC-IRCP	135831	C
1,269	ERU -57 -CV	ERU-HV5701305	INSPECT CONTROL VALVE NO. HV57	PMT	1Y										I			RRC	RRC-IRCP	135832	C
1,270	ERU -57 -CV	ERU-HV5701306	INSPECT CONTROL VALVE NO. HV57	PMT	1Y										I			RRC	RRC-IRCP	135833	C
1,271	ERU -57 -CV	ERU-HV5701307	INSPECT CONTROL VALVE NO. HV57	PMT	1Y										I			RRC	RRC-IRCP	135834	C
1,272	ERU -58 -CV	ERU-HV5800101	INSPECT CONTROL VALVE NO. HV58	PMT	1Y										I			RRC	RRC-IRCP	135835	C
1,273	ERU -58 -CV	ERU-HV5800301	INSPECT CONTROL VALVE NO. HV58	PMT	1Y										I			RRC	RRC-IRCP	135836	C
1,274	ERU -58 -CV	ERU-HV5801501	INSPECT CONTROL VALVE NO. HV58	PMT	1Y										I			RRC	RRC-IRCP	135855	C
1,275	ERU -58 -CV	ERU-HV5801601	INSPECT CONTROL VALVE NO. HV58	PMT	1Y										I			RRC	RRC-IRCP	135837	C
1,276	ERU -58 -CV	ERU-HV5804901	INSPECT CONTROL VALVE NO. HV58	PMT	1Y										I			RRC	RRC-IRCP	135838	C
1,277	ERU -57 -57K002	ERU-LT5251210A	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y			I										RRC	RRC-IRCP	134963	B
1,278	ERU -57 -57K002	ERU-LT5251810B	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y			I										RRC	RRC-IRCP	134964	B
1,279	ERU -54 -LEVEL	ERU-LT5400201	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134861	C
1,280	ERU -54 -LEVEL	ERU-LT5400202	INSP. FIELD INST. (ต่อกูปกรณ์)	INS	1Y		I											RRC	RRC-IRCP	134862	C
1,281	ERU -54 -LEVEL	ERU-LT5400202	LT5400202-FULL FUN TEST PT & P	PMT	5Y												F	RRC	RRC-IRCP	260613	C
1,282	ERU -54 -LEVEL	ERU-LT5400203	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y			I										RRC	RRC-IRCP	134967	C
1,283	ERU -54 -LEVEL	ERU-LT5400301	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y			I										RRC	RRC-IRCP	134968	C
1,284	ERU -54 -LEVEL	ERU-LT5400701	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y			I										RRC	RRC-IRCP	134969	C
1,285	ERU -54 -LEVEL	ERU-LT5400702	INSP. FIELD INST. (ต่อกูปกรณ์)	INS	1Y		I											RRC	RRC-IRCP	134863	C
1,286	ERU -54 -LEVEL	ERU-LT5400702	LT5400702-FULL FUN TEST PT & P	PMT	5Y												F	RRC	RRC-IRCP	260614	C
1,287	ERU -54 -LEVEL	ERU-LT5400703	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134864	C
1,288	ERU -54 -LEVEL	ERU-LT5400704	INSP. FIELD INST. (ต่อกูปกรณ์)	INS	1Y			I										RRC	RRC-IRCP	134970	C
1,289	ERU -54 -LEVEL	ERU-LT5400704	LT5400704-FULLFUN TEST LEV. RA	PMT	5Y												F	RRC	RRC-IRCP	260420	C
1,290	ERU -54 -LEVEL	ERU-LT5400901	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134865	C
1,291	ERU -54 -LEVEL	ERU-LT5400902A	INSP. FIELD INST. (ต่อกูปกรณ์)	INS	1Y		I											RRC	RRC-IRCP	134866	C
1,292	ERU -54 -LEVEL	ERU-LT5400902A	LT5400902A-FULL FUN TEST PT &	PMT	5Y												F	RRC	RRC-IRCP	260615	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,293	ERU -54 -LEVEL	ERU-LT5400902B	INSP. FIELD INST. (ต่อกูปกรณ์)	INS	1Y		I											RRC	RRC-IRCP	134867	C
1,294	ERU -54 -LEVEL	ERU-LT5400902B	LT5400902B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260616	C
1,295	ERU -54 -LEVEL	ERU-LT5400902C	INSP. FIELD INST. (ต่อกูปกรณ์)	INS	1Y		I											RRC	RRC-IRCP	134868	C
1,296	ERU -54 -LEVEL	ERU-LT5400902C	LT5400902C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260617	C
1,297	ERU -54 -LEVEL	ERU-LT5401001	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134869	C
1,298	ERU -54 -LEVEL	ERU-LT5401002	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134870	C
1,299	ERU -54 -LEVEL	ERU-LT5401003	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y			I										RRC	RRC-IRCP	134971	C
1,300	ERU -54 -LEVEL	ERU-LT5401101	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y			I										RRC	RRC-IRCP	134972	C
1,301	ERU -54 -LEVEL	ERU-LT5401102	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134871	C
1,302	ERU -54 -LEVEL	ERU-LT5401103	INSP. FIELD INST. (ต่อกูปกรณ์)	INS	1Y		I											RRC	RRC-IRCP	134872	C
1,303	ERU -54 -LEVEL	ERU-LT5401103	LT5401103-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IRCP	260622	C
1,304	ERU -54 -LEVEL	ERU-LT5401104	INSP. FIELD INST. (ต่อกูปกรณ์)	INS	1Y			I										RRC	RRC-IRCP	134973	C
1,305	ERU -54 -LEVEL	ERU-LT5401104	LT5401104-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IRCP	260421	C
1,306	ERU -54 -LEVEL	ERU-LT5401301	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134873	C
1,307	ERU -54 -LEVEL	ERU-LT5401302	INSP. FIELD INST. (ต่อกูปกรณ์)	INS	1Y		I											RRC	RRC-IRCP	134874	C
1,308	ERU -54 -LEVEL	ERU-LT5401302	LT5401302-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IRCP	260626	C
1,309	ERU -54 -LEVEL	ERU-LT5401303	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y			I										RRC	RRC-IRCP	134974	C
1,310	ERU -54 -LEVEL	ERU-LT5401401	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y			I										RRC	RRC-IRCP	134975	C
1,311	ERU -54 -LEVEL	ERU-LT5401402	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134875	C
1,312	ERU -54 -LEVEL	ERU-LT5401403	INSP. FIELD INST. (ต่อกูปกรณ์)	INS	1Y		I											RRC	RRC-IRCP	134876	C
1,313	ERU -54 -LEVEL	ERU-LT5401403	LT5401403-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IRCP	260627	C
1,314	ERU -54 -LEVEL	ERU-LT5401701	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134877	C
1,315	ERU -54 -LEVEL	ERU-LT5401702	INSP. FIELD INST. (ต่อกูปกรณ์)	INS	1Y		I											RRC	RRC-IRCP	134878	C
1,316	ERU -54 -LEVEL	ERU-LT5401702	LT5401702-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IRCP	260618	C
1,317	ERU -54 -54K001A	ERU-LT5450310A	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y			I										RRC	RRC-IRCP	134965	C
1,318	ERU -54 -54K001B	ERU-LT5450910B	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y			I										RRC	RRC-IRCP	134966	C
1,319	ERU -57 -LEVEL	ERU-LT5700101	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y			I										RRC	RRC-IRCP	134976	C
1,320	ERU -57 -LEVEL	ERU-LT5700201A	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134879	C
1,321	ERU -57 -LEVEL	ERU-LT5700201B	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134880	C
1,322	ERU -57 -LEVEL	ERU-LT5700202A	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134881	C
1,323	ERU -57 -LEVEL	ERU-LT5700202B	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134882	C
1,324	ERU -57 -LEVEL	ERU-LT5700301A	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134883	C
1,325	ERU -57 -LEVEL	ERU-LT5700301B	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134884	C
1,326	ERU -57 -LEVEL	ERU-LT5700302A	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134885	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,327	ERU -57 -LEVEL	ERU-LT5700302B	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134886	C
1,328	ERU -57 -LEVEL	ERU-LT5700401	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134887	C
1,329	ERU -57 -LEVEL	ERU-LT5700701	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y			I										RRC	RRC-IRCP	134977	C
1,330	ERU -57 -LEVEL	ERU-LT5700801	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134888	C
1,331	ERU -57 -LEVEL	ERU-LT5700805	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134889	C
1,332	ERU -57 -LEVEL	ERU-LT5700901	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134890	C
1,333	ERU -57 -LEVEL	ERU-LT5700902	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134891	C
1,334	ERU -57 -LEVEL	ERU-LT5701101	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134892	C
1,335	ERU -57 -LEVEL	ERU-LT5701401	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134893	C
1,336	ERU -57 -LEVEL	ERU-LT5701601	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134894	C
1,337	ERU -57 -LEVEL	ERU-LT5701602A	INSP. FIELD INST. (ต่อกูปกรณ์)	INS	1Y		I											RRC	RRC-IRCP	134895	C
1,338	ERU -57 -LEVEL	ERU-LT5701602A	LT5701602A-FULL FUN TEST PT &	PMT	5Y												F	RRC	RRC-IRCP	260640	C
1,339	ERU -57 -LEVEL	ERU-LT5701602B	INSP. FIELD INST. (ต่อกูปกรณ์)	INS	1Y		I											RRC	RRC-IRCP	134896	C
1,340	ERU -57 -LEVEL	ERU-LT5701602B	LT5701602B-FULL FUN TEST PT &	PMT	5Y												F	RRC	RRC-IRCP	260641	C
1,341	ERU -57 -LEVEL	ERU-LT5701801	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134897	C
1,342	ERU -57 -57K001	ERU-LT5750201	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y			I										RRC	RRC-IRCP	134961	B
1,343	ERU -57 -57K002	ERU-LT5750901	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y			I										RRC	RRC-IRCP	134962	B
1,344	ERU -57 -57X002	ERU-LT5754601	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y			I										RRC	RRC-IRCP	134989	B
1,345	ERU -57 -57X002	ERU-LT5754602	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y			I										RRC	RRC-IRCP	134990	B
1,346	ERU -57 -57X002	ERU-LT5754603	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y			I										RRC	RRC-IRCP	134991	B
1,347	ERU -58 -LEVEL	ERU-LT5800101	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134898	C
1,348	ERU -58 -LEVEL	ERU-LT5800104	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134899	C
1,349	ERU -58 -LEVEL	ERU-LT5800301	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y			I										RRC	RRC-IRCP	134978	C
1,350	ERU -58 -LEVEL	ERU-LT5800302	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y			I										RRC	RRC-IRCP	134979	C
1,351	ERU -58 -LEVEL	ERU-LT5800401	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134900	C
1,352	ERU -58 -LEVEL	ERU-LT5800402	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134901	C
1,353	ERU -58 -LEVEL	ERU-LT5801201	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134902	C
1,354	ERU -58 -LEVEL	ERU-LT5801203	INSP. FIELD INST. (ต่อกูปกรณ์)	PMT	1Y		I											RRC	RRC-IRCP	134903	C
1,355	ERU -58 -LEVEL	ERU-LT5801204A	INSP. FIELD INST. (ต่อกูปกรณ์)	INS	1Y		I											RRC	RRC-IRCP	134904	C
1,356	ERU -58 -LEVEL	ERU-LT5801204A	LT5801204A-FULL FUN TEST PT &	PMT	5Y												F	RRC	RRC-IRCP	260642	C
1,357	ERU -58 -LEVEL	ERU-LT5801204B	INSP. FIELD INST. (ต่อกูปกรณ์)	INS	1Y		I											RRC	RRC-IRCP	134905	C
1,358	ERU -58 -LEVEL	ERU-LT5801204B	LT5801204B-FULL FUN TEST PT &	PMT	5Y												F	RRC	RRC-IRCP	260643	C
1,359	ERU -58 -LEVEL	ERU-LT5801204C	INSP. FIELD INST. (ต่อกูปกรณ์)	INS	1Y		I											RRC	RRC-IRCP	134906	C
1,360	ERU -58 -LEVEL	ERU-LT5801204C	LT5801204C-FULL FUN TEST PT &	PMT	5Y												F	RRC	RRC-IRCP	260644	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,361	ERU -58 -LEVEL	ERU-LT5801501	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134980	C
1,362	ERU -58 -LEVEL	ERU-LT5802001	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134907	C
1,363	ERU -58 -LEVEL	ERU-LT5802101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134908	C
1,364	ERU -58 -LEVEL	ERU-LT5802301	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134909	C
1,365	ERU -58 -LEVEL	ERU-LT5802401	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134910	C
1,366	ERU -58 -LEVEL	ERU-LT5802501	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134911	C
1,367	ERU -58 -LEVEL	ERU-LT5802502	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134912	C
1,368	ERU -58 -LEVEL	ERU-LT5802503	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134913	C
1,369	ERU -58 -LEVEL	ERU-LT5802701	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134914	C
1,370	ERU -58 -LEVEL	ERU-LT5802702A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y		I											RRC	RRC-IRCP	134915	C
1,371	ERU -58 -LEVEL	ERU-LT5802702A	LT5802702A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260649	C
1,372	ERU -58 -LEVEL	ERU-LT5802702B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y		I											RRC	RRC-IRCP	134916	C
1,373	ERU -58 -LEVEL	ERU-LT5802702B	LT5802702B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260650	C
1,374	ERU -58 -LEVEL	ERU-LT5802702C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y		I											RRC	RRC-IRCP	134917	C
1,375	ERU -58 -LEVEL	ERU-LT5802702C	LT5802702C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260651	C
1,376	ERU -58 -LEVEL	ERU-LT5802703	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134918	C
1,377	ERU -58 -LEVEL	ERU-LT5803201	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134919	C
1,378	ERU -58 -LEVEL	ERU-LT5803202	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134981	C
1,379	ERU -58 -LEVEL	ERU-LT5803401	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134920	C
1,380	ERU -58 -LEVEL	ERU-LT5803402	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134921	C
1,381	ERU -58 -LEVEL	ERU-LT5803501	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134922	C
1,382	ERU -58 -LEVEL	ERU-LT5803601	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134982	C
1,383	ERU -58 -LEVEL	ERU-LT5803701	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134923	C
1,384	ERU -58 -LEVEL	ERU-LT5803702A	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134924	C
1,385	ERU -58 -LEVEL	ERU-LT5803702B	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134925	C
1,386	ERU -58 -LEVEL	ERU-LT5803702C	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134926	C
1,387	ERU -58 -LEVEL	ERU-LT5803703	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134927	C
1,388	ERU -58 -LEVEL	ERU-LT5803801	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134928	C
1,389	ERU -58 -LEVEL	ERU-LT5803802A	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134929	C
1,390	ERU -58 -LEVEL	ERU-LT5803802B	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134930	C
1,391	ERU -58 -LEVEL	ERU-LT5803802C	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134931	C
1,392	ERU -58 -LEVEL	ERU-LT5803803	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134932	C
1,393	ERU -58 -LEVEL	ERU-LT5803901	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134933	C
1,394	ERU -58 -LEVEL	ERU-LT5803902A	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134934	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,395	ERU -58 -LEVEL	ERU-LT5803902B	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134935	C
1,396	ERU -58 -LEVEL	ERU-LT5803902C	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y		I											RRC	RRC-IRCP	134936	C
1,397	ERU -58 -LEVEL	ERU-LT5803903	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134937	C
1,398	ERU -58 -LEVEL	ERU-LT5804601	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134983	C
1,399	ERU -58 -LEVEL	ERU-LT5804602	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134984	C
1,400	ERU -58 -LEVEL	ERU-LT5804603	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134938	C
1,401	ERU -58 -LEVEL	ERU-LT5804701	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134939	C
1,402	ERU -58 -LEVEL	ERU-LT5804801	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134940	C
1,403	ERU -58 -LEVEL	ERU-LT5804802	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134985	C
1,404	ERU -58 -LEVEL	ERU-LT5804901	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134941	C
1,405	ERU -58 -LEVEL	ERU-LT5804902A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y			I										RRC	RRC-IRCP	134942	C
1,406	ERU -58 -LEVEL	ERU-LT5804902A	LT5804902A-FULL FUN TEST PT &	PMT	5Y												F	RRC	RRC-IRCP	260661	C
1,407	ERU -58 -LEVEL	ERU-LT5804902B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y			I										RRC	RRC-IRCP	134943	C
1,408	ERU -58 -LEVEL	ERU-LT5804902B	LT5804902B-FULL FUN TEST PT &	PMT	5Y												F	RRC	RRC-IRCP	260662	C
1,409	ERU -58 -LEVEL	ERU-LT5804902C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y			I										RRC	RRC-IRCP	134944	C
1,410	ERU -58 -LEVEL	ERU-LT5804902C	LT5804902C-FULL FUN TEST PT &	PMT	5Y												F	RRC	RRC-IRCP	260663	C
1,411	ERU -58 -LEVEL	ERU-LT5804903	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134945	C
1,412	ERU -58 -LEVEL	ERU-LT5805001	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134946	C
1,413	ERU -58 -LEVEL	ERU-LT5805002A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y			I										RRC	RRC-IRCP	134947	C
1,414	ERU -58 -LEVEL	ERU-LT5805002A	LT5805002A-FULL FUN TEST PT &	PMT	5Y												F	RRC	RRC-IRCP	260664	C
1,415	ERU -58 -LEVEL	ERU-LT5805002B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y			I										RRC	RRC-IRCP	134948	C
1,416	ERU -58 -LEVEL	ERU-LT5805002B	LT5805002B-FULL FUN TEST PT &	PMT	5Y												F	RRC	RRC-IRCP	260665	C
1,417	ERU -58 -LEVEL	ERU-LT5805002C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y			I										RRC	RRC-IRCP	134949	C
1,418	ERU -58 -LEVEL	ERU-LT5805002C	LT5805002C-FULL FUN TEST PT &	PMT	5Y												F	RRC	RRC-IRCP	260666	C
1,419	ERU -58 -LEVEL	ERU-LT5805003	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134950	C
1,420	ERU -58 -LEVEL	ERU-LT5805101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134951	C
1,421	ERU -58 -LEVEL	ERU-LT5805801	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134952	C
1,422	ERU -58 -LEVEL	ERU-LT5805901	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134986	C
1,423	ERU -58 -LEVEL	ERU-LT5806001	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134953	C
1,424	ERU -58 -58K001	ERU-LT5850201	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134955	C
1,425	ERU -58 -58K001	ERU-LT5850501	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134956	C
1,426	ERU -58 -58K401	ERU-LT5851401	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134958	C
1,427	ERU -58 -58K401	ERU-LT5851701	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134957	C
1,428	ERU -58 -58K501	ERU-LT5852101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134960	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,429	ERU -58 -58K501	ERU-LT5852301	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134959	C
1,430	ERU -57 -57X002	ERU-LT5852501	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134988	B
1,431	ERU -58 -58X003	ERU-LT5852701	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134987	C
1,432	ERU -59 -LEVEL	ERU-LT5900101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IRCP	134954	C
1,433	ERU -58 -CV	ERU-LV5800401	INSPECT CONTROL VALVE NO. LV58	PMT	1Y									I				RRC	RRC-IRCP	135839	C
1,434	ERU -58 -CV	ERU-LV5800402	INSPECT CONTROL VALVE NO. LV58	PMT	1Y									I				RRC	RRC-IRCP	132901	C
1,435	ERU -58 -CV	ERU-LV5801201	INSPECT CONTROL VALVE NO. LV58	PMT	1Y									I				RRC	RRC-IRCP	132902	C
1,436	ERU -58 -CV	ERU-LV5801203	INSPECT CONTROL VALVE NO. LV58	PMT	1Y										I			RRC	RRC-IRCP	132903	C
1,437	ERU -58 -CV	ERU-LV5801501	INSPECT CONTROL VALVE NO. LV58	PMT	1Y										I			RRC	RRC-IRCP	132904	C
1,438	ERU -58 -CV	ERU-LV5802001	INSPECT CONTROL VALVE NO. LV58	PMT	1Y										I			RRC	RRC-IRCP	132905	C
1,439	ERU -58 -CV	ERU-LV5802503	INSPECT CONTROL VALVE NO. LV58	PMT	1Y										I			RRC	RRC-IRCP	132906	C
1,440	ERU -58 -CV	ERU-LV5802701	INSPECT CONTROL VALVE NO. LV58	PMT	1Y										I			RRC	RRC-IRCP	132907	C
1,441	ERU -58 -CV	ERU-LV5802703	INSPECT CONTROL VALVE NO. LV58	PMT	1Y										I			RRC	RRC-IRCP	132908	C
1,442	ERU -58 -CV	ERU-LV5803202	INSPECT CONTROL VALVE NO. LV58	PMT	1Y										I			RRC	RRC-IRCP	132909	C
1,443	ERU -58 -CV	ERU-LV5803701	INSPECT CONTROL VALVE NO. LV58	PMT	1Y									I				RRC	RRC-IRCP	135840	C
1,444	ERU -58 -CV	ERU-LV5803801	INSPECT CONTROL VALVE NO. LV58	PMT	1Y									I				RRC	RRC-IRCP	135841	C
1,445	ERU -58 -CV	ERU-LV5803901	INSPECT CONTROL VALVE NO. LV58	PMT	1Y									I				RRC	RRC-IRCP	135842	C
1,446	ERU -58 -CV	ERU-LV5804603	INSPECT CONTROL VALVE NO. LV58	PMT	1Y									I				RRC	RRC-IRCP	135843	C
1,447	ERU -58 -CV	ERU-LV5804801	INSPECT CONTROL VALVE NO. LV58	PMT	1Y									I				RRC	RRC-IRCP	135844	C
1,448	ERU -58 -CV	ERU-LV5804802	INSPECT CONTROL VALVE NO. LV58	PMT	1Y									I				RRC	RRC-IRCP	135845	C
1,449	ERU -58 -CV	ERU-LV5804901	INSPECT CONTROL VALVE NO. LV58	PMT	1Y									I				RRC	RRC-IRCP	135846	C
1,450	ERU -58 -CV	ERU-LV5805001	INSPECT CONTROL VALVE NO. LV58	PMT	1Y									I				RRC	RRC-IRCP	135847	C
1,451	ERU -58 -CV	ERU-LV5805101	INSPECT CONTROL VALVE NO. LV58	PMT	1Y									I				RRC	RRC-IRCP	135848	C
1,452	ERU -58 -CV	ERU-LV5805901	INSPECT CONTROL VALVE NO. LV58	PMT	1Y									I				RRC	RRC-IRCP	135849	C
1,453	ERU -58 -CV	ERU-LV5806001	INSPECT CONTROL VALVE NO. LV58	PMT	1Y									I				RRC	RRC-IRCP	135850	C
1,454	ERU -54 -CV	ERU-PCV5401901	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y										I			RRC	RRC-IRCP	135912	C
1,455	ERU -54 -CV	ERU-PCV5401902	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y										I			RRC	RRC-IRCP	135913	C
1,456	ERU -54 -54K001A	ERU-PCV5450208A	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	136118	C
1,457	ERU -54 -54K001A	ERU-PCV5450210A	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	136126	C
1,458	ERU -54 -54K001A	ERU-PCV5450224A	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	136120	C
1,459	ERU -54 -54K001A	ERU-PCV5450226A	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	136122	C
1,460	ERU -54 -54K001A	ERU-PCV5450402A	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	136128	C
1,461	ERU -54 -54K001A	ERU-PCV5450605A	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	136124	C
1,462	ERU -54 -54K001B	ERU-PCV5450808B	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	136119	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,463	ERU -54 -54K001B	ERU-PCV5450810B	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IRCP	136127	C
1,464	ERU -54 -54K001B	ERU-PCV5450824B	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IRCP	136121	C
1,465	ERU -54 -54K001B	ERU-PCV5450826B	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IRCP	136123	C
1,466	ERU -54 -54K001B	ERU-PCV5451002B	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IRCP	136129	C
1,467	ERU -54 -54K001B	ERU-PCV5451205B	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IRCP	136125	C
1,468	ERU -57 -57K001	ERU-PCV5750201	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IRCP	136104	B
1,469	ERU -57 -57K001	ERU-PCV5750202	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IRCP	136106	B
1,470	ERU -57 -57K001	ERU-PCV5750203	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IRCP	136105	B
1,471	ERU -57 -57K002	ERU-PCV5750901	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IRCP	136109	B
1,472	ERU -57 -57K002	ERU-PCV5750902	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IRCP	136111	B
1,473	ERU -57 -57K002	ERU-PCV5750903	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IRCP	136110	B
1,474	ERU -58 -CV	ERU-PCV5800304	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	135914	C
1,475	ERU -58 -CV	ERU-PCV5800305	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	135915	C
1,476	ERU -58 -CV	ERU-PCV5802401	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	135916	C
1,477	ERU -58 -CV	ERU-PCV5852501	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	135917	C
1,478	ERU -58 -CV	ERU-PCV5852502	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	135918	C
1,479	ERU -58 -58K101	ERU-PDCV5850705	INSPECT CONTROL VALVE NO. PDCV	PMT	1Y												I	RRC	RRC-IRCP	136098	C
1,480	ERU -57 -57K002	ERU-PDIT110	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y							I						RRC	RRC-IRCP	135364	B
1,481	ERU -57 -57K002	ERU-PDIT116	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y							I						RRC	RRC-IRCP	135365	B
1,482	ERU -54 -PRESS	ERU-PDT5400101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y													RRC	RRC-IRCP	134992	C
1,483	ERU -54 -PRESS	ERU-PDT5400403	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y													RRC	RRC-IRCP	134993	C
1,484	ERU -54 -PRESS	ERU-PDT5400404	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y													RRC	RRC-IRCP	134994	C
1,485	ERU -54 -PRESS	ERU-PDT5400601	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y													RRC	RRC-IRCP	134995	C
1,486	ERU -54 -PRESS	ERU-PDT5400602	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y													RRC	RRC-IRCP	134996	C
1,487	ERU -54 -PRESS	ERU-PDT5400605	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y													RRC	RRC-IRCP	134997	C
1,488	ERU -54 -PRESS	ERU-PDT5400606	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y													RRC	RRC-IRCP	134998	C
1,489	ERU -54 -PRESS	ERU-PDT5400607	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y													RRC	RRC-IRCP	134999	C
1,490	ERU -54 -PRESS	ERU-PDT5400906	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y													RRC	RRC-IRCP	135000	C
1,491	ERU -54 -PRESS	ERU-PDT5400907	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y													RRC	RRC-IRCP	135001	C
1,492	ERU -54 -PRESS	ERU-PDT5401201	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y													RRC	RRC-IRCP	135002	C
1,493	ERU -54 -PRESS	ERU-PDT5401305	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y													RRC	RRC-IRCP	135003	C
1,494	ERU -54 -PRESS	ERU-PDT5401306	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y													RRC	RRC-IRCP	135004	C
1,495	ERU -54 -PRESS	ERU-PDT5401402	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y													RRC	RRC-IRCP	135005	C
1,496	ERU -54 -PRESS	ERU-PDT5401916	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y													RRC	RRC-IRCP	135006	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,497	ERU -54 -54K001A	ERU-PDT5450103A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	135391	C
1,498	ERU -54 -54K001A	ERU-PDT5450331A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	135393	C
1,499	ERU -54 -54K001A	ERU-PDT5450511A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	135395	C
1,500	ERU -54 -54K001B	ERU-PDT5450703B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	135392	C
1,501	ERU -54 -54K001B	ERU-PDT5450931B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	135394	C
1,502	ERU -54 -54K001B	ERU-PDT5451111B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	135396	C
1,503	ERU -57 -PRESS	ERU-PDT5700101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135007	C
1,504	ERU -57 -PRESS	ERU-PDT5700102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135008	C
1,505	ERU -57 -PRESS	ERU-PDT5700410	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135009	C
1,506	ERU -57 -PRESS	ERU-PDT5701701	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135010	C
1,507	ERU -57 -PRESS	ERU-PDT5701702	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135011	C
1,508	ERU -57 -PRESS	ERU-PDT5701703	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135012	C
1,509	ERU -57 -PRESS	ERU-PDT5701704	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135013	C
1,510	ERU -57 -PRESS	ERU-PDT5701705	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135014	C
1,511	ERU -57 -PRESS	ERU-PDT5701706	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135015	C
1,512	ERU -57 -PRESS	ERU-PDT5750101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135016	C
1,513	ERU -57 -57K001	ERU-PDT5750102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135017	B
1,514	ERU -57 -57K001	ERU-PDT5750103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135018	B
1,515	ERU -57 -57K001	ERU-PDT5750104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135019	B
1,516	ERU -57 -57K001	ERU-PDT5750201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135020	B
1,517	ERU -57 -57K001	ERU-PDT5750301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	135359	B
1,518	ERU -57 -57K001	ERU-PDT5750302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	135360	B
1,519	ERU -57 -57K001	ERU-PDT5750303	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	135361	B
1,520	ERU -57 -57K002	ERU-PDT5750801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135021	B
1,521	ERU -57 -PRESS	ERU-PDT5750802	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135022	C
1,522	ERU -57 -57K002	ERU-PDT5750803	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135023	B
1,523	ERU -57 -PRESS	ERU-PDT5750804	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135024	C
1,524	ERU -57 -57K002	ERU-PDT5750901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135025	B
1,525	ERU -57 -57K002	ERU-PDT5751001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	135366	B
1,526	ERU -57 -57K002	ERU-PDT5751002	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	135367	B
1,527	ERU -57 -57K002	ERU-PDT5751003	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	135368	B
1,528	ERU -58 -PRESS	ERU-PDT5800804	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135026	C
1,529	ERU -58 -PRESS	ERU-PDT5801601	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y			I										RRC	RRC-IRCP	135027	C
1,530	ERU -58 -PRESS	ERU-PDT5801601	PDT5801601-FULL RUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260645	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,531	ERU -58 -PRESS	ERU-PDT5802101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135028	C
1,532	ERU -58 -PRESS	ERU-PDT5802401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135029	C
1,533	ERU -58 -PRESS	ERU-PDT5802701	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135030	C
1,534	ERU -58 -58K101	ERU-PDT5802804	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135031	C
1,535	ERU -58 -58K101	ERU-PDT5802805	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	135340	C
1,536	ERU -58 -PRESS	ERU-PDT5803601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135032	C
1,537	ERU -58 -PRESS	ERU-PDT5804003	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135033	C
1,538	ERU -58 -PRESS	ERU-PDT5804004	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135034	C
1,539	ERU -58 -PRESS	ERU-PDT5804105	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135035	C
1,540	ERU -58 -PRESS	ERU-PDT5804501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135036	C
1,541	ERU -58 -PRESS	ERU-PDT5804502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135037	C
1,542	ERU -58 -PRESS	ERU-PDT5804503	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135038	C
1,543	ERU -58 -PRESS	ERU-PDT5804602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135039	C
1,544	ERU -58 -PRESS	ERU-PDT5805204	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135040	C
1,545	ERU -58 -PRESS	ERU-PDT5805304	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135041	C
1,546	ERU -58 -PRESS	ERU-PDT5805802	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135042	C
1,547	ERU -58 -PRESS	ERU-PDT5806004	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135043	C
1,548	ERU -58 -58K001	ERU-PDT5850203	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135044	C
1,549	ERU -58 -58K001	ERU-PDT5850204	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135045	C
1,550	ERU -58 -58K001	ERU-PDT5850205	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135046	C
1,551	ERU -58 -58K001	ERU-PDT5850206	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135047	C
1,552	ERU -58 -58K001	ERU-PDT5850207A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135048	C
1,553	ERU -58 -58K001	ERU-PDT5850207B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135049	C
1,554	ERU -58 -58K001	ERU-PDT5850207C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135050	C
1,555	ERU -58 -58K001	ERU-PDT5850208A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135051	C
1,556	ERU -58 -58K001	ERU-PDT5850208B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135052	C
1,557	ERU -58 -58K001	ERU-PDT5850208C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135053	C
1,558	ERU -58 -58K001	ERU-PDT5850504	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135054	C
1,559	ERU -58 -58K101	ERU-PDT5850701	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	135341	C
1,560	ERU -58 -58K101	ERU-PDT5850703A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	135342	C
1,561	ERU -58 -58K101	ERU-PDT5850703B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	135343	C
1,562	ERU -58 -58K101	ERU-PDT5850703C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	135344	C
1,563	ERU -58 -58K101	ERU-PDT5850710	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	135345	C
1,564	ERU -58 -PRESS	ERU-PDT5851403	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135055	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,565	ERU -58 -PRESS	ERU-PDT5851404	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135056	C
1,566	ERU -58 -PRESS	ERU-PDT5851405	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135057	C
1,567	ERU -58 -PRESS	ERU-PDT5851407A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	135058	C
1,568	ERU -58 -PRESS	ERU-PDT5851407B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135059	C
1,569	ERU -58 -PRESS	ERU-PDT5851407C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135060	C
1,570	ERU -58 -PRESS	ERU-PDT5851408A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135061	C
1,571	ERU -58 -PRESS	ERU-PDT5851408B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135062	C
1,572	ERU -58 -PRESS	ERU-PDT5851408C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135063	C
1,573	ERU -58 -PRESS	ERU-PDT5851409A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135064	C
1,574	ERU -58 -PRESS	ERU-PDT5851409B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135065	C
1,575	ERU -58 -PRESS	ERU-PDT5851410	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135066	C
1,576	ERU -58 -PRESS	ERU-PDT5851411	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135067	C
1,577	ERU -58 -58K401	ERU-PDT5851704	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135068	C
1,578	ERU -58 -PRESS	ERU-PDT5852003	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135069	C
1,579	ERU -58 -PRESS	ERU-PDT5852004A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135070	C
1,580	ERU -58 -PRESS	ERU-PDT5852004B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135071	C
1,581	ERU -58 -PRESS	ERU-PDT5852005	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135072	C
1,582	ERU -58 -PRESS	ERU-PDT5852007A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135073	C
1,583	ERU -58 -PRESS	ERU-PDT5852007B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135074	C
1,584	ERU -58 -PRESS	ERU-PDT5852007C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135075	C
1,585	ERU -58 -PRESS	ERU-PDT5852008A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135076	C
1,586	ERU -58 -PRESS	ERU-PDT5852008B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135077	C
1,587	ERU -58 -PRESS	ERU-PDT5852008C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135078	C
1,588	ERU -58 -PRESS	ERU-PDT5852009A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135079	C
1,589	ERU -58 -PRESS	ERU-PDT5852009B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135080	C
1,590	ERU -58 -PRESS	ERU-PDT5852010	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135081	C
1,591	ERU -58 -PRESS	ERU-PDT5852011	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135082	C
1,592	ERU -58 -58K501	ERU-PDT5852304	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	135083	C
1,593	ERU -54 -CV	ERU-PDV5401402	INSPECT CONTROL VALVE NO. PDV5	PMT	1Y										I			RRC	RRC-IRCP	135851	C
1,594	ERU -57 -57K001	ERU-PDV5750101	INSPECT CONTROL VALVE NO. PDV5	PMT	1Y												I	RRC	RRC-IRCP	136107	B
1,595	ERU -57 -57K002	ERU-PDV5750801	INSPECT CONTROL VALVE NO. PDV5	PMT	1Y												I	RRC	RRC-IRCP	136112	B
1,596	ERU -58 -CV	ERU-PDV5802701	INSPECT CONTROL VALVE NO. PDV5	PMT	1Y										I			RRC	RRC-IRCP	135852	C
1,597	ERU -58 -CV	ERU-PDV5805802	INSPECT CONTROL VALVE NO. PDV5	PMT	1Y										I			RRC	RRC-IRCP	135853	C
1,598	ERU -58 -CV	ERU-PDV5806004	INSPECT CONTROL VALVE NO. PDV5	PMT	1Y										I			RRC	RRC-IRCP	135854	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,599	ERU -58 -58K001	ERU-PDV5850204	INSPECT CONTROL VALVE NO. PDV5	PMT	1Y												I	RRC	RRC-IRCP	136103	C
1,600	ERU -STR-PIPE_RACK	ERU-PR-54-001	INSPECTION PIPE RACK FOR ROPR	INT	6Y				I									ENE	ENE-ENQS	204439	A
1,601	ERU -STR-PIPE_RACK	ERU-PR-57-001	INSPECTION PIPE RACK FOR ROPR	INT	6Y				I									ENE	ENE-ENQS	204440	A
1,602	ERU -STR-PIPE_RACK	ERU-PR-57-002	INSPECTION PIPE RACK FOR ROPR	INT	6Y				I									ENE	ENE-ENQS	204441	A
1,603	ERU -STR-PIPE_RACK	ERU-PR-58-001	INSPECTION PIPE RACK FOR ROPR	INT	6Y				I									ENE	ENE-ENQS	204442	A
1,604	ERU -STR-PIPE_RACK	ERU-PR-58-002	INSPECTION PIPE RACK FOR ROPR	INT	6Y				I									ENE	ENE-ENQS	204443	A
1,605	ERU -54 -PRD	ERU-PSV5400103	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163135	A
1,606	ERU -54 -54F001A	ERU-PSV5400104	Pressure Relief Device Calibra	PMT	5Y						I							RRC	RRC-MRCP	254801	B
1,607	ERU -54 -54F001B	ERU-PSV5400105	Pressure Relief Device Calibra	PMT	5Y						I							RRC	RRC-MRCP	254802	B
1,608	ERU -54 -54D001	ERU-PSV5400201	Pressure Relief Device Calibra	PMT	5Y						I							RRC	RRC-MRCP	163136	B
1,609	ERU -54 -54D001	ERU-PSV5400202	Pressure Relief Device Calibra	PMT	5Y						I							RRC	RRC-MRCP	163137	B
1,610	ERU -54 -54R001A	ERU-PSV5400401	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163141	A
1,611	ERU -54 -54R001B	ERU-PSV5400402	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163142	A
1,612	ERU -54 -54D002	ERU-PSV5400701	Pressure Relief Device Calibra	PMT	5Y						I							RRC	RRC-MRCP	163143	B
1,613	ERU -54 -54D002	ERU-PSV5400702	Pressure Relief Device Calibra	PMT	5Y						I							RRC	RRC-MRCP	163144	B
1,614	ERU -54 -54K001A	ERU-PSV5400901	Pressure Relief Device Calibra	PMT	5Y						I							RRC	RRC-MRCP	163145	B
1,615	ERU -54 -54K001B	ERU-PSV5400902	Pressure Relief Device Calibra	PMT	5Y						I							RRC	RRC-MRCP	163146	B
1,616	ERU -54 -54E009	ERU-PSV5401001	Pressure Relief Device Calibra	PMT	5Y						I							RRC	RRC-MRCP	163147	B
1,617	ERU -54 -54E009	ERU-PSV5401002	Pressure Relief Device Calibra	PMT	5Y						I							RRC	RRC-MRCP	163148	B
1,618	ERU -54 -54R003	ERU-PSV5401201	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163153	A
1,619	ERU -54 -54Q002	ERU-PSV5401301	Pressure Relief Device Calibra	PMT	5Y						I							RRC	RRC-MRCP	163154	B
1,620	ERU -54 -54Q002	ERU-PSV5401302	Pressure Relief Device Calibra	PMT	5Y						I							RRC	RRC-MRCP	163155	B
1,621	ERU -54 -54D006	ERU-PSV5401401	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163156	A
1,622	ERU -54 -54D004	ERU-PSV5401701	Pressure Relief Device Calibra	PMT	5Y						I							RRC	RRC-MRCP	163159	B
1,623	ERU -54 -54D004	ERU-PSV5401702	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163160	B
1,624	ERU -54 -PRD	ERU-PSV5401705	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163163	A
1,625	ERU -54 -54X001	ERU-PSV5402101	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163164	B
1,626	ERU -54 -54X001	ERU-PSV5402102	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163165	B
1,627	ERU -54 -54K001A	ERU-PSV5450227	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163168	A
1,628	ERU -54 -54K001A	ERU-PSV5450320A	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163169	B
1,629	ERU -54 -54K001A	ERU-PSV5450323	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163170	B
1,630	ERU -54 -54K001A	ERU-PSV5450334A	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163171	B
1,631	ERU -54 -54K001B	ERU-PSV5450920B	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163175	B
1,632	ERU -54 -54K001B	ERU-PSV5450923B	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163176	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,633	ERU -54 -54K001B	ERU-PSV5450934B	Pressure Relief Device Calibra	PMT	5Y						I							RRC	RRC-MRCP	163177	B
1,634	ERU -57 -57E001	ERU-PSV5700102	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163180	A
1,635	ERU -57 -57X001	ERU-PSV5700103	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163181	A
1,636	ERU -57 -PRD	ERU-PSV5700104	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163182	A
1,637	ERU -57 -PRD	ERU-PSV5700105	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163183	A
1,638	ERU -57 -57R001A	ERU-PSV5700201	Pressure Relief Device Calibra	PMT	5Y						I							RRC	RRC-MRCP	163184	B
1,639	ERU -57 -57R001B	ERU-PSV5700202	Pressure Relief Device Calibra	PMT	5Y						I							RRC	RRC-MRCP	163185	B
1,640	ERU -57 -57R002A	ERU-PSV5700301	Pressure Relief Device Calibra	PMT	5Y						I							RRC	RRC-MRCP	163178	A
1,641	ERU -57 -57R002B	ERU-PSV5700302	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163186	B
1,642	ERU -57 -57F001	ERU-PSV5700401	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163187	A
1,643	ERU -57 -57C002	ERU-PSV5700901	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163197	B
1,644	ERU -57 -57C002	ERU-PSV5700902	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163198	B
1,645	ERU -57 -57C002	ERU-PSV5700903	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163199	B
1,646	ERU -57 -57C002	ERU-PSV5700904	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163200	B
1,647	ERU -57 -57E005	ERU-PSV5701202	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163210	A
1,648	ERU -57 -57R003	ERU-PSV5701301	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163211	A
1,649	ERU -57 -PRD	ERU-PSV5701302	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163212	A
1,650	ERU -57 -PRD	ERU-PSV5701303	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163213	A
1,651	ERU -57 -PRD	ERU-PSV5701701	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163219	B
1,652	ERU -57 -PRD	ERU-PSV5701702	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163220	B
1,653	ERU -57 -57X002	ERU-PSV5754601	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163229	B
1,654	ERU -57 -57X002	ERU-PSV5754602	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163230	B
1,655	ERU -57 -57X002	ERU-PSV5754603	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163231	B
1,656	ERU -57 -57X002	ERU-PSV5754604	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163232	B
1,657	ERU -57 -57X002	ERU-PSV5754605	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MRCP	163233	B
1,658	ERU -57 -57X002	ERU-PSV5754606	Pressure Relief Device Calibra	PMT	5Y									I				RRC	RRC-MRCP	163234	B
1,659	ERU -58 -58C001	ERU-PSV5800101	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163236	A
1,660	ERU -58 -PRD	ERU-PSV5800201	Pressure Relief Device Calibra	PMT	5Y									I				RRC	RRC-MRCP	163237	B
1,661	ERU -58 -PRD	ERU-PSV5800202	Pressure Relief Device Calibra	PMT	5Y									I				RRC	RRC-MRCP	163238	B
1,662	ERU -58 -58P001A	ERU-PSV5800302	Pressure Relief Device Calibra	PMT	5Y									I				RRC	RRC-MRCP	163239	B
1,663	ERU -58 -58P001B	ERU-PSV5800303	Pressure Relief Device Calibra	PMT	5Y									I				RRC	RRC-MRCP	163240	B
1,664	ERU -58 -58C002	ERU-PSV5800401	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163241	A
1,665	ERU -58 -PRD	ERU-PSV5800402	Pressure Relief Device Calibra	PMT	5Y									I				RRC	RRC-MRCP	163242	B
1,666	ERU -58 -PRD	ERU-PSV5800403	Pressure Relief Device Calibra	PMT	5Y									I				RRC	RRC-MRCP	163243	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,667	ERU -58 -58E004	ERU-PSV5800603	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163249	A
1,668	ERU -58 -58E003	ERU-PSV5801202	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163253	A
1,669	ERU -58 -58D001	ERU-PSV5801203	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163254	A
1,670	ERU -58 -58R002A	ERU-PSV5801401	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163257	B
1,671	ERU -58 -58R002B	ERU-PSV5801402	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163258	B
1,672	ERU -58 -58E010B	ERU-PSV5801502	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163260	A
1,673	ERU -58 -58R003	ERU-PSV5801601	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163261	A
1,674	ERU -58 -58D101	ERU-PSV5802103	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163267	A
1,675	ERU -58 -58D102	ERU-PSV5802302	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163268	A
1,676	ERU -58 -58D103	ERU-PSV5802402	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163269	A
1,677	ERU -58 -58D104	ERU-PSV5802701	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163272	A
1,678	ERU -58 -58K101	ERU-PSV5802803	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163277	B
1,679	ERU -58 -58E502	ERU-PSV5804801	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163301	A
1,680	ERU -58 -58E502	ERU-PSV5804802	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163302	A
1,681	ERU -58 -58E502	ERU-PSV5804806	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163305	A
1,682	ERU -58 -58E501	ERU-PSV5805701	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163314	A
1,683	ERU -58 -58D504	ERU-PSV5805801	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163316	A
1,684	ERU -58 -58K001	ERU-PSV5850501	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163325	A
1,685	ERU -58 -58K001	ERU-PSV5850502	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163326	A
1,686	ERU -58 -58K001	ERU-PSV5850504	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163327	A
1,687	ERU -58 -58K001	ERU-PSV5850505	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163328	A
1,688	ERU -58 -58K401	ERU-PSV5851701	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163329	A
1,689	ERU -58 -58K401	ERU-PSV5851702	Pressure Relief Device Calibra	PMT	5Y								I					RRC	RRC-MRCP	163330	A
1,690	ERU -58 -58K401	ERU-PSV5851704	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163331	A
1,691	ERU -58 -58K401	ERU-PSV5851705	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163332	A
1,692	ERU -58 -58K501	ERU-PSV5852301	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163333	A
1,693	ERU -58 -58K501	ERU-PSV5852302	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163334	A
1,694	ERU -58 -58K501	ERU-PSV5852304	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163335	A
1,695	ERU -58 -58K501	ERU-PSV5852305	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163336	A
1,696	ERU -58 -58K001	ERU-PSV5852502	Pressure Relief Device Calibra	PMT	5Y								I					RRC	RRC-MRCP	163338	B
1,697	ERU -58 -58K003	ERU-PSV5852701	Pressure Relief Device Calibra	PMT	5Y								I					RRC	RRC-MRCP	163342	B
1,698	ERU -59 -59E001	ERU-PSV5900106	Pressure Relief Device Calibra	PMT	10Y											I		RRC	RRC-MRCP	163346	B
1,699	ERU -54 -PRESS	ERU-PT5400102	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135084	C
1,700	ERU -54 -PRESS	ERU-PT5400103	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135085	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,701	ERU -54 -PRESS	ERU-PT5400104	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135086	C
1,702	ERU -54 -PRESS	ERU-PT5400105	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135087	C
1,703	ERU -54 -PRESS	ERU-PT5400106	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135088	C
1,704	ERU -54 -PRESS	ERU-PT5400201	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135089	C
1,705	ERU -54 -PRESS	ERU-PT5400301	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135090	C
1,706	ERU -54 -PRESS	ERU-PT5400302	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135091	C
1,707	ERU -54 -PRESS	ERU-PT5400303	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135092	C
1,708	ERU -54 -PRESS	ERU-PT5400401	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135093	C
1,709	ERU -54 -PRESS	ERU-PT5400402	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135094	C
1,710	ERU -54 -PRESS	ERU-PT5400405	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135095	C
1,711	ERU -54 -PRESS	ERU-PT5400501	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135096	C
1,712	ERU -54 -PRESS	ERU-PT5400603	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135097	C
1,713	ERU -54 -PRESS	ERU-PT5400604	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135098	C
1,714	ERU -54 -PRESS	ERU-PT5400611	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135099	C
1,715	ERU -54 -PRESS	ERU-PT5400701	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135100	C
1,716	ERU -54 -PRESS	ERU-PT5400702	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135101	C
1,717	ERU -54 -54P004	ERU-PT5400801A	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	135397	C
1,718	ERU -54 -54P004	ERU-PT5400801B	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	135398	C
1,719	ERU -54 -54P002	ERU-PT5400802A	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	135409	B
1,720	ERU -54 -54P002	ERU-PT5400802B	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	135410	B
1,721	ERU -54 -PRESS	ERU-PT5400901	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135102	C
1,722	ERU -54 -PRESS	ERU-PT5400902	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135103	C
1,723	ERU -54 -PRESS	ERU-PT5400903	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135104	C
1,724	ERU -54 -PRESS	ERU-PT5401001	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135105	C
1,725	ERU -54 -PRESS	ERU-PT5401002	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135106	C
1,726	ERU -54 -PRESS	ERU-PT5401003A	INSP. FIELD INST. (ห้ครูปกรณ์)	INS	1Y				I									RRC	RRC-IRCP	135107	C
1,727	ERU -54 -PRESS	ERU-PT5401003A	PT5401003A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260619	C
1,728	ERU -54 -PRESS	ERU-PT5401003B	INSP. FIELD INST. (ห้ครูปกรณ์)	INS	1Y				I									RRC	RRC-IRCP	135108	C
1,729	ERU -54 -PRESS	ERU-PT5401003B	PT5401003B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260620	C
1,730	ERU -54 -PRESS	ERU-PT5401003C	INSP. FIELD INST. (ห้ครูปกรณ์)	INS	1Y				I									RRC	RRC-IRCP	135109	C
1,731	ERU -54 -PRESS	ERU-PT5401003C	PT5401003C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260621	C
1,732	ERU -54 -PRESS	ERU-PT5401004	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135110	C
1,733	ERU -54 -PRESS	ERU-PT5401009	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135111	C
1,734	ERU -54 -PRESS	ERU-PT5401103	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	135112	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,735	ERU -54 -PRESS	ERU-PT5401108	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135113	C
1,736	ERU -54 -54P005	ERU-PT5401109A	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	135399	B
1,737	ERU -54 -54P005	ERU-PT5401109B	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	135400	B
1,738	ERU -54 -PRESS	ERU-PT5401202	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135114	C
1,739	ERU -54 -PRESS	ERU-PT5401301	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135115	C
1,740	ERU -54 -PRESS	ERU-PT5401302	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135116	C
1,741	ERU -54 -PRESS	ERU-PT5401303A	INSP. FIELD INST. (ห้ครูปกรณ์)	INS	1Y					I								RRC	RRC-IRCP	135117	C
1,742	ERU -54 -PRESS	ERU-PT5401303A	PT5401303A-FULL FUN TEST PT &	PMT	5Y												F	RRC	RRC-IRCP	260623	C
1,743	ERU -54 -PRESS	ERU-PT5401303B	INSP. FIELD INST. (ห้ครูปกรณ์)	INS	1Y					I								RRC	RRC-IRCP	135118	C
1,744	ERU -54 -PRESS	ERU-PT5401303B	PT5401303B-FULL FUN TEST PT &	PMT	5Y												F	RRC	RRC-IRCP	260624	C
1,745	ERU -54 -PRESS	ERU-PT5401303C	INSP. FIELD INST. (ห้ครูปกรณ์)	INS	1Y					I								RRC	RRC-IRCP	135119	C
1,746	ERU -54 -PRESS	ERU-PT5401303C	PT5401303C-FULL FUN TEST PT &	PMT	5Y												F	RRC	RRC-IRCP	260625	C
1,747	ERU -54 -PRESS	ERU-PT5401401	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135120	C
1,748	ERU -54 -PRESS	ERU-PT5401403	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135121	C
1,749	ERU -54 -PRESS	ERU-PT5401504	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135122	C
1,750	ERU -54 -PRESS	ERU-PT5401606	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135123	C
1,751	ERU -54 -PRESS	ERU-PT5401701	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135124	C
1,752	ERU -54 -PRESS	ERU-PT5401708	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135125	C
1,753	ERU -54 -PRESS	ERU-PT5401801	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135126	C
1,754	ERU -54 -PRESS	ERU-PT5401802	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135127	C
1,755	ERU -54 -PRESS	ERU-PT5401803	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135128	C
1,756	ERU -54 -PRESS	ERU-PT5401804	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135129	C
1,757	ERU -54 -PRESS	ERU-PT5401805	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135130	C
1,758	ERU -54 -PRESS	ERU-PT5401806	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135131	C
1,759	ERU -54 -PRESS	ERU-PT5401807	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135132	C
1,760	ERU -54 -PRESS	ERU-PT5401808	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135133	C
1,761	ERU -54 -PRESS	ERU-PT5401910	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135134	C
1,762	ERU -54 -PRESS	ERU-PT5401911	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135135	C
1,763	ERU -54 -PRESS	ERU-PT5401912	INSP. FIELD INST. (ห้ครูปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	135136	C
1,764	ERU -54 -PRESS	ERU-PT5401913A	INSP. FIELD INST. (ห้ครูปกรณ์)	INS	1Y					I								RRC	RRC-IRCP	135137	C
1,765	ERU -54 -PRESS	ERU-PT5401913A	PT5401913A-FULL FUN TEST PT &	PMT	5Y												F	RRC	RRC-IRCP	260631	C
1,766	ERU -54 -PRESS	ERU-PT5401913B	INSP. FIELD INST. (ห้ครูปกรณ์)	INS	1Y					I								RRC	RRC-IRCP	135138	C
1,767	ERU -54 -PRESS	ERU-PT5401913B	PT5401913B-FULL FUN TEST PT &	PMT	5Y												F	RRC	RRC-IRCP	260632	C
1,768	ERU -54 -PRESS	ERU-PT5401913C	INSP. FIELD INST. (ห้ครูปกรณ์)	INS	1Y					I								RRC	RRC-IRCP	135139	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,769	ERU -54 -PRESS	ERU-PT5401913C	PT5401913C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IRCP	260633	C
1,770	ERU -54 -PRESS	ERU-PT5401914	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135140	C
1,771	ERU -54 -PRESS	ERU-PT5401915A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	INS	1Y				I									RRC	RRC- IRCP	135141	C
1,772	ERU -54 -PRESS	ERU-PT5401915A	PT5401915A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IRCP	260628	C
1,773	ERU -54 -PRESS	ERU-PT5401915B	INSP. FIELD INST. (ตัดทุกปีเหลือ)	INS	1Y				I									RRC	RRC- IRCP	135142	C
1,774	ERU -54 -PRESS	ERU-PT5401915B	PT5401915B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IRCP	260629	C
1,775	ERU -54 -PRESS	ERU-PT5401915C	INSP. FIELD INST. (ตัดทุกปีเหลือ)	INS	1Y				I									RRC	RRC- IRCP	135143	C
1,776	ERU -54 -PRESS	ERU-PT5401915C	PT5401915C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IRCP	260630	C
1,777	ERU -54 -PRESS	ERU-PT5401921	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135144	C
1,778	ERU -54 -PRESS	ERU-PT5402001	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135145	C
1,779	ERU -54 -PRESS	ERU-PT5402003A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135146	C
1,780	ERU -54 -PRESS	ERU-PT5402003B	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135147	C
1,781	ERU -54 -PRESS	ERU-PT5402003C	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135148	C
1,782	ERU -54 -PRESS	ERU-PT5402004	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135149	C
1,783	ERU -54 -PRESS	ERU-PT5402006	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135150	C
1,784	ERU -54 -PRESS	ERU-PT5402008	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135151	C
1,785	ERU -54 -PRESS	ERU-PT5430101	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135152	C
1,786	ERU -54 -PRESS	ERU-PT5431101	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135153	C
1,787	ERU -54 -PRESS	ERU-PT5431103	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135154	C
1,788	ERU -54 -PRESS	ERU-PT5434101	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135155	C
1,789	ERU -54 -54K001A	ERU-PT5450102A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135371	C
1,790	ERU -54 -54K001A	ERU-PT5450112A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135373	C
1,791	ERU -54 -54K001A	ERU-PT5450213A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135375	C
1,792	ERU -54 -54K001A	ERU-PT5450217A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135377	C
1,793	ERU -54 -54K001A	ERU-PT5450221A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135379	C
1,794	ERU -54 -54K001A	ERU-PT5450229A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135381	C
1,795	ERU -54 -54K001A	ERU-PT5450328A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135385	C
1,796	ERU -54 -54K001A	ERU-PT5450329A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135383	C
1,797	ERU -54 -54K001A	ERU-PT5450401A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135387	C
1,798	ERU -54 -PRESS	ERU-PT5450604A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135156	C
1,799	ERU -54 -54K001B	ERU-PT5450702B	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135372	C
1,800	ERU -54 -54K001B	ERU-PT5450712B	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135374	C
1,801	ERU -54 -54K001A	ERU-PT5450804A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135389	C
1,802	ERU -54 -54K001B	ERU-PT5450813B	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135376	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,803	ERU -54 -54K001B	ERU-PT5450817B	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y							I						RRC	RRC- IRCP	135378	C
1,804	ERU -54 -54K001B	ERU-PT5450821B	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y							I						RRC	RRC- IRCP	135380	C
1,805	ERU -54 -54K001B	ERU-PT5450829B	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y							I						RRC	RRC- IRCP	135382	C
1,806	ERU -54 -54K001B	ERU-PT5450928B	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y							I						RRC	RRC- IRCP	135386	C
1,807	ERU -54 -54K001B	ERU-PT5450929B	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y							I						RRC	RRC- IRCP	135384	C
1,808	ERU -54 -54K001B	ERU-PT5451001B	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y							I						RRC	RRC- IRCP	135388	C
1,809	ERU -54 -54K001B	ERU-PT5451204B	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y							I						RRC	RRC- IRCP	135390	C
1,810	ERU -57 -PRESS	ERU-PT5700101	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135157	C
1,811	ERU -57 -PRESS	ERU-PT5700102	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135158	C
1,812	ERU -57 -PRESS	ERU-PT5700103	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135159	C
1,813	ERU -57 -PRESS	ERU-PT5700106	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135160	C
1,814	ERU -57 -PRESS	ERU-PT5700201A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135161	C
1,815	ERU -57 -PRESS	ERU-PT5700201B	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135162	C
1,816	ERU -57 -PRESS	ERU-PT5700202A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135163	C
1,817	ERU -57 -PRESS	ERU-PT5700202B	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135164	C
1,818	ERU -57 -PRESS	ERU-PT5700301A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135165	C
1,819	ERU -57 -PRESS	ERU-PT5700301B	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135166	C
1,820	ERU -57 -PRESS	ERU-PT5700302A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135167	C
1,821	ERU -57 -PRESS	ERU-PT5700302B	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135168	C
1,822	ERU -57 -PRESS	ERU-PT5700304	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135169	C
1,823	ERU -57 -PRESS	ERU-PT5700401	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135170	C
1,824	ERU -57 -PRESS	ERU-PT5700402	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135171	C
1,825	ERU -57 -PRESS	ERU-PT5700404	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135172	C
1,826	ERU -57 -PRESS	ERU-PT5700406	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135173	C
1,827	ERU -57 -PRESS	ERU-PT5700408	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135174	C
1,828	ERU -57 -PRESS	ERU-PT5700409	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135175	C
1,829	ERU -57 -PRESS	ERU-PT5700502	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135176	C
1,830	ERU -57 -PRESS	ERU-PT5700901A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	INS	1Y					I								RRC	RRC- IRCP	135177	C
1,831	ERU -57 -PRESS	ERU-PT5700901A	PT5700901A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IRCP	260637	C
1,832	ERU -57 -PRESS	ERU-PT5700901B	INSP. FIELD INST. (ตัดทุกปีเหลือ)	INS	1Y					I								RRC	RRC- IRCP	135178	C
1,833	ERU -57 -PRESS	ERU-PT5700901B	PT5700901B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IRCP	260638	C
1,834	ERU -57 -PRESS	ERU-PT5700901C	INSP. FIELD INST. (ตัดทุกปีเหลือ)	INS	1Y					I								RRC	RRC- IRCP	135179	C
1,835	ERU -57 -PRESS	ERU-PT5700901C	PT5700901C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IRCP	260639	C
1,836	ERU -57 -PRESS	ERU-PT5700902	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135180	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,837	ERU -57 -PRESS	ERU-PT5700903	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135181	C
1,838	ERU -57 -PRESS	ERU-PT5701002	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135182	C
1,839	ERU -57 -PRESS	ERU-PT5701101	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135183	C
1,840	ERU -57 -PRESS	ERU-PT5701201	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135184	C
1,841	ERU -57 -PRESS	ERU-PT5701301	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135185	C
1,842	ERU -57 -PRESS	ERU-PT5701302	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135186	C
1,843	ERU -57 -PRESS	ERU-PT5701304	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135187	C
1,844	ERU -57 -PRESS	ERU-PT5701402	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135188	C
1,845	ERU -57 -PRESS	ERU-PT5701601	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135189	C
1,846	ERU -57 -PRESS	ERU-PT5701701	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135190	C
1,847	ERU -57 -PRESS	ERU-PT5701721	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135191	C
1,848	ERU -57 -PRESS	ERU-PT5701722	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135192	C
1,849	ERU -57 -PRESS	ERU-PT5701723	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135193	C
1,850	ERU -57 -PRESS	ERU-PT5701724	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135194	C
1,851	ERU -57 -PRESS	ERU-PT5701801	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135195	C
1,852	ERU -57 -PRESS	ERU-PT5701802	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135196	C
1,853	ERU -57 -PRESS	ERU-PT5730101	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135197	C
1,854	ERU -57 -PRESS	ERU-PT5730102	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135198	C
1,855	ERU -57 -PRESS	ERU-PT5731101	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135199	C
1,856	ERU -57 -PRESS	ERU-PT5734101	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135200	C
1,857	ERU -57 -PRESS	ERU-PT5734102	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135201	C
1,858	ERU -57 -57K001	ERU-PT5750101	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135202	B
1,859	ERU -57 -57K001	ERU-PT5750102	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135203	B
1,860	ERU -57 -57K001	ERU-PT5750103	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135204	B
1,861	ERU -57 -57K001	ERU-PT5750201	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135205	B
1,862	ERU -57 -57K001	ERU-PT5750202	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135206	B
1,863	ERU -57 -57K001	ERU-PT5750203	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135207	B
1,864	ERU -57 -57K001	ERU-PT5750204	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135208	B
1,865	ERU -57 -57K001	ERU-PT5750301	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135362	B
1,866	ERU -57 -57K001	ERU-PT5750302	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135363	B
1,867	ERU -57 -57K002	ERU-PT5750801	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135209	B
1,868	ERU -57 -57K002	ERU-PT5750802	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135210	B
1,869	ERU -57 -57K002	ERU-PT5750803	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135211	B
1,870	ERU -57 -57K002	ERU-PT5750901	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y				I									RRC	RRC- IRCP	135212	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,871	ERU -57 -57K002	ERU-PT5750902	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135213	B
1,872	ERU -57 -57K002	ERU-PT5750903	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135214	B
1,873	ERU -57 -57K002	ERU-PT5750904	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y					I								RRC	RRC- IRCP	135215	B
1,874	ERU -57 -57K002	ERU-PT5751001	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135369	B
1,875	ERU -57 -57K002	ERU-PT5751002	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135370	B
1,876	ERU -58 -PRESS	ERU-PT5800101	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135216	C
1,877	ERU -58 -PRESS	ERU-PT5800103	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135217	C
1,878	ERU -58 -PRESS	ERU-PT5800105	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135218	C
1,879	ERU -58 -PRESS	ERU-PT5800107	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135219	C
1,880	ERU -58 -58P004	ERU-PT5800201A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y							I						RRC	RRC- IRCP	135403	C
1,881	ERU -58 -58P004	ERU-PT5800201B	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y							I						RRC	RRC- IRCP	135404	C
1,882	ERU -58 -58P006	ERU-PT5800202A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y							I						RRC	RRC- IRCP	135405	C
1,883	ERU -58 -58P006	ERU-PT5800202B	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y							I						RRC	RRC- IRCP	135406	C
1,884	ERU -58 -PRESS	ERU-PT5800301	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135220	C
1,885	ERU -58 -PRESS	ERU-PT5800401	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135221	C
1,886	ERU -58 -PRESS	ERU-PT5800403	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135222	C
1,887	ERU -58 -58P002	ERU-PT5800503A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y							I						RRC	RRC- IRCP	135401	C
1,888	ERU -58 -58P002	ERU-PT5800503B	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y							I						RRC	RRC- IRCP	135402	C
1,889	ERU -58 -PRESS	ERU-PT5800601	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135223	C
1,890	ERU -58 -58K001	ERU-PT5800801	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y							I						RRC	RRC- IRCP	135338	C
1,891	ERU -58 -58K001	ERU-PT5800802	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y							I						RRC	RRC- IRCP	135339	C
1,892	ERU -58 -PRESS	ERU-PT5800803	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135224	C
1,893	ERU -58 -PRESS	ERU-PT5801201	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135225	C
1,894	ERU -58 -PRESS	ERU-PT5801203	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135226	C
1,895	ERU -58 -PRESS	ERU-PT5801204	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135227	C
1,896	ERU -58 -PRESS	ERU-PT5801206	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135228	C
1,897	ERU -58 -PRESS	ERU-PT5801301A	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135229	C
1,898	ERU -58 -PRESS	ERU-PT5801301B	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135230	C
1,899	ERU -58 -PRESS	ERU-PT5801304	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135231	C
1,900	ERU -58 -PRESS	ERU-PT5801401	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135232	C
1,901	ERU -58 -PRESS	ERU-PT5801403	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135233	C
1,902	ERU -58 -PRESS	ERU-PT5801405	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135234	C
1,903	ERU -58 -PRESS	ERU-PT5801407	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135235	C
1,904	ERU -58 -PRESS	ERU-PT5801501	INSP. FIELD INST. (ตัดทุกปีเหลือ)	PMT	1Y						I							RRC	RRC- IRCP	135236	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,905	ERU -58 -PRESS	ERU-PT5801502	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135237	C
1,906	ERU -58 -PRESS	ERU-PT5801602	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135238	C
1,907	ERU -58 -PRESS	ERU-PT5801604	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135239	C
1,908	ERU -58 -PRESS	ERU-PT5801701A	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135240	C
1,909	ERU -58 -PRESS	ERU-PT5801701B	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135241	C
1,910	ERU -58 -PRESS	ERU-PT5801704	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135242	C
1,911	ERU -58 -PRESS	ERU-PT5802001	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135243	C
1,912	ERU -58 -PRESS	ERU-PT5802002	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135244	C
1,913	ERU -58 -PRESS	ERU-PT5802003	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135245	C
1,914	ERU -58 -PRESS	ERU-PT5802102	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135246	C
1,915	ERU -58 -PRESS	ERU-PT5802301	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135247	C
1,916	ERU -58 -PRESS	ERU-PT5802401	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135248	C
1,917	ERU -58 -PRESS	ERU-PT5802402	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135249	C
1,918	ERU -58 -PRESS	ERU-PT5802403	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135250	C
1,919	ERU -58 -PRESS	ERU-PT5802404	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135251	C
1,920	ERU -58 -PRESS	ERU-PT5802405	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135252	C
1,921	ERU -58 -PRESS	ERU-PT5802501A	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y					I								RRC	RRC-IRCP	135253	C
1,922	ERU -58 -PRESS	ERU-PT5802501A	PT5802501A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260646	C
1,923	ERU -58 -PRESS	ERU-PT5802501B	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y					I								RRC	RRC-IRCP	135254	C
1,924	ERU -58 -PRESS	ERU-PT5802501B	PT5802501B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260647	C
1,925	ERU -58 -PRESS	ERU-PT5802501C	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y					I								RRC	RRC-IRCP	135255	C
1,926	ERU -58 -PRESS	ERU-PT5802501C	PT5802501C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260648	C
1,927	ERU -58 -PRESS	ERU-PT5802502	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135256	C
1,928	ERU -58 -PRESS	ERU-PT5802504	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135257	C
1,929	ERU -58 -PRESS	ERU-PT5802506	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135258	C
1,930	ERU -58 -PRESS	ERU-PT5802508	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135259	C
1,931	ERU -58 -PRESS	ERU-PT5802510	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135260	C
1,932	ERU -58 -PRESS	ERU-PT5802703	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135261	C
1,933	ERU -58 -PRESS	ERU-PT5802801	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135262	C
1,934	ERU -58 -PRESS	ERU-PT5802802	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135263	C
1,935	ERU -58 -58K101	ERU-PT5802805	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135346	C
1,936	ERU -58 -PRESS	ERU-PT5803204A	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y					I								RRC	RRC-IRCP	135264	C
1,937	ERU -58 -PRESS	ERU-PT5803204A	PT5803204A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260652	C
1,938	ERU -58 -PRESS	ERU-PT5803204B	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y					I								RRC	RRC-IRCP	135265	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,939	ERU -58 -PRESS	ERU-PT5803204B	PT5803204B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260653	C
1,940	ERU -58 -PRESS	ERU-PT5803204C	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y					I								RRC	RRC-IRCP	135266	C
1,941	ERU -58 -PRESS	ERU-PT5803204C	PT5803204C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260654	C
1,942	ERU -58 -PRESS	ERU-PT5803205	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135267	C
1,943	ERU -58 -PRESS	ERU-PT5803206	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135268	C
1,944	ERU -58 -PRESS	ERU-PT5803208	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135269	C
1,945	ERU -58 -PRESS	ERU-PT5803210	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135270	C
1,946	ERU -58 -PRESS	ERU-PT5803211	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135271	C
1,947	ERU -58 -PRESS	ERU-PT5803212	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135272	C
1,948	ERU -58 -PRESS	ERU-PT5803404	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135273	C
1,949	ERU -58 -58P201	ERU-PT5803405A	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135407	C
1,950	ERU -58 -58P201	ERU-PT5803405B	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135408	C
1,951	ERU -58 -PRESS	ERU-PT5803501	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135274	C
1,952	ERU -58 -PRESS	ERU-PT5803503A	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y					I								RRC	RRC-IRCP	135275	C
1,953	ERU -58 -PRESS	ERU-PT5803503A	PT5803503A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260658	C
1,954	ERU -58 -PRESS	ERU-PT5803503B	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y					I								RRC	RRC-IRCP	135276	C
1,955	ERU -58 -PRESS	ERU-PT5803503B	PT5803503B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260659	C
1,956	ERU -58 -PRESS	ERU-PT5803503C	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y					I								RRC	RRC-IRCP	135277	C
1,957	ERU -58 -PRESS	ERU-PT5803503C	PT5803503C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260660	C
1,958	ERU -58 -PRESS	ERU-PT5803504	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135278	C
1,959	ERU -58 -PRESS	ERU-PT5803506	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135279	C
1,960	ERU -58 -PRESS	ERU-PT5803508	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135280	C
1,961	ERU -58 -58K401	ERU-PT5804001	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135281	C
1,962	ERU -58 -58K401	ERU-PT5804002	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135354	C
1,963	ERU -58 -PRESS	ERU-PT5804003	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135282	C
1,964	ERU -58 -58K401	ERU-PT5804103	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135355	C
1,965	ERU -58 -PRESS	ERU-PT5804105A	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y					I								RRC	RRC-IRCP	135283	C
1,966	ERU -58 -PRESS	ERU-PT5804105A	PT5804105A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260655	C
1,967	ERU -58 -PRESS	ERU-PT5804105B	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y					I								RRC	RRC-IRCP	135284	C
1,968	ERU -58 -PRESS	ERU-PT5804105B	PT5804105B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260656	C
1,969	ERU -58 -PRESS	ERU-PT5804105C	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y					I								RRC	RRC-IRCP	135285	C
1,970	ERU -58 -PRESS	ERU-PT5804105C	PT5804105C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260657	C
1,971	ERU -58 -PRESS	ERU-PT5804106	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135286	C
1,972	ERU -58 -PRESS	ERU-PT5804702	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135287	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,973	ERU -58 -PRESS	ERU-PT5804801	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135288	C
1,974	ERU -58 -PRESS	ERU-PT5804802	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135289	C
1,975	ERU -58 -PRESS	ERU-PT5804901	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135290	C
1,976	ERU -58 -PRESS	ERU-PT5804902	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135291	C
1,977	ERU -58 -PRESS	ERU-PT5805101	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135292	C
1,978	ERU -58 -58K501	ERU-PT5805201	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135356	C
1,979	ERU -58 -PRESS	ERU-PT5805203	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135293	C
1,980	ERU -58 -58K501	ERU-PT5805301	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135357	C
1,981	ERU -58 -58K501	ERU-PT5805302	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135358	C
1,982	ERU -58 -PRESS	ERU-PT5805303A	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y					I								RRC	RRC-IRCP	135294	C
1,983	ERU -58 -PRESS	ERU-PT5805303A	PT5805303A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260667	C
1,984	ERU -58 -PRESS	ERU-PT5805303B	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y					I								RRC	RRC-IRCP	135295	C
1,985	ERU -58 -PRESS	ERU-PT5805303B	PT5805303B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260668	C
1,986	ERU -58 -PRESS	ERU-PT5805303C	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y					I								RRC	RRC-IRCP	135296	C
1,987	ERU -58 -PRESS	ERU-PT5805303C	PT5805303C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260669	C
1,988	ERU -58 -PRESS	ERU-PT5805801	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135297	C
1,989	ERU -58 -PRESS	ERU-PT5805903	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135298	C
1,990	ERU -58 -PRESS	ERU-PT5805905	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135299	C
1,991	ERU -58 -PRESS	ERU-PT5806003	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135300	C
1,992	ERU -58 -PRESS	ERU-PT5806006	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135301	C
1,993	ERU -58 -PRESS	ERU-PT5830101	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	135302	C
1,994	ERU -58 -PRESS	ERU-PT5831101	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135303	C
1,995	ERU -58 -PRESS	ERU-PT5831103	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135304	C
1,996	ERU -58 -PRESS	ERU-PT5834101	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135305	C
1,997	ERU -58 -PRESS	ERU-PT5834102	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135306	C
1,998	ERU -58 -PRESS	ERU-PT5834103	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135307	C
1,999	ERU -58 -58K001	ERU-PT5850201	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135308	C
2,000	ERU -58 -58K001	ERU-PT5850202A	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135309	C
2,001	ERU -58 -58K001	ERU-PT5850202B	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135310	C
2,002	ERU -58 -58K001	ERU-PT5850202C	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135311	C
2,003	ERU -58 -58K001	ERU-PT5850206	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135312	C
2,004	ERU -58 -58K001	ERU-PT5850501	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135313	C
2,005	ERU -58 -58K001	ERU-PT5850502	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135314	C
2,006	ERU -58 -58K001	ERU-PT5850505	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135315	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,007	ERU -58 -58K101	ERU-PT5850702	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135347	C
2,008	ERU -58 -58K101	ERU-PT5850708	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135348	C
2,009	ERU -58 -58K101	ERU-PT5850709	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135349	C
2,010	ERU -58 -58K101	ERU-PT5850723A	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135350	C
2,011	ERU -58 -58K101	ERU-PT5850723B	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135351	C
2,012	ERU -58 -58K101	ERU-PT5850723C	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135352	C
2,013	ERU -58 -58K101	ERU-PT5850724	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135353	C
2,014	ERU -58 -58K401	ERU-PT5851401	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135316	C
2,015	ERU -58 -58K401	ERU-PT5851402A	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135317	C
2,016	ERU -58 -58K401	ERU-PT5851402B	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135318	C
2,017	ERU -58 -58K401	ERU-PT5851402C	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135319	C
2,018	ERU -58 -PRESS	ERU-PT5851406	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135320	C
2,019	ERU -58 -58K401	ERU-PT5851701	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135321	C
2,020	ERU -58 -58K401	ERU-PT5851702	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135322	C
2,021	ERU -58 -58K401	ERU-PT5851705	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135323	C
2,022	ERU -58 -58K501	ERU-PT5852001	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135324	C
2,023	ERU -58 -58K501	ERU-PT5852002A	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135325	C
2,024	ERU -58 -58K501	ERU-PT5852002B	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135326	C
2,025	ERU -58 -58K501	ERU-PT5852002C	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135327	C
2,026	ERU -58 -PRESS	ERU-PT5852006	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135328	C
2,027	ERU -58 -58K501	ERU-PT5852301	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135329	C
2,028	ERU -58 -58K501	ERU-PT5852302	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135330	C
2,029	ERU -58 -58K501	ERU-PT5852305	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135331	C
2,030	ERU -59 -PRESS	ERU-PT5900101	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135332	C
2,031	ERU -59 -PRESS	ERU-PT5900102	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135333	C
2,032	ERU -59 -PRESS	ERU-PT5900103	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135334	C
2,033	ERU -59 -PRESS	ERU-PT5900104	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135335	C
2,034	ERU -59 -PRESS	ERU-PT5900105	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135336	C
2,035	ERU -59 -PRESS	ERU-PT5900107	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	135337	C
2,036	ERU -54 -CV	ERU-PV5400201A	INSPECT CONTROL VALVE NO. PV54	PMT	1Y										I			RRC	RRC-IRCP	135856	C
2,037	ERU -54 -CV	ERU-PV5400201B	INSPECT CONTROL VALVE NO. PV54	PMT	1Y										I			RRC	RRC-IRCP	135857	C
2,038	ERU -54 -CV	ERU-PV5400301	INSPECT CONTROL VALVE NO. PV54	PMT	1Y										I			RRC	RRC-IRCP	135858	C
2,039	ERU -54 -CV	ERU-PV5400901	INSPECT CONTROL VALVE NO. PV54	PMT	1Y										I			RRC	RRC-IRCP	135859	C
2,040	ERU -54 -CV	ERU-PV5401001	INSPECT CONTROL VALVE NO. PV54	PMT	1Y										I			RRC	RRC-IRCP	135860	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,041	ERU -54 -CV	ERU-PV5401401	INSPECT CONTROL VALVE NO. PV54	PMT	1Y											I		RRC	RRC-IRCP	135919	C
2,042	ERU -54 -CV	ERU-PV5401403	INSPECT CONTROL VALVE NO. PV54	PMT	1Y										I			RRC	RRC-IRCP	135861	C
2,043	ERU -54 -CV	ERU-PV5401701A	INSPECT CONTROL VALVE NO. PV54	PMT	1Y										I			RRC	RRC-IRCP	135862	C
2,044	ERU -54 -CV	ERU-PV5401701B	INSPECT CONTROL VALVE NO. PV54	PMT	1Y										I			RRC	RRC-IRCP	135863	C
2,045	ERU -54 -CV	ERU-PV5401911	INSPECT CONTROL VALVE NO. PV54	PMT	1Y										I			RRC	RRC-IRCP	135864	C
2,046	ERU -57 -CV	ERU-PV5701101	INSPECT CONTROL VALVE NO. PV57	PMT	1Y										I			RRC	RRC-IRCP	135865	C
2,047	ERU -57 -CV	ERU-PV5701102	INSPECT CONTROL VALVE NO. PV57	PMT	1Y											I		RRC	RRC-IRCP	135920	C
2,048	ERU -57 -CV	ERU-PV5701601A	INSPECT CONTROL VALVE NO. PV57	PMT	1Y										I			RRC	RRC-IRCP	135866	C
2,049	ERU -57 -CV	ERU-PV5701601B	INSPECT CONTROL VALVE NO. PV57	PMT	1Y										I			RRC	RRC-IRCP	135867	C
2,050	ERU -57 -CV	ERU-PV5701801A	INSPECT CONTROL VALVE NO. PV57	PMT	1Y										I			RRC	RRC-IRCP	135868	C
2,051	ERU -57 -CV	ERU-PV5701801B	INSPECT CONTROL VALVE NO. PV57	PMT	1Y										I			RRC	RRC-IRCP	135869	C
2,052	ERU -58 -CV	ERU-PV5800601	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135870	C
2,053	ERU -58 -CV	ERU-PV5800803	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135871	C
2,054	ERU -58 -CV	ERU-PV5801204	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135872	C
2,055	ERU -58 -CV	ERU-PV5801501A	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135873	C
2,056	ERU -58 -CV	ERU-PV5801501B	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135874	C
2,057	ERU -58 -CV	ERU-PV5802002	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135875	C
2,058	ERU -58 -CV	ERU-PV5802403	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135876	C
2,059	ERU -58 -CV	ERU-PV5802801	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135877	C
2,060	ERU -58 -CV	ERU-PV5803205A	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135878	C
2,061	ERU -58 -CV	ERU-PV5803205B	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135879	C
2,062	ERU -58 -CV	ERU-PV5803404	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135880	C
2,063	ERU -58 -CV	ERU-PV5803501	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135881	C
2,064	ERU -58 -CV	ERU-PV5803504	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135882	C
2,065	ERU -58 -CV	ERU-PV5804106	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135883	C
2,066	ERU -58 -CV	ERU-PV5804702	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135884	C
2,067	ERU -58 -CV	ERU-PV5804801A	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135885	C
2,068	ERU -58 -CV	ERU-PV5804801B	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135886	C
2,069	ERU -58 -CV	ERU-PV5805101A	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135887	C
2,070	ERU -58 -CV	ERU-PV5805101B	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135888	C
2,071	ERU -58 -CV	ERU-PV5805801A	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135889	C
2,072	ERU -58 -CV	ERU-PV5805801B	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135890	C
2,073	ERU -58 -CV	ERU-PV5806006A	INSPECT CONTROL VALVE NO. PV58	PMT	1Y											I		RRC	RRC-IRCP	135921	C
2,074	ERU -58 -CV	ERU-PV5806006B	INSPECT CONTROL VALVE NO. PV58	PMT	1Y										I			RRC	RRC-IRCP	135891	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,075	ERU -58 -58K001	ERU-PV5850201	INSPECT CONTROL VALVE NO. PV58	PMT	1Y												I	RRC	RRC-IRCP	136102	C
2,076	ERU -58 -58K101	ERU-PV5850801	INSPECT CONTROL VALVE NO. PV58	PMT	1Y												I	RRC	RRC-IRCP	136099	C
2,077	ERU -59 -CV	ERU-PV5900101A	INSPECT CONTROL VALVE NO. PV59	PMT	1Y										I			RRC	RRC-IRCP	135892	C
2,078	ERU -59 -CV	ERU-PV5900101B	INSPECT CONTROL VALVE NO. PV59	PMT	1Y										I			RRC	RRC-IRCP	135893	C
2,079	ERU -59 -CV	ERU-PV5900104A	INSPECT CONTROL VALVE NO. PV59	PMT	1Y										I			RRC	RRC-IRCP	135894	C
2,080	ERU -59 -CV	ERU-PV5900104B	INSPECT CONTROL VALVE NO. PV59	PMT	1Y										I			RRC	RRC-IRCP	135895	C
2,081	ERU -59 -CV	ERU-PV5900105	INSPECT CONTROL VALVE NO. PV59	PMT	1Y										I			RRC	RRC-IRCP	135896	C
2,082	ERU -54 -SIS	ERU-SIS	INSPECT ESD SYSTEM	PMT	3M		I			I			I			I		CCS	CCS-SYS	246445	A
2,083	ERU -54 -SIS	ERU-SIS	BACKUP ESD SYSTEM	PMT	6M		I						I					CCS	CCS-SYS	246446	A
2,084	ERU -54 -SIS	ERU-SIS	UPDATE ANTIVIRUS ESD SYSTEM	PMT	3M		U			U			U			U		CCS	CCS-SYS	246447	A
2,085	ERU -54 -54K001A	ERU-TCV5450332A	INSPECT CONTROL VALVE NO. TCV5	PMT	1Y												I	RRC	RRC-IRCP	136114	C
2,086	ERU -54 -54K001A	ERU-TCV5450514A	INSPECT CONTROL VALVE NO. TCV5	PMT	1Y												I	RRC	RRC-IRCP	136116	C
2,087	ERU -54 -54K001B	ERU-TCV5450932B	INSPECT CONTROL VALVE NO. TCV5	PMT	1Y												I	RRC	RRC-IRCP	136115	C
2,088	ERU -54 -54K001B	ERU-TCV5451114B	INSPECT CONTROL VALVE NO. TCV5	PMT	1Y												I	RRC	RRC-IRCP	136117	C
2,089	ERU -57 -57K001	ERU-TCV5750201	INSPECT CONTROL VALVE NO. TCV5	PMT	1Y												I	RRC	RRC-IRCP	136108	B
2,090	ERU -57 -57K002	ERU-TCV5750901	INSPECT CONTROL VALVE NO. TCV5	PMT	1Y												I	RRC	RRC-IRCP	136113	B
2,091	ERU -54 -54K001A	ERU-TE5450104A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135731	C
2,092	ERU -54 -54K001A	ERU-TE5450113A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135733	C
2,093	ERU -54 -54K001A	ERU-TE5450325A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135735	C
2,094	ERU -54 -54K001A	ERU-TE5450502A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135737	C
2,095	ERU -54 -54K001A	ERU-TE5450509A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135739	C
2,096	ERU -54 -54K001B	ERU-TE5450704B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135732	C
2,097	ERU -54 -54K001B	ERU-TE5450713B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135734	C
2,098	ERU -54 -54K001B	ERU-TE5450925B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135736	C
2,099	ERU -54 -54K001B	ERU-TE5451102B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135738	C
2,100	ERU -54 -54K001B	ERU-TE5451109B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135740	C
2,101	ERU -54 -TEMP	ERU-TT5400101	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	135411	C
2,102	ERU -54 -TEMP	ERU-TT5400102	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	135412	C
2,103	ERU -54 -TEMP	ERU-TT5400103	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	135413	C
2,104	ERU -54 -TEMP	ERU-TT5400104	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	135414	C
2,105	ERU -54 -TEMP	ERU-TT5400105	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	135415	C
2,106	ERU -54 -TEMP	ERU-TT5400201	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	135416	C
2,107	ERU -54 -TEMP	ERU-TT5400202	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	135417	C
2,108	ERU -54 -TEMP	ERU-TT5400301	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	135418	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,109	ERU -54 -TEMP	ERU-TT5400302	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	135419	C
2,110	ERU -54 -TEMP	ERU-TT5400303	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	135420	C
2,111	ERU -54 -TEMP	ERU-TT5400304	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	135421	C
2,112	ERU -54 -TEMP	ERU-TT5400305	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	135422	C
2,113	ERU -54 -TEMP	ERU-TT5400306	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	135423	C
2,114	ERU -54 -TEMP	ERU-TT5400401	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	135424	C
2,115	ERU -54 -TEMP	ERU-TT5400450	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135425	C
2,116	ERU -54 -TEMP	ERU-TT5400450	TT5400450-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261283	C
2,117	ERU -54 -TEMP	ERU-TT5400451	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135426	C
2,118	ERU -54 -TEMP	ERU-TT5400451	TT5400451-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261284	C
2,119	ERU -54 -TEMP	ERU-TT5400452	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135427	C
2,120	ERU -54 -TEMP	ERU-TT5400452	TT5400452-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261285	C
2,121	ERU -54 -TEMP	ERU-TT5400453	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135428	C
2,122	ERU -54 -TEMP	ERU-TT5400453	TT5400453-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261286	C
2,123	ERU -54 -TEMP	ERU-TT5400454	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135429	C
2,124	ERU -54 -TEMP	ERU-TT5400454	TT5400454-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261287	C
2,125	ERU -54 -TEMP	ERU-TT5400455	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135430	C
2,126	ERU -54 -TEMP	ERU-TT5400455	TT5400455-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261288	C
2,127	ERU -54 -TEMP	ERU-TT5400456	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135431	C
2,128	ERU -54 -TEMP	ERU-TT5400456	TT5400456-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261289	C
2,129	ERU -54 -TEMP	ERU-TT5400457	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135432	C
2,130	ERU -54 -TEMP	ERU-TT5400457	TT5400457-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261290	C
2,131	ERU -54 -TEMP	ERU-TT5400458	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135433	C
2,132	ERU -54 -TEMP	ERU-TT5400458	TT5400458-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261291	C
2,133	ERU -54 -TEMP	ERU-TT5400459	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135434	C
2,134	ERU -54 -TEMP	ERU-TT5400459	TT5400459-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261292	C
2,135	ERU -54 -TEMP	ERU-TT5400460	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135435	C
2,136	ERU -54 -TEMP	ERU-TT5400460	TT5400460-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261293	C
2,137	ERU -54 -TEMP	ERU-TT5400461	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135436	C
2,138	ERU -54 -TEMP	ERU-TT5400461	TT5400461-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261294	C
2,139	ERU -54 -TEMP	ERU-TT5400462	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135437	C
2,140	ERU -54 -TEMP	ERU-TT5400462	TT5400462-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261295	C
2,141	ERU -54 -TEMP	ERU-TT5400470	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135438	C
2,142	ERU -54 -TEMP	ERU-TT5400470	TT5400470-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261296	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,143	ERU -54 -TEMP	ERU-TT5400471	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135439	C
2,144	ERU -54 -TEMP	ERU-TT5400471	TT5400471-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261297	C
2,145	ERU -54 -TEMP	ERU-TT5400472	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135440	C
2,146	ERU -54 -TEMP	ERU-TT5400472	TT5400472-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261298	C
2,147	ERU -54 -TEMP	ERU-TT5400473	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135441	C
2,148	ERU -54 -TEMP	ERU-TT5400473	TT5400473-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261299	C
2,149	ERU -54 -TEMP	ERU-TT5400474	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135442	C
2,150	ERU -54 -TEMP	ERU-TT5400474	TT5400474-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261300	C
2,151	ERU -54 -TEMP	ERU-TT5400475	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135443	C
2,152	ERU -54 -TEMP	ERU-TT5400475	TT5400475-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261301	C
2,153	ERU -54 -TEMP	ERU-TT5400476	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135444	C
2,154	ERU -54 -TEMP	ERU-TT5400476	TT5400476-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261302	C
2,155	ERU -54 -TEMP	ERU-TT5400477	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135445	C
2,156	ERU -54 -TEMP	ERU-TT5400477	TT5400477-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261303	C
2,157	ERU -54 -TEMP	ERU-TT5400478	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135446	C
2,158	ERU -54 -TEMP	ERU-TT5400478	TT5400478-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261304	C
2,159	ERU -54 -TEMP	ERU-TT5400479	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135447	C
2,160	ERU -54 -TEMP	ERU-TT5400479	TT5400479-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261305	C
2,161	ERU -54 -TEMP	ERU-TT5400480	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135448	C
2,162	ERU -54 -TEMP	ERU-TT5400480	TT5400480-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261306	C
2,163	ERU -54 -TEMP	ERU-TT5400481	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135449	C
2,164	ERU -54 -TEMP	ERU-TT5400481	TT5400481-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261307	C
2,165	ERU -54 -TEMP	ERU-TT5400482	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135450	C
2,166	ERU -54 -TEMP	ERU-TT5400482	TT5400482-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261308	C
2,167	ERU -54 -TEMP	ERU-TT5400501	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135451	C
2,168	ERU -54 -TEMP	ERU-TT5400502	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135452	C
2,169	ERU -54 -TEMP	ERU-TT5400601	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135453	C
2,170	ERU -54 -TEMP	ERU-TT5400602A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135454	C
2,171	ERU -54 -TEMP	ERU-TT5400602B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135455	C
2,172	ERU -54 -TEMP	ERU-TT5400602C	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135456	C
2,173	ERU -54 -TEMP	ERU-TT5400608	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135457	C
2,174	ERU -54 -TEMP	ERU-TT5400609	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135458	C
2,175	ERU -54 -TEMP	ERU-TT5400620	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135459	C
2,176	ERU -54 -TEMP	ERU-TT5400622	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135460	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,177	ERU -54 -TEMP	ERU-TT5400622	TT5400622-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261309	C
2,178	ERU -54 -TEMP	ERU-TT5400623	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135461	C
2,179	ERU -54 -TEMP	ERU-TT5400623	TT5400623-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261310	C
2,180	ERU -54 -TEMP	ERU-TT5400624	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135462	C
2,181	ERU -54 -TEMP	ERU-TT5400624	TT5400624-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261311	C
2,182	ERU -54 -TEMP	ERU-TT5400625	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135463	C
2,183	ERU -54 -TEMP	ERU-TT5400625	TT5400625-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261312	C
2,184	ERU -54 -TEMP	ERU-TT5400626	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135464	C
2,185	ERU -54 -TEMP	ERU-TT5400626	TT5400626-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261313	C
2,186	ERU -54 -TEMP	ERU-TT5400627	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135465	C
2,187	ERU -54 -TEMP	ERU-TT5400627	TT5400627-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261314	C
2,188	ERU -54 -TEMP	ERU-TT5400628	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135466	C
2,189	ERU -54 -TEMP	ERU-TT5400628	TT5400628-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261315	C
2,190	ERU -54 -TEMP	ERU-TT5400629	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135467	C
2,191	ERU -54 -TEMP	ERU-TT5400629	TT5400629-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261316	C
2,192	ERU -54 -TEMP	ERU-TT5400630	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135468	C
2,193	ERU -54 -TEMP	ERU-TT5400630	TT5400630-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261317	C
2,194	ERU -54 -TEMP	ERU-TT5400631	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135469	C
2,195	ERU -54 -TEMP	ERU-TT5400631	TT5400631-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261318	C
2,196	ERU -54 -TEMP	ERU-TT5400632	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135470	C
2,197	ERU -54 -TEMP	ERU-TT5400632	TT5400632-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261319	C
2,198	ERU -54 -TEMP	ERU-TT5400633	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135471	C
2,199	ERU -54 -TEMP	ERU-TT5400633	TT5400633-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261320	C
2,200	ERU -54 -TEMP	ERU-TT5400634	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135472	C
2,201	ERU -54 -TEMP	ERU-TT5400634	TT5400634-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261321	C
2,202	ERU -54 -TEMP	ERU-TT5400635	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135473	C
2,203	ERU -54 -TEMP	ERU-TT5400635	TT5400635-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261322	C
2,204	ERU -54 -TEMP	ERU-TT5400636	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135474	C
2,205	ERU -54 -TEMP	ERU-TT5400636	TT5400636-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261323	C
2,206	ERU -54 -TEMP	ERU-TT5400637	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135475	C
2,207	ERU -54 -TEMP	ERU-TT5400637	TT5400637-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261324	C
2,208	ERU -54 -TEMP	ERU-TT5400638	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135476	C
2,209	ERU -54 -TEMP	ERU-TT5400638	TT5400638-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261325	C
2,210	ERU -54 -TEMP	ERU-TT5400639	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135477	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,211	ERU -54 -TEMP	ERU-TT5400639	TT5400639-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261326	C
2,212	ERU -54 -TEMP	ERU-TT5400640	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135478	C
2,213	ERU -54 -TEMP	ERU-TT5400640	TT5400640-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261327	C
2,214	ERU -54 -TEMP	ERU-TT5400641	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135479	C
2,215	ERU -54 -TEMP	ERU-TT5400641	TT5400641-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261328	C
2,216	ERU -54 -TEMP	ERU-TT5400642	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135480	C
2,217	ERU -54 -TEMP	ERU-TT5400642	TT5400642-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261329	C
2,218	ERU -54 -TEMP	ERU-TT5400643	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135481	C
2,219	ERU -54 -TEMP	ERU-TT5400643	TT5400643-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261330	C
2,220	ERU -54 -TEMP	ERU-TT5400654	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135482	C
2,221	ERU -54 -TEMP	ERU-TT5400660	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135483	C
2,222	ERU -54 -TEMP	ERU-TT5400701	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135484	C
2,223	ERU -54 -TEMP	ERU-TT5400702	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135485	C
2,224	ERU -54 -TEMP	ERU-TT5400703	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135486	C
2,225	ERU -54 -TEMP	ERU-TT5400704	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135487	C
2,226	ERU -54 -TEMP	ERU-TT5400706	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135488	C
2,227	ERU -54 -54P004	ERU-TT5400801A	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135741	C
2,228	ERU -54 -54P004	ERU-TT5400801B	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135742	C
2,229	ERU -54 -54P002	ERU-TT5400802A	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135753	B
2,230	ERU -54 -54P002	ERU-TT5400802B	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135754	B
2,231	ERU -54 -TEMP	ERU-TT5400901A	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135489	C
2,232	ERU -54 -TEMP	ERU-TT5400901A	TT5400901A-FULLFUN TEST TEMP T	PMT	5Y											F		RRC	RRC-IRCP	261331	C
2,233	ERU -54 -TEMP	ERU-TT5400901B	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135490	C
2,234	ERU -54 -TEMP	ERU-TT5400901B	TT5400901B-FULLFUN TEST TEMP T	PMT	5Y											F		RRC	RRC-IRCP	261332	C
2,235	ERU -54 -TEMP	ERU-TT5400901C	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135491	C
2,236	ERU -54 -TEMP	ERU-TT5400901C	TT5400901C-FULLFUN TEST TEMP T	PMT	5Y											F		RRC	RRC-IRCP	261333	C
2,237	ERU -54 -TEMP	ERU-TT5400902A	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135492	C
2,238	ERU -54 -TEMP	ERU-TT5400902A	TT5400902A-FULLFUN TEST TEMP T	PMT	5Y											F		RRC	RRC-IRCP	261334	C
2,239	ERU -54 -TEMP	ERU-TT5400902B	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135493	C
2,240	ERU -54 -TEMP	ERU-TT5400902B	TT5400902B-FULLFUN TEST TEMP T	PMT	5Y											F		RRC	RRC-IRCP	261335	C
2,241	ERU -54 -TEMP	ERU-TT5400902C	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y							I						RRC	RRC-IRCP	135494	C
2,242	ERU -54 -TEMP	ERU-TT5400902C	TT5400902C-FULLFUN TEST TEMP T	PMT	5Y											F		RRC	RRC-IRCP	261336	C
2,243	ERU -54 -TEMP	ERU-TT5400903	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135495	C
2,244	ERU -54 -TEMP	ERU-TT5400903A	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135496	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,245	ERU -54 -TEMP	ERU-TT5400903B	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135497	C
2,246	ERU -54 -TEMP	ERU-TT5400903C	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135498	C
2,247	ERU -54 -TEMP	ERU-TT5400904A	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135499	C
2,248	ERU -54 -TEMP	ERU-TT5400904B	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135500	C
2,249	ERU -54 -TEMP	ERU-TT5400904C	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135501	C
2,250	ERU -54 -TEMP	ERU-TT5401001	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135502	C
2,251	ERU -54 -TEMP	ERU-TT5401002	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135503	C
2,252	ERU -54 -TEMP	ERU-TT5401003	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135504	C
2,253	ERU -54 -TEMP	ERU-TT5401004	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135505	C
2,254	ERU -54 -TEMP	ERU-TT5401005	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135506	C
2,255	ERU -54 -TEMP	ERU-TT5401006	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135507	C
2,256	ERU -54 -TEMP	ERU-TT5401007	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135508	C
2,257	ERU -54 -TEMP	ERU-TT5401010	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135509	C
2,258	ERU -54 -TEMP	ERU-TT5401101	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135510	C
2,259	ERU -54 -TEMP	ERU-TT5401102	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135511	C
2,260	ERU -54 -TEMP	ERU-TT5401103	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135512	C
2,261	ERU -54 -TEMP	ERU-TT5401105	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135513	C
2,262	ERU -54 -54P005	ERU-TT5401109A	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y									I				RRC	RRC-IRCP	135743	B
2,263	ERU -54 -54P005	ERU-TT5401109B	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y									I				RRC	RRC-IRCP	135744	B
2,264	ERU -54 -TEMP	ERU-TT5401201	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135514	C
2,265	ERU -54 -TEMP	ERU-TT5401303	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135515	C
2,266	ERU -54 -TEMP	ERU-TT5401401	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135516	C
2,267	ERU -54 -TEMP	ERU-TT5401501	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135517	C
2,268	ERU -54 -TEMP	ERU-TT5401502	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135518	C
2,269	ERU -54 -TEMP	ERU-TT5401503	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135519	C
2,270	ERU -54 -TEMP	ERU-TT5401601	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135520	C
2,271	ERU -54 -TEMP	ERU-TT5401701	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135521	C
2,272	ERU -54 -TEMP	ERU-TT5401801	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135522	C
2,273	ERU -54 -TEMP	ERU-TT5401802	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135523	C
2,274	ERU -54 -TEMP	ERU-TT5401803	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135524	C
2,275	ERU -54 -TEMP	ERU-TT5401804	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135525	C
2,276	ERU -54 -TEMP	ERU-TT5401817	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135526	C
2,277	ERU -54 -TEMP	ERU-TT5401818	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135527	C
2,278	ERU -54 -TEMP	ERU-TT5401819	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135528	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,279	ERU -54 -TEMP	ERU-TT5401820	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135529	C
2,280	ERU -54 -TEMP	ERU-TT5401907	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135530	C
2,281	ERU -54 -TEMP	ERU-TT5401910	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135531	C
2,282	ERU -54 -TEMP	ERU-TT5402001A	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135532	C
2,283	ERU -54 -TEMP	ERU-TT5402001B	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135533	C
2,284	ERU -54 -TEMP	ERU-TT5402001C	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135534	C
2,285	ERU -54 -TEMP	ERU-TT5402003	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135535	C
2,286	ERU -54 -TEMP	ERU-TT5402004	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135536	C
2,287	ERU -54 -TEMP	ERU-TT5402005	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135537	C
2,288	ERU -54 -TEMP	ERU-TT5430101	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135538	C
2,289	ERU -54 -TEMP	ERU-TT5431101	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135539	C
2,290	ERU -54 -TEMP	ERU-TT5431103	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135540	C
2,291	ERU -54 -TEMP	ERU-TT5434101	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135541	C
2,292	ERU -57 -TEMP	ERU-TT5700101	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135542	C
2,293	ERU -57 -TEMP	ERU-TT5700102	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135543	C
2,294	ERU -57 -TEMP	ERU-TT5700103	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135544	C
2,295	ERU -57 -TEMP	ERU-TT5700104	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	135545	C
2,296	ERU -57 -TEMP	ERU-TT5700105	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135546	C
2,297	ERU -57 -TEMP	ERU-TT5700411	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135547	C
2,298	ERU -57 -TEMP	ERU-TT5700501	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135548	C
2,299	ERU -57 -TEMP	ERU-TT5700601	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135549	C
2,300	ERU -57 -TEMP	ERU-TT5700602	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135550	C
2,301	ERU -57 -TEMP	ERU-TT5700603	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135551	C
2,302	ERU -57 -TEMP	ERU-TT5700604	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135552	C
2,303	ERU -57 -TEMP	ERU-TT5700605	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135553	C
2,304	ERU -57 -TEMP	ERU-TT5700606	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135554	C
2,305	ERU -57 -TEMP	ERU-TT5700701	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135555	C
2,306	ERU -57 -TEMP	ERU-TT5700702	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135556	C
2,307	ERU -57 -TEMP	ERU-TT5700703	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135557	C
2,308	ERU -57 -TEMP	ERU-TT5700801	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135558	C
2,309	ERU -57 -TEMP	ERU-TT5700802	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135559	C
2,310	ERU -57 -TEMP	ERU-TT5700803	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135560	C
2,311	ERU -57 -TEMP	ERU-TT5700804	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135561	C
2,312	ERU -57 -TEMP	ERU-TT5700806	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y								I					RRC	RRC-IRCP	135562	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,313	ERU -57 -TEMP	ERU-TT5700905	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135563	C
2,314	ERU -57 -TEMP	ERU-TT5701001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135564	C
2,315	ERU -57 -TEMP	ERU-TT5701002	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135565	C
2,316	ERU -57 -TEMP	ERU-TT5701101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135566	C
2,317	ERU -57 -TEMP	ERU-TT5701201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135567	C
2,318	ERU -57 -TEMP	ERU-TT5701202	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135568	C
2,319	ERU -57 -TEMP	ERU-TT5701307	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135569	C
2,320	ERU -57 -TEMP	ERU-TT5701401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135570	C
2,321	ERU -57 -TEMP	ERU-TT5701402	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135571	C
2,322	ERU -57 -TEMP	ERU-TT5701403	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135572	C
2,323	ERU -57 -TEMP	ERU-TT5701404	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135573	C
2,324	ERU -57 -TEMP	ERU-TT5701405	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135574	C
2,325	ERU -57 -TEMP	ERU-TT5701501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135575	C
2,326	ERU -57 -TEMP	ERU-TT5701503	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135576	C
2,327	ERU -57 -TEMP	ERU-TT5701601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135577	C
2,328	ERU -57 -TEMP	ERU-TT5701602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135578	C
2,329	ERU -57 -TEMP	ERU-TT5701603	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135579	C
2,330	ERU -57 -TEMP	ERU-TT5701701	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135580	C
2,331	ERU -57 -TEMP	ERU-TT5701701	TT5701701-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261338	C
2,332	ERU -57 -TEMP	ERU-TT5701801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135581	C
2,333	ERU -57 -TEMP	ERU-TT5701802	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135582	C
2,334	ERU -57 -TEMP	ERU-TT5701805	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135583	C
2,335	ERU -57 -TEMP	ERU-TT5730101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135584	C
2,336	ERU -57 -TEMP	ERU-TT5730102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135585	C
2,337	ERU -57 -TEMP	ERU-TT5731101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135586	C
2,338	ERU -57 -TEMP	ERU-TT5734101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135587	C
2,339	ERU -57 -TEMP	ERU-TT5734102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135588	C
2,340	ERU -58 -TEMP	ERU-TT5800101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135589	C
2,341	ERU -58 -TEMP	ERU-TT5800102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135590	C
2,342	ERU -58 -TEMP	ERU-TT5800103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135591	C
2,343	ERU -58 -58P004	ERU-TT5800201A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	135747	C
2,344	ERU -58 -58P004	ERU-TT5800201B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	135748	C
2,345	ERU -58 -58P006	ERU-TT5800202A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	135749	C
2,346	ERU -58 -58P006	ERU-TT5800202B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	135750	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,347	ERU -58 -TEMP	ERU-TT5800301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135592	C
2,348	ERU -58 -TEMP	ERU-TT5800302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135593	C
2,349	ERU -58 -TEMP	ERU-TT5800501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135594	C
2,350	ERU -58 -TEMP	ERU-TT5800502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135595	C
2,351	ERU -58 -58P002	ERU-TT5800503A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	135745	C
2,352	ERU -58 -58P002	ERU-TT5800503B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	135746	C
2,353	ERU -58 -TEMP	ERU-TT5800601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135596	C
2,354	ERU -58 -TEMP	ERU-TT5800602A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135597	C
2,355	ERU -58 -TEMP	ERU-TT5800602A	TT5800602A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261342	C
2,356	ERU -58 -TEMP	ERU-TT5800602B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135598	C
2,357	ERU -58 -TEMP	ERU-TT5800602B	TT5800602B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261343	C
2,358	ERU -58 -TEMP	ERU-TT5800602C	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135599	C
2,359	ERU -58 -TEMP	ERU-TT5800602C	TT5800602C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261344	C
2,360	ERU -58 -58K001	ERU-TT5800801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	135715	C
2,361	ERU -58 -58K001	ERU-TT5800802	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	135716	C
2,362	ERU -58 -TEMP	ERU-TT5800803A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135600	C
2,363	ERU -58 -TEMP	ERU-TT5800803A	TT5800803A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261339	C
2,364	ERU -58 -TEMP	ERU-TT5800803B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135601	C
2,365	ERU -58 -TEMP	ERU-TT5800803B	TT5800803B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261340	C
2,366	ERU -58 -TEMP	ERU-TT5800803C	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135602	C
2,367	ERU -58 -TEMP	ERU-TT5800803C	TT5800803C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261341	C
2,368	ERU -58 -TEMP	ERU-TT5801201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135603	C
2,369	ERU -58 -TEMP	ERU-TT5801202	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135604	C
2,370	ERU -58 -TEMP	ERU-TT5801203	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135605	C
2,371	ERU -58 -TEMP	ERU-TT5801301A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135606	C
2,372	ERU -58 -TEMP	ERU-TT5801301B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135607	C
2,373	ERU -58 -TEMP	ERU-TT5801501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135608	C
2,374	ERU -58 -TEMP	ERU-TT5801502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135609	C
2,375	ERU -58 -TEMP	ERU-TT5801601A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135610	C
2,376	ERU -58 -TEMP	ERU-TT5801601B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135611	C
2,377	ERU -58 -TEMP	ERU-TT5801602A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135612	C
2,378	ERU -58 -TEMP	ERU-TT5801602B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135613	C
2,379	ERU -58 -TEMP	ERU-TT5801603A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135614	C
2,380	ERU -58 -TEMP	ERU-TT5801603A	TT5801603A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261345	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,381	ERU -58 -TEMP	ERU-TT5801603B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135615	C
2,382	ERU -58 -TEMP	ERU-TT5801603B	TT5801603B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261346	C
2,383	ERU -58 -TEMP	ERU-TT5801604A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135616	C
2,384	ERU -58 -TEMP	ERU-TT5801604A	TT5801604A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261347	C
2,385	ERU -58 -TEMP	ERU-TT5801604B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135617	C
2,386	ERU -58 -TEMP	ERU-TT5801604B	TT5801604B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261348	C
2,387	ERU -58 -TEMP	ERU-TT5801605A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135618	C
2,388	ERU -58 -TEMP	ERU-TT5801605A	TT5801605A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261349	C
2,389	ERU -58 -TEMP	ERU-TT5801605B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135619	C
2,390	ERU -58 -TEMP	ERU-TT5801605B	TT5801605B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261350	C
2,391	ERU -58 -TEMP	ERU-TT5801606A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135620	C
2,392	ERU -58 -TEMP	ERU-TT5801606A	TT5801606A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261351	C
2,393	ERU -58 -TEMP	ERU-TT5801606B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135621	C
2,394	ERU -58 -TEMP	ERU-TT5801606B	TT5801606B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261352	C
2,395	ERU -58 -TEMP	ERU-TT5801607A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135622	C
2,396	ERU -58 -TEMP	ERU-TT5801607A	TT5801607A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261353	C
2,397	ERU -58 -TEMP	ERU-TT5801607B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135623	C
2,398	ERU -58 -TEMP	ERU-TT5801607B	TT5801607B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261354	C
2,399	ERU -58 -TEMP	ERU-TT5801608A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135624	C
2,400	ERU -58 -TEMP	ERU-TT5801608A	TT5801608A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261355	C
2,401	ERU -58 -TEMP	ERU-TT5801608B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135625	C
2,402	ERU -58 -TEMP	ERU-TT5801608B	TT5801608B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261356	C
2,403	ERU -58 -TEMP	ERU-TT5801609A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135626	C
2,404	ERU -58 -TEMP	ERU-TT5801609A	TT5801609A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261357	C
2,405	ERU -58 -TEMP	ERU-TT5801609B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135627	C
2,406	ERU -58 -TEMP	ERU-TT5801609B	TT5801609B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261358	C
2,407	ERU -58 -TEMP	ERU-TT5801610A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135628	C
2,408	ERU -58 -TEMP	ERU-TT5801610A	TT5801610A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261359	C
2,409	ERU -58 -TEMP	ERU-TT5801610B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135629	C
2,410	ERU -58 -TEMP	ERU-TT5801610B	TT5801610B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261360	C
2,411	ERU -58 -TEMP	ERU-TT5801611A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135630	C
2,412	ERU -58 -TEMP	ERU-TT5801611A	TT5801611A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261361	C
2,413	ERU -58 -TEMP	ERU-TT5801611B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135631	C
2,414	ERU -58 -TEMP	ERU-TT5801611B	TT5801611B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261362	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,415	ERU -58 -TEMP	ERU-TT5801612A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135632	C
2,416	ERU -58 -TEMP	ERU-TT5801612A	TT5801612A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261363	C
2,417	ERU -58 -TEMP	ERU-TT5801612B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135633	C
2,418	ERU -58 -TEMP	ERU-TT5801612B	TT5801612B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261364	C
2,419	ERU -58 -TEMP	ERU-TT5801613A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135634	C
2,420	ERU -58 -TEMP	ERU-TT5801613A	TT5801613A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261365	C
2,421	ERU -58 -TEMP	ERU-TT5801613B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135635	C
2,422	ERU -58 -TEMP	ERU-TT5801613B	TT5801613B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261366	C
2,423	ERU -58 -TEMP	ERU-TT5801614A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135636	C
2,424	ERU -58 -TEMP	ERU-TT5801614A	TT5801614A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261367	C
2,425	ERU -58 -TEMP	ERU-TT5801614B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135637	C
2,426	ERU -58 -TEMP	ERU-TT5801614B	TT5801614B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261368	C
2,427	ERU -58 -TEMP	ERU-TT5801615A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135638	C
2,428	ERU -58 -TEMP	ERU-TT5801615A	TT5801615A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261369	C
2,429	ERU -58 -TEMP	ERU-TT5801615B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135639	C
2,430	ERU -58 -TEMP	ERU-TT5801615B	TT5801615B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261370	C
2,431	ERU -58 -TEMP	ERU-TT5801616A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135640	C
2,432	ERU -58 -TEMP	ERU-TT5801616A	TT5801616A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261371	C
2,433	ERU -58 -TEMP	ERU-TT5801616B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135641	C
2,434	ERU -58 -TEMP	ERU-TT5801616B	TT5801616B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261372	C
2,435	ERU -58 -TEMP	ERU-TT5801621	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135642	C
2,436	ERU -58 -TEMP	ERU-TT5801701A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135643	C
2,437	ERU -58 -TEMP	ERU-TT5801701B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135644	C
2,438	ERU -58 -TEMP	ERU-TT5802001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135645	C
2,439	ERU -58 -TEMP	ERU-TT5802002A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135646	C
2,440	ERU -58 -TEMP	ERU-TT5802002A	TT5802002A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261373	C
2,441	ERU -58 -TEMP	ERU-TT5802002B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135647	C
2,442	ERU -58 -TEMP	ERU-TT5802002B	TT5802002B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261374	C
2,443	ERU -58 -TEMP	ERU-TT5802002C	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	135648	C
2,444	ERU -58 -TEMP	ERU-TT5802002C	TT5802002C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261375	C
2,445	ERU -58 -TEMP	ERU-TT5802101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135649	C
2,446	ERU -58 -TEMP	ERU-TT5802102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135650	C
2,447	ERU -58 -TEMP	ERU-TT5802103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135651	C
2,448	ERU -58 -TEMP	ERU-TT5802104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	135652	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,449	ERU -58 -TEMP	ERU-TT5802301	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y								I					RRC	RRC-IRCP	135653	C
2,450	ERU -58 -TEMP	ERU-TT5802302	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y								I					RRC	RRC-IRCP	135654	C
2,451	ERU -58 -TEMP	ERU-TT5802401	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y								I					RRC	RRC-IRCP	135655	C
2,452	ERU -58 -TEMP	ERU-TT5802402	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y								I					RRC	RRC-IRCP	135656	C
2,453	ERU -58 -TEMP	ERU-TT5802403	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y								I					RRC	RRC-IRCP	135657	C
2,454	ERU -58 -TEMP	ERU-TT5802404	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y								I					RRC	RRC-IRCP	135658	C
2,455	ERU -58 -TEMP	ERU-TT5802509	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y								I					RRC	RRC-IRCP	135659	C
2,456	ERU -58 -TEMP	ERU-TT5802703	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y								I					RRC	RRC-IRCP	135660	C
2,457	ERU -58 -TEMP	ERU-TT5802801	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y								I					RRC	RRC-IRCP	135661	C
2,458	ERU -58 -TEMP	ERU-TT5802802	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y								I					RRC	RRC-IRCP	135662	C
2,459	ERU -58 -TEMP	ERU-TT5802803	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y								I					RRC	RRC-IRCP	135663	C
2,460	ERU -58 -TEMP	ERU-TT5802807	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y								I					RRC	RRC-IRCP	135664	C
2,461	ERU -58 -TEMP	ERU-TT5803201	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y								I					RRC	RRC-IRCP	135665	C
2,462	ERU -58 -TEMP	ERU-TT5803202	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y								I					RRC	RRC-IRCP	135666	C
2,463	ERU -58 -TEMP	ERU-TT5803203	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135667	C
2,464	ERU -58 -TEMP	ERU-TT5803204	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135668	C
2,465	ERU -58 -TEMP	ERU-TT5803205	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135669	C
2,466	ERU -58 -TEMP	ERU-TT5803211	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135670	C
2,467	ERU -58 -TEMP	ERU-TT5803212	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135671	C
2,468	ERU -58 -TEMP	ERU-TT5803401	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135672	C
2,469	ERU -58 -58P201	ERU-TT5803405A	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135751	C
2,470	ERU -58 -58P201	ERU-TT5803405B	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135752	C
2,471	ERU -58 -TEMP	ERU-TT5803501	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135673	C
2,472	ERU -58 -TEMP	ERU-TT5803502	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135674	C
2,473	ERU -58 -TEMP	ERU-TT5803503	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135675	C
2,474	ERU -58 -TEMP	ERU-TT5803504	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135676	C
2,475	ERU -58 -TEMP	ERU-TT5803505	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135677	C
2,476	ERU -58 -TEMP	ERU-TT5803506	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135678	C
2,477	ERU -58 -TEMP	ERU-TT5803507	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135679	C
2,478	ERU -58 -TEMP	ERU-TT5803701	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135680	C
2,479	ERU -58 -58K401	ERU-TT5804001	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135722	C
2,480	ERU -58 -58K401	ERU-TT5804002	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135723	C
2,481	ERU -58 -58K401	ERU-TT5804103	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135724	C
2,482	ERU -58 -58K401	ERU-TT5804104	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135725	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,483	ERU -58 -TEMP	ERU-TT5804501	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135681	C
2,484	ERU -58 -TEMP	ERU-TT5804502	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135682	C
2,485	ERU -58 -TEMP	ERU-TT5804801	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135683	C
2,486	ERU -58 -TEMP	ERU-TT5804802	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135684	C
2,487	ERU -58 -TEMP	ERU-TT5804901	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135685	C
2,488	ERU -58 -TEMP	ERU-TT5804902	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135686	C
2,489	ERU -58 -TEMP	ERU-TT5805101	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135687	C
2,490	ERU -58 -TEMP	ERU-TT5805102	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135688	C
2,491	ERU -58 -TEMP	ERU-TT5805103	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135689	C
2,492	ERU -58 -58K501	ERU-TT5805201	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135727	C
2,493	ERU -58 -58K501	ERU-TT5805301	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135728	C
2,494	ERU -58 -58K501	ERU-TT5805302	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135729	C
2,495	ERU -58 -TEMP	ERU-TT5805701	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135690	C
2,496	ERU -58 -TEMP	ERU-TT5805703	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135691	C
2,497	ERU -58 -TEMP	ERU-TT5805801	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135692	C
2,498	ERU -58 -TEMP	ERU-TT5805901	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135693	C
2,499	ERU -58 -TEMP	ERU-TT5805902	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135694	C
2,500	ERU -58 -TEMP	ERU-TT5805903	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135695	C
2,501	ERU -58 -TEMP	ERU-TT5805904	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135696	C
2,502	ERU -58 -TEMP	ERU-TT5805905	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135697	C
2,503	ERU -58 -TEMP	ERU-TT5806001	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135698	C
2,504	ERU -58 -TEMP	ERU-TT5806002	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135699	C
2,505	ERU -58 -TEMP	ERU-TT5806003	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135700	C
2,506	ERU -58 -TEMP	ERU-TT5806006A	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y									I				RRC	RRC-IRCP	135701	C
2,507	ERU -58 -TEMP	ERU-TT5806006A	TT5806006A-FULLFUN TEST TEMP.T	PMT	5Y												F	RRC	RRC-IRCP	261376	C
2,508	ERU -58 -TEMP	ERU-TT5806006B	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y									I				RRC	RRC-IRCP	135702	C
2,509	ERU -58 -TEMP	ERU-TT5806006B	TT5806006B-FULLFUN TEST TEMP.T	PMT	5Y												F	RRC	RRC-IRCP	261377	C
2,510	ERU -58 -TEMP	ERU-TT5806006C	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y									I				RRC	RRC-IRCP	135703	C
2,511	ERU -58 -TEMP	ERU-TT5806006C	TT5806006C-FULLFUN TEST TEMP.T	PMT	5Y												F	RRC	RRC-IRCP	261378	C
2,512	ERU -58 -TEMP	ERU-TT5830101	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135704	C
2,513	ERU -58 -TEMP	ERU-TT5831101	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135705	C
2,514	ERU -58 -TEMP	ERU-TT5831103	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135706	C
2,515	ERU -58 -TEMP	ERU-TT5834101	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135707	C
2,516	ERU -58 -TEMP	ERU-TT5834102	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135708	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,517	ERU -58 -TEMP	ERU-TT5834103	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135709	C
2,518	ERU -58 -58K001	ERU-TT5850506	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135717	C
2,519	ERU -58 -58K101	ERU-TT5850708A	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135718	C
2,520	ERU -58 -58K101	ERU-TT5850708B	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135719	C
2,521	ERU -58 -58K101	ERU-TT5850708C	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135720	C
2,522	ERU -58 -58K101	ERU-TT5850709	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135721	C
2,523	ERU -58 -58K401	ERU-TT5851706	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135726	C
2,524	ERU -58 -58K501	ERU-TT5852306	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135730	C
2,525	ERU -59 -TEMP	ERU-TT5900101	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135710	C
2,526	ERU -59 -TEMP	ERU-TT5900102	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135711	C
2,527	ERU -59 -TEMP	ERU-TT5900104	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135712	C
2,528	ERU -59 -TEMP	ERU-TT5900105	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135713	C
2,529	ERU -59 -TEMP	ERU-TT5900111	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y									I				RRC	RRC-IRCP	135714	C
2,530	ERU -54 -CV	ERU-TV5400301	INSPECT CONTROL VALVE NO. TV54	PMT	1Y										I			RRC	RRC-IRCP	135897	C
2,531	ERU -54 -CV	ERU-TV5401001	INSPECT CONTROL VALVE NO. TV54	PMT	1Y										I			RRC	RRC-IRCP	135898	C
2,532	ERU -57 -CV	ERU-TV5701405	INSPECT CONTROL VALVE NO. TV57	PMT	1Y										I			RRC	RRC-IRCP	135899	C
2,533	ERU -57 -CV	ERU-TV5701802A	INSPECT CONTROL VALVE NO. TV57	PMT	1Y											I		RRC	RRC-IRCP	135922	C
2,534	ERU -57 -CV	ERU-TV5701802B	INSPECT CONTROL VALVE NO. TV57	PMT	1Y											I		RRC	RRC-IRCP	135923	C
2,535	ERU -57 -CV	ERU-TV5701805	INSPECT CONTROL VALVE NO. TV57	PMT	1Y										I			RRC	RRC-IRCP	135900	C
2,536	ERU -58 -CV	ERU-TV5800601	INSPECT CONTROL VALVE NO. TV58	PMT	1Y										I			RRC	RRC-IRCP	135901	C
2,537	ERU -58 -CV	ERU-TV5801203	INSPECT CONTROL VALVE NO. TV58	PMT	1Y										I			RRC	RRC-IRCP	135902	C
2,538	ERU -58 -CV	ERU-TV5801501A	INSPECT CONTROL VALVE NO. TV58	INS	1Y										I			RRC	RRC-IRCP	135903	C
2,539	ERU -58 -CV	ERU-TV5801501A	TV5801501A-FULLFUN TEST CONTRO	PMT	5Y											F		RRC	RRC-IRCP	260351	C
2,540	ERU -58 -CV	ERU-TV5801501B	INSPECT CONTROL VALVE NO. TV58	INS	1Y										I			RRC	RRC-IRCP	135904	C
2,541	ERU -58 -CV	ERU-TV5801501B	TV5801501B-FULLFUN TEST CONTRO	PMT	5Y											F		RRC	RRC-IRCP	260352	C
2,542	ERU -58 -CV	ERU-TV5801501C	INSPECT CONTROL VALVE NO. TV58	INS	1Y										I			RRC	RRC-IRCP	135905	C
2,543	ERU -58 -CV	ERU-TV5801501C	TV5801501C-FULLFUN TEST CONTRO	PMT	5Y											F		RRC	RRC-IRCP	260353	C
2,544	ERU -58 -CV	ERU-TV5802403	INSPECT CONTROL VALVE NO. TV58	PMT	1Y										I			RRC	RRC-IRCP	135906	C
2,545	ERU -58 -CV	ERU-TV5802509	INSPECT CONTROL VALVE NO. TV58	PMT	1Y										I			RRC	RRC-IRCP	135907	C
2,546	ERU -58 -CV	ERU-TV5802807A	INSPECT CONTROL VALVE NO. TV58	PMT	1Y										I			RRC	RRC-IRCP	135908	C
2,547	ERU -58 -CV	ERU-TV5802807B	INSPECT CONTROL VALVE NO. TV58	PMT	1Y											I		RRC	RRC-IRCP	135909	C
2,548	ERU -58 -CV	ERU-TV5804801	INSPECT CONTROL VALVE NO. TV58	PMT	1Y											I		RRC	RRC-IRCP	135910	C
2,549	ERU -58 -CV	ERU-TV5850506	INSPECT CONTROL VALVE NO. TV58	PMT	1Y											I		RRC	RRC-IRCP	135924	C
2,550	ERU -59 -CV	ERU-TV5900105	INSPECT CONTROL VALVE NO. TV59	PMT	1Y											I		RRC	RRC-IRCP	135911	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,551	ERU -58 -58K101	ERU-LV5802801	INSPECT CONTROL VALVE NO. LV58	PMT	1Y												I	RRC	RRC-IRCP	136100	C
2,552	ERU -54 -54E015	ERU-VSD-B8-4001-09	Inspec VSD FOR 54E015-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-ERCP	254128	B
2,553	ERU -54 -CV	ERU-XV5400201	INSPECT CONTROL VALVE NO. XV54	INS	1Y											I		RRC	RRC-IRCP	135925	C
2,554	ERU -54 -CV	ERU-XV5400201	XV5400201-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261465	C
2,555	ERU -54 -CV	ERU-XV5400202	INSPECT CONTROL VALVE NO. XV54	INS	1Y											I		RRC	RRC-IRCP	135926	C
2,556	ERU -54 -CV	ERU-XV5400202	XV5400202-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261466	C
2,557	ERU -54 -CV	ERU-XV5400203	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251303	C
2,558	ERU -54 -CV	ERU-XV5400203	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251156	C
2,559	ERU -54 -CV	ERU-XV5400301	INSPECT CONTROL VALVE NO. XV54	INS	1Y											I		RRC	RRC-IRCP	135928	C
2,560	ERU -54 -CV	ERU-XV5400301	XV5400301-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261467	C
2,561	ERU -54 -CV	ERU-XV5400302	INSPECT CONTROL VALVE NO. XV54	PMT	1Y											I		RRC	RRC-IRCP	135929	C
2,562	ERU -54 -CV	ERU-XV5400701	INSPECT CONTROL VALVE NO. XV54	INS	1Y											I		RRC	RRC-IRCP	135930	C
2,563	ERU -54 -CV	ERU-XV5400701	XV5400701-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261470	C
2,564	ERU -54 -CV	ERU-XV5400702	INSPECT CONTROL VALVE NO. XV54	PMT	1Y											I		RRC	RRC-IRCP	135931	C
2,565	ERU -54 -CV	ERU-XV5400703	INSPECT CONTROL VALVE NO. XV54	PMT	1Y											I		RRC	RRC-IRCP	135932	C
2,566	ERU -54 -CV	ERU-XV5401001	INSPECT CONTROL VALVE NO. XV54	INS	1Y											I		RRC	RRC-IRCP	135933	C
2,567	ERU -54 -CV	ERU-XV5401001	XV5401001-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261471	C
2,568	ERU -54 -CV	ERU-XV5401101	INSPECT CONTROL VALVE NO. XV54	INS	1Y											I		RRC	RRC-IRCP	135934	C
2,569	ERU -54 -CV	ERU-XV5401101	XV5401101-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261472	C
2,570	ERU -54 -CV	ERU-XV5401201	INSPECT CONTROL VALVE NO. XV54	INS	1Y											I		RRC	RRC-IRCP	135935	C
2,571	ERU -54 -CV	ERU-XV5401201	XV5401201-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261475	C
2,572	ERU -54 -CV	ERU-XV5401202	INSPECT CONTROL VALVE NO. XV54	INS	1Y											I		RRC	RRC-IRCP	135936	C
2,573	ERU -54 -CV	ERU-XV5401202	XV5401202-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261474	C
2,574	ERU -54 -CV	ERU-XV5401301	INSPECT CONTROL VALVE NO. XV54	INS	1Y											I		RRC	RRC-IRCP	135937	C
2,575	ERU -54 -CV	ERU-XV5401301	XV5401301-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261473	C
2,576	ERU -54 -CV	ERU-XV5401302	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251304	C
2,577	ERU -54 -CV	ERU-XV5401302	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251158	C
2,578	ERU -54 -CV	ERU-XV5401901	INSPECT CONTROL VALVE NO. XV54	INS	1Y											I		RRC	RRC-IRCP	135939	C
2,579	ERU -54 -CV	ERU-XV5401901	XV5401901-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261468	C
2,580	ERU -54 -CV	ERU-XV5401902	INSPECT CONTROL VALVE NO. XV54	PMT	1Y											I		RRC	RRC-IRCP	135940	C
2,581	ERU -54 -CV	ERU-XV5401903	INSPECT CONTROL VALVE NO. XV54	INS	1Y											I		RRC	RRC-IRCP	135941	C
2,582	ERU -54 -CV	ERU-XV5401903	XV5401903-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261469	C
2,583	ERU -54 -CV	ERU-XV5401904	INSPECT CONTROL VALVE NO. XV54	PMT	1Y											I		RRC	RRC-IRCP	135942	C
2,584	ERU -54 -CV	ERU-XV5401905	INSPECT CONTROL VALVE NO. XV54	INS	1Y											I		RRC	RRC-IRCP	135943	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,585	ERU -54 -CV	ERU-XV5401905	XV5401905-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261476	C
2,586	ERU -54 -CV	ERU-XV5401915	INSPECT CONTROL VALVE NO. XV54	PMT	1Y											I		RRC	RRC-IRCP	135944	C
2,587	ERU -57 -CV	ERU-XV5702201A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135945	C
2,588	ERU -57 -CV	ERU-XV5702201B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135946	C
2,589	ERU -57 -CV	ERU-XV5702202A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135947	C
2,590	ERU -57 -CV	ERU-XV5702202B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135948	C
2,591	ERU -57 -CV	ERU-XV5702203A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135949	C
2,592	ERU -57 -CV	ERU-XV5702203B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135950	C
2,593	ERU -57 -CV	ERU-XV5702204A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135951	C
2,594	ERU -57 -CV	ERU-XV5702204B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135952	C
2,595	ERU -57 -CV	ERU-XV5702205A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135953	C
2,596	ERU -57 -CV	ERU-XV5702205B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135954	C
2,597	ERU -57 -CV	ERU-XV5702206A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135955	C
2,598	ERU -57 -CV	ERU-XV5702206B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135956	C
2,599	ERU -57 -CV	ERU-XV5702207A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135957	C
2,600	ERU -57 -CV	ERU-XV5702207B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135958	C
2,601	ERU -57 -CV	ERU-XV5702208A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135959	C
2,602	ERU -57 -CV	ERU-XV5702208B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135960	C
2,603	ERU -57 -CV	ERU-XV5702209A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135961	C
2,604	ERU -57 -CV	ERU-XV5702209B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135962	C
2,605	ERU -57 -CV	ERU-XV5702210A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135963	C
2,606	ERU -57 -CV	ERU-XV5702210B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135964	C
2,607	ERU -57 -CV	ERU-XV5702211A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135965	C
2,608	ERU -57 -CV	ERU-XV5702211B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135966	C
2,609	ERU -57 -CV	ERU-XV5702212A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135967	C
2,610	ERU -57 -CV	ERU-XV5702212B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135968	C
2,611	ERU -57 -CV	ERU-XV5703301A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135969	C
2,612	ERU -57 -CV	ERU-XV5703301B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135970	C
2,613	ERU -57 -CV	ERU-XV5703302A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135971	C
2,614	ERU -57 -CV	ERU-XV5703302B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135972	C
2,615	ERU -57 -CV	ERU-XV5703303A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135973	C
2,616	ERU -57 -CV	ERU-XV5703303B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135974	C
2,617	ERU -57 -CV	ERU-XV5703304A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135975	C
2,618	ERU -57 -CV	ERU-XV5703304B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135976	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,619	ERU -57 -CV	ERU-XV5700305A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135977	C
2,620	ERU -57 -CV	ERU-XV5700305B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135978	C
2,621	ERU -57 -CV	ERU-XV5700306A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135979	C
2,622	ERU -57 -CV	ERU-XV5700306B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135980	C
2,623	ERU -57 -CV	ERU-XV5700307A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135981	C
2,624	ERU -57 -CV	ERU-XV5700307B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135982	C
2,625	ERU -57 -CV	ERU-XV5700308A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135983	C
2,626	ERU -57 -CV	ERU-XV5700308B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135984	C
2,627	ERU -57 -CV	ERU-XV5700309A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135985	C
2,628	ERU -57 -CV	ERU-XV5700309B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135986	C
2,629	ERU -57 -CV	ERU-XV5700310A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135987	C
2,630	ERU -57 -CV	ERU-XV5700310B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135988	C
2,631	ERU -57 -CV	ERU-XV5700311A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135989	C
2,632	ERU -57 -CV	ERU-XV5700311B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135990	C
2,633	ERU -57 -CV	ERU-XV5700312A	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135991	C
2,634	ERU -57 -CV	ERU-XV5700312B	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135992	C
2,635	ERU -57 -CV	ERU-XV5700601	INSPECT CONTROL VALVE NO. XV57	INS	1Y											I		RRC	RRC-IRCP	135993	C
2,636	ERU -57 -CV	ERU-XV5700601	XV5700601-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261480	C
2,637	ERU -57 -CV	ERU-XV5700602	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135994	C
2,638	ERU -57 -CV	ERU-XV5700701	INSPECT CONTROL VALVE NO. XV57	INS	1Y											I		RRC	RRC-IRCP	135995	C
2,639	ERU -57 -CV	ERU-XV5700701	XV5700701-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261481	C
2,640	ERU -57 -CV	ERU-XV5700901	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251341	C
2,641	ERU -57 -CV	ERU-XV5700901	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251232	C
2,642	ERU -57 -CV	ERU-XV5700902	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251342	C
2,643	ERU -57 -CV	ERU-XV5700902	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251234	C
2,644	ERU -57 -CV	ERU-XV5700903	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	135998	C
2,645	ERU -57 -CV	ERU-XV5701101	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251343	C
2,646	ERU -57 -CV	ERU-XV5701101	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251236	C
2,647	ERU -57 -CV	ERU-XV5701102	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	136000	C
2,648	ERU -57 -CV	ERU-XV5701301	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	136001	C
2,649	ERU -57 -CV	ERU-XV5701401	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	136002	C
2,650	ERU -57 -CV	ERU-XV5701402	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	136003	C
2,651	ERU -57 -CV	ERU-XV5701601	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	136004	C
2,652	ERU -57 -CV	ERU-XV5701602	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	136005	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,653	ERU -57 -CV	ERU-XV5701701	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	136006	C
2,654	ERU -57 -CV	ERU-XV5701702	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	136007	C
2,655	ERU -57 -CV	ERU-XV5701703	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	136008	C
2,656	ERU -57 -CV	ERU-XV5701704	INSPECT CONTROL VALVE NO. XV57	PMT	1Y											I		RRC	RRC-IRCP	136009	C
2,657	ERU -58 -CV	ERU-XV5800601	INSPECT CONTROL VALVE NO. XV58	INS	1Y											I		RRC	RRC-IRCP	136010	C
2,658	ERU -58 -CV	ERU-XV5800601	XV5800601-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261482	C
2,659	ERU -58 -CV	ERU-XV5801201	INSPECT CONTROL VALVE NO. XV58	PMT	1Y											I		RRC	RRC-IRCP	136011	C
2,660	ERU -58 -CV	ERU-XV5801302A	INSPECT CONTROL VALVE NO. XV58	PMT	1Y											I		RRC	RRC-IRCP	136012	C
2,661	ERU -58 -CV	ERU-XV5801302B	INSPECT CONTROL VALVE NO. XV58	PMT	1Y											I		RRC	RRC-IRCP	136013	C
2,662	ERU -58 -CV	ERU-XV5801303A	INSPECT CONTROL VALVE NO. XV58	PMT	1Y											I		RRC	RRC-IRCP	136014	C
2,663	ERU -58 -CV	ERU-XV5801303B	INSPECT CONTROL VALVE NO. XV58	PMT	1Y											I		RRC	RRC-IRCP	136015	C
2,664	ERU -58 -CV	ERU-XV5801304A	INSPECT CONTROL VALVE NO. XV58	PMT	1Y											I		RRC	RRC-IRCP	136016	C
2,665	ERU -58 -CV	ERU-XV5801304B	INSPECT CONTROL VALVE NO. XV58	PMT	1Y											I		RRC	RRC-IRCP	136017	C
2,666	ERU -58 -CV	ERU-XV5801305A	INSPECT CONTROL VALVE NO. XV58	PMT	1Y											I		RRC	RRC-IRCP	136018	C
2,667	ERU -58 -CV	ERU-XV5801305B	INSPECT CONTROL VALVE NO. XV58	PMT	1Y											I		RRC	RRC-IRCP	136019	C
2,668	ERU -58 -CV	ERU-XV5801306A	INSPECT CONTROL VALVE NO. XV58	PMT	1Y											I		RRC	RRC-IRCP	136020	C
2,669	ERU -58 -CV	ERU-XV5801306B	INSPECT CONTROL VALVE NO. XV58	PMT	1Y											I		RRC	RRC-IRCP	136021	C
2,670	ERU -58 -CV	ERU-XV5801307A	INSPECT CONTROL VALVE NO. XV58	PMT	1Y											I		RRC	RRC-IRCP	136022	C
2,671	ERU -58 -CV	ERU-XV5801307B	INSPECT CONTROL VALVE NO. XV58	PMT	1Y											I		RRC	RRC-IRCP	136023	C
2,672	ERU -58 -CV	ERU-XV5801308A	INSPECT CONTROL VALVE NO. XV58	PMT	1Y											I		RRC	RRC-IRCP	136024	C
2,673	ERU -58 -CV	ERU-XV5801308B	INSPECT CONTROL VALVE NO. XV58	PMT	1Y											I		RRC	RRC-IRCP	136025	C
2,674	ERU -58 -CV	ERU-XV5801401	INSPECT CONTROL VALVE NO. XV58	PMT	1Y											I		RRC	RRC-IRCP	136026	C
2,675	ERU -58 -CV	ERU-XV5801601	INSPECT CONTROL VALVE NO. XV58	INS	1Y											I		RRC	RRC-IRCP	136027	C
2,676	ERU -58 -CV	ERU-XV5801601	XV5801601-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261483	C
2,677	ERU -58 -CV	ERU-XV5801602	INSPECT CONTROL VALVE NO. XV58	INS	1Y											I		RRC	RRC-IRCP	136028	C
2,678	ERU -58 -CV	ERU-XV5801602	XV5801602-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261486	C
2,679	ERU -58 -CV	ERU-XV5801603	INSPECT CONTROL VALVE NO. XV58	PMT	1Y											I		RRC	RRC-IRCP	136029	C
2,680	ERU -58 -CV	ERU-XV5801604	INSPECT CONTROL VALVE NO. XV58	INS	1Y												I	RRC	RRC-IRCP	136030	C
2,681	ERU -58 -CV	ERU-XV5801604	XV5801604-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261484	C
2,682	ERU -58 -CV	ERU-XV5801605	INSPECT CONTROL VALVE NO. XV58	INS	1Y												I	RRC	RRC-IRCP	136031	C
2,683	ERU -58 -CV	ERU-XV5801605	XV5801605-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261485	C
2,684	ERU -58 -CV	ERU-XV5801702A	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136032	C
2,685	ERU -58 -CV	ERU-XV5801702B	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136033	C
2,686	ERU -58 -CV	ERU-XV5801703A	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136034	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,687	ERU -58 -CV	ERU-XV5801703B	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136035	C
2,688	ERU -58 -CV	ERU-XV5801704A	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136036	C
2,689	ERU -58 -CV	ERU-XV5801704B	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136037	C
2,690	ERU -58 -CV	ERU-XV5801705A	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136038	C
2,691	ERU -58 -CV	ERU-XV5801705B	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136039	C
2,692	ERU -58 -CV	ERU-XV5801706A	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136040	C
2,693	ERU -58 -CV	ERU-XV5801706B	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136041	C
2,694	ERU -58 -CV	ERU-XV5801707A	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136042	C
2,695	ERU -58 -CV	ERU-XV5801707B	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136043	C
2,696	ERU -58 -CV	ERU-XV5801708A	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136044	C
2,697	ERU -58 -CV	ERU-XV5801708B	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136045	C
2,698	ERU -58 -CV	ERU-XV5801709A	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136046	C
2,699	ERU -58 -CV	ERU-XV5801709B	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136047	C
2,700	ERU -58 -CV	ERU-XV5802001	INSPECT CONTROL VALVE NO. XV58	INS	1Y												I	RRC	RRC-IRCP	136048	C
2,701	ERU -58 -CV	ERU-XV5802001	XV5802001-FULL FUNC. TEST SHUT	PMT	5Y												F	RRC	RRC-IRCP	261487	C
2,702	ERU -58 -CV	ERU-XV5802501	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136049	C
2,703	ERU -58 -CV	ERU-XV5802601	INSPECT CONTROL VALVE NO. XV58	INS	1Y												I	RRC	RRC-IRCP	136050	C
2,704	ERU -58 -CV	ERU-XV5802601	XV5802601-FULL FUNC. TEST SHUT	PMT	5Y												F	RRC	RRC-IRCP	261489	C
2,705	ERU -58 -58K101	ERU-XV5802801	INSPECT CONTROL VALVE NO. XV58	INS	1Y												I	RRC	RRC-IRCP	136051	C
2,706	ERU -58 -58K101	ERU-XV5802801	XV5802801-FULL FUNC. TEST SHUT	PMT	5Y												F	RRC	RRC-IRCP	261488	C
2,707	ERU -58 -CV	ERU-XV5802802	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136052	C
2,708	ERU -58 -CV	ERU-XV5803201	INSPECT CONTROL VALVE NO. XV58	INS	1Y												I	RRC	RRC-IRCP	136053	C
2,709	ERU -58 -CV	ERU-XV5803201	XV5803201-FULL FUNC. TEST SHUT	PMT	5Y												F	RRC	RRC-IRCP	261490	C
2,710	ERU -58 -CV	ERU-XV5803202	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136054	C
2,711	ERU -58 -CV	ERU-XV5803401	TO PREVENT FAILURE ON DEMAND	INS	1Y												I	RRC	RRC-IRCP	251344	C
2,712	ERU -58 -CV	ERU-XV5803401	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251238	C
2,713	ERU -58 -CV	ERU-XV5803501	INSPECT CONTROL VALVE NO. XV58	INS	1Y												I	RRC	RRC-IRCP	136056	C
2,714	ERU -58 -CV	ERU-XV5803501	XV5803501-FULL FUNC. TEST SHUT	PMT	5Y												F	RRC	RRC-IRCP	261491	C
2,715	ERU -58 -CV	ERU-XV5804101	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136057	C
2,716	ERU -58 -CV	ERU-XV5804102	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136058	C
2,717	ERU -58 -CV	ERU-XV5804501	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136059	C
2,718	ERU -58 -CV	ERU-XV5804701	TO PREVENT FAILURE ON DEMAND	INS	1Y												I	RRC	RRC-IRCP	251345	C
2,719	ERU -58 -CV	ERU-XV5804701	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251240	C
2,720	ERU -58 -CV	ERU-XV5804702	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136061	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,721	ERU -58 -CV	ERU-XV5804703	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136062	C
2,722	ERU -58 -CV	ERU-XV5805101	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136063	C
2,723	ERU -58 -CV	ERU-XV5805701	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136064	C
2,724	ERU -58 -CV	ERU-XV5805801	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136065	C
2,725	ERU -58 -CV	ERU-XV5805802	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136066	C
2,726	ERU -58 -CV	ERU-XV5806001	INSPECT CONTROL VALVE NO. XV58	INS	1Y												I	RRC	RRC-IRCP	136067	C
2,727	ERU -58 -CV	ERU-XV5806001	XV5806001-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261492	C
2,728	ERU -58 -58K101	ERU-XV5850703	INSPECT CONTROL VALVE NO. XV58	PMT	1Y												I	RRC	RRC-IRCP	136101	C
2,729	ERU -59 -CV	ERU-XV5900101	INSPECT CONTROL VALVE NO. XV59	PMT	1Y												I	RRC	RRC-IRCP	136068	C
2,730	ERU -58 -58K001	MSS-58K001-VSD	Inspect 6.3KV VARISPEED DRIVE FOR 58K001	PMT	3M	I			I			I			I			CCH	CCH-VSD	140515	A
2,731	ERU -58 -58K001	MSS-58K001-VSD	PM 6.3KV VARISPEED DRIVE FOR 58K001-M	PMT	1Y											P		CCH	CCH-VSD	140522	A
2,732	ERU -58 -58K001	MSS-58K001-VSD	Inspect 6.3KV VARISPEED DRIVE FOR 58K001	PMT	3M		I			I			I			I		RRC	RRC-ERCP	254170	A
2,733	ERU -58 -58K401	MSS-58K401-VSD	Inspect 6.3KV VARISPEED DRIVE FOR 58K401	PMT	3M	I			I			I			I			CCH	CCH-VSD	140516	A
2,734	ERU -58 -58K401	MSS-58K401-VSD	PM 6.3KV VARISPEED DRIVE FOR 58K401-M	PMT	1Y											P		CCH	CCH-VSD	140523	A
2,735	ERU -58 -58K401	MSS-58K401-VSD	Inspect 6.3KV VARISPEED DRIVE FOR 58K401	PMT	3M		I			I			I			I		RRC	RRC-ERCP	254171	A
2,736	ERU -58 -58K501	MSS-58K501-VSD	Inspect 6.3KV VARISPEED DRIVE FOR 58K501	INT	3M	I			I			I			I			CCH	CCH-VSD	258075	A
2,737	ERU -58 -58K501	MSS-58K501-VSD	PM 6.3KV VARISPEED DRIVE FOR 58K501-MPM	PMT	1Y											P		CCH	CCH-VSD	258074	A
2,738	ERU -58 -58K501	MSS-58K501-VSD	Inspect 6.3KV VARISPEED DRIVE FOR 58K501	PMT	3M		I			I			I			I		RRC	RRC-ERCP	254129	A
2,739	ERU -54 -54K001A	MSS-B2-3001-A09	INSPECT M/V SWGR & CB B2-3001-A09	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138359	A
2,740	ERU -54 -54P001A	MSS-B2-3001-A10	INSPECT M/V SWGR & CB B2-3001-A10	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138358	A
2,741	ERU -57 -57K001	MSS-B2-3001-A12	INSPECT M/V SWGR & CB B2-3001-A12	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138356	B
2,742	ERU -57 -57P001A	MSS-B2-3001-A13	INSPECT M/V SWGR & CB B2-3001-A13	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138355	C
2,743	ERU -57 -57P002A	MSS-B2-3001-A14	INSPECT M/V SWGR & CB B2-3001-A14	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138354	C
2,744	ERU -57 -57P002C	MSS-B2-3001-A15	INSPECT M/V SWGR & CB B2-3001-A15	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138353	C
2,745	ERU -57 -57P004A	MSS-B2-3001-A16	INSPECT M/V SWGR & CB B2-3001-A16	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138352	C
2,746	ERU -58 -58K401	MSS-B2-3001-A17	PM M/V SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249605	A
2,747	ERU -58 -58K401	MSS-B2-3001-A17	INSPECT M/V SWGR & CB B2-3001-A17	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138351	A
2,748	ERU -54 -54K001B	MSS-B2-3001-B11	INSPECT M/V SWGR & CB B2-3001-B11	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138322	A
2,749	ERU -54 -54P001B	MSS-B2-3001-B12	INSPECT M/V SWGR & CB B2-3001-B12	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138323	A
2,750	ERU -57 -57K002	MSS-B2-3001-B14	INSPECT M/V SWGR & CB B2-3001-B14	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138325	B
2,751	ERU -57 -57P001B	MSS-B2-3001-B15	INSPECT M/V SWGR & CB B2-3001-B15	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138326	C
2,752	ERU -57 -57P001C	MSS-B2-3001-B16	INSPECT M/V SWGR & CB B2-3001-B16	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138327	C
2,753	ERU -57 -57P002B	MSS-B2-3001-B17	INSPECT M/V SWGR & CB B2-3001-B17	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138328	C
2,754	ERU -57 -57P004B	MSS-B2-3001-B18	INSPECT M/V SWGR & CB B2-3001-B18	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138329	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: ERU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,755	ERU -58 -58K001	MSS-B2-3001-B19	PM M/V SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249629	A
2,756	ERU -58 -58K001	MSS-B2-3001-B19	INSPECT M/V SWGR & CB B2-3001-B19	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138330	A
2,757	ERU -58 -58K501	MSS-B2-3001-B21	PM M/V SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249630	A
2,758	ERU -58 -58K501	MSS-B2-3001-B21	INSPECT M/V SWGR & CB B2-3001-B21	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138332	A
2,759	ERU -58 -58K501	MSS-B2-3001-B22	PM M/V SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249631	A
2,760	ERU -58 -58K501	MSS-B2-3001-B22	INSPECT M/V SWGR & CB B2-3001-B22	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138333	A
2,761	ERU -58 -58K001	MSS-B2-3002-01	PM M/V SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249637	A
2,762	ERU -58 -58K001	MSS-B2-3002-01	INSPECT M/V SWGR & CB B2-3002-A01	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138367	A
2,763	ERU -58 -58K001	MSS-B2-3002-02	PM M/V SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249638	A
2,764	ERU -58 -58K001	MSS-B2-3002-02	INSPECT M/V SWGR & CB B2-3002-A02	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138368	A
2,765	ERU -58 -58K401	MSS-B2-3002-04	PM M/V SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249639	A
2,766	ERU -58 -58K401	MSS-B2-3002-04	INSPECT M/V SWGR & BP-B2-3004-A01	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138370	A
2,767	ERU -58 -58K401	MSS-B2-3002-05	PM M/V SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249640	A
2,768	ERU -58 -58K401	MSS-B2-3002-05	INSPECT M/V SWGR & CB B2-3004-A02	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138371	A
2,769	ERU -58 -58K501	MSS-B2-3002-07	PM M/V SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249641	A
2,770	ERU -58 -58K501	MSS-B2-3002-07	INSPECT M/V SWGR & CB B2-3006-A01	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138373	A
2,771	ERU -58 -58K501	MSS-B2-3002-08	PM M/V SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249642	A
2,772	ERU -58 -58K501	MSS-B2-3002-08	INSPECT M/V SWGR & CB B2-3006-A02	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138374	A
2,773	ERU -58 -58K001	MSS-TR-B2-2009	OIL ANALYSIS (DGA,etc.) TR_B2-2009	PMT	1Y										Q			CCH	CCH-TRTL	140457	A
2,774	ERU -58 -58K001	MSS-TR-B2-2009	PM DISTRIBUTION TRANSFORMER	PMT	5Y											P		CCH	CCH-TRTL	249667	A
2,775	ERU -58 -58K001	MSS-TR-B2-2009	INSPECTION M/V TRANSFORMER TR_B2-2009	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138390	A
2,776	ERU -58 -58K401	MSS-TR-B2-2010	OIL ANALYSIS (DGA,etc.) TR_B2-2010	PMT	1Y										Q			CCH	CCH-TRTL	140458	A
2,777	ERU -58 -58K401	MSS-TR-B2-2010	PM DISTRIBUTION TRANSFORMER	PMT	5Y											P		CCH	CCH-TRTL	249668	A
2,778	ERU -58 -58K401	MSS-TR-B2-2010	INSPECTION M/V TRANSFORMER TR_B2-2010	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138391	A
2,779	ERU -58 -58K501	MSS-TR-B2-2011	OIL ANALYSIS (DGA,etc.) TR_B2-2011	PMT	1Y										Q			CCH	CCH-TRTL	140459	A
2,780	ERU -58 -58K501	MSS-TR-B2-2011	PM DISTRIBUTION TRANSFORMER	PMT	5Y											P		CCH	CCH-TRTL	249669	A
2,781	ERU -58 -58K501	MSS-TR-B2-2011	INSPECTION M/V TRANSFORMER TR_B2-2011	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCP	138392	A
2,782	ERU -58 -58K501	MSS-VSD-STANDBY	Inspec VSD STD FOR 58K001_58K401_58K501	PMT	3M		I			I			I			I		RRC	RRC-ERCP	254130	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1	HSU		VB. INSP & ANALY M/C HSU PLANT	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	150295	
2	HSU -72 -72K101		PM COMBUSTION AIR LOWER NO. 72K101	PMT	1Y						P							CRE	CRE-OHIP	155804	B
3	HSU -72 -72K201		PM COMBUSTION AIR LOWER NO. 72K201	PMT	1Y							P						CRE	CRE-OHIP	155805	B
4	HSU -72 -72K301		PM COMBUSTION AIR LOWER NO. 72K301	PMT	1Y				P									CRE	CRE-OHIP	155806	B
5	HSU -72 -72K601		PM COMBUSTION AIR LOWER NO. 72K601	PMT	1Y									P				CRE	CRE-OHIP	155807	B
6	HSU -51 -GRD_LIGHTN		PM GND SYS (LOOP) (UNIT 51)	PMT	1Y			P										RRC	RRC-ERCH	140347	
7	HSU -51 -GRD_LIGHTN		VISUAL GROUNDING SYS (UNIT 51)	PMT	4M			P				P				P		RRC	RRC-ERCH	141707	
8	HSU -70 -GRD_LIGHTN		PM GND SYS (LOOP) (UNIT 70)	PMT	1Y												P	RRC	RRC-ERCH	140348	
9	HSU -70 -GRD_LIGHTN		VISUAL GROUNDING SYS (UNIT 70)	PMT	4M				P				P				P	RRC	RRC-ERCH	141708	
10	HSU -71 -GRD_LIGHTN		PM GND SYS (LOOP) (UNIT 71)	PMT	1Y	P												RRC	RRC-ERCH	140349	
11	HSU -71 -GRD_LIGHTN		VISUAL GROUNDING SYS (UNIT 71)	PMT	4M	P				P				P				RRC	RRC-ERCH	141709	
12	HSU -72 -GRD_LIGHTN		PM GND SYS (LOOP) (UNIT 72)	PMT	1Y		P											RRC	RRC-ERCH	140350	
13	HSU -72 -GRD_LIGHTN		VISUAL GROUNDING SYS (UNIT 72)	PMT	4M		P				P				P			RRC	RRC-ERCH	141710	
14	HSU -73 -GRD_LIGHTN		PM GND SYS (LOOP) (UNIT 73)	PMT	1Y		P											RRC	RRC-ERCH	140351	
15	HSU -73 -GRD_LIGHTN		VISUAL GROUNDING SYS (UNIT 73)	PMT	4M		P				P				P			RRC	RRC-ERCH	141711	
16	HSU -51 -PIPING	1-1/2-AII-51351003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167721	C
17	HSU -72 -PIPING	1-1/2-AIP-72361001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168769	C
18	HSU -73 -PIPING	1-1/2-AML-73020005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169058	B
19	HSU -73 -PIPING	1-1/2-AML-73020007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169060	B
20	HSU -73 -PIPING	1-1/2-AML-73020009	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169062	B
21	HSU -73 -PIPING	1-1/2-AML-73020011	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169064	B
22	HSU -73 -PIPING	1-1/2-AML-73021001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169069	B
23	HSU -73 -PIPING	1-1/2-AML-73021003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169071	B
24	HSU -73 -PIPING	1-1/2-AML-73021004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169072	B
25	HSU -73 -PIPING	1-1/2-AML-73021006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169073	B
26	HSU -73 -PIPING	1-1/2-AML-73022003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169084	B
27	HSU -73 -PIPING	1-1/2-AML-73022005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169085	B
28	HSU -73 -PIPING	1-1/2-AML-73022006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169086	B
29	HSU -73 -PIPING	1-1/2-AML-73022007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169087	B
30	HSU -73 -PIPING	1-1/2-AMWD73017001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169015	B
31	HSU -73 -PIPING	1-1/2-AMWD73018001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169033	B
32	HSU -72 -PIPING	1-1/2-NL72371007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168779	C
33	HSU -51 -PIPING	1-1/2-P-51012031	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167455	B
34	HSU -51 -PIPING	1-1/2-P-51012033	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167457	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
35	HSU -51 -PIPING	1-1/2-P-51018011	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167498	B
36	HSU -51 -PIPING	1-1/2-P-51018012	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167499	B
37	HSU -51 -PIPING	1-AII-51351005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167722	C
38	HSU -51 -PIPING	1-AII-51351006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167723	C
39	HSU -70 -PIPING	1-AIP-70361002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167771	C
40	HSU -70 -PIPING	1-AIP-70361003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167772	C
41	HSU -70 -PIPING	1-AIP-70361004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167773	C
42	HSU -70 -PIPING	1-AIP-70361005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167774	C
43	HSU -72 -PIPING	1-AIP-72361003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168771	C
44	HSU -72 -PIPING	1-AIP-72361004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168772	C
45	HSU -71 -PIPING	1-AMD-71001301	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168093	B
46	HSU -71 -PIPING	1-AMD-71001302	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168094	B
47	HSU -71 -PIPING	1-AMD-71007301	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168129	B
48	HSU -73 -PIPING	1-AML-73020012	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169065	B
49	HSU -71 -PIPING	1-AMR-71001301	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168192	B
50	HSU -71 -PIPING	1-AMR-71001303	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168202	B
51	HSU -73 -PIPING	1-AMWD-73016006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168997	B
52	HSU -73 -PIPING	1-AMWD-73016007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168998	B
53	HSU -73 -PIPING	1-AMWD-73019003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169049	B
54	HSU -73 -PIPING	1-AMWD-73019004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169050	B
55	HSU -70 -PIPING	1-AMX-70002004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167825	B
56	HSU -51 -PIPING	1-NL-51371001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167725	C
57	HSU -51 -PIPING	1-NL-51371002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167726	C
58	HSU -51 -PIPING	1-NL-51371011	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167735	C
59	HSU -51 -PIPING	1-NL-51371018	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167742	C
60	HSU -72 -PIPING	1-NL-72371006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168778	C
61	HSU -72 -PIPING	1-NL-72371012	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168784	C
62	HSU -72 -PIPING	1-NL-72371016	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168789	C
63	HSU -72 -PIPING	1-NL-72371018	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168790	C
64	HSU -72 -PIPING	1-NL-72372011	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168801	C
65	HSU -72 -PIPING	1-NL-72372025	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168815	C
66	HSU -72 -PIPING	1-NL-72372026	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168816	C
67	HSU -72 -PIPING	1-NL-72372027	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168817	C
68	HSU -72 -PIPING	1-NL-72372031	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168821	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
69	HSU -51 -PIPING	1-P-51012003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167453	B
70	HSU -73 -PIPING	1-P-73009006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168934	B
71	HSU -72 -PIPING	1-WCI-72040024	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168441	B
72	HSU -72 -PIPING	1-WCI-72040025	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168442	B
73	HSU -71 -PIPING	1/2-AD-71502001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168085	B
74	HSU -72 -PIPING	1/2-AII-72351003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168759	C
75	HSU -72 -PIPING	1/2-AII-72351004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168760	C
76	HSU -72 -PIPING	1/2-AII-72351005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168761	C
77	HSU -72 -PIPING	1/2-AII-72351006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168762	C
78	HSU -51 -PIPING	1/2-GCH-51551001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167604	A
79	HSU -51 -PIPING	1/2-GCH-51552001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167605	A
80	HSU -51 -PIPING	1/2-GCH-51553001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167606	A
81	HSU -71 -PIPING	1/2-GCH-71501001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168210	A
82	HSU -71 -PIPING	10-AMD-71009004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168140	B
83	HSU -71 -PIPING	10-AMD-71009006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168142	B
84	HSU -71 -PIPING	10-AML-71002001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168159	B
85	HSU -71 -PIPING	10-AML-71005001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168172	B
86	HSU -71 -PIPING	10-AML-71005004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168175	B
87	HSU -71 -PIPING	10-AML-71006009	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168180	B
88	HSU -71 -PIPING	10-AML-71007009	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168189	B
89	HSU -71 -PIPING	10-AMR-71001002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168194	B
90	HSU -71 -PIPING	10-AMR-71001004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168196	B
91	HSU -51 -PIPING	10-P-51017001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167479	B
92	HSU -51 -PIPING	10-P-51018006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167492	B
93	HSU -73 -PIPING	10-P-73009004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168932	B
94	HSU -73 -PIPING	10-P-73013001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168951	B
95	HSU -71 -PIPING	12-AMR-71001001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168193	B
96	HSU -71 -PIPING	12-AMR-71001003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168195	B
97	HSU -71 -PIPING	12-AMR-71001007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168199	B
98	HSU -71 -PIPING	12-AMR-71001009	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168201	B
99	HSU -51 -PIPING	12-P-51012002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167451	B
100	HSU -51 -PIPING	12-P-51012003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167452	B
101	HSU -51 -PIPING	12-P-51012004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167454	B
102	HSU -51 -PIPING	12-P-51013001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167620	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
103	HSU -51 -PIPING	12-P-51015002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167466	B
104	HSU -51 -PIPING	12-P-51015006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167469	B
105	HSU -51 -PIPING	12-P-51016004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167475	B
106	HSU -51 -PIPING	12-P-51016005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167476	B
107	HSU -51 -PIPING	12-P-51506053	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167768	B
108	HSU -73 -PIPING	12-P-73001004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168831	B
109	HSU -73 -PIPING	12-P-73001005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168832	B
110	HSU -73 -PIPING	12-P-73001006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168833	B
111	HSU -73 -PIPING	12-P-73009003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168931	B
112	HSU -72 -PIPING	14-AC-72024002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168336	C
113	HSU -72 -PIPING	14-AC-72024005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168337	C
114	HSU -72 -PIPING	14-AC-72024008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168338	C
115	HSU -72 -PIPING	14-AC-72024011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168339	C
116	HSU -72 -PIPING	14-AC-72024014	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168341	C
117	HSU -72 -PIPING	14-AC-72024015	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168342	C
118	HSU -72 -PIPING	14-AC-72024016	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168343	C
119	HSU -72 -PIPING	14-AC-72027001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168362	C
120	HSU -72 -PIPING	14-AC-72057001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168476	C
121	HSU -72 -PIPING	14-AC-72077001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168553	C
122	HSU -73 -PIPING	16-AML-73017002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169002	B
123	HSU -51 -PIPING	16-P-51013008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167460	B
124	HSU -51 -PIPING	16-P-51015001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167465	B
125	HSU -73 -PIPING	16-P-73002001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168837	B
126	HSU -73 -PIPING	16-P-73006002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168867	B
127	HSU -73 -PIPING	16-P-73006004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168869	B
128	HSU -73 -PIPING	16-P-73008002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168914	B
129	HSU -73 -PIPING	16-P-73009001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168929	B
130	HSU -73 -PIPING	16-P-73009002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168930	B
131	HSU -72 -PIPING	2-AC-72026001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168350	C
132	HSU -72 -PIPING	2-AC-72026002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168351	C
133	HSU -72 -PIPING	2-AC-72056001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168471	C
134	HSU -72 -PIPING	2-AC-72056002-H118	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168472	C
135	HSU -72 -PIPING	2-AC-72076001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168548	C
136	HSU -72 -PIPING	2-AC-72076002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168549	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
137	HSU -70 -PIPING	2-AII-70351001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167769	C
138	HSU -72 -PIPING	2-AII-72351002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168757	C
139	HSU -72 -PIPING	2-AII-72351003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168758	C
140	HSU -51 -PIPING	2-AIP-51361001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167614	C
141	HSU -70 -PIPING	2-AIP-70361001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167770	C
142	HSU -71 -PIPING	2-AMD-71001001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168086	B
143	HSU -71 -PIPING	2-AMD-71001002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168087	B
144	HSU -71 -PIPING	2-AMD-71001007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168089	B
145	HSU -71 -PIPING	2-AMD-71001602	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168096	B
146	HSU -71 -PIPING	2-AMD-71001603	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168095	B
147	HSU -71 -PIPING	2-AMD-71002001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168098	B
148	HSU -71 -PIPING	2-AMD-71002002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168099	B
149	HSU -71 -PIPING	2-AMD-71003001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168103	B
150	HSU -71 -PIPING	2-AMD-71003002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168104	B
151	HSU -71 -PIPING	2-AMD-71004601	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168111	B
152	HSU -71 -PIPING	2-AMD-71004602	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168112	B
153	HSU -71 -PIPING	2-AMD-71005101	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168118	B
154	HSU -71 -PIPING	2-AMD-71006601	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168119	B
155	HSU -71 -PIPING	2-AMD-71006602	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168120	B
156	HSU -71 -PIPING	2-AMD-71007001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168122	B
157	HSU -71 -PIPING	2-AMD-71007003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168124	B
158	HSU -71 -PIPING	2-AMD-71007005-H24	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168126	B
159	HSU -71 -PIPING	2-AMD-71007007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168127	B
160	HSU -71 -PIPING	2-AMD-71007008-H24	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168128	B
161	HSU -71 -PIPING	2-AMD-71008008	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168136	B
162	HSU -71 -PIPING	2-AMD-71009007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168143	B
163	HSU -71 -PIPING	2-AMD-71009009	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168145	B
164	HSU -71 -PIPING	2-AMD-71009014	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168149	B
165	HSU -71 -PIPING	2-AMD-71009015	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168150	B
166	HSU -71 -PIPING	2-AMD-71009601	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168154	B
167	HSU -71 -PIPING	2-AMD-71009602	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168155	B
168	HSU -71 -PIPING	2-AML-71007014	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168190	B
169	HSU -73 -PIPING	2-AML-73020008	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169061	B
170	HSU -73 -PIPING	2-AML-73021002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169070	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
171	HSU -73 -PIPING	2-AML-73022002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169083	B
172	HSU -73 -PIPING	2-AML-73022008	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169088	B
173	HSU -71 -PIPING	2-AMR-71001005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168197	B
174	HSU -71 -PIPING	2-AMR-71001006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168198	B
175	HSU -73 -PIPING	2-AMD-73009001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168939	B
176	HSU -73 -PIPING	2-AMD-73016001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168992	B
177	HSU -73 -PIPING	2-AMD-73016002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168993	B
178	HSU -73 -PIPING	2-AMD-73016003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168994	B
179	HSU -73 -PIPING	2-AMD-73016004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168995	B
180	HSU -73 -PIPING	2-AMD-73019001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169047	B
181	HSU -73 -PIPING	2-AMD-73019002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169048	B
182	HSU -73 -PIPING	2-AMD-73020002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169066	B
183	HSU -73 -PIPING	2-AMD-73022001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169080	B
184	HSU -70 -PIPING	2-AMK-70001002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167821	B
185	HSU -70 -PIPING	2-AMK-70002001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167822	B
186	HSU -70 -PIPING	2-AMK-70002002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167823	B
187	HSU -70 -PIPING	2-AMK-70002003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167824	B
188	HSU -70 -PIPING	2-AMK-70004001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167827	B
189	HSU -51 -PIPING	2-NL-51371028	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167750	C
190	HSU -51 -PIPING	2-NL-51371032	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167754	C
191	HSU -70 -PIPING	2-NL-70371004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167831	C
192	HSU -70 -PIPING	2-NL-70371005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167832	C
193	HSU -70 -PIPING	2-NL-70371006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167833	C
194	HSU -70 -PIPING	2-NL-70371009	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167836	C
195	HSU -70 -PIPING	2-NL-70371010	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167837	C
196	HSU -70 -PIPING	2-NL-70371013	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167840	C
197	HSU -71 -PIPING	2-NL-71001001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168228	C
198	HSU -72 -PIPING	2-NL-72027001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168364	C
199	HSU -72 -PIPING	2-NL-72057001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168478	C
200	HSU -72 -PIPING	2-NL-72077001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168555	C
201	HSU -72 -PIPING	2-NL-72371003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168775	C
202	HSU -72 -PIPING	2-NL-72371011	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168783	C
203	HSU -72 -PIPING	2-NL-72372005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168795	C
204	HSU -72 -PIPING	2-NL-72372008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168798	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
205	HSU -72 -PIPING	2-NL-72372021	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168811	C
206	HSU -72 -PIPING	2-NL-72372022	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168812	C
207	HSU -72 -PIPING	2-NL-72372023	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168813	C
208	HSU -72 -PIPING	2-NL-72372024	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168814	C
209	HSU -72 -PIPING	2-NL-72372028	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168818	C
210	HSU -73 -PIPING	2-NL-73021002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169074	C
211	HSU -73 -PIPING	2-NL-73021004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169075	C
212	HSU -51 -PIPING	2-P-51011016	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167439	B
213	HSU -51 -PIPING	2-P-51011018	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167441	B
214	HSU -51 -PIPING	2-P-51011019	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167442	B
215	HSU -51 -PIPING	2-P-51011020	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167443	B
216	HSU -51 -PIPING	2-P-51018007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167493	B
217	HSU -73 -PIPING	2-P-73009005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168933	B
218	HSU -73 -PIPING	2-P-73009007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168935	B
219	HSU -73 -PIPING	20-AC-73010002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168944	C
220	HSU -73 -PIPING	20-AC-73010005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168945	C
221	HSU -72 -PIPING	20-P-72029001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168371	B
222	HSU -72 -PIPING	20-P-72030001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168385	B
223	HSU -72 -PIPING	20-P-72030002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168386	B
224	HSU -72 -PIPING	20-P-72031001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168399	B
225	HSU -72 -PIPING	20-P-72031002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168400	B
226	HSU -72 -PIPING	20-P-72031003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168401	B
227	HSU -72 -PIPING	20-P-72031004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168402	B
228	HSU -72 -PIPING	20-P-72032001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168408	B
229	HSU -72 -PIPING	20-P-72059001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168485	B
230	HSU -72 -PIPING	20-P-72060001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168499	B
231	HSU -72 -PIPING	20-P-72060002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168500	B
232	HSU -72 -PIPING	20-P-72061001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168513	B
233	HSU -72 -PIPING	20-P-72061002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168514	B
234	HSU -72 -PIPING	20-P-72061003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168515	B
235	HSU -72 -PIPING	20-P-72061004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168516	B
236	HSU -72 -PIPING	20-P-72062001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168522	B
237	HSU -72 -PIPING	20-P-72079001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168562	B
238	HSU -72 -PIPING	20-P-72080001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168576	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
239	HSU -72 -PIPING	20-P-72080002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168577	B
240	HSU -72 -PIPING	20-P-72081001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168590	B
241	HSU -72 -PIPING	20-P-72081002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168591	B
242	HSU -72 -PIPING	20-P-72081003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168592	B
243	HSU -72 -PIPING	20-P-72081004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168593	B
244	HSU -72 -PIPING	20-P-72082001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168599	B
245	HSU -73 -PIPING	20-P-73001007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168834	B
246	HSU -73 -PIPING	24-P-73006001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168866	B
247	HSU -73 -PIPING	24-P-73008001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168913	B
248	HSU -72 -PIPING	26-AC-72024013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168340	C
249	HSU -73 -PIPING	28-P-73001003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168830	B
250	HSU -73 -PIPING	28-P-73003002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168842	B
251	HSU -73 -PIPING	28-P-73004001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168849	B
252	HSU -73 -PIPING	28-P-73004002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168850	B
253	HSU -73 -PIPING	28-P-73005001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168856	B
254	HSU -72 -PIPING	3-ADG-72035007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168433	C
255	HSU -51 -PIPING	3-AII-51351001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167720	C
256	HSU -72 -PIPING	3-AIP-72361002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168770	C
257	HSU -71 -PIPING	3-AMD-71003003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168105	B
258	HSU -71 -PIPING	3-AMD-71003004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168106	B
259	HSU -71 -PIPING	3-AMD-71005001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168115	B
260	HSU -71 -PIPING	3-AMD-71005002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168116	B
261	HSU -71 -PIPING	3-AMD-71008001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168131	B
262	HSU -71 -PIPING	3-AMD-71008002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168132	B
263	HSU -71 -PIPING	3-AMD-71008003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168133	B
264	HSU -71 -PIPING	3-AMD-71008004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168134	B
265	HSU -71 -PIPING	3-AMD-71009008	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168144	B
266	HSU -71 -PIPING	3-AMD-71009010	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168146	B
267	HSU -71 -PIPING	3-AMD-71009011	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168147	B
268	HSU -71 -PIPING	3-AMD-71009012	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168148	B
269	HSU -73 -PIPING	3-AMD-73019001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169041	B
270	HSU -73 -PIPING	3-AMD-73019003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169052	B
271	HSU -71 -PIPING	3-AML-71005005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168176	B
272	HSU -71 -PIPING	3-AML-71009001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168191	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
273	HSU -73 -PIPING	3-AML-73019003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169043	B
274	HSU -73 -PIPING	3-AML-73019004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169044	B
275	HSU -73 -PIPING	3-AML-73020001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169054	B
276	HSU -73 -PIPING	3-AML-73020002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169055	B
277	HSU -73 -PIPING	3-AML-73020003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169056	B
278	HSU -73 -PIPING	3-AML-73020004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169057	B
279	HSU -73 -PIPING	3-AML-73020006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169059	B
280	HSU -73 -PIPING	3-AML-73020010	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169063	B
281	HSU -73 -PIPING	3-AML-73022001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169082	B
282	HSU -73 -PIPING	3-AMVD-73008001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168921	B
283	HSU -73 -PIPING	3-AMVD-73017002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169016	B
284	HSU -73 -PIPING	3-AMVD-73021001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169076	B
285	HSU -73 -PIPING	3-AMVD-73021002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169077	B
286	HSU -70 -PIPING	3-AMX-70001001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167820	B
287	HSU -70 -PIPING	3-AMX-70002005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167826	B
288	HSU -71 -PIPING	3-AMX-71001001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168227	B
289	HSU -51 -PIPING	3-NL-51026003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167680	C
290	HSU -51 -PIPING	3-NL-51371033	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167755	C
291	HSU -70 -PIPING	3-NL-70371002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167829	C
292	HSU -70 -PIPING	3-NL-70371003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167830	C
293	HSU -70 -PIPING	3-NL-70371008	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167835	C
294	HSU -70 -PIPING	3-NL-70371012	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167839	C
295	HSU -51 -PIPING	3-P-51018002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167489	B
296	HSU -51 -PIPING	3-P-51018003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167383	B
297	HSU -51 -PIPING	3-P-51018005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167491	B
298	HSU -51 -PIPING	3-P-51018016	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167500	B
299	HSU -51 -PIPING	3-P-51018017	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167501	B
300	HSU -73 -PIPING	3-P-73006003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168868	B
301	HSU -73 -PIPING	3-P-73008003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168915	B
302	HSU -72 -PIPING	3/4-AD-72041004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168452	B
303	HSU -72 -PIPING	3/4-AD-72041012	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168453	B
304	HSU -51 -PIPING	3/4-AIP-51361003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167724	C
305	HSU -71 -PIPING	3/4-AMD-71001006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168088	B
306	HSU -71 -PIPING	3/4-AMD-71001201	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168090	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
307	HSU -71 -PIPING	3/4-AMD-71001202	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168091	B
308	HSU -71 -PIPING	3/4-AMD-71001203	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168092	B
309	HSU -71 -PIPING	3/4-AMD-71001701	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168097	B
310	HSU -71 -PIPING	3/4-AMD-71004201	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168110	B
311	HSU -71 -PIPING	3/4-AMD-71004701	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168113	B
312	HSU -71 -PIPING	3/4-AMD-71004702	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168114	B
313	HSU -71 -PIPING	3/4-AMD-71005006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168117	B
314	HSU -71 -PIPING	3/4-AMD-71007004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168125	B
315	HSU -71 -PIPING	3/4-AMD-71008005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168135	B
316	HSU -71 -PIPING	3/4-AMD-71009016	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168151	B
317	HSU -71 -PIPING	3/4-AMD-71009017	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168152	B
318	HSU -71 -PIPING	3/4-AMD-71009019	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168153	B
319	HSU -73 -PIPING	3/4-AML-73019301	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169045	B
320	HSU -73 -PIPING	3/4-AMR-73008301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168910	B
321	HSU -73 -PIPING	3/4-AMVD-73008201	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168922	B
322	HSU -73 -PIPING	3/4-AMVD-73008202	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168923	B
323	HSU -73 -PIPING	3/4-AMVD-73008301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168927	B
324	HSU -73 -PIPING	3/4-AMVD-73008601	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168925	B
325	HSU -73 -PIPING	3/4-AMVD-73008602	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168926	B
326	HSU -73 -PIPING	3/4-AMVD-73008701	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168924	B
327	HSU -73 -PIPING	3/4-AMVD-73016005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168996	B
328	HSU -73 -PIPING	3/4-AMVD-73016601	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168999	B
329	HSU -73 -PIPING	3/4-AMVD-73016602	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169000	B
330	HSU -73 -PIPING	3/4-AMVD-73017201	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169017	B
331	HSU -73 -PIPING	3/4-AMVD-73019301	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169051	B
332	HSU -73 -PIPING	3/4-AMVD-73020701	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169067	B
333	HSU -73 -PIPING	3/4-AMVD-73020702	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169068	B
334	HSU -73 -PIPING	3/4-AMVD-73021601	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169078	B
335	HSU -73 -PIPING	3/4-AMVD-73021602	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169079	B
336	HSU -51 -PIPING	3/4-NL-51026301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167690	C
337	HSU -51 -PIPING	3/4-NL-51371003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167727	C
338	HSU -51 -PIPING	3/4-NL-51371004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167728	C
339	HSU -51 -PIPING	3/4-NL-51371005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167729	C
340	HSU -51 -PIPING	3/4-NL-51371006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167730	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
341	HSU -51 -PIPING	3/4-NL-51371007	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167731	C
342	HSU -51 -PIPING	3/4-NL-51371008	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167732	C
343	HSU -51 -PIPING	3/4-NL-51371009	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167733	C
344	HSU -51 -PIPING	3/4-NL-51371010	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167734	C
345	HSU -51 -PIPING	3/4-NL-51371012	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167736	C
346	HSU -51 -PIPING	3/4-NL-51371013	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167737	C
347	HSU -51 -PIPING	3/4-NL-51371014	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167738	C
348	HSU -51 -PIPING	3/4-NL-51371015	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167739	C
349	HSU -51 -PIPING	3/4-NL-51371016	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167740	C
350	HSU -51 -PIPING	3/4-NL-51371017	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167741	C
351	HSU -51 -PIPING	3/4-NL-51371019	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167743	C
352	HSU -51 -PIPING	3/4-NL-51371020	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167744	C
353	HSU -51 -PIPING	3/4-NL-51371022	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167746	C
354	HSU -51 -PIPING	3/4-NL-51371023	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167747	C
355	HSU -51 -PIPING	3/4-NL-51371026	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167748	C
356	HSU -51 -PIPING	3/4-NL-51371027	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167749	C
357	HSU -51 -PIPING	3/4-NL-51371029	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167751	C
358	HSU -51 -PIPING	3/4-NL-51371030	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167752	C
359	HSU -51 -PIPING	3/4-NL-51371031	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167753	C
360	HSU -70 -PIPING	3/4-NL-70371011	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167838	C
361	HSU -72 -PIPING	3/4-NL-72371004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168776	C
362	HSU -72 -PIPING	3/4-NL-72372001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168791	C
363	HSU -72 -PIPING	3/4-NL-72372002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168792	C
364	HSU -72 -PIPING	3/4-NL-72372003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168793	C
365	HSU -72 -PIPING	3/4-NL-72372004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168794	C
366	HSU -72 -PIPING	3/4-NL-72372006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168796	C
367	HSU -72 -PIPING	3/4-NL-72372007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168797	C
368	HSU -72 -PIPING	3/4-NL-72372012	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168802	C
369	HSU -72 -PIPING	3/4-NL-72372014	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168804	C
370	HSU -72 -PIPING	3/4-NL-72372015	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168805	C
371	HSU -72 -PIPING	3/4-NL-72372016	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168806	C
372	HSU -72 -PIPING	3/4-NL-72372017	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168807	C
373	HSU -72 -PIPING	3/4-NL-72372018	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168808	C
374	HSU -72 -PIPING	3/4-NL-72372019	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168809	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
375	HSU -72 -PIPING	3/4-NL-72372020	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168810	C
376	HSU -72 -PIPING	3/4-NL-72372029	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168819	C
377	HSU -72 -PIPING	3/4-NL-72372030	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168820	C
378	HSU -72 -PIPING	3/4-NL72372009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168799	C
379	HSU -72 -PIPING	3/4-NL72372010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168800	C
380	HSU -72 -PIPING	3/4-NL72372013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168803	C
381	HSU -51 -PIPING	3/4-P-51011005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167429	B
382	HSU -51 -PIPING	3/4-P-51011006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167430	B
383	HSU -51 -PIPING	3/4-P-51011007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167431	B
384	HSU -51 -PIPING	3/4-P-51011012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167435	B
385	HSU -51 -PIPING	3/4-P-51011301	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167449	B
386	HSU -51 -PIPING	3/4-P-51012301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167459	B
387	HSU -51 -PIPING	3/4-P-51017301	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167487	B
388	HSU -51 -PIPING	3/4-P-51018301	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167509	B
389	HSU -51 -PIPING	3/4-P-51018302	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167511	B
390	HSU -51 -PIPING	3/4-P-51018303	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167513	B
391	HSU -72 -PIPING	3/4-P-72030301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168387	B
392	HSU -72 -PIPING	3/4-P-72030302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168388	B
393	HSU -72 -PIPING	3/4-P-72031301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168403	B
394	HSU -72 -PIPING	3/4-P-72031302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168404	B
395	HSU -72 -PIPING	3/4-P-72032301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168409	B
396	HSU -72 -PIPING	3/4-P-72060301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168501	B
397	HSU -72 -PIPING	3/4-P-72060302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168502	B
398	HSU -72 -PIPING	3/4-P-72061301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168517	B
399	HSU -72 -PIPING	3/4-P-72061302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168518	B
400	HSU -72 -PIPING	3/4-P-72062301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168523	B
401	HSU -72 -PIPING	3/4-P-72080301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168578	B
402	HSU -72 -PIPING	3/4-P-72080302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168579	B
403	HSU -72 -PIPING	3/4-P-72081301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168594	B
404	HSU -72 -PIPING	3/4-P-72081302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168595	B
405	HSU -72 -PIPING	3/4-P-72082301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168600	B
406	HSU -73 -PIPING	3/4-P-73004301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168851	A
407	HSU -73 -PIPING	3/4-P-73005301	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168857	A
408	HSU -73 -PIPING	3/4-P-73006301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168870	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
409	HSU -73 -PIPING	3/4-P-73008301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168916	A
410	HSU -72 -PIPING	3/4-WCI-72040026	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168443	B
411	HSU -72 -PIPING	3/4-WCI-72040027	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168444	B
412	HSU -72 -PIPING	3/4-WCI-72040028	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168445	B
413	HSU -72 -PIPING	3/4-WCI-72040029	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168446	B
414	HSU -72 -PIPING	3/4-WCI-72040030	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168447	B
415	HSU -72 -PIPING	3/4-WCI-72040031	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168448	B
416	HSU -72 -PIPING	3/4-WCI-72040032	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168449	B
417	HSU -72 -PIPING	3/4-WCI-72040033	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168450	B
418	HSU -72 -PIPING	4-AII-72351001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168756	C
419	HSU -71 -PIPING	4-AWD-71003005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168107	B
420	HSU -73 -PIPING	4-AWD-73022002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169081	B
421	HSU -73 -PIPING	4-AWL-73016001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168984	B
422	HSU -72 -PIPING	4-WWD-72811001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168828	B
423	HSU -51 -PIPING	4-NL-51012005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167616	C
424	HSU -51 -PIPING	4-NL-51012006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167617	C
425	HSU -51 -PIPING	4-NL-51012009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167618	C
426	HSU -51 -PIPING	4-NL-51026001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167678	C
427	HSU -51 -PIPING	4-NL-51026005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167682	C
428	HSU -51 -PIPING	4-NL-51026076	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167688	C
429	HSU -51 -PIPING	4-NL-51026077	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167689	C
430	HSU -72 -PIPING	4-NL-72371005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168777	C
431	HSU -72 -PIPING	4-NL-72371008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168780	C
432	HSU -72 -PIPING	4-NL-72371009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168781	C
433	HSU -72 -PIPING	4-NL-72371010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168782	C
434	HSU -72 -PIPING	6-AC-72026003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168349	C
435	HSU -72 -PIPING	6-AC-72056003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168470	C
436	HSU -72 -PIPING	6-AC-72076003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168547	C
437	HSU -71 -PIPING	6-AWD-71811001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168156	B
438	HSU -71 -PIPING	6-AWD-71811002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168157	B
439	HSU -71 -PIPING	6-AWD-71811003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168158	B
440	HSU -73 -PIPING	6-AWD-73020001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169053	B
441	HSU -71 -PIPING	6-AWL-71006003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168179	B
442	HSU -73 -PIPING	6-AWL-73016001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168986	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
443	HSU -73 -PIPING	6-AWL-73016002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168987	B
444	HSU -73 -PIPING	6-AWL-73016003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168988	B
445	HSU -73 -PIPING	6-AWL-73016004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168989	B
446	HSU -73 -PIPING	6-AWL-73016005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168990	B
447	HSU -73 -PIPING	6-AWL-73017001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169001	B
448	HSU -73 -PIPING	6-AWL-73019001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	169042	B
449	HSU -71 -PIPING	6-AWR-71001008	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168200	B
450	HSU -73 -PIPING	6-AWR-73008001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168906	B
451	HSU -73 -PIPING	6-AWR-73008002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168907	B
452	HSU -73 -PIPING	6-AWR-73008003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168908	B
453	HSU -73 -PIPING	6-AWR-73008004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168909	B
454	HSU -73 -PIPING	6-AWR-73016001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168991	B
455	HSU -51 -PIPING	6-NL-51026002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167679	C
456	HSU -51 -PIPING	6-NL-51026004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167681	C
457	HSU -70 -PIPING	6-NL-70371001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167828	C
458	HSU -72 -PIPING	6-NL-72371001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168773	C
459	HSU -72 -PIPING	6-NL-72371013	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168785	C
460	HSU -72 -PIPING	6-NL-72371014	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168786	C
461	HSU -72 -PIPING	6-NL-72371015	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168788	C
462	HSU -72 -PIPING	6-NL-72371016	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168787	C
463	HSU -51 -PIPING	6-P-51010002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167419	B
464	HSU -51 -PIPING	6-P-51015051	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167472	B
465	HSU -51 -PIPING	6-P-51015052	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167473	B
466	HSU -51 -PIPING	6-P-51018004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167490	B
467	HSU -51 -PIPING	6-P-51018056	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167506	B
468	HSU -73 -PIPING	8-AC-73012001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	168948	C
469	HSU -71 -PIPING	8-AWD-71009001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168137	B
470	HSU -71 -PIPING	8-AWD-71009002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168138	B
471	HSU -71 -PIPING	8-AWD-71009003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168139	B
472	HSU -71 -PIPING	8-AWD-71009005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168141	B
473	HSU -73 -PIPING	8-AWD-73016002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	168985	B
474	HSU -51 -PIPING	8-NL-51018020	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167652	C
475	HSU -51 -PIPING	8-NL-51026007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	167684	C
476	HSU -51 -PIPING	8-NL-51371021	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	167745	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
477	HSU -70 -PIPING	8-NL-70371007	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	167834	C
478	HSU -72 -PIPING	8-NL-72371002	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	168774	C
479	HSU -51 -PIPING	8-P-51011008	Piping inspection	PMT	5Y					I								IRI	IRI-INRC	167432	B
480	HSU -51 -PIPING	8-P-51011009	Piping inspection	PMT	5Y					I								IRI	IRI-INRC	167433	B
481	HSU -51 -PIPING	8-P-51011011	Piping inspection	PMT	5Y					I								IRI	IRI-INRC	167434	B
482	HSU -51 -PIPING	8-P-51011013	Piping inspection	PMT	5Y					I								IRI	IRI-INRC	167436	B
483	HSU -51 -PIPING	8-P-51011022	Piping inspection	PMT	5Y					I								IRI	IRI-INRC	167445	B
484	HSU -51 -PIPING	8-P-51011025	Piping inspection	PMT	5Y					I								IRI	IRI-INRC	167447	B
485	HSU -51 -PIPING	8-P-51013009	Piping inspection	PMT	5Y					I								IRI	IRI-INRC	167461	B
486	HSU -51 -PIPING	8-P-51015003	Piping inspection	PMT	5Y					I								IRI	IRI-INRC	167467	B
487	HSU -51 -PIPING	8-P-51015005	Piping inspection	PMT	5Y					I								IRI	IRI-INRC	167468	B
488	HSU -51 -PIPING	8-P-51015008	Piping inspection	PMT	5Y					I								IRI	IRI-INRC	167470	B
489	HSU -51 -PIPING	8-P-51016002	Piping inspection	PMT	5Y					I								IRI	IRI-INRC	167474	B
490	HSU -51 -PIPING	8-P-51016006	Piping inspection	PMT	5Y					I								IRI	IRI-INRC	167477	B
491	HSU -51 -PIPING	8-P-51018008	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	167494	B
492	HSU -51 -PIPING	8-P-51018009	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	167495	B
493	HSU -51 -PIPING	8-P-51018010	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	167496	B
494	HSU -51 -PIPING	8-P-51019009	Piping inspection	PMT	5Y					I								IRI	IRI-INRC	167524	B
495	HSU -51 -AIR	HSU-51-AC-001	PM ALL TYPE OF AIR 51-AC-001 (Large 2,8)	PMT	2M				P		P			P		P	P	RRC	RRC-ERCH	138220	B
496	HSU -51 -AIR	HSU-51-AC-001	PM ALL TYPE OF AIR 51-AC-001 (Large 2,8)	PMT	6M		P						P					RRC	RRC-ERCH	138220	B
497	HSU -51 -AIR	HSU-51-AC-002	PM ALL TYPE OF AIR 51-AC-002 (Large 2,8)	PMT	2M				P		P			P		P	P	RRC	RRC-ERCH	138221	B
498	HSU -51 -AIR	HSU-51-AC-002	PM ALL TYPE OF AIR 51-AC-002 (Large 2,8)	PMT	6M		P						P					RRC	RRC-ERCH	138221	B
499	HSU -51 -AIR	HSU-51-CEMS-001	PM TYPE OF AIR 51-CEMS-001 (Large 2,8)	PMT	2M				P		P			P		P	P	RRC	RRC-ERCH	138248	A
500	HSU -51 -AIR	HSU-51-CEMS-001	PM TYPE OF AIR 51-CEMS-001 (Large 2,8)	PMT	6M		P						P					RRC	RRC-ERCH	138248	A
501	HSU -51 -51B001	HSU-51B001-B01	FIRE HEATER ON-STREAM INSPECTION#51B001	PMT	1Y					I								IRI	IRI-INRC	150307	A
502	HSU -51 -51B002	HSU-51B002-B01	FIRE HEATER ON-STREAM INSPECTION#51B002	PMT	1Y					I								IRI	IRI-INRC	150306	A
503	HSU -51 -51B003	HSU-51B003-B01	FIRE HEATER ON-STREAM INSPECTION#51B003	PMT	1Y					I								IRI	IRI-INRC	150305	A
504	HSU -51 -51B004	HSU-51B004-B01	FIRE HEATER ON-STREAM INSPECTION#51B004	PMT	1Y					I								IRI	IRI-INRC	150304	A
505	HSU -51 -51B005	HSU-51B005-B01	FIRE HEATER ON-STREAM INSPECTION#51B005	PMT	1Y					I								IRI	IRI-INRC	150303	A
506	HSU -51 -51B006A	HSU-51B006A-B01	FIRE HEATER ON-STREAM INSPECTION#51B006A	PMT	1Y					I								IRI	IRI-INRC	150301	A
507	HSU -51 -51B006B	HSU-51B006B-B01	FIRE HEATER ON-STREAM INSPECTION#51B006B	PMT	1Y					I								IRI	IRI-INRC	150302	A
508	HSU -51 -51B007	HSU-51B007-B01	Fire Boilers and Heaters On-St	INT	1Y					I								IRI	IRI-INRC	158214	A
509	HSU -51 -51B010	HSU-51B010-B01	FIRE HEATER ON-STREAM INSPECTION#51B010	PMT	1Y					I								IRI	IRI-INRC	150308	A
510	HSU -51 -DVA5101	HSU-51DV001	TEST LINEAR HEAT DETECTOR HSU-51DV001	PMT	6M						P					P		RRC	RRC-ERCH	150123	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
511	HSU -51 -DVA5101	HSU-51DV002	TEST LINEAR HEAT DETECTOR HSU-51DV002	PMT	6M					P						P		RRC	RRC-ERCH	150124	B
512	HSU -51 -51E001	HSU-51E001-E01	On-Stream Inspection	INT	1Y				I									IRI	IRI-INRC	158215	A
513	HSU -51 -51E006	HSU-51E006A-K01A	VB. INSP & ANALY M/C 51E006A-K01A	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149180	B
514	HSU -51 -51E006	HSU-51E006A-K01A	PM INSP OF M/C NO. 51E006A-K01A	PMT	3M	I			I			I			I			RRC	RRC-MRCH	149131	B
515	HSU -51 -51E006	HSU-51E006A-K01A	REGREASING BRG OF 51E006A-K01A	PMT	3M			L		L			L			L		RRC	RRC-MRCH	149132	B
516	HSU -51 -51E006A	HSU-51E006A-K01A-M	Regreasing Mot BRG of 51E006A-K01A-MD1	PMT	4M	L				L			L			L		RRC	RRC-ERCH	139445	B
517	HSU -51 -51E006	HSU-51E006A-K01B	VB. INSP & ANALY M/C 51E006A-K01B	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149181	B
518	HSU -51 -51E006	HSU-51E006A-K01B	PM INSP OF M/C NO. 51E006A-K01B	PMT	3M	I			I			I			I			RRC	RRC-MRCH	149133	B
519	HSU -51 -51E006	HSU-51E006A-K01B	REGREASING BRG OF 51E006A-K01B	PMT	3M			L		L			L			L		RRC	RRC-MRCH	149134	B
520	HSU -51 -51E006A	HSU-51E006A-K01B-M	Regreasing Mot BRG of 51E006A-K01B-MD1	PMT	4M				L			L			L		L	RRC	RRC-ERCH	139446	B
521	HSU -51 -51E006	HSU-51E006B-K01A	VB. INSP & ANALY M/C 51E006B-K01A	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149182	B
522	HSU -51 -51E006	HSU-51E006B-K01A	PM INSP OF M/C NO. 51E006B-K01A	PMT	3M	I			I			I			I			RRC	RRC-MRCH	149135	B
523	HSU -51 -51E006	HSU-51E006B-K01A	REGREASING BRG OF 51E006B-K01A	PMT	3M			L		L			L			L		RRC	RRC-MRCH	149136	B
524	HSU -51 -51E006B	HSU-51E006B-K01A-M	Regreasing Mot BRG of 51E006B-K01A-MD1	PMT	4M	L				L			L			L		RRC	RRC-ERCH	139447	B
525	HSU -51 -51E006	HSU-51E006B-K01B	VB. INSP & ANALY M/C 51E006B-K01B	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149183	B
526	HSU -51 -51E006	HSU-51E006B-K01B	PM INSP OF M/C NO. 51E006B-K01B	PMT	3M	I			I			I			I			RRC	RRC-MRCH	149137	B
527	HSU -51 -51E006	HSU-51E006B-K01B	REGREASING BRG OF 51E006B-K01B	PMT	3M			L		L			L			L		RRC	RRC-MRCH	149138	B
528	HSU -51 -51E006B	HSU-51E006B-K01B-M	Regreasing Mot BRG of 51E006B-K01B-MD1	PMT	4M				L			L			L		L	RRC	RRC-ERCH	139448	B
529	HSU -51 -51E006	HSU-51E006C-K01A	VB. INSP & ANALY M/C 51E006C-K01A	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149184	B
530	HSU -51 -51E006	HSU-51E006C-K01A	PM INSP OF M/C NO. 51E006C-K01A	PMT	3M	I			I			I			I			RRC	RRC-MRCH	149139	B
531	HSU -51 -51E006	HSU-51E006C-K01A	REGREASING BRG OF 51E006C-K01A	PMT	3M			L		L			L			L		RRC	RRC-MRCH	149140	B
532	HSU -51 -51E006C	HSU-51E006C-K01A-M	Regreasing Mot BRG of 51E006C-K01A-MD1	PMT	4M	L				L			L			L		RRC	RRC-ERCH	139449	B
533	HSU -51 -51E006	HSU-51E006C-K01B	VB. INSP & ANALY M/C 51E006C-K01B	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149185	B
534	HSU -51 -51E006	HSU-51E006C-K01B	PM INSP OF M/C NO. 51E006C-K01B	PMT	3M	I			I			I			I			RRC	RRC-MRCH	149141	B
535	HSU -51 -51E006	HSU-51E006C-K01B	REGREASING BRG OF 51E006C-K01B	PMT	3M			L		L			L			L		RRC	RRC-MRCH	149142	B
536	HSU -51 -51E006C	HSU-51E006C-K01B-M	Regreasing Mot BRG of 51E006C-K01B-MD1	PMT	4M				L			L			L		L	RRC	RRC-ERCH	139450	B
537	HSU -51 -51E006	HSU-51E006D-K01A	VB. INSP & ANALY M/C 51E006D-K01A	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149186	B
538	HSU -51 -51E006	HSU-51E006D-K01A	PM INSP OF M/C NO. 51E006D-K01A	PMT	3M	I			I			I			I			RRC	RRC-MRCH	149143	B
539	HSU -51 -51E006	HSU-51E006D-K01A	REGREASING BRG OF 51E006D-K01A	PMT	3M			L		L			L			L		RRC	RRC-MRCH	149144	B
540	HSU -51 -51E006D	HSU-51E006D-K01A-M	Regreasing Mot BRG of 51E006D-K01A-MD1	PMT	4M	L				L			L			L		RRC	RRC-ERCH	139451	B
541	HSU -51 -51E006	HSU-51E006D-K01B	VB. INSP & ANALY M/C 51E006D-K01B	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149187	B
542	HSU -51 -51E006	HSU-51E006D-K01B	PM INSP OF M/C NO. 51E006D-K01B	PMT	3M	I			I			I			I			RRC	RRC-MRCH	149145	B
543	HSU -51 -51E006	HSU-51E006D-K01B	REGREASING BRG OF 51E006D-K01B	PMT	3M			L		L			L			L		RRC	RRC-MRCH	149146	B
544	HSU -51 -51E006D	HSU-51E006D-K01B-M	Regreasing Mot BRG of 51E006D-K01B-MD1	PMT	4M				L			L			L		L	RRC	RRC-ERCH	139452	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
545	HSU -51 -51E013	HSU-51E013-K01A	VB. INSP & ANALY M/C 51E013-K01A	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149188	C
546	HSU -51 -51E013	HSU-51E013-K01A	PM INSP OF M/C NO. 51E013-K01A	PMT	3M	I			I			I			I			RRC	RRC-MRCH	149147	C
547	HSU -51 -51E013	HSU-51E013-K01A	REGREASING BRG OF 51E013-K01A	PMT	3M			L		L			L			L		RRC	RRC-MRCH	149148	C
548	HSU -51 -51E013	HSU-51E013-K01A-M	Regreasing Mot BRG of 51E013-K01A-M	PMT	4M	L				L			L			L		RRC	RRC-ERCH	139453	C
549	HSU -51 -51E013	HSU-51E013-K01B	VB. INSP & ANALY M/C 51E013-K01B	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149189	C
550	HSU -51 -51E013	HSU-51E013-K01B	PM INSP OF M/C NO. 51E013-K01B	PMT	3M	I			I			I			I			RRC	RRC-MRCH	149149	C
551	HSU -51 -51E013	HSU-51E013-K01B	REGREASING BRG OF 51E013-K01B	PMT	3M			L		L			L			L		RRC	RRC-MRCH	149150	C
552	HSU -51 -51E013	HSU-51E013-K01B-M	Regreasing Mot BRG of 51E013-K01B-M	PMT	4M				L			L			L			RRC	RRC-ERCH	139454	C
553	HSU -51 -51H001	HSU-51H001-H01	OVERHEAD CRANE INSPECT & LOAD TEST_LAW	INT	1Y				I									IRI	IRI-INSS	157592	C
554	HSU -51 -51K001	HSU-51K001-M	STAND BY CHECK MV. MOT 51K001-M01	PMT	6M			T						T				RRC	RRC-ERCH	138954	A
555	HSU -51 -51K001	HSU-51K001-M	Regreasing Mot BRG of 51K001-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139375	A
556	HSU -51 -51K001	HSU-51K001-P01	VB. INSP & ANALY M/C 51K001	INT	4M	I				I				I				IRI	IRI-INVB	130110	A
557	HSU -51 -51K001	HSU-51K001-P01	VB. INSP & ANALY M/C 51K001 -P01	INT	4M		I				I				I			IRI	IRI-INVB	130941	A
558	HSU -51 -51K001	HSU-51K001-P01	VB. INSP & ANALY M/C 51K001 -P01	INT	4M			I				I				I		IRI	IRI-INVB	131166	A
559	HSU -51 -51K001	HSU-51K001-P01	PM INSP OF M/C NO. 51K001 -P01	PMT	4M		I				I				I			RRC	RRC-MRCH	129511	A
560	HSU -51 -51K001	HSU-51K001-P02	VB. INSP & ANALY M/C 51K001	INT	4M				I			I				I		IRI	IRI-INVB	130111	A
561	HSU -51 -51K001	HSU-51K001-P02	PM INSP OF M/C NO. 51K001 -P02	PMT	4M				I			I				I		RRC	RRC-MRCH	129512	A
562	HSU -51 -51K002	HSU-51K002-M	STAND BY CHECK MV. MOT 51K002-M01	PMT	6M			T						T				RRC	RRC-ERCH	138955	A
563	HSU -51 -51K002	HSU-51K002-M	Regreasing Mot BRG of 51K002-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139376	A
564	HSU -51 -51K002	HSU-51K002-P01	VB. INSP & ANALY M/C 51K002	INT	4M	I				I				I				IRI	IRI-INVB	130112	A
565	HSU -51 -51K002	HSU-51K002-P01	VB. INSP & ANALY M/C 51K002 -P01	INT	4M		I				I				I			IRI	IRI-INVB	130942	A
566	HSU -51 -51K002	HSU-51K002-P01	VB. INSP & ANALY M/C 51K002 -P01	INT	4M			I				I				I		IRI	IRI-INVB	131167	A
567	HSU -51 -51K002	HSU-51K002-P01	PM INSP OF M/C NO. 51K002 -P01	PMT	4M		I				I				I			RRC	RRC-MRCH	129513	A
568	HSU -51 -51K002	HSU-51K002-P02	VB. INSP & ANALY M/C 51K002	INT	4M				I			I				I		IRI	IRI-INVB	130113	A
569	HSU -51 -51K002	HSU-51K002-P02	PM INSP OF M/C NO. 51K002 -P02	PMT	4M				I			I				I		RRC	RRC-MRCH	129514	A
570	HSU -51 -51K003A	HSU-51K003A-M	STAND BY CHECK LV. MOT 51K003A-M01	PMT	6M		T					T						RRC	RRC-ERCH	138956	C
571	HSU -51 -51K003A	HSU-51K003A-M	STAND BY CHECK LV. MOT 51K003A-M01	PMT	1Y			T										RRC	RRC-ERCH	154243	C
572	HSU -51 -51K003B	HSU-51K003B-M	STAND BY CHECK LV. MOT 51K003B-M01	PMT	6M		T					T						RRC	RRC-ERCH	138957	C
573	HSU -51 -51K003C	HSU-51K003C-M	STAND BY CHECK LV. MOT 51K003C-M01	PMT	6M		T					T						RRC	RRC-ERCH	138958	C
574	HSU -51 -51K003D	HSU-51K003D-M	STAND BY CHECK LV. MOT 51K003D-M01	PMT	6M			T					T					RRC	RRC-ERCH	138959	C
575	HSU -51 -51K004A	HSU-51K004A-K01	PM COMPRESSOR NO. 51K004 A	PMT	1Y							P						CRE	CRE-OHIP	155803	B
576	HSU -51 -51K004A	HSU-51K004A-K01	OIL INSP & ANALYSIS M/C 51K004 A	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INDL	129962	B
577	HSU -51 -51K004A	HSU-51K004A-M	STAND BY CHECK MV. MOT 51K004A-M01	PMT	1Y							T						RRC	RRC-ERCH	138960	B
578	HSU -51 -51K004A	HSU-51K004A-M	Change BRG Lube Oil of Mot 51K004A-M01	PMT	1Y				L									RRC	RRC-ERCH	139377	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
579	HSU -51 -51K004A	HSU-51K004A-M	STAND BY CHECK MV. MOT 51K004A-M01	PMT	1Y					T								RRC	RRC-ERCH	154244	B
580	HSU -51 -51K004A	HSU-51K004A-P01	VB. INSP & ANALY M/C 51K004 A	INT	4M	I					I			I				IRI	IRI-INVB	130098	B
581	HSU -51 -51K004A	HSU-51K004A-P01	VB. INSP & ANALY M/C 51K004 A -P01	INT	4M		I					I			I			IRI	IRI-INVB	130935	B
582	HSU -51 -51K004A	HSU-51K004A-P01	VB. INSP & ANALY M/C 51K004 A -P01	INT	4M				I				I			I		IRI	IRI-INVB	131160	B
583	HSU -51 -51K004A	HSU-51K004A-P02	VB. INSP & ANALY M/C 51K004 A	INT	4M					I				I				IRI	IRI-INVB	130099	B
584	HSU -51 -51K004A	HSU-51K004A-P02	PM INSP OF M/C NO. 51K004 A -P02	PMT	4M					I				I				RRC	RRC-MRCH	129500	B
585	HSU -51 -51K004B	HSU-51K004B-K01	PM COMPRESSOR NO. 51K004 B	PMT	1Y										P			CRE	CRE-OHIP	129491	B
586	HSU -51 -51K004B	HSU-51K004B-K01	OIL INSP & ANALYSIS M/C 51K004 B	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INDL	129963	B
587	HSU -51 -51K004B	HSU-51K004B-M	STAND BY CHECK MV. MOT 51K004B-M01	PMT	6M			T					T					RRC	RRC-ERCH	138961	B
588	HSU -51 -51K004B	HSU-51K004B-M	Change BRG Lube Oil of Mot 51K004B-M01	PMT	1Y				L									RRC	RRC-ERCH	139378	B
589	HSU -51 -51K004B	HSU-51K004B-P01	VB. INSP & ANALY M/C 51K004 B	INT	4M	I				I			I					IRI	IRI-INVB	130100	B
590	HSU -51 -51K004B	HSU-51K004B-P01	VB. INSP & ANALY M/C 51K004 B -P01	INT	4M		I				I			I				IRI	IRI-INVB	130936	B
591	HSU -51 -51K004B	HSU-51K004B-P01	VB. INSP & ANALY M/C 51K004 B -P01	INT	4M			I				I			I			IRI	IRI-INVB	131161	B
592	HSU -51 -51K004B	HSU-51K004B-P02	VB. INSP & ANALY M/C 51K004 B	INT	4M				I				I			I		IRI	IRI-INVB	130101	B
593	HSU -51 -51K004B	HSU-51K004B-P02	PM INSP OF M/C NO. 51K004 B -P02	PMT	4M				I				I			I		RRC	RRC-MRCH	129502	B
594	HSU -51 -51K005	HSU-51K005-K01	PM COMPRESSOR NO. 51K005	PMT	1Y								P					CRE	CRE-OHIP	129492	C
595	HSU -51 -51K005	HSU-51K005-K01	OIL INSP & ANALYSIS M/C 51K005	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INDL	129964	C
596	HSU -51 -51K005	HSU-51K005-M	STAND BY CHECK MV. MOT 51K005-M01	PMT	6M			T					T					RRC	RRC-ERCH	138962	C
597	HSU -51 -51K005	HSU-51K005-M	Regreasing Mot BRG of 51K005-M01	PMT	4M	L				L			L					RRC	RRC-ERCH	139379	C
598	HSU -51 -51K005	HSU-51K005-P01	VB. INSP & ANALY M/C 51K005	INT	4M	I				I			I					IRI	IRI-INVB	130102	C
599	HSU -51 -51K005	HSU-51K005-P01	VB. INSP & ANALY M/C 51K005 -P01	INT	4M		I				I			I				IRI	IRI-INVB	130937	C
600	HSU -51 -51K005	HSU-51K005-P01	VB. INSP & ANALY M/C 51K005 -P01	INT	4M			I				I			I			IRI	IRI-INVB	131162	C
601	HSU -51 -51K005	HSU-51K005-P01	PM INSP OF M/C NO. 51K005 -P01	PMT	4M		I				I			I				RRC	RRC-MRCH	129503	C
602	HSU -51 -51K005	HSU-51K005-P02	VB. INSP & ANALY M/C 51K005	INT	4M				I			I				I		IRI	IRI-INVB	130103	C
603	HSU -51 -51K005	HSU-51K005-P02	PM INSP OF M/C NO. 51K005 -P02	PMT	4M				I			I				I		RRC	RRC-MRCH	129504	C
604	HSU -51 -51P001A	HSU-51P001A-M	STAND BY CHECK LV. MOT 51P001A-M01	PMT	1Y								T					RRC	RRC-ERCH	138963	B
605	HSU -51 -51P001A	HSU-51P001A-M	Regreasing Mot BRG of 51P001A-M01	PMT	4M	L				L			L					RRC	RRC-ERCH	139455	B
606	HSU -51 -51P001A	HSU-51P001A-M	STAND BY CHECK LV. MOT 51P001A-M01	PMT	1Y				T									RRC	RRC-ERCH	154245	B
607	HSU -51 -51P001A	HSU-51P001A-P01	VB. INSP & ANALY M/C 51P001A	INT	4M	I				I			I					IRI	IRI-INVB	130088	B
608	HSU -51 -51P001A	HSU-51P001A-P01	VB. INSP & ANALY M/C 51P001A	INT	4M		I				I			I				IRI	IRI-INVB	130932	B
609	HSU -51 -51P001A	HSU-51P001A-P01	VB. INSP & ANALY M/C 51P001A	INT	4M			I				I			I			IRI	IRI-INVB	131157	B
610	HSU -51 -51P001A	HSU-51P001A-P01	PM INSP OF M/C NO. 51P001A	PMT	4M		I				I			I				RRC	RRC-MRCH	129493	B
611	HSU -51 -51P001A	HSU-51P001A-P01	PM OF 51P001A-P01	PMT	4M			P				P			P			RRC	RRC-MRCH	130097	B
612	HSU -51 -51P001B	HSU-51P001B-M	STAND BY CHECK LV. MOT 51P001B-M01	PMT	6M			T					T					RRC	RRC-ERCH	138964	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
613	HSU -51 -51P001B	HSU-51P001B-P01	VB. INSP & ANALY M/C 51P001B	INT	4M				I				I				I	IRI	IRI-INVB	130089	B
614	HSU -51 -51P001B	HSU-51P001B-P01	PM INSP OF M/C NO. 51P001B	PMT	4M				I				I				I	RRC	RRC-MRCH	129494	B
615	HSU -51 -51P001B	HSU-51P001B-P01	PM OF 51P001B-P01	PMT	4M	P				P				P				RRC	RRC-MRCH	130579	B
616	HSU -51 -51P002A	HSU-51P002A-M	STAND BY CHECK LV. MOT 51P002A-M01	PMT	1Y							T						RRC	RRC-ERCH	138965	B
617	HSU -51 -51P002A	HSU-51P002A-M	Regreasing Mot BRG of 51P002A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139457	B
618	HSU -51 -51P002A	HSU-51P002A-M	STAND BY CHECK LV. MOT 51P002A-M01	PMT	1Y				T									RRC	RRC-ERCH	154246	B
619	HSU -51 -51P002A	HSU-51P002A-P01	VB. INSP & ANALY M/C 51P002A	INT	4M	I				I				I				IRI	IRI-INVB	130090	B
620	HSU -51 -51P002A	HSU-51P002A-P01	VB. INSP & ANALY M/C 51P002A	INT	4M		I				I				I			IRI	IRI-INVB	130933	B
621	HSU -51 -51P002A	HSU-51P002A-P01	VB. INSP & ANALY M/C 51P002A	INT	4M			I				I				I		IRI	IRI-INVB	131158	B
622	HSU -51 -51P002A	HSU-51P002A-P01	PM INSP OF M/C NO. 51P002A	PMT	4M		I				I				I			RRC	RRC-MRCH	129495	B
623	HSU -51 -51P002A	HSU-51P002A-P01	PM OF 51P002A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	130580	B
624	HSU -51 -51P002B	HSU-51P002B-M	STAND BY CHECK LV. MOT 51P002B-M01	PMT	6M			T						T				RRC	RRC-ERCH	138966	B
625	HSU -51 -51P002B	HSU-51P002B-M	Regreasing Mot BRG of 51P002B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139458	B
626	HSU -51 -51P002B	HSU-51P002B-P01	VB. INSP & ANALY M/C 51P002B	INT	4M				I				I				I	IRI	IRI-INVB	130091	B
627	HSU -51 -51P002B	HSU-51P002B-P01	PM INSP OF M/C NO. 51P002B	PMT	4M				I				I				I	RRC	RRC-MRCH	129496	B
628	HSU -51 -51P002B	HSU-51P002B-P01	PM OF 51P002B-P01	PMT	4M	P				P				P				RRC	RRC-MRCH	130581	B
629	HSU -51 -51P003A	HSU-51P003A-M	STAND BY CHECK LV. MOT 51P003A-M01	PMT	1Y							T						RRC	RRC-ERCH	138967	B
630	HSU -51 -51P003A	HSU-51P003A-M	Regreasing Mot BRG of 51P003A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139459	B
631	HSU -51 -51P003A	HSU-51P003A-M	STAND BY CHECK LV. MOT 51P003A-M01	PMT	1Y				T									RRC	RRC-ERCH	154247	B
632	HSU -51 -51P003A	HSU-51P003A-P01	VB. INSP & ANALY M/C 51P003A	INT	4M	I				I				I				IRI	IRI-INVB	130092	B
633	HSU -51 -51P003A	HSU-51P003A-P01	VB. INSP & ANALY M/C 51P003A	INT	4M		I				I				I			IRI	IRI-INVB	130934	B
634	HSU -51 -51P003A	HSU-51P003A-P01	VB. INSP & ANALY M/C 51P003A	INT	4M			I				I				I		IRI	IRI-INVB	131159	B
635	HSU -51 -51P003A	HSU-51P003A-P01	PM INSP OF M/C NO. 51P003A	PMT	4M		I				I				I			RRC	RRC-MRCH	129497	B
636	HSU -51 -51P003A	HSU-51P003A-P01	PM OF 51P003A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	130582	B
637	HSU -51 -51P003B	HSU-51P003B-M	STAND BY CHECK LV. MOT 51P003B-M01	PMT	6M			T						T				RRC	RRC-ERCH	138968	B
638	HSU -51 -51P003B	HSU-51P003B-M	Regreasing Mot BRG of 51P003B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139460	B
639	HSU -51 -51P003B	HSU-51P003B-P01	VB. INSP & ANALY M/C 51P003B	INT	4M				I				I				I	IRI	IRI-INVB	130093	B
640	HSU -51 -51P003B	HSU-51P003B-P01	PM INSP OF M/C NO. 51P003B	PMT	4M				I				I				I	RRC	RRC-MRCH	129498	B
641	HSU -51 -51P003B	HSU-51P003B-P01	PM OF 51P003B-P01	PMT	4M	P				P				P				RRC	RRC-MRCH	130583	B
642	HSU -51 -51X001	HSU-51X001-PLC	INSPECT PLC SYSTEM	PMT	3M	I			I			I			I			CCS	CCS-SYS	246485	A
643	HSU -51 -51X001	HSU-51X001-PLC	BACKUP PLC SYSTEM	PMT	6M	I						I						CCS	CCS-SYS	246486	A
644	HSU -51 -51X003	HSU-51X003-P01A	PM INSP OF M/C NO. 51X003 -P01A	PMT	4M		I				I				I			RRC	RRC-MRCH	129507	B
645	HSU -51 -51X003	HSU-51X003-P01A	PM OF 51X003 -P01A	PMT	4M				P				P				P	RRC	RRC-MRCH	130592	B
646	HSU -51 -51X003	HSU-51X003-P01A-M	STAND BY CHECK LV. MOT 51X003-P01A-M01	PMT	1Y							T						RRC	RRC-ERCH	138969	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
647	HSU -51 -51X003	HSU-51X003-P01A-M	STAND BY CHECK LV. MOT 51X003-P01A-M01	PMT	1Y					T								RRC	RRC-ERCH	154248	B
648	HSU -51 -51X003	HSU-51X003-P01B	PM INSP OF M/C NO. 51X003 -P01B	PMT	4M					I			I				I	RRC	RRC-MRCH	129508	B
649	HSU -51 -51X003	HSU-51X003-P01B	PM OF 51X003 -P01B	PMT	4M	P					P			P				RRC	RRC-MRCH	130593	B
650	HSU -51 -51X003	HSU-51X003-P01B-M	STAND BY CHECK LV. MOT 51X003-P01B-M01	PMT	6M			T						T				RRC	RRC-ERCH	138970	B
651	HSU -51 -51X003	HSU-51X003-P02A	PM INSP OF M/C NO. 51X003 -P02A	PMT	4M		I				I				I			RRC	RRC-MRCH	129509	B
652	HSU -51 -51X003	HSU-51X003-P02A	PM OF 51X003 -P02A	PMT	4M					P			P				P	RRC	RRC-MRCH	130594	B
653	HSU -51 -51X003	HSU-51X003-P02A-M	STAND BY CHECK LV. MOT 51X003-P02A-M01	PMT	1Y								T					RRC	RRC-ERCH	138971	B
654	HSU -51 -51X003	HSU-51X003-P02A-M	STAND BY CHECK LV. MOT 51X003-P02A-M01	PMT	1Y					T								RRC	RRC-ERCH	154249	B
655	HSU -51 -51X003	HSU-51X003-P02B	PM INSP OF M/C NO. 51X003 -P02B	PMT	4M					I			I				I	RRC	RRC-MRCH	129510	B
656	HSU -51 -51X003	HSU-51X003-P02B	PM OF 51X003 -P02B	PMT	4M	P					P			P				RRC	RRC-MRCH	130595	B
657	HSU -51 -51X003	HSU-51X003-P02B-M	STAND BY CHECK LV. MOT 51X003-P02B-M01	PMT	6M			T						T				RRC	RRC-ERCH	138972	B
658	HSU -51 -51X004	HSU-51X004-P01A	PM INSP OF M/C NO. 51X004 -P01A	PMT	4M		I				I				I			RRC	RRC-MRCH	129505	B
659	HSU -51 -51X004	HSU-51X004-P01A	PM OF 51X004 -P01A	PMT	4M					P			P				P	RRC	RRC-MRCH	130590	B
660	HSU -51 -51X004	HSU-51X004-P01A-M	STAND BY CHECK LV. MOT 51X004-P01A-M01	PMT	1Y								T					RRC	RRC-ERCH	138973	B
661	HSU -51 -51X004	HSU-51X004-P01A-M	STAND BY CHECK LV. MOT 51X004-P01A-M01	PMT	1Y					T								RRC	RRC-ERCH	154250	B
662	HSU -51 -51X004	HSU-51X004-P01B	PM INSP OF M/C NO. 51X004 -P01B	PMT	4M					I			I				I	RRC	RRC-MRCH	129506	B
663	HSU -51 -51X004	HSU-51X004-P01B	PM OF 51X004 -P01B	PMT	4M	P					P			P				RRC	RRC-MRCH	130591	B
664	HSU -51 -51X004	HSU-51X004-P01B-M	STAND BY CHECK LV. MOT 51X004-P01B-M01	PMT	6M			T						T				RRC	RRC-ERCH	138974	B
665	HSU -70 -70E003	HSU-70E003A-K01A	VB. INSP & ANALY M/C 70E003A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130343	B
666	HSU -70 -70E003	HSU-70E003A-K01A	PM INSP OF M/C NO. 70E003A-K01A	PMT	3M				I				I				I	RRC	RRC-MRCH	129744	B
667	HSU -70 -70E003	HSU-70E003A-K01A	REGREASING BRG OF 70E003A-K01A	PMT	3M				L			L					L	RRC	RRC-MRCH	130026	B
668	HSU -70 -70E003A	HSU-70E003A-K01A-M	Regreasing Mot BRG of 70E003A-K01A-M01	PMT	4M	L				L			L				L	RRC	RRC-ERCH	139659	B
669	HSU -70 -70E003	HSU-70E003A-K01B	VB. INSP & ANALY M/C 70E003A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130344	B
670	HSU -70 -70E003	HSU-70E003A-K01B	PM INSP OF M/C NO. 70E003A-K01B	PMT	3M				I				I				I	RRC	RRC-MRCH	129745	B
671	HSU -70 -70E003	HSU-70E003A-K01B	REGREASING BRG OF 70E003A-K01B	PMT	3M				L			L					L	RRC	RRC-MRCH	130027	B
672	HSU -70 -70E003A	HSU-70E003A-K01B-M	Regreasing Mot BRG of 70E003A-K01B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139660	B
673	HSU -70 -70E003	HSU-70E003B-K01A	VB. INSP & ANALY M/C 70E003B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130345	B
674	HSU -70 -70E003	HSU-70E003B-K01A	PM INSP OF M/C NO. 70E003B-K01A	PMT	3M				I				I				I	RRC	RRC-MRCH	129746	B
675	HSU -70 -70E003	HSU-70E003B-K01A	REGREASING BRG OF 70E003B-K01A	PMT	3M				L			L					L	RRC	RRC-MRCH	130028	B
676	HSU -70 -70E003B	HSU-70E003B-K01A-M	Regreasing Mot BRG of 70E003B-K01A-M01	PMT	4M	L				L			L				L	RRC	RRC-ERCH	139661	B
677	HSU -70 -70E003	HSU-70E003B-K01B	VB. INSP & ANALY M/C 70E003B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130346	B
678	HSU -70 -70E003	HSU-70E003B-K01B	PM INSP OF M/C NO. 70E003B-K01B	PMT	3M				I				I				I	RRC	RRC-MRCH	129747	B
679	HSU -70 -70E003	HSU-70E003B-K01B	REGREASING BRG OF 70E003B-K01B	PMT	3M				L			L					L	RRC	RRC-MRCH	130029	B
680	HSU -70 -70E003B	HSU-70E003B-K01B-M	Regreasing Mot BRG of 70E003B-K01B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139662	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
681	HSU -70 -70E003	HSU-70E003C-K01A	VB. INSP & ANALY M/C 70E003C-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130347	B
682	HSU -70 -70E003	HSU-70E003C-K01A	PM INSP OF M/C NO. 70E003C-K01A	PMT	3M				I			I			I			RRC	RRC-MRCH	129748	B
683	HSU -70 -70E003	HSU-70E003C-K01A	REGREASING BRG OF 70E003C-K01A	PMT	3M				L			L			L			RRC	RRC-MRCH	130030	B
684	HSU -70 -70E003C	HSU-70E003C-K01A-M	Regreasing Mot BRG of 70E003C-K01A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139663	B
685	HSU -70 -70E003	HSU-70E003C-K01B	VB. INSP & ANALY M/C 70E003C-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130348	B
686	HSU -70 -70E003	HSU-70E003C-K01B	PM INSP OF M/C NO. 70E003C-K01B	PMT	3M				I			I			I			RRC	RRC-MRCH	129749	B
687	HSU -70 -70E003	HSU-70E003C-K01B	REGREASING BRG OF 70E003C-K01B	PMT	3M				L			L			L			RRC	RRC-MRCH	130031	B
688	HSU -70 -70E003C	HSU-70E003C-K01B-M	Regreasing Mot BRG of 70E003C-K01B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139664	B
689	HSU -70 -70E003	HSU-70E003D-K01A	VB. INSP & ANALY M/C 70E003D-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130349	B
690	HSU -70 -70E003	HSU-70E003D-K01A	PM INSP OF M/C NO. 70E003D-K01A	PMT	3M				I			I			I			RRC	RRC-MRCH	129750	B
691	HSU -70 -70E003	HSU-70E003D-K01A	REGREASING BRG OF 70E003D-K01A	PMT	3M				L			L			L			RRC	RRC-MRCH	130032	B
692	HSU -70 -70E003D	HSU-70E003D-K01A-M	Regreasing Mot BRG of 70E003D-K01A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139665	B
693	HSU -70 -70E003	HSU-70E003D-K01B	VB. INSP & ANALY M/C 70E003D-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130350	B
694	HSU -70 -70E003	HSU-70E003D-K01B	PM INSP OF M/C NO. 70E003D-K01B	PMT	3M				I			I			I			RRC	RRC-MRCH	129751	B
695	HSU -70 -70E003	HSU-70E003D-K01B	REGREASING BRG OF 70E003D-K01B	PMT	3M				L			L			L			RRC	RRC-MRCH	130033	B
696	HSU -70 -70E003D	HSU-70E003D-K01B-M	Regreasing Mot BRG of 70E003D-K01B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139666	B
697	HSU -70 -70E004	HSU-70E004A-K01A	VB. INSP & ANALY M/C 70E004A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130351	B
698	HSU -70 -70E004	HSU-70E004A-K01A	PM INSP OF M/C NO. 70E004A-K01A	PMT	3M				I			I			I			RRC	RRC-MRCH	129752	B
699	HSU -70 -70E004	HSU-70E004A-K01A	REGREASING BRG OF 70E004A-K01A	PMT	3M				L			L			L			RRC	RRC-MRCH	130034	B
700	HSU -70 -70E004A	HSU-70E004A-K01A-M	Regreasing Mot BRG of 70E004A-K01A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139667	B
701	HSU -70 -70E004	HSU-70E004A-K01B	VB. INSP & ANALY M/C 70E004A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130352	B
702	HSU -70 -70E004	HSU-70E004A-K01B	PM INSP OF M/C NO. 70E004A-K01B	PMT	3M				I			I			I			RRC	RRC-MRCH	129753	B
703	HSU -70 -70E004	HSU-70E004A-K01B	REGREASING BRG OF 70E004A-K01B	PMT	3M				L			L			L			RRC	RRC-MRCH	130035	B
704	HSU -70 -70E004A	HSU-70E004A-K01B-M	Regreasing Mot BRG of 70E004A-K01B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139668	B
705	HSU -70 -70E004	HSU-70E004B-K01A	VB. INSP & ANALY M/C 70E004B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130353	B
706	HSU -70 -70E004	HSU-70E004B-K01A	PM INSP OF M/C NO. 70E004B-K01A	PMT	3M				I			I			I			RRC	RRC-MRCH	129754	B
707	HSU -70 -70E004	HSU-70E004B-K01A	REGREASING BRG OF 70E004B-K01A	PMT	3M				L			L			L			RRC	RRC-MRCH	130036	B
708	HSU -70 -70E004B	HSU-70E004B-K01A-M	Regreasing Mot BRG of 70E004B-K01A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139669	B
709	HSU -70 -70E004	HSU-70E004B-K01B	VB. INSP & ANALY M/C 70E004B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130354	B
710	HSU -70 -70E004	HSU-70E004B-K01B	PM INSP OF M/C NO. 70E004B-K01B	PMT	3M				I			I			I			RRC	RRC-MRCH	129755	B
711	HSU -70 -70E004	HSU-70E004B-K01B	REGREASING BRG OF 70E004B-K01B	PMT	3M				L			L			L			RRC	RRC-MRCH	130037	B
712	HSU -70 -70E004B	HSU-70E004B-K01B-M	Regreasing Mot BRG of 70E004B-K01B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139670	B
713	HSU -70 -70P001	HSU-70P001-M	STAND BY CHECK LV. MOT 70P001-M01	PMT	6M			T						T				RRC	RRC-ERCH	138987	A
714	HSU -70 -70P001	HSU-70P001-P01	VB. INSP & ANALY M/C 70P001	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130355	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
715	HSU -70 -70P001	HSU-70P001-P01	PM INSP OF M/C NO. 70P001	PMT	4M			I			I			I				RRC	RRC-MRCH	129756	B
716	HSU -70 -70P001	HSU-70P001-P01	PM OF 70P001-P01	PMT	4M	P				P			P					RRC	RRC-MRCH	130767	B
717	HSU -70 -70P002A	HSU-70P002A-M	STAND BY CHECK LV. MOT 70P002A-M01	PMT	1Y								T					RRC	RRC-ERCH	138988	B
718	HSU -70 -70P002A	HSU-70P002A-M	Regreasing Mot BRG of 70P002A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139672	B
719	HSU -70 -70P002A	HSU-70P002A-M	STAND BY CHECK LV. MOT 70P002A-M01	PMT	1Y					T								RRC	RRC-ERCH	154251	B
720	HSU -70 -70P002A	HSU-70P002A-P01	VB. INSP & ANALY M/C 70P002A	INT	4M	I				I			I					IRI	IRI-INVB	130356	B
721	HSU -70 -70P002A	HSU-70P002A-P01	VB. INSP & ANALY M/C 70P002A	INT	4M		I				I			I				IRI	IRI-INVB	131059	B
722	HSU -70 -70P002A	HSU-70P002A-P01	VB. INSP & ANALY M/C 70P002A	INT	4M			I				I			I			IRI	IRI-INVB	131286	B
723	HSU -70 -70P002A	HSU-70P002A-P01	PM INSP OF M/C NO. 70P002A	PMT	4M		I				I			I				RRC	RRC-MRCH	129757	B
724	HSU -70 -70P002A	HSU-70P002A-P01	PM OF 70P002A-P01	PMT	4M					P			P				P	RRC	RRC-MRCH	130768	B
725	HSU -70 -70P002B	HSU-70P002B-M	STAND BY CHECK LV. MOT 70P002B-M01	PMT	6M			T						T				RRC	RRC-ERCH	138989	B
726	HSU -70 -70P002B	HSU-70P002B-M	Regreasing Mot BRG of 70P002B-M01	PMT	4M					L			L				L	RRC	RRC-ERCH	139673	B
727	HSU -70 -70P002B	HSU-70P002B-P01	VB. INSP & ANALY M/C 70P002B	INT	4M					I			I				I	IRI	IRI-INVB	130357	B
728	HSU -70 -70P002B	HSU-70P002B-P01	PM INSP OF M/C NO. 70P002B	PMT	4M					I			I				I	RRC	RRC-MRCH	129758	B
729	HSU -70 -70P002B	HSU-70P002B-P01	PM OF 70P002B-P01	PMT	4M	P					P			P				RRC	RRC-MRCH	130769	B
730	HSU -70 -70P003A	HSU-70P003A-M	STAND BY CHECK LV. MOT 70P003A-M01	PMT	1Y								T					RRC	RRC-ERCH	138990	B
731	HSU -70 -70P003A	HSU-70P003A-M	Regreasing Mot BRG of 70P003A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139674	B
732	HSU -70 -70P003A	HSU-70P003A-M	STAND BY CHECK LV. MOT 70P003A-M01	PMT	1Y					T								RRC	RRC-ERCH	154252	B
733	HSU -70 -70P003A	HSU-70P003A-P01	VB. INSP & ANALY M/C 70P003A	INT	4M	I				I			I					IRI	IRI-INVB	130358	B
734	HSU -70 -70P003A	HSU-70P003A-P01	VB. INSP & ANALY M/C 70P003A	INT	4M		I				I			I				IRI	IRI-INVB	131060	B
735	HSU -70 -70P003A	HSU-70P003A-P01	VB. INSP & ANALY M/C 70P003A	INT	4M			I				I			I			IRI	IRI-INVB	131287	B
736	HSU -70 -70P003A	HSU-70P003A-P01	PM INSP OF M/C NO. 70P003A	PMT	4M		I				I			I				RRC	RRC-MRCH	129759	B
737	HSU -70 -70P003A	HSU-70P003A-P01	PM OF 70P003A-P01	PMT	4M					P			P				P	RRC	RRC-MRCH	130770	B
738	HSU -70 -70P003B	HSU-70P003B-M	STAND BY CHECK LV. MOT 70P003B-M01	PMT	6M			T						T				RRC	RRC-ERCH	138991	B
739	HSU -70 -70P003B	HSU-70P003B-M	Regreasing Mot BRG of 70P003B-M01	PMT	4M					L			L				L	RRC	RRC-ERCH	139675	B
740	HSU -70 -70P003B	HSU-70P003B-P01	VB. INSP & ANALY M/C 70P003B	INT	4M					I			I				I	IRI	IRI-INVB	130359	B
741	HSU -70 -70P003B	HSU-70P003B-P01	PM INSP OF M/C NO. 70P003B	PMT	4M					I			I				I	RRC	RRC-MRCH	129760	B
742	HSU -70 -70P003B	HSU-70P003B-P01	PM OF 70P003B-P01	PMT	4M	P					P			P				RRC	RRC-MRCH	130771	B
743	HSU -70 -70P004A	HSU-70P004A-M	STAND BY CHECK LV. MOT 70P004A-M01	PMT	1Y								T					RRC	RRC-ERCH	138992	B
744	HSU -70 -70P004A	HSU-70P004A-M	Regreasing Mot BRG of 70P004A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139676	B
745	HSU -70 -70P004A	HSU-70P004A-M	STAND BY CHECK LV. MOT 70P004A-M01	PMT	1Y					T								RRC	RRC-ERCH	154253	B
746	HSU -70 -70P004A	HSU-70P004A-P01	VB. INSP & ANALY M/C 70P004A	INT	4M	I				I			I					IRI	IRI-INVB	130360	B
747	HSU -70 -70P004A	HSU-70P004A-P01	VB. INSP & ANALY M/C 70P004A	INT	4M		I				I			I				IRI	IRI-INVB	131061	B
748	HSU -70 -70P004A	HSU-70P004A-P01	VB. INSP & ANALY M/C 70P004A	INT	4M			I				I			I			IRI	IRI-INVB	131288	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
749	HSU -70 -70P004A	HSU-70P004A-P01	PM INSP OF M/C NO. 70P004A	PMT	4M		I				I				I			RRC	RRC-MRCH	129761	B
750	HSU -70 -70P004A	HSU-70P004A-P01	PM OF 70P004A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	130772	B
751	HSU -70 -70P004B	HSU-70P004B-M	STAND BY CHECK LV. MOT 70P004B-M01	PMT	6M			T						T				RRC	RRC-ERCH	138993	B
752	HSU -70 -70P004B	HSU-70P004B-M	Regreasing Mot BRG of 70P004B-M01	PMT	4M				L			L				L		RRC	RRC-ERCH	139677	B
753	HSU -70 -70P004B	HSU-70P004B-P01	VB. INSP & ANALY M/C 70P004B	INT	4M					I				I			I	IRI	IRI-INVB	130361	B
754	HSU -70 -70P004B	HSU-70P004B-P01	PM INSP OF M/C NO. 70P004B	PMT	4M				I			I		I			I	RRC	RRC-MRCH	129762	B
755	HSU -70 -70P004B	HSU-70P004B-P01	PM OF 70P004B-P01	PMT	4M	P				P				P				RRC	RRC-MRCH	130773	B
756	HSU -70 -70P006A	HSU-70P006A-M	STAND BY CHECK LV. MOT 70P006A-M01	PMT	1Y							T						RRC	RRC-ERCH	138994	B
757	HSU -70 -70P006A	HSU-70P006A-M	Regreasing Mot BRG of 70P006A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139678	B
758	HSU -70 -70P006A	HSU-70P006A-M	STAND BY CHECK LV. MOT 70P006A-M01	PMT	1Y				T									RRC	RRC-ERCH	154254	B
759	HSU -70 -70P006A	HSU-70P006A-P01	VB. INSP & ANALY M/C 70P006A	INT	4M	I				I				I				IRI	IRI-INVB	130362	B
760	HSU -70 -70P006A	HSU-70P006A-P01	VB. INSP & ANALY M/C 70P006A	INT	4M		I				I				I			IRI	IRI-INVB	131062	B
761	HSU -70 -70P006A	HSU-70P006A-P01	VB. INSP & ANALY M/C 70P006A	INT	4M			I				I				I		IRI	IRI-INVB	131289	B
762	HSU -70 -70P006A	HSU-70P006A-P01	PM INSP OF M/C NO. 70P006A	PMT	4M		I				I				I			RRC	RRC-MRCH	129763	B
763	HSU -70 -70P006A	HSU-70P006A-P01	PM OF 70P006A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	130774	B
764	HSU -70 -70P006B	HSU-70P006B-M	STAND BY CHECK LV. MOT 70P006B-M01	PMT	6M			T						T				RRC	RRC-ERCH	138995	B
765	HSU -70 -70P006B	HSU-70P006B-M	Regreasing Mot BRG of 70P006B-M01	PMT	4M				L			L				L		RRC	RRC-ERCH	139679	B
766	HSU -70 -70P006B	HSU-70P006B-P01	VB. INSP & ANALY M/C 70P006B	INT	4M				I			I				I		IRI	IRI-INVB	130363	B
767	HSU -70 -70P006B	HSU-70P006B-P01	PM INSP OF M/C NO. 70P006B	PMT	4M				I			I				I		RRC	RRC-MRCH	129764	B
768	HSU -70 -70P006B	HSU-70P006B-P01	PM OF 70P006B-P01	PMT	4M	P				P				P				RRC	RRC-MRCH	130775	B
769	HSU -70 -70P007A	HSU-70P007A-M	STAND BY CHECK LV. MOT 70P007A-M01	PMT	1Y							T						RRC	RRC-ERCH	138996	B
770	HSU -70 -70P007A	HSU-70P007A-M	STAND BY CHECK LV. MOT 70P007A-M01	PMT	1Y				T									RRC	RRC-ERCH	154255	B
771	HSU -70 -70P007A	HSU-70P007A-P01	VB. INSP & ANALY M/C 70P007A	INT	4M	I				I				I				IRI	IRI-INVB	130364	B
772	HSU -70 -70P007A	HSU-70P007A-P01	VB. INSP & ANALY M/C 70P007A	INT	4M		I				I				I			IRI	IRI-INVB	131063	B
773	HSU -70 -70P007A	HSU-70P007A-P01	VB. INSP & ANALY M/C 70P007A	INT	4M			I				I				I		IRI	IRI-INVB	131290	B
774	HSU -70 -70P007A	HSU-70P007A-P01	PM INSP OF M/C NO. 70P007A	PMT	4M		I				I				I			RRC	RRC-MRCH	129765	B
775	HSU -70 -70P007A	HSU-70P007A-P01	PM OF 70P007A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	130776	B
776	HSU -70 -70P007B	HSU-70P007B-M	STAND BY CHECK LV. MOT 70P007B-M01	PMT	6M			T						T				RRC	RRC-ERCH	138997	B
777	HSU -70 -70P007B	HSU-70P007B-P01	VB. INSP & ANALY M/C 70P007B	INT	4M				I			I				I		IRI	IRI-INVB	130365	B
778	HSU -70 -70P007B	HSU-70P007B-P01	PM INSP OF M/C NO. 70P007B	PMT	4M				I			I				I		RRC	RRC-MRCH	129766	B
779	HSU -70 -70P007B	HSU-70P007B-P01	PM OF 70P007B-P01	PMT	4M		P				P				P			RRC	RRC-MRCH	130777	B
780	HSU -70 -70P009	HSU-70P009-M	STAND BY CHECK LV. MOT 70P009-M01	PMT	6M			T						T				RRC	RRC-ERCH	138998	A
781	HSU -70 -70P009	HSU-70P009-P01	VB. INSP & ANALY M/C 70P009	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130366	A
782	HSU -70 -70P009	HSU-70P009-P01	PM INSP OF M/C NO. 70P009	PMT	4M		I				I				I			RRC	RRC-MRCH	129767	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
783	HSU -70 -70P009	HSU-70P009-P01	PM OF 70P009-P01	PMT	4M	P				P				P				RRC	RRC-MRCH	130778	A
784	HSU -70 -70P010	HSU-70P010-M	STAND BY CHECK LV. MOT 70P010-M01	PMT	6M			T						T				RRC	RRC-ERCH	138999	C
785	HSU -70 -70P010	HSU-70P010-P01	VB. INSP & ANALY M/C 70P010	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130367	C
786	HSU -70 -70P010	HSU-70P010-P01	PM INSP OF M/C NO. 70P010	PMT	4M		I				I			I				RRC	RRC-MRCH	129768	C
787	HSU -70 -70P010	HSU-70P010-P01	PM OF 70P010-P01	PMT	4M	P				P				P				RRC	RRC-MRCH	130779	C
788	HSU -70 -70P011	HSU-70P011-P01	VB. INSP & ANALY M/C 70P011	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130368	C
789	HSU -70 -70P011	HSU-70P011-P01	PM INSP OF M/C NO. 70P011	PMT	4M		I				I			I				RRC	RRC-MRCH	129769	C
790	HSU -70 -70P011	HSU-70P011-P01	PM OF 70P011-P01	PMT	4M	P				P				P				RRC	RRC-MRCH	130780	C
791	HSU -70 -70T001	HSU-70T001-4001	INSPECTION CATHODIC PROTECTION 70T001	PMT	2M		I		I		I		I		I		I	RRC	RRC-ERCH	140428	C
792	HSU -70 -70T001	HSU-70T001-T01	PM; FOR Emergency Vent Cover 70T001	PMT	6M					P						P		RRC	RRC-MRCH	254630	A
793	HSU -70 -70T002	HSU-70T002-4002	INSPECTION CATHODIC PROTECTION 70T002	PMT	2M		I		I		I		I		I		I	RRC	RRC-ERCH	140429	C
794	HSU -70 -70T002	HSU-70T002-T01	Storage tank inspection	PMT	5Y					I								IRI	IRI-INRC	167362	A
795	HSU -70 -70T002	HSU-70T002-T01	PM; FOR Emergency Vent Cover 70T002	PMT	6M					P						P		RRC	RRC-MRCH	254631	A
796	HSU -71 -71C001	HSU-71C001-C01	Pressure Vessel inspection	PMT	5Y					I								IRI	IRI-INRC	167287	A
797	HSU -71 -71D001	HSU-71D001-D01	Pressure Vessel inspection	PMT	5Y					I								IRI	IRI-INRC	167288	A
798	HSU -71 -71D002	HSU-71D002-D01	Pressure Vessel inspection	PMT	5Y					I								IRI	IRI-INRC	167289	A
799	HSU -71 -71D003	HSU-71D003-D01	Pressure Vessel inspection	PMT	5Y					I								IRI	IRI-INRC	167290	A
800	HSU -71 -71D004A	HSU-71D004A-D01	Pressure Vessel inspection	PMT	5Y					I								IRI	IRI-INRC	167291	B
801	HSU -71 -71D004B	HSU-71D004B-D01	Pressure Vessel inspection	PMT	5Y					I								IRI	IRI-INRC	167292	B
802	HSU -71 -71E001A	HSU-71E001A-E01	Pressure Vessel inspection	PMT	5Y					I								IRI	IRI-INRC	167293	A
803	HSU -71 -71E001B	HSU-71E001B-E01	Pressure Vessel inspection	PMT	5Y					I								IRI	IRI-INRC	167294	A
804	HSU -71 -71E002A	HSU-71E002A-E01	Pressure Vessel inspection	PMT	5Y					I								IRI	IRI-INRC	167295	B
805	HSU -71 -71E002B	HSU-71E002B-E01	Pressure Vessel inspection	PMT	5Y					I								IRI	IRI-INRC	167296	B
806	HSU -71 -71E003	HSU-71E003A-E01	Pressure Vessel inspection	PMT	5Y					I								IRI	IRI-INRC	167297	A
807	HSU -71 -71E003	HSU-71E003A-K01A	VB. INSP & ANALY M/C 71E003A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130369	A
808	HSU -71 -71E003	HSU-71E003A-K01A	PM INSP OF M/C NO. 71E003A-K01A	PMT	3M	I			I			I		I				RRC	RRC-MRCH	129770	A
809	HSU -71 -71E003	HSU-71E003A-K01A	REGREASING BRG OF 71E003A-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130038	A
810	HSU -71 -71E003A	HSU-71E003A-K01A-M	Regreasing Mot BRG of 71E003A-K01A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139684	A
811	HSU -71 -71E003	HSU-71E003A-K01B	VB. INSP & ANALY M/C 71E003A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130370	A
812	HSU -71 -71E003	HSU-71E003A-K01B	PM INSP OF M/C NO. 71E003A-K01B	PMT	3M	I			I			I		I				RRC	RRC-MRCH	129771	A
813	HSU -71 -71E003	HSU-71E003A-K01B	REGREASING BRG OF 71E003A-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130039	A
814	HSU -71 -71E003A	HSU-71E003A-K01B-M	Regreasing Mot BRG of 71E003A-K01B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139685	A
815	HSU -71 -71E003	HSU-71E003B-E01	Pressure Vessel inspection	PMT	5Y					I								IRI	IRI-INRC	167298	A
816	HSU -71 -71E003	HSU-71E003B-K01A	VB. INSP & ANALY M/C 71E003B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130371	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
817	HSU -71 -71E003	HSU-71E003B-K01A	PM INSP OF M/C NO. 71E003B-K01A	PMT	3M	I				I			I			I		RRC	RRC-MRCH	129772	A
818	HSU -71 -71E003	HSU-71E003B-K01A	REGREASING BRG OF 71E003B-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130040	A
819	HSU -71 -71E003B	HSU-71E003B-K01A-M	Regreasing Mot BRG of 71E003B-K01A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139686	A
820	HSU -71 -71E003	HSU-71E003B-K01B	VB. INSP & ANALY M/C 71E003B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130372	A
821	HSU -71 -71E003	HSU-71E003B-K01B	PM INSP OF M/C NO. 71E003B-K01B	PMT	3M	I			I			I		I				RRC	RRC-MRCH	129773	A
822	HSU -71 -71E003	HSU-71E003B-K01B	REGREASING BRG OF 71E003B-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130041	A
823	HSU -71 -71E003B	HSU-71E003B-K01B-M	Regreasing Mot BRG of 71E003B-K01B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139687	A
824	HSU -71 -71E004	HSU-71E004A-E01	Pressure Vessel inspection	PMT	5Y					I								IRI	IRI-INRC	167299	B
825	HSU -71 -71E004	HSU-71E004A-K01A	VB. INSP & ANALY M/C 71E004A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130373	B
826	HSU -71 -71E004	HSU-71E004A-K01A	PM INSP OF M/C NO. 71E004A-K01A	PMT	3M	I			I			I			I			RRC	RRC-MRCH	129774	B
827	HSU -71 -71E004	HSU-71E004A-K01A	REGREASING BRG OF 71E004A-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130042	B
828	HSU -71 -71E004A	HSU-71E004A-K01A-M	Regreasing Mot BRG of 71E004A-K01A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139688	B
829	HSU -71 -71E004	HSU-71E004A-K01B	VB. INSP & ANALY M/C 71E004A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130374	B
830	HSU -71 -71E004	HSU-71E004A-K01B	PM INSP OF M/C NO. 71E004A-K01B	PMT	3M	I			I			I		I				RRC	RRC-MRCH	129775	B
831	HSU -71 -71E004	HSU-71E004A-K01B	REGREASING BRG OF 71E004A-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130043	B
832	HSU -71 -71E004A	HSU-71E004A-K01B-M	Regreasing Mot BRG of 71E004A-K01B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139689	B
833	HSU -71 -71E004	HSU-71E004B-E01	Pressure Vessel inspection	PMT	5Y					I								IRI	IRI-INRC	167300	B
834	HSU -71 -71E004	HSU-71E004B-K01A	VB. INSP & ANALY M/C 71E004B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130375	B
835	HSU -71 -71E004	HSU-71E004B-K01A	PM INSP OF M/C NO. 71E004B-K01A	PMT	3M	I			I			I		I				RRC	RRC-MRCH	129776	B
836	HSU -71 -71E004	HSU-71E004B-K01A	REGREASING BRG OF 71E004B-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130044	B
837	HSU -71 -71E004B	HSU-71E004B-K01A-M	Regreasing Mot BRG of 71E004B-K01A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139690	B
838	HSU -71 -71E004	HSU-71E004B-K01B	VB. INSP & ANALY M/C 71E004B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130376	B
839	HSU -71 -71E004	HSU-71E004B-K01B	PM INSP OF M/C NO. 71E004B-K01B	PMT	3M	I			I			I		I				RRC	RRC-MRCH	129777	B
840	HSU -71 -71E004	HSU-71E004B-K01B	REGREASING BRG OF 71E004B-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130045	B
841	HSU -71 -71E004B	HSU-71E004B-K01B-M	Regreasing Mot BRG of 71E004B-K01B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139691	B
842	HSU -71 -71E004	HSU-71E004C-E01	Pressure Vessel inspection	PMT	5Y					I								IRI	IRI-INRC	167301	B
843	HSU -71 -71E004	HSU-71E004C-K01A	VB. INSP & ANALY M/C 71E004C-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130377	B
844	HSU -71 -71E004	HSU-71E004C-K01A	PM INSP OF M/C NO. 71E004C-K01A	PMT	3M	I			I			I		I				RRC	RRC-MRCH	129778	B
845	HSU -71 -71E004	HSU-71E004C-K01A	REGREASING BRG OF 71E004C-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130046	B
846	HSU -71 -71E004C	HSU-71E004C-K01A-M	Regreasing Mot BRG of 71E004C-K01A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139692	B
847	HSU -71 -71E004	HSU-71E004C-K01B	VB. INSP & ANALY M/C 71E004C-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130378	B
848	HSU -71 -71E004	HSU-71E004C-K01B	PM INSP OF M/C NO. 71E004C-K01B	PMT	3M	I			I			I		I				RRC	RRC-MRCH	129779	B
849	HSU -71 -71E004	HSU-71E004C-K01B	REGREASING BRG OF 71E004C-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130047	B
850	HSU -71 -71E004C	HSU-71E004C-K01B-M	Regreasing Mot BRG of 71E004C-K01B-M01	PMT	4M				L			L			L		L	RRC	RRC-ERCH	139693	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
851	HSU -71 -71E004	HSU-71E004D-E01	Pressure Vessel inspection	PMT	5Y					I								IRI	IRI-INRC	167302	B
852	HSU -71 -71E004	HSU-71E004D-K01A	VB. INSP & ANALY M/C 71E004D-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130379	B
853	HSU -71 -71E004	HSU-71E004D-K01A	PM INSP OF M/C NO. 71E004D-K01A	PMT	3M	I			I			I		I				RRC	RRC-MRCH	129780	B
854	HSU -71 -71E004	HSU-71E004D-K01A	REGREASING BRG OF 71E004D-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130048	B
855	HSU -71 -71E004D	HSU-71E004D-K01A-M	Regreasing Mot BRG of 71E004D-K01A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139694	B
856	HSU -71 -71E004	HSU-71E004D-K01B	VB. INSP & ANALY M/C 71E004D-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130380	B
857	HSU -71 -71E004	HSU-71E004D-K01B	PM INSP OF M/C NO. 71E004D-K01B	PMT	3M	I			I			I		I				RRC	RRC-MRCH	129781	B
858	HSU -71 -71E004	HSU-71E004D-K01B	REGREASING BRG OF 71E004D-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130049	B
859	HSU -71 -71E004D	HSU-71E004D-K01B-M	Regreasing Mot BRG of 71E004D-K01B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139695	B
860	HSU -71 -71P001A	HSU-71P001A-M	STAND BY CHECK LV. MOT 71P001A-M01	PMT	1Y					T			T					RRC	RRC-ERCH	139013	B
861	HSU -71 -71P001A	HSU-71P001A-M	Regreasing Mot BRG of 71P001A-M01	PMT	4M	L				L			L					RRC	RRC-ERCH	139696	B
862	HSU -71 -71P001A	HSU-71P001A-M	STAND BY CHECK LV. MOT 71P001A-M01	PMT	1Y				T									RRC	RRC-ERCH	154256	B
863	HSU -71 -71P001A	HSU-71P001A-P01	VB. INSP & ANALY M/C 71P001A	INT	4M	I				I			I					IRI	IRI-INVB	130381	B
864	HSU -71 -71P001A	HSU-71P001A-P01	VB. INSP & ANALY M/C 71P001A	INT	4M		I				I			I				IRI	IRI-INVB	131071	B
865	HSU -71 -71P001A	HSU-71P001A-P01	VB. INSP & ANALY M/C 71P001A	INT	4M			I				I			I			IRI	IRI-INVB	131297	B
866	HSU -71 -71P001A	HSU-71P001A-P01	PM INSP OF M/C NO. 71P001A	PMT	4M		I				I			I				RRC	RRC-MRCH	129782	B
867	HSU -71 -71P001A	HSU-71P001A-P01	PM OF 71P001A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	130781	B
868	HSU -71 -71P001B	HSU-71P001B-M	STAND BY CHECK LV. MOT 71P001B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139014	B
869	HSU -71 -71P001B	HSU-71P001B-M	Regreasing Mot BRG of 71P001B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139697	B
870	HSU -71 -71P001B	HSU-71P001B-P01	VB. INSP & ANALY M/C 71P001B	INT	4M				I				I				I	IRI	IRI-INVB	130382	B
871	HSU -71 -71P001B	HSU-71P001B-P01	PM INSP OF M/C NO. 71P001B	PMT	4M				I				I				I	IRI	IRI-INVB	129783	B
872	HSU -71 -71P001B	HSU-71P001B-P01	PM OF 71P001B-P01	PMT	4M		P				P				P			RRC	RRC-MRCH	130782	B
873	HSU -71 -71P002A	HSU-71P002A-M	STAND BY CHECK LV. MOT 71P002A-M01	PMT	1Y								T					RRC	RRC-ERCH	139015	B
874	HSU -71 -71P002A	HSU-71P002A-M	Regreasing Mot BRG of 71P002A-M01	PMT	4M	L				L			L					RRC	RRC-ERCH	139698	B
875	HSU -71 -71P002A	HSU-71P002A-M	STAND BY CHECK LV. MOT 71P002A-M01	PMT	1Y				T									RRC	RRC-ERCH	154257	B
876	HSU -71 -71P002A	HSU-71P002A-P01	VB. INSP & ANALY M/C 71P002A	INT	4M	I				I			I					IRI	IRI-INVB	130383	B
877	HSU -71 -71P002A	HSU-71P002A-P01	VB. INSP & ANALY M/C 71P002A	INT	4M		I				I			I				IRI	IRI-INVB	131072	B
878	HSU -71 -71P002A	HSU-71P002A-P01	VB. INSP & ANALY M/C 71P002A	INT	4M			I				I			I			IRI	IRI-INVB	131298	B
879	HSU -71 -71P002A	HSU-71P002A-P01	PM INSP OF M/C NO. 71P002A	PMT	4M		I				I			I				RRC	RRC-MRCH	129784	B
880	HSU -71 -71P002A	HSU-71P002A-P01	PM OF 71P002A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	130783	B
881	HSU -71 -71P002B	HSU-71P002B-M	STAND BY CHECK LV. MOT 71P002B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139016	B
882	HSU -71 -71P002B	HSU-71P002B-M	Regreasing Mot BRG of 71P002B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139699	B
883	HSU -71 -71P002B	HSU-71P002B-P01	VB. INSP & ANALY M/C 71P002B	INT	4M				I				I				I	IRI	IRI-INVB	130384	B
884	HSU -71 -71P002B	HSU-71P002B-P01	PM INSP OF M/C NO. 71P002B	PMT	4M				I				I				I	RRC	RRC-MRCH	129785	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
885	HSU -71 -71P002B	HSU-71P002B-P01	PM OF 71P002B-P01	PMT	4M		P				P				P			RRC	RRC-MRCH	130784	B
886	HSU -71 -71P003A	HSU-71P003A-M	STAND BY CHECK LV. MOT 71P003A-M01	PMT	1Y								T					RRC	RRC-ERCH	139017	B
887	HSU -71 -71P003A	HSU-71P003A-M	STAND BY CHECK LV. MOT 71P003A-M01	PMT	1Y				T									RRC	RRC-ERCH	154258	B
888	HSU -71 -71P003A	HSU-71P003A-P01	VB. INSP & ANALY M/C 71P003A	INT	4M	I				I			I					IRI	IRI-INVB	130385	B
889	HSU -71 -71P003A	HSU-71P003A-P01	VB. INSP & ANALY M/C 71P003A	INT	4M		I				I			I				IRI	IRI-INVB	131073	B
890	HSU -71 -71P003A	HSU-71P003A-P01	VB. INSP & ANALY M/C 71P003A	INT	4M			I				I			I			IRI	IRI-INVB	131299	B
891	HSU -71 -71P003A	HSU-71P003A-P01	PM INSP OF M/C NO. 71P003A	PMT	4M		I				I			I				RRC	RRC-MRCH	129786	B
892	HSU -71 -71P003A	HSU-71P003A-P01	PM OF 71P003A-P01	PMT	4M				P			P				P		RRC	RRC-MRCH	130785	B
893	HSU -71 -71P003B	HSU-71P003B-M	STAND BY CHECK LV. MOT 71P003B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139018	B
894	HSU -71 -71P003B	HSU-71P003B-P01	VB. INSP & ANALY M/C 71P003B	INT	4M				I			I				I		IRI	IRI-INVB	130386	B
895	HSU -71 -71P003B	HSU-71P003B-P01	PM INSP OF M/C NO. 71P003B	PMT	4M				I			I				I		RRC	RRC-MRCH	129787	B
896	HSU -71 -71P003B	HSU-71P003B-P01	PM OF 71P003B-P01	PMT	4M		P				P			P				RRC	RRC-MRCH	130786	B
897	HSU -71 -71P004A	HSU-71P004A-M	STAND BY CHECK MV. MOT 71P004A-M01	PMT	1Y								T					RRC	RRC-ERCH	139019	B
898	HSU -71 -71P004A	HSU-71P004A-M	Regreasing Mot BRG of 71P004A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139416	B
899	HSU -71 -71P004A	HSU-71P004A-M	STAND BY CHECK MV. MOT 71P004A-M01	PMT	1Y				T									RRC	RRC-ERCH	154259	B
900	HSU -71 -71P004A	HSU-71P004A-P01	VB. INSP & ANALY M/C 71P004A	INT	4M	I				I			I					IRI	IRI-INVB	130387	B
901	HSU -71 -71P004A	HSU-71P004A-P01	VB. INSP & ANALY M/C 71P004A	INT	4M		I				I			I				IRI	IRI-INVB	131074	B
902	HSU -71 -71P004A	HSU-71P004A-P01	VB. INSP & ANALY M/C 71P004A	INT	4M			I				I			I			IRI	IRI-INVB	131300	B
903	HSU -71 -71P004A	HSU-71P004A-P01	PM INSP OF M/C NO. 71P004A	PMT	4M		I				I			I				RRC	RRC-MRCH	129788	B
904	HSU -71 -71P004A	HSU-71P004A-P01	PM OF 71P004A-P01	PMT	4M				P			P				P		RRC	RRC-MRCH	130787	B
905	HSU -71 -71P004B	HSU-71P004B-M	STAND BY CHECK MV. MOT 71P004B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139020	B
906	HSU -71 -71P004B	HSU-71P004B-M	Regreasing Mot BRG of 71P004B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139417	B
907	HSU -71 -71P004B	HSU-71P004B-P01	VB. INSP & ANALY M/C 71P004B	INT	4M				I				I				I	IRI	IRI-INVB	130388	B
908	HSU -71 -71P004B	HSU-71P004B-P01	PM INSP OF M/C NO. 71P004B	PMT	4M				I				I				I	RRC	RRC-MRCH	129789	B
909	HSU -71 -71P004B	HSU-71P004B-P01	PM OF 71P004B-P01	PMT	4M		P				P			P				RRC	RRC-MRCH	130788	B
910	HSU -71 -71P005	HSU-71P005-M	STAND BY CHECK LV. MOT 71P005-M01	PMT	6M			T						T				RRC	RRC-ERCH	139021	C
911	HSU -71 -71P005	HSU-71P005-M	Regreasing Mot BRG of 71P005-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139702	C
912	HSU -71 -71P005	HSU-71P005-P01	VB. INSP & ANALY M/C 71P005	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130389	C
913	HSU -71 -71P005	HSU-71P005-P01	PM INSP OF M/C NO. 71P005	PMT	4M	I				I				I				RRC	RRC-MRCH	129790	C
914	HSU -71 -71P005	HSU-71P005-P01	PM OF 71P005-P01	PMT	4M	P				P				P				RRC	RRC-MRCH	130789	C
915	HSU -71 -71P007A	HSU-71P007A-M	STAND BY CHECK LV. MOT 71P007A-M01	PMT	1Y								T					RRC	RRC-ERCH	139022	B
916	HSU -71 -71P007A	HSU-71P007A-M	Regreasing Mot BRG of 71P007A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139703	B
917	HSU -71 -71P007A	HSU-71P007A-M	STAND BY CHECK LV. MOT 71P007A-M01	PMT	1Y				T									RRC	RRC-ERCH	154260	B
918	HSU -71 -71P007A	HSU-71P007A-P01	VB. INSP & ANALY M/C 71P007A	INT	4M	I				I			I					IRI	IRI-INVB	130390	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
919	HSU -71 -71P007A	HSU-71P007A-P01	VB. INSP & ANALY M/C 71P007A	INT	4M			I				I				I		IRI	IRI-INVB	131075	B
920	HSU -71 -71P007A	HSU-71P007A-P01	VB. INSP & ANALY M/C 71P007A	INT	4M				I				I				I	IRI	IRI-INVB	131301	B
921	HSU -71 -71P007A	HSU-71P007A-P01	PM INSP OF M/C NO. 71P007A	PMT	4M		I				I			I				RRC	RRC-MRCH	129791	B
922	HSU -71 -71P007A	HSU-71P007A-P01	PM OF 71P007A-P01	PMT	4M				P			P				P		RRC	RRC-MRCH	130790	B
923	HSU -71 -71P007B	HSU-71P007B-M	STAND BY CHECK LV. MOT 71P007B-M01	PMT	6M			T					T					RRC	RRC-ERCH	139023	B
924	HSU -71 -71P007B	HSU-71P007B-M	Regreasing Mot BRG of 71P007B-M01	PMT	4M				L			L				L		RRC	RRC-ERCH	139704	B
925	HSU -71 -71P007B	HSU-71P007B-P01	VB. INSP & ANALY M/C 71P007B	INT	4M				I			I				I		IRI	IRI-INVB	130391	B
926	HSU -71 -71P007B	HSU-71P007B-P01	PM INSP OF M/C NO. 71P007B	PMT	4M				I			I				I		RRC	RRC-MRCH	129792	B
927	HSU -71 -71P007B	HSU-71P007B-P01	PM OF 71P007B-P01	PMT	4M		P				P			P				RRC	RRC-MRCH	130791	B
928	HSU -71 -71P008	HSU-71P008-P01	VB. INSP & ANALY M/C 71P008	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130392	C
929	HSU -71 -71P008	HSU-71P008-P01	PM INSP OF M/C NO. 71P008	PMT	4M		I				I			I				RRC	RRC-MRCH	129793	C
930	HSU -71 -71P008	HSU-71P008-P01	PM OF 71P008-P01	PMT	4M	P				P			P					RRC	RRC-MRCH	130792	C
931	HSU -71 -71T001	HSU-71T001-T01	Storage tank inspection	PMT	5Y						I							IRI	IRI-INRC	167363	A
932	HSU -71 -71T001	HSU-71T001-T01	PM; FOR Emergency Vent Cover 71T001	PMT	6M					P						P		RRC	RRC-MRCH	264632	A
933	HSU -71 -71T001	HSU-71T001-TN01	VB. INSP & ANALY M/C 71TN001	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149190	B
934	HSU -71 -71T001	HSU-71T001-TN01	PM OF 71TN001	PMT	4M		P				P			P				RRC	RRC-MRCH	148838	B
935	HSU -71 -71T001	HSU-71T001-TN01	PM INSP OF M/C NO. 71TN001	PMT	4M		I				I			I				RRC	RRC-MRCH	149130	B
936	HSU -71 -71T002	HSU-71T002-4001	INSPECTION CATHODIC PROTECTION 71T002	PMT	2M		I		I		I		I		I		I	RRC	RRC-MRCH	140430	C
937	HSU -71 -71T002	HSU-71T002-T01	Storage tank inspection	PMT	5Y							I						IRI	IRI-INRC	167364	A
938	HSU -71 -71T002	HSU-71T002-T01	PM; FOR Emergency Vent Cover 71T002	PMT	6M					P						P		RRC	RRC-MRCH	264633	A
939	HSU -71 -71TN001	HSU-71TN001-M	STAND BY CHECK LV. MOT 71TN001-M01	PMT	6M			T						T				RRC	RRC-ERCH	139025	B
940	HSU -71 -71X001	HSU-71X001-P01A	PM INSP OF M/C NO. 71X001 -P01A	PMT	4M		I				I			I				RRC	RRC-MRCH	129794	B
941	HSU -71 -71X001	HSU-71X001-P01A	PM OF 71X001 -P01A	PMT	4M				P			P				P		RRC	RRC-MRCH	130793	B
942	HSU -71 -71X001	HSU-71X001-P01A-M	STAND BY CHECK LV. MOT 71X001-P01A-M01	PMT	1Y							T						RRC	RRC-ERCH	139026	B
943	HSU -71 -71X001	HSU-71X001-P01A-M	STAND BY CHECK LV. MOT 71X001-P01A-M01	PMT	1Y				T									RRC	RRC-ERCH	154261	B
944	HSU -71 -71X001	HSU-71X001-P01B	PM INSP OF M/C NO. 71X001 -P01B	PMT	4M				I			I				I		RRC	RRC-MRCH	129795	B
945	HSU -71 -71X001	HSU-71X001-P01B	PM OF 71X001 -P01B	PMT	4M		P				P			P				RRC	RRC-MRCH	130794	B
946	HSU -71 -71X001	HSU-71X001-P01B-M	STAND BY CHECK LV. MOT 71X001-P01B-M01	PMT	6M			T					T					RRC	RRC-ERCH	139027	B
947	HSU -71 -71X002	HSU-71X002-P01A	PM INSP OF M/C NO. 71X002 -P01A	PMT	4M		I				I			I				RRC	RRC-MRCH	129796	B
948	HSU -71 -71X002	HSU-71X002-P01A	PM OF 71X002 -P01A	PMT	4M				P			P				P		RRC	RRC-MRCH	130795	B
949	HSU -71 -71X002	HSU-71X002-P01B	PM INSP OF M/C NO. 71X002 -P01B	PMT	4M				I			I				I		RRC	RRC-MRCH	129797	B
950	HSU -71 -71X002	HSU-71X002-P01B	PM OF 71X002 -P01B	PMT	4M		P				P			P				RRC	RRC-MRCH	130796	B
951	HSU -72 -AIR	HSU-72-AC-001	PM ALL TYPE OF AIR 72-AC-001 (Large 2,8)	PMT	2M				P		P				P		P	RRC	RRC-MRCH	138226	B
952	HSU -72 -AIR	HSU-72-AC-001	PM ALL TYPE OF AIR 72-AC-001 (Large 2,8)	PMT	6M			P					P					RRC	RRC-ERCH	138226	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
953	HSU -72 -72B101	HSU-72B101-B01	On-Stream Inspection	INT	1Y				I									IRI	IRI-INRC	158216	B
954	HSU -72 -72B201	HSU-72B201-B01	On-Stream Inspection	INT	1Y				I									IRI	IRI-INRC	158217	B
955	HSU -72 -72B301	HSU-72B301-B01	On-Stream Inspection	INT	1Y				I									IRI	IRI-INRC	158218	B
956	HSU -72 -72C601	HSU-72C601-C01	Pressure Vessel inspection	PMT	5Y						I							IRI	IRI-INRC	167303	A
957	HSU -72 -72C602	HSU-72C602-C01	Pressure Vessel inspection	PMT	5Y						I							IRI	IRI-INRC	167304	A
958	HSU -72 -72D101	HSU-72D101-D01	Pressure Vessel inspection	PMT	5Y						I							IRI	IRI-INRC	167305	B
959	HSU -72 -72D201	HSU-72D201-D01	Pressure Vessel inspection	PMT	5Y						I							IRI	IRI-INRC	167306	B
960	HSU -72 -72D301	HSU-72D301-D01	Pressure Vessel inspection	PMT	5Y						I							IRI	IRI-INRC	167307	B
961	HSU -72 -72D601	HSU-72D601-D01	Pressure Vessel inspection	PMT	5Y						I							IRI	IRI-INRC	167308	A
962	HSU -72 -72D602	HSU-72D602-D01	Pressure Vessel inspection	PMT	5Y						I							IRI	IRI-INRC	167309	A
963	HSU -72 -72D603	HSU-72D603-D01	Pressure Vessel inspection	PMT	5Y						I							IRI	IRI-INRC	167310	A
964	HSU -72 -72D604	HSU-72D604-D01	Pressure Vessel inspection	PMT	5Y						I							IRI	IRI-INRC	167311	A
965	HSU -72 -72D605	HSU-72D605-D01	Pressure Vessel inspection	PMT	5Y						I							IRI	IRI-INRC	167312	A
966	HSU -72 -72D606	HSU-72D606-D01	Pressure Vessel inspection	PMT	5Y						I							IRI	IRI-INRC	167313	A
967	HSU -72 -72E101	HSU-72E101-E01	Pressure Vessel inspection	PMT	5Y						I							IRI	IRI-INRC	167314	B
968	HSU -72 -72E102	HSU-72E102-E01	Pressure Vessel inspection	PMT	5Y							I						IRI	IRI-INRC	167315	B
969	HSU -72 -72E103	HSU-72E103-E01	Pressure Vessel inspection	PMT	5Y							I						IRI	IRI-INRC	167316	B
970	HSU -72 -72E104	HSU-72E104-E01	Pressure Vessel inspection	PMT	5Y							I						IRI	IRI-INRC	167317	B
971	HSU -72 -72E105	HSU-72E105-E01	Pressure Vessel inspection	PMT	5Y							I						IRI	IRI-INRC	167318	B
972	HSU -72 -72E106	HSU-72E106-E01	Pressure Vessel inspection	PMT	5Y							I						IRI	IRI-INRC	167319	B
973	HSU -72 -72E201	HSU-72E201-E01	Pressure Vessel inspection	PMT	5Y							I						IRI	IRI-INRC	167320	B
974	HSU -72 -72E202	HSU-72E202-E01	Pressure Vessel inspection	PMT	5Y							I						IRI	IRI-INRC	167321	B
975	HSU -72 -72E203	HSU-72E203-E01	Pressure Vessel inspection	PMT	5Y							I						IRI	IRI-INRC	167322	B
976	HSU -72 -72E204	HSU-72E204-E01	Pressure Vessel inspection	PMT	5Y							I						IRI	IRI-INRC	167323	B
977	HSU -72 -72E205	HSU-72E205-E01	Pressure Vessel inspection	PMT	5Y							I						IRI	IRI-INRC	167324	B
978	HSU -72 -72E206	HSU-72E206-E01	Pressure Vessel inspection	PMT	5Y							I						IRI	IRI-INRC	167325	B
979	HSU -72 -72E301	HSU-72E301-E01	Pressure Vessel inspection	PMT	5Y							I						IRI	IRI-INRC	167326	B
980	HSU -72 -72E302	HSU-72E302-E01	Pressure Vessel inspection	PMT	5Y							I						IRI	IRI-INRC	167327	B
981	HSU -72 -72E303	HSU-72E303-E01	Pressure Vessel inspection	PMT	5Y							I						IRI	IRI-INRC	167328	B
982	HSU -72 -72E304	HSU-72E304-E01	Pressure Vessel inspection	PMT	5Y								I					IRI	IRI-INRC	167329	B
983	HSU -72 -72E305	HSU-72E305-E01	Pressure Vessel inspection	PMT	5Y								I					IRI	IRI-INRC	167330	B
984	HSU -72 -72E306	HSU-72E306-E01	Pressure Vessel inspection	PMT	5Y								I					IRI	IRI-INRC	167331	B
985	HSU -72 -72E601	HSU-72E601-E01	Pressure Vessel inspection	PMT	5Y								I					IRI	IRI-INRC	167332	A
986	HSU -72 -72E602	HSU-72E602-E01	Pressure Vessel inspection	PMT	5Y								I					IRI	IRI-INRC	167333	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
987	HSU -72 -72E603	HSU-72E603-E01	Pressure Vessel inspection	PMT	5Y								I					IRI	IRI-INRC	167334	A
988	HSU -72 -72E604	HSU-72E604-E01	Pressure Vessel inspection	PMT	5Y								I					IRI	IRI-INRC	167335	A
989	HSU -72 -72K101	HSU-72K101-K01	OIL INSP & ANALYSIS M/C 72K101	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INOL	130081	B
990	HSU -72 -72K101	HSU-72K101-M	STAND BY CHECK MV. MOT 72K101-M01	PMT	6M				T					T				RRC	RRC-ERCH	139030	B
991	HSU -72 -72K101	HSU-72K101-M	Regreasing Mot BRG of 72K101-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139418	B
992	HSU -72 -72K101	HSU-72K101-PLC	INSPECT PLC SYSTEM	PMT	3M	I			I			I			I			CCS	CCS-SYS	246487	A
993	HSU -72 -72K101	HSU-72K101-PLC	BACKUP PLC SYSTEM	PMT	6M	I						I						CCS	CCS-SYS	246488	A
994	HSU -72 -72K201	HSU-72K201-K01	OIL INSP & ANALYSIS M/C 72K201	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INOL	130082	B
995	HSU -72 -72K201	HSU-72K201-M	STAND BY CHECK MV. MOT 72K201-M01	PMT	6M				T					T				RRC	RRC-ERCH	139031	B
996	HSU -72 -72K201	HSU-72K201-M	Regreasing Mot BRG of 72K201-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139419	B
997	HSU -72 -72K201	HSU-72K201-PLC	INSPECT PLC SYSTEM	PMT	3M	I			I			I			I			CCS	CCS-SYS	246489	A
998	HSU -72 -72K201	HSU-72K201-PLC	BACKUP PLC SYSTEM	PMT	6M	I						I						CCS	CCS-SYS	246490	A
999	HSU -72 -72K301	HSU-72K301-K01	OIL INSP & ANALYSIS M/C 72K301	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INOL	130083	B
1,000	HSU -72 -72K301	HSU-72K301-M	STAND BY CHECK MV. MOT 72K301-M01	PMT	6M				T					T				RRC	RRC-ERCH	139032	B
1,001	HSU -72 -72K301	HSU-72K301-M	Regreasing Mot BRG of 72K301-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139420	B
1,002	HSU -72 -72K301	HSU-72K301-PLC	INSPECT PLC SYSTEM	PMT	3M	I			I			I			I			CCS	CCS-SYS	246491	A
1,003	HSU -72 -72K301	HSU-72K301-PLC	BACKUP PLC SYSTEM	PMT	6M	I						I						CCS	CCS-SYS	246492	A
1,004	HSU -72 -72K601	HSU-72K601-K01	OIL INSP & ANALYSIS M/C 72K601	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INOL	130084	B
1,005	HSU -72 -72K601	HSU-72K601-M	STAND BY CHECK MV. MOT 72K601-M01	PMT	6M				T					T				RRC	RRC-ERCH	139033	B
1,006	HSU -72 -72K601	HSU-72K601-M	Regreasing Mot BRG of 72K601-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139421	B
1,007	HSU -72 -72K601	HSU-72K601-PLC	INSPECT PLC SYSTEM	PMT	3M	I			I			I			I			CCS	CCS-SYS	246493	A
1,008	HSU -72 -72K601	HSU-72K601-PLC	BACKUP PLC SYSTEM	PMT	6M	I						I						CCS	CCS-SYS	246494	A
1,009	HSU -72 -72P601A	HSU-72P601A-M	STAND BY CHECK LV. MOT 72P601A-M01	PMT	1Y								T					RRC	RRC-ERCH	139034	B
1,010	HSU -72 -72P601A	HSU-72P601A-M	STAND BY CHECK LV. MOT 72P601A-M01	PMT	1Y				T									RRC	RRC-ERCH	154262	B
1,011	HSU -72 -72P601A	HSU-72P601A-P01	VB. INSP & ANALY M/C 72P601A	INT	4M	I				I			I					IRI	IRI-INVB	130397	B
1,012	HSU -72 -72P601A	HSU-72P601A-P01	VB. INSP & ANALY M/C 72P601A	INT	4M		I				I			I				IRI	IRI-INVB	131078	B
1,013	HSU -72 -72P601A	HSU-72P601A-P01	VB. INSP & ANALY M/C 72P601A	INT	4M			I				I			I			IRI	IRI-INVB	131304	B
1,014	HSU -72 -72P601A	HSU-72P601A-P01	PM INSP OF M/C NO. 72P601A	PMT	4M		I				I			I				RRC	RRC-MRCH	129798	B
1,015	HSU -72 -72P601A	HSU-72P601A-P01	PM OF 72P601A-P01	PMT	4M				P			P				P		RRC	RRC-MRCH	130797	B
1,016	HSU -72 -72P601B	HSU-72P601B-M	STAND BY CHECK LV. MOT 72P601B-M01	PMT	6M			T					T					RRC	RRC-ERCH	139035	B
1,017	HSU -72 -72P601B	HSU-72P601B-P01	VB. INSP & ANALY M/C 72P601B	INT	4M				I			I				I		IRI	IRI-INVB	130398	B
1,018	HSU -72 -72P601B	HSU-72P601B-P01	PM INSP OF M/C NO. 72P601B	PMT	4M				I			I				I		RRC	RRC-MRCH	129799	B
1,019	HSU -72 -72P601B	HSU-72P601B-P01	PM OF 72P601B-P01	PMT	4M		P				P			P				RRC	RRC-MRCH	130798	B
1,020	HSU -72 -72P602A	HSU-72P602A-M	STAND BY CHECK LV. MOT 72P602A-M01	PMT	1Y								T					RRC	RRC-ERCH	139036	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,021	HSU -72 -72P602A	HSU-72P602A-M	STAND BY CHECK LV. MOT 72P602A-M01	PMT	1Y				T									RRC	RRC-ERCH	154263	B
1,022	HSU -72 -72P602A	HSU-72P602A-P01	VB. INSP & ANALY M/C 72P602A	INT	4M	I				I				I				IRI	IRI-INVB	130399	B
1,023	HSU -72 -72P602A	HSU-72P602A-P01	VB. INSP & ANALY M/C 72P602A	INT	4M		I				I				I			IRI	IRI-INVB	131079	B
1,024	HSU -72 -72P602A	HSU-72P602A-P01	VB. INSP & ANALY M/C 72P602A	INT	4M			I				I				I		IRI	IRI-INVB	131305	B
1,025	HSU -72 -72P602A	HSU-72P602A-P01	PM INSP OF M/C NO. 72P602A	PMT	4M		I				I				I			RRC	RRC-MRCH	129800	B
1,026	HSU -72 -72P602A	HSU-72P602A-P01	PM OF 72P602A-P01	PMT	4M				P			P		P			P	RRC	RRC-MRCH	130799	B
1,027	HSU -72 -72P602B	HSU-72P602B-M	STAND BY CHECK LV. MOT 72P602B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139037	B
1,028	HSU -72 -72P602B	HSU-72P602B-P01	VB. INSP & ANALY M/C 72P602B	INT	4M				I			I				I		IRI	IRI-INVB	130400	B
1,029	HSU -72 -72P602B	HSU-72P602B-P01	PM INSP OF M/C NO. 72P602B	PMT	4M				I			I				I		RRC	RRC-MRCH	129801	B
1,030	HSU -72 -72P602B	HSU-72P602B-P01	PM OF 72P602B-P01	PMT	4M		P				P			P				RRC	RRC-MRCH	130800	B
1,031	HSU -72 -72P603A	HSU-72P603A-M	STAND BY CHECK LV. MOT 72P603A-M01	PMT	1Y							T						RRC	RRC-ERCH	139038	B
1,032	HSU -72 -72P603A	HSU-72P603A-M	Regreasing Mot BRG of 72P603A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139711	B
1,033	HSU -72 -72P603A	HSU-72P603A-M	STAND BY CHECK LV. MOT 72P603A-M01	PMT	1Y				T									RRC	RRC-ERCH	154264	B
1,034	HSU -72 -72P603A	HSU-72P603A-P01	VB. INSP & ANALY M/C 72P603A	INT	4M	I				I				I				IRI	IRI-INVB	130401	B
1,035	HSU -72 -72P603A	HSU-72P603A-P01	VB. INSP & ANALY M/C 72P603A	INT	4M		I				I				I			IRI	IRI-INVB	131080	B
1,036	HSU -72 -72P603A	HSU-72P603A-P01	VB. INSP & ANALY M/C 72P603A	INT	4M			I				I				I		IRI	IRI-INVB	131306	B
1,037	HSU -72 -72P603A	HSU-72P603A-P01	PM INSP OF M/C NO. 72P603A	PMT	4M		I				I				I			RRC	RRC-MRCH	129802	B
1,038	HSU -72 -72P603B	HSU-72P603B-M	STAND BY CHECK LV. MOT 72P603B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139039	B
1,039	HSU -72 -72P603B	HSU-72P603B-M	Regreasing Mot BRG of 72P603B-M01	PMT	4M				L			L				L		RRC	RRC-ERCH	139712	B
1,040	HSU -72 -72P603B	HSU-72P603B-P01	VB. INSP & ANALY M/C 72P603B	INT	4M				I			I				I		IRI	IRI-INVB	130402	B
1,041	HSU -72 -72P603B	HSU-72P603B-P01	PM INSP OF M/C NO. 72P603B	PMT	4M				I			I				I		RRC	RRC-MRCH	129803	B
1,042	HSU -72 -72P603B	HSU-72P603B-P01	PM OF 72P603B-P01	PMT	4M			P			P				P			RRC	RRC-MRCH	130802	B
1,043	HSU -72 -72P604A	HSU-72P604A-M	STAND BY CHECK LV. MOT 72P604A-M01	PMT	1Y							T						RRC	RRC-ERCH	139040	B
1,044	HSU -72 -72P604A	HSU-72P604A-M	Regreasing Mot BRG of 72P604A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139713	B
1,045	HSU -72 -72P604A	HSU-72P604A-M	STAND BY CHECK LV. MOT 72P604A-M01	PMT	1Y				T									RRC	RRC-ERCH	154265	B
1,046	HSU -72 -72P604A	HSU-72P604A-P01	VB. INSP & ANALY M/C 72P604A	INT	4M	I				I				I				IRI	IRI-INVB	130403	B
1,047	HSU -72 -72P604A	HSU-72P604A-P01	VB. INSP & ANALY M/C 72P604A	INT	4M		I				I				I			IRI	IRI-INVB	131081	B
1,048	HSU -72 -72P604A	HSU-72P604A-P01	VB. INSP & ANALY M/C 72P604A	INT	4M			I				I				I		IRI	IRI-INVB	131307	B
1,049	HSU -72 -72P604A	HSU-72P604A-P01	PM INSP OF M/C NO. 72P604A	PMT	4M		I				I				I			RRC	RRC-MRCH	129804	B
1,050	HSU -72 -72P604A	HSU-72P604A-P01	PM OF 72P604A-P01	PMT	4M				P			P		P			P	RRC	RRC-MRCH	130803	B
1,051	HSU -72 -72P604B	HSU-72P604B-M	STAND BY CHECK LV. MOT 72P604B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139041	B
1,052	HSU -72 -72P604B	HSU-72P604B-M	Regreasing Mot BRG of 72P604B-M01	PMT	4M				L			L				L		RRC	RRC-ERCH	139714	B
1,053	HSU -72 -72P604B	HSU-72P604B-P01	VB. INSP & ANALY M/C 72P604B	INT	4M				I			I				I		IRI	IRI-INVB	130404	B
1,054	HSU -72 -72P604B	HSU-72P604B-P01	PM INSP OF M/C NO. 72P604B	PMT	4M				I			I				I		RRC	RRC-MRCH	129805	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,055	HSU -72 -72P604B	HSU-72P604B-P01	PM OF 72P604B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	130804	B
1,056	HSU -72 -72R101	HSU-72R101-R01	Pressure Vessel inspection	PMT	5Y								I					IRI	IRI-INRC	167336	B
1,057	HSU -72 -72R201	HSU-72R201-R01	Pressure Vessel inspection	PMT	5Y								I					IRI	IRI-INRC	167337	B
1,058	HSU -72 -72R301	HSU-72R301-R01	Pressure Vessel inspection	PMT	5Y								I					IRI	IRI-INRC	167338	B
1,059	HSU -72 -72T601	HSU-72T601-T01	Storage tank inspection	PMT	5Y							I						IRI	IRI-INRC	167365	A
1,060	HSU -72 -72X601	HSU-72X601-P01A	PM INSP OF M/C NO. 72X601 -P01A	PMT	4M			I					I			I		RRC	RRC-MRCH	129808	B
1,061	HSU -72 -72X601	HSU-72X601-P01A	PM OF 72X601 -P01A	PMT	4M					P				P			P	RRC	RRC-MRCH	130807	B
1,062	HSU -72 -72X601	HSU-72X601-P01A-M	STAND BY CHECK LV. MOT 72X601-P01A	PMT	1Y									T				RRC	RRC-ERCH	139042	B
1,063	HSU -72 -72X601	HSU-72X601-P01A-M	STAND BY CHECK LV. MOT 72X601-P01A	PMT	1Y					T								RRC	RRC-ERCH	154266	B
1,064	HSU -72 -72X601	HSU-72X601-P01B	PM INSP OF M/C NO. 72X601 -P01B	PMT	4M					I			I				I	RRC	RRC-MRCH	129809	B
1,065	HSU -72 -72X601	HSU-72X601-P01B	PM OF 72X601 -P01B	PMT	4M				P			P			P			RRC	RRC-MRCH	130808	B
1,066	HSU -72 -72X601	HSU-72X601-P01B-M	STAND BY CHECK LV. MOT 72X601-P01B	PMT	6M				T					T				RRC	RRC-ERCH	139043	B
1,067	HSU -72 -72X602	HSU-72X602-P01A	PM INSP OF M/C NO. 72X602 -P01A	PMT	4M			I				I			I			RRC	RRC-MRCH	129810	B
1,068	HSU -72 -72X602	HSU-72X602-P01A	PM OF 72X602 -P01A	PMT	4M					P				P			P	RRC	RRC-MRCH	130809	B
1,069	HSU -72 -72X602	HSU-72X602-P01A-M	STAND BY CHECK LV. MOT 72X602-P01A	PMT	1Y									T				RRC	RRC-ERCH	139044	B
1,070	HSU -72 -72X602	HSU-72X602-P01A-M	STAND BY CHECK LV. MOT 72X602-P01A	PMT	1Y					T								RRC	RRC-ERCH	154267	B
1,071	HSU -72 -72X602	HSU-72X602-P01B	PM INSP OF M/C NO. 72X602 -P01B	PMT	4M					I			I				I	RRC	RRC-MRCH	129811	B
1,072	HSU -72 -72X602	HSU-72X602-P01B	PM OF 72X602 -P01B	PMT	4M				P			P			P			RRC	RRC-MRCH	130810	B
1,073	HSU -72 -72X602	HSU-72X602-P01B-M	STAND BY CHECK LV. MOT 72X602-P01B	PMT	6M				T					T				RRC	RRC-ERCH	139045	B
1,074	HSU -72 -72X603	HSU-72X603-P01A	PM INSP OF M/C NO. 72X603 -P01A	PMT	4M			I				I			I			RRC	RRC-MRCH	129812	B
1,075	HSU -72 -72X603	HSU-72X603-P01A	PM OF 72X603 -P01A	PMT	4M					P				P			P	RRC	RRC-MRCH	130811	B
1,076	HSU -72 -72X603	HSU-72X603-P01A-M	STAND BY CHECK LV. MOT 72X603-P01A	PMT	1Y									T				RRC	RRC-ERCH	139046	B
1,077	HSU -72 -72X603	HSU-72X603-P01A-M	STAND BY CHECK LV. MOT 72X603-P01A	PMT	1Y					T								RRC	RRC-ERCH	154268	B
1,078	HSU -72 -72X603	HSU-72X603-P01B	PM INSP OF M/C NO. 72X603 -P01B	PMT	4M					I			I				I	RRC	RRC-MRCH	129813	B
1,079	HSU -72 -72X603	HSU-72X603-P01B	PM OF 72X603 -P01B	PMT	4M				P			P			P			RRC	RRC-MRCH	130812	B
1,080	HSU -72 -72X603	HSU-72X603-P01B-M	STAND BY CHECK LV. MOT 72X603-P01B	PMT	6M				T					T				RRC	RRC-ERCH	139047	B
1,081	HSU -73 -AIR	HSU-73-AC-001	PM ALL TYPE OF AIR 73-AC-001 (Large 2,8)	PMT	2M					P		P			P		P	RRC	RRC-ERCH	138227	B
1,082	HSU -73 -AIR	HSU-73-AC-001	PM ALL TYPE OF AIR 73-AC-001 (Large 2,8)	PMT	6M			P						P				RRC	RRC-ERCH	138227	B
1,083	HSU -73 -AIR	HSU-73-CEMS-001	PM TYPE OF AIR 73-CEMS-001 (Large 2,8)	PMT	2M					P		P			P		P	RRC	RRC-ERCH	138254	A
1,084	HSU -73 -AIR	HSU-73-CEMS-001	PM TYPE OF AIR 73-CEMS-001 (Large 2,8)	PMT	6M			P						P				RRC	RRC-ERCH	138254	A
1,085	HSU -73 -73C401	HSU-73C401-C01	Pressure Vessel inspection	PMT	5Y									I				IRI	IRI-INRC	167339	A
1,086	HSU -73 -73C402	HSU-73C402-C01	Pressure Vessel inspection	PMT	5Y									I				IRI	IRI-INRC	167340	A
1,087	HSU -73 -73C501	HSU-73C501-C01	Pressure Vessel inspection	PMT	5Y									I				IRI	IRI-INRC	167341	A
1,088	HSU -73 -73D401	HSU-73D401-D01	Pressure Vessel inspection	PMT	5Y									I				IRI	IRI-INRC	167342	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,089	HSU -73 -73D402	HSU-73D402-D01	Pressure Vessel inspection	PMT	5Y									I				IRI	IRI-INRC	167343	A
1,090	HSU -73 -73D403	HSU-73D403-D01	Pressure Vessel inspection	PMT	5Y									I				IRI	IRI-INRC	167344	A
1,091	HSU -73 -73D501	HSU-73D501-D01	Pressure Vessel inspection	PMT	5Y									I				IRI	IRI-INRC	167345	A
1,092	HSU -73 -73D502	HSU-73D502-D01	Pressure Vessel inspection	PMT	5Y									I				IRI	IRI-INRC	167346	A
1,093	HSU -73 -73D503	HSU-73D503-D01	Pressure Vessel inspection	PMT	5Y									I				IRI	IRI-INRC	167347	A
1,094	HSU -73 -73E401A	HSU-73E401A-E01	Pressure Vessel inspection	PMT	5Y									I				IRI	IRI-INRC	167348	A
1,095	HSU -73 -73E401B	HSU-73E401B-E01	Pressure Vessel inspection	PMT	5Y									I				IRI	IRI-INRC	167349	A
1,096	HSU -73 -73E402A	HSU-73E402A-E01	Pressure Vessel inspection	PMT	5Y									I				IRI	IRI-INRC	167350	B
1,097	HSU -73 -73E402A	HSU-73E402A-K01A	VB. INSP & ANALY M/C 73E402A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130413	B
1,098	HSU -73 -73E402A	HSU-73E402A-K01A	PM INSP OF M/C NO. 73E402A-K01A	PMT	3M	I			I			I			I			RRC	RRC-MRCH	129814	B
1,099	HSU -73 -73E402A	HSU-73E402A-K01A	REGREASING BRG OF 73E402A-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130050	B
1,100	HSU -73 -73E402A	HSU-73E402A-K01A-M	Regreasing Mot BRG of 73E402A-K01A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139715	B
1,101	HSU -73 -73E402A	HSU-73E402A-K01B	VB. INSP & ANALY M/C 73E402A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130414	B
1,102	HSU -73 -73E402A	HSU-73E402A-K01B	PM INSP OF M/C NO. 73E402A-K01B	PMT	3M	I			I			I			I			RRC	RRC-MRCH	129815	B
1,103	HSU -73 -73E402A	HSU-73E402A-K01B	REGREASING BRG OF 73E402A-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130051	B
1,104	HSU -73 -73E402A	HSU-73E402A-K01B-M	Regreasing Mot BRG of 73E402A-K01B-M01	PMT	4M				L			L			L			RRC	RRC-ERCH	139716	B
1,105	HSU -73 -73E402B	HSU-73E402B-E01	Pressure Vessel inspection	PMT	5Y									I				IRI	IRI-INRC	167351	B
1,106	HSU -73 -73E402B	HSU-73E402B-K01A	VB. INSP & ANALY M/C 73E402B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130415	B
1,107	HSU -73 -73E402B	HSU-73E402B-K01A	PM INSP OF M/C NO. 73E402B-K01A	PMT	3M	I			I			I			I			RRC	RRC-MRCH	129816	B
1,108	HSU -73 -73E402B	HSU-73E402B-K01A	REGREASING BRG OF 73E402B-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130052	B
1,109	HSU -73 -73E402B	HSU-73E402B-K01A-M	Regreasing Mot BRG of 73E402B-K01A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139717	B
1,110	HSU -73 -73E402B	HSU-73E402B-K01B	VB. INSP & ANALY M/C 73E402B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130416	B
1,111	HSU -73 -73E402B	HSU-73E402B-K01B	PM INSP OF M/C NO. 73E402B-K01B	PMT	3M	I			I			I			I			RRC	RRC-MRCH	129817	B
1,112	HSU -73 -73E402B	HSU-73E402B-K01B	REGREASING BRG OF 73E402B-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130053	B
1,113	HSU -73 -73E402B	HSU-73E402B-K01B-M	Regreasing Mot BRG of 73E402B-K01B-M01	PMT	4M				L			L			L			RRC	RRC-ERCH	139718	B
1,114	HSU -73 -73E402C	HSU-73E402C-E01	Pressure Vessel inspection	PMT	5Y									I				IRI	IRI-INRC	167352	B
1,115	HSU -73 -73E402C	HSU-73E402C-K01A	VB. INSP & ANALY M/C 73E402C-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130417	B
1,116	HSU -73 -73E402C	HSU-73E402C-K01A	PM INSP OF M/C NO. 73E402C-K01A	PMT	3M	I			I			I			I			RRC	RRC-MRCH	129818	B
1,117	HSU -73 -73E402C	HSU-73E402C-K01A	REGREASING BRG OF 73E402C-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130054	B
1,118	HSU -73 -73E402C	HSU-73E402C-K01A-M	Regreasing Mot BRG of 73E402C-K01A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139719	B
1,119	HSU -73 -73E402C	HSU-73E402C-K01B	VB. INSP & ANALY M/C 73E402C-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130418	B
1,120	HSU -73 -73E402C	HSU-73E402C-K01B	PM INSP OF M/C NO. 73E402C-K01B	PMT	3M	I			I			I			I			RRC	RRC-MRCH	129819	B
1,121	HSU -73 -73E402C	HSU-73E402C-K01B	REGREASING BRG OF 73E402C-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130055	B
1,122	HSU -73 -73E402C	HSU-73E402C-K01B-M	Regreasing Mot BRG of 73E402C-K01B-M01	PMT	4M				L			L			L			RRC	RRC-ERCH	139720	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,123	HSU -73 -73E403A	HSU-73E403A-E01	Pressure Vessel inspection	PMT	5Y									I				IRI	IRI-INRC	167353	A
1,124	HSU -73 -73E403B	HSU-73E403B-E01	Pressure Vessel inspection	PMT	5Y									I				IRI	IRI-INRC	167354	A
1,125	HSU -73 -73E404	HSU-73E404-E01	Pressure Vessel inspection	PMT	5Y									I				IRI	IRI-INRC	167355	B
1,126	HSU -73 -73E405	HSU-73E405-E01	Pressure Vessel inspection	PMT	5Y									I				IRI	IRI-INRC	167356	A
1,127	HSU -73 -73E501A	HSU-73E501A-E01	Pressure Vessel inspection	PMT	5Y										I			IRI	IRI-INRC	167357	A
1,128	HSU -73 -73E501B	HSU-73E501B-E01	Pressure Vessel inspection	PMT	5Y										I			IRI	IRI-INRC	167358	A
1,129	HSU -73 -73E502	HSU-73E502-E01	Pressure Vessel inspection	PMT	5Y										I			IRI	IRI-INRC	167359	A
1,130	HSU -73 -73E503	HSU-73E503-E01	Pressure Vessel inspection	PMT	5Y										I			IRI	IRI-INRC	167360	A
1,131	HSU -73 -73E503	HSU-73E503-K01A	VB. INSP & ANALY M/C 73E503-K01A	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	131089	A
1,132	HSU -73 -73E503	HSU-73E503-K01A	PM INSP OF M/C NO. 73E503-K01A	PMT	3M	I			I			I			I			RRC	RRC-MRCH	129820	A
1,133	HSU -73 -73E503	HSU-73E503-K01A	REGREASING BRG OF 73E503-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130056	A
1,134	HSU -73 -73E503	HSU-73E503-K01B	VB. INSP & ANALY M/C 73E503-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130420	A
1,135	HSU -73 -73E503	HSU-73E503-K01B	PM INSP OF M/C NO. 73E503-K01B	PMT	3M	I			I			I			I			RRC	RRC-MRCH	129821	A
1,136	HSU -73 -73E503	HSU-73E503-K01B	REGREASING BRG OF 73E503-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130057	A
1,137	HSU -73 -73E503A	HSU-73E503A-K01A-M	Regreasing Mot BRG of 73E503A-K01A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139721	A
1,138	HSU -73 -73E503A	HSU-73E503A-K01B-M	Regreasing Mot BRG of 73E503A-K01B-M01	PMT	4M				L			L			L			RRC	RRC-ERCH	139722	A
1,139	HSU -73 -73K401	HSU-73K401-K01	PM OF HSU-73K401	PMT	4M	P				P			P					RRC	RRC-MRCH	148839	C
1,140	HSU -73 -73K401	HSU-73K401-K01	PM INSP OF M/C NO. 73K401	PMT	4M	I				I			I					RRC	RRC-MRCH	149151	C
1,141	HSU -73 -73K401	HSU-73K401-M	STAND BY CHECK LV. MOT 73K401 -M01	PMT	6M				T				T					RRC	RRC-ERCH	139056	C
1,142	HSU -73 -73K401	HSU-73K401-M	Regreasing Mot BRG of 73K401-M01	PMT	4M	L				L			L					RRC	RRC-ERCH	139723	C
1,143	HSU -73 -73K402A	HSU-73K402A-K01	PM OF 73K402A	PMT	4M				P			P			P			RRC	RRC-MRCH	148840	B
1,144	HSU -73 -73K402A	HSU-73K402A-K01	PM INSP OF M/C NO. 73K402A	PMT	4M			I			I			I				RRC	RRC-MRCH	149152	B
1,145	HSU -73 -73K402A	HSU-73K402A-M	STAND BY CHECK LV. MOT 73K402A-M01	PMT	1Y					T								RRC	RRC-ERCH	139057	B
1,146	HSU -73 -73K402A	HSU-73K402A-M	Regreasing Mot BRG of 73K402A-M01	PMT	4M	L				L			L					RRC	RRC-ERCH	139724	B
1,147	HSU -73 -73K402A	HSU-73K402A-M	STAND BY CHECK LV. MOT 73K402A-M01	PMT	1Y					T								RRC	RRC-ERCH	154269	B
1,148	HSU -73 -73K402B	HSU-73K402B-K01	PM OF 73K402B	PMT	4M			P				P			P			RRC	RRC-MRCH	148841	B
1,149	HSU -73 -73K402B	HSU-73K402B-K01	PM INSP OF M/C NO. 73K402B	PMT	4M					I			I				I	RRC	RRC-MRCH	149153	B
1,150	HSU -73 -73K402B	HSU-73K402B-M	STAND BY CHECK LV. MOT 73K402B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139058	B
1,151	HSU -73 -73K402B	HSU-73K402B-M	Regreasing Mot BRG of 73K402B-M01	PMT	4M					L			L				L	RRC	RRC-ERCH	139725	B
1,152	HSU -73 -73P401A	HSU-73P401A-M	STAND BY CHECK LV. MOT 73P401A-M01	PMT	1Y								T					RRC	RRC-ERCH	139059	B
1,153	HSU -73 -73P401A	HSU-73P401A-M	Regreasing Mot BRG of 73P401A-M01	PMT	4M	L				L			L					RRC	RRC-ERCH	139726	B
1,154	HSU -73 -73P401A	HSU-73P401A-M	STAND BY CHECK LV. MOT 73P401A-M01	PMT	1Y				T									RRC	RRC-ERCH	154270	B
1,155	HSU -73 -73P401A	HSU-73P401A-P01	VB. INSP & ANALY M/C 73P401A	INT	4M	I				I			I					IRI	IRI-INVB	130421	A
1,156	HSU -73 -73P401A	HSU-73P401A-P01	VB. INSP & ANALY M/C 73P401A	INT	4M		I				I			I				IRI	IRI-INVB	131090	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,157	HSU -73 -73P401A	HSU-73P401A-P01	VB. INSP & ANALY M/C 73P401A	INT	4M			I				I				I		IRI	IRI-INVB	131316	A
1,158	HSU -73 -73P401A	HSU-73P401A-P01	PM INSP OF M/C NO. 73P401A	PMT	4M		I				I				I			RRC	RRC-MRCH	129822	A
1,159	HSU -73 -73P401A	HSU-73P401A-P01	PM OF 73P401A-P01	PMT	4M				P			P				P		RRC	RRC-MRCH	130813	A
1,160	HSU -73 -73P401B	HSU-73P401B-M	STAND BY CHECK LV. MOT 73P401B-MD1	PMT	6M			T					T					RRC	RRC-ERCH	139060	B
1,161	HSU -73 -73P401B	HSU-73P401B-M	Regreasing Mot BRG of 73P401B-MD1	PMT	4M				L			L				L		RRC	RRC-ERCH	139727	B
1,162	HSU -73 -73P401B	HSU-73P401B-P01	VB. INSP & ANALY M/C 73P401B	INT	4M				I			I				I		IRI	IRI-INVB	130422	A
1,163	HSU -73 -73P401B	HSU-73P401B-P01	PM INSP OF M/C NO. 73P401B	PMT	4M				I			I				I		RRC	RRC-MRCH	129823	A
1,164	HSU -73 -73P401B	HSU-73P401B-P01	PM OF 73P401B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	130814	A
1,165	HSU -73 -73P402A	HSU-73P402A-M	STAND BY CHECK LV. MOT 73P402A-MD1	PMT	1Y								T					RRC	RRC-ERCH	139061	B
1,166	HSU -73 -73P402A	HSU-73P402A-M	Regreasing Mot BRG of 73P402A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139728	B
1,167	HSU -73 -73P402A	HSU-73P402A-M	STAND BY CHECK LV. MOT 73P402A-MD1	PMT	1Y				T									RRC	RRC-ERCH	154271	B
1,168	HSU -73 -73P402A	HSU-73P402A-P01	VB. INSP & ANALY M/C 73P402A	INT	4M	I				I				I				IRI	IRI-INVB	130423	A
1,169	HSU -73 -73P402A	HSU-73P402A-P01	VB. INSP & ANALY M/C 73P402A	INT	4M		I				I				I			IRI	IRI-INVB	131091	A
1,170	HSU -73 -73P402A	HSU-73P402A-P01	VB. INSP & ANALY M/C 73P402A	INT	4M			I				I				I		IRI	IRI-INVB	131317	A
1,171	HSU -73 -73P402A	HSU-73P402A-P01	PM INSP OF M/C NO. 73P402A	PMT	4M		I				I				I			RRC	RRC-MRCH	129824	A
1,172	HSU -73 -73P402A	HSU-73P402A-P01	PM OF 73P402A-P01	PMT	4M				P			P				P		RRC	RRC-MRCH	130815	A
1,173	HSU -73 -73P402B	HSU-73P402B-M	STAND BY CHECK LV. MOT 73P402B-MD1	PMT	6M			T					T					RRC	RRC-ERCH	139062	B
1,174	HSU -73 -73P402B	HSU-73P402B-M	Regreasing Mot BRG of 73P402B-MD1	PMT	4M				L			L				L		RRC	RRC-ERCH	139729	B
1,175	HSU -73 -73P402B	HSU-73P402B-P01	VB. INSP & ANALY M/C 73P402B	INT	4M				I			I				I		IRI	IRI-INVB	130424	A
1,176	HSU -73 -73P402B	HSU-73P402B-P01	PM INSP OF M/C NO. 73P402B	PMT	4M				I			I				I		RRC	RRC-MRCH	129825	A
1,177	HSU -73 -73P402B	HSU-73P402B-P01	PM OF 73P402B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	130816	A
1,178	HSU -73 -73P501A	HSU-73P501A-M	STAND BY CHECK LV. MOT 73P501A-MD1	PMT	1Y								T					RRC	RRC-ERCH	139063	B
1,179	HSU -73 -73P501A	HSU-73P501A-M	Regreasing Mot BRG of 73P501A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139730	B
1,180	HSU -73 -73P501A	HSU-73P501A-M	STAND BY CHECK LV. MOT 73P501A-MD1	PMT	1Y				T									RRC	RRC-ERCH	154272	B
1,181	HSU -73 -73P501A	HSU-73P501A-P01	VB. INSP & ANALY M/C 73P501A	INT	4M	I				I				I				IRI	IRI-INVB	130425	A
1,182	HSU -73 -73P501A	HSU-73P501A-P01	VB. INSP & ANALY M/C 73P501A	INT	4M		I				I				I			IRI	IRI-INVB	131092	A
1,183	HSU -73 -73P501A	HSU-73P501A-P01	VB. INSP & ANALY M/C 73P501A	INT	4M			I				I				I		IRI	IRI-INVB	131318	A
1,184	HSU -73 -73P501A	HSU-73P501A-P01	PM INSP OF M/C NO. 73P501A	PMT	4M		I				I				I			RRC	RRC-MRCH	129826	A
1,185	HSU -73 -73P501A	HSU-73P501A-P01	PM OF 73P501A-P01	PMT	4M				P			P				P		RRC	RRC-MRCH	130817	A
1,186	HSU -73 -73P501B	HSU-73P501B-M	STAND BY CHECK LV. MOT 73P501B-MD1	PMT	6M			T					T					RRC	RRC-ERCH	139064	B
1,187	HSU -73 -73P501B	HSU-73P501B-M	Regreasing Mot BRG of 73P501B-MD1	PMT	4M				L			L				L		RRC	RRC-ERCH	139731	B
1,188	HSU -73 -73P501B	HSU-73P501B-P01	VB. INSP & ANALY M/C 73P501B	INT	4M				I			I				I		IRI	IRI-INVB	130426	A
1,189	HSU -73 -73P501B	HSU-73P501B-P01	PM INSP OF M/C NO. 73P501B	PMT	4M				I			I				I		RRC	RRC-MRCH	129827	A
1,190	HSU -73 -73P501B	HSU-73P501B-P01	PM OF 73P501B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	130818	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,191	HSU -73 -73P502A	HSU-73P502A-M	STAND BY CHECK LV. MOT 73P502A-MD1	PMT	1Y								T					RRC	RRC-ERCH	139065	B
1,192	HSU -73 -73P502A	HSU-73P502A-M	STAND BY CHECK LV. MOT 73P502A-MD1	PMT	1Y				T									RRC	RRC-ERCH	154273	B
1,193	HSU -73 -73P502A	HSU-73P502A-P01	VB. INSP & ANALY M/C 73P502A	INT	4M	I				I			I					IRI	IRI-INVB	130427	B
1,194	HSU -73 -73P502A	HSU-73P502A-P01	VB. INSP & ANALY M/C 73P502A	INT	4M		I				I			I				IRI	IRI-INVB	131093	B
1,195	HSU -73 -73P502A	HSU-73P502A-P01	VB. INSP & ANALY M/C 73P502A	INT	4M			I				I			I			IRI	IRI-INVB	131319	B
1,196	HSU -73 -73P502A	HSU-73P502A-P01	PM INSP OF M/C NO. 73P502A	PMT	4M		I				I			I				RRC	RRC-MRCH	129828	B
1,197	HSU -73 -73P502A	HSU-73P502A-P01	PM OF 73P502A-P01	PMT	4M				P			P				P		RRC	RRC-MRCH	130819	B
1,198	HSU -73 -73P502B	HSU-73P502B-M	STAND BY CHECK LV. MOT 73P502B-MD1	PMT	6M			T					T					RRC	RRC-ERCH	139066	B
1,199	HSU -73 -73P502B	HSU-73P502B-P01	VB. INSP & ANALY M/C 73P502B	INT	4M				I			I				I		IRI	IRI-INVB	130428	B
1,200	HSU -73 -73P502B	HSU-73P502B-P01	PM INSP OF M/C NO. 73P502B	PMT	4M				I			I				I		RRC	RRC-MRCH	129829	B
1,201	HSU -73 -73P502B	HSU-73P502B-P01	PM OF 73P502B-P01	PMT	4M			P				P			P			RRC	RRC-MRCH	130820	B
1,202	HSU -73 -73P503A	HSU-73P503A-M	STAND BY CHECK LV. MOT 73P503A-MD1	PMT	1Y								T					RRC	RRC-ERCH	139067	B
1,203	HSU -73 -73P503A	HSU-73P503A-M	STAND BY CHECK LV. MOT 73P503A-MD1	PMT	1Y				T									RRC	RRC-ERCH	154274	B
1,204	HSU -73 -73P503A	HSU-73P503A-P01	VB. INSP & ANALY M/C 73P503A	INT	4M	I				I			I					IRI	IRI-INVB	130429	B
1,205	HSU -73 -73P503A	HSU-73P503A-P01	VB. INSP & ANALY M/C 73P503A	INT	4M		I				I			I				IRI	IRI-INVB	131094	B
1,206	HSU -73 -73P503A	HSU-73P503A-P01	VB. INSP & ANALY M/C 73P503A	INT	4M			I				I			I			IRI	IRI-INVB	131320	B
1,207	HSU -73 -73P503A	HSU-73P503A-P01	PM INSP OF M/C NO. 73P503A	PMT	4M		I				I			I				RRC	RRC-MRCH	129830	B
1,208	HSU -73 -73P503A	HSU-73P503A-P01	PM OF 73P503A-P01	PMT	4M				P			P			P			RRC	RRC-MRCH	130821	B
1,209	HSU -73 -73P503B	HSU-73P503B-M	STAND BY CHECK LV. MOT 73P503B-MD1	PMT	6M			T					T					RRC	RRC-ERCH	139068	B
1,210	HSU -73 -73P503B	HSU-73P503B-P01	VB. INSP & ANALY M/C 73P503B	INT	4M				I			I				I		IRI	IRI-INVB	130430	B
1,211	HSU -73 -73P503B	HSU-73P503B-P01	PM INSP OF M/C NO. 73P503B	PMT	4M				I			I				I		RRC	RRC-MRCH	129831	B
1,212	HSU -73 -73P503B	HSU-73P503B-P01	PM OF 73P503B-P01	PMT	4M			P			P			P				RRC	RRC-MRCH	130822	B
1,213	HSU -73 -73P504	HSU-73P504-M	STAND BY CHECK LV. MOT 73P504-MD1	PMT	6M			T					T					RRC	RRC-ERCH	139069	C
1,214	HSU -73 -73P504	HSU-73P504-P01	VB. INSP & ANALY M/C 73P504	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130431	C
1,215	HSU -73 -73P504	HSU-73P504-P01	PM INSP OF M/C NO. 73P504	PMT	4M		I				I			I				RRC	RRC-MRCH	129832	C
1,216	HSU -73 -73P504	HSU-73P504-P01	PM OF 73P504-P01	PMT	4M	P				P			P					RRC	RRC-MRCH	130823	C
1,217	HSU -73 -73R401	HSU-73R401-R01	Pressure Vessel inspection	PMT	5Y									I				IRI	IRI-INRC	167361	A
1,218	HSU -73 -73T501	HSU-73T501-T01	Storage tank inspection	PMT	5Y							I						IRI	IRI-INRC	167366	A
1,219	HSU -73 -73T501	HSU-73T501-T01	PM; FOR Emergency Vent Cover 73T501	PMT	6M						P							RRC	RRC-MRCH	254648	A
1,220	HSU -51 -QMI_GC	HSU-AT5101701	VERIFY GC AT5101701	PMT	4M					V			V			V		CAN	CAN-QUHV	140932	B
1,221	HSU -51 -QMI_GC	HSU-AT5101901	VERIFY GC AT5101901	PMT	4M					V			V			V		CAN	CAN-QUHV	140933	A
1,222	HSU -51 -QMI_GAS	HSU-AT5101902	VERIFY OXYGEN AT5101902	PMT	4M					V			V			V		CAN	CAN-QUHV	140934	B
1,223	HSU -51 -QMI_GAS	HSU-AT5101904	VERIFY OXYGEN AT5101904	PMT	4M					V			V			V		CAN	CAN-QUHV	140935	B
1,224	HSU -51 -QMI_GAS	HSU-AT5150203	VERIFY OXYGEN AT5150203	PMT	6M					V					V			CAN	CAN-QUHV	204942	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,225	HSU -51 -QMI_GAS	HSU-AT5150401	VERIFY OEMS AT5150401	PMT	2M	V		V		V		V		V		V		CAN	CAN-QUHV	204940	B
1,226	HSU -51 -QMI_GAS	HSU-AT5150402	VERIFY DUST AT5150402	PMT	6M				V						V			CAN	CAN-QUHV	204941	B
1,227	HSU -51 -QMI_LIQ	HSU-AT5150501	VERIFY Conductivity AT5150501	PMT	6M						V			V			V	CAN	CAN-QUHV	140936	B
1,228	HSU -51 -QMI_LIQ	HSU-AT5150502	VERIFY PH AT5150502	PMT	6M						V						V	CAN	CAN-QUHV	140937	B
1,229	HSU -70 -QMI_LIQ	HSU-AT7000301	VERIFY PH AT7000301	PMT	6M				V				V					CAN	CAN-QUHV	140740	B
1,230	HSU -72 -QMI_GC	HSU-AT7202101	VERIFY GC AT7202101	PMT	4M	V				V				V				CAN	CAN-QUHV	140716	B
1,231	HSU -72 -QMI_GC	HSU-AT7202201	VERIFY GC AT7202201	PMT	4M	V				V				V				CAN	CAN-QUHV	140717	B
1,232	HSU -72 -QMI_GAS	HSU-AT7203201	VERIFY OXYGEN AIT7203201	PMT	4M			V				V				V		CAN	CAN-QUHV	140710	B
1,233	HSU -72 -QMI_GAS	HSU-AT7203202	VERIFY OXYGEN AIT7203202	PMT	6M				V					V				CAN	CAN-QUHV	140711	B
1,234	HSU -72 -QMI_GAS	HSU-AT7206201	VERIFY OXYGEN AIT7206201	PMT	4M			V				V				V		CAN	CAN-QUHV	140712	B
1,235	HSU -72 -QMI_GAS	HSU-AT7206202	VERIFY OXYGEN AIT7206202	PMT	6M				V					V				CAN	CAN-QUHV	140713	B
1,236	HSU -72 -QMI_GAS	HSU-AT7208201	VERIFY OXYGEN AIT7208201	PMT	4M			V				V				V		CAN	CAN-QUHV	140714	B
1,237	HSU -72 -QMI_GAS	HSU-AT7208202	VERIFY OXYGEN AIT7208202	PMT	6M				V					V				CAN	CAN-QUHV	140715	B
1,238	HSU -73 -QMI_GC	HSU-AT7300601	VERIFY GC AT7300601	PMT	4M	V				V				V				CAN	CAN-QUHV	140680	A
1,239	HSU -73 -QMI_LIQ	HSU-AT7300602	VERIFY PH AT7300602	PMT	6M						V						V	CAN	CAN-QUHV	140681	C
1,240	HSU -73 -QMI_GC	HSU-AT7300801	VERIFY GC AT7300801	PMT	4M	V				V				V				CAN	CAN-QUHV	140682	B
1,241	HSU -73 -QMI_GAS	HSU-AT7301301	VERIFY OXYGEN AT7301301	PMT	6M			V						V				CAN	CAN-QUHV	140683	B
1,242	HSU -73 -QMI_GAS	HSU-AT7301401	VERIFY DUST AT7301401	PMT	6M				V				V					CAN	CAN-QUHV	204679	B
1,243	HSU -73 -QMI_GAS	HSU-AT7301402	VERIFY OEMS AT7301402	PMT	2M	V		V		V		V		V		V		CAN	CAN-QUHV	204680	B
1,244	HSU -STR-BUILDING	HSU-BDG-51D001	INSPECTION BUILDING FOR RCHS	INT	6Y				I									ENE	ENE-ENQS	204337	A
1,245	HSU -STR-BUILDING	HSU-BDG-51E002	INSPECTION BUILDING FOR RCHS	INT	6Y				I									ENE	ENE-ENQS	204338	A
1,246	HSU -STR-BUILDING	HSU-BDG-51E003	INSPECTION BUILDING FOR RCHS	INT	6Y				I									ENE	ENE-ENQS	204339	A
1,247	HSU -STR-BUILDING	HSU-BDG-51E004	INSPECTION BUILDING FOR RCHS	INT	6Y				I									ENE	ENE-ENQS	204340	A
1,248	HSU -STR-BUILDING	HSU-BDG-51E005	INSPECTION BUILDING FOR RCHS	INT	6Y				I									ENE	ENE-ENQS	204342	A
1,249	HSU -STR-BUILDING	HSU-BDG-51E006	INSPECTION BUILDING FOR RCHS	INT	6Y				I									ENE	ENE-ENQS	204344	A
1,250	HSU -STR-BUILDING	HSU-BDG-51E007	INSPECTION BUILDING FOR RCHS	INT	6Y				I									ENE	ENE-ENQS	204345	A
1,251	HSU -STR-BUILDING	HSU-BDG-51E009	INSPECTION BUILDING FOR RCHS	INT	6Y				I									ENE	ENE-ENQS	204346	A
1,252	HSU -STR-BUILDING	HSU-BDG-51E011	INSPECTION BUILDING FOR RCHS	INT	6Y				I									ENE	ENE-ENQS	204347	A
1,253	HSU -STR-BUILDING	HSU-BDG-51E013	INSPECTION BUILDING FOR RCHS	INT	6Y				I									ENE	ENE-ENQS	204349	A
1,254	HSU -STR-BUILDING	HSU-BDG-51K004	INSPECTION BUILDING FOR RCHS	INT	6Y				I									ENE	ENE-ENQS	204350	A
1,255	HSU -STR-BUILDING	HSU-BDG-70C001	INSPECTION BUILDING FOR RCHS	INT	6Y				I									ENE	ENE-ENQS	204353	A
1,256	HSU -STR-BUILDING	HSU-BDG-70D001	INSPECTION BUILDING FOR RCHS	INT	6Y				I									ENE	ENE-ENQS	204355	A
1,257	HSU -STR-BUILDING	HSU-BDG-70D002	INSPECTION BUILDING FOR RCHS	INT	6Y				I									ENE	ENE-ENQS	204356	A
1,258	HSU -STR-BUILDING	HSU-BDG-70D003	INSPECTION BUILDING FOR RCHS	INT	6Y				I									ENE	ENE-ENQS	204358	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,259	HSU -STR-BUILDING	HSU-BDG-70D004	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204360	A
1,260	HSU -STR-BUILDING	HSU-BDG-70D005	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204362	A
1,261	HSU -STR-BUILDING	HSU-BDG-70D006	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204363	A
1,262	HSU -STR-BUILDING	HSU-BDG-70E001	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204364	A
1,263	HSU -STR-BUILDING	HSU-BDG-70E002	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204365	A
1,264	HSU -STR-BUILDING	HSU-BDG-70E003	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204366	A
1,265	HSU -STR-BUILDING	HSU-BDG-70E004	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204367	A
1,266	HSU -STR-BUILDING	HSU-BDG-70F001	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204368	A
1,267	HSU -STR-BUILDING	HSU-BDG-70F002	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204369	A
1,268	HSU -STR-BUILDING	HSU-BDG-70F003	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204370	A
1,269	HSU -STR-BUILDING	HSU-BDG-71C001	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204371	A
1,270	HSU -STR-BUILDING	HSU-BDG-71D001	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204372	A
1,271	HSU -STR-BUILDING	HSU-BDG-71D002	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204373	A
1,272	HSU -STR-BUILDING	HSU-BDG-71D003	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204374	A
1,273	HSU -STR-BUILDING	HSU-BDG-71D004	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204375	A
1,274	HSU -STR-BUILDING	HSU-BDG-71E001	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204376	A
1,275	HSU -STR-BUILDING	HSU-BDG-71E002	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204377	A
1,276	HSU -STR-BUILDING	HSU-BDG-71E003	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204378	A
1,277	HSU -STR-BUILDING	HSU-BDG-71E004	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204379	A
1,278	HSU -STR-BUILDING	HSU-BDG-71F001	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204380	A
1,279	HSU -STR-BUILDING	HSU-BDG-71F002	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204381	A
1,280	HSU -STR-BUILDING	HSU-BDG-71F003	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204382	A
1,281	HSU -STR-BUILDING	HSU-BDG-71F004	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204383	A
1,282	HSU -STR-BUILDING	HSU-BDG-71F005	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204384	A
1,283	HSU -STR-BUILDING	HSU-BDG-71F006	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204385	A
1,284	HSU -STR-BUILDING	HSU-BDG-72B101-2	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204386	A
1,285	HSU -STR-BUILDING	HSU-BDG-72B201-2	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204387	A
1,286	HSU -STR-BUILDING	HSU-BDG-72B301-2	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204388	A
1,287	HSU -STR-BUILDING	HSU-BDG-REFORM	INSPECTION BUILDING FOR RCHS	INT	6Y					I								ENE	ENE-ENQS	204352	A
1,288	HSU -51 -DCS	HSU-DCS	INSPECT DCS SYSTEM	PMT	3M	I				I		I		I				CCS	CCS-SYS	246476	A
1,289	HSU -51 -DCS	HSU-DCS	BACKUP DCS SYSTEM	PMT	6M	I						I						CCS	CCS-SYS	246477	A
1,290	HSU -51 -DCS	HSU-DCS	UPDATE ANTIVIRUS DCS SYSTEM	PMT	3M	U				U		U		U				CCS	CCS-SYS	246478	A
1,291	HSU -73 -73K402A	HSU-DPT7350601	INSP. FIELD INST. (ห้ามปากบึ้ม)	PMT	1Y							I						RRC	RRC-IRCH	136748	C
1,292	HSU -73 -73K402B	HSU-DPT7351101	INSP. FIELD INST. (ห้ามปากบึ้ม)	PMT	1Y							I						RRC	RRC-IRCH	136749	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,293	HSU -51 -FIRE_ALARM	HSU-FA-MCP-51	PM F/A PUSH BUTTON (###) (UNIT 51)	PMT	3M		P			P			P			P		RRC	RRC-ERCH	140378	A
1,294	HSU -70 -FIRE_ALARM	HSU-FA-MCP-70	PM F/A PUSH BUTTON (###) (UNIT 70)	PMT	3M		P			P			P			P		RRC	RRC-ERCH	140386	A
1,295	HSU -71 -FIRE_ALARM	HSU-FA-MCP-71	PM F/A PUSH BUTTON (###) (UNIT 71)	PMT	3M		P			P			P			P		RRC	RRC-ERCH	140387	A
1,296	HSU -72 -FIRE_ALARM	HSU-FA-MCP-72	PM F/A PUSH BUTTON (###) (UNIT 72)	PMT	3M		P			P			P			P		RRC	RRC-ERCH	140388	A
1,297	HSU -73 -FIRE_ALARM	HSU-FA-MCP-73	PM F/A PUSH BUTTON (###) (UNIT 73)	PMT	3M		P			P			P			P		RRC	RRC-ERCH	140389	A
1,298	HSU -51 -FGS	HSU-FGS	INSPECT FGS SYSTEM	PMT	3M	I			I			I		I				CCS	CCS-SYS	246482	A
1,299	HSU -51 -FGS	HSU-FGS	BACKUP FGS SYSTEM	PMT	6M	I						I						CCS	CCS-SYS	246483	A
1,300	HSU -51 -FGS	HSU-FGS	UPDATE ANTIVIRUS FGS SYSTEM	PMT	3M	U			U			U		U				CCS	CCS-SYS	246484	A
1,301	HSU -51 -FLOW	HSU-FT5100902	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136157	C
1,302	HSU -51 -FLOW	HSU-FT5101001	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136167	C
1,303	HSU -51 -FLOW	HSU-FT5101002	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136168	C
1,304	HSU -51 -FLOW	HSU-FT5101003	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136158	C
1,305	HSU -51 -FLOW	HSU-FT5101004	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136159	C
1,306	HSU -51 -FLOW	HSU-FT5101005	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136160	C
1,307	HSU -51 -FLOW	HSU-FT5101006	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y	I												RRC	RRC-IRCH	136169	C
1,308	HSU -51 -FLOW	HSU-FT5101006	FT5101006-FULLFUN TEST FLOW TR	PMT	5Y											F		RRC	RRC-IRCH	260400	C
1,309	HSU -51 -FLOW	HSU-FT5101007	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136170	C
1,310	HSU -51 -FLOW	HSU-FT5101030	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136171	C
1,311	HSU -51 -FLOW	HSU-FT5101031	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136172	C
1,312	HSU -51 -FLOW	HSU-FT5101203	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y	I												RRC	RRC-IRCH	136173	C
1,313	HSU -51 -FLOW	HSU-FT5101203	FT5101203-FULLFUN TEST FLOW TR	PMT	5Y											F		RRC	RRC-IRCH	260401	C
1,314	HSU -51 -FLOW	HSU-FT5101801	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136164	C
1,315	HSU -51 -FLOW	HSU-FT5101802	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136165	C
1,316	HSU -51 -FLOW	HSU-FT5101803	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136166	C
1,317	HSU -51 -FLOW	HSU-FT5101804	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136174	C
1,318	HSU -51 -FLOW	HSU-FT5101805	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136175	C
1,319	HSU -51 -FLOW	HSU-FT5101902	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136176	C
1,320	HSU -51 -FLOW	HSU-FT5102101	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136177	C
1,321	HSU -51 -FLOW	HSU-FT5102201	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136161	C
1,322	HSU -51 -FLOW	HSU-FT5102301	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136178	C
1,323	HSU -51 -FLOW	HSU-FT5102302	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136179	C
1,324	HSU -51 -FLOW	HSU-FT5102305	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136180	C
1,325	HSU -51 -FLOW	HSU-FT5102401	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136181	C
1,326	HSU -51 -FLOW	HSU-FT5102402	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136182	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,327	HSU -51 -FLOW	HSU-FT5102601	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136183	C
1,328	HSU -51 -FLOW	HSU-FT5130101	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136184	C
1,329	HSU -51 -FLOW	HSU-FT5131101	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136185	C
1,330	HSU -51 -FLOW	HSU-FT5131102	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136186	C
1,331	HSU -51 -FLOW	HSU-FT5132103	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136187	C
1,332	HSU -51 -FLOW	HSU-FT5133101	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136188	C
1,333	HSU -51 -FLOW	HSU-FT5134102	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136189	C
1,334	HSU -51 -FLOW	HSU-FT5134106	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136190	C
1,335	HSU -51 -FLOW	HSU-FT5135102	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136191	C
1,336	HSU -51 -FLOW	HSU-FT5136103	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136192	C
1,337	HSU -51 -FLOW	HSU-FT5137101	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136193	C
1,338	HSU -51 -FLOW	HSU-FT5150301	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136194	C
1,339	HSU -51 -FLOW	HSU-FT5150302	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136195	C
1,340	HSU -51 -FLOW	HSU-FT5150303A	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136196	C
1,341	HSU -51 -FLOW	HSU-FT5150303B	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136197	C
1,342	HSU -51 -FLOW	HSU-FT5150303C	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136198	C
1,343	HSU -51 -FLOW	HSU-FT5150501	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136199	C
1,344	HSU -51 -FLOW	HSU-FT5150601A	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136200	C
1,345	HSU -51 -FLOW	HSU-FT5150601B	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136201	C
1,346	HSU -51 -FLOW	HSU-FT5150601C	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136202	C
1,347	HSU -51 -FLOW	HSU-FT5150602A	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136203	C
1,348	HSU -51 -FLOW	HSU-FT5150602B	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136204	C
1,349	HSU -51 -FLOW	HSU-FT5150602C	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136205	C
1,350	HSU -51 -FLOW	HSU-FT5150603	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136206	C
1,351	HSU -51 -FLOW	HSU-FT5150604	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136207	C
1,352	HSU -51 -FLOW	HSU-FT5150605	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136208	C
1,353	HSU -51 -FLOW	HSU-FT5150606A	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136209	C
1,354	HSU -51 -FLOW	HSU-FT5150606B	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136210	C
1,355	HSU -51 -FLOW	HSU-FT5150606C	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136211	C
1,356	HSU -51 -FLOW	HSU-FT5150801	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136212	C
1,357	HSU -51 -FLOW	HSU-FT5150802	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136213	C
1,358	HSU -70 -FLOW	HSU-FT7000101	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136214	C
1,359	HSU -70 -FLOW	HSU-FT7000102	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136215	C
1,360	HSU -70 -FLOW	HSU-FT7000103	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136216	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,361	HSU -70 -FLOW	HSU-FT7000201	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136217	C
1,362	HSU -70 -FLOW	HSU-FT7000301	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136218	C
1,363	HSU -70 -FLOW	HSU-FT7000302	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136219	C
1,364	HSU -70 -FLOW	HSU-FT7000303	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136220	C
1,365	HSU -70 -FLOW	HSU-FT7000304	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136221	C
1,366	HSU -70 -FLOW	HSU-FT7000401	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136222	C
1,367	HSU -70 -FLOW	HSU-FT7000402	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136223	C
1,368	HSU -70 -FLOW	HSU-FT7000601	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136224	C
1,369	HSU -70 -FLOW	HSU-FT7031101	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136225	C
1,370	HSU -70 -FLOW	HSU-FT7031102	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136226	C
1,371	HSU -70 -FLOW	HSU-FT7032101	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136227	C
1,372	HSU -70 -FLOW	HSU-FT7032102	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136228	C
1,373	HSU -70 -FLOW	HSU-FT7033101	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136229	C
1,374	HSU -70 -FLOW	HSU-FT7034101	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136230	C
1,375	HSU -70 -FLOW	HSU-FT7035101	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136231	C
1,376	HSU -70 -FLOW	HSU-FT7036102	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136232	C
1,377	HSU -70 -FLOW	HSU-FT7037101	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136233	C
1,378	HSU -71 -FLOW	HSU-FT7100101	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136234	C
1,379	HSU -71 -FLOW	HSU-FT7100102	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136235	C
1,380	HSU -71 -FLOW	HSU-FT7100103	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	136236	C
1,381	HSU -71 -FLOW	HSU-FT7100201	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136237	C
1,382	HSU -71 -FLOW	HSU-FT7100301	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136238	C
1,383	HSU -71 -FLOW	HSU-FT7100302	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136239	C
1,384	HSU -71 -FLOW	HSU-FT7100401	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136240	C
1,385	HSU -71 -FLOW	HSU-FT7100402	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136241	C
1,386	HSU -71 -FLOW	HSU-FT7100403	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136242	C
1,387	HSU -71 -FLOW	HSU-FT7100601	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136243	C
1,388	HSU -71 -FLOW	HSU-FT7100701	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136244	C
1,389	HSU -71 -FLOW	HSU-FT7100702	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136245	C
1,390	HSU -71 -FLOW	HSU-FT7100901	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136246	C
1,391	HSU -72 -FLOW	HSU-FT7202001	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136247	C
1,392	HSU -72 -FLOW	HSU-FT7202002	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136248	C
1,393	HSU -72 -FLOW	HSU-FT7202003	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136249	C
1,394	HSU -72 -FLOW	HSU-FT7202004	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136250	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,395	HSU -72 -FLOW	HSU-FT7202101	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	136375	C
1,396	HSU -72 -FLOW	HSU-FT7202102	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136251	C
1,397	HSU -72 -FLOW	HSU-FT7202103	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	136376	C
1,398	HSU -72 -FLOW	HSU-FT7202301	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136252	C
1,399	HSU -72 -FLOW	HSU-FT7202302	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136253	C
1,400	HSU -72 -FLOW	HSU-FT7202303	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136254	C
1,401	HSU -72 -FLOW	HSU-FT7202304	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136255	C
1,402	HSU -72 -FLOW	HSU-FT7202305	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136256	C
1,403	HSU -72 -FLOW	HSU-FT7202306	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136257	C
1,404	HSU -72 -FLOW	HSU-FT7202501	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y		I											RRC	RRC-IRCH	136258	C
1,405	HSU -72 -FLOW	HSU-FT7202501	FT7202501-FULLFUN TEST FLOW TR	PMT	5Y											F		RRC	RRC-IRCH	260402	C
1,406	HSU -72 -FLOW	HSU-FT7202601	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y		I											RRC	RRC-IRCH	136259	C
1,407	HSU -72 -FLOW	HSU-FT7202601	FT7202601-FULLFUN TEST FLOW TR	PMT	5Y											F		RRC	RRC-IRCH	260404	C
1,408	HSU -72 -FLOW	HSU-FT7202602	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136260	C
1,409	HSU -72 -FLOW	HSU-FT7202603	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136261	C
1,410	HSU -72 -FLOW	HSU-FT7202604	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136262	C
1,411	HSU -72 -FLOW	HSU-FT7202605	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y		I											RRC	RRC-IRCH	136263	C
1,412	HSU -72 -FLOW	HSU-FT7202605	FT7202605-FULLFUN TEST FLOW TR	PMT	5Y											F		RRC	RRC-IRCH	260403	C
1,413	HSU -72 -FLOW	HSU-FT7202606	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136264	C
1,414	HSU -72 -FLOW	HSU-FT7202611	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136265	C
1,415	HSU -72 -FLOW	HSU-FT7202615	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136266	C
1,416	HSU -72 -FLOW	HSU-FT7202619	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136267	C
1,417	HSU -72 -FLOW	HSU-FT7202620	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136268	C
1,418	HSU -72 -FLOW	HSU-FT7202622	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136269	C
1,419	HSU -72 -FLOW	HSU-FT7202623	INSP. FIELD INST. (ตัดกุปกรณ์)	INS	1Y		I											RRC	RRC-IRCH	136270	C
1,420	HSU -72 -FLOW	HSU-FT7202623	FT7202623-FULLFUN TEST FLOW TR	PMT	5Y											F		RRC	RRC-IRCH	260405	C
1,421	HSU -72 -FLOW	HSU-FT7202624	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136271	C
1,422	HSU -72 -FLOW	HSU-FT7202626	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136272	C
1,423	HSU -72 -FLOW	HSU-FT7202627	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136273	C
1,424	HSU -72 -FLOW	HSU-FT7202628	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136274	C
1,425	HSU -72 -FLOW	HSU-FT7202901	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136275	C
1,426	HSU -72 -FLOW	HSU-FT7202902	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136276	C
1,427	HSU -72 -FLOW	HSU-FT7203001	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136277	C
1,428	HSU -72 -FLOW	HSU-FT7203002	INSP. FIELD INST. (ตัดกุปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	136278	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,429	HSU -72 -FLOW	HSU-FT7203101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136279	C
1,430	HSU -72 -FLOW	HSU-FT7203102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136280	C
1,431	HSU -72 -FLOW	HSU-FT7203201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136281	C
1,432	HSU -72 -FLOW	HSU-FT7203202	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136282	C
1,433	HSU -72 -FLOW	HSU-FT7203401	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y			I										RRC	RRC-IROH	136283	C
1,434	HSU -72 -FLOW	HSU-FT7203401	FT7203401-FULLFUN TEST FLOW TR	PMT	5Y											F		RRC	RRC-IROH	260407	C
1,435	HSU -72 -FLOW	HSU-FT7203402	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136284	C
1,436	HSU -72 -FLOW	HSU-FT7203403	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IROH	136377	C
1,437	HSU -72 -FLOW	HSU-FT7203404	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IROH	136378	C
1,438	HSU -72 -FLOW	HSU-FT7203501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136285	C
1,439	HSU -72 -FLOW	HSU-FT7203502	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y			I										RRC	RRC-IROH	136286	C
1,440	HSU -72 -FLOW	HSU-FT7203502	FT7203502-FULLFUN TEST FLOW TR	PMT	5Y											F		RRC	RRC-IROH	260406	C
1,441	HSU -72 -FLOW	HSU-FT7203601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IROH	136379	C
1,442	HSU -72 -FLOW	HSU-FT7205501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136287	C
1,443	HSU -72 -FLOW	HSU-FT7205601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136288	C
1,444	HSU -72 -FLOW	HSU-FT7205602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136289	C
1,445	HSU -72 -FLOW	HSU-FT7205603	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136290	C
1,446	HSU -72 -FLOW	HSU-FT7205604	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136291	C
1,447	HSU -72 -FLOW	HSU-FT7205605	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136292	C
1,448	HSU -72 -FLOW	HSU-FT7205606	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136293	C
1,449	HSU -72 -FLOW	HSU-FT7205611	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136294	C
1,450	HSU -72 -FLOW	HSU-FT7205615	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136295	C
1,451	HSU -72 -FLOW	HSU-FT7205619	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136296	C
1,452	HSU -72 -FLOW	HSU-FT7205620	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136297	C
1,453	HSU -72 -FLOW	HSU-FT7205622	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136298	C
1,454	HSU -72 -FLOW	HSU-FT7205623	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136299	C
1,455	HSU -72 -FLOW	HSU-FT7205624	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136300	C
1,456	HSU -72 -FLOW	HSU-FT7205626	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136301	C
1,457	HSU -72 -FLOW	HSU-FT7205627	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136302	C
1,458	HSU -72 -FLOW	HSU-FT7205628	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136303	C
1,459	HSU -72 -FLOW	HSU-FT7205901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136304	C
1,460	HSU -72 -FLOW	HSU-FT7205902	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136305	C
1,461	HSU -72 -FLOW	HSU-FT7206001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136306	C
1,462	HSU -72 -FLOW	HSU-FT7206002	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136307	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,463	HSU -72 -FLOW	HSU-FT7206101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136308	C
1,464	HSU -72 -FLOW	HSU-FT7206102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136309	C
1,465	HSU -72 -FLOW	HSU-FT7206201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136310	C
1,466	HSU -72 -FLOW	HSU-FT7206202	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136311	C
1,467	HSU -72 -FLOW	HSU-FT7207501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136312	C
1,468	HSU -72 -FLOW	HSU-FT7207601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136313	C
1,469	HSU -72 -FLOW	HSU-FT7207602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136314	C
1,470	HSU -72 -FLOW	HSU-FT7207603	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136315	C
1,471	HSU -72 -FLOW	HSU-FT7207604	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136316	C
1,472	HSU -72 -FLOW	HSU-FT7207605	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136317	C
1,473	HSU -72 -FLOW	HSU-FT7207606	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136318	C
1,474	HSU -72 -FLOW	HSU-FT7207611	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136319	C
1,475	HSU -72 -FLOW	HSU-FT7207615	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136320	C
1,476	HSU -72 -FLOW	HSU-FT7207619	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136321	C
1,477	HSU -72 -FLOW	HSU-FT7207620	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136322	C
1,478	HSU -72 -FLOW	HSU-FT7207622	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136323	C
1,479	HSU -72 -FLOW	HSU-FT7207623	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136324	C
1,480	HSU -72 -FLOW	HSU-FT7207624	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136325	C
1,481	HSU -72 -FLOW	HSU-FT7207626	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136326	C
1,482	HSU -72 -FLOW	HSU-FT7207627	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136327	C
1,483	HSU -72 -FLOW	HSU-FT7207628	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136328	C
1,484	HSU -72 -FLOW	HSU-FT7207901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136329	C
1,485	HSU -72 -FLOW	HSU-FT7207902	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136330	C
1,486	HSU -72 -FLOW	HSU-FT7208001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136331	C
1,487	HSU -72 -FLOW	HSU-FT7208002	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136332	C
1,488	HSU -72 -FLOW	HSU-FT7208101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136333	C
1,489	HSU -72 -FLOW	HSU-FT7208102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136334	C
1,490	HSU -72 -FLOW	HSU-FT7208201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136335	C
1,491	HSU -72 -FLOW	HSU-FT7208202	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136336	C
1,492	HSU -72 -FLOW	HSU-FT7230101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136337	C
1,493	HSU -72 -FLOW	HSU-FT7230102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136338	C
1,494	HSU -72 -FLOW	HSU-FT7231101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136339	C
1,495	HSU -72 -FLOW	HSU-FT7231301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136340	C
1,496	HSU -72 -FLOW	HSU-FT7231401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136341	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,497	HSU -72 -FLOW	HSU-FT7232101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136342	C
1,498	HSU -72 -FLOW	HSU-FT7232102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136343	C
1,499	HSU -72 -FLOW	HSU-FT7232103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136344	C
1,500	HSU -72 -FLOW	HSU-FT7232104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136345	C
1,501	HSU -72 -FLOW	HSU-FT7233101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136346	C
1,502	HSU -72 -FLOW	HSU-FT7234101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136347	C
1,503	HSU -72 -FLOW	HSU-FT7234102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136348	C
1,504	HSU -72 -FLOW	HSU-FT7235101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136349	C
1,505	HSU -72 -FLOW	HSU-FT7235103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136350	C
1,506	HSU -72 -FLOW	HSU-FT7236101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136351	C
1,507	HSU -72 -FLOW	HSU-FT7237102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136352	C
1,508	HSU -51 -FLOW	HSU-FT7252101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	136162	C
1,509	HSU -73 -FLOW	HSU-FT7300101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136353	C
1,510	HSU -73 -FLOW	HSU-FT7300201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136354	C
1,511	HSU -73 -FLOW	HSU-FT7300301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136355	C
1,512	HSU -73 -FLOW	HSU-FT7300401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136356	C
1,513	HSU -73 -FLOW	HSU-FT7300501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136380	C
1,514	HSU -73 -FLOW	HSU-FT7300502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136357	C
1,515	HSU -73 -FLOW	HSU-FT7300602	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y			I										RRC	RRC-IROH	136358	C
1,516	HSU -73 -FLOW	HSU-FT7300602	FT7300602-FULLFUN TEST FLOW TR	PMT	5Y											F		RRC	RRC-IROH	260408	C
1,517	HSU -73 -FLOW	HSU-FT7300603	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136359	C
1,518	HSU -73 -FLOW	HSU-FT7300701	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136360	C
1,519	HSU -73 -FLOW	HSU-FT7300801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136361	C
1,520	HSU -73 -FLOW	HSU-FT7300901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136362	C
1,521	HSU -73 -FLOW	HSU-FT7301202	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136363	C
1,522	HSU -73 -FLOW	HSU-FT7301203	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136364	C
1,523	HSU -73 -FLOW	HSU-FT7301204	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136365	C
1,524	HSU -73 -FLOW	HSU-FT7301206	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136366	C
1,525	HSU -73 -FLOW	HSU-FT7301207	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136367	C
1,526	HSU -73 -FLOW	HSU-FT7301209	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136381	C
1,527	HSU -73 -FLOW	HSU-FT7301501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136382	C
1,528	HSU -73 -FLOW	HSU-FT7301502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136368	C
1,529	HSU -73 -FLOW	HSU-FT7301701	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136369	C
1,530	HSU -73 -FLOW	HSU-FT7301801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136370	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,531	HSU -73 -FLOW	HSU-FT7301802	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136371	C
1,532	HSU -73 -FLOW	HSU-FT7301804	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136383	C
1,533	HSU -73 -FLOW	HSU-FT7302001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136372	C
1,534	HSU -73 -FLOW	HSU-FT7302002	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136373	C
1,535	HSU -73 -FLOW	HSU-FT7302101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136374	C
1,536	HSU -73 -73K402A	HSU-FT7350601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136384	C
1,537	HSU -73 -73K402B	HSU-FT7351101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	136385	C
1,538	HSU -51 -FLOW	HSU-FT7700502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	136163	C
1,539	HSU -51 -CV	HSU-FV5101001	INSPECT CONTROL VALVE NO. FV51	PMT	1Y										I			RRC	RRC-IROH	137034	C
1,540	HSU -51 -CV	HSU-FV5101003	INSPECT CONTROL VALVE NO. FV51	PMT	1Y										I			RRC	RRC-IROH	137035	C
1,541	HSU -51 -CV	HSU-FV5101006	INSPECT CONTROL VALVE NO. FV51	PMT	1Y										I			RRC	RRC-IROH	137036	C
1,542	HSU -51 -CV	HSU-FV5101031	INSPECT CONTROL VALVE NO. FV51	PMT	1Y										I			RRC	RRC-IROH	137037	C
1,543	HSU -51 -CV	HSU-FV5101801	INSPECT CONTROL VALVE NO. FV51	PMT	1Y										I			RRC	RRC-IROH	137038	C
1,544	HSU -51 -CV	HSU-FV5101802	INSPECT CONTROL VALVE NO. FV51	PMT	1Y										I			RRC	RRC-IROH	137039	C
1,545	HSU -51 -CV	HSU-FV5101803	INSPECT CONTROL VALVE NO. FV51	PMT	1Y										I			RRC	RRC-IROH	137040	C
1,546	HSU -51 -51X001	HSU-FV5101901	INSPECT CONTROL VALVE NO. FV51	PMT	1Y												I	RRC	RRC-IROH	137380	C
1,547	HSU -51 -51X001	HSU-FV5101901	OVERHAUL CONTROL VALVE NO.FV5101901	PMT	2Y				H									RRC	RRC-IROH	152200	C
1,548	HSU -51 -CV	HSU-FV5102301	INSPECT CONTROL VALVE NO. FV51	PMT	1Y										I			RRC	RRC-IROH	137041	C
1,549	HSU -51 -CV	HSU-FV5102403	INSPECT CONTROL VALVE NO. FV51	PMT	1Y										I			RRC	RRC-IROH	137042	C
1,550	HSU -51 -CV	HSU-FV5102601	INSPECT CONTROL VALVE NO. FV51	PMT	1Y										I			RRC	RRC-IROH	137043	C
1,551	HSU -51 -CV	HSU-FV5150601	INSPECT CONTROL VALVE NO. FV51	PMT	1Y										I			RRC	RRC-IROH	137044	C
1,552	HSU -51 -CV	HSU-FV5150604	INSPECT CONTROL VALVE NO. FV51	PMT	1Y										I			RRC	RRC-IROH	137045	C
1,553	HSU -51 -CV	HSU-FV5150605	INSPECT CONTROL VALVE NO. FV51	PMT	1Y										I			RRC	RRC-IROH	137046	C
1,554	HSU -51 -CV	HSU-FV5150801	INSPECT CONTROL VALVE NO. FV51	PMT	1Y										I			RRC	RRC-IROH	137047	C
1,555	HSU -70 -CV	HSU-FV7000101	INSPECT CONTROL VALVE NO. FV70	PMT	1Y										I			RRC	RRC-IROH	137048	C
1,556	HSU -70 -CV	HSU-FV7000301	INSPECT CONTROL VALVE NO. FV70	PMT	1Y										I			RRC	RRC-IROH	137049	C
1,557	HSU -70 -CV	HSU-FV7000302	INSPECT CONTROL VALVE NO. FV70	PMT	1Y										I			RRC	RRC-IROH	137050	C
1,558	HSU -70 -CV	HSU-FV7000303	INSPECT CONTROL VALVE NO. FV70	PMT	1Y										I			RRC	RRC-IROH	137051	C
1,559	HSU -70 -CV	HSU-FV7000304	INSPECT CONTROL VALVE NO. FV70	PMT	1Y										I			RRC	RRC-IROH	137052	C
1,560	HSU -70 -CV	HSU-FV7000401	INSPECT CONTROL VALVE NO. FV70	PMT	1Y										I			RRC	RRC-IROH	137053	C
1,561	HSU -71 -CV	HSU-FV7100101	INSPECT CONTROL VALVE NO. FV71	PMT	1Y										I			RRC	RRC-IROH	137054	C
1,562	HSU -71 -CV	HSU-FV7100201	INSPECT CONTROL VALVE NO. FV71	PMT	1Y										I			RRC	RRC-IROH	137055	C
1,563	HSU -71 -CV	HSU-FV7100301	INSPECT CONTROL VALVE NO. FV71	PMT	1Y										I			RRC	RRC-IROH	137056	C
1,564	HSU -71 -CV	HSU-FV7100302	INSPECT CONTROL VALVE NO. FV71	PMT	1Y										I			RRC	RRC-IROH	137057	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,565	HSU -71 -CV	HSU-FV7100401	INSPECT CONTROL VALVE NO. FV71	PMT	1Y									I				RRC	RRC-IRCH	137058	C
1,566	HSU -71 -CV	HSU-FV7100402	INSPECT CONTROL VALVE NO. FV71	PMT	1Y									I				RRC	RRC-IRCH	137059	C
1,567	HSU -71 -CV	HSU-FV7100601	INSPECT CONTROL VALVE NO. FV71	PMT	1Y									I				RRC	RRC-IRCH	137060	C
1,568	HSU -71 -CV	HSU-FV7100701	INSPECT CONTROL VALVE NO. FV71	PMT	1Y									I				RRC	RRC-IRCH	137061	C
1,569	HSU -72 -CV	HSU-FV7202101	INSPECT CONTROL VALVE NO. FV72	PMT	1Y									I				RRC	RRC-IRCH	137062	C
1,570	HSU -72 -CV	HSU-FV7202103	INSPECT CONTROL VALVE NO. FV72	PMT	1Y									I				RRC	RRC-IRCH	137063	C
1,571	HSU -72 -CV	HSU-FV7202603	INSPECT CONTROL VALVE NO. FV72	PMT	1Y									I				RRC	RRC-IRCH	137064	C
1,572	HSU -72 -CV	HSU-FV7202604	INSPECT CONTROL VALVE NO. FV72	PMT	1Y									I				RRC	RRC-IRCH	137065	C
1,573	HSU -72 -CV	HSU-FV7202606	INSPECT CONTROL VALVE NO. FV72	PMT	1Y									I				RRC	RRC-IRCH	137066	C
1,574	HSU -72 -CV	HSU-FV7202615	INSPECT CONTROL VALVE NO. FV72	PMT	1Y									I				RRC	RRC-IRCH	137067	C
1,575	HSU -72 -CV	HSU-FV7202619	INSPECT CONTROL VALVE NO. FV72	PMT	1Y									I				RRC	RRC-IRCH	137068	C
1,576	HSU -72 -CV	HSU-FV7202622	INSPECT CONTROL VALVE NO. FV72	PMT	1Y									I				RRC	RRC-IRCH	137069	C
1,577	HSU -72 -CV	HSU-FV7202628	INSPECT CONTROL VALVE NO. FV72	PMT	1Y									I				RRC	RRC-IRCH	137070	C
1,578	HSU -72 -CV	HSU-FV7202902	INSPECT CONTROL VALVE NO. FV72	PMT	1Y									I				RRC	RRC-IRCH	137071	C
1,579	HSU -72 -CV	HSU-FV7203101	INSPECT CONTROL VALVE NO. FV72	PMT	1Y									I				RRC	RRC-IRCH	137072	C
1,580	HSU -72 -CV	HSU-FV7203102	INSPECT CONTROL VALVE NO. FV72	PMT	1Y									I				RRC	RRC-IRCH	137073	C
1,581	HSU -72 -CV	HSU-FV7203403	INSPECT CONTROL VALVE NO. FV72	PMT	1Y									I				RRC	RRC-IRCH	137074	C
1,582	HSU -72 -CV	HSU-FV7203501	INSPECT CONTROL VALVE NO. FV72	PMT	1Y									I				RRC	RRC-IRCH	137075	C
1,583	HSU -72 -CV	HSU-FV7205603	INSPECT CONTROL VALVE NO. FV72	PMT	1Y									I				RRC	RRC-IRCH	137076	C
1,584	HSU -72 -CV	HSU-FV7205604	INSPECT CONTROL VALVE NO. FV72	PMT	1Y										I			RRC	RRC-IRCH	137077	C
1,585	HSU -72 -CV	HSU-FV7205606	INSPECT CONTROL VALVE NO. FV72	PMT	1Y										I			RRC	RRC-IRCH	137078	C
1,586	HSU -72 -CV	HSU-FV7205615	INSPECT CONTROL VALVE NO. FV72	PMT	1Y										I			RRC	RRC-IRCH	137079	C
1,587	HSU -72 -CV	HSU-FV7205619	INSPECT CONTROL VALVE NO. FV72	PMT	1Y										I			RRC	RRC-IRCH	137080	C
1,588	HSU -72 -CV	HSU-FV7205622	INSPECT CONTROL VALVE NO. FV72	PMT	1Y										I			RRC	RRC-IRCH	137081	C
1,589	HSU -72 -CV	HSU-FV7205628	INSPECT CONTROL VALVE NO. FV72	PMT	1Y										I			RRC	RRC-IRCH	137082	C
1,590	HSU -72 -CV	HSU-FV7205902	INSPECT CONTROL VALVE NO. FV72	PMT	1Y										I			RRC	RRC-IRCH	137083	C
1,591	HSU -72 -CV	HSU-FV7206101	INSPECT CONTROL VALVE NO. FV72	PMT	1Y										I			RRC	RRC-IRCH	137084	C
1,592	HSU -72 -CV	HSU-FV7206102	INSPECT CONTROL VALVE NO. FV72	PMT	1Y										I			RRC	RRC-IRCH	137085	C
1,593	HSU -72 -CV	HSU-FV7207603	INSPECT CONTROL VALVE NO. FV72	PMT	1Y										I			RRC	RRC-IRCH	137086	C
1,594	HSU -72 -CV	HSU-FV7207604	INSPECT CONTROL VALVE NO. FV72	PMT	1Y										I			RRC	RRC-IRCH	137087	C
1,595	HSU -72 -CV	HSU-FV7207606	INSPECT CONTROL VALVE NO. FV72	PMT	1Y										I			RRC	RRC-IRCH	137088	C
1,596	HSU -72 -CV	HSU-FV7207615	INSPECT CONTROL VALVE NO. FV72	PMT	1Y										I			RRC	RRC-IRCH	137089	C
1,597	HSU -72 -CV	HSU-FV7207619	INSPECT CONTROL VALVE NO. FV72	PMT	1Y										I			RRC	RRC-IRCH	137090	C
1,598	HSU -72 -CV	HSU-FV7207622	INSPECT CONTROL VALVE NO. FV72	PMT	1Y										I			RRC	RRC-IRCH	137091	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,599	HSU -72 -CV	HSU-FV7207628	INSPECT CONTROL VALVE NO. FV72	PMT	1Y										I			RRC	RRC-IRCH	137092	C
1,600	HSU -72 -CV	HSU-FV7207902	INSPECT CONTROL VALVE NO. FV72	PMT	1Y										I			RRC	RRC-IRCH	137093	C
1,601	HSU -72 -CV	HSU-FV7208101	INSPECT CONTROL VALVE NO. FV72	PMT	1Y										I			RRC	RRC-IRCH	137094	C
1,602	HSU -72 -CV	HSU-FV7208102	INSPECT CONTROL VALVE NO. FV72	PMT	1Y										I			RRC	RRC-IRCH	137095	C
1,603	HSU -72 -CV	HSU-FV7232101	INSPECT CONTROL VALVE NO. FV72	PMT	1Y										I			RRC	RRC-IRCH	137096	C
1,604	HSU -73 -CV	HSU-FV7300301	INSPECT CONTROL VALVE NO. FV73	PMT	1Y										I			RRC	RRC-IRCH	137097	C
1,605	HSU -73 -CV	HSU-FV7300401	INSPECT CONTROL VALVE NO. FV73	PMT	1Y										I			RRC	RRC-IRCH	137098	C
1,606	HSU -73 -CV	HSU-FV7300603	INSPECT CONTROL VALVE NO. FV73	PMT	1Y										I			RRC	RRC-IRCH	137099	C
1,607	HSU -73 -CV	HSU-FV7300701	INSPECT CONTROL VALVE NO. FV73	PMT	1Y										I			RRC	RRC-IRCH	137100	C
1,608	HSU -73 -CV	HSU-FV7300801	INSPECT CONTROL VALVE NO. FV73	PMT	1Y										I			RRC	RRC-IRCH	137101	C
1,609	HSU -73 -CV	HSU-FV7300901	INSPECT CONTROL VALVE NO. FV73	PMT	1Y										I			RRC	RRC-IRCH	137102	C
1,610	HSU -73 -CV	HSU-FV7301202	INSPECT CONTROL VALVE NO. FV73	PMT	1Y										I			RRC	RRC-IRCH	137103	C
1,611	HSU -73 -CV	HSU-FV7301203	INSPECT CONTROL VALVE NO. FV73	PMT	1Y										I			RRC	RRC-IRCH	137104	C
1,612	HSU -73 -CV	HSU-FV7301204	INSPECT CONTROL VALVE NO. FV73	PMT	1Y										I			RRC	RRC-IRCH	137105	C
1,613	HSU -73 -CV	HSU-FV7301501	INSPECT CONTROL VALVE NO. FV73	PMT	1Y										I			RRC	RRC-IRCH	137106	C
1,614	HSU -73 -CV	HSU-FV7301701	INSPECT CONTROL VALVE NO. FV73	PMT	1Y										I			RRC	RRC-IRCH	137107	C
1,615	HSU -73 -CV	HSU-FV7301801	INSPECT CONTROL VALVE NO. FV73	PMT	1Y										I			RRC	RRC-IRCH	137108	C
1,616	HSU -73 -CV	HSU-FV7301804	INSPECT CONTROL VALVE NO. FV73	PMT	1Y										I			RRC	RRC-IRCH	137109	C
1,617	HSU -73 -CV	HSU-FV7302001	INSPECT CONTROL VALVE NO. FV73	PMT	1Y										I			RRC	RRC-IRCH	137110	C
1,618	HSU -73 -CV	HSU-FV7302002	INSPECT CONTROL VALVE NO. FV73	PMT	1Y										I			RRC	RRC-IRCH	137111	C
1,619	HSU -51 -QMI_GD	HSU-GDT5100101	VERIFY CORROSION CC5700601	PMT	1Y											V		CAN	CAN-QUHV	140764	C
1,620	HSU -51 -QMI_GD	HSU-GDT5100102	VERIFY GAS_DETECTOR GDT5100102	PMT	4M					V						V		CAN	CAN-QUHV	140894	C
1,621	HSU -51 -QMI_GD	HSU-GDT5100103	VERIFY GAS_DETECTOR GDT5100103	PMT	4M					V						V		CAN	CAN-QUHV	140895	C
1,622	HSU -51 -QMI_GD	HSU-GDT5100104	VERIFY GAS_DETECTOR GDT5100104	PMT	4M					V						V		CAN	CAN-QUHV	140896	C
1,623	HSU -51 -QMI_GD	HSU-GDT5100105	VERIFY GAS_DETECTOR GDT5100105	PMT	4M					V						V		CAN	CAN-QUHV	140897	C
1,624	HSU -51 -QMI_GD	HSU-GDT5100106	VERIFY GAS_DETECTOR GDT5100106	PMT	4M					V						V		CAN	CAN-QUHV	140898	C
1,625	HSU -51 -QMI_GD	HSU-GDT5100107	VERIFY GAS_DETECTOR GDT5100107	PMT	4M					V						V		CAN	CAN-QUHV	140899	C
1,626	HSU -51 -QMI_GD	HSU-GDT5100108	VERIFY GAS_DETECTOR GDT5100108	PMT	4M					V						V		CAN	CAN-QUHV	140900	C
1,627	HSU -51 -QMI_GD	HSU-GDT5100109	VERIFY GAS_DETECTOR GDT5100109	PMT	4M					V						V		CAN	CAN-QUHV	140901	C
1,628	HSU -51 -QMI_GD	HSU-GDT5100110	VERIFY GAS_DETECTOR GDT5100110	PMT	4M					V						V		CAN	CAN-QUHV	140902	C
1,629	HSU -51 -QMI_GD	HSU-GDT5100111	VERIFY GAS_DETECTOR GDT5100111	PMT	4M					V						V		CAN	CAN-QUHV	140903	C
1,630	HSU -51 -QMI_GD	HSU-GDT5100112	VERIFY GAS_DETECTOR GDT5100112	PMT	4M					V						V		CAN	CAN-QUHV	140904	C
1,631	HSU -51 -QMI_GD	HSU-GDT5100113	VERIFY GAS_DETECTOR GDT5100113	PMT	4M					V						V		CAN	CAN-QUHV	140905	C
1,632	HSU -51 -QMI_GD	HSU-GDT5100114	VERIFY GAS_DETECTOR GDT5100114	PMT	4M					V						V		CAN	CAN-QUHV	140906	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,633	HSU -51 -QMI_GD	HSU-GDT5100115	VERIFY GAS_DETECTOR GDT5100115	PMT	4M			V				V				V		CAN	CAN-QUHV	140907	C
1,634	HSU -51 -QMI_GD	HSU-GDT5100116	VERIFY GAS_DETECTOR GDT5100116	PMT	4M			V				V				V		CAN	CAN-QUHV	140908	C
1,635	HSU -51 -QMI_GD	HSU-GDT5100117	VERIFY GAS_DETECTOR GDT5100117	PMT	4M			V				V				V		CAN	CAN-QUHV	140909	C
1,636	HSU -51 -QMI_GD	HSU-GDT5100118	VERIFY GAS_DETECTOR GDT5100118	PMT	4M			V				V				V		CAN	CAN-QUHV	140910	C
1,637	HSU -51 -QMI_GD	HSU-GDT5100119	VERIFY GAS_DETECTOR GDT5100119	PMT	4M			V				V				V		CAN	CAN-QUHV	140911	C
1,638	HSU -51 -QMI_GD	HSU-GDT5100120	VERIFY GAS_DETECTOR GDT5100120	PMT	4M			V				V				V		CAN	CAN-QUHV	140912	C
1,639	HSU -51 -QMI_GD	HSU-GDT5100121	VERIFY GAS_DETECTOR GDT5100121	PMT	4M			V				V				V		CAN	CAN-QUHV	140913	C
1,640	HSU -51 -QMI_GD	HSU-GDT5100122	VERIFY GAS_DETECTOR GDT5100122	PMT	4M			V				V				V		CAN	CAN-QUHV	140914	C
1,641	HSU -51 -QMI_GD	HSU-GDT5100123	VERIFY GAS_DETECTOR GDT5100123	PMT	4M			V				V				V		CAN	CAN-QUHV	140915	C
1,642	HSU -51 -QMI_GD	HSU-GDT5100124	VERIFY GAS_DETECTOR GDT5100124	PMT	4M			V				V				V		CAN	CAN-QUHV	140916	C
1,643	HSU -51 -QMI_GD	HSU-GDT5100125	VERIFY GAS_DETECTOR GDT5100125	PMT	4M			V				V				V		CAN	CAN-QUHV	140917	C
1,644	HSU -51 -QMI_GD	HSU-GDT5100201	VERIFY GAS_DETECTOR GDT5100201	PMT	6M			V						V				CAN	CAN-QUHV	140918	C
1,645	HSU -51 -QMI_GD	HSU-GDT5100202	VERIFY GAS_DETECTOR GDT5100202	PMT	6M			V						V				CAN	CAN-QUHV	140919	C
1,646	HSU -51 -QMI_GD	HSU-GDT5100205	VERIFY GAS_DETECTOR GDT5100205	PMT	6M			V						V				CAN	CAN-QUHV	140920	C
1,647	HSU -51 -QMI_GD	HSU-GDT5100206	VERIFY GAS_DETECTOR GDT5100206	PMT	6M			V						V				CAN	CAN-QUHV	140921	C
1,648	HSU -51 -QMI_GD	HSU-GDT5100207	VERIFY GAS_DETECTOR GDT5100207	PMT	6M			V						V				CAN	CAN-QUHV	140922	C
1,649	HSU -51 -QMI_GD	HSU-GDT5100208	VERIFY GAS_DETECTOR GDT5100208	PMT	6M			V						V				CAN	CAN-QUHV	140923	C
1,650	HSU -51 -QMI_GD	HSU-GDT5100209	VERIFY GAS_DETECTOR GDT5100209	PMT	6M			V						V				CAN	CAN-QUHV	140924	C
1,651	HSU -51 -QMI_GD	HSU-GDT5100210	VERIFY GAS_DETECTOR GDT5100210	PMT	6M			V						V				CAN	CAN-QUHV	140925	C
1,652	HSU -51 -QMI_GD	HSU-GDT5100211	VERIFY GAS_DETECTOR GDT5100211	PMT	6M			V						V				CAN	CAN-QUHV	140926	C
1,653	HSU -51 -QMI_GD	HSU-GDT5100212	VERIFY GAS_DETECTOR GDT5100212	PMT	6M			V						V				CAN	CAN-QUHV	140927	C
1,654	HSU -51 -QMI_GD	HSU-GDT5100214	VERIFY GAS_DETECTOR GDT5100214	PMT	6M			V						V				CAN	CAN-QUHV	140928	C
1,655	HSU -51 -QMI_GD	HSU-GDT5100215	VERIFY GAS_DETECTOR GDT5100215	PMT	6M			V						V				CAN	CAN-QUHV	140929	C
1,656	HSU -51 -QMI_GD	HSU-GDT5100601	VERIFY GAS_DETECTOR GDT5100601	PMT	1Y							V						CAN	CAN-QUHV	140930	C
1,657	HSU -51 -QMI_GD	HSU-GDT5100602	VERIFY GAS_DETECTOR GDT5100602	PMT	1Y							V						CAN	CAN-QUHV	140931	C
1,658	HSU -70 -QMI_GD	HSU-GDT7000301	VERIFY GAS_DETECTOR GDT7000301	PMT	4M				V				V				V	CAN	CAN-QUHV	140727	C
1,659	HSU -70 -QMI_GD	HSU-GDT7000302	VERIFY GAS_DETECTOR GDT7000302	PMT	4M				V				V				V	CAN	CAN-QUHV	140728	C
1,660	HSU -70 -QMI_GD	HSU-GDT7000303	VERIFY GAS_DETECTOR GDT7000303	PMT	4M				V				V				V	CAN	CAN-QUHV	140729	C
1,661	HSU -70 -QMI_GD	HSU-GDT7000304	VERIFY GAS_DETECTOR GDT7000304	PMT	4M				V				V				V	CAN	CAN-QUHV	140730	C
1,662	HSU -70 -QMI_GD	HSU-GDT7000305	VERIFY GAS_DETECTOR GDT7000305	PMT	4M				V				V				V	CAN	CAN-QUHV	140731	C
1,663	HSU -70 -QMI_GD	HSU-GDT7000306	VERIFY GAS_DETECTOR GDT7000306	PMT	4M				V				V				V	CAN	CAN-QUHV	140732	C
1,664	HSU -70 -QMI_GD	HSU-GDT7000307	VERIFY GAS_DETECTOR GDT7000307	PMT	4M				V				V				V	CAN	CAN-QUHV	140733	C
1,665	HSU -70 -QMI_GD	HSU-GDT7000308	VERIFY GAS_DETECTOR GDT7000308	PMT	4M				V				V				V	CAN	CAN-QUHV	140734	C
1,666	HSU -70 -QMI_GD	HSU-GDT7000309	VERIFY GAS_DETECTOR GDT7000309	PMT	4M				V				V				V	CAN	CAN-QUHV	140735	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,667	HSU -70 -QMI_GD	HSU-GDT7000310	VERIFY GAS_DETECTOR GDT7000310	PMT	4M				V				V				V	CAN	CAN-QUHV	140736	C
1,668	HSU -70 -QMI_GD	HSU-GDT7000311	VERIFY GAS_DETECTOR GDT7000311	PMT	4M				V				V				V	CAN	CAN-QUHV	140737	C
1,669	HSU -70 -QMI_GD	HSU-GDT7000312	VERIFY GAS_DETECTOR GDT7000312	PMT	4M				V				V				V	CAN	CAN-QUHV	140738	C
1,670	HSU -70 -QMI_GD	HSU-GDT7000313	VERIFY GAS_DETECTOR GDT7000313	PMT	4M				V				V				V	CAN	CAN-QUHV	140739	C
1,671	HSU -71 -QMI_GD	HSU-GDT7100301	VERIFY GAS_DETECTOR GDT7100301	PMT	4M				V				V				V	CAN	CAN-QUHV	140718	C
1,672	HSU -71 -QMI_GD	HSU-GDT7100302	VERIFY GAS_DETECTOR GDT7100302	PMT	4M				V				V				V	CAN	CAN-QUHV	140719	C
1,673	HSU -71 -QMI_GD	HSU-GDT7100303	VERIFY GAS_DETECTOR GDT7100303	PMT	4M				V				V				V	CAN	CAN-QUHV	140720	C
1,674	HSU -71 -QMI_GD	HSU-GDT7100304	VERIFY GAS_DETECTOR GDT7100304	PMT	4M				V				V				V	CAN	CAN-QUHV	140721	C
1,675	HSU -71 -QMI_GD	HSU-GDT7100305	VERIFY GAS_DETECTOR GDT7100305	PMT	4M				V				V				V	CAN	CAN-QUHV	140722	C
1,676	HSU -71 -QMI_GD	HSU-GDT7100306	VERIFY GAS_DETECTOR GDT7100306	PMT	4M				V				V				V	CAN	CAN-QUHV	140723	C
1,677	HSU -71 -QMI_GD	HSU-GDT7100307	VERIFY GAS_DETECTOR GDT7100307	PMT	4M				V				V				V	CAN	CAN-QUHV	140724	C
1,678	HSU -71 -QMI_GD	HSU-GDT7100308	VERIFY GAS_DETECTOR GDT7100308	PMT	4M				V				V				V	CAN	CAN-QUHV	140725	C
1,679	HSU -71 -QMI_GD	HSU-GDT7100309	VERIFY GAS_DETECTOR GDT7100309	PMT	4M				V				V				V	CAN	CAN-QUHV	140726	C
1,680	HSU -72 -QMI_GD	HSU-GDT7200301	VERIFY GAS_DETECTOR GDT7200301	PMT	4M				V				V				V	CAN	CAN-QUHV	140684	C
1,681	HSU -72 -QMI_GD	HSU-GDT7200302	VERIFY GAS_DETECTOR GDT7200302	PMT	4M				V				V				V	CAN	CAN-QUHV	140685	C
1,682	HSU -72 -QMI_GD	HSU-GDT7200303	VERIFY GAS_DETECTOR GDT7200303	PMT	4M				V				V				V	CAN	CAN-QUHV	140686	C
1,683	HSU -72 -QMI_GD	HSU-GDT7200304	VERIFY GAS_DETECTOR GDT7200304	PMT	4M				V				V				V	CAN	CAN-QUHV	140687	C
1,684	HSU -72 -QMI_GD	HSU-GDT7200305	VERIFY GAS_DETECTOR GDT7200305	PMT	4M				V				V				V	CAN	CAN-QUHV	140688	C
1,685	HSU -72 -QMI_GD	HSU-GDT7200306	VERIFY GAS_DETECTOR GDT7200306	PMT	4M				V				V				V	CAN	CAN-QUHV	140689	C
1,686	HSU -72 -QMI_GD	HSU-GDT7200307	VERIFY GAS_DETECTOR GDT7200307	PMT	4M				V				V				V	CAN	CAN-QUHV	140690	C
1,687	HSU -72 -QMI_GD	HSU-GDT7200308	VERIFY GAS_DETECTOR GDT7200308	PMT	4M				V				V				V	CAN	CAN-QUHV	140691	C
1,688	HSU -72 -QMI_GD	HSU-GDT7200309	VERIFY GAS_DETECTOR GDT7200309	PMT	4M				V				V				V	CAN	CAN-QUHV	140692	C
1,689	HSU -72 -QMI_GD	HSU-GDT7200310	VERIFY GAS_DETECTOR GDT7200310	PMT	4M				V				V				V	CAN	CAN-QUHV	140693	C
1,690	HSU -72 -QMI_GD	HSU-GDT7200311	VERIFY GAS_DETECTOR GDT7200311	PMT	4M				V				V				V	CAN	CAN-QUHV	140694	C
1,691	HSU -72 -QMI_GD	HSU-GDT7200312	VERIFY GAS_DETECTOR GDT7200312	PMT	4M				V				V				V	CAN	CAN-QUHV	140695	C
1,692	HSU -72 -QMI_GD	HSU-GDT7200313	VERIFY GAS_DETECTOR GDT7200313	PMT	4M				V				V				V	CAN	CAN-QUHV	140696	C
1,693	HSU -72 -QMI_GD	HSU-GDT7200314	VERIFY GAS_DETECTOR GDT7200314	PMT	4M				V				V				V	CAN	CAN-QUHV	140697	C
1,694	HSU -72 -QMI_GD	HSU-GDT7200315	VERIFY GAS_DETECTOR GDT7200315	PMT	4M				V				V				V	CAN	CAN-QUHV	140698	C
1,695	HSU -72 -QMI_GD	HSU-GDT7200317	VERIFY GAS_DETECTOR GDT7200317	PMT	4M				V				V				V	CAN	CAN-QUHV	140699	C
1,696	HSU -72 -QMI_GD	HSU-GDT7200318	VERIFY GAS_DETECTOR GDT7200318	PMT	4M				V				V				V	CAN	CAN-QUHV	140700	C
1,697	HSU -72 -QMI_GD	HSU-GDT7200320	VERIFY GAS_DETECTOR GDT7200320	PMT	4M				V				V				V	CAN	CAN-QUHV	140701	C
1,698	HSU -72 -QMI_GD	HSU-GDT7200321	VERIFY GAS_DETECTOR GDT7200321	PMT	4M				V				V				V	CAN	CAN-QUHV	140702	C
1,699	HSU -72 -QMI_GD	HSU-GDT7200322	VERIFY GAS_DETECTOR GDT7200322	PMT	4M				V				V				V	CAN	CAN-QUHV	140703	C
1,700	HSU -72 -QMI_GD	HSU-GDT7200323	VERIFY GAS_DETECTOR GDT7200323	PMT	4M				V				V				V	CAN	CAN-QUHV	140704	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,701	HSU -72 -QMI_GD	HSU-GDT7200324	VERIFY GAS_DETECTOR GDT7200324	PMT	4M				V				V				V	CAN	CAN-QUHV	140705	C
1,702	HSU -72 -QMI_GD	HSU-GDT7200325	VERIFY GAS_DETECTOR GDT7200325	PMT	4M				V				V				V	CAN	CAN-QUHV	140706	C
1,703	HSU -72 -QMI_GD	HSU-GDT7200327	VERIFY GAS_DETECTOR GDT7200327	PMT	4M				V				V				V	CAN	CAN-QUHV	140707	C
1,704	HSU -72 -QMI_GD	HSU-GDT7200328	VERIFY GAS_DETECTOR GDT7200328	PMT	4M				V				V				V	CAN	CAN-QUHV	140708	C
1,705	HSU -72 -QMI_GD	HSU-GDT7200329	VERIFY GAS_DETECTOR GDT7200329	PMT	4M				V				V				V	CAN	CAN-QUHV	140709	C
1,706	HSU -73 -QMI_GD	HSU-GDT7300101	VERIFY GAS_DETECTOR GDT7300101	PMT	6M				V						V			CAN	CAN-QUHV	140661	C
1,707	HSU -73 -QMI_GD	HSU-GDT7300102	VERIFY GAS_DETECTOR GDT7300102	PMT	6M				V						V			CAN	CAN-QUHV	140662	C
1,708	HSU -73 -QMI_GD	HSU-GDT7300103	VERIFY GAS_DETECTOR GDT7300103	PMT	6M				V						V			CAN	CAN-QUHV	140663	C
1,709	HSU -73 -QMI_GD	HSU-GDT7300104	VERIFY GAS_DETECTOR GDT7300104	PMT	6M				V						V			CAN	CAN-QUHV	140664	C
1,710	HSU -73 -QMI_GD	HSU-GDT7300301	VERIFY GAS_DETECTOR GDT7300301	PMT	4M				V				V				V	CAN	CAN-QUHV	140665	C
1,711	HSU -73 -QMI_GD	HSU-GDT7300302	VERIFY GAS_DETECTOR GDT7300302	PMT	4M				V				V				V	CAN	CAN-QUHV	140666	C
1,712	HSU -73 -QMI_GD	HSU-GDT7300303	VERIFY GAS_DETECTOR GDT7300303	PMT	4M				V				V				V	CAN	CAN-QUHV	140667	C
1,713	HSU -73 -QMI_GD	HSU-GDT7300304	VERIFY GAS_DETECTOR GDT7300304	PMT	4M				V				V				V	CAN	CAN-QUHV	140668	C
1,714	HSU -73 -QMI_GD	HSU-GDT7300305	VERIFY GAS_DETECTOR GDT7300305	PMT	4M				V				V				V	CAN	CAN-QUHV	140669	C
1,715	HSU -73 -QMI_GD	HSU-GDT7300306	VERIFY GAS_DETECTOR GDT7300306	PMT	4M				V				V				V	CAN	CAN-QUHV	140670	C
1,716	HSU -73 -QMI_GD	HSU-GDT7300307	VERIFY GAS_DETECTOR GDT7300307	PMT	4M				V				V				V	CAN	CAN-QUHV	140671	C
1,717	HSU -73 -QMI_GD	HSU-GDT7300308	VERIFY GAS_DETECTOR GDT7300308	PMT	4M				V				V				V	CAN	CAN-QUHV	140672	C
1,718	HSU -73 -QMI_GD	HSU-GDT7300309	VERIFY GAS_DETECTOR GDT7300309	PMT	4M				V				V				V	CAN	CAN-QUHV	140673	C
1,719	HSU -73 -QMI_GD	HSU-GDT7300310	VERIFY GAS_DETECTOR GDT7300310	PMT	4M				V				V				V	CAN	CAN-QUHV	140674	C
1,720	HSU -73 -QMI_GD	HSU-GDT7300311	VERIFY GAS_DETECTOR GDT7300311	PMT	4M				V				V				V	CAN	CAN-QUHV	140675	C
1,721	HSU -73 -QMI_GD	HSU-GDT7300312	VERIFY GAS_DETECTOR GDT7300312	PMT	4M				V				V				V	CAN	CAN-QUHV	140676	C
1,722	HSU -73 -QMI_GD	HSU-GDT7300313	VERIFY GAS_DETECTOR GDT7300313	PMT	4M				V				V				V	CAN	CAN-QUHV	140677	C
1,723	HSU -73 -QMI_GD	HSU-GDT7300314	VERIFY GAS_DETECTOR GDT7300314	PMT	4M				V				V				V	CAN	CAN-QUHV	140678	C
1,724	HSU -73 -QMI_GD	HSU-GDT7300315	VERIFY GAS_DETECTOR GDT7300315	PMT	4M				V				V				V	CAN	CAN-QUHV	140679	C
1,725	HSU -70 -CV	HSU-HV7000101	INSPECT CONTROL VALVE NO. HV70	PMT	1Y										I			RRC	RRC- IROH	137112	C
1,726	HSU -71 -CV	HSU-HV7100101	INSPECT CONTROL VALVE NO. HV71	PMT	1Y										I			RRC	RRC- IROH	137113	C
1,727	HSU -71 -CV	HSU-HV7100701	INSPECT CONTROL VALVE NO. HV71	PMT	1Y										I			RRC	RRC- IROH	137114	C
1,728	HSU -72 -CV	HSU-HV7202001	INSPECT CONTROL VALVE NO. HV72	INS	1Y										I			RRC	RRC- IROH	137115	C
1,729	HSU -72 -CV	HSU-HV7202001	HV7202001-FULL FUNC. TEST CONT	PMT	5Y											F		RRC	RRC- IROH	260360	C
1,730	HSU -72 -CV	HSU-HV7203401	INSPECT CONTROL VALVE NO. HV72	INS	1Y										I			RRC	RRC- IROH	137116	C
1,731	HSU -72 -CV	HSU-HV7203401	HV7203401-FULL FUNC. TEST CONT	PMT	5Y											F		RRC	RRC- IROH	260357	C
1,732	HSU -72 -CV	HSU-HV7203402	INSPECT CONTROL VALVE NO. HV72	PMT	1Y										I			RRC	RRC- IROH	137117	C
1,733	HSU -72 -CV	HSU-HV7203501	INSPECT CONTROL VALVE NO. HV72	PMT	1Y										I			RRC	RRC- IROH	137118	C
1,734	HSU -72 -CV	HSU-HV7203502	INSPECT CONTROL VALVE NO. HV72	PMT	1Y										I			RRC	RRC- IROH	137119	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,735	HSU -72 -CV	HSU-HV7203503	INSPECT CONTROL VALVE NO. HV72	PMT	1Y										I			RRC	RRC- IROH	137120	C
1,736	HSU -72 -CV	HSU-HV7203504	INSPECT CONTROL VALVE NO. HV72	PMT	1Y										I			RRC	RRC- IROH	137121	C
1,737	HSU -73 -CV	HSU-HV7300101	INSPECT CONTROL VALVE NO. HV73	INS	1Y										I			RRC	RRC- IROH	137122	C
1,738	HSU -73 -CV	HSU-HV7300101	HV7300101-FULL FUNC. TEST CONT	PMT	5Y											F		RRC	RRC- IROH	260354	C
1,739	HSU -73 -CV	HSU-HV7300102	INSPECT CONTROL VALVE NO. HV73	INS	1Y										I			RRC	RRC- IROH	137123	C
1,740	HSU -73 -CV	HSU-HV7300102	HV7300102-FULL FUNC. TEST CONT	PMT	5Y											F		RRC	RRC- IROH	260358	C
1,741	HSU -73 -CV	HSU-HV7300103	INSPECT CONTROL VALVE NO. HV73	INS	1Y										I			RRC	RRC- IROH	137124	C
1,742	HSU -73 -CV	HSU-HV7300103	HV7300103-FULL FUNC. TEST CONT	PMT	5Y											F		RRC	RRC- IROH	260359	C
1,743	HSU -73 -CV	HSU-HV7300104	INSPECT CONTROL VALVE NO. HV73	INS	1Y										I			RRC	RRC- IROH	137125	C
1,744	HSU -73 -CV	HSU-HV7300104	HV7300104-FULL FUNC. TEST CONT	PMT	5Y											F		RRC	RRC- IROH	260355	C
1,745	HSU -73 -CV	HSU-HV7300105	INSPECT CONTROL VALVE NO. HV73	INS	1Y										I			RRC	RRC- IROH	137126	C
1,746	HSU -73 -CV	HSU-HV7300105	HV7300105-FULL FUNC. TEST CONT	PMT	5Y											F		RRC	RRC- IROH	260356	C
1,747	HSU -73 -CV	HSU-HV7300106	INSPECT CONTROL VALVE NO. HV73	INS	1Y										I			RRC	RRC- IROH	137127	C
1,748	HSU -73 -CV	HSU-HV7300106	HV7300106-FULL FUNC. TEST CONT	PMT	5Y											F		RRC	RRC- IROH	261511	C
1,749	HSU -73 -CV	HSU-HV7300601	INSPECT CONTROL VALVE NO. HV73	INS	1Y										I			RRC	RRC- IROH	137128	C
1,750	HSU -73 -CV	HSU-HV7300601	HV7300601-FULL FUNC TEST CONTR	PMT	5Y											F		RRC	RRC- IROH	260362	C
1,751	HSU -73 -CV	HSU-HV7300801	INSPECT CONTROL VALVE NO. HV73	PMT	1Y										I			RRC	RRC- IROH	137129	C
1,752	HSU -73 -CV	HSU-HV7301401	INSPECT CONTROL VALVE NO. HV73	PMT	1Y										I			RRC	RRC- IROH	137130	C
1,753	HSU -73 -CV	HSU-HV7301402	INSPECT CONTROL VALVE NO. HV73	PMT	1Y										I			RRC	RRC- IROH	137131	C
1,754	HSU -73 -CV	HSU-HV7301403	INSPECT CONTROL VALVE NO. HV73	PMT	1Y										I			RRC	RRC- IROH	137132	C
1,755	HSU -73 -CV	HSU-HV7301801	INSPECT CONTROL VALVE NO. HV73	PMT	1Y										I			RRC	RRC- IROH	137133	C
1,756	HSU -51 -LEVEL	HSU-LT5100901	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y					I								RRC	RRC- IROH	136426	C
1,757	HSU -51 -LEVEL	HSU-LT5100902	INSP. FIELD INST. (ตัดชุมปากน้ำ)	INS	1Y					I								RRC	RRC- IROH	136427	C
1,758	HSU -51 -LEVEL	HSU-LT5100902	LT5100902-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC- IROH	260430	C
1,759	HSU -51 -LEVEL	HSU-LT5100903	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y					I								RRC	RRC- IROH	136428	C
1,760	HSU -51 -LEVEL	HSU-LT5101401	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y					I								RRC	RRC- IROH	136429	C
1,761	HSU -51 -LEVEL	HSU-LT5101701	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y					I								RRC	RRC- IROH	136430	C
1,762	HSU -51 -LEVEL	HSU-LT5101702	INSP. FIELD INST. (ตัดชุมปากน้ำ)	INS	1Y					I								RRC	RRC- IROH	136431	C
1,763	HSU -51 -LEVEL	HSU-LT5101702	LT5101702-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC- IROH	260431	C
1,764	HSU -51 -LEVEL	HSU-LT5101801	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y					I								RRC	RRC- IROH	136432	C
1,765	HSU -51 -LEVEL	HSU-LT5101802	INSP. FIELD INST. (ตัดชุมปากน้ำ)	INS	1Y					I								RRC	RRC- IROH	136433	C
1,766	HSU -51 -LEVEL	HSU-LT5101802	LT5101802-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC- IROH	260432	C
1,767	HSU -51 -LEVEL	HSU-LT5102001	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y					I								RRC	RRC- IROH	136434	C
1,768	HSU -51 -LEVEL	HSU-LT5102002	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y					I								RRC	RRC- IROH	136435	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,769	HSU -51 -LEVEL	HSU-LT5102301	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136436	C
1,770	HSU -51 -LEVEL	HSU-LT5102302	INSP. FIELD INST. (ตัดชุมปากน้ำ)	INS	1Y			I										RRC	RRC- IROH	136437	C
1,771	HSU -51 -LEVEL	HSU-LT5102302	LT5102302-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC- IROH	260434	C
1,772	HSU -51 -LEVEL	HSU-LT5102303	INSP. FIELD INST. (ตัดชุมปากน้ำ)	INS	1Y			I										RRC	RRC- IROH	136438	C
1,773	HSU -51 -LEVEL	HSU-LT5102303	LT5102303-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC- IROH	260435	C
1,774	HSU -51 -LEVEL	HSU-LT5102601	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136439	C
1,775	HSU -51 -LEVEL	HSU-LT5102602	INSP. FIELD INST. (ตัดชุมปากน้ำ)	INS	1Y			I										RRC	RRC- IROH	136440	C
1,776	HSU -51 -LEVEL	HSU-LT5102602	LT5102602-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC- IROH	260433	C
1,777	HSU -51 -LEVEL	HSU-LT5150501A	INSP. FIELD INST. (ตัดชุมปากน้ำ)	INS	1Y			I										RRC	RRC- IROH	136441	C
1,778	HSU -51 -LEVEL	HSU-LT5150501A	LT5150501A-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC- IROH	260436	C
1,779	HSU -51 -LEVEL	HSU-LT5150501B	INSP. FIELD INST. (ตัดชุมปากน้ำ)	INS	1Y			I										RRC	RRC- IROH	136442	C
1,780	HSU -51 -LEVEL	HSU-LT5150501B	LT5150501B-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC- IROH	260437	C
1,781	HSU -51 -LEVEL	HSU-LT5150501C	INSP. FIELD INST. (ตัดชุมปากน้ำ)	INS	1Y			I										RRC	RRC- IROH	136443	C
1,782	HSU -51 -LEVEL	HSU-LT5150501C	LT5150501C-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC- IROH	260438	C
1,783	HSU -51 -LEVEL	HSU-LT5150502	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136444	C
1,784	HSU -51 -51K004A	HSU-LT5151201	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136386	C
1,785	HSU -51 -51K004B	HSU-LT5152101	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136387	C
1,786	HSU -51 -51K005	HSU-LT5153001A	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136388	C
1,787	HSU -51 -51K005	HSU-LT5153001B	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136389	C
1,788	HSU -51 -51K005	HSU-LT5153001C	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136390	C
1,789	HSU -51 -51K005	HSU-LT5153101	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136391	C
1,790	HSU -51 -51X003	HSU-LT5155201	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y				I									RRC	RRC- IROH	136508	C
1,791	HSU -51 -51X003	HSU-LT5155301	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y				I									RRC	RRC- IROH	136509	C
1,792	HSU -70 -LEVEL	HSU-LT7000102	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136396	C
1,793	HSU -70 -LEVEL	HSU-LT7000105	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136445	C
1,794	HSU -70 -LEVEL	HSU-LT7000201	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136397	C
1,795	HSU -70 -LEVEL	HSU-LT7000202	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136398	C
1,796	HSU -70 -LEVEL	HSU-LT7000301	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136446	C
1,797	HSU -70 -LEVEL	HSU-LT7000302	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y				I									RRC	RRC- IROH	136447	C
1,798	HSU -70 -LEVEL	HSU-LT7000306	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y				I									RRC	RRC- IROH	136448	C
1,799	HSU -70 -LEVEL	HSU-LT7000307	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136399	C
1,800	HSU -70 -LEVEL	HSU-LT7000401	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y				I									RRC	RRC- IROH	136449	C
1,801	HSU -70 -LEVEL	HSU-LT7000404	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136400	C
1,802	HSU -70 -LEVEL	HSU-LT7000601	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136401	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,803	HSU -70 -LEVEL	HSU-LT7000702	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136402	C
1,804	HSU -70 -LEVEL	HSU-LT7000801	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136403	C
1,805	HSU -71 -LEVEL	HSU-LT7100101	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136404	C
1,806	HSU -71 -LEVEL	HSU-LT7100105	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136405	C
1,807	HSU -71 -LEVEL	HSU-LT7100106	INSP. FIELD INST. (ตัดชุมปากน้ำ)	INS	1Y					I								RRC	RRC- IROH	136450	C
1,808	HSU -71 -LEVEL	HSU-LT7100106	LT7100106-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC- IROH	260439	C
1,809	HSU -71 -LEVEL	HSU-LT7100107	INSP. FIELD INST. (ตัดชุมปากน้ำ)	INS	1Y					I								RRC	RRC- IROH	136451	C
1,810	HSU -71 -LEVEL	HSU-LT7100107	LT7100107-FULLFUNTEST CAP&COND	PMT	5Y											F		RRC	RRC- IROH	260409	C
1,811	HSU -71 -LEVEL	HSU-LT7100301	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y					I								RRC	RRC- IROH	136452	C
1,812	HSU -71 -LEVEL	HSU-LT7100302	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y					I								RRC	RRC- IROH	136453	C
1,813	HSU -71 -LEVEL	HSU-LT7100305	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y					I								RRC	RRC- IROH	136454	C
1,814	HSU -71 -LEVEL	HSU-LT7100403	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y					I								RRC	RRC- IROH	136455	C
1,815	HSU -71 -LEVEL	HSU-LT7100501	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136406	C
1,816	HSU -71 -LEVEL	HSU-LT7100502	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136407	C
1,817	HSU -71 -LEVEL	HSU-LT7100801	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136408	C
1,818	HSU -71 -LEVEL	HSU-LT7100803	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136409	C
1,819	HSU -71 -LEVEL	HSU-LT7100901	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136410	C
1,820	HSU -71 -71X001	HSU-LT7150201	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y					I								RRC	RRC- IROH	136510	C
1,821	HSU -72 -LEVEL	HSU-LT7202101A	INSP. FIELD INST. (ตัดชุมปากน้ำ)	INS	1Y					I								RRC	RRC- IROH	136456	C
1,822	HSU -72 -LEVEL	HSU-LT7202101A	LT7202101A-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC- IROH	260443	C
1,823	HSU -72 -LEVEL	HSU-LT7202101B	INSP. FIELD INST. (ตัดชุมปากน้ำ)	INS	1Y					I								RRC	RRC- IROH	136457	C
1,824	HSU -72 -LEVEL	HSU-LT7202101B	LT7202101B-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC- IROH	260444	C
1,825	HSU -72 -LEVEL	HSU-LT7202101C	INSP. FIELD INST. (ตัดชุมปากน้ำ)	INS	1Y					I								RRC	RRC- IROH	136458	C
1,826	HSU -72 -LEVEL	HSU-LT7202101C	LT7202101C-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC- IROH	260445	C
1,827	HSU -72 -LEVEL	HSU-LT7202103	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136411	C
1,828	HSU -72 -LEVEL	HSU-LT7202201	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y			I										RRC	RRC- IROH	136412	C
1,829	HSU -72 -LEVEL	HSU-LT7202203A	INSP. FIELD INST. (ตัดชุมปากน้ำ)	INS	1Y					I								RRC	RRC- IROH	136459	C
1,830	HSU -72 -LEVEL	HSU-LT7202203A	LT7202203A-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC- IROH	260446	C
1,831	HSU -72 -LEVEL	HSU-LT7202203B	INSP. FIELD INST. (ตัดชุมปากน้ำ)	INS	1Y					I								RRC	RRC- IROH	136460	C
1,832	HSU -72 -LEVEL	HSU-LT7202203B	LT7202203B-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC- IROH	260447	C
1,833	HSU -72 -LEVEL	HSU-LT7202203C	INSP. FIELD INST. (ตัดชุมปากน้ำ)	INS	1Y					I								RRC	RRC- IROH	136461	C
1,834	HSU -72 -LEVEL	HSU-LT7202203C	LT7202203C-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC- IROH	260448	C
1,835	HSU -72 -LEVEL	HSU-LT7202205	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y					I								RRC	RRC- IROH	136462	C
1,836	HSU -72 -LEVEL	HSU-LT7202901	INSP. FIELD INST. (ตัดชุมปากน้ำ)	PMT	1Y					I								RRC	RRC- IROH	136463	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,837	HSU -72 -LEVEL	HSU-LT7202904A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y				I									RRC	RRC-IROH	136464	C
1,838	HSU -72 -LEVEL	HSU-LT7202904A	LT7202904A-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC-IROH	260440	C
1,839	HSU -72 -LEVEL	HSU-LT7202904B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y				I									RRC	RRC-IROH	136465	C
1,840	HSU -72 -LEVEL	HSU-LT7202904B	LT7202904B-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC-IROH	260441	C
1,841	HSU -72 -LEVEL	HSU-LT7202904C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y				I									RRC	RRC-IROH	136466	C
1,842	HSU -72 -LEVEL	HSU-LT7202904C	LT7202904C-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC-IROH	260442	C
1,843	HSU -72 -LEVEL	HSU-LT7203001	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136467	C
1,844	HSU -72 -LEVEL	HSU-LT7203004	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136468	C
1,845	HSU -72 -LEVEL	HSU-LT7203401	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IROH	136413	C
1,846	HSU -72 -LEVEL	HSU-LT7203402	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IROH	136414	C
1,847	HSU -72 -LEVEL	HSU-LT7203501	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y				I									RRC	RRC-IROH	136469	C
1,848	HSU -72 -LEVEL	HSU-LT7203501	LT7203501-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260450	C
1,849	HSU -72 -LEVEL	HSU-LT7203502	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136470	C
1,850	HSU -72 -LEVEL	HSU-LT7203503	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y				I									RRC	RRC-IROH	136471	C
1,851	HSU -72 -LEVEL	HSU-LT7203503	LT7203503-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260449	C
1,852	HSU -72 -LEVEL	HSU-LT7203601	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IROH	136415	C
1,853	HSU -72 -LEVEL	HSU-LT7203602	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IROH	136416	C
1,854	HSU -72 -72K601	HSU-LT7204001	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136511	C
1,855	HSU -72 -72X603	HSU-LT7204901	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136512	C
1,856	HSU -72 -LEVEL	HSU-LT7205901	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136472	C
1,857	HSU -72 -LEVEL	HSU-LT7205904A	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136473	C
1,858	HSU -72 -LEVEL	HSU-LT7205904B	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136474	C
1,859	HSU -72 -LEVEL	HSU-LT7205904C	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136475	C
1,860	HSU -72 -LEVEL	HSU-LT7206001	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136476	C
1,861	HSU -72 -LEVEL	HSU-LT7206004	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136477	C
1,862	HSU -72 -LEVEL	HSU-LT7207901	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136478	C
1,863	HSU -72 -LEVEL	HSU-LT7207904A	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136479	C
1,864	HSU -72 -LEVEL	HSU-LT7207904B	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136480	C
1,865	HSU -72 -LEVEL	HSU-LT7207904C	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136481	C
1,866	HSU -72 -LEVEL	HSU-LT7208001	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136482	C
1,867	HSU -72 -LEVEL	HSU-LT7208004	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136483	C
1,868	HSU -72 -LEVEL	HSU-LT7231401	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136484	C
1,869	HSU -72 -LEVEL	HSU-LT7231403	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IROH	136417	C
1,870	HSU -72 -LEVEL	HSU-LT7232202	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IROH	136418	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,871	HSU -72 -LEVEL	HSU-LT7232204	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136485	C
1,872	HSU -72 -LEVEL	HSU-LT7234102	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136486	C
1,873	HSU -72 -LEVEL	HSU-LT7234103	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y				I									RRC	RRC-IROH	136487	C
1,874	HSU -72 -LEVEL	HSU-LT7234103	LT7234103-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260451	C
1,875	HSU -72 -72K101	HSU-LT7250101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136392	C
1,876	HSU -72 -72K201	HSU-LT7250601	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136393	C
1,877	HSU -72 -72K301	HSU-LT7251101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136394	C
1,878	HSU -72 -72K601	HSU-LT7251601	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136395	C
1,879	HSU -73 -LEVEL	HSU-LT7300302	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136419	C
1,880	HSU -73 -LEVEL	HSU-LT7300501	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	136488	C
1,881	HSU -73 -LEVEL	HSU-LT7300504	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	136489	C
1,882	HSU -73 -LEVEL	HSU-LT7300601A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	136490	C
1,883	HSU -73 -LEVEL	HSU-LT7300601A	LT7300601A-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC-IROH	260452	C
1,884	HSU -73 -LEVEL	HSU-LT7300601B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	136491	C
1,885	HSU -73 -LEVEL	HSU-LT7300601B	LT7300601B-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC-IROH	260453	C
1,886	HSU -73 -LEVEL	HSU-LT7300601C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	136492	C
1,887	HSU -73 -LEVEL	HSU-LT7300601C	LT7300601C-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC-IROH	260454	C
1,888	HSU -73 -LEVEL	HSU-LT7300603	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	136493	C
1,889	HSU -73 -LEVEL	HSU-LT7300801A	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	136494	C
1,890	HSU -73 -LEVEL	HSU-LT7300801B	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	136495	C
1,891	HSU -73 -LEVEL	HSU-LT7300801C	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	136496	C
1,892	HSU -73 -LEVEL	HSU-LT7300803	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	136497	C
1,893	HSU -73 -LEVEL	HSU-LT7300902	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	136498	C
1,894	HSU -73 -LEVEL	HSU-LT7300903	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	136499	C
1,895	HSU -73 -LEVEL	HSU-LT7301501	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	136500	C
1,896	HSU -73 -LEVEL	HSU-LT7301504A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	136501	C
1,897	HSU -73 -LEVEL	HSU-LT7301504A	LT7301504A-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC-IROH	260455	C
1,898	HSU -73 -LEVEL	HSU-LT7301504B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	136502	C
1,899	HSU -73 -LEVEL	HSU-LT7301504B	LT7301504B-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC-IROH	260456	C
1,900	HSU -73 -LEVEL	HSU-LT7301504C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	136503	C
1,901	HSU -73 -LEVEL	HSU-LT7301504C	LT7301504C-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC-IROH	260457	C
1,902	HSU -73 -LEVEL	HSU-LT7301701	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	136504	C
1,903	HSU -73 -LEVEL	HSU-LT7301701	LT7301701-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260458	C
1,904	HSU -73 -LEVEL	HSU-LT7301703	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	136505	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,905	HSU -73 -LEVEL	HSU-LT7301802	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136506	C
1,906	HSU -73 -LEVEL	HSU-LT7301803	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y				I									RRC	RRC-IROH	136507	C
1,907	HSU -73 -LEVEL	HSU-LT7302101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IROH	136420	C
1,908	HSU -73 -LEVEL	HSU-LT7302102	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IROH	136421	C
1,909	HSU -73 -LEVEL	HSU-LT7302103	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IROH	136422	C
1,910	HSU -73 -LEVEL	HSU-LT7302104	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IROH	136423	C
1,911	HSU -73 -LEVEL	HSU-LT7302201	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IROH	136424	C
1,912	HSU -73 -LEVEL	HSU-LT7302202	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y			I										RRC	RRC-IROH	136425	C
1,913	HSU -51 -CV	HSU-LV5100901	INSPECT CONTROL VALVE NO. LV51	PMT	1Y									I				RRC	RRC-IROH	137134	C
1,914	HSU -51 -CV	HSU-LV5101401	INSPECT CONTROL VALVE NO. LV51	PMT	1Y									I				RRC	RRC-IROH	137135	C
1,915	HSU -51 -CV	HSU-LV5101701	INSPECT CONTROL VALVE NO. LV51	PMT	1Y									I				RRC	RRC-IROH	137136	C
1,916	HSU -51 -CV	HSU-LV5102301A	INSPECT CONTROL VALVE NO. LV51	PMT	1Y									I				RRC	RRC-IROH	137137	C
1,917	HSU -51 -CV	HSU-LV5102301B	INSPECT CONTROL VALVE NO. LV51	PMT	1Y									I				RRC	RRC-IROH	137138	C
1,918	HSU -70 -CV	HSU-LV7000301	INSPECT CONTROL VALVE NO. LV70	PMT	1Y									I				RRC	RRC-IROH	137139	C
1,919	HSU -70 -CV	HSU-LV7000302	INSPECT CONTROL VALVE NO. LV70	PMT	1Y									I				RRC	RRC-IROH	137140	C
1,920	HSU -70 -CV	HSU-LV7000501	INSPECT CONTROL VALVE NO. LV70	PMT	1Y									I				RRC	RRC-IROH	137141	C
1,921	HSU -70 -CV	HSU-LV7000702	INSPECT CONTROL VALVE NO. LV70	PMT	1Y									I				RRC	RRC-IROH	137142	C
1,922	HSU -71 -CV	HSU-LV7100301	INSPECT CONTROL VALVE NO. LV71	PMT	1Y									I				RRC	RRC-IROH	137143	C
1,923	HSU -71 -CV	HSU-LV7100302	INSPECT CONTROL VALVE NO. LV71	PMT	1Y									I				RRC	RRC-IROH	137144	C
1,924	HSU -72 -CV	HSU-LV7203001	INSPECT CONTROL VALVE NO. LV72	PMT	1Y									I				RRC	RRC-IROH	137145	C
1,925	HSU -72 -CV	HSU-LV7203401	INSPECT CONTROL VALVE NO. LV72	PMT	1Y									I				RRC	RRC-IROH	137146	C
1,926	HSU -72 -CV	HSU-LV7203502	INSPECT CONTROL VALVE NO. LV72	PMT	1Y									I				RRC	RRC-IROH	137147	C
1,927	HSU -72 -CV	HSU-LV7206001	INSPECT CONTROL VALVE NO. LV72	PMT	1Y									I				RRC	RRC-IROH	137148	C
1,928	HSU -72 -CV	HSU-LV7208001	INSPECT CONTROL VALVE NO. LV72	PMT	1Y									I				RRC	RRC-IROH	137149	C
1,929	HSU -72 -CV	HSU-LV7231403	INSPECT CONTROL VALVE NO. LV72	PMT	1Y									I				RRC	RRC-IROH	137150	C
1,930	HSU -72 -CV	HSU-LV7232203	INSPECT CONTROL VALVE NO. LV72	PMT	1Y									I				RRC	RRC-IROH	137151	C
1,931	HSU -73 -CV	HSU-LV7300302	INSPECT CONTROL VALVE NO. LV73	PMT	1Y									I				RRC	RRC-IROH	137152	C
1,932	HSU -73 -CV	HSU-LV7300501	INSPECT CONTROL VALVE NO. LV73	PMT	1Y									I				RRC	RRC-IROH	137153	C
1,933	HSU -73 -CV	HSU-LV7301703	INSPECT CONTROL VALVE NO. LV73	PMT	1Y									I				RRC	RRC-IROH	137154	C
1,934	HSU -51 -CV	HSU-PCV5102201	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IROH	137209	C
1,935	HSU -51 -CV	HSU-PCV5150802	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IROH	137210	C
1,936	HSU -51 -CV	HSU-PCV5150803	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IROH	137211	C
1,937	HSU -51 -CV	HSU-PCV5150804	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IROH	137212	C
1,938	HSU -51 -CV	HSU-PCV5155101	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IROH	137213	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,939	HSU -70 -CV	HSU-PCV7000201	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y											I		RRC	RRC-IROH	137214	C
1,940	HSU -70 -CV	HSU-PCV7000203	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y											I		RRC	RRC-IROH	137215	C
1,941	HSU -70 -CV	HSU-PCV7000204	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y											I		RRC	RRC-IROH	137216	C
1,942	HSU -70 -CV	HSU-PCV7000701	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y											I		RRC	RRC-IROH	137217	C
1,943	HSU -71 -CV	HSU-PCV7100101	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y											I		RRC	RRC-IROH	137218	C
1,944	HSU -71 -CV	HSU-PCV7100501	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y											I		RRC	RRC-IROH	137219	C
1,945	HSU -71 -CV	HSU-PCV7100502	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y											I		RRC	RRC-IROH	137220	C
1,946	HSU -71 -CV	HSU-PCV7100901	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y											I		RRC	RRC-IROH	137221	C
1,947	HSU -71 -CV	HSU-PCV7100902	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y											I		RRC	RRC-IROH	137222	C
1,948	HSU -73 -CV	HSU-PCV7301204	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y											I		RRC	RRC-IROH	137223	C
1,949	HSU -73 -CV	HSU-PCV7301207	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y											I		RRC	RRC-IROH	137224	C
1,950	HSU -73 -CV	HSU-PCV7302103	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y											I		RRC	RRC-IROH	137225	C
1,951	HSU -73 -CV	HSU-PCV7302105	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y											I		RRC	RRC-IROH	137226	C
1,952	HSU -51 -PRESS	HSU-PDT5101201	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y									I				RRC	RRC-IROH	136667	C
1,953	HSU -51 -PRESS	HSU-PDT5102003	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y									I				RRC	RRC-IROH	136668	C
1,954	HSU -51 -PRESS	HSU-PDT5102301	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y									I				RRC	RRC-IROH	136669	C
1,955	HSU -51 -51K004A	HSU-PDT5151102	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y									I				RRC	RRC-IROH	136692	C
1,956	HSU -51 -51K004A	HSU-PDT5151202	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y									I				RRC	RRC-IROH	136696	C
1,957	HSU -51 -51K004A	HSU-PDT5151502	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y									I				RRC	RRC-IROH	136708	C
1,958	HSU -51 -51K004B	HSU-PDT5152002	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y									I				RRC	RRC-IROH	136693	C
1,959	HSU -51 -51K004B	HSU-PDT5152102	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y									I				RRC	RRC-IROH	136697	C
1,960	HSU -51 -51K004B	HSU-PDT5152402	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y									I				RRC	RRC-IROH	136709	C
1,961	HSU -51 -51K005	HSU-PDT5153002	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y									I				RRC	RRC-IROH	136710	C
1,962	HSU -51 -51K005	HSU-PDT5153003	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y									I				RRC	RRC-IROH	136711	C
1,963	HSU -51 -51K005	HSU-PDT5153102	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y									I				RRC	RRC-IROH	136715	C
1,964	HSU -51 -PRESS	HSU-PDT5154101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y									I				RRC	RRC-IROH	136670	C
1,965	HSU -71 -PRESS	HSU-PDT7100701	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y									I				RRC	RRC-IROH	136671	C
1,966	HSU -71 -PRESS	HSU-PDT7100702	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y									I				RRC	RRC-IROH	136672	C
1,967	HSU -71 -PRESS	HSU-PDT7100703	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y									I				RRC	RRC-IROH	136673	C
1,968	HSU -72 -PRESS	HSU-PDT7202102	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y									I				RRC	RRC-IROH	136674	C
1,969	HSU -72 -PRESS	HSU-PDT7202701	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y									I				RRC	RRC-IROH	136675	C
1,970	HSU -72 -PRESS	HSU-PDT7202704	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y									I				RRC	RRC-IROH	136678	C
1,971	HSU -72 -PRESS	HSU-PDT7202704	PDT7202704-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260686	C
1,972	HSU -72 -PRESS	HSU-PDT7205701	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y									I				RRC	RRC-IROH	136676	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,973	HSU -72 -PRESS	HSU-PDT7205704	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136679	C
1,974	HSU -72 -PRESS	HSU-PDT7207701	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136677	C
1,975	HSU -72 -PRESS	HSU-PDT7207704	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136680	C
1,976	HSU -72 -72K101	HSU-PDT7250101	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136719	C
1,977	HSU -72 -72K101	HSU-PDT7250102	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136723	C
1,978	HSU -72 -72K201	HSU-PDT7250601	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136720	C
1,979	HSU -72 -72K201	HSU-PDT7250602	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136724	C
1,980	HSU -72 -72K301	HSU-PDT7251101	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136721	C
1,981	HSU -72 -72K301	HSU-PDT7251102	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136725	C
1,982	HSU -72 -72K601	HSU-PDT7251601	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136722	C
1,983	HSU -72 -72K601	HSU-PDT7251602	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136726	C
1,984	HSU -73 -PRESS	HSU-PDT7300601	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136681	C
1,985	HSU -73 -PRESS	HSU-PDT7300701	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136682	C
1,986	HSU -73 -PRESS	HSU-PDT7300702	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136683	C
1,987	HSU -73 -PRESS	HSU-PDT7300801	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136684	C
1,988	HSU -73 -PRESS	HSU-PDT7301705	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136685	C
1,989	HSU -73 -PRESS	HSU-PDT7302001	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136686	C
1,990	HSU -73 -PRESS	HSU-PDT7302002	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136687	C
1,991	HSU -73 -PRESS	HSU-PDT7302003	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136688	C
1,992	HSU -73 -PRESS	HSU-PDT7302204	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136689	C
1,993	HSU -STR-PIPE_RACK	HSU-PR-72-001	INSPECTION PIPE RACK FOR ROHS	INT	6Y				I									ENE	ENE-ENQS	204389	A
1,994	HSU -51 -51P001A	HSU-PSV5100905	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162817	A
1,995	HSU -51 -51P001B	HSU-PSV5100906	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162818	A
1,996	HSU -51 -51K001	HSU-PSV5151011	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162855	A
1,997	HSU -51 -51K001	HSU-PSV5151012	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162856	A
1,998	HSU -51 -51K001	HSU-PSV5151013	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162857	A
1,999	HSU -51 -51K001	HSU-PSV5151014	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162858	A
2,000	HSU -51 -51K002	HSU-PSV5151021	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162859	A
2,001	HSU -51 -51K002	HSU-PSV5151022	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162860	A
2,002	HSU -51 -51K002	HSU-PSV5151023	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162861	A
2,003	HSU -51 -51K002	HSU-PSV5151024	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162862	A
2,004	HSU -51 -51K004A	HSU-PSV5151201	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162864	A
2,005	HSU -51 -51K004A	HSU-PSV5151202	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162865	A
2,006	HSU -51 -51K004B	HSU-PSV5152101	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162869	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,007	HSU -51 -51K004B	HSU-PSV5152102	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162870	A
2,008	HSU -51 -51K005	HSU-PSV5153101	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162875	A
2,009	HSU -51 -51K005	HSU-PSV5153102	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162876	A
2,010	HSU -51 -51X001	HSU-PSV5154101	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162877	A
2,011	HSU -51 -51X001	HSU-PSV5154102	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162878	A
2,012	HSU -51 -51X001	HSU-PSV5154106	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162879	A
2,013	HSU -51 -51X001	HSU-PSV5154107	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162880	A
2,014	HSU -51 -51X001	HSU-PSV5154203	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162881	A
2,015	HSU -51 -51X001	HSU-PSV5154204	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162882	A
2,016	HSU -51 -51X001	HSU-PSV5154205	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162883	A
2,017	HSU -51 -51X001	HSU-PSV5154208	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162884	A
2,018	HSU -51 -51X001	HSU-PSV5154209	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162885	A
2,019	HSU -51 -51X001	HSU-PSV5154210	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162886	A
2,020	HSU -72 -72K101	HSU-PSV7250101	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162963	A
2,021	HSU -72 -72K101	HSU-PSV7250102	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162964	A
2,022	HSU -72 -72K101	HSU-PSV7250103	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162965	A
2,023	HSU -72 -72K201	HSU-PSV7250601	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162966	A
2,024	HSU -72 -72K201	HSU-PSV7250602	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162967	A
2,025	HSU -72 -72K201	HSU-PSV7250603	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162968	A
2,026	HSU -72 -72K301	HSU-PSV7251101	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162969	A
2,027	HSU -72 -72K301	HSU-PSV7251102	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162970	A
2,028	HSU -72 -72K301	HSU-PSV7251103	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162971	A
2,029	HSU -72 -72K601	HSU-PSV7251601	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162972	A
2,030	HSU -72 -72K601	HSU-PSV7251602	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162973	A
2,031	HSU -72 -72K601	HSU-PSV7251603	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	162974	A
2,032	HSU -51 -PRESS	HSU-PT5100901	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y					I								RRC	RRC-IRCH	136513	C
2,033	HSU -51 -PRESS	HSU-PT5100908	INSP. FIELD INST. (ตรวจปากรม์)	INS	1Y					I								RRC	RRC-IRCH	136514	C
2,034	HSU -51 -PRESS	HSU-PT5100908	PT5100908-FULL FUN TEST PT & P	PMT	5Y												F	RRC	RRC-IRCH	260670	C
2,035	HSU -51 -PRESS	HSU-PT5100910	INSP. FIELD INST. (ตรวจปากรม์)	INS	1Y					I								RRC	RRC-IRCH	136515	C
2,036	HSU -51 -PRESS	HSU-PT5100910	PT5100910-FULL FUN TEST PT & P	PMT	5Y												F	RRC	RRC-IRCH	260671	C
2,037	HSU -51 -PRESS	HSU-PT5100916	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y					I								RRC	RRC-IRCH	136516	C
2,038	HSU -51 -PRESS	HSU-PT5101001	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y					I								RRC	RRC-IRCH	136517	C
2,039	HSU -51 -PRESS	HSU-PT5101002	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y					I								RRC	RRC-IRCH	136518	C
2,040	HSU -51 -PRESS	HSU-PT5101301	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y					I								RRC	RRC-IRCH	136519	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,041	HSU -51 -PRESS	HSU-PT5101302	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y				I									RRC	RRC-IRCH	136520	C
2,042	HSU -51 -PRESS	HSU-PT5101801	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y				I									RRC	RRC-IRCH	136521	C
2,043	HSU -51 -PRESS	HSU-PT5101802	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y				I									RRC	RRC-IRCH	136522	C
2,044	HSU -51 -PRESS	HSU-PT5101803	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y				I									RRC	RRC-IRCH	136523	C
2,045	HSU -51 -PRESS	HSU-PT5101804	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y				I									RRC	RRC-IRCH	136524	C
2,046	HSU -51 -PRESS	HSU-PT5101901	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y				I									RRC	RRC-IRCH	136525	C
2,047	HSU -51 -PRESS	HSU-PT5101905	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y				I									RRC	RRC-IRCH	136526	C
2,048	HSU -51 -PRESS	HSU-PT5102101	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y				I									RRC	RRC-IRCH	136527	C
2,049	HSU -51 -PRESS	HSU-PT5102102	INSP. FIELD INST. (ตรวจปากรม์)	INS	1Y				I									RRC	RRC-IRCH	136528	C
2,050	HSU -51 -PRESS	HSU-PT5102102	PT5102102-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IRCH	260674	C
2,051	HSU -51 -PRESS	HSU-PT5102104	INSP. FIELD INST. (ตรวจปากรม์)	INS	1Y				I									RRC	RRC-IRCH	136529	C
2,052	HSU -51 -PRESS	HSU-PT5102104	PT5102104-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IRCH	260672	C
2,053	HSU -51 -PRESS	HSU-PT5102106	INSP. FIELD INST. (ตรวจปากรม์)	INS	1Y				I									RRC	RRC-IRCH	136530	C
2,054	HSU -51 -PRESS	HSU-PT5102106	PT5102106-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IRCH	260675	C
2,055	HSU -51 -PRESS	HSU-PT5102108	INSP. FIELD INST. (ตรวจปากรม์)	INS	1Y				I									RRC	RRC-IRCH	136531	C
2,056	HSU -51 -PRESS	HSU-PT5102108	PT5102108-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IRCH	260673	C
2,057	HSU -51 -PRESS	HSU-PT5102202	INSP. FIELD INST. (ตรวจปากรม์)	INS	1Y				I									RRC	RRC-IRCH	136532	C
2,058	HSU -51 -PRESS	HSU-PT5102202	PT5102202-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IRCH	260678	C
2,059	HSU -51 -PRESS	HSU-PT5102204	INSP. FIELD INST. (ตรวจปากรม์)	INS	1Y				I									RRC	RRC-IRCH	136533	C
2,060	HSU -51 -PRESS	HSU-PT5102204	PT5102204-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IRCH	260676	C
2,061	HSU -51 -PRESS	HSU-PT5102206	INSP. FIELD INST. (ตรวจปากรม์)	INS	1Y				I									RRC	RRC-IRCH	136534	C
2,062	HSU -51 -PRESS	HSU-PT5102206	PT5102206-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IRCH	260679	C
2,063	HSU -51 -PRESS	HSU-PT5102208	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y				I									RRC	RRC-IRCH	136535	C
2,064	HSU -51 -PRESS	HSU-PT5102210	INSP. FIELD INST. (ตรวจปากรม์)	INS	1Y				I									RRC	RRC-IRCH	136536	C
2,065	HSU -51 -PRESS	HSU-PT5102210	PT5102210-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IRCH	260677	C
2,066	HSU -51 -PRESS	HSU-PT5102302	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y				I									RRC	RRC-IRCH	136537	C
2,067	HSU -51 -PRESS	HSU-PT5102401	INSP. FIELD INST. (ตรวจปากรม์)	INS	1Y				I									RRC	RRC-IRCH	136538	C
2,068	HSU -51 -PRESS	HSU-PT5102401	PT5102401-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IRCH	260683	C
2,069	HSU -51 -PRESS	HSU-PT5102402	INSP. FIELD INST. (ตรวจปากรม์)	INS	1Y				I									RRC	RRC-IRCH	136539	C
2,070	HSU -51 -PRESS	HSU-PT5102402	PT5102402-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IRCH	260682	C
2,071	HSU -51 -PRESS	HSU-PT5102413	INSP. FIELD INST. (ตรวจปากรม์)	INS	1Y				I									RRC	RRC-IRCH	136540	C
2,072	HSU -51 -PRESS	HSU-PT5102413	PT5102413-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IRCH	260685	C
2,073	HSU -51 -PRESS	HSU-PT5102416	INSP. FIELD INST. (ตรวจปากรม์)	INS	1Y				I									RRC	RRC-IRCH	136541	C
2,074	HSU -51 -PRESS	HSU-PT5102416	PT5102416-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IRCH	260684	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,075	HSU -51 -PRESS	HSU-PT5102601	INSP. FIELD INST. (ตรวจปากรม์)	INS	1Y					I								RRC	RRC-IRCH	136542	C
2,076	HSU -51 -PRESS	HSU-PT5102601	PT5102601-FULL FUN TEST PT & P	PMT	5Y												F	RRC	RRC-IRCH	260680	C
2,077	HSU -51 -PRESS	HSU-PT5102602	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y					I								RRC	RRC-IRCH	136543	C
2,078	HSU -51 -PRESS	HSU-PT5102603	INSP. FIELD INST. (ตรวจปากรม์)	INS	1Y					I								RRC	RRC-IRCH	136544	C
2,079	HSU -51 -PRESS	HSU-PT5102603	PT5102603-FULL FUN TEST PT & P	PMT	5Y												F	RRC	RRC-IRCH	260681	C
2,080	HSU -51 -PRESS	HSU-PT5130103	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y					I								RRC	RRC-IRCH	136545	C
2,081	HSU -51 -PRESS	HSU-PT5131101	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y					I								RRC	RRC-IRCH	136546	C
2,082	HSU -51 -PRESS	HSU-PT5134102	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y					I								RRC	RRC-IRCH	136547	C
2,083	HSU -51 -PRESS	HSU-PT5134105	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y					I								RRC	RRC-IRCH	136548	C
2,084	HSU -51 -PRESS	HSU-PT5150101A	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y					I								RRC	RRC-IRCH	136549	C
2,085	HSU -51 -PRESS	HSU-PT5150101B	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y					I								RRC	RRC-IRCH	136550	C
2,086	HSU -51 -PRESS	HSU-PT5150101C	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y					I								RRC	RRC-IRCH	136551	C
2,087	HSU -51 -PRESS	HSU-PT5150102	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136552	C
2,088	HSU -51 -PRESS	HSU-PT5150103	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136553	C
2,089	HSU -51 -PRESS	HSU-PT5150201	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136554	C
2,090	HSU -51 -PRESS	HSU-PT5150501	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136555	C
2,091	HSU -51 -PRESS	HSU-PT5150502	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136556	C
2,092	HSU -51 -PRESS	HSU-PT5150601	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136557	C
2,093	HSU -51 -PRESS	HSU-PT5150602	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136558	C
2,094	HSU -51 -PRESS	HSU-PT5150801	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136559	C
2,095	HSU -51 -PRESS	HSU-PT5150803A	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136560	C
2,096	HSU -51 -PRESS	HSU-PT5150803B	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136561	C
2,097	HSU -51 -PRESS	HSU-PT5150803C	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136562	C
2,098	HSU -51 -PRESS	HSU-PT5150806A	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136563	C
2,099	HSU -51 -PRESS	HSU-PT5150806B	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136564	C
2,100	HSU -51 -PRESS	HSU-PT5150806C	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y						I							RRC	RRC-IRCH	136565	C
2,101	HSU -51 -51K004A	HSU-PT5151101	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y							I						RRC	RRC-IRCH	136690	C
2,102	HSU -51 -51K004A	HSU-PT5151102	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y							I						RRC	RRC-IRCH	136694	C
2,103	HSU -51 -51K004A	HSU-PT5151203A	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y							I						RRC	RRC-IRCH	136698	C
2,104	HSU -51 -51K004A	HSU-PT5151203B	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y							I						RRC	RRC-IRCH	136700	C
2,105	HSU -51 -51K004A	HSU-PT5151203C	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y							I						RRC	RRC-IRCH	136702	C
2,106	HSU -51 -51K004A	HSU-PT5151306	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y							I						RRC	RRC-IRCH	136704	C
2,107	HSU -51 -51K004A	HSU-PT5151307	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y							I						RRC	RRC-IRCH	136706	C
2,108	HSU -51 -51K004B	HSU-PT5152001	INSP. FIELD INST. (ตรวจปากรม์)	PMT	1Y							I						RRC	RRC-IRCH	136691	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,109	HSU -51 -51K004B	HSU-PT5152002	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136695	C
2,110	HSU -51 -51K004B	HSU-PT5152103A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136699	C
2,111	HSU -51 -51K004B	HSU-PT5152103B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136701	C
2,112	HSU -51 -51K004B	HSU-PT5152103C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136703	C
2,113	HSU -51 -51K004B	HSU-PT5152206	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136705	C
2,114	HSU -51 -51K004B	HSU-PT5152207	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136707	C
2,115	HSU -51 -51K005	HSU-PT5153001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136712	C
2,116	HSU -51 -51K005	HSU-PT5153002	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136713	C
2,117	HSU -51 -51K005	HSU-PT5153003	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136714	C
2,118	HSU -51 -51K005	HSU-PT5153103A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136716	C
2,119	HSU -51 -51K005	HSU-PT5153103B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136717	C
2,120	HSU -51 -51K005	HSU-PT5153103C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136718	C
2,121	HSU -51 -51X001	HSU-PT5154101A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136760	C
2,122	HSU -51 -51X001	HSU-PT5154101B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136761	C
2,123	HSU -51 -51X001	HSU-PT5154101C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136762	C
2,124	HSU -51 -51X001	HSU-PT5154102A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136750	C
2,125	HSU -51 -51X001	HSU-PT5154102B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136751	C
2,126	HSU -51 -51X001	HSU-PT5154102F	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136755	C
2,127	HSU -51 -51X001	HSU-PT5154102G	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136756	C
2,128	HSU -51 -51X001	HSU-PT5154202C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136752	C
2,129	HSU -51 -51X001	HSU-PT5154202D	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136753	C
2,130	HSU -51 -51X001	HSU-PT5154202E	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136754	C
2,131	HSU -51 -51X001	HSU-PT5154202H	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136757	C
2,132	HSU -51 -51X001	HSU-PT5154202I	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136758	C
2,133	HSU -51 -51X001	HSU-PT5154202J	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136759	C
2,134	HSU -51 -51X001	HSU-PT5154303A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136763	C
2,135	HSU -51 -51X001	HSU-PT5154303B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136764	C
2,136	HSU -51 -51X001	HSU-PT5154303C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136765	C
2,137	HSU -70 -PRESS	HSU-PT7000104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136566	C
2,138	HSU -70 -PRESS	HSU-PT7000207	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136567	C
2,139	HSU -70 -PRESS	HSU-PT7000301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136568	C
2,140	HSU -70 -PRESS	HSU-PT7000302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136569	C
2,141	HSU -70 -PRESS	HSU-PT7000401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136570	C
2,142	HSU -70 -PRESS	HSU-PT7000409	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136571	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,143	HSU -70 -PRESS	HSU-PT7000601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136572	C
2,144	HSU -70 -PRESS	HSU-PT7000702	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136573	C
2,145	HSU -70 -PRESS	HSU-PT7000801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136574	C
2,146	HSU -70 -PRESS	HSU-PT7031101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136575	C
2,147	HSU -70 -PRESS	HSU-PT7034101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136576	C
2,148	HSU -71 -PRESS	HSU-PT7100101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136577	C
2,149	HSU -71 -PRESS	HSU-PT7100103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136578	C
2,150	HSU -71 -PRESS	HSU-PT7100301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136579	C
2,151	HSU -71 -PRESS	HSU-PT7100302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136580	C
2,152	HSU -71 -PRESS	HSU-PT7100303	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136581	C
2,153	HSU -71 -PRESS	HSU-PT7100401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136582	C
2,154	HSU -71 -PRESS	HSU-PT7100408	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136583	C
2,155	HSU -71 -PRESS	HSU-PT7100501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136584	C
2,156	HSU -71 -PRESS	HSU-PT7100704	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136585	C
2,157	HSU -71 -PRESS	HSU-PT7100801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136586	C
2,158	HSU -71 -PRESS	HSU-PT7100901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136587	C
2,159	HSU -72 -PRESS	HSU-PT7202005	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136588	C
2,160	HSU -72 -PRESS	HSU-PT7202006	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136589	C
2,161	HSU -72 -PRESS	HSU-PT7202007	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136590	C
2,162	HSU -72 -PRESS	HSU-PT7202203	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136591	C
2,163	HSU -72 -PRESS	HSU-PT7202301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136592	C
2,164	HSU -72 -PRESS	HSU-PT7202305	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136593	C
2,165	HSU -72 -PRESS	HSU-PT7202409	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136594	C
2,166	HSU -72 -PRESS	HSU-PT7202410A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y					I								RRC	RRC-IROH	136595	C
2,167	HSU -72 -PRESS	HSU-PT7202410A	PT7202410A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260688	C
2,168	HSU -72 -PRESS	HSU-PT7202410B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y					I								RRC	RRC-IROH	136596	C
2,169	HSU -72 -PRESS	HSU-PT7202410B	PT7202410B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260689	C
2,170	HSU -72 -PRESS	HSU-PT7202410C	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y					I								RRC	RRC-IROH	136597	C
2,171	HSU -72 -PRESS	HSU-PT7202410C	PT7202410C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260690	C
2,172	HSU -72 -PRESS	HSU-PT7202601	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y					I								RRC	RRC-IROH	136598	C
2,173	HSU -72 -PRESS	HSU-PT7202601	PT7202601-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IROH	260687	C
2,174	HSU -72 -PRESS	HSU-PT7202702	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136599	C
2,175	HSU -72 -PRESS	HSU-PT7202706	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IROH	136600	C
2,176	HSU -72 -PRESS	HSU-PT7202708A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y					I								RRC	RRC-IROH	136601	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,177	HSU -72 -PRESS	HSU-PT7202708A	PT7202708A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260691	C
2,178	HSU -72 -PRESS	HSU-PT7202708B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y						I							RRC	RRC-IROH	136602	C
2,179	HSU -72 -PRESS	HSU-PT7202708B	PT7202708B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260692	C
2,180	HSU -72 -PRESS	HSU-PT7202708C	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y						I							RRC	RRC-IROH	136603	C
2,181	HSU -72 -PRESS	HSU-PT7202708C	PT7202708C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260693	C
2,182	HSU -72 -PRESS	HSU-PT7202901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136604	C
2,183	HSU -72 -PRESS	HSU-PT7203002	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136605	C
2,184	HSU -72 -PRESS	HSU-PT7203003	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136606	C
2,185	HSU -72 -PRESS	HSU-PT7203401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136607	C
2,186	HSU -72 -PRESS	HSU-PT7203408	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136608	C
2,187	HSU -72 -PRESS	HSU-PT7203501	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y						I							RRC	RRC-IROH	136609	C
2,188	HSU -72 -PRESS	HSU-PT7203501	PT7203501-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IROH	260695	C
2,189	HSU -72 -PRESS	HSU-PT7203503	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136610	C
2,190	HSU -72 -PRESS	HSU-PT7205601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136611	C
2,191	HSU -72 -PRESS	HSU-PT7205702	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136612	C
2,192	HSU -72 -PRESS	HSU-PT7205706	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136613	C
2,193	HSU -72 -PRESS	HSU-PT7205708A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136614	C
2,194	HSU -72 -PRESS	HSU-PT7205708B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136615	C
2,195	HSU -72 -PRESS	HSU-PT7205708C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136616	C
2,196	HSU -72 -PRESS	HSU-PT7205901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136617	C
2,197	HSU -72 -PRESS	HSU-PT7206002	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136618	C
2,198	HSU -72 -PRESS	HSU-PT7206003	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136619	C
2,199	HSU -72 -PRESS	HSU-PT7207601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136620	C
2,200	HSU -72 -PRESS	HSU-PT7207702	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136621	C
2,201	HSU -72 -PRESS	HSU-PT7207706	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136622	C
2,202	HSU -72 -PRESS	HSU-PT7207708A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136623	C
2,203	HSU -72 -PRESS	HSU-PT7207708B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136624	C
2,204	HSU -72 -PRESS	HSU-PT7207708C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136625	C
2,205	HSU -72 -PRESS	HSU-PT7207901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136626	C
2,206	HSU -72 -PRESS	HSU-PT7208002	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136627	C
2,207	HSU -72 -PRESS	HSU-PT7208003	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136628	C
2,208	HSU -72 -PRESS	HSU-PT7230102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136629	C
2,209	HSU -72 -PRESS	HSU-PT7231102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136630	C
2,210	HSU -72 -PRESS	HSU-PT7231302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136631	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,211	HSU -72 -PRESS	HSU-PT7231303	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136632	C
2,212	HSU -72 -PRESS	HSU-PT7234102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136633	C
2,213	HSU -72 -PRESS	HSU-PT7234103	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y						I							RRC	RRC-IROH	136634	C
2,214	HSU -72 -PRESS	HSU-PT7234103	PT7234103-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IROH	260694	C
2,215	HSU -72 -PRESS	HSU-PT7234105	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136635	C
2,216	HSU -72 -PRESS	HSU-PT7234107	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136636	C
2,217	HSU -72 -PRESS	HSU-PT7234108	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y						I							RRC	RRC-IROH	136637	C
2,218	HSU -72 -PRESS	HSU-PT7234108	PT7234108-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IROH	260696	C
2,219	HSU -72 -PRESS	HSU-PT7234109	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136638	C
2,220	HSU -72 -PRESS	HSU-PT7235101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136639	C
2,221	HSU -72 -PRESS	HSU-PT7235106	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136640	C
2,222	HSU -72 -PRESS	HSU-PT7235110	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136641	C
2,223	HSU -72 -PRESS	HSU-PT7237104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IROH	136642	C
2,224	HSU -72 -72K101	HSU-PT7250101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136739	C
2,225	HSU -72 -72K101	HSU-PT7250102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136743	C
2,226	HSU -72 -72K101	HSU-PT7250103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136735	C
2,227	HSU -72 -72K101	HSU-PT7250104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136727	C
2,228	HSU -72 -72K101	HSU-PT7250105	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136731	C
2,229	HSU -72 -72K201	HSU-PT7250601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136740	C
2,230	HSU -72 -72K201	HSU-PT7250602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136744	C
2,231	HSU -72 -72K201	HSU-PT7250603	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136736	C
2,232	HSU -72 -72K201	HSU-PT7250604	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136728	C
2,233	HSU -72 -72K201	HSU-PT7250605	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136732	C
2,234	HSU -72 -72K301	HSU-PT7251101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136741	C
2,235	HSU -72 -72K301	HSU-PT7251102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136745	C
2,236	HSU -72 -72K301	HSU-PT7251103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136737	C
2,237	HSU -72 -72K301	HSU-PT7251104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136729	C
2,238	HSU -72 -72K301	HSU-PT7251105	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136733	C
2,239	HSU -72 -72K601	HSU-PT7251601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136742	C
2,240	HSU -72 -72K601	HSU-PT7251602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136746	C
2,241	HSU -72 -72K601	HSU-PT7251603	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136738	C
2,242	HSU -72 -72K601	HSU-PT7251604	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136730	C
2,243	HSU -72 -72K601	HSU-PT7251605	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136734	C
2,244	HSU -73 -PRESS	HSU-PT7301101A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y						I							RRC	RRC-IROH	136643	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,245	HSU -73 -PRESS	HSU-PT7300101A	PT7300101A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260697	C
2,246	HSU -73 -PRESS	HSU-PT7300101B	INSP., FIELD INST. (ตัดลูปกลวง)	INS	1Y					I								RRC	RRC- IROH	136644	C
2,247	HSU -73 -PRESS	HSU-PT7300101B	PT7300101B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260698	C
2,248	HSU -73 -PRESS	HSU-PT7300101C	INSP., FIELD INST. (ตัดลูปกลวง)	INS	1Y					I								RRC	RRC- IROH	136645	C
2,249	HSU -73 -PRESS	HSU-PT7300101C	PT7300101C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260699	C
2,250	HSU -73 -PRESS	HSU-PT7300102	INSP., FIELD INST. (ตัดลูปกลวง)	PMT	1Y					I								RRC	RRC- IROH	136646	C
2,251	HSU -73 -PRESS	HSU-PT7300302	INSP., FIELD INST. (ตัดลูปกลวง)	PMT	1Y					I								RRC	RRC- IROH	136647	C
2,252	HSU -73 -PRESS	HSU-PT7300503	INSP., FIELD INST. (ตัดลูปกลวง)	PMT	1Y					I								RRC	RRC- IROH	136648	C
2,253	HSU -73 -PRESS	HSU-PT7300603	INSP., FIELD INST. (ตัดลูปกลวง)	PMT	1Y					I								RRC	RRC- IROH	136649	C
2,254	HSU -73 -PRESS	HSU-PT7300608	INSP., FIELD INST. (ตัดลูปกลวง)	PMT	1Y					I								RRC	RRC- IROH	136650	C
2,255	HSU -73 -PRESS	HSU-PT7300609	INSP., FIELD INST. (ตัดลูปกลวง)	PMT	1Y					I								RRC	RRC- IROH	136651	C
2,256	HSU -73 -PRESS	HSU-PT7300803	INSP., FIELD INST. (ตัดลูปกลวง)	PMT	1Y					I								RRC	RRC- IROH	136652	C
2,257	HSU -73 -PRESS	HSU-PT7300902	INSP., FIELD INST. (ตัดลูปกลวง)	PMT	1Y					I								RRC	RRC- IROH	136653	C
2,258	HSU -73 -PRESS	HSU-PT7301002	INSP., FIELD INST. (ตัดลูปกลวง)	PMT	1Y					I								RRC	RRC- IROH	136654	C
2,259	HSU -73 -PRESS	HSU-PT7301101A	INSP., FIELD INST. (ตัดลูปกลวง)	INS	1Y					I								RRC	RRC- IROH	136655	C
2,260	HSU -73 -PRESS	HSU-PT7301101A	PT7301101A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260700	C
2,261	HSU -73 -PRESS	HSU-PT7301101B	INSP., FIELD INST. (ตัดลูปกลวง)	INS	1Y					I								RRC	RRC- IROH	136656	C
2,262	HSU -73 -PRESS	HSU-PT7301101B	PT7301101B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260701	C
2,263	HSU -73 -PRESS	HSU-PT7301101C	INSP., FIELD INST. (ตัดลูปกลวง)	INS	1Y						I							RRC	RRC- IROH	136657	C
2,264	HSU -73 -PRESS	HSU-PT7301101C	PT7301101C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260702	C
2,265	HSU -73 -PRESS	HSU-PT7301201	INSP., FIELD INST. (ตัดลูปกลวง)	INS	1Y						I							RRC	RRC- IROH	136658	C
2,266	HSU -73 -PRESS	HSU-PT7301201	PT7301201-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC- IROH	260703	C
2,267	HSU -73 -PRESS	HSU-PT7301206	INSP., FIELD INST. (ตัดลูปกลวง)	INS	1Y						I							RRC	RRC- IROH	136659	C
2,268	HSU -73 -PRESS	HSU-PT7301206	PT7301206-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC- IROH	260704	C
2,269	HSU -73 -PRESS	HSU-PT7301209	INSP., FIELD INST. (ตัดลูปกลวง)	PMT	1Y						I							RRC	RRC- IROH	136660	C
2,270	HSU -73 -PRESS	HSU-PT7301401	INSP., FIELD INST. (ตัดลูปกลวง)	PMT	1Y						I							RRC	RRC- IROH	136661	C
2,271	HSU -73 -PRESS	HSU-PT7301502	INSP., FIELD INST. (ตัดลูปกลวง)	PMT	1Y						I							RRC	RRC- IROH	136662	C
2,272	HSU -73 -PRESS	HSU-PT7301704	INSP., FIELD INST. (ตัดลูปกลวง)	PMT	1Y						I							RRC	RRC- IROH	136663	C
2,273	HSU -73 -PRESS	HSU-PT7301806	INSP., FIELD INST. (ตัดลูปกลวง)	PMT	1Y						I							RRC	RRC- IROH	136664	C
2,274	HSU -73 -PRESS	HSU-PT7302104	INSP., FIELD INST. (ตัดลูปกลวง)	PMT	1Y						I							RRC	RRC- IROH	136665	C
2,275	HSU -73 -PRESS	HSU-PT7302203	INSP., FIELD INST. (ตัดลูปกลวง)	PMT	1Y						I							RRC	RRC- IROH	136666	C
2,276	HSU -73 -73K401	HSU-PT7350101	INSP., FIELD INST. (ตัดลูปกลวง)	PMT	1Y						I							RRC	RRC- IROH	136747	C
2,277	HSU -51 -CV	HSU-PV5100901A	INSPECT CONTROL VALVE NO. PV51	PMT	1Y									I				RRC	RRC- IROH	137155	C
2,278	HSU -51 -CV	HSU-PV5100901B	INSPECT CONTROL VALVE NO. PV51	PMT	1Y									I				RRC	RRC- IROH	137156	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,279	HSU -51 -CV	HSU-PV5101301	INSPECT CONTROL VALVE NO. PV51	PMT	1Y										I			RRC	RRC- IROH	137157	C
2,280	HSU -51 -CV	HSU-PV5101302	INSPECT CONTROL VALVE NO. PV51	PMT	1Y										I			RRC	RRC- IROH	137158	C
2,281	HSU -51 -CV	HSU-PV5101801	INSPECT CONTROL VALVE NO. PV51	PMT	1Y										I			RRC	RRC- IROH	137159	C
2,282	HSU -51 -CV	HSU-PV5101901	INSPECT CONTROL VALVE NO. PV51	PMT	1Y										I			RRC	RRC- IROH	137160	C
2,283	HSU -51 -CV	HSU-PV5101905	INSPECT CONTROL VALVE NO. PV51	PMT	1Y										I			RRC	RRC- IROH	137161	C
2,284	HSU -51 -CV	HSU-PV5102101	INSPECT CONTROL VALVE NO. PV51	PMT	1Y										I			RRC	RRC- IROH	137162	C
2,285	HSU -51 -51K004A	HSU-PV5102102	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137306	C
2,286	HSU -51 -CV	HSU-PV5102208A	INSPECT CONTROL VALVE NO. PV51	PMT	1Y										I			RRC	RRC- IROH	137163	C
2,287	HSU -51 -CV	HSU-PV5102208B	INSPECT CONTROL VALVE NO. PV51	PMT	1Y										I			RRC	RRC- IROH	137164	C
2,288	HSU -51 -CV	HSU-PV5150601	INSPECT CONTROL VALVE NO. PV51	PMT	1Y										I			RRC	RRC- IROH	137165	C
2,289	HSU -51 -51X001	HSU-PV5154101A	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137323	C
2,290	HSU -51 -51X001	HSU-PV5154101A	OVERHAUL CONTROL VALVE NO.PV5154101A	PMT	2Y		H											RRC	RRC- IROH	152201	C
2,291	HSU -51 -51X001	HSU-PV5154101B	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137324	C
2,292	HSU -51 -51X001	HSU-PV5154101B	OVERHAUL CONTROL VALVE NO.PV5154101B	PMT	2Y			H										RRC	RRC- IROH	152202	C
2,293	HSU -51 -51X001	HSU-PV5154101F	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137328	C
2,294	HSU -51 -51X001	HSU-PV5154101F	OVERHAUL CONTROL VALVE NO.PV5154101F	PMT	2Y		H											RRC	RRC- IROH	152203	C
2,295	HSU -51 -51X001	HSU-PV5154101G	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137329	C
2,296	HSU -51 -51X001	HSU-PV5154101G	OVERHAUL CONTROL VALVE NO.PV5154101G	PMT	2Y			H										RRC	RRC- IROH	152204	C
2,297	HSU -51 -51X001	HSU-PV5154102A	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137333	C
2,298	HSU -51 -51X001	HSU-PV5154102A	OVERHAUL CONTROL VALVE NO.PV5154102A	PMT	2Y		H											RRC	RRC- IROH	152205	C
2,299	HSU -51 -51X001	HSU-PV5154102B	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137334	C
2,300	HSU -51 -51X001	HSU-PV5154102B	OVERHAUL CONTROL VALVE NO.PV5154102B	PMT	2Y			H										RRC	RRC- IROH	152206	C
2,301	HSU -51 -51X001	HSU-PV5154102F	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137338	C
2,302	HSU -51 -51X001	HSU-PV5154102F	OVERHAUL CONTROL VALVE NO.PV5154102F	PMT	2Y		H											RRC	RRC- IROH	152207	C
2,303	HSU -51 -51X001	HSU-PV5154102G	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137339	C
2,304	HSU -51 -51X001	HSU-PV5154102G	OVERHAUL CONTROL VALVE NO.PV5154102G	PMT	2Y			H										RRC	RRC- IROH	152208	C
2,305	HSU -51 -51X001	HSU-PV5154103A	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137313	C
2,306	HSU -51 -51X001	HSU-PV5154103A	OVERHAUL CONTROL VALVE NO.PV5154103A	PMT	2Y		H											RRC	RRC- IROH	152209	C
2,307	HSU -51 -51X001	HSU-PV5154103B	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137314	C
2,308	HSU -51 -51X001	HSU-PV5154103B	OVERHAUL CONTROL VALVE NO.PV5154103B	PMT	2Y			H										RRC	RRC- IROH	152210	C
2,309	HSU -51 -51X001	HSU-PV5154103F	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137318	C
2,310	HSU -51 -51X001	HSU-PV5154103F	OVERHAUL CONTROL VALVE NO.PV5154103F	PMT	2Y		H											RRC	RRC- IROH	152211	C
2,311	HSU -51 -51X001	HSU-PV5154103G	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137319	C
2,312	HSU -51 -51X001	HSU-PV5154103G	OVERHAUL CONTROL VALVE NO.PV5154103G	PMT	2Y			H										RRC	RRC- IROH	152212	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,313	HSU -51 -51X001	HSU-PV5154103H	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC- IROH	137320	C
2,314	HSU -51 -51X001	HSU-PV5154103H	OVERHAUL CONTROL VALVE NO.PV5154103H	PMT	2Y				H									RRC	RRC- IROH	152213	C
2,315	HSU -51 -51X001	HSU-PV5154103I	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137321	C
2,316	HSU -51 -51X001	HSU-PV5154103I	OVERHAUL CONTROL VALVE NO.PV5154103I	PMT	2Y						H							RRC	RRC- IROH	152214	C
2,317	HSU -51 -51X001	HSU-PV5154103J	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137322	C
2,318	HSU -51 -51X001	HSU-PV5154103J	OVERHAUL CONTROL VALVE NO.PV5154103J	PMT	2Y							H						RRC	RRC- IROH	152215	C
2,319	HSU -51 -51X001	HSU-PV5154104A	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137343	C
2,320	HSU -51 -51X001	HSU-PV5154104A	OVERHAUL CONTROL VALVE NO.PV5154104A	PMT	2Y		H											RRC	RRC- IROH	152216	C
2,321	HSU -51 -51X001	HSU-PV5154104B	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137344	C
2,322	HSU -51 -51X001	HSU-PV5154104B	OVERHAUL CONTROL VALVE NO.PV5154104B	PMT	2Y			H										RRC	RRC- IROH	152217	C
2,323	HSU -51 -51X001	HSU-PV5154104F	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137348	C
2,324	HSU -51 -51X001	HSU-PV5154104F	OVERHAUL CONTROL VALVE NO.PV5154104F	PMT	2Y		H											RRC	RRC- IROH	152218	C
2,325	HSU -51 -51X001	HSU-PV5154104G	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137349	C
2,326	HSU -51 -51X001	HSU-PV5154104G	OVERHAUL CONTROL VALVE NO.PV5154104G	PMT	2Y			H										RRC	RRC- IROH	152219	C
2,327	HSU -51 -51X001	HSU-PV5154105A	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137353	C
2,328	HSU -51 -51X001	HSU-PV5154105A	OVERHAUL CONTROL VALVE NO.PV5154105A	PMT	2Y		H											RRC	RRC- IROH	152220	C
2,329	HSU -51 -51X001	HSU-PV5154105B	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137354	C
2,330	HSU -51 -51X001	HSU-PV5154105B	OVERHAUL CONTROL VALVE NO.PV5154105B	PMT	2Y			H										RRC	RRC- IROH	152221	C
2,331	HSU -51 -51X001	HSU-PV5154105F	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137358	C
2,332	HSU -51 -51X001	HSU-PV5154105F	OVERHAUL CONTROL VALVE NO.PV5154105F	PMT	2Y		H											RRC	RRC- IROH	152222	C
2,333	HSU -51 -51X001	HSU-PV5154105G	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137359	C
2,334	HSU -51 -51X001	HSU-PV5154105G	OVERHAUL CONTROL VALVE NO.PV5154105G	PMT	2Y			H										RRC	RRC- IROH	152223	C
2,335	HSU -51 -51X001	HSU-PV5154106A	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137363	C
2,336	HSU -51 -51X001	HSU-PV5154106A	OVERHAUL CONTROL VALVE NO.PV5154106A	PMT	2Y		H											RRC	RRC- IROH	152224	C
2,337	HSU -51 -51X001	HSU-PV5154106B	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137364	C
2,338	HSU -51 -51X001	HSU-PV5154106B	OVERHAUL CONTROL VALVE NO.PV5154106B	PMT	2Y			H										RRC	RRC- IROH	152225	C
2,339	HSU -51 -51X001	HSU-PV5154108A	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137368	C
2,340	HSU -51 -51X001	HSU-PV5154108A	OVERHAUL CONTROL VALVE NO.PV5154108A	PMT	2Y		H											RRC	RRC- IROH	152226	C
2,341	HSU -51 -51X001	HSU-PV5154108B	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137369	C
2,342	HSU -51 -51X001	HSU-PV5154108B	OVERHAUL CONTROL VALVE NO.PV5154108B	PMT	2Y			H										RRC	RRC- IROH	152227	C
2,343	HSU -51 -51X001	HSU-PV5154108F	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137373	C
2,344	HSU -51 -51X001	HSU-PV5154108F	OVERHAUL CONTROL VALVE NO.PV5154108F	PMT	2Y		H											RRC	RRC- IROH	152228	C
2,345	HSU -51 -51X001	HSU-PV5154108G	INSPECT CONTROL VALVE NO. PV51	PMT	1Y											I		RRC	RRC- IROH	137374	C
2,346	HSU -51 -51X001	HSU-PV5154108G	OVERHAUL CONTROL VALVE NO.PV5154108G	PMT	2Y			H										RRC	RRC- IROH	152229	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,347	HSU -51 -51X001	HSU-PV5154110	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC- IROH	137378	C
2,348	HSU -51 -51X001	HSU-PV5154110	OVERHAUL CONTROL VALVE NO.PV5154110	PMT	2Y				H									RRC	RRC- IROH	152230	C
2,349	HSU -51 -51X001	HSU-PV5154111	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC- IROH	137379	C
2,350	HSU -51 -51X001	HSU-PV5154111	OVERHAUL CONTROL VALVE NO.PV5154111	PMT	2Y				H									RRC	RRC- IROH	152231	C
2,351	HSU -51 -51X001	HSU-PV5154201C	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC- IROH	137325	C
2,352	HSU -51 -51X001	HSU-PV5154201C	OVERHAUL CONTROL VALVE NO.PV5154201C	PMT	2Y					H								RRC	RRC- IROH	152232	C
2,353	HSU -51 -51X001	HSU-PV5154201D	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC- IROH	137326	C
2,354	HSU -51 -51X001	HSU-PV5154201D	OVERHAUL CONTROL VALVE NO.PV5154201D	PMT	2Y						H							RRC	RRC- IROH	152233	C
2,355	HSU -51 -51X001	HSU-PV5154201E	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC- IROH	137327	C
2,356	HSU -51 -51X001	HSU-PV5154201E	OVERHAUL CONTROL VALVE NO.PV5154201E	PMT	2Y							H						RRC	RRC- IROH	152234	C
2,357	HSU -51 -51X001	HSU-PV5154201H	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC- IROH	137330	C
2,358	HSU -51 -51X001	HSU-PV5154201H	OVERHAUL CONTROL VALVE NO.PV5154201H	PMT	2Y						H							RRC	RRC- IROH	152235	C
2,359	HSU -51 -51X001	HSU-PV5154201I	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC- IROH	137331	C
2,360	HSU -51 -51X001	HSU-PV5154201I	OVERHAUL CONTROL VALVE NO.PV5154201I	PMT	2Y						H							RRC	RRC- IROH	152236	C
2,361	HSU -51 -51X001	HSU-PV5154201J	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC- IROH	137332	C
2,362	HSU -51 -51X001	HSU-PV5154201J	OVERHAUL CONTROL VALVE NO.PV5154201J	PMT	2Y							H						RRC	RRC- IROH	152237	C
2,363	HSU -51 -51X001	HSU-PV5154202C	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC- IROH	137335	C
2,364	HSU -51 -51X001	HSU-PV5154202C	OVERHAUL CONTROL VALVE NO.PV5154202C	PMT	2Y						H							RRC	RRC- IROH	152238	C
2,365	HSU -51 -51X001	HSU-PV5154202D	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC- IROH	137336	C
2,366	HSU -51 -51X001	HSU-PV5154202D	OVERHAUL CONTROL VALVE NO.PV5154202D	PMT	2Y						H							RRC	RRC- IROH	152239	C
2,367	HSU -51 -51X001	HSU-PV5154202E	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC- IROH	137337	C
2,368	HSU -51 -51X001	HSU-PV5154202E	OVERHAUL CONTROL VALVE NO.PV5154202E	PMT	2Y							H						RRC	RRC- IROH	152240	C
2,369	HSU -51 -51X001	HSU-PV5154202H	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC- IROH	137340	C
2,370	HSU -51 -51X001	HSU-PV5154202H	OVERHAUL CONTROL VALVE NO.PV5154202H	PMT	2Y						H							RRC	RRC- IROH	152241	C
2,371	HSU -51 -51X001	HSU-PV5154202I	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC- IROH	137341	C
2,372	HSU -51 -51X001	HSU-PV5154202I	OVERHAUL CONTROL VALVE NO.PV5154202I	PMT	2Y							H						RRC	RRC- IROH	152242	C
2,373	HSU -51 -51X001	HSU-PV5154202J	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC- IROH	137342	C
2,374	HSU -51 -51X001	HSU-PV5154202J	OVERHAUL CONTROL VALVE NO.PV5154202J	PMT	2Y							H						RRC	RRC- IROH	152243	C
2,375	HSU -51 -51X001	HSU-PV5154203C	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC- IROH	137315	C
2,376	HSU -51 -51X001	HSU-PV5154203C	OVERHAUL CONTROL VALVE NO.PV5154203C	PMT	2Y					H								RRC	RRC- IROH	152244	C
2,377	HSU -51 -51X001	HSU-PV5154203D	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC- IROH	137316	C
2,378	HSU -51 -51X001	HSU-PV5154203D	OVERHAUL CONTROL VALVE NO.PV5154203D	PMT	2Y						H							RRC	RRC- IROH	152245	C
2,379	HSU -51 -51X001	HSU-PV5154203E	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC- IROH	137317	C
2,380	HSU -51 -51X001	HSU-PV5154203E	OVERHAUL CONTROL VALVE NO.PV5154203E	PMT	2Y							H						RRC	RRC- IROH	152246	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,381	HSU -51 -51X001	HSU-PV5154204C	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC-IROH	137345	C
2,382	HSU -51 -51X001	HSU-PV5154204C	OVERHAUL CONTROL VALVE NO.PV5154204C	PMT	2Y					H								RRC	RRC-IROH	152247	C
2,383	HSU -51 -51X001	HSU-PV5154204D	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC-IROH	137346	C
2,384	HSU -51 -51X001	HSU-PV5154204D	OVERHAUL CONTROL VALVE NO.PV5154204D	PMT	2Y						H							RRC	RRC-IROH	152248	C
2,385	HSU -51 -51X001	HSU-PV5154204E	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC-IROH	137347	C
2,386	HSU -51 -51X001	HSU-PV5154204E	OVERHAUL CONTROL VALVE NO.PV5154204E	PMT	2Y							H						RRC	RRC-IROH	152249	C
2,387	HSU -51 -51X001	HSU-PV5154204H	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC-IROH	137350	C
2,388	HSU -51 -51X001	HSU-PV5154204H	OVERHAUL CONTROL VALVE NO.PV5154204H	PMT	2Y					H								RRC	RRC-IROH	152250	C
2,389	HSU -51 -51X001	HSU-PV5154204 I	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC-IROH	137351	C
2,390	HSU -51 -51X001	HSU-PV5154204 I	OVERHAUL CONTROL VALVE NO.PV5154204I	PMT	2Y						H							RRC	RRC-IROH	152251	C
2,391	HSU -51 -51X001	HSU-PV5154204J	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC-IROH	137352	C
2,392	HSU -51 -51X001	HSU-PV5154204J	OVERHAUL CONTROL VALVE NO.PV5154204J	PMT	2Y							H						RRC	RRC-IROH	152252	C
2,393	HSU -51 -51X001	HSU-PV5154205C	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC-IROH	137355	C
2,394	HSU -51 -51X001	HSU-PV5154205C	OVERHAUL CONTROL VALVE NO.PV5154205C	PMT	2Y					H								RRC	RRC-IROH	152253	C
2,395	HSU -51 -51X001	HSU-PV5154205D	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC-IROH	137356	C
2,396	HSU -51 -51X001	HSU-PV5154205D	OVERHAUL CONTROL VALVE NO.PV5154205D	PMT	2Y						H							RRC	RRC-IROH	152254	C
2,397	HSU -51 -51X001	HSU-PV5154205E	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC-IROH	137357	C
2,398	HSU -51 -51X001	HSU-PV5154205E	OVERHAUL CONTROL VALVE NO.PV5154205E	PMT	2Y							H						RRC	RRC-IROH	152255	C
2,399	HSU -51 -51X001	HSU-PV5154205H	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC-IROH	137360	C
2,400	HSU -51 -51X001	HSU-PV5154205H	OVERHAUL CONTROL VALVE NO.PV5154205H	PMT	2Y					H								RRC	RRC-IROH	152256	C
2,401	HSU -51 -51X001	HSU-PV5154205 I	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC-IROH	137361	C
2,402	HSU -51 -51X001	HSU-PV5154205 I	OVERHAUL CONTROL VALVE NO.PV5154205I	PMT	2Y						H							RRC	RRC-IROH	152257	C
2,403	HSU -51 -51X001	HSU-PV5154205J	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC-IROH	137362	C
2,404	HSU -51 -51X001	HSU-PV5154205J	OVERHAUL CONTROL VALVE NO.PV5154205J	PMT	2Y							H						RRC	RRC-IROH	152258	C
2,405	HSU -51 -51X001	HSU-PV5154206C	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC-IROH	137365	C
2,406	HSU -51 -51X001	HSU-PV5154206C	OVERHAUL CONTROL VALVE NO.PV5154206C	PMT	2Y					H								RRC	RRC-IROH	152259	C
2,407	HSU -51 -51X001	HSU-PV5154206D	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC-IROH	137366	C
2,408	HSU -51 -51X001	HSU-PV5154206D	OVERHAUL CONTROL VALVE NO.PV5154206D	PMT	2Y						H							RRC	RRC-IROH	152260	C
2,409	HSU -51 -51X001	HSU-PV5154206E	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC-IROH	137367	C
2,410	HSU -51 -51X001	HSU-PV5154206E	OVERHAUL CONTROL VALVE NO.PV5154206E	PMT	2Y							H						RRC	RRC-IROH	152261	C
2,411	HSU -51 -51X001	HSU-PV5154208C	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC-IROH	137370	C
2,412	HSU -51 -51X001	HSU-PV5154208C	OVERHAUL CONTROL VALVE NO.PV5154208C	PMT	2Y					H								RRC	RRC-IROH	152262	C
2,413	HSU -51 -51X001	HSU-PV5154208D	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC-IROH	137371	C
2,414	HSU -51 -51X001	HSU-PV5154208D	OVERHAUL CONTROL VALVE NO.PV5154208D	PMT	2Y						H							RRC	RRC-IROH	152263	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,415	HSU -51 -51X001	HSU-PV5154208E	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC-IROH	137372	C
2,416	HSU -51 -51X001	HSU-PV5154208E	OVERHAUL CONTROL VALVE NO.PV5154208E	PMT	2Y							H						RRC	RRC-IROH	152264	C
2,417	HSU -51 -51X001	HSU-PV5154208H	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC-IROH	137375	C
2,418	HSU -51 -51X001	HSU-PV5154208H	OVERHAUL CONTROL VALVE NO.PV5154208H	PMT	2Y						H							RRC	RRC-IROH	152265	C
2,419	HSU -51 -51X001	HSU-PV5154208 I	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC-IROH	137376	C
2,420	HSU -51 -51X001	HSU-PV5154208 I	OVERHAUL CONTROL VALVE NO.PV5154208 I	PMT	2Y							H						RRC	RRC-IROH	152266	C
2,421	HSU -51 -51X001	HSU-PV5154208J	INSPECT CONTROL VALVE NO. PV51	PMT	1Y												I	RRC	RRC-IROH	137377	C
2,422	HSU -51 -51X001	HSU-PV5154208J	OVERHAUL CONTROL VALVE NO.PV5154208J	PMT	2Y							H						RRC	RRC-IROH	152267	C
2,423	HSU -70 -CV	HSU-PV7000104A	INSPECT CONTROL VALVE NO. PV70	PMT	1Y										I			RRC	RRC-IROH	137166	C
2,424	HSU -70 -CV	HSU-PV7000104B	INSPECT CONTROL VALVE NO. PV70	PMT	1Y										I			RRC	RRC-IROH	137167	C
2,425	HSU -70 -CV	HSU-PV7000207	INSPECT CONTROL VALVE NO. PV70	PMT	1Y										I			RRC	RRC-IROH	137168	C
2,426	HSU -70 -CV	HSU-PV7000401A	INSPECT CONTROL VALVE NO. PV70	PMT	1Y										I			RRC	RRC-IROH	137169	C
2,427	HSU -70 -CV	HSU-PV7000401B	INSPECT CONTROL VALVE NO. PV70	PMT	1Y										I			RRC	RRC-IROH	137170	C
2,428	HSU -70 -CV	HSU-PV7000601	INSPECT CONTROL VALVE NO. PV70	PMT	1Y										I			RRC	RRC-IROH	137171	C
2,429	HSU -70 -CV	HSU-PV7000801A	INSPECT CONTROL VALVE NO. PV70	PMT	1Y										I			RRC	RRC-IROH	137172	C
2,430	HSU -70 -CV	HSU-PV7000801B	INSPECT CONTROL VALVE NO. PV70	PMT	1Y										I			RRC	RRC-IROH	137173	C
2,431	HSU -71 -CV	HSU-PV7100101A	INSPECT CONTROL VALVE NO. PV71	PMT	1Y										I			RRC	RRC-IROH	137174	C
2,432	HSU -71 -CV	HSU-PV7100101B	INSPECT CONTROL VALVE NO. PV71	PMT	1Y										I			RRC	RRC-IROH	137175	C
2,433	HSU -71 -CV	HSU-PV7100301	INSPECT CONTROL VALVE NO. PV71	PMT	1Y										I			RRC	RRC-IROH	137176	C
2,434	HSU -71 -CV	HSU-PV7100401A	INSPECT CONTROL VALVE NO. PV71	PMT	1Y										I			RRC	RRC-IROH	137177	C
2,435	HSU -71 -CV	HSU-PV7100401B	INSPECT CONTROL VALVE NO. PV71	PMT	1Y										I			RRC	RRC-IROH	137178	C
2,436	HSU -71 -CV	HSU-PV7100801A	INSPECT CONTROL VALVE NO. PV71	PMT	1Y										I			RRC	RRC-IROH	137179	C
2,437	HSU -71 -CV	HSU-PV7100801B	INSPECT CONTROL VALVE NO. PV71	PMT	1Y										I			RRC	RRC-IROH	137180	C
2,438	HSU -72 -CV	HSU-PV7202901	INSPECT CONTROL VALVE NO. PV72	PMT	1Y											I		RRC	RRC-IROH	137181	C
2,439	HSU -72 -CV	HSU-PV7203003	INSPECT CONTROL VALVE NO. PV72	PMT	1Y											I		RRC	RRC-IROH	137182	C
2,440	HSU -72 -CV	HSU-PV7203503	INSPECT CONTROL VALVE NO. PV72	PMT	1Y											I		RRC	RRC-IROH	137183	C
2,441	HSU -72 -CV	HSU-PV7205901	INSPECT CONTROL VALVE NO. PV72	PMT	1Y											I		RRC	RRC-IROH	137184	C
2,442	HSU -72 -CV	HSU-PV7206003	INSPECT CONTROL VALVE NO. PV72	PMT	1Y											I		RRC	RRC-IROH	137185	C
2,443	HSU -72 -CV	HSU-PV7207901	INSPECT CONTROL VALVE NO. PV72	PMT	1Y											I		RRC	RRC-IROH	137186	C
2,444	HSU -72 -CV	HSU-PV7208003	INSPECT CONTROL VALVE NO. PV72	PMT	1Y											I		RRC	RRC-IROH	137187	C
2,445	HSU -72 -CV	HSU-PV7231303	INSPECT CONTROL VALVE NO. PV72	PMT	1Y											I		RRC	RRC-IROH	137188	C
2,446	HSU -72 -CV	HSU-PV7234102	INSPECT CONTROL VALVE NO. PV72	PMT	1Y											I		RRC	RRC-IROH	137189	C
2,447	HSU -72 -CV	HSU-PV7234107	INSPECT CONTROL VALVE NO. PV72	PMT	1Y											I		RRC	RRC-IROH	137190	C
2,448	HSU -72 -CV	HSU-PV7235106A	INSPECT CONTROL VALVE NO. PV72	PMT	1Y											I		RRC	RRC-IROH	137191	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,449	HSU -72 -CV	HSU-PV7235106B	INSPECT CONTROL VALVE NO. PV72	PMT	1Y											I		RRC	RRC-IROH	137192	C
2,450	HSU -72 -CV	HSU-PV7237104A	INSPECT CONTROL VALVE NO. PV72	PMT	1Y											I		RRC	RRC-IROH	137193	C
2,451	HSU -72 -CV	HSU-PV7237104B	INSPECT CONTROL VALVE NO. PV72	PMT	1Y											I		RRC	RRC-IROH	137194	C
2,452	HSU -73 -CV	HSU-PV7300503	INSPECT CONTROL VALVE NO. PV73	PMT	1Y											I		RRC	RRC-IROH	137195	C
2,453	HSU -73 -CV	HSU-PV7300603	INSPECT CONTROL VALVE NO. PV73	INS	1Y											I		RRC	RRC-IROH	137196	C
2,454	HSU -73 -CV	HSU-PV7300603	PV7300603-FULL FUNC TEST CONTR	PMT	5Y											F		RRC	RRC-IROH	260361	C
2,455	HSU -73 -CV	HSU-PV7301401	INSPECT CONTROL VALVE NO. PV73	PMT	1Y											I		RRC	RRC-IROH	137197	C
2,456	HSU -73 -CV	HSU-PV7301502	INSPECT CONTROL VALVE NO. PV73	PMT	1Y											I		RRC	RRC-IROH	137198	C
2,457	HSU -73 -CV	HSU-PV7301806A	INSPECT CONTROL VALVE NO. PV73	PMT	1Y											I		RRC	RRC-IROH	137199	C
2,458	HSU -73 -CV	HSU-PV7301806B	INSPECT CONTROL VALVE NO. PV73	PMT	1Y											I		RRC	RRC-IROH	137200	C
2,459	HSU -70 -70T001	HSU-PVSV7000201	PM; FOR Breather Valve HSU-PVSV7000201	PMT	6M					P						P		RRC	RRC-MROH	254609	A
2,460	HSU -70 -70T002	HSU-PVSV7000601	PM; FOR Breather Valve HSU-PVSV7000601	PMT	6M					P						P		RRC	RRC-MROH	254610	A
2,461	HSU -71 -71T002	HSU-PVSV7000901	Pressure Relief Device Calibra	PMT	5Y							I						RRC	RRC-MROH	163581	A
2,462	HSU -71 -71T002	HSU-PVSV7000901	PM; FOR Breather Valve HSU-PVSV7000901	PMT	6M					P						P		RRC	RRC-MROH	254612	A
2,463	HSU -71 -71T001	HSU-PVSV7100501	PM; FOR Breather Valve HSU-PVSV7100501	PMT	6M					P						P		RRC	RRC-MROH	254611	A
2,464	HSU -51 -SIS	HSU-SIS	INSPECT ESD SYSTEM	PMT	3M	I			I			I			I			CCS	CCS-SYS	246479	A
2,465	HSU -51 -SIS	HSU-SIS	BACKUP ESD SYSTEM	PMT	6M	I						I						CCS	CCS-SYS	246480	A
2,466	HSU -51 -SIS	HSU-SIS	UPDATE ANTIVIRUS ESD SYSTEM	PMT	3M	U			U			U			U			CCS	CCS-SYS	246481	A
2,467	HSU -51 -51K004A	HSU-TCV5151201	INSPECT CONTROL VALVE NO. TCV5	PMT	1Y												I	RRC	RRC-IROH	137307	C
2,468	HSU -51 -51K004B	HSU-TCV5152101	INSPECT CONTROL VALVE NO. TCV5	PMT	1Y												I	RRC	RRC-IROH	137308	C
2,469	HSU -51 -TEMP	HSU-TT5100901	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136766	C
2,470	HSU -51 -TEMP	HSU-TT5101001	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136767	C
2,471	HSU -51 -TEMP	HSU-TT5101002	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136768	C
2,472	HSU -51 -TEMP	HSU-TT5101003	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136769	C
2,473	HSU -51 -TEMP	HSU-TT5101004	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136770	C
2,474	HSU -51 -TEMP	HSU-TT5101020	INSP. FIELD INST. (ต่อกุปกรณ์)	INS	1Y							I						RRC	RRC-IROH	136771	C
2,475	HSU -51 -TEMP	HSU-TT5101020	TT5101020-FULLFUN TEST TEMP.TR	PMT	5Y											F		RRC	RRC-IROH	261379	C
2,476	HSU -51 -TEMP	HSU-TT5101021	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136772	C
2,477	HSU -51 -TEMP	HSU-TT5101101	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136773	C
2,478	HSU -51 -TEMP	HSU-TT5101102	INSP. FIELD INST. (ต่อกุปกรณ์)	INS	1Y							I						RRC	RRC-IROH	136774	C
2,479	HSU -51 -TEMP	HSU-TT5101102	TT5101102-FULLFUN TEST TEMP.TR	PMT	5Y											F		RRC	RRC-IROH	261380	C
2,480	HSU -51 -TEMP	HSU-TT5101103	INSP. FIELD INST. (ต่อกุปกรณ์)	INS	1Y							I						RRC	RRC-IROH	136775	C
2,481	HSU -51 -TEMP	HSU-TT5101103	TT5101103-FULLFUN TEST TEMP.TR	PMT	5Y											F		RRC	RRC-IROH	261381	C
2,482	HSU -51 -TEMP	HSU-TT5101104	INSP. FIELD INST. (ต่อกุปกรณ์)	INS	1Y							I						RRC	RRC-IROH	136776	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,483	HSU -51 -TEMP	HSU-TT5101104	TT5101104-FULLFUN TEST TEMP.TR	PMT	5Y											F		RRC	RRC-IROH	261382	C
2,484	HSU -51 -TEMP	HSU-TT5101105	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136777	C
2,485	HSU -51 -TEMP	HSU-TT5101201	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136778	C
2,486	HSU -51 -TEMP	HSU-TT5101201	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136782	C
2,487	HSU -51 -TEMP	HSU-TT5101204	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136779	C
2,488	HSU -51 -TEMP	HSU-TT5101205	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136780	C
2,489	HSU -51 -TEMP	HSU-TT5101206	INSP. FIELD INST. (ต่อกุปกรณ์)	INS	1Y							I						RRC	RRC-IROH	136781	C
2,490	HSU -51 -TEMP	HSU-TT5101206	TT5101206-FULLFUN TEST TEMP.TR	PMT	5Y											F		RRC	RRC-IROH	261388	C
2,491	HSU -51 -51B012	HSU-TT5101207	INSP. FIELD INST. (ต่อกุปกรณ์)	INS	1Y									I				RRC	RRC-IROH	136978	C
2,492	HSU -51 -51B012	HSU-TT5101207	TT5101207-FULLFUN TEST TEMP.TR	PMT	5Y											F		RRC	RRC-IROH	261387	C
2,493	HSU -51 -51B012	HSU-TT5101208	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y									I				RRC	RRC-IROH	136979	C
2,494	HSU -51 -TEMP	HSU-TT5101220	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136783	C
2,495	HSU -51 -TEMP	HSU-TT5101302	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136784	C
2,496	HSU -51 -TEMP	HSU-TT5101401	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136785	C
2,497	HSU -51 -TEMP	HSU-TT5101501	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136786	C
2,498	HSU -51 -TEMP	HSU-TT5101502	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136787	C
2,499	HSU -51 -TEMP	HSU-TT5101503	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136788	C
2,500	HSU -51 -TEMP	HSU-TT5101504	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136789	C
2,501	HSU -51 -TEMP	HSU-TT5101505	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136790	C
2,502	HSU -51 -TEMP	HSU-TT5101506	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136791	C
2,503	HSU -51 -TEMP	HSU-TT5101507	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136792	C
2,504	HSU -51 -TEMP	HSU-TT5101601	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136793	C
2,505	HSU -51 -TEMP	HSU-TT5101603	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136794	C
2,506	HSU -51 -TEMP	HSU-TT5101604	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136795	C
2,507	HSU -51 -TEMP	HSU-TT5101701	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136796	C
2,508	HSU -51 -TEMP	HSU-TT5101702	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136797	C
2,509	HSU -51 -TEMP	HSU-TT5101703	INSP. FIELD INST. (ต่อกุปกรณ์)	INS	1Y							I						RRC	RRC-IROH	136798	C
2,510	HSU -51 -TEMP	HSU-TT5101703	TT5101703-FULLFUN TEST TEMP.TR	PMT	5Y											F		RRC	RRC-IROH	261383	C
2,511	HSU -51 -TEMP	HSU-TT5101801	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136799	C
2,512	HSU -51 -TEMP	HSU-TT5101802	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136800	C
2,513	HSU -51 -TEMP	HSU-TT5101803	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136801	C
2,514	HSU -51 -TEMP	HSU-TT5101804	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IROH	136802	C
2,515	HSU -51 -TEMP	HSU-TT5101805	INSP. FIELD INST. (ต่อกุปกรณ์)	INS	1Y							I						RRC	RRC-IROH	136803	C
2,516	HSU -51 -TEMP	HSU-TT5101805	TT5101805-FULLFUN TEST TEMP.TR	PMT	5Y											F		RRC	RRC-IROH	261384	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,517	HSU -51 -TEMP	HSU-TT5101901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136804	C
2,518	HSU -51 -TEMP	HSU-TT5102101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136805	C
2,519	HSU -51 -TEMP	HSU-TT5102102	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y							I						RRC	RRC-IROH	136806	C
2,520	HSU -51 -TEMP	HSU-TT5102102	TT5102102-FULLFUN TEST TEMP.TR	PMT	5Y											F		RRC	RRC-IROH	261385	C
2,521	HSU -51 -TEMP	HSU-TT5102201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136807	C
2,522	HSU -51 -TEMP	HSU-TT5102202	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y							I						RRC	RRC-IROH	136808	C
2,523	HSU -51 -TEMP	HSU-TT5102202	TT5102202-FULLFUN TEST TEMP.TR	PMT	5Y											F		RRC	RRC-IROH	261386	C
2,524	HSU -51 -TEMP	HSU-TT5102211	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136809	C
2,525	HSU -51 -TEMP	HSU-TT5102301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136810	C
2,526	HSU -51 -TEMP	HSU-TT5102305	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136811	C
2,527	HSU -51 -TEMP	HSU-TT5102306	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136812	C
2,528	HSU -51 -TEMP	HSU-TT5102401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136813	C
2,529	HSU -51 -TEMP	HSU-TT5102601	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y							I						RRC	RRC-IROH	136814	C
2,530	HSU -51 -TEMP	HSU-TT5102601	TT5102601-FULLFUN TEST TEMP.TR	PMT	5Y											F		RRC	RRC-IROH	261389	C
2,531	HSU -51 -TEMP	HSU-TT5102602	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y							I						RRC	RRC-IROH	136815	C
2,532	HSU -51 -TEMP	HSU-TT5102602	TT5102602-FULLFUN TEST TEMP.TR	PMT	5Y											F		RRC	RRC-IROH	261390	C
2,533	HSU -51 -TEMP	HSU-TT5102603	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136816	C
2,534	HSU -51 -TEMP	HSU-TT5130102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136817	C
2,535	HSU -51 -TEMP	HSU-TT5131101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136818	C
2,536	HSU -51 -TEMP	HSU-TT5134102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136819	C
2,537	HSU -51 -TEMP	HSU-TT5134107	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136820	C
2,538	HSU -51 -TEMP	HSU-TT5150101A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136821	C
2,539	HSU -51 -TEMP	HSU-TT5150101B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136822	C
2,540	HSU -51 -TEMP	HSU-TT5150101C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136823	C
2,541	HSU -51 -TEMP	HSU-TT5150102A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136824	C
2,542	HSU -51 -TEMP	HSU-TT5150102B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136825	C
2,543	HSU -51 -TEMP	HSU-TT5150102C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136826	C
2,544	HSU -51 -TEMP	HSU-TT5150103A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136827	C
2,545	HSU -51 -TEMP	HSU-TT5150103B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136828	C
2,546	HSU -51 -TEMP	HSU-TT5150103C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136829	C
2,547	HSU -51 -TEMP	HSU-TT5150104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136830	C
2,548	HSU -51 -TEMP	HSU-TT5150105	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136831	C
2,549	HSU -51 -TEMP	HSU-TT5150205	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136832	C
2,550	HSU -51 -TEMP	HSU-TT5150206	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136833	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,551	HSU -51 -TEMP	HSU-TT5150207	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136834	C
2,552	HSU -51 -TEMP	HSU-TT5150208	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136835	C
2,553	HSU -51 -TEMP	HSU-TT5150209	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136836	C
2,554	HSU -51 -TEMP	HSU-TT5150210	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136837	C
2,555	HSU -51 -TEMP	HSU-TT5150211	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136838	C
2,556	HSU -51 -TEMP	HSU-TT5150212	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136839	C
2,557	HSU -51 -TEMP	HSU-TT5150213	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136840	C
2,558	HSU -51 -TEMP	HSU-TT5150215	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136841	C
2,559	HSU -51 -TEMP	HSU-TT5150301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136842	C
2,560	HSU -51 -TEMP	HSU-TT5150302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136843	C
2,561	HSU -51 -TEMP	HSU-TT5150401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136844	C
2,562	HSU -51 -TEMP	HSU-TT5150501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136845	C
2,563	HSU -51 -TEMP	HSU-TT5150601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136846	C
2,564	HSU -51 -TEMP	HSU-TT5150602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136847	C
2,565	HSU -51 -TEMP	HSU-TT5150801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136848	C
2,566	HSU -51 -TEMP	HSU-TT5150802	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136849	C
2,567	HSU -51 -51K004A	HSU-TT5151102A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136983	C
2,568	HSU -51 -51K004A	HSU-TT5151102B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136985	C
2,569	HSU -51 -51K004A	HSU-TT5151102C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136987	C
2,570	HSU -51 -51K004A	HSU-TT5151103A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136989	C
2,571	HSU -51 -51K004A	HSU-TT5151103B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136991	C
2,572	HSU -51 -51K004A	HSU-TT5151103C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136993	C
2,573	HSU -51 -51K004A	HSU-TT5151202	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136995	C
2,574	HSU -51 -51K004A	HSU-TT5151501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136997	C
2,575	HSU -51 -51K004A	HSU-TT5151503	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136999	C
2,576	HSU -51 -51K004B	HSU-TT5152002A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136984	C
2,577	HSU -51 -51K004B	HSU-TT5152002B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136986	C
2,578	HSU -51 -51K004B	HSU-TT5152002C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136988	C
2,579	HSU -51 -51K004B	HSU-TT5152003A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136990	C
2,580	HSU -51 -51K004B	HSU-TT5152003B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136992	C
2,581	HSU -51 -51K004B	HSU-TT5152003C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136994	C
2,582	HSU -51 -51K004B	HSU-TT5152102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136996	C
2,583	HSU -51 -51K004B	HSU-TT5152401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136998	C
2,584	HSU -51 -51K004B	HSU-TT5152403	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	137000	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,585	HSU -51 -51K005	HSU-TT5153002A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137001	C
2,586	HSU -51 -51K005	HSU-TT5153002B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137002	C
2,587	HSU -51 -51K005	HSU-TT5153002C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137003	C
2,588	HSU -51 -51K005	HSU-TT5153004A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137004	C
2,589	HSU -51 -51K005	HSU-TT5153004B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137005	C
2,590	HSU -51 -51K005	HSU-TT5153004C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137006	C
2,591	HSU -51 -51K005	HSU-TT5153102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137007	C
2,592	HSU -51 -51K005	HSU-TT5153301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137008	C
2,593	HSU -51 -51K005	HSU-TT5153302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137009	C
2,594	HSU -70 -TEMP	HSU-TT7000201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136850	C
2,595	HSU -70 -TEMP	HSU-TT7000301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136851	C
2,596	HSU -70 -TEMP	HSU-TT7000302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136852	C
2,597	HSU -70 -TEMP	HSU-TT7000307	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136853	C
2,598	HSU -70 -TEMP	HSU-TT7000308	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136854	C
2,599	HSU -70 -TEMP	HSU-TT7000401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136855	C
2,600	HSU -70 -TEMP	HSU-TT7000402	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136856	C
2,601	HSU -70 -TEMP	HSU-TT7000403	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136857	C
2,602	HSU -70 -TEMP	HSU-TT7000501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136858	C
2,603	HSU -70 -TEMP	HSU-TT7000506	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136859	C
2,604	HSU -70 -TEMP	HSU-TT7000701	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136860	C
2,605	HSU -70 -TEMP	HSU-TT7031101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136861	C
2,606	HSU -70 -TEMP	HSU-TT7034101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136862	C
2,607	HSU -71 -TEMP	HSU-TT7100102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136863	C
2,608	HSU -71 -TEMP	HSU-TT7100201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136864	C
2,609	HSU -71 -TEMP	HSU-TT7100202	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136865	C
2,610	HSU -71 -TEMP	HSU-TT7100204	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IROH	136866	C
2,611	HSU -71 -TEMP	HSU-TT7100301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136867	C
2,612	HSU -71 -TEMP	HSU-TT7100302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136868	C
2,613	HSU -71 -TEMP	HSU-TT7100303	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136869	C
2,614	HSU -71 -TEMP	HSU-TT7100306	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136870	C
2,615	HSU -71 -TEMP	HSU-TT7100401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136871	C
2,616	HSU -71 -TEMP	HSU-TT7100403	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136872	C
2,617	HSU -71 -TEMP	HSU-TT7100501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136873	C
2,618	HSU -71 -TEMP	HSU-TT7100701	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136874	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,619	HSU -72 -TEMP	HSU-TT7202005	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136875	C
2,620	HSU -72 -TEMP	HSU-TT7202006	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136876	C
2,621	HSU -72 -TEMP	HSU-TT7202007	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136877	C
2,622	HSU -72 -TEMP	HSU-TT7202301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136878	C
2,623	HSU -72 -TEMP	HSU-TT7202302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136879	C
2,624	HSU -72 -TEMP	HSU-TT7202401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136880	C
2,625	HSU -72 -TEMP	HSU-TT7202403	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136881	C
2,626	HSU -72 -TEMP	HSU-TT7202405	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136882	C
2,627	HSU -72 -TEMP	HSU-TT7202407	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136883	C
2,628	HSU -72 -TEMP	HSU-TT7202701	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136884	C
2,629	HSU -72 -TEMP	HSU-TT7202802	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	136972	C
2,630	HSU -72 -TEMP	HSU-TT7202803	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	136973	C
2,631	HSU -72 -TEMP	HSU-TT7202901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136885	C
2,632	HSU -72 -TEMP	HSU-TT7203001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136886	C
2,633	HSU -72 -TEMP	HSU-TT7203102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136887	C
2,634	HSU -72 -TEMP	HSU-TT7203104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136888	C
2,635	HSU -72 -TEMP	HSU-TT7203111	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136889	C
2,636	HSU -72 -TEMP	HSU-TT7203112	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136890	C
2,637	HSU -72 -TEMP	HSU-TT7203201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136891	C
2,638	HSU -72 -TEMP	HSU-TT7203401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136892	C
2,639	HSU -72 -TEMP	HSU-TT7203405	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136893	C
2,640	HSU -72 -TEMP	HSU-TT7203406	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136894	C
2,641	HSU -72 -TEMP	HSU-TT7203407	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136895	C
2,642	HSU -72 -TEMP	HSU-TT7203501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136896	C
2,643	HSU -72 -TEMP	HSU-TT7203502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136897	C
2,644	HSU -72 -TEMP	HSU-TT7203503	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IROH	136898	C
2,645	HSU -72 -TEMP	HSU-TT7203503	TT7203503-FULLFUN TEST TEMP.TR	PMT	5Y											F		RRC	RRC-IROH	261391	C
2,646	HSU -72 -TEMP	HSU-TT7203504	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136899	C
2,647	HSU -72 -TEMP	HSU-TT7203505	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136900	C
2,648	HSU -72 -TEMP	HSU-TT7203506	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136901	C
2,649	HSU -72 -TEMP	HSU-TT7203601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136902	C
2,650	HSU -72 -TEMP	HSU-TT7203602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136903	C
2,651	HSU -72 -TEMP	HSU-TT7203605	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136904	C
2,652	HSU -72 -TEMP	HSU-TT7205701	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136905	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,653	HSU -72 -TEMP	HSU-TT7205802	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	136974	C
2,654	HSU -72 -TEMP	HSU-TT7205803	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	136975	C
2,655	HSU -72 -TEMP	HSU-TT7205901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136906	C
2,656	HSU -72 -TEMP	HSU-TT7206001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136907	C
2,657	HSU -72 -TEMP	HSU-TT7206102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136908	C
2,658	HSU -72 -TEMP	HSU-TT7206104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136909	C
2,659	HSU -72 -TEMP	HSU-TT7206111	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136910	C
2,660	HSU -72 -TEMP	HSU-TT7206112	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136911	C
2,661	HSU -72 -TEMP	HSU-TT7206201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136912	C
2,662	HSU -72 -TEMP	HSU-TT7207701	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136913	C
2,663	HSU -72 -TEMP	HSU-TT7207802	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	136976	C
2,664	HSU -72 -TEMP	HSU-TT7207803	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	136977	C
2,665	HSU -72 -TEMP	HSU-TT7207901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136914	C
2,666	HSU -72 -TEMP	HSU-TT7208001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136915	C
2,667	HSU -72 -TEMP	HSU-TT7208102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136916	C
2,668	HSU -72 -TEMP	HSU-TT7208104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136917	C
2,669	HSU -72 -TEMP	HSU-TT7208111	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136918	C
2,670	HSU -72 -TEMP	HSU-TT7208112	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136919	C
2,671	HSU -72 -TEMP	HSU-TT7208201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136920	C
2,672	HSU -72 -TEMP	HSU-TT7230102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136921	C
2,673	HSU -72 -TEMP	HSU-TT7231102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136922	C
2,674	HSU -72 -TEMP	HSU-TT7231302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136923	C
2,675	HSU -72 -TEMP	HSU-TT7232103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136924	C
2,676	HSU -72 -TEMP	HSU-TT7232201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136925	C
2,677	HSU -72 -TEMP	HSU-TT7234102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136926	C
2,678	HSU -72 -TEMP	HSU-TT7234104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136927	C
2,679	HSU -72 -TEMP	HSU-TT7235106	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136928	C
2,680	HSU -72 -72K101	HSU-TT7250101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137010	C
2,681	HSU -72 -72K101	HSU-TT7250102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137014	C
2,682	HSU -72 -72K101	HSU-TT7250103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137018	C
2,683	HSU -72 -72K101	HSU-TT7250104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137022	C
2,684	HSU -72 -72K101	HSU-TT7250105	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137026	C
2,685	HSU -72 -72K101	HSU-TT7250117	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137030	C
2,686	HSU -72 -72K201	HSU-TT7250601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137011	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,687	HSU -72 -72K201	HSU-TT7250602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137015	C
2,688	HSU -72 -72K201	HSU-TT7250603	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137019	C
2,689	HSU -72 -72K201	HSU-TT7250604	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137023	C
2,690	HSU -72 -72K201	HSU-TT7250605	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137027	C
2,691	HSU -72 -72K201	HSU-TT7250617	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137031	C
2,692	HSU -72 -72K301	HSU-TT7251101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137012	C
2,693	HSU -72 -72K301	HSU-TT7251102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137016	C
2,694	HSU -72 -72K301	HSU-TT7251103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137020	C
2,695	HSU -72 -72K301	HSU-TT7251104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137024	C
2,696	HSU -72 -72K301	HSU-TT7251105	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137028	C
2,697	HSU -72 -72K301	HSU-TT7251117	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137032	C
2,698	HSU -72 -72K601	HSU-TT7251601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137013	C
2,699	HSU -72 -72K601	HSU-TT7251602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137017	C
2,700	HSU -72 -72K601	HSU-TT7251603	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137021	C
2,701	HSU -72 -72K601	HSU-TT7251604	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137025	C
2,702	HSU -72 -72K601	HSU-TT7251605	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137029	C
2,703	HSU -72 -72K601	HSU-TT7251617	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IROH	137033	C
2,704	HSU -72 -TEMP	HSU-TT7252101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136929	C
2,705	HSU -73 -TEMP	HSU-TT7300101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136930	C
2,706	HSU -73 -TEMP	HSU-TT7300201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136931	C
2,707	HSU -73 -TEMP	HSU-TT7300202	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136932	C
2,708	HSU -73 -73B404	HSU-TT7300203	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y									I				RRC	RRC-IROH	136980	C
2,709	HSU -73 -73B404	HSU-TT7300203	TT7300203-FULLFUN TEST TEMP.TR	PMT	5Y											F		RRC	RRC-IROH	261395	C
2,710	HSU -73 -73B404	HSU-TT7300204	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y									I				RRC	RRC-IROH	136981	C
2,711	HSU -73 -73B404	HSU-TT7300204	TT7300204-FULL FUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261396	C
2,712	HSU -73 -73B404	HSU-TT7300205	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y									I				RRC	RRC-IROH	136982	C
2,713	HSU -73 -73B404	HSU-TT7300205	TT7300205-FULLFUN TEST TEMP.TR	PMT	5Y											F		RRC	RRC-IROH	261397	C
2,714	HSU -73 -TEMP	HSU-TT7300301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136933	C
2,715	HSU -73 -TEMP	HSU-TT7300302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136934	C
2,716	HSU -73 -TEMP	HSU-TT7300401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136935	C
2,717	HSU -73 -TEMP	HSU-TT7300402	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136936	C
2,718	HSU -73 -TEMP	HSU-TT7300501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136937	C
2,719	HSU -73 -TEMP	HSU-TT7300601A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IROH	136938	C
2,720	HSU -73 -TEMP	HSU-TT7300601A	TT7300601A-FULLFUN TEST TEMP.T	PMT	5Y												F	RRC	RRC-IROH	261392	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,721	HSU -73 -TEMP	HSU-TT7300601B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IROH	136939	C
2,722	HSU -73 -TEMP	HSU-TT7300601B	TT7300601B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261393	C
2,723	HSU -73 -TEMP	HSU-TT7300601C	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IROH	136940	C
2,724	HSU -73 -TEMP	HSU-TT7300601C	TT7300601C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261394	C
2,725	HSU -73 -TEMP	HSU-TT7300603	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136941	C
2,726	HSU -73 -TEMP	HSU-TT7300703	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136942	C
2,727	HSU -73 -TEMP	HSU-TT7300708	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136943	C
2,728	HSU -73 -TEMP	HSU-TT7300710	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136944	C
2,729	HSU -73 -TEMP	HSU-TT7300801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136945	C
2,730	HSU -73 -TEMP	HSU-TT7300802	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136946	C
2,731	HSU -73 -TEMP	HSU-TT7301301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136947	C
2,732	HSU -73 -TEMP	HSU-TT7301302A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IROH	136948	C
2,733	HSU -73 -TEMP	HSU-TT7301302A	TT7301302A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261398	C
2,734	HSU -73 -TEMP	HSU-TT7301302B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IROH	136949	C
2,735	HSU -73 -TEMP	HSU-TT7301302B	TT7301302B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261399	C
2,736	HSU -73 -TEMP	HSU-TT7301302C	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IROH	136950	C
2,737	HSU -73 -TEMP	HSU-TT7301302C	TT7301302C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261400	C
2,738	HSU -73 -TEMP	HSU-TT7301403	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136951	C
2,739	HSU -73 -TEMP	HSU-TT7301404	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136952	C
2,740	HSU -73 -TEMP	HSU-TT7301405	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136953	C
2,741	HSU -73 -TEMP	HSU-TT7301406	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136954	C
2,742	HSU -73 -TEMP	HSU-TT7301407	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136955	C
2,743	HSU -73 -TEMP	HSU-TT7301408	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136956	C
2,744	HSU -73 -TEMP	HSU-TT7301409	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136957	C
2,745	HSU -73 -TEMP	HSU-TT7301410	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136958	C
2,746	HSU -73 -TEMP	HSU-TT7301411	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136959	C
2,747	HSU -73 -TEMP	HSU-TT7301601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136960	C
2,748	HSU -73 -TEMP	HSU-TT7301606	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136961	C
2,749	HSU -73 -TEMP	HSU-TT7301701	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136962	C
2,750	HSU -73 -TEMP	HSU-TT7301703	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136963	C
2,751	HSU -73 -TEMP	HSU-TT7301704	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136964	C
2,752	HSU -73 -TEMP	HSU-TT7301706	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136965	C
2,753	HSU -73 -TEMP	HSU-TT7301802	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136966	C
2,754	HSU -73 -TEMP	HSU-TT7301803	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136967	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,755	HSU -73 -TEMP	HSU-TT7301906	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136968	C
2,756	HSU -73 -TEMP	HSU-TT7302101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136969	C
2,757	HSU -73 -TEMP	HSU-TT7302102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136970	C
2,758	HSU -73 -TEMP	HSU-TT7302202	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IROH	136971	C
2,759	HSU -51 -CV	HSU-TV5101101	INSPECT CONTROL VALVE NO. TV51	PMT	1Y									I				RRC	RRC-IROH	137201	C
2,760	HSU -51 -CV	HSU-TV5101301	INSPECT CONTROL VALVE NO. TV51	PMT	1Y									I				RRC	RRC-IROH	137202	C
2,761	HSU -51 -CV	HSU-TV5101302	INSPECT CONTROL VALVE NO. TV51	PMT	1Y									I				RRC	RRC-IROH	137203	C
2,762	HSU -51 -CV	HSU-TV5101601	INSPECT CONTROL VALVE NO. TV51	PMT	1Y									I				RRC	RRC-IROH	137204	C
2,763	HSU -51 -CV	HSU-TV5150214	INSPECT CONTROL VALVE NO. TV51	PMT	1Y									I				RRC	RRC-IROH	137205	C
2,764	HSU -51 -CV	HSU-TV5150216	INSPECT CONTROL VALVE NO. TV51	PMT	1Y									I				RRC	RRC-IROH	137206	C
2,765	HSU -51 -51B001	HSU-TV5150301	INSPECT CONTROL VALVE NO. TV51	PMT	1Y										I			RRC	RRC-IROH	137305	C
2,766	HSU -72 -CV	HSU-TV7203401	INSPECT CONTROL VALVE NO. TV72	PMT	1Y									I				RRC	RRC-IROH	137207	C
2,767	HSU -73 -CV	HSU-TV7301410	INSPECT CONTROL VALVE NO. TV73	PMT	1Y									I				RRC	RRC-IROH	137208	C
2,768	HSU -51 -CV	HSU-XV5100901	INSPECT CONTROL VALVE NO. XV51	INS	1Y									I				RRC	RRC-IROH	137227	C
2,769	HSU -51 -CV	HSU-XV5100901	XV5100901-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261493	C
2,770	HSU -51 -CV	HSU-XV5100902	INSPECT CONTROL VALVE NO. XV51	PMT	1Y											F		RRC	RRC-IROH	137228	C
2,771	HSU -51 -CV	HSU-XV5101001	INSPECT CONTROL VALVE NO. XV51	INS	1Y									I				RRC	RRC-IROH	137229	C
2,772	HSU -51 -CV	HSU-XV5101001	XV5101001-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261496	C
2,773	HSU -51 -CV	HSU-XV5101002	INSPECT CONTROL VALVE NO. XV51	INS	1Y									I				RRC	RRC-IROH	137230	C
2,774	HSU -51 -CV	HSU-XV5101002	XV5101002-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261494	C
2,775	HSU -51 -CV	HSU-XV5101003	INSPECT CONTROL VALVE NO. XV51	INS	1Y									I				RRC	RRC-IROH	137231	C
2,776	HSU -51 -CV	HSU-XV5101003	XV5101003-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261495	C
2,777	HSU -51 -CV	HSU-XV5101701	INSPECT CONTROL VALVE NO. XV51	PMT	1Y									I				RRC	RRC-IROH	137232	C
2,778	HSU -51 -CV	HSU-XV5101801	INSPECT CONTROL VALVE NO. XV51	INS	1Y									I				RRC	RRC-IROH	137233	C
2,779	HSU -51 -CV	HSU-XV5101801	XV5101801-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261498	C
2,780	HSU -51 -CV	HSU-XV5101802	INSPECT CONTROL VALVE NO. XV51	INS	1Y									I				RRC	RRC-IROH	137234	C
2,781	HSU -51 -CV	HSU-XV5101802	XV5101802-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261497	C
2,782	HSU -51 -CV	HSU-XV5101803	INSPECT CONTROL VALVE NO. XV51	INS	1Y									I				RRC	RRC-IROH	137235	C
2,783	HSU -51 -CV	HSU-XV5101803	XV5101803-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261499	C
2,784	HSU -51 -CV	HSU-XV5101804	INSPECT CONTROL VALVE NO. XV51	INS	1Y									I				RRC	RRC-IROH	137236	C
2,785	HSU -51 -CV	HSU-XV5101804	XV5101804-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261500	C
2,786	HSU -51 -CV	HSU-XV5102401	INSPECT CONTROL VALVE NO. XV51	INS	1Y									I				RRC	RRC-IROH	137237	C
2,787	HSU -51 -CV	HSU-XV5102401	XV5102401-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261501	C
2,788	HSU -51 -CV	HSU-XV5150801	INSPECT CONTROL VALVE NO. XV51	PMT	1Y									I				RRC	RRC-IROH	137238	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,789	HSU -51 -CV	HSU-XV5150802	INSPECT CONTROL VALVE NO. XV51	PMT	1Y											I		RRC	RRC-IROH	137239	C
2,790	HSU -51 -CV	HSU-XV5150803	INSPECT CONTROL VALVE NO. XV51	PMT	1Y											I		RRC	RRC-IROH	137240	C
2,791	HSU -51 -CV	HSU-XV5150808	INSPECT CONTROL VALVE NO. XV51	PMT	1Y											I		RRC	RRC-IROH	137241	C
2,792	HSU -51 -CV	HSU-XV5150809	INSPECT CONTROL VALVE NO. XV51	PMT	1Y											I		RRC	RRC-IROH	137242	C
2,793	HSU -51 -CV	HSU-XV5150810	INSPECT CONTROL VALVE NO. XV51	PMT	1Y											I		RRC	RRC-IROH	137243	C
2,794	HSU -51 -CV	HSU-XV5150811	INSPECT CONTROL VALVE NO. XV51	PMT	1Y											I		RRC	RRC-IROH	137244	C
2,795	HSU -51 -CV	HSU-XV5150812	INSPECT CONTROL VALVE NO. XV51	PMT	1Y											I		RRC	RRC-IROH	137245	C
2,796	HSU -51 -CV	HSU-XV5150813	INSPECT CONTROL VALVE NO. XV51	PMT	1Y											I		RRC	RRC-IROH	137246	C
2,797	HSU -51 -CV	HSU-XV5150814	INSPECT CONTROL VALVE NO. XV51	PMT	1Y											I		RRC	RRC-IROH	137247	C
2,798	HSU -51 -CV	HSU-XV5150815	INSPECT CONTROL VALVE NO. XV51	PMT	1Y											I		RRC	RRC-IROH	137248	C
2,799	HSU -51 -CV	HSU-XV5150816	INSPECT CONTROL VALVE NO. XV51	PMT	1Y											I		RRC	RRC-IROH	137249	C
2,800	HSU -71 -CV	HSU-XV7100101	INSPECT CONTROL VALVE NO. XV71	INS	1Y											I		RRC	RRC-IROH	137250	C
2,801	HSU -71 -CV	HSU-XV7100101	XV7100101-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261502	C
2,802	HSU -71 -CV	HSU-XV7100801	INSPECT CONTROL VALVE NO. XV71	PMT	1Y											I		RRC	RRC-IROH	137251	C
2,803	HSU -72 -CV	HSU-XV7202201	INSPECT CONTROL VALVE NO. XV72	PMT	1Y											I		RRC	RRC-IROH	137252	C
2,804	HSU -72 -CV	HSU-XV7202202	INSPECT CONTROL VALVE NO. XV72	PMT	1Y											I		RRC	RRC-IROH	137253	C
2,805	HSU -72 -CV	HSU-XV7202501	INSPECT CONTROL VALVE NO. XV72	INS	1Y											I		RRC	RRC-IROH	137254	C
2,806	HSU -72 -CV	HSU-XV7202501	XV7202501-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261503	C
2,807	HSU -72 -CV	HSU-XV7202502	INSPECT CONTROL VALVE NO. XV72	INS	1Y											I		RRC	RRC-IROH	137255	C
2,808	HSU -72 -CV	HSU-XV7202502	XV7202502-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261507	C
2,809	HSU -72 -CV	HSU-XV7202503	INSPECT CONTROL VALVE NO. XV72	INS	1Y											I		RRC	RRC-IROH	137256	C
2,810	HSU -72 -CV	HSU-XV7202503	XV7202503-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261504	C
2,811	HSU -72 -CV	HSU-XV7202504	INSPECT CONTROL VALVE NO. XV72	INS	1Y											I		RRC	RRC-IROH	137257	C
2,812	HSU -72 -CV	HSU-XV7202504	XV7202504-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261505	C
2,813	HSU -72 -CV	HSU-XV7202505	INSPECT CONTROL VALVE NO. XV72	PMT	1Y											I		RRC	RRC-IROH	137258	C
2,814	HSU -72 -CV	HSU-XV7202506	INSPECT CONTROL VALVE NO. XV72	INS	1Y											I		RRC	RRC-IROH	137259	C
2,815	HSU -72 -CV	HSU-XV7202506	XV7202506-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261506	C
2,816	HSU -72 -CV	HSU-XV7202507	INSPECT CONTROL VALVE NO. XV72	PMT	1Y											I		RRC	RRC-IROH	137260	C
2,817	HSU -72 -CV	HSU-XV7202508	INSPECT CONTROL VALVE NO. XV72	PMT	1Y											I		RRC	RRC-IROH	137261	C
2,818	HSU -72 -CV	HSU-XV7202601	INSPECT CONTROL VALVE NO. XV72	PMT	1Y											I		RRC	RRC-IROH	137262	C
2,819	HSU -72 -CV	HSU-XV7202901	INSPECT CONTROL VALVE NO. XV72	PMT	1Y											I		RRC	RRC-IROH	137263	C
2,820	HSU -72 -CV	HSU-XV7203401	INSPECT CONTROL VALVE NO. XV72	PMT	1Y											I		RRC	RRC-IROH	137264	C
2,821	HSU -72 -CV	HSU-XV7203501	INSPECT CONTROL VALVE NO. XV72	INS	1Y											I		RRC	RRC-IROH	137265	C
2,822	HSU -72 -CV	HSU-XV7203501	XV7203501-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261508	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,823	HSU -72 -CV	HSU-XV7203502	INSPECT CONTROL VALVE NO. XV72	INS	1Y											I		RRC	RRC-IROH	137266	C
2,824	HSU -72 -CV	HSU-XV7203502	XV7203502-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261509	C
2,825	HSU -72 -CV	HSU-XV7203503	INSPECT CONTROL VALVE NO. XV72	INS	1Y											I		RRC	RRC-IROH	137267	C
2,826	HSU -72 -CV	HSU-XV7203503	XV7203503-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261510	C
2,827	HSU -72 -CV	HSU-XV7205501	INSPECT CONTROL VALVE NO. XV72	PMT	1Y											I		RRC	RRC-IROH	137268	C
2,828	HSU -72 -CV	HSU-XV7205502	INSPECT CONTROL VALVE NO. XV72	PMT	1Y											I		RRC	RRC-IROH	137269	C
2,829	HSU -72 -CV	HSU-XV7205503	INSPECT CONTROL VALVE NO. XV72	PMT	1Y											I		RRC	RRC-IROH	137270	C
2,830	HSU -72 -CV	HSU-XV7205504	INSPECT CONTROL VALVE NO. XV72	PMT	1Y											I		RRC	RRC-IROH	137271	C
2,831	HSU -72 -CV	HSU-XV7205505	INSPECT CONTROL VALVE NO. XV72	PMT	1Y											I		RRC	RRC-IROH	137272	C
2,832	HSU -72 -CV	HSU-XV7205506	INSPECT CONTROL VALVE NO. XV72	PMT	1Y											I		RRC	RRC-IROH	137273	C
2,833	HSU -72 -CV	HSU-XV7205507	INSPECT CONTROL VALVE NO. XV72	PMT	1Y											I		RRC	RRC-IROH	137274	C
2,834	HSU -72 -CV	HSU-XV7205508	INSPECT CONTROL VALVE NO. XV72	PMT	1Y											I		RRC	RRC-IROH	137275	C
2,835	HSU -72 -CV	HSU-XV7205601	INSPECT CONTROL VALVE NO. XV72	PMT	1Y											I		RRC	RRC-IROH	137276	C
2,836	HSU -72 -CV	HSU-XV7205901	INSPECT CONTROL VALVE NO. XV72	PMT	1Y											I		RRC	RRC-IROH	137277	C
2,837	HSU -72 -CV	HSU-XV7207501	INSPECT CONTROL VALVE NO. XV72	PMT	1Y											I		RRC	RRC-IROH	137278	C
2,838	HSU -72 -CV	HSU-XV7207502	INSPECT CONTROL VALVE NO. XV72	PMT	1Y											I		RRC	RRC-IROH	137279	C
2,839	HSU -72 -CV	HSU-XV7207503	INSPECT CONTROL VALVE NO. XV72	PMT	1Y											I		RRC	RRC-IROH	137280	C
2,840	HSU -72 -CV	HSU-XV7207504	INSPECT CONTROL VALVE NO. XV72	PMT	1Y												I	RRC	RRC-IROH	137281	C
2,841	HSU -72 -CV	HSU-XV7207505	INSPECT CONTROL VALVE NO. XV72	PMT	1Y												I	RRC	RRC-IROH	137282	C
2,842	HSU -72 -CV	HSU-XV7207506	INSPECT CONTROL VALVE NO. XV72	PMT	1Y												I	RRC	RRC-IROH	137283	C
2,843	HSU -72 -CV	HSU-XV7207507	INSPECT CONTROL VALVE NO. XV72	PMT	1Y												I	RRC	RRC-IROH	137284	C
2,844	HSU -72 -CV	HSU-XV7207508	INSPECT CONTROL VALVE NO. XV72	PMT	1Y												I	RRC	RRC-IROH	137285	C
2,845	HSU -72 -CV	HSU-XV7207601	INSPECT CONTROL VALVE NO. XV72	PMT	1Y												I	RRC	RRC-IROH	137286	C
2,846	HSU -72 -CV	HSU-XV7207901	INSPECT CONTROL VALVE NO. XV72	PMT	1Y												I	RRC	RRC-IROH	137287	C
2,847	HSU -72 -CV	HSU-XV7252101	INSPECT CONTROL VALVE NO. XV72	PMT	1Y												I	RRC	RRC-IROH	137303	C
2,848	HSU -73 -CV	HSU-XV7300101	INSPECT CONTROL VALVE NO. XV73	PMT	1Y												I	RRC	RRC-IROH	137288	C
2,849	HSU -73 -CV	HSU-XV7300201	INSPECT CONTROL VALVE NO. XV73	INS	1Y												I	RRC	RRC-IROH	137289	C
2,850	HSU -73 -CV	HSU-XV7300201	XV7300201-FULL FUNC. TEST SHUT	PMT	5Y												F	RRC	RRC-IROH	261512	C
2,851	HSU -73 -CV	HSU-XV7300202	INSPECT CONTROL VALVE NO. XV73	INS	1Y												I	RRC	RRC-IROH	137290	C
2,852	HSU -73 -CV	HSU-XV7300202	XV7300202-FULL FUNC. TEST SHUT	PMT	5Y												F	RRC	RRC-IROH	261513	C
2,853	HSU -73 -CV	HSU-XV7300401	INSPECT CONTROL VALVE NO. XV73	INS	1Y												I	RRC	RRC-IROH	137291	C
2,854	HSU -73 -CV	HSU-XV7300401	XV7300401-FULL FUNC. TEST SHUT	PMT	5Y												F	RRC	RRC-IROH	261514	C
2,855	HSU -73 -CV	HSU-XV7300801	INSPECT CONTROL VALVE NO. XV73	PMT	1Y												I	RRC	RRC-IROH	137292	C
2,856	HSU -73 -CV	HSU-XV7301101	INSPECT CONTROL VALVE NO. XV73	INS	1Y												I	RRC	RRC-IROH	137293	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,857	HSU -73 -CV	HSU-XV7301101	XV7301101-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261515	C
2,858	HSU -73 -CV	HSU-XV7301102	INSPECT CONTROL VALVE NO. XV73	PMT	1Y												I	RRC	RRC-IROH	137294	C
2,859	HSU -73 -CV	HSU-XV7301103	INSPECT CONTROL VALVE NO. XV73	INS	1Y												I	RRC	RRC-IROH	137295	C
2,860	HSU -73 -CV	HSU-XV7301103	XV7301103-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261516	C
2,861	HSU -73 -CV	HSU-XV7301104	INSPECT CONTROL VALVE NO. XV73	INS	1Y												I	RRC	RRC-IROH	137296	C
2,862	HSU -73 -CV	HSU-XV7301104	XV7301104-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261517	C
2,863	HSU -73 -CV	HSU-XV7301105	INSPECT CONTROL VALVE NO. XV73	PMT	1Y												I	RRC	RRC-IROH	137297	C
2,864	HSU -73 -CV	HSU-XV7301106	INSPECT CONTROL VALVE NO. XV73	INS	1Y												I	RRC	RRC-IROH	137298	C
2,865	HSU -73 -CV	HSU-XV7301106	XV7301106-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261518	C
2,866	HSU -73 -CV	HSU-XV7301107	INSPECT CONTROL VALVE NO. XV73	INS	1Y												I	RRC	RRC-IROH	137299	C
2,867	HSU -73 -CV	HSU-XV7301107	XV7301107-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261519	C
2,868	HSU -73 -CV	HSU-XV7301108	INSPECT CONTROL VALVE NO. XV73	PMT	1Y												I	RRC	RRC-IROH	137300	C
2,869	HSU -73 -CV	HSU-XV7301501	INSPECT CONTROL VALVE NO. XV73	PMT	1Y												I	RRC	RRC-IROH	137301	C
2,870	HSU -73 -CV	HSU-XV7301701	INSPECT CONTROL VALVE NO. XV73	INS	1Y												I	RRC	RRC-IROH	137302	C
2,871	HSU -73 -CV	HSU-XV7301701	XV7301701-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261520	C
2,872	HSU -73 -73K402A	HSU-ZSL7350601	INSPECT CONTROL VALVE NO. ZSL7	PMT	1Y												I	RRC	RRC-IROH	137309	C
2,873	HSU -73 -73K402A	HSU-ZSL7350602	INSPECT CONTROL VALVE NO. ZSL7	PMT	1Y												I	RRC	RRC-IROH	137310	C
2,874	HSU -73 -73K402B	HSU-ZSL7351101	INSPECT CONTROL VALVE NO. ZSL7	PMT	1Y												I	RRC	RRC-IROH	137311	C
2,875	HSU -73 -73K402B	HSU-ZSL7351102	INSPECT CONTROL VALVE NO. ZSL7	PMT	1Y												I	RRC	RRC-IROH	137312	C
2,876	HSU -70 -70E003A	MSS-70E003A-VSD	Inspec VSD FOR 70E003A-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254135	B
2,877	HSU -70 -70E003B	MSS-70E003B-VSD	Inspec VSD FOR 70E003B-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254136	B
2,878	HSU -70 -70E003C	MSS-70E003C-VSD	Inspec VSD FOR 70E003C-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254137	B
2,879	HSU -70 -70E003D	MSS-70E003D-VSD	Inspec VSD FOR 70E003D-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254138	B
2,880	HSU -71 -71E003A	MSS-71E003A-VSD	Inspec VSD FOR 71E003A-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254139	A
2,881	HSU -71 -71E003B	MSS-71E003B-VSD	Inspec VSD FOR 71E003B-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254140	A
2,882	HSU -71 -71E004A	MSS-71E004A-VSD	Inspec VSD FOR 71E004A-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254141	B
2,883	HSU -71 -71E004B	MSS-71E004B-VSD	Inspec VSD FOR 71E004B-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254142	B
2,884	HSU -71 -71E004C	MSS-71E004C-VSD	Inspec VSD FOR 71E004C-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254143	B
2,885	HSU -71 -71E004D	MSS-71E004D-VSD	Inspec VSD FOR 71E004D-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254144	B
2,886	HSU -51 -51K002	MSS-B2-3001-A03	INSPECT MV SWGR & CB B2-3001-A03	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-EROH	138365	A
2,887	HSU -71 -71P004A	MSS-B2-3001-A19	INSPECT MV SWGR & CB B2-3001-A19	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-EROH	138349	B
2,888	HSU -72 -72K101	MSS-B2-3001-A20	INSPECT MV SWGR & CB B2-3001-A20	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-EROH	138348	B
2,889	HSU -72 -72K301	MSS-B2-3001-A21	INSPECT MV SWGR & CB B2-3001-A21	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-EROH	138347	B
2,890	HSU -51 -51K001	MSS-B2-3001-B03	INSPECT MV SWGR & CB B2-3001-B03	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-EROH	138314	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: HSU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,891	HSU -51 -51K005	MSS-B2-3001-B04	INSPECT MV SWGR & CB B2-3001-B04	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-EROH	138315	C
2,892	HSU -71 -71P004B	MSS-B2-3001-B23	INSPECT MV SWGR & CB B2-3001-B23	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-EROH	138334	B
2,893	HSU -72 -72K201	MSS-B2-3001-B24	INSPECT MV SWGR & CB B2-3001-B24	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-EROH	138335	B
2,894	HSU -72 -72K601	MSS-B2-3001-B25	INSPECT MV SWGR & CB B2-3001-B25	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-EROH	138336	B
2,895	HSU -51 -51E006A	SS1-51E006A-VSD	Inspect VSD FOR 51E006A-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254131	B
2,896	HSU -51 -51E006B	SS1-51E006B-VSD	Inspec VSD FOR 51E006B-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254132	B
2,897	HSU -51 -51E006C	SS1-51E006C-VSD	Inspec VSD FOR 51E006C-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254133	B
2,898	HSU -51 -51E006D	SS1-51E006D-VSD	Inspec VSD FOR 51E006D-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254134	B
2,899	HSU -51 -51K004A	SS1-B7-2001-A08	INSPECT MV SWGR & CB B7-2001-A08	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-EROH	138267	B
2,900	HSU -51 -51K004B	SS1-B7-2001-B07	INSPECT MV SWGR & CB B7-2001-B07	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-EROH	138297	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1	RDCC		VB. INSP & ANALY M/C RDCC PLANT	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	150292	
2	RDCC-53 -53Q004		REGREASING BRG OF 53Q004	PMT	3M			L			L			L			L	RRC	RRC-MRCP	148916	A
3	RDCC-53 -53Q001		REGREASING BRG OF 53Q001	PMT	3M			L			L			L			L	RRC	RRC-MRCP	148904	A
4	RDCC-53 -53Q002		REGREASING BRG OF 53Q002	PMT	3M			L			L			L			L	RRC	RRC-MRCP	148908	A
5	RDCC-53 -53Q003		REGREASING BRG OF 53Q003	PMT	3M			L			L			L			L	RRC	RRC-MRCP	148912	A
6	RDCC-53 -GRD_LIGHTN		PM GND SYS (LOOP) (UNIT 53)	PMT	1Y			P										RRC	RRC-ERCP	140340	
7	RDCC-53 -GRD_LIGHTN		VISUAL GROUNDING SYS (UNIT 53)	PMT	4M			P				P				P		RRC	RRC-ERCP	141700	
8	RDCC-56 -GRD_LIGHTN		PM GND SYS (LOOP) (UNIT 56)	PMT	1Y			P										RRC	RRC-ERCP	140341	
9	RDCC-56 -GRD_LIGHTN		VISUAL GROUNDING SYS (UNIT 56)	PMT	4M			P				P				P		RRC	RRC-ERCP	141701	
10	RDCC-53 -PIPING	1-1/2-CL-53044006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169885	B
11	RDCC-53 -PIPING	1-1/2-CL-53044007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169886	B
12	RDCC-53 -PIPING	1-1/2-CL-53044011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169887	B
13	RDCC-53 -PIPING	1-1/2-CL-53044015	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169888	B
14	RDCC-53 -PIPING	1-1/2-CL-53046027	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169899	B
15	RDCC-53 -PIPING	1-1/2-P-53030005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171178	B
16	RDCC-53 -PIPING	1-1/2-P-53030018	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171182	B
17	RDCC-53 -PIPING	1-1/2-P-53031003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171186	B
18	RDCC-53 -PIPING	1-1/2-P-53031004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171187	B
19	RDCC-53 -PIPING	1-1/2-P-53031010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171193	B
20	RDCC-53 -PIPING	1-1/2-P-53031011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171194	B
21	RDCC-53 -PIPING	1-1/2-P-53075003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171413	B
22	RDCC-53 -PIPING	1-1/2-P-53075004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171414	B
23	RDCC-53 -PIPING	1-1/2-P-53075010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171420	B
24	RDCC-53 -PIPING	1-1/2-P-53075011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171421	B
25	RDCC-53 -PIPING	1-AV-53003005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169354	B
26	RDCC-53 -PIPING	1-AV-53105001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169396	B
27	RDCC-53 -PIPING	1-AV-53105002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169397	B
28	RDCC-53 -PIPING	1-CG-53045001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169528	B
29	RDCC-53 -PIPING	1-CG-53045002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169529	B
30	RDCC-53 -PIPING	1-CL-53026009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169741	B
31	RDCC-53 -PIPING	1-CL-53045301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169895	B
32	RDCC-53 -PIPING	1-CL-53045302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169896	B
33	RDCC-53 -PIPING	1-P-53030003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171176	B
34	RDCC-53 -PIPING	1-P-53032005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171201	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
35	RDCC-53 -PIPING	1-P-53032010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171206	B
36	RDCC-53 -PIPING	1-P-53074002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171400	B
37	RDCC-53 -PIPING	1-P-53074005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171403	B
38	RDCC-53 -PIPING	1-P-53074009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171407	B
39	RDCC-53 -PIPING	1-P-53074012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171410	B
40	RDCC-53 -PIPING	1-P-53079002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171440	B
41	RDCC-53 -PIPING	1-P-53079003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171441	B
42	RDCC-53 -PIPING	1-P-53079004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171442	B
43	RDCC-53 -PIPING	1-P-53079005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171443	B
44	RDCC-53 -PIPING	1-P-53079009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171447	B
45	RDCC-53 -PIPING	1/2-P-53032001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171197	B
46	RDCC-53 -PIPING	1/2-P-53032006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171202	B
47	RDCC-53 -PIPING	1/2-P-53049008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171238	B
48	RDCC-53 -PIPING	10-AV-53040002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169361	B
49	RDCC-53 -PIPING	10-AV-53040003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169362	B
50	RDCC-53 -PIPING	10-AV-53040004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169363	B
51	RDCC-53 -PIPING	10-AV-53040006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169364	B
52	RDCC-53 -PIPING	10-AV-53041001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169365	B
53	RDCC-53 -PIPING	10-AV-53041002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169366	B
54	RDCC-53 -PIPING	10-AV-53041004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169367	B
55	RDCC-53 -PIPING	10-AV-53041005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169368	B
56	RDCC-53 -PIPING	10-AV-53042002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169369	B
57	RDCC-53 -PIPING	10-AV-53042003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169370	B
58	RDCC-53 -PIPING	10-AV-53042004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169371	B
59	RDCC-53 -PIPING	10-AV-53042005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169372	B
60	RDCC-53 -PIPING	10-CG-53038001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169495	B
61	RDCC-53 -PIPING	10-CG-53064001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169587	B
62	RDCC-53 -PIPING	10-CG-53064002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169588	B
63	RDCC-53 -PIPING	10-CG-53065001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169589	B
64	RDCC-53 -PIPING	10-CG-53069001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169592	B
65	RDCC-53 -PIPING	10-CG-53070001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169595	B
66	RDCC-53 -PIPING	10-CG-53070003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169597	B
67	RDCC-53 -PIPING	10-CG-53077005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169607	B
68	RDCC-53 -PIPING	10-CG-53077006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169608	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
69	RDCC-53 -PIPING	10-CG-53077007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169609	B
70	RDCC-53 -PIPING	10-CG-53077008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169613	B
71	RDCC-53 -PIPING	10-CG-53077009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169616	B
72	RDCC-53 -PIPING	10-CG-53077010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169617	B
73	RDCC-53 -PIPING	10-CG-53077011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169621	B
74	RDCC-53 -PIPING	10-CG-53077012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169622	B
75	RDCC-53 -PIPING	10-CG-53090007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169639	B
76	RDCC-53 -PIPING	10-CG-53090008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169640	B
77	RDCC-53 -PIPING	10-CG-53090009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169641	B
78	RDCC-53 -PIPING	10-CL-53000013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169679	B
79	RDCC-53 -PIPING	10-CL-53000014	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169680	B
80	RDCC-53 -PIPING	10-CL-53025001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169730	B
81	RDCC-53 -PIPING	10-CL-53025002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169731	B
82	RDCC-53 -PIPING	10-CL-53025003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169736	B
83	RDCC-53 -PIPING	10-CL-53025004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169737	B
84	RDCC-53 -PIPING	10-CL-53025051	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169738	B
85	RDCC-53 -PIPING	10-CL-53026001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169739	B
86	RDCC-53 -PIPING	10-CL-53026002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169740	B
87	RDCC-53 -PIPING	10-CL-53028004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169759	B
88	RDCC-53 -PIPING	10-CL-53029012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169770	B
89	RDCC-53 -PIPING	10-CL-53030002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169772	B
90	RDCC-53 -PIPING	10-CL-53030003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169773	B
91	RDCC-53 -PIPING	10-CL-53030004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169777	B
92	RDCC-53 -PIPING	10-CL-53030012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169775	B
93	RDCC-53 -PIPING	10-CL-53031006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169788	B
94	RDCC-53 -PIPING	10-CL-53032001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169801	B
95	RDCC-53 -PIPING	10-CL-53032002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169802	B
96	RDCC-53 -PIPING	10-CL-53032005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169805	B
97	RDCC-53 -PIPING	10-CL-53032007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169807	B
98	RDCC-53 -PIPING	10-CL-53033001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169810	B
99	RDCC-53 -PIPING	10-CL-53033002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169811	B
100	RDCC-53 -PIPING	10-CL-53037004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169842	B
101	RDCC-53 -PIPING	10-CL-53039023	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169851	B
102	RDCC-53 -PIPING	10-CL-53039025	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169852	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
103	RDCC-53 -PIPING	10-CL-53039027	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169853	B
104	RDCC-53 -PIPING	10-CL-53039034	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169856	B
105	RDCC-53 -PIPING	10-CL-53039035	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169857	B
106	RDCC-53 -PIPING	10-CL-53039038	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169859	B
107	RDCC-53 -PIPING	10-CL-53040002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169862	B
108	RDCC-53 -PIPING	10-CL-53040003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169863	B
109	RDCC-53 -PIPING	10-CL-53040004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169864	B
110	RDCC-53 -PIPING	10-CL-53040005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169865	B
111	RDCC-53 -PIPING	10-CL-53041002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169869	B
112	RDCC-53 -PIPING	10-CL-53041004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169871	B
113	RDCC-53 -PIPING	10-CL-53041005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169872	B
114	RDCC-53 -PIPING	10-CL-53041009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169873	B
115	RDCC-53 -PIPING	10-CL-53043001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169879	B
116	RDCC-53 -PIPING	10-CL-53043003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169881	B
117	RDCC-53 -PIPING	10-CL-53043004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169882	B
118	RDCC-53 -PIPING	10-CL-53043005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169883	B
119	RDCC-53 -PIPING	10-CL-53065004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170013	B
120	RDCC-53 -PIPING	10-CL-53065005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170014	B
121	RDCC-53 -PIPING	10-CL-53065006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170015	B
122	RDCC-53 -PIPING	10-CL-53065009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170017	B
123	RDCC-53 -PIPING	10-CL-53065011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170019	B
124	RDCC-53 -PIPING	10-CL-53065013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170021	B
125	RDCC-53 -PIPING	10-CL-53065014	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170022	B
126	RDCC-53 -PIPING	10-CL-53066001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170024	B
127	RDCC-53 -PIPING	10-CL-53066002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170025	B
128	RDCC-53 -PIPING	10-CL-53068005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170050	B
129	RDCC-53 -PIPING	10-CL-53068006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170051	B
130	RDCC-53 -PIPING	10-CL-53068007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170052	B
131	RDCC-53 -PIPING	10-CL-53068008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170053	B
132	RDCC-53 -PIPING	10-CL-53068009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170054	B
133	RDCC-53 -PIPING	12-AV-53029001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169357	B
134	RDCC-53 -PIPING	12-AV-53029002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169358	B
135	RDCC-53 -PIPING	12-AV-53100003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169394	B
136	RDCC-53 -PIPING	12-AV-53100005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169395	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
137	RDCC-53 -PIPING	12-CG-53009007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169479	B
138	RDCC-53 -PIPING	12-CG-53009008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169480	B
139	RDCC-53 -PIPING	12-CG-53058003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169571	B
140	RDCC-53 -PIPING	12-CG-53062002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169578	B
141	RDCC-53 -PIPING	12-CG-53062003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169579	B
142	RDCC-53 -PIPING	12-CG-53062004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169580	B
143	RDCC-53 -PIPING	12-CG-53062005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169581	B
144	RDCC-53 -PIPING	12-CG-53069003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169594	B
145	RDCC-53 -PIPING	12-CG-53077004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169606	B
146	RDCC-53 -PIPING	12-CG-53077014	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169624	B
147	RDCC-53 -PIPING	12-CG-53092001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169642	B
148	RDCC-53 -PIPING	12-CG-53092002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169643	B
149	RDCC-53 -PIPING	12-CG-53093025	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169664	B
150	RDCC-53 -PIPING	12-CL-53029007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169765	B
151	RDCC-53 -PIPING	12-CL-53029008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169766	B
152	RDCC-53 -PIPING	12-CL-53037002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169840	B
153	RDCC-53 -PIPING	12-CL-53037003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169841	B
154	RDCC-53 -PIPING	12-CL-53039028	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169854	B
155	RDCC-53 -PIPING	12-CL-53040001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169861	B
156	RDCC-53 -PIPING	12-CL-53040006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169866	B
157	RDCC-53 -PIPING	12-CL-53040007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169867	B
158	RDCC-53 -PIPING	12-CL-53040008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169868	B
159	RDCC-53 -PIPING	12-CL-53041003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169870	B
160	RDCC-53 -PIPING	12-CL-53042001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169874	B
161	RDCC-53 -PIPING	12-CL-53043002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169880	B
162	RDCC-53 -PIPING	12-CL-53062004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169981	B
163	RDCC-53 -PIPING	12-CL-53062005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169982	B
164	RDCC-53 -PIPING	12-CL-53062008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169985	B
165	RDCC-53 -PIPING	12-CL-53062009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169987	B
166	RDCC-53 -PIPING	12-CL-53062012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169990	B
167	RDCC-53 -PIPING	12-CL-53062013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169991	B
168	RDCC-53 -PIPING	12-CL-53063004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169995	B
169	RDCC-53 -PIPING	12-CL-53063005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169996	B
170	RDCC-53 -PIPING	12-CL-53063007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169998	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
171	RDCC-53 -PIPING	12-CL-53064006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170003	B
172	RDCC-53 -PIPING	12-CL-53065001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170010	B
173	RDCC-53 -PIPING	12-CL-53065002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170011	B
174	RDCC-53 -PIPING	12-CL-53065003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170012	B
175	RDCC-53 -PIPING	12-CL-53065008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170016	B
176	RDCC-53 -PIPING	12-CL-53067001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170034	B
177	RDCC-53 -PIPING	12-CL-53067002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170035	B
178	RDCC-53 -PIPING	14-CG-53058005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169573	B
179	RDCC-53 -PIPING	14-CL-53068011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170056	B
180	RDCC-53 -PIPING	16-AIT-53001006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	172133	C
181	RDCC-53 -PIPING	16-AIT-53004010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	172155	C
182	RDCC-53 -PIPING	16-AV-53055006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169375	B
183	RDCC-53 -PIPING	16-AV-53055007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169376	B
184	RDCC-53 -PIPING	16-AV-53055008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169377	B
185	RDCC-53 -PIPING	16-AV-53055009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169378	B
186	RDCC-53 -PIPING	16-CG-53025001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169483	B
187	RDCC-53 -PIPING	16-CG-53028002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169489	B
188	RDCC-53 -PIPING	16-CG-53028003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169487	B
189	RDCC-53 -PIPING	16-CG-53028004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169488	B
190	RDCC-53 -PIPING	16-CG-53028005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169490	B
191	RDCC-53 -PIPING	16-CG-53028006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169491	B
192	RDCC-53 -PIPING	16-CG-53028007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169492	B
193	RDCC-53 -PIPING	16-CG-53058009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169576	B
194	RDCC-53 -PIPING	16-CG-53062001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169577	B
195	RDCC-53 -PIPING	16-CG-53062006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169582	B
196	RDCC-53 -PIPING	16-CG-53063001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169583	B
197	RDCC-53 -PIPING	16-CG-53083001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169633	B
198	RDCC-53 -PIPING	16-CG-53089001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169634	B
199	RDCC-53 -PIPING	16-CG-53090001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169637	B
200	RDCC-53 -PIPING	16-CG-53092020	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169657	B
201	RDCC-53 -PIPING	16-CL-53028002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169755	B
202	RDCC-53 -PIPING	16-CL-53029001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169761	B
203	RDCC-53 -PIPING	16-CL-53029002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169762	B
204	RDCC-53 -PIPING	16-CL-53030001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169771	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
205	RDCC-53 -PIPING	16-CL-53030006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169778	B
206	RDCC-53 -PIPING	16-CL-53031002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169784	B
207	RDCC-53 -PIPING	16-CL-53031003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169785	B
208	RDCC-53 -PIPING	16-CL-53031030	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169800	B
209	RDCC-53 -PIPING	16-CL-53062002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169979	B
210	RDCC-53 -PIPING	16-CL-53062003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169980	B
211	RDCC-53 -PIPING	16-CL-53062011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169986	B
212	RDCC-53 -PIPING	16-CL-53062014	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169988	B
213	RDCC-53 -PIPING	16-CL-53063001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169992	B
214	RDCC-53 -PIPING	16-CL-53063002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169993	B
215	RDCC-53 -PIPING	16-CL-53063003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169994	B
216	RDCC-53 -PIPING	16-CL-53064001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170000	B
217	RDCC-53 -PIPING	16-CL-53064003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170002	B
218	RDCC-53 -PIPING	16-CL-53064009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170004	B
219	RDCC-53 -PIPING	16-CL-53068004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170049	B
220	RDCC-53 -PIPING	16-CL-53068013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170058	B
221	RDCC-53 -PIPING	18-CG-53055002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169558	B
222	RDCC-53 -PIPING	18-CG-53073002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169601	B
223	RDCC-53 -PIPING	18-CG-53073007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169603	B
224	RDCC-53 -PIPING	2-AV-53055066	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169374	B
225	RDCC-53 -PIPING	2-CG-53042001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169511	B
226	RDCC-53 -PIPING	2-CG-53042002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169512	B
227	RDCC-53 -PIPING	2-CG-53042003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169513	B
228	RDCC-53 -PIPING	2-CG-53042005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169514	B
229	RDCC-53 -PIPING	2-CG-53044016	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169520	B
230	RDCC-53 -PIPING	2-CG-53044017	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169521	B
231	RDCC-53 -PIPING	2-CG-53044018	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169522	B
232	RDCC-53 -PIPING	2-CG-53044019	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169523	B
233	RDCC-53 -PIPING	2-CG-53044020	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169524	B
234	RDCC-53 -PIPING	2-CG-53044021	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169525	B
235	RDCC-53 -PIPING	2-CG-53044022	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169526	B
236	RDCC-53 -PIPING	2-CG-53044023	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169527	B
237	RDCC-53 -PIPING	2-CG-53050001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169537	B
238	RDCC-53 -PIPING	2-CG-53055003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169559	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
239	RDCC-53 -PIPING	2-CG-53058010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169574	B
240	RDCC-53 -PIPING	2-CG-53077003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169610	B
241	RDCC-53 -PIPING	2-CG-53077013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169611	B
242	RDCC-53 -PIPING	2-CG-53077015	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169612	B
243	RDCC-53 -PIPING	2-CG-53077016	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169614	B
244	RDCC-53 -PIPING	2-CG-53077017	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169615	B
245	RDCC-53 -PIPING	2-CG-53077018	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169618	B
246	RDCC-53 -PIPING	2-CG-53077019	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169619	B
247	RDCC-53 -PIPING	2-CG-53077021	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169620	B
248	RDCC-53 -PIPING	2-CG-53077022	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169623	B
249	RDCC-53 -PIPING	2-CG-53078002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169627	B
250	RDCC-53 -PIPING	2-CG-53078006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169628	B
251	RDCC-53 -PIPING	2-CG-53089004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169635	B
252	RDCC-53 -PIPING	2-CG-53089006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169636	B
253	RDCC-53 -PIPING	2-CG-53092003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169651	B
254	RDCC-53 -PIPING	2-CG-53092005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169654	B
255	RDCC-53 -PIPING	2-CG-53092006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169655	B
256	RDCC-53 -PIPING	2-CG-53092007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169656	B
257	RDCC-53 -PIPING	2-CG-53092008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169658	B
258	RDCC-53 -PIPING	2-CG-53092009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169659	B
259	RDCC-53 -PIPING	2-CG-53092010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169660	B
260	RDCC-53 -PIPING	2-CG-53092011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169661	B
261	RDCC-53 -PIPING	2-CG-53095002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169667	B
262	RDCC-53 -PIPING	2-CL-53000005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169672	B
263	RDCC-53 -PIPING	2-CL-53000006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169673	B
264	RDCC-53 -PIPING	2-CL-53000012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169678	B
265	RDCC-53 -PIPING	2-CL-53008001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169694	B
266	RDCC-53 -PIPING	2-CL-53008002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169695	B
267	RDCC-53 -PIPING	2-CL-53008003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169696	B
268	RDCC-53 -PIPING	2-CL-53008004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169697	B
269	RDCC-53 -PIPING	2-CL-53008006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169699	B
270	RDCC-53 -PIPING	2-CL-53008007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169700	B
271	RDCC-53 -PIPING	2-CL-53008008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169701	B
272	RDCC-53 -PIPING	2-CL-53008009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169702	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
273	RDCC-53 -PIPING	2-CL-53008010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169703	B
274	RDCC-53 -PIPING	2-CL-53008011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169704	B
275	RDCC-53 -PIPING	2-CL-53008012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169705	B
276	RDCC-53 -PIPING	2-CL-53008013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169706	B
277	RDCC-53 -PIPING	2-CL-53009002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169707	B
278	RDCC-53 -PIPING	2-CL-53010002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169714	B
279	RDCC-53 -PIPING	2-CL-53010003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169716	B
280	RDCC-53 -PIPING	2-CL-53010004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169717	B
281	RDCC-53 -PIPING	2-CL-53010007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169720	B
282	RDCC-53 -PIPING	2-CL-53010008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169721	B
283	RDCC-53 -PIPING	2-CL-53010009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169722	B
284	RDCC-53 -PIPING	2-CL-53010010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169723	B
285	RDCC-53 -PIPING	2-CL-53010011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169724	B
286	RDCC-53 -PIPING	2-CL-53011003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169726	B
287	RDCC-53 -PIPING	2-CL-53011007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169727	B
288	RDCC-53 -PIPING	2-CL-53011008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169728	B
289	RDCC-53 -PIPING	2-CL-53011009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169729	B
290	RDCC-53 -PIPING	2-CL-53031005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169787	B
291	RDCC-53 -PIPING	2-CL-53031008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169790	B
292	RDCC-53 -PIPING	2-CL-53031020	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169797	B
293	RDCC-53 -PIPING	2-CL-53034007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169820	B
294	RDCC-53 -PIPING	2-CL-53034010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169823	B
295	RDCC-53 -PIPING	2-CL-53034012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169824	B
296	RDCC-53 -PIPING	2-CL-53036006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169831	B
297	RDCC-53 -PIPING	2-CL-53036009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169832	B
298	RDCC-53 -PIPING	2-CL-53036010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169833	B
299	RDCC-53 -PIPING	2-CL-53044001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169884	B
300	RDCC-53 -PIPING	2-CL-53045001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169889	B
301	RDCC-53 -PIPING	2-CL-53045002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169890	B
302	RDCC-53 -PIPING	2-CL-53045003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169891	B
303	RDCC-53 -PIPING	2-CL-53045008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169894	B
304	RDCC-53 -PIPING	2-CL-53046001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169897	B
305	RDCC-53 -PIPING	2-CL-53046002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169898	B
306	RDCC-53 -PIPING	2-CL-53046012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169900	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
307	RDCC-53 -PIPING	2-CL-53046013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169901	B
308	RDCC-53 -PIPING	2-CL-53046014	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169902	B
309	RDCC-53 -PIPING	2-CL-53046015	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169903	B
310	RDCC-53 -PIPING	2-CL-53046016	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169904	B
311	RDCC-53 -PIPING	2-CL-53046047	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169905	B
312	RDCC-53 -PIPING	2-CL-53049007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169925	B
313	RDCC-53 -PIPING	2-CL-53049011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169926	B
314	RDCC-53 -PIPING	2-CL-53049017	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169929	B
315	RDCC-53 -PIPING	2-CL-53052001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169942	B
316	RDCC-53 -PIPING	2-CL-53052008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169949	B
317	RDCC-53 -PIPING	2-CL-53052009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169952	B
318	RDCC-53 -PIPING	2-CL-53054001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169954	B
319	RDCC-53 -PIPING	2-CL-53054002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169955	B
320	RDCC-53 -PIPING	2-CL-53055001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169956	B
321	RDCC-53 -PIPING	2-CL-53055002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169957	B
322	RDCC-53 -PIPING	2-CL-53062030	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169989	B
323	RDCC-53 -PIPING	2-CL-53064004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170006	B
324	RDCC-53 -PIPING	2-CL-53064005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170007	B
325	RDCC-53 -PIPING	2-CL-53067012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170044	B
326	RDCC-53 -PIPING	2-CL-53067013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170045	B
327	RDCC-53 -PIPING	2-P-53031002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171185	B
328	RDCC-53 -PIPING	2-P-53031005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171188	B
329	RDCC-53 -PIPING	2-P-53031009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171192	B
330	RDCC-53 -PIPING	2-P-53031012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171195	B
331	RDCC-53 -PIPING	2-P-53075002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171412	B
332	RDCC-53 -PIPING	2-P-53075005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171415	B
333	RDCC-53 -PIPING	2-P-53075009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171419	B
334	RDCC-53 -PIPING	2-P-53075012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171422	B
335	RDCC-53 -PIPING	20-AIT-53001010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	172137	C
336	RDCC-53 -PIPING	20-AIT-53004009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	172154	C
337	RDCC-53 -PIPING	20-AV-53042006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169373	B
338	RDCC-53 -PIPING	20-CG-53054002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169551	B
339	RDCC-53 -PIPING	20-CG-53054005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169554	B
340	RDCC-53 -PIPING	20-CG-53058002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169570	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
341	RDCC-53 -PIPING	20-CG-53058004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169572	B
342	RDCC-53 -PIPING	20-CG-53077001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169604	B
343	RDCC-53 -PIPING	20-CG-53077002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169605	B
344	RDCC-53 -PIPING	20-CL-53029006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169764	B
345	RDCC-53 -PIPING	20-CL-53029010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169768	B
346	RDCC-53 -PIPING	20-CL-53062006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169983	B
347	RDCC-53 -PIPING	20-CL-53062007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169984	B
348	RDCC-53 -PIPING	20-CL-53068001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170046	B
349	RDCC-53 -PIPING	20-CL-53068002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170047	B
350	RDCC-53 -PIPING	20-CL-53068003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170048	B
351	RDCC-53 -PIPING	24-AIT-53001005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	172132	C
352	RDCC-53 -PIPING	24-AIT-53004001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	172146	C
353	RDCC-53 -PIPING	24-AIT-53004008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	172153	C
354	RDCC-53 -PIPING	24-CG-53051006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169538	B
355	RDCC-53 -PIPING	24-CG-53051007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169539	B
356	RDCC-53 -PIPING	24-CG-53051008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169540	B
357	RDCC-53 -PIPING	24-CG-53051009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169541	B
358	RDCC-53 -PIPING	24-CG-53051011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169542	B
359	RDCC-53 -PIPING	24-CG-53051013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169543	B
360	RDCC-53 -PIPING	24-CG-53051015	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169544	B
361	RDCC-53 -PIPING	24-CG-53051017	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169545	B
362	RDCC-53 -PIPING	24-CG-53055006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169562	B
363	RDCC-53 -PIPING	24-CG-53056001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169565	B
364	RDCC-53 -PIPING	24-CG-53056002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169566	B
365	RDCC-53 -PIPING	24-CG-53073001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169600	B
366	RDCC-53 -PIPING	24-CG-53077020	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169625	B
367	RDCC-53 -PIPING	24-CL-53029011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169769	B
368	RDCC-53 -PIPING	24-CL-53031001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169783	B
369	RDCC-53 -PIPING	24-CL-53031009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169791	B
370	RDCC-53 -PIPING	24-CL-53031010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169792	B
371	RDCC-53 -PIPING	24-CL-53031011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169793	B
372	RDCC-53 -PIPING	24-CL-53051002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169932	B
373	RDCC-53 -PIPING	24-CL-53051003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169933	B
374	RDCC-53 -PIPING	24-CL-53051004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169934	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
375	RDCC-53 -PIPING	24-CL-53051005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169935	B
376	RDCC-53 -PIPING	24-CL-53051010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169936	B
377	RDCC-53 -PIPING	24-CL-53051012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169937	B
378	RDCC-53 -PIPING	24-CL-53051014	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169938	B
379	RDCC-53 -PIPING	24-CL-53051016	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169939	B
380	RDCC-53 -PIPING	24-CL-53056003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169958	B
381	RDCC-53 -PIPING	24-CL-53056004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169959	B
382	RDCC-53 -PIPING	24-CL-53056006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169961	B
383	RDCC-53 -PIPING	24-CL-53056007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169962	B
384	RDCC-53 -PIPING	24-CL-53056017	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169968	B
385	RDCC-53 -PIPING	24-CL-53056018	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169969	B
386	RDCC-53 -PIPING	24-CL-53062001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169978	B
387	RDCC-53 -PIPING	24-CL-53064002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170001	B
388	RDCC-53 -PIPING	26-CL-53064010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170005	B
389	RDCC-53 -PIPING	28-CG-53055005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169561	B
390	RDCC-53 -PIPING	3-AV-53068001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169379	B
391	RDCC-53 -PIPING	3-CD-53007001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169418	B
392	RDCC-53 -PIPING	3-CG-53006002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169470	B
393	RDCC-53 -PIPING	3-CG-53010001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169481	B
394	RDCC-53 -PIPING	3-CG-53010002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169482	B
395	RDCC-53 -PIPING	3-CG-53027007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169484	B
396	RDCC-53 -PIPING	3-CG-53027008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169485	B
397	RDCC-53 -PIPING	3-CG-53054007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169555	B
398	RDCC-53 -PIPING	3-CG-53054008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169556	B
399	RDCC-53 -PIPING	3-CG-53080002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169629	B
400	RDCC-53 -PIPING	3-CG-53093001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169663	B
401	RDCC-53 -PIPING	3-CG-53093006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169665	B
402	RDCC-53 -PIPING	3-CL-53000001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169670	B
403	RDCC-53 -PIPING	3-CL-53000003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169671	B
404	RDCC-53 -PIPING	3-CL-53000011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169677	B
405	RDCC-53 -PIPING	3-CL-53006001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169683	B
406	RDCC-53 -PIPING	3-CL-53006002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169684	B
407	RDCC-53 -PIPING	3-CL-53008005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169698	B
408	RDCC-53 -PIPING	3-CL-53009003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169710	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
409	RDCC-53 -PIPING	3-CL-53009004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169711	B
410	RDCC-53 -PIPING	3-CL-53010005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169718	B
411	RDCC-53 -PIPING	3-CL-53010006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169719	B
412	RDCC-53 -PIPING	3-CL-53011001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169725	B
413	RDCC-53 -PIPING	3-CL-53026007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169746	B
414	RDCC-53 -PIPING	3-CL-53030009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169781	B
415	RDCC-53 -PIPING	3-CL-53032008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169808	B
416	RDCC-53 -PIPING	3-CL-53032009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169809	B
417	RDCC-53 -PIPING	3-CL-53034004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169817	B
418	RDCC-53 -PIPING	3-CL-53034005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169818	B
419	RDCC-53 -PIPING	3-CL-53034006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169819	B
420	RDCC-53 -PIPING	3-CL-53035001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169825	B
421	RDCC-53 -PIPING	3-CL-53035002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169826	B
422	RDCC-53 -PIPING	3-CL-53036001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169827	B
423	RDCC-53 -PIPING	3-CL-53036003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169828	B
424	RDCC-53 -PIPING	3-CL-53036004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169829	B
425	RDCC-53 -PIPING	3-CL-53036005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169830	B
426	RDCC-53 -PIPING	3-CL-53036008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169838	B
427	RDCC-53 -PIPING	3-CL-53036011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169839	B
428	RDCC-53 -PIPING	3-CL-53036012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169834	B
429	RDCC-53 -PIPING	3-CL-53036014	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169835	B
430	RDCC-53 -PIPING	3-CL-53039011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169850	B
431	RDCC-53 -PIPING	3-CL-53039029	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169855	B
432	RDCC-53 -PIPING	3-CL-53039037	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169858	B
433	RDCC-53 -PIPING	3-CL-53039039	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169860	B
434	RDCC-53 -PIPING	3-CL-53047005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169911	B
435	RDCC-53 -PIPING	3-CL-53047007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169912	B
436	RDCC-53 -PIPING	3-CL-53049012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169927	B
437	RDCC-53 -PIPING	3-CL-53049015	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169928	B
438	RDCC-53 -PIPING	3-CL-53052005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169946	B
439	RDCC-53 -PIPING	3-CL-53052006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169947	B
440	RDCC-53 -PIPING	3-CL-53052007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169948	B
441	RDCC-53 -PIPING	3-CL-53056001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169963	B
442	RDCC-53 -PIPING	3-CL-53056002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169964	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
443	RDCC-53 -PIPING	3-CL-53056011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169965	B
444	RDCC-53 -PIPING	3-CL-53056012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169966	B
445	RDCC-53 -PIPING	3-CL-53057004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169973	B
446	RDCC-53 -PIPING	3-CL-53057005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169974	B
447	RDCC-53 -PIPING	3-CL-53057006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169975	B
448	RDCC-53 -PIPING	3-CL-53057008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169977	B
449	RDCC-53 -PIPING	3-CL-53064008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170008	B
450	RDCC-53 -PIPING	3/4-AV-53015301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169356	B
451	RDCC-53 -PIPING	3/4-AV-53068301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169380	B
452	RDCC-53 -PIPING	3/4-AV-53091301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169393	B
453	RDCC-53 -PIPING	3/4-CG-53065006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169591	B
454	RDCC-53 -PIPING	3/4-CG-53070301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169598	B
455	RDCC-53 -PIPING	3/4-CG-53070302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169599	B
456	RDCC-53 -PIPING	3/4-CL-53006003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169685	B
457	RDCC-53 -PIPING	3/4-CL-53006301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169686	B
458	RDCC-53 -PIPING	3/4-CL-53006302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169687	B
459	RDCC-53 -PIPING	3/4-CL-53009301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169708	B
460	RDCC-53 -PIPING	3/4-CL-53009302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169709	B
461	RDCC-53 -PIPING	3/4-CL-53010301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169715	B
462	RDCC-53 -PIPING	3/4-CL-53025053	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169732	B
463	RDCC-53 -PIPING	3/4-CL-53025056	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169733	B
464	RDCC-53 -PIPING	3/4-CL-53025301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169734	B
465	RDCC-53 -PIPING	3/4-CL-53025302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169735	B
466	RDCC-53 -PIPING	3/4-CL-53028301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169757	B
467	RDCC-53 -PIPING	3/4-CL-53028302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169758	B
468	RDCC-53 -PIPING	3/4-CL-53030301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169776	B
469	RDCC-53 -PIPING	3/4-CL-53036301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169836	B
470	RDCC-53 -PIPING	3/4-CL-53036302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169837	B
471	RDCC-53 -PIPING	3/4-CL-53045004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169892	B
472	RDCC-53 -PIPING	3/4-CL-53045005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169893	B
473	RDCC-53 -PIPING	3/4-CL-53052301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169950	B
474	RDCC-53 -PIPING	3/4-CL-53052302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169951	B
475	RDCC-53 -PIPING	3/4-P-53029001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171173	B
476	RDCC-53 -PIPING	3/4-P-53031001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171184	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
477	RDCC-53 -PIPING	3/4-P-53031006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171189	B
478	RDCC-53 -PIPING	3/4-P-53031007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171190	B
479	RDCC-53 -PIPING	3/4-P-53031008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171191	B
480	RDCC-53 -PIPING	3/4-P-53031301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171196	B
481	RDCC-53 -PIPING	3/4-P-53032002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171198	B
482	RDCC-53 -PIPING	3/4-P-53032003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171199	B
483	RDCC-53 -PIPING	3/4-P-53032004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171200	B
484	RDCC-53 -PIPING	3/4-P-53032007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171203	B
485	RDCC-53 -PIPING	3/4-P-53032008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171204	B
486	RDCC-53 -PIPING	3/4-P-53032009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171205	B
487	RDCC-53 -PIPING	3/4-P-53034001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171207	B
488	RDCC-53 -PIPING	3/4-P-53049003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171233	B
489	RDCC-53 -PIPING	3/4-P-53049004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171234	B
490	RDCC-53 -PIPING	3/4-P-53049005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171235	B
491	RDCC-53 -PIPING	3/4-P-53049006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171236	B
492	RDCC-53 -PIPING	3/4-P-53049007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171237	B
493	RDCC-53 -PIPING	3/4-P-53049009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171239	B
494	RDCC-53 -PIPING	3/4-P-53049010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171240	B
495	RDCC-53 -PIPING	3/4-P-53049011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171241	B
496	RDCC-53 -PIPING	3/4-P-53049012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171242	B
497	RDCC-53 -PIPING	3/4-P-53064001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171332	B
498	RDCC-53 -PIPING	3/4-P-53073001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171395	B
499	RDCC-53 -PIPING	3/4-P-53073002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171396	B
500	RDCC-53 -PIPING	3/4-P-53073003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171397	B
501	RDCC-53 -PIPING	3/4-P-53073004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171398	B
502	RDCC-53 -PIPING	3/4-P-53074001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171399	B
503	RDCC-53 -PIPING	3/4-P-53074003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171401	B
504	RDCC-53 -PIPING	3/4-P-53074006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171404	B
505	RDCC-53 -PIPING	3/4-P-53074007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171405	B
506	RDCC-53 -PIPING	3/4-P-53074008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171406	B
507	RDCC-53 -PIPING	3/4-P-53074010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171408	B
508	RDCC-53 -PIPING	3/4-P-53074011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171409	B
509	RDCC-53 -PIPING	3/4-P-53075001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171411	B
510	RDCC-53 -PIPING	3/4-P-53075006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171416	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
511	RDCC-53 -PIPING	3/4-P-53075007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171417	B
512	RDCC-53 -PIPING	3/4-P-53075008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171418	B
513	RDCC-53 -PIPING	3/4-P-53078001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171423	B
514	RDCC-53 -PIPING	3/4-P-53079001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171439	B
515	RDCC-53 -PIPING	3/4-P-53079006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171444	B
516	RDCC-53 -PIPING	3/4-P-53079007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171445	B
517	RDCC-53 -PIPING	3/4-P-53079008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171446	B
518	RDCC-53 -PIPING	3/4-P-53088001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171515	B
519	RDCC-53 -PIPING	3/4-P-53088002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171516	B
520	RDCC-53 -PIPING	3/4-P-53088003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171517	B
521	RDCC-53 -PIPING	3/4-P-53088004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171518	B
522	RDCC-53 -PIPING	3/4-P-53088005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171519	B
523	RDCC-53 -PIPING	3/4-P-53088006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171520	B
524	RDCC-53 -PIPING	3/4-P-53088007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171521	B
525	RDCC-53 -PIPING	3/4-P-53088008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171522	B
526	RDCC-53 -PIPING	3/4-P-53088009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171523	B
527	RDCC-53 -PIPING	3/4-P-53088010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171524	B
528	RDCC-53 -PIPING	3/4-P-53088011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171525	B
529	RDCC-53 -PIPING	3/4-P-53089002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171528	B
530	RDCC-53 -PIPING	3/4-P-53099001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171603	B
531	RDCC-53 -PIPING	3/4-P-53099002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171604	B
532	RDCC-53 -PIPING	3/4-P-53099003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171605	B
533	RDCC-53 -PIPING	3/4-P-53099004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171606	B
534	RDCC-53 -PIPING	3/4-P-53099005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171607	B
535	RDCC-53 -PIPING	3/4-P-53099006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171608	B
536	RDCC-53 -PIPING	3/4-P-53099007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171609	B
537	RDCC-53 -PIPING	3/4-P-53099008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171610	B
538	RDCC-53 -PIPING	3/4-P-53099009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171611	B
539	RDCC-53 -PIPING	3/4-P-53099010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171612	B
540	RDCC-53 -PIPING	3/4-P-53099011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171613	B
541	RDCC-53 -PIPING	3/4-P-53099012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	171614	B
542	RDCC-53 -PIPING	30-CG-53055001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169557	B
543	RDCC-53 -PIPING	30-CG-53055013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169564	B
544	RDCC-53 -PIPING	30-CL-53056005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169960	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
545	RDCC-53 -PIPING	30-CL-53056010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169967	B
546	RDCC-53 -PIPING	32-AIT-53001004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	172131	C
547	RDCC-53 -PIPING	32-CG-53048002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169531	B
548	RDCC-53 -PIPING	32-CG-53048003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169532	B
549	RDCC-53 -PIPING	32-CL-53048001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169914	B
550	RDCC-53 -PIPING	32-CL-53048002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169915	B
551	RDCC-53 -PIPING	32-CL-53048003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169916	B
552	RDCC-53 -PIPING	32-CL-53048004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169917	B
553	RDCC-53 -PIPING	36-CG-53057001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169567	B
554	RDCC-53 -PIPING	36-CG-53058001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169569	B
555	RDCC-53 -PIPING	4-AV-53076001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169381	B
556	RDCC-53 -PIPING	4-AV-53076003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169382	B
557	RDCC-53 -PIPING	4-AV-53076004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169383	B
558	RDCC-53 -PIPING	4-AV-53076005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169384	B
559	RDCC-53 -PIPING	4-AV-53091001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169385	B
560	RDCC-53 -PIPING	4-AV-53091002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169386	B
561	RDCC-53 -PIPING	4-AV-53091003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169387	B
562	RDCC-53 -PIPING	4-AV-53091004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169388	B
563	RDCC-53 -PIPING	4-AV-53091005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169389	B
564	RDCC-53 -PIPING	4-AV-53091006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169390	B
565	RDCC-53 -PIPING	4-AV-53091007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169391	B
566	RDCC-53 -PIPING	4-AV-53091008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169392	B
567	RDCC-53 -PIPING	4-CG-53009005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169477	B
568	RDCC-53 -PIPING	4-CG-53037001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169494	B
569	RDCC-53 -PIPING	4-CG-53049002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169535	B
570	RDCC-53 -PIPING	4-CG-53050002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169536	B
571	RDCC-53 -PIPING	4-CG-53055004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169560	B
572	RDCC-53 -PIPING	4-CG-53058008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169575	B
573	RDCC-53 -PIPING	4-CG-53063002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169584	B
574	RDCC-53 -PIPING	4-CG-53069002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169593	B
575	RDCC-53 -PIPING	4-CG-53078001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169626	B
576	RDCC-53 -PIPING	4-CG-53080004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169630	B
577	RDCC-53 -PIPING	4-CG-53090006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169638	B
578	RDCC-53 -PIPING	4-CL-53007001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169688	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
579	RDCC-53 -PIPING	4-CL-53007002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169689	B
580	RDCC-53 -PIPING	4-CL-53007003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169690	B
581	RDCC-53 -PIPING	4-CL-53007004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169691	B
582	RDCC-53 -PIPING	4-CL-53007005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169692	B
583	RDCC-53 -PIPING	4-CL-53009005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169712	B
584	RDCC-53 -PIPING	4-CL-53010001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169713	B
585	RDCC-53 -PIPING	4-CL-53026006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169745	B
586	RDCC-53 -PIPING	4-CL-53026008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169747	B
587	RDCC-53 -PIPING	4-CL-53027001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169748	B
588	RDCC-53 -PIPING	4-CL-53027002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169749	B
589	RDCC-53 -PIPING	4-CL-53027006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169751	B
590	RDCC-53 -PIPING	4-CL-53027007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169752	B
591	RDCC-53 -PIPING	4-CL-53030008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169780	B
592	RDCC-53 -PIPING	4-CL-53031018	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169796	B
593	RDCC-53 -PIPING	4-CL-53049004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169922	B
594	RDCC-53 -PIPING	4-CL-53049005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169923	B
595	RDCC-53 -PIPING	4-CL-53049006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169924	B
596	RDCC-53 -PIPING	4-CL-53049010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169930	B
597	RDCC-53 -PIPING	4-CL-53052002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169943	B
598	RDCC-53 -PIPING	4-CL-53052003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169944	B
599	RDCC-53 -PIPING	4-CL-53052004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169945	B
600	RDCC-53 -PIPING	4-CL-53052010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169953	B
601	RDCC-53 -PIPING	4-CL-53068010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170055	B
602	RDCC-53 -PIPING	4-CL-53068012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170057	B
603	RDCC-53 -PIPING	42-AIT-53001002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	172129	C
604	RDCC-53 -PIPING	42-AIT-53001013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	172139	C
605	RDCC-53 -PIPING	42-CG-53048001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169530	B
606	RDCC-53 -PIPING	42-CG-53048004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169533	B
607	RDCC-53 -PIPING	42-CG-53051020	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169546	B
608	RDCC-53 -PIPING	42-CG-53051021	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169547	B
609	RDCC-53 -PIPING	42-CL-53051018	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169940	B
610	RDCC-53 -PIPING	42-CL-53051019	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169941	B
611	RDCC-53 -PIPING	54-CG-53052001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169548	B
612	RDCC-53 -PIPING	54-CG-53054003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169552	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
613	RDCC-53 -PIPING	54-CG-53055007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169563	B
614	RDCC-53 -PIPING	6-AV-53006004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169355	B
615	RDCC-53 -PIPING	6-AV-53037001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169359	B
616	RDCC-53 -PIPING	6-AV-53037003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169360	B
617	RDCC-53 -PIPING	6-CG-53006001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169471	B
618	RDCC-53 -PIPING	6-CG-53009001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169473	B
619	RDCC-53 -PIPING	6-CG-53009002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169474	B
620	RDCC-53 -PIPING	6-CG-53009003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169475	B
621	RDCC-53 -PIPING	6-CG-53009004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169476	B
622	RDCC-53 -PIPING	6-CG-53034007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169493	B
623	RDCC-53 -PIPING	6-CG-53039001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169497	B
624	RDCC-53 -PIPING	6-CG-53039003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169498	B
625	RDCC-53 -PIPING	6-CG-53039005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169499	B
626	RDCC-53 -PIPING	6-CG-53039006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169500	B
627	RDCC-53 -PIPING	6-CG-53039008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169501	B
628	RDCC-53 -PIPING	6-CG-53039009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169502	B
629	RDCC-53 -PIPING	6-CG-53040001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169503	B
630	RDCC-53 -PIPING	6-CG-53040002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169504	B
631	RDCC-53 -PIPING	6-CG-53040003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169505	B
632	RDCC-53 -PIPING	6-CG-53040004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169506	B
633	RDCC-53 -PIPING	6-CG-53041001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169507	B
634	RDCC-53 -PIPING	6-CG-53041002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169508	B
635	RDCC-53 -PIPING	6-CG-53041005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169509	B
636	RDCC-53 -PIPING	6-CG-53041006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169510	B
637	RDCC-53 -PIPING	6-CG-53043003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169517	B
638	RDCC-53 -PIPING	6-CG-53043004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169518	B
639	RDCC-53 -PIPING	6-CG-53043007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169519	B
640	RDCC-53 -PIPING	6-CG-53052003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169549	B
641	RDCC-53 -PIPING	6-CG-53093002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169662	B
642	RDCC-53 -PIPING	6-CL-53000007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169674	B
643	RDCC-53 -PIPING	6-CL-53000008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169675	B
644	RDCC-53 -PIPING	6-CL-53000009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169676	B
645	RDCC-53 -PIPING	6-CL-53000015	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169681	B
646	RDCC-53 -PIPING	6-CL-53028003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169756	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
647	RDCC-53 -PIPING	6-CL-53028006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169760	B
648	RDCC-53 -PIPING	6-CL-53030007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169779	B
649	RDCC-53 -PIPING	6-CL-53030010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169782	B
650	RDCC-53 -PIPING	6-CL-53031004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169786	B
651	RDCC-53 -PIPING	6-CL-53031007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169789	B
652	RDCC-53 -PIPING	6-CL-53031016	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169795	B
653	RDCC-53 -PIPING	6-CL-53031022	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169798	B
654	RDCC-53 -PIPING	6-CL-53031023	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169799	B
655	RDCC-53 -PIPING	6-CL-53032003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169803	B
656	RDCC-53 -PIPING	6-CL-53032004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169804	B
657	RDCC-53 -PIPING	6-CL-53032006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169806	B
658	RDCC-53 -PIPING	6-CL-53033003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169812	B
659	RDCC-53 -PIPING	6-CL-53033004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169813	B
660	RDCC-53 -PIPING	6-CL-53034001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169814	B
661	RDCC-53 -PIPING	6-CL-53034002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169815	B
662	RDCC-53 -PIPING	6-CL-53034003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169816	B
663	RDCC-53 -PIPING	6-CL-53034008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169821	B
664	RDCC-53 -PIPING	6-CL-53034009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169822	B
665	RDCC-53 -PIPING	6-CL-53039001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169843	B
666	RDCC-53 -PIPING	6-CL-53039002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169844	B
667	RDCC-53 -PIPING	6-CL-53039003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169845	B
668	RDCC-53 -PIPING	6-CL-53039004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169846	B
669	RDCC-53 -PIPING	6-CL-53039005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169847	B
670	RDCC-53 -PIPING	6-CL-53039006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169848	B
671	RDCC-53 -PIPING	6-CL-53047001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169906	B
672	RDCC-53 -PIPING	6-CL-53047002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169907	B
673	RDCC-53 -PIPING	6-CL-53047003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169908	B
674	RDCC-53 -PIPING	6-CL-53047004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169910	B
675	RDCC-53 -PIPING	6-CL-53047006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169909	B
676	RDCC-53 -PIPING	6-CL-53047008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169913	B
677	RDCC-53 -PIPING	6-CL-53057001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169970	B
678	RDCC-53 -PIPING	6-CL-53057002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169971	B
679	RDCC-53 -PIPING	6-CL-53057003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169972	B
680	RDCC-53 -PIPING	6-CL-53057007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169976	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
681	RDCC-53 -PIPING	6-CL-53063006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169997	B
682	RDCC-53 -PIPING	6-CL-53063008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169999	B
683	RDCC-53 -PIPING	6-CL-53065010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170018	B
684	RDCC-53 -PIPING	6-CL-53065012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170020	B
685	RDCC-53 -PIPING	60-CG-53028001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169486	B
686	RDCC-53 -PIPING	60-CG-53049001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169534	B
687	RDCC-53 -PIPING	60-CL-53048005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169918	B
688	RDCC-53 -PIPING	60-CL-53051001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169931	B
689	RDCC-53 -PIPING	78-CG-53005001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169469	B
690	RDCC-53 -PIPING	8-CG-53006003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169472	B
691	RDCC-53 -PIPING	8-CG-53009006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169478	B
692	RDCC-53 -PIPING	8-CG-53038002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169496	B
693	RDCC-53 -PIPING	8-CG-53043001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169515	B
694	RDCC-53 -PIPING	8-CG-53043002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169516	B
695	RDCC-53 -PIPING	8-CG-53052005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169550	B
696	RDCC-53 -PIPING	8-CG-53054004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169553	B
697	RDCC-53 -PIPING	8-CG-53057002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169568	B
698	RDCC-53 -PIPING	8-CG-53063006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169585	B
699	RDCC-53 -PIPING	8-CG-53063007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169586	B
700	RDCC-53 -PIPING	8-CG-53065002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169590	B
701	RDCC-53 -PIPING	8-CG-53070002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169596	B
702	RDCC-53 -PIPING	8-CG-53073006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169602	B
703	RDCC-53 -PIPING	8-CG-53080005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169631	B
704	RDCC-53 -PIPING	8-CG-53080006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169632	B
705	RDCC-53 -PIPING	8-CG-53092004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169644	B
706	RDCC-53 -PIPING	8-CG-53092012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169645	B
707	RDCC-53 -PIPING	8-CG-53092013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169646	B
708	RDCC-53 -PIPING	8-CG-53092014	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169647	B
709	RDCC-53 -PIPING	8-CG-53092015	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169648	B
710	RDCC-53 -PIPING	8-CG-53092016	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169649	B
711	RDCC-53 -PIPING	8-CG-53092017	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169650	B
712	RDCC-53 -PIPING	8-CG-53092018	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169652	B
713	RDCC-53 -PIPING	8-CG-53092019	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169653	B
714	RDCC-53 -PIPING	8-CG-53095001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169666	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
715	RDCC-53 -PIPING	8-CG-53096001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169668	B
716	RDCC-53 -PIPING	8-CG-53098001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169669	B
717	RDCC-53 -PIPING	8-CL-53000004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169682	B
718	RDCC-53 -PIPING	8-CL-53007007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169693	B
719	RDCC-53 -PIPING	8-CL-53026003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169742	B
720	RDCC-53 -PIPING	8-CL-53026004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169743	B
721	RDCC-53 -PIPING	8-CL-53026005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169744	B
722	RDCC-53 -PIPING	8-CL-53027005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169750	B
723	RDCC-53 -PIPING	8-CL-53027010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169753	B
724	RDCC-53 -PIPING	8-CL-53028001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169754	B
725	RDCC-53 -PIPING	8-CL-53029003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169763	B
726	RDCC-53 -PIPING	8-CL-53029009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169767	B
727	RDCC-53 -PIPING	8-CL-53030011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169774	B
728	RDCC-53 -PIPING	8-CL-53031014	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169794	B
729	RDCC-53 -PIPING	8-CL-53039007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169849	B
730	RDCC-53 -PIPING	8-CL-53042002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169875	B
731	RDCC-53 -PIPING	8-CL-53042003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169876	B
732	RDCC-53 -PIPING	8-CL-53042004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169877	B
733	RDCC-53 -PIPING	8-CL-53042005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169878	B
734	RDCC-53 -PIPING	8-CL-53049001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169919	B
735	RDCC-53 -PIPING	8-CL-53049002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169920	B
736	RDCC-53 -PIPING	8-CL-53049003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	169921	B
737	RDCC-53 -PIPING	8-CL-53064012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170009	B
738	RDCC-53 -PIPING	8-CL-53065016	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170023	B
739	RDCC-53 -PIPING	8-CL-53066003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170026	B
740	RDCC-53 -PIPING	8-CL-53066005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170027	B
741	RDCC-53 -PIPING	8-CL-53066007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170028	B
742	RDCC-53 -PIPING	8-CL-53066008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170029	B
743	RDCC-53 -PIPING	8-CL-53066009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170030	B
744	RDCC-53 -PIPING	8-CL-53066010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170031	B
745	RDCC-53 -PIPING	8-CL-53066011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170032	B
746	RDCC-53 -PIPING	8-CL-53066012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170033	B
747	RDCC-53 -PIPING	8-CL-53067003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170036	B
748	RDCC-53 -PIPING	8-CL-53067004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170037	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
749	RDCC-53 -PIPING	8-CL-53067005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170038	B
750	RDCC-53 -PIPING	8-CL-53067007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170039	B
751	RDCC-53 -PIPING	8-CL-53067008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170040	B
752	RDCC-53 -PIPING	8-CL-53067009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170041	B
753	RDCC-53 -PIPING	8-CL-53067010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170042	B
754	RDCC-53 -PIPING	8-CL-53067011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	170043	B
755	RDCC-53 -B10	B10-FA-DETECT-SD	PM SMOKE DETECTOR (###) RDCC-EHO-FA	PMT	6M					P						P		RRC	RRC-ERCP	140418	A
756	RDCC-53 -B10	B10-LFCP-EST-3	PM F/A PANEL LFCP-EST_3 EL E-HOUSE (B10)	PMT	1Y											P		RRC	RRC-ERCP	140402	A
757	RDCC-53 -53E117	MSS-53E117-VSD	Inspec VSD FOR 53E117-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-ERCP	254145	C
758	RDCC-53 -53E133	MSS-53E133-VSD	Inspec VSD FOR 53E133-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-ERCP	254146	C
759	RDCC-53 -53K001	MSS-53K001-SOFT	Inspect 11KV SOFT STARTER FOR MOTOR 53K0	PMT	3M	I			I			I			I			CCH	CCH-VSD	140518	A
760	RDCC-53 -53K001	MSS-53K001-SOFT	PM 11KV SOFT STARTER FOR MOTOR 53K001-M	PMT	1Y											P		CCH	CCH-VSD	140525	A
761	RDCC-53 -53K001	MSS-53K001-SOFT	Inspect 11KV SOFT STARTER FOR MOTOR 53K0	PMT	3M		I			I			I			I		RRC	RRC-ERCP	254172	A
762	RDCC-53 -53K002	MSS-B2-2001-A11	INSPECT MV SWGR & CB MSS-B2-20	PMT	1M	I	I	I	I	I	I	I	I	I	I	I		RRC	RRC-ERCP	255687	C
763	RDCC-53 -53K001	MSS-B2-2001-B10	PM MV SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249588	A
764	RDCC-53 -53K001	MSS-B2-2001-B10	INSPECT MV SWGR & CB B2-2001-B10	PMT	1M	I	I	I	I	I	I	I	I	I	I	I		RRC	RRC-ERCP	138304	A
765	RDCC-53 -53P101A	MSS-B2-3001-A04	INSPECT MV SWGR & CB B2-3001-A04	PMT	1M	I	I	I	I	I	I	I	I	I	I	I		RRC	RRC-ERCP	138364	A
766	RDCC-53 -53P102B	MSS-B2-3001-A05	INSPECT MV SWGR & CB B2-3001-A05	PMT	1M	I	I	I	I	I	I	I	I	I	I	I		RRC	RRC-ERCP	138363	A
767	RDCC-53 -53P103A	MSS-B2-3001-A06	INSPECT MV SWGR & CB B2-3001-A06	PMT	1M	I	I	I	I	I	I	I	I	I	I	I		RRC	RRC-ERCP	138362	A
768	RDCC-53 -53P105A	MSS-B2-3001-A07	INSPECT MV SWGR & CB B2-3001-A07	PMT	1M	I	I	I	I	I	I	I	I	I	I	I		RRC	RRC-ERCP	138361	A
769	RDCC-53 -53P121A	MSS-B2-3001-A08	INSPECT MV SWGR & CB B2-3001-A08	PMT	1M	I	I	I	I	I	I	I	I	I	I	I		RRC	RRC-ERCP	138360	A
770	RDCC-53 -53P140A	MSS-B2-3001-A24	INSPECT MV SWGR & CB MSS-B2-30	PMT	1M	I	I	I	I	I	I	I	I	I	I	I		RRC	RRC-ERCP	255684	C
771	RDCC-53 -53P140C	MSS-B2-3001-A25	INSPECT MV SWGR & CB MSS-B2-30	PMT	1M	I	I	I	I	I	I	I	I	I	I	I		RRC	RRC-ERCP	255686	C
772	RDCC-53 -53P101B	MSS-B2-3001-B06	INSPECT MV SWGR & CB B2-3001-B06	PMT	1M	I	I	I	I	I	I	I	I	I	I	I		RRC	RRC-ERCP	138317	A
773	RDCC-53 -53P102C	MSS-B2-3001-B07	INSPECT MV SWGR & CB B2-3001-B07	PMT	1M	I	I	I	I	I	I	I	I	I	I	I		RRC	RRC-ERCP	138318	A
774	RDCC-53 -53P103B	MSS-B2-3001-B08	INSPECT MV SWGR & CB B2-3001-B08	PMT	1M	I	I	I	I	I	I	I	I	I	I	I		RRC	RRC-ERCP	138319	A
775	RDCC-53 -53P105B	MSS-B2-3001-B09	INSPECT MV SWGR & CB B2-3001-B09	PMT	1M	I	I	I	I	I	I	I	I	I	I	I		RRC	RRC-ERCP	138320	A
776	RDCC-53 -53P121B	MSS-B2-3001-B10	INSPECT MV SWGR & CB B2-3001-B10	PMT	1M	I	I	I	I	I	I	I	I	I	I	I		RRC	RRC-ERCP	138321	A
777	RDCC-53 -53P140B	MSS-B2-3001-B28	INSPECT MV SWGR & CB MSS-B2-30	PMT	1M	I	I	I	I	I	I	I	I	I	I	I		RRC	RRC-ERCP	255685	C
778	RDCC-53 -AIR	RDCC-53-AH-001	PM ALL TYPE OF AIR 53-AH-001 (Large 2,8)	PMT	2M				P		P					P	P	RRC	RRC-ERCP	138222	A
779	RDCC-53 -AIR	RDCC-53-AH-001	PM ALL TYPE OF AIR 53-AH-001 (Large 2,8)	PMT	6M		P						P					RRC	RRC-ERCP	138222	A
780	RDCC-53 -AIR	RDCC-53-CEMS-001	PM TYPE OF AIR 53-CEMS-001 (Large 2,8)	PMT	2M				P		P					P	P	RRC	RRC-ERCP	138251	A
781	RDCC-53 -AIR	RDCC-53-CEMS-001	PM TYPE OF AIR 53-CEMS-001 (Large 2,8)	PMT	6M		P						P					RRC	RRC-ERCP	138251	A
782	RDCC-53 -AIR	RDCC-53-CEMS-101	PM TYPE OF AIR 53-CEMS-101 (Large 2,8)	PMT	2M				P		P					P	P	RRC	RRC-ERCP	138252	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
783	RDCC-53 -AIR	RDCC-53-CEMS-101	PM TYPE OF AIR 53-CEMS-101 (Large 2,8)	PMT	6M		P							P				RRC	RRC-ERCP	138252	A
784	RDCC-53 -53B101	RDCC-53B101-B01	FIRE HEATER ON-STREAM INSPECTION#53B101	PMT	1Y					I								IRI	IRI-INRC	150298	B
785	RDCC-53 -53B101	RDCC-53B101-BURN1	PM INSP OF M/C NO. 53B101 -B1	PMT	6M				L						L			RRC	RRC-MRCP	149117	B
786	RDCC-53 -53B101	RDCC-53B101-BURN2	PM INSP OF M/C NO. 53B101 -B2	PMT	6M				L						L			RRC	RRC-MRCP	149118	B
787	RDCC-53 -53B101	RDCC-53B101-BURN3	PM INSP OF M/C NO. 53B101 -B3	PMT	6M				L						L			RRC	RRC-MRCP	149119	B
788	RDCC-53 -53B101	RDCC-53B101-BURN4	PM INSP OF M/C NO. 53B101 -B4	PMT	6M				L						L			RRC	RRC-MRCP	149120	B
789	RDCC-53 -53B101	RDCC-53B101-BURN5	PM INSP OF M/C NO. 53B101 -B5	PMT	6M				L						L			RRC	RRC-MRCP	149121	B
790	RDCC-53 -53B101	RDCC-53B101-BURN6	PM INSP OF M/C NO. 53B101 -B6	PMT	6M				L						L			RRC	RRC-MRCP	149122	B
791	RDCC-53 -53C101	RDCC-53C101-C01	Pressure Vessel inspection	PMT	5Y											I		IRI	IRI-INRC	169096	C
792	RDCC-53 -53C102	RDCC-53C102-C01	Pressure Vessel inspection	PMT	5Y											I		IRI	IRI-INRC	169097	C
793	RDCC-53 -53C103	RDCC-53C103-C01	Pressure Vessel inspection	PMT	5Y											I		IRI	IRI-INRC	169098	C
794	RDCC-53 -53C104	RDCC-53C104-C01	Pressure Vessel inspection	PMT	5Y											I		IRI	IRI-INRC	169099	C
795	RDCC-53 -53C105	RDCC-53C105-C01	Pressure Vessel inspection	PMT	5Y											I		IRI	IRI-INRC	169100	C
796	RDCC-53 -53C106	RDCC-53C106-C01	Pressure Vessel inspection	PMT	5Y											I		IRI	IRI-INRC	169101	C
797	RDCC-53 -53C107	RDCC-53C107-C01	Pressure Vessel inspection	PMT	5Y											I		IRI	IRI-INRC	169102	C
798	RDCC-53 -53C108	RDCC-53C108-C01	Pressure Vessel inspection	PMT	5Y											I		IRI	IRI-INRC	169103	C
799	RDCC-53 -53C109	RDCC-53C109-C01	Pressure Vessel inspection	PMT	5Y											I		IRI	IRI-INRC	169104	C
800	RDCC-53 -53C110	RDCC-53C110-C01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169105	C
801	RDCC-53 -53D001	RDCC-53D001-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169106	C
802	RDCC-53 -53D002	RDCC-53D002-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169107	C
803	RDCC-53 -53D003A	RDCC-53D003A-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169108	C
804	RDCC-53 -53D003B	RDCC-53D003B-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169109	C
805	RDCC-53 -53D004	RDCC-53D004-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169110	C
806	RDCC-53 -53D005	RDCC-53D005-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169111	C
807	RDCC-53 -53D101	RDCC-53D101-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169112	C
808	RDCC-53 -53D102	RDCC-53D102-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169113	C
809	RDCC-53 -53D103	RDCC-53D103-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169114	C
810	RDCC-53 -53D104	RDCC-53D104-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169115	C
811	RDCC-53 -53D105	RDCC-53D105-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169116	C
812	RDCC-53 -53D106	RDCC-53D106-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169117	C
813	RDCC-53 -53D107	RDCC-53D107-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169118	C
814	RDCC-53 -53D108	RDCC-53D108-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169119	C
815	RDCC-53 -53D110	RDCC-53D110-D01	Pressure Vessel inspection	PMT	5Y													I	IRI	IRI-INRC	169120	C
816	RDCC-53 -53D111	RDCC-53D111-D01	Pressure Vessel inspection	PMT	5Y													I	IRI	IRI-INRC	169121	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
817	RDCC-53 -53D112	RDCC-53D112-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169122	C
818	RDCC-53 -53D114	RDCC-53D114-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169123	C
819	RDCC-53 -53D115	RDCC-53D115-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169124	C
820	RDCC-53 -53D116	RDCC-53D116-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169125	C
821	RDCC-53 -53D117	RDCC-53D117-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169126	C
822	RDCC-53 -53D118	RDCC-53D118-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169127	C
823	RDCC-53 -53D119	RDCC-53D119-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169128	C
824	RDCC-53 -53D120	RDCC-53D120-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169129	C
825	RDCC-53 -53D121	RDCC-53D121-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169130	C
826	RDCC-53 -53D122	RDCC-53D122-D01	Pressure Vessel inspection	PMT	5Y												I	IRI	IRI-INRC	169131	C
827	RDCC-53 -DVA5301	RDCC-53DV001	TEST LINEAR HEAT DETECTOR RDCC-53DV001	PMT	6M			P						P				RRC	RRC-ERCP	150078	B
828	RDCC-53 -DVA5301	RDCC-53DV002	TEST LINEAR HEAT DETECTOR RDCC-53DV002	PMT	6M			P						P				RRC	RRC-ERCP	150079	B
829	RDCC-53 -DVA5301	RDCC-53DV003	TEST LINEAR HEAT DETECTOR RDCC-53DV003	PMT	6M			P						P				RRC	RRC-ERCP	150080	B
830	RDCC-53 -DVA5301	RDCC-53DV004	TEST LINEAR HEAT DETECTOR RDCC-53DV004	PMT	6M			P						P				RRC	RRC-ERCP	150081	B
831	RDCC-53 -DVA5301	RDCC-53DV005	TEST LINEAR HEAT DETECTOR RDCC-53DV005	PMT	6M			P						P				RRC	RRC-ERCP	150082	B
832	RDCC-53 -DVA5301	RDCC-53DV006	TEST LINEAR HEAT DETECTOR RDCC-53DV006	PMT	6M			P						P				RRC	RRC-ERCP	150083	B
833	RDCC-53 -DVA5302	RDCC-53DV007	TEST LINEAR HEAT DETECTOR RDCC-53DV007	PMT	6M			P						P				RRC	RRC-ERCP	150084	B
834	RDCC-53 -DVA5302	RDCC-53DV008	TEST LINEAR HEAT DETECTOR RDCC-53DV008	PMT	6M			P						P				RRC	RRC-ERCP	150085	B
835	RDCC-53 -DVA5302	RDCC-53DV009	TEST LINEAR HEAT DETECTOR RDCC-53DV009	PMT	6M			P						P				RRC	RRC-ERCP	150086	B
836	RDCC-53 -DVA5302	RDCC-53DV010	TEST LINEAR HEAT DETECTOR RDCC-53DV010	PMT	6M			P						P				RRC	RRC-ERCP	150087	B
837	RDCC-53 -DVA5303	RDCC-53DV011	TEST LINEAR HEAT DETECTOR RDCC-53DV011	PMT	6M			P						P				RRC	RRC-ERCP	150088	B
838	RDCC-53 -DVA5303	RDCC-53DV012	TEST LINEAR HEAT DETECTOR RDCC-53DV012	PMT	6M			P						P				RRC	RRC-ERCP	150089	B
839	RDCC-53 -DVA5303	RDCC-53DV013	TEST LINEAR HEAT DETECTOR RDCC-53DV013	PMT	6M			P						P				RRC	RRC-ERCP	150090	B
840	RDCC-53 -DVA5303	RDCC-53DV014	TEST LINEAR HEAT DETECTOR RDCC-53DV014	PMT	6M			P						P				RRC	RRC-ERCP	150091	B
841	RDCC-53 -DVA5303	RDCC-53DV015	TEST LINEAR HEAT DETECTOR RDCC-53DV015	PMT	6M			P						P				RRC	RRC-ERCP	150092	B
842	RDCC-53 -DVA5304	RDCC-53DV016	TEST LINEAR HEAT DETECTOR RDCC-53DV016	PMT	6M			P						P				RRC	RRC-ERCP	150093	B
843	RDCC-53 -DVA5304	RDCC-53DV017	TEST LINEAR HEAT DETECTOR RDCC-53DV017	PMT	6M			P						P				RRC	RRC-ERCP	150094	B
844	RDCC-53 -DVA5304	RDCC-53DV018	TEST LINEAR HEAT DETECTOR RDCC-53DV018	PMT	6M			P						P				RRC	RRC-ERCP	150095	B
845	RDCC-53 -DVA5304	RDCC-53DV019	TEST LINEAR HEAT DETECTOR RDCC-53DV019	PMT	6M			P						P				RRC	RRC-ERCP	150096	B
846	RDCC-53 -DVA5304	RDCC-53DV020	TEST LINEAR HEAT DETECTOR RDCC-53DV020	PMT	6M			P						P				RRC	RRC-ERCP	150097	B
847	RDCC-53 -DVA5304	RDCC-53DV021	TEST LINEAR HEAT DETECTOR RDCC-53DV021	PMT	6M			P						P				RRC	RRC-ERCP	150098	B
848	RDCC-53 -DVA5304	RDCC-53DV022	TEST LINEAR HEAT DETECTOR RDCC-53DV022	PMT	6M			P						P				RRC	RRC-ERCP	150099	B
849	RDCC-53 -DVA5304	RDCC-53DV023	TEST LINEAR HEAT DETECTOR RDCC-53DV023	PMT	6M			P						P				RRC	RRC-ERCP	150100	B
850	RDCC-53 -DVA5304	RDCC-53DV024	TEST LINEAR HEAT DETECTOR RDCC-53DV024	PMT	6M			P						P				RRC	RRC-ERCP	150101	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
851	RDCC-53 -53E117	RDCC-53E117-K01A	VB. INSP & ANALY M/C 53E117-K01A	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149155	C
852	RDCC-53 -53E117	RDCC-53E117-K01A	PM INSP OF M/C NO. 53E117-K01A	PMT	3M			I			I			I			I	RRC	RRC-MRCP	148818	C
853	RDCC-53 -53E117	RDCC-53E117-K01A	REGREASING BRG OF 53E117-K01A	PMT	3M			L			L			L			L	RRC	RRC-MRCP	148894	C
854	RDCC-53 -53E117	RDCC-53E117-K01A-M	STAND BY CHECK LV. MOT 53E117-K01A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139070	C
855	RDCC-53 -53E117	RDCC-53E117-K01A-M	Regreasing Mot BRG of 53E117-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139508	C
856	RDCC-53 -53E117	RDCC-53E117-K01A-M	STAND BY CHECK LV. MOT 53E117-K01A-MD1	PMT	1Y				T									RRC	RRC-ERCP	153768	C
857	RDCC-53 -53E117	RDCC-53E117-K01B	VB. INSP & ANALY M/C 53E117-K01B	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149156	C
858	RDCC-53 -53E117	RDCC-53E117-K01B	PM INSP OF M/C NO. 53E117-K01B	PMT	3M			I			I			I			I	RRC	RRC-MRCP	148819	C
859	RDCC-53 -53E117	RDCC-53E117-K01B	REGREASING BRG OF 53E117-K01B	PMT	3M			L			L			L			L	RRC	RRC-MRCP	148895	C
860	RDCC-53 -53E117	RDCC-53E117-K01B-M	Regreasing Mot BRG of 53E117-K01B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139509	C
861	RDCC-53 -53E131	RDCC-53E131-K01A	VB. INSP & ANALY M/C 53E131-K01A	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149157	C
862	RDCC-53 -53E131	RDCC-53E131-K01A	PM INSP OF M/C NO. 53E131-K01A	PMT	3M			I			I			I			I	RRC	RRC-MRCP	148820	C
863	RDCC-53 -53E131	RDCC-53E131-K01A	REGREASING BRG OF 53E131-K01A	PMT	3M			L			L			L			L	RRC	RRC-MRCP	148896	C
864	RDCC-53 -53E131	RDCC-53E131-K01A-M	STAND BY CHECK LV. MOT 53E131-K01A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139072	C
865	RDCC-53 -53E131	RDCC-53E131-K01A-M	Regreasing Mot BRG of 53E131-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139510	C
866	RDCC-53 -53E131	RDCC-53E131-K01A-M	STAND BY CHECK LV. MOT 53E131-K01A-MD1	PMT	1Y				T									RRC	RRC-ERCP	153769	C
867	RDCC-53 -53E131	RDCC-53E131-K01B	VB. INSP & ANALY M/C 53E131-K01B	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149158	C
868	RDCC-53 -53E131	RDCC-53E131-K01B	PM INSP OF M/C NO. 53E131-K01B	PMT	3M			I			I			I			I	RRC	RRC-MRCP	148821	C
869	RDCC-53 -53E131	RDCC-53E131-K01B	REGREASING BRG OF 53E131-K01B	PMT	3M			L			L			L			L	RRC	RRC-MRCP	148897	C
870	RDCC-53 -53E131	RDCC-53E131-K01B-M	Regreasing Mot BRG of 53E131-K01B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139511	C
871	RDCC-53 -53E133	RDCC-53E133-K01A	VB. INSP & ANALY M/C 53E133-K01A	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149159	C
872	RDCC-53 -53E133	RDCC-53E133-K01A	PM INSP OF M/C NO. 53E133-K01A	PMT	3M			I			I			I			I	RRC	RRC-MRCP	148822	C
873	RDCC-53 -53E133	RDCC-53E133-K01A	REGREASING BRG OF 53E133-K01A	PMT	3M			L			L			L			L	RRC	RRC-MRCP	148898	C
874	RDCC-53 -53E133	RDCC-53E133-K01A-M	STAND BY CHECK LV. MOT 53E133-K01A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139074	C
875	RDCC-53 -53E133	RDCC-53E133-K01A-M	Regreasing Mot BRG of 53E133-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139512	C
876	RDCC-53 -53E133	RDCC-53E133-K01A-M	STAND BY CHECK LV. MOT 53E133-K01A-MD1	PMT	1Y				T									RRC	RRC-ERCP	153770	C
877	RDCC-53 -53E133	RDCC-53E133-K01B	VB. INSP & ANALY M/C 53E133-K01B	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149160	C
878	RDCC-53 -53E133	RDCC-53E133-K01B	PM INSP OF M/C NO. 53E133-K01B	PMT	3M			I			I			I			I	RRC	RRC-MRCP	148823	C
879	RDCC-53 -53E133	RDCC-53E133-K01B	REGREASING BRG OF 53E133-K01B	PMT	3M			L			L			L			L	RRC	RRC-MRCP	148899	C
880	RDCC-53 -53E133	RDCC-53E133-K01B-M	Regreasing Mot BRG of 53E133-K01B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139513	C
881	RDCC-53 -53H001	RDCC-53H001-H01	Over Head Crane Inspection By	INT	1Y				I									IRI	IRI-INSS	130569	C
882	RDCC-53 -53H001	RDCC-53H001-H01	PM OF 53H001	PMT	1Y										P			RRC	RRC-MRCP	148824	C
883	RDCC-53 -53H001	RDCC-53H001-H01	PM INSP OF M/C NO. 53H001	PMT	4M	I				I				I				RRC	RRC-MRCP	148900	C
884	RDCC-53 -53H002	RDCC-53H002-H01	Over Head Crane Inspection By	INT	6M				I						I			IRI	IRI-INSS	130566	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
885	RDCC-53 -53H002	RDCC-53H002-H01	PM OF 53H002	PMT	1Y										P			RRC	RRC-MRCP	148825	C
886	RDCC-53 -53H002	RDCC-53H002-H01	PM INSP OF M/C NO. 53H002	PMT	4M	I				I				I				RRC	RRC-MRCP	148901	C
887	RDCC-53 -53H003	RDCC-53H003-H01	Over Head Crane Inspection By	INT	6M				I						I			IRI	IRI-INSS	130567	C
888	RDCC-53 -53H003	RDCC-53H003-H01	PM OF 53H003	PMT	1Y										P			RRC	RRC-MRCP	148826	C
889	RDCC-53 -53H003	RDCC-53H003-H01	PM INSP OF M/C NO. 53H003	PMT	4M	I				I				I				RRC	RRC-MRCP	148902	C
890	RDCC-53 -53H004	RDCC-53H004-H01	PM LIFT 53H004-H01	PMT	1M	P	P	P	P	P	P	P	P	P	P	P	P	RRC	RRC-ERCP	242146	C
891	RDCC-53 -53H005	RDCC-53H005-H01	OVERHEAD CRANE INSPECT & LOAD TEST_LAW	INT	6M				I						I			IRI	IRI-INSS	157591	C
892	RDCC-53 -53H006	RDCC-53H006-H01	PM INSP OF M/C NO. RDCC-53H006	PMT	4M	I				I				I				RRC	RRC-MRCP	255694	C
893	RDCC-53 -53H006	RDCC-53H006-H01	PM OF RDCC-53H006-H01	PMT	4M	P				P				P				RRC	RRC-MRCP	255702	C
894	RDCC-53 -53K001	RDCC-53K001-K01	PM COMPRESSOR NO. 53K001 -K01	PMT	1Y				I									CRE	CRE-OHIP	129949	A
895	RDCC-53 -53K001	RDCC-53K001-K01	OIL INSP & ANALYSIS M/C 53K001 -K01	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INDL	130072	A
896	RDCC-53 -53K001	RDCC-53K001-K02-M	STAND BY CHECK LV. MOT 53K001-K02-MD1	PMT	6M			T						T				RRC	RRC-ERCP	139076	A
897	RDCC-53 -53K001	RDCC-53K001-P01	VB. INSP & ANALY M/C 53K001	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130168	A
898	RDCC-53 -53K001	RDCC-53K001-P01	PM INSP OF M/C NO. 53K001 -P01	PMT	4M		I			I				I				RRC	RRC-MRCP	129569	A
899	RDCC-53 -53K001	RDCC-53K001-P01-M	Regreasing Mot BRG of 53K001-P01-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139515	A
900	RDCC-53 -53K001	RDCC-53K001-P02	VB. INSP & ANALY M/C 53K001	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130169	A
901	RDCC-53 -53K001	RDCC-53K001-P02	PM INSP OF M/C NO. 53K001 -P02	PMT	4M		I			I				I				RRC	RRC-MRCP	129570	A
902	RDCC-53 -53K001	RDCC-53K001-P02-M	Regreasing Mot BRG of 53K001-P02-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139516	A
903	RDCC-53 -53K001	RDCC-53K001-PLC	INSPECT PLC SYSTEM	PMT	3M			I		I				I			I	CCS	CCS-SYS	246466	A
904	RDCC-53 -53K001	RDCC-53K001-PLC	BACKUP PLC SYSTEM	PMT	6M			I		I				I				CCS	CCS-SYS	246467	A
905	RDCC-53 -53K002	RDCC-53K002-K01	PM COMPRESSOR NO. RDCC-53K002-	PMT	1Y				I									CRE	CRE-OHIP	255710	C
906	RDCC-53 -53K002	RDCC-53K002-K01	OIL INSP & ANALYSIS M/C	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INDL	260304	C
907	RDCC-53 -53K002	RDCC-53K002-P01A	PM INSP OF M/C NO. RDCC-53K002	PMT	4M	I				I				I				RRC	RRC-MRCP	255692	C
908	RDCC-53 -53K002	RDCC-53K002-P01B	PM INSP OF M/C NO. RDCC-53K002	PMT	4M	I				I				I				RRC	RRC-MRCP	255693	C
909	RDCC-53 -53K002	RDCC-53K002-P01B-M	Regreasing Mot BRG of RDCC-53K	PMT	4M	L				L				L				RRC	RRC-ERCP	255706	C
910	RDCC-53 -53K101	RDCC-53K101-K01	PM COMPRESSOR NO. 53K101	PMT	1Y				I									CRE	CRE-OHIP	155801	A
911	RDCC-53 -53K101	RDCC-53K101-P01	VB. INSP & ANALY M/C 53K101	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130170	A
912	RDCC-53 -53K101	RDCC-53K101-P01	PM INSP OF M/C NO. 53K101 -P01	PMT	4M		I			I				I				RRC	RRC-MRCP	129571	A
913	RDCC-53 -53K101	RDCC-53K101-P01-M	Regreasing Mot BRG of 53K101-P01-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139517	A
914	RDCC-53 -53K101	RDCC-53K101-P02	VB. INSP & ANALY M/C 53K101	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130171	A
915	RDCC-53 -53K101	RDCC-53K101-P02	PM INSP OF M/C NO. 53K101 -P02	PMT	4M		I			I				I				RRC	RRC-MRCP	129572	A
916	RDCC-53 -53K101	RDCC-53K101-P02-M	Regreasing Mot BRG of 53K101-P02-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139518	A
917	RDCC-53 -53K101	RDCC-53K101-TB01	PM COMPRESSOR NO. 53K101	PMT	1Y				I									CRE	CRE-OHIP	129950	A
918	RDCC-53 -53K101	RDCC-53K101-TB01	OIL INSP & ANALYSIS M/C 53K101	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INDL	130073	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
919	RDCC-53 -53K101	RDCC-53K101-TB01	VANISH INSP&ANALYSIS	INT	6M					I					I			IRI	IRI-INDL	157623	A
920	RDCC-53 -53P101A	RDCC-53P101A-M	STAND BY CHECK MV. MOT 53P101A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139078	A
921	RDCC-53 -53P101A	RDCC-53P101A-M	Regreasing Mot BRG of 53P101A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139388	A
922	RDCC-53 -53P101A	RDCC-53P101A-M	STAND BY CHECK MV. MOT 53P101A-MD1	PMT	1Y				T									RRC	RRC-ERCP	153771	A
923	RDCC-53 -53P101A	RDCC-53P101A-P01	VB. INSP & ANALY M/C 53P101A	INT	4M	I				I				I				IRI	IRI-INVB	130172	A
924	RDCC-53 -53P101A	RDCC-53P101A-P01	VB. INSP & ANALY M/C 53P101A -P01	INT	4M		I				I				I			IRI	IRI-INVB	130969	A
925	RDCC-53 -53P101A	RDCC-53P101A-P01	VB. INSP & ANALY M/C 53P101A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131195	A
926	RDCC-53 -53P101A	RDCC-53P101A-P01	PM INSP OF M/C NO. 53P101A -P01	PMT	4M	I				I				I				RRC	RRC-MRCP	129573	A
927	RDCC-53 -53P101A	RDCC-53P101A-P01	PM OF 53P101A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130628	A
928	RDCC-53 -53P101B	RDCC-53P101B-M	STAND BY CHECK MV. MOT 53P101B-MD1	PMT	6M			T						T				RRC	RRC-ERCP	139079	A
929	RDCC-53 -53P101B	RDCC-53P101B-M	Regreasing Mot BRG of 53P101B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139389	A
930	RDCC-53 -53P101B	RDCC-53P101B-P01	VB. INSP & ANALY M/C 53P101B	INT	4M				I				I				I	IRI	IRI-INVB	130173	A
931	RDCC-53 -53P101B	RDCC-53P101B-P01	PM INSP OF M/C NO. 53P101B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129574	A
932	RDCC-53 -53P101B	RDCC-53P101B-P01	PM OF 53P101B -P01	PMT	4M	P				P				P				RRC	RRC-MRCP	130629	A
933	RDCC-53 -53P102A	RDCC-53P102A-P01	VB. INSP & ANALY M/C 53P102A	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130174	A
934	RDCC-53 -53P102A	RDCC-53P102A-P01	PM INSP OF M/C NO. 53P102A -P01	PMT	4M	I				I				I				RRC	RRC-MRCP	129575	A
935	RDCC-53 -53P102A	RDCC-53P102A-P01	PM OF 53P102A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130630	A
936	RDCC-53 -53P102A	RDCC-53P102A-TB	FUNCTION TEST TURBINE NO.53P102A-TB	PMT	1Y		F											CRE	CRE-OHIP	125575	A
937	RDCC-53 -53P102A	RDCC-53P102A-TB	PM TURBINE DRIVE PUMP NO.53P102A-TB	PMT	1Y		P											CRE	CRE-OHIP	125577	A
938	RDCC-53 -53P102B	RDCC-53P102B-M	STAND BY CHECK MV. MOT 53P102B-MD1	PMT	1Y								T					RRC	RRC-ERCP	139080	A
939	RDCC-53 -53P102B	RDCC-53P102B-M	Regreasing Mot BRG of 53P102B-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139390	A
940	RDCC-53 -53P102B	RDCC-53P102B-M	STAND BY CHECK MV. MOT 53P102B-MD1	PMT	1Y				T									RRC	RRC-ERCP	153772	A
941	RDCC-53 -53P102B	RDCC-53P102B-P01	VB. INSP & ANALY M/C 53P102B	INT	4M	I				I				I				IRI	IRI-INVB	130175	A
942	RDCC-53 -53P102B	RDCC-53P102B-P01	VB. INSP & ANALY M/C 53P102B -P01	INT	4M			I			I				I			IRI	IRI-INVB	130970	A
943	RDCC-53 -53P102B	RDCC-53P102B-P01	VB. INSP & ANALY M/C 53P102B -P01	INT	4M				I			I				I		IRI	IRI-INVB	131196	A
944	RDCC-53 -53P102B	RDCC-53P102B-P01	PM INSP OF M/C NO. 53P102B -P01	PMT	4M	I				I				I				RRC	RRC-MRCP	129576	A
945	RDCC-53 -53P102B	RDCC-53P102B-P01	PM OF 53P102B -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130631	A
946	RDCC-53 -53P102C	RDCC-53P102C-M	STAND BY CHECK MV. MOT 53P102C-MD1	PMT	6M			T						T				RRC	RRC-ERCP	139081	A
947	RDCC-53 -53P102C	RDCC-53P102C-M	Regreasing Mot BRG of 53P102C-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139391	A
948	RDCC-53 -53P102C	RDCC-53P102C-P01	VB. INSP & ANALY M/C 53P102C	INT	4M				I				I				I	IRI	IRI-INVB	130176	A
949	RDCC-53 -53P102C	RDCC-53P102C-P01	PM INSP OF M/C NO. 53P102C -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129577	A
950	RDCC-53 -53P102C	RDCC-53P102C-P01	PM OF 53P102C -P01	PMT	4M	P				P				P				RRC	RRC-MRCP	130632	A
951	RDCC-53 -53P103A	RDCC-53P103A-M	STAND BY CHECK MV. MOT 53P103A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139082	A
952	RDCC-53 -53P103A	RDCC-53P103A-M	Regreasing Mot BRG of 53P103A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139392	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
953	RDCC-53 -53P103A	RDCC-53P103A-M	STAND BY CHECK MV. MOT 53P103A-MD1	PMT	1Y				T									RRC	RRC-ERCP	153773	A
954	RDCC-53 -53P103A	RDCC-53P103A-P01	VB. INSP & ANALY M/C 53P103A	INT	4M	I				I				I				IRI	IRI-INVB	130177	A
955	RDCC-53 -53P103A	RDCC-53P103A-P01	VB. INSP & ANALY M/C 53P103A -P01	INT	4M		I				I				I			IRI	IRI-INVB	130971	A
956	RDCC-53 -53P103A	RDCC-53P103A-P01	VB. INSP & ANALY M/C 53P103A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131197	A
957	RDCC-53 -53P103A	RDCC-53P103A-P01	PM INSP OF M/C NO. 53P103A -P01	PMT	4M	I				I				I				RRC	RRC-MRCP	129578	A
958	RDCC-53 -53P103A	RDCC-53P103A-P01	PM OF 53P103A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130633	A
959	RDCC-53 -53P103B	RDCC-53P103B-M	STAND BY CHECK MV. MOT 53P103B-MD1	PMT	6M			T						T				RRC	RRC-ERCP	139083	A
960	RDCC-53 -53P103B	RDCC-53P103B-M	Regreasing Mot BRG of 53P103B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139393	A
961	RDCC-53 -53P103B	RDCC-53P103B-P01	VB. INSP & ANALY M/C 53P103B	INT	4M				I				I				I	IRI	IRI-INVB	130178	A
962	RDCC-53 -53P103B	RDCC-53P103B-P01	PM INSP OF M/C NO. 53P103B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129579	A
963	RDCC-53 -53P103B	RDCC-53P103B-P01	PM OF 53P103B -P01	PMT	4M	P				P				P				RRC	RRC-MRCP	130634	A
964	RDCC-53 -53P104A	RDCC-53P104A-M	STAND BY CHECK LV. MOT 53P104A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139084	A
965	RDCC-53 -53P104A	RDCC-53P104A-M	Regreasing Mot BRG of 53P104A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139519	A
966	RDCC-53 -53P104A	RDCC-53P104A-M	STAND BY CHECK LV. MOT 53P104A-MD1	PMT	1Y				T									RRC	RRC-ERCP	153774	A
967	RDCC-53 -53P104A	RDCC-53P104A-P01	VB. INSP & ANALY M/C 53P104A	INT	4M	I				I				I				IRI	IRI-INVB	130179	A
968	RDCC-53 -53P104A	RDCC-53P104A-P01	VB. INSP & ANALY M/C 53P104A -P01	INT	4M		I				I				I			IRI	IRI-INVB	130972	A
969	RDCC-53 -53P104A	RDCC-53P104A-P01	VB. INSP & ANALY M/C 53P104A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131198	A
970	RDCC-53 -53P104A	RDCC-53P104A-P01	PM INSP OF M/C NO. 53P104A -P01	PMT	4M	I				I				I				RRC	RRC-MRCP	129580	A
971	RDCC-53 -53P104A	RDCC-53P104A-P01	PM OF 53P104A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130635	A
972	RDCC-53 -53P104B	RDCC-53P104B-M	STAND BY CHECK LV. MOT 53P104B-MD1	PMT	6M			T						T				RRC	RRC-ERCP	139085	A
973	RDCC-53 -53P104B	RDCC-53P104B-M	Regreasing Mot BRG of 53P104B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139520	A
974	RDCC-53 -53P104B	RDCC-53P104B-P01	VB. INSP & ANALY M/C 53P104B	INT	4M				I				I				I	IRI	IRI-INVB	130180	A
975	RDCC-53 -53P104B	RDCC-53P104B-P01	PM INSP OF M/C NO. 53P104B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129581	A
976	RDCC-53 -53P104B	RDCC-53P104B-P01	PM OF 53P104B -P01	PMT	4M	P				P				P				RRC	RRC-MRCP	130636	A
977	RDCC-53 -53P105A	RDCC-53P105A-M	STAND BY CHECK MV. MOT 53P105A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139086	A
978	RDCC-53 -53P105A	RDCC-53P105A-M	Regreasing Mot BRG of 53P105A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139394	A
979	RDCC-53 -53P105A	RDCC-53P105A-M	STAND BY CHECK MV. MOT 53P105A-MD1	PMT	1Y				T									RRC	RRC-ERCP	153775	A
980	RDCC-53 -53P105A	RDCC-53P105A-P01	VB. INSP & ANALY M/C 53P105A	INT	4M	I				I				I				IRI	IRI-INVB	130181	A
981	RDCC-53 -53P105A	RDCC-53P105A-P01	VB. INSP & ANALY M/C 53P105A -P01	INT	4M		I				I				I			IRI	IRI-INVB	130973	A
982	RDCC-53 -53P105A	RDCC-53P105A-P01	VB. INSP & ANALY M/C 53P105A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131199	A
983	RDCC-53 -53P105A	RDCC-53P105A-P01	PM INSP OF M/C NO. 53P105A -P01	PMT	4M		I				I				I			RRC	RRC-MRCP	129582	A
984	RDCC-53 -53P105A	RDCC-53P105A-P01	PM OF 53P105A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130637	A
985	RDCC-53 -53P105B	RDCC-53P105B-M	STAND BY CHECK MV. MOT 53P105B-MD1	PMT	6M			T						T				RRC	RRC-ERCP	139087	A
986	RDCC-53 -53P105B	RDCC-53P105B-M	Regreasing Mot BRG of 53P105B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139395	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
987	RDCC-53 -53P105B	RDCC-53P105B-P01	VB. INSP & ANALY M/C 53P105B	INT	4M				I				I				I	IRI	IRI-INVB	130182	A
988	RDCC-53 -53P105B	RDCC-53P105B-P01	PM INSP OF M/C NO. 53P105B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129583	A
989	RDCC-53 -53P105B	RDCC-53P105B-P01	PM OF 53P105B -P01	PMT	4M	P				P				P				RRC	RRC-MRCP	130638	A
990	RDCC-53 -53P106A	RDCC-53P106A-M	STAND BY CHECK LV. MOT 53P106A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139088	A
991	RDCC-53 -53P106A	RDCC-53P106A-M	Regreasing Mot BRG of 53P106A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139521	A
992	RDCC-53 -53P106A	RDCC-53P106A-M	STAND BY CHECK LV. MOT 53P106A-MD1	PMT	1Y				T									RRC	RRC-ERCP	153776	A
993	RDCC-53 -53P106A	RDCC-53P106A-P01	VB. INSP & ANALY M/C 53P106A	INT	4M	I				I				I				IRI	IRI-INVB	130183	A
994	RDCC-53 -53P106A	RDCC-53P106A-P01	VB. INSP & ANALY M/C 53P106A -P01	INT	4M		I				I				I			IRI	IRI-INVB	130974	A
995	RDCC-53 -53P106A	RDCC-53P106A-P01	VB. INSP & ANALY M/C 53P106A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131200	A
996	RDCC-53 -53P106A	RDCC-53P106A-P01	PM INSP OF M/C NO. 53P106A -P01	PMT	4M		I				I				I			RRC	RRC-MRCP	129584	A
997	RDCC-53 -53P106A	RDCC-53P106A-P01	PM OF 53P106A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130639	A
998	RDCC-53 -53P106B	RDCC-53P106B-M	STAND BY CHECK LV. MOT 53P106B-MD1	PMT	6M			T						T				RRC	RRC-ERCP	139089	A
999	RDCC-53 -53P106B	RDCC-53P106B-M	Regreasing Mot BRG of 53P106B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139522	A
1,000	RDCC-53 -53P106B	RDCC-53P106B-P01	VB. INSP & ANALY M/C 53P106B	INT	4M				I				I				I	IRI	IRI-INVB	130184	A
1,001	RDCC-53 -53P106B	RDCC-53P106B-P01	PM INSP OF M/C NO. 53P106B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129585	A
1,002	RDCC-53 -53P106B	RDCC-53P106B-P01	PM OF 53P106B -P01	PMT	4M	P				P				P				RRC	RRC-MRCP	130640	A
1,003	RDCC-53 -53P108A	RDCC-53P108A-M	STAND BY CHECK LV. MOT 53P108A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139090	A
1,004	RDCC-53 -53P108A	RDCC-53P108A-M	Regreasing Mot BRG of 53P108A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139523	A
1,005	RDCC-53 -53P108A	RDCC-53P108A-M	STAND BY CHECK LV. MOT 53P108A-MD1	PMT	1Y				T									RRC	RRC-ERCP	153777	A
1,006	RDCC-53 -53P108A	RDCC-53P108A-P01	VB. INSP & ANALY M/C 53P108A	INT	4M	I				I				I				IRI	IRI-INVB	130185	A
1,007	RDCC-53 -53P108A	RDCC-53P108A-P01	VB. INSP & ANALY M/C 53P108A -P01	INT	4M		I				I				I			IRI	IRI-INVB	130975	A
1,008	RDCC-53 -53P108A	RDCC-53P108A-P01	VB. INSP & ANALY M/C 53P108A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131201	A
1,009	RDCC-53 -53P108A	RDCC-53P108A-P01	PM INSP OF M/C NO. 53P108A -P01	PMT	4M		I				I				I			RRC	RRC-MRCP	129586	A
1,010	RDCC-53 -53P108A	RDCC-53P108A-P01	PM OF 53P108A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130641	A
1,011	RDCC-53 -53P108B	RDCC-53P108B-M	STAND BY CHECK LV. MOT 53P108B-MD1	PMT	6M			T						T				RRC	RRC-ERCP	139091	A
1,012	RDCC-53 -53P108B	RDCC-53P108B-M	Regreasing Mot BRG of 53P108B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139524	A
1,013	RDCC-53 -53P108B	RDCC-53P108B-P01	VB. INSP & ANALY M/C 53P108B	INT	4M				I				I				I	IRI	IRI-INVB	130186	A
1,014	RDCC-53 -53P108B	RDCC-53P108B-P01	PM INSP OF M/C NO. 53P108B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129587	A
1,015	RDCC-53 -53P108B	RDCC-53P108B-P01	PM OF 53P108B -P01	PMT	4M		P				P				P			RRC	RRC-MRCP	130642	A
1,016	RDCC-53 -53P109A	RDCC-53P109A-M	STAND BY CHECK LV. MOT 53P109A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139092	A
1,017	RDCC-53 -53P109A	RDCC-53P109A-M	Regreasing Mot BRG of 53P109A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139525	A
1,018	RDCC-53 -53P109A	RDCC-53P109A-M	STAND BY CHECK LV. MOT 53P109A-MD1	PMT	1Y				T									RRC	RRC-ERCP	153778	A
1,019	RDCC-53 -53P109A	RDCC-53P109A-P01	VB. INSP & ANALY M/C 53P109A	INT	4M	I				I				I				IRI	IRI-INVB	130187	A
1,020	RDCC-53 -53P109A	RDCC-53P109A-P01	VB. INSP & ANALY M/C 53P109A -P01	INT	4M				I				I				I	IRI	IRI-INVB	130976	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,021	RDCC-53 -53P109A	RDCC-53P109A-P01	VB. INSP & ANALY M/C 53P109A -P01	INT	4M			I			I				I			IRI	IRI-INVB	131202	A
1,022	RDCC-53 -53P109A	RDCC-53P109A-P01	PM INSP OF M/C NO. 53P109A -P01	PMT	4M		I				I			I				RRC	RRC-MRCP	129588	A
1,023	RDCC-53 -53P109A	RDCC-53P109A-P01	PM OF 53P109A -P01	PMT	4M				P			P				P		RRC	RRC-MRCP	130643	A
1,024	RDCC-53 -53P109B	RDCC-53P109B-M	STAND BY CHECK LV. MOT 53P109B-MD1	PMT	6M			T					T					RRC	RRC-ERCP	139093	A
1,025	RDCC-53 -53P109B	RDCC-53P109B-M	Regreasing Mot BRG of 53P109B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139526	A
1,026	RDCC-53 -53P109B	RDCC-53P109B-P01	VB. INSP & ANALY M/C 53P109B	INT	4M				I				I				I	IRI	IRI-INVB	130188	B
1,027	RDCC-53 -53P109B	RDCC-53P109B-P01	PM INSP OF M/C NO. 53P109B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129589	B
1,028	RDCC-53 -53P109B	RDCC-53P109B-P01	PM OF 53P109B -P01	PMT	4M		P				P				P			RRC	RRC-MRCP	130644	B
1,029	RDCC-53 -53P110A	RDCC-53P110A-M	STAND BY CHECK LV. MOT 53P110A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139094	A
1,030	RDCC-53 -53P110A	RDCC-53P110A-M	STAND BY CHECK LV. MOT 53P110A-MD1	PMT	1Y				T									RRC	RRC-ERCP	153779	A
1,031	RDCC-53 -53P110A	RDCC-53P110A-P01	VB. INSP & ANALY M/C 53P110A	INT	4M	I				I				I				IRI	IRI-INVB	130189	A
1,032	RDCC-53 -53P110A	RDCC-53P110A-P01	VB. INSP & ANALY M/C 53P110A -P01	INT	4M		I				I				I			IRI	IRI-INVB	130977	A
1,033	RDCC-53 -53P110A	RDCC-53P110A-P01	VB. INSP & ANALY M/C 53P110A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131203	A
1,034	RDCC-53 -53P110A	RDCC-53P110A-P01	PM INSP OF M/C NO. 53P110A -P01	PMT	4M		I				I				I			RRC	RRC-MRCP	129590	A
1,035	RDCC-53 -53P110A	RDCC-53P110A-P01	PM OF 53P110A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130645	A
1,036	RDCC-53 -53P110B	RDCC-53P110B-M	STAND BY CHECK LV. MOT 53P110B-MD1	PMT	6M			T						T				RRC	RRC-ERCP	139095	A
1,037	RDCC-53 -53P110B	RDCC-53P110B-P01	VB. INSP & ANALY M/C 53P110B	INT	4M				I				I				I	IRI	IRI-INVB	130190	A
1,038	RDCC-53 -53P110B	RDCC-53P110B-P01	PM INSP OF M/C NO. 53P110B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129591	A
1,039	RDCC-53 -53P110B	RDCC-53P110B-P01	PM OF 53P110B -P01	PMT	4M		P				P				P			RRC	RRC-MRCP	130646	A
1,040	RDCC-53 -53P111	RDCC-53P111-M	STAND BY CHECK LV. MOT 53P111-MD1	PMT	6M			T						T				RRC	RRC-ERCP	139096	A
1,041	RDCC-53 -53P111	RDCC-53P111-M	Regreasing Mot BRG of 53P111-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139529	A
1,042	RDCC-53 -53P111	RDCC-53P111-P01	VB. INSP & ANALY M/C 53P111	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130191	A
1,043	RDCC-53 -53P111	RDCC-53P111-P01	PM INSP OF M/C NO. 53P111 -P01	PMT	4M			I			I				I			RRC	RRC-MRCP	129592	A
1,044	RDCC-53 -53P111	RDCC-53P111-P01	PM OF 53P111 -P01	PMT	4M		P				P			P				RRC	RRC-MRCP	130647	A
1,045	RDCC-53 -53P112A	RDCC-53P112A-M	STAND BY CHECK LV. MOT 53P112A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139097	A
1,046	RDCC-53 -53P112A	RDCC-53P112A-M	Regreasing Mot BRG of 53P112A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139530	A
1,047	RDCC-53 -53P112A	RDCC-53P112A-M	STAND BY CHECK LV. MOT 53P112A-MD1	PMT	1Y				T									RRC	RRC-ERCP	153780	A
1,048	RDCC-53 -53P112A	RDCC-53P112A-P01	VB. INSP & ANALY M/C 53P112A	INT	4M	I				I				I				IRI	IRI-INVB	130192	A
1,049	RDCC-53 -53P112A	RDCC-53P112A-P01	VB. INSP & ANALY M/C 53P112A -P01	INT	4M		I				I				I			IRI	IRI-INVB	130978	A
1,050	RDCC-53 -53P112A	RDCC-53P112A-P01	VB. INSP & ANALY M/C 53P112A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131204	A
1,051	RDCC-53 -53P112A	RDCC-53P112A-P01	PM INSP OF M/C NO. 53P112A -P01	PMT	4M			I				I				I		RRC	RRC-MRCP	129593	A
1,052	RDCC-53 -53P112A	RDCC-53P112A-P01	PM OF 53P112A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130648	A
1,053	RDCC-53 -53P112B	RDCC-53P112B-M	STAND BY CHECK LV. MOT 53P112B-MD1	PMT	6M			T						T				RRC	RRC-ERCP	139098	A
1,054	RDCC-53 -53P112B	RDCC-53P112B-M	Regreasing Mot BRG of 53P112B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139531	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,055	RDCC-53 -53P112B	RDCC-53P112B-P01	VB. INSP & ANALY M/C 53P112B	INT	4M				I				I				I	IRI	IRI-INVB	130193	A
1,056	RDCC-53 -53P112B	RDCC-53P112B-P01	PM INSP OF M/C NO. 53P112B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129594	A
1,057	RDCC-53 -53P112B	RDCC-53P112B-P01	PM OF 53P112B -P01	PMT	4M		P				P				P			RRC	RRC-MRCP	130649	A
1,058	RDCC-53 -53P113	RDCC-53P113-M	STAND BY CHECK LV. MOT 53P113-MD1	PMT	6M			T						T				RRC	RRC-ERCP	139099	A
1,059	RDCC-53 -53P113	RDCC-53P113-P01	VB. INSP & ANALY M/C 53P113	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130194	A
1,060	RDCC-53 -53P113	RDCC-53P113-P01	PM INSP OF M/C NO. 53P113 -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129595	A
1,061	RDCC-53 -53P113	RDCC-53P113-P01	PM OF 53P113 -P01	PMT	4M		P				P				P			RRC	RRC-MRCP	130650	A
1,062	RDCC-53 -53P114A	RDCC-53P114A-M	STAND BY CHECK LV. MOT 53P114A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139100	B
1,063	RDCC-53 -53P114A	RDCC-53P114A-M	Regreasing Mot BRG of 53P114A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139533	B
1,064	RDCC-53 -53P114A	RDCC-53P114A-M	STAND BY CHECK LV. MOT 53P114A-MD1	PMT	1Y				T									RRC	RRC-ERCP	153781	B
1,065	RDCC-53 -53P114A	RDCC-53P114A-P01	VB. INSP & ANALY M/C 53P114A	INT	4M	I				I				I				IRI	IRI-INVB	130195	B
1,066	RDCC-53 -53P114A	RDCC-53P114A-P01	VB. INSP & ANALY M/C 53P114A -P01	INT	4M		I				I				I			IRI	IRI-INVB	130979	B
1,067	RDCC-53 -53P114A	RDCC-53P114A-P01	VB. INSP & ANALY M/C 53P114A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131205	B
1,068	RDCC-53 -53P114A	RDCC-53P114A-P01	PM INSP OF M/C NO. 53P114A -P01	PMT	4M			I				I				I		RRC	RRC-MRCP	129596	B
1,069	RDCC-53 -53P114A	RDCC-53P114A-P01	PM OF 53P114A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130651	B
1,070	RDCC-53 -53P114B	RDCC-53P114B-M	STAND BY CHECK LV. MOT 53P114B-MD1	PMT	6M			T						T				RRC	RRC-ERCP	139101	B
1,071	RDCC-53 -53P114B	RDCC-53P114B-M	Regreasing Mot BRG of 53P114B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139534	B
1,072	RDCC-53 -53P114B	RDCC-53P114B-P01	VB. INSP & ANALY M/C 53P114B	INT	4M				I				I				I	IRI	IRI-INVB	130196	B
1,073	RDCC-53 -53P114B	RDCC-53P114B-P01	PM INSP OF M/C NO. 53P114B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129597	B
1,074	RDCC-53 -53P114B	RDCC-53P114B-P01	PM OF 53P114B -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130652	B
1,075	RDCC-53 -53P115A	RDCC-53P115A-M	STAND BY CHECK LV. MOT 53P115A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139102	A
1,076	RDCC-53 -53P115A	RDCC-53P115A-M	Regreasing Mot BRG of 53P115A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139535	A
1,077	RDCC-53 -53P115A	RDCC-53P115A-M	STAND BY CHECK LV. MOT 53P115A-MD1	PMT	1Y				T									RRC	RRC-ERCP	153782	A
1,078	RDCC-53 -53P115A	RDCC-53P115A-P01	VB. INSP & ANALY M/C 53P115A	INT	4M	I				I				I				IRI	IRI-INVB	130197	A
1,079	RDCC-53 -53P115A	RDCC-53P115A-P01	VB. INSP & ANALY M/C 53P115A -P01	INT	4M		I				I				I			IRI	IRI-INVB	130980	A
1,080	RDCC-53 -53P115A	RDCC-53P115A-P01	VB. INSP & ANALY M/C 53P115A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131206	A
1,081	RDCC-53 -53P115A	RDCC-53P115A-P01	PM INSP OF M/C NO. 53P115A -P01	PMT	4M			I				I				I		RRC	RRC-MRCP	129598	A
1,082	RDCC-53 -53P115A	RDCC-53P115A-P01	PM OF 53P115A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130653	A
1,083	RDCC-53 -53P115B	RDCC-53P115B-M	STAND BY CHECK LV. MOT 53P115B-MD1	PMT	6M			T						T				RRC	RRC-ERCP	139103	A
1,084	RDCC-53 -53P115B	RDCC-53P115B-M	Regreasing Mot BRG of 53P115B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139536	A
1,085	RDCC-53 -53P115B	RDCC-53P115B-P01	VB. INSP & ANALY M/C 53P115B	INT	4M				I				I				I	IRI	IRI-INVB	130198	A
1,086	RDCC-53 -53P115B	RDCC-53P115B-P01	PM INSP OF M/C NO. 53P115B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129599	A
1,087	RDCC-53 -53P115B	RDCC-53P115B-P01	PM OF 53P115B -P01	PMT	4M			P				P				P		RRC	RRC-MRCP	130654	A
1,088	RDCC-53 -53P116A	RDCC-53P116A-M	STAND BY CHECK LV. MOT 53P116A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139104	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,089	RDCC-53 -53P116A	RDCC-53P116A-M	Regreasing Mot BRG of 53P116A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139537	A
1,090	RDCC-53 -53P116A	RDCC-53P116A-M	STAND BY CHECK LV. MOT 53P116A-MD1	PMT	1Y				T									RRC	RRC-ERCP	153783	A
1,091	RDCC-53 -53P116A	RDCC-53P116A-P01	VB. INSP & ANALY M/C 53P116A	INT	4M	I				I				I				IRI	IRI-INVB	130199	A
1,092	RDCC-53 -53P116A	RDCC-53P116A-P01	VB. INSP & ANALY M/C 53P116A -P01	INT	4M		I				I				I			IRI	IRI-INVB	130981	A
1,093	RDCC-53 -53P116A	RDCC-53P116A-P01	VB. INSP & ANALY M/C 53P116A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131207	A
1,094	RDCC-53 -53P116A	RDCC-53P116A-P01	PM INSP OF M/C NO. 53P116A -P01	PMT	4M	I				I				I				RRC	RRC-MRCP	129600	A
1,095	RDCC-53 -53P116A	RDCC-53P116A-P01	PM OF 53P116A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130655	A
1,096	RDCC-53 -53P116B	RDCC-53P116B-M	STAND BY CHECK LV. MOT 53P116B-MD1	PMT	6M			T						T				RRC	RRC-ERCP	139105	A
1,097	RDCC-53 -53P116B	RDCC-53P116B-M	Regreasing Mot BRG of 53P116B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139538	A
1,098	RDCC-53 -53P116B	RDCC-53P116B-P01	VB. INSP & ANALY M/C 53P116B	INT	4M				I				I				I	IRI	IRI-INVB	130200	A
1,099	RDCC-53 -53P116B	RDCC-53P116B-P01	PM INSP OF M/C NO. 53P116B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129601	A
1,100	RDCC-53 -53P116B	RDCC-53P116B-P01	PM OF 53P116B -P01	PMT	4M			P				P				P		RRC	RRC-MRCP	130656	A
1,101	RDCC-53 -53P117A	RDCC-53P117A-M	STAND BY CHECK LV. MOT 53P117A-MD1	PMT	1Y							T						RRC	RRC-ERCP	139106	B
1,102	RDCC-53 -53P117A	RDCC-53P117A-M	Regreasing Mot BRG of 53P117A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139539	B
1,103	RDCC-53 -53P117A	RDCC-53P117A-M	STAND BY CHECK LV. MOT 53P117A-MD1	PMT	1Y				T									RRC	RRC-ERCP	153784	B
1,104	RDCC-53 -53P117A	RDCC-53P117A-P01	VB. INSP & ANALY M/C 53P117A	INT	4M	I				I				I				IRI	IRI-INVB	130201	B
1,105	RDCC-53 -53P117A	RDCC-53P117A-P01	VB. INSP & ANALY M/C 53P117A -P01	INT	4M		I				I				I			IRI	IRI-INVB	130982	B
1,106	RDCC-53 -53P117A	RDCC-53P117A-P01	VB. INSP & ANALY M/C 53P117A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131208	B
1,107	RDCC-53 -53P117A	RDCC-53P117A-P01	PM INSP OF M/C NO. 53P117A -P01	PMT	4M	I				I				I				RRC	RRC-MRCP	129602	B
1,108	RDCC-53 -53P117A	RDCC-53P117A-P01	PM OF 53P117A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130657	B
1,109	RDCC-53 -53P117B	RDCC-53P117B-M	STAND BY CHECK LV. MOT 53P117B-MD1	PMT	6M			T						T				RRC	RRC-ERCP	139107	B
1,110	RDCC-53 -53P117B	RDCC-53P117B-M	Regreasing Mot BRG of 53P117B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139540	B
1,111	RDCC-53 -53P117B	RDCC-53P117B-P01	VB. INSP & ANALY M/C 53P117B	INT	4M				I				I				I	IRI	IRI-INVB	130202	B
1,112	RDCC-53 -53P117B	RDCC-53P117B-P01	PM INSP OF M/C NO. 53P117B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129603	B
1,113	RDCC-53 -53P117B	RDCC-53P117B-P01	PM OF 53P117B -P01	PMT	4M			P				P				P		RRC	RRC-MRCP	130658	B
1,114	RDCC-53 -53P118A	RDCC-53P118A-M	STAND BY CHECK LV. MOT 53P118A-MD1	PMT	1Y							T						RRC	RRC-ERCP	139108	B
1,115	RDCC-53 -53P118A	RDCC-53P118A-M	Regreasing Mot BRG of 53P118A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139541	B
1,116	RDCC-53 -53P118A	RDCC-53P118A-M	STAND BY CHECK LV. MOT 53P118A-MD1	PMT	1Y				T									RRC	RRC-ERCP	153785	B
1,117	RDCC-53 -53P118A	RDCC-53P118A-P01	VB. INSP & ANALY M/C 53P118A	INT	4M	I				I				I				IRI	IRI-INVB	130203	B
1,118	RDCC-53 -53P118A	RDCC-53P118A-P01	VB. INSP & ANALY M/C 53P118A -P01	INT	4M		I				I				I			IRI	IRI-INVB	130983	B
1,119	RDCC-53 -53P118A	RDCC-53P118A-P01	VB. INSP & ANALY M/C 53P118A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131209	B
1,120	RDCC-53 -53P118A	RDCC-53P118A-P01	PM INSP OF M/C NO. 53P118A -P01	PMT	4M	I				I				I				RRC	RRC-MRCP	129604	B
1,121	RDCC-53 -53P118A	RDCC-53P118A-P01	PM OF 53P118A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130659	B
1,122	RDCC-53 -53P118B	RDCC-53P118B-M	STAND BY CHECK LV. MOT 53P118B-MD1	PMT	6M			T						T				RRC	RRC-ERCP	139109	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,123	RDCC-53 -53P118B	RDCC-53P118B-M	Regreasing Mot BRG of 53P118B-MD1	PMT	4M					L			L				L	RRC	RRC-ERCP	139542	B
1,124	RDCC-53 -53P118B	RDCC-53P118B-P01	VB. INSP & ANALY M/C 53P118B	INT	4M					I			I				I	IRI	IRI-INVB	130204	B
1,125	RDCC-53 -53P118B	RDCC-53P118B-P01	PM INSP OF M/C NO. 53P118B -P01	PMT	4M					I			I				I	RRC	RRC-MRCP	129605	B
1,126	RDCC-53 -53P118B	RDCC-53P118B-P01	PM OF 53P118B -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130660	B
1,127	RDCC-53 -53P119A	RDCC-53P119A-M	STAND BY CHECK LV. MOT 53P119A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139110	A
1,128	RDCC-53 -53P119A	RDCC-53P119A-M	Regreasing Mot BRG of 53P119A-MD1	PMT	4M	L				L			L				L	RRC	RRC-ERCP	139543	A
1,129	RDCC-53 -53P119A	RDCC-53P119A-M	STAND BY CHECK LV. MOT 53P119A-MD1	PMT	1Y					T								RRC	RRC-ERCP	153786	A
1,130	RDCC-53 -53P119A	RDCC-53P119A-P01	VB. INSP & ANALY M/C 53P119A	INT	4M	I				I			I				I	IRI	IRI-INVB	130205	A
1,131	RDCC-53 -53P119A	RDCC-53P119A-P01	VB. INSP & ANALY M/C 53P119A -P01	INT	4M		I				I			I				IRI	IRI-INVB	130984	A
1,132	RDCC-53 -53P119A	RDCC-53P119A-P01	VB. INSP & ANALY M/C 53P119A -P01	INT	4M			I				I			I			IRI	IRI-INVB	131210	A
1,133	RDCC-53 -53P119A	RDCC-53P119A-P01	PM INSP OF M/C NO. 53P119A -P01	PMT	4M	I				I			I					RRC	RRC-MRCP	129606	A
1,134	RDCC-53 -53P119A	RDCC-53P119A-P01	PM OF 53P119A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130661	A
1,135	RDCC-53 -53P119B	RDCC-53P119B-M	STAND BY CHECK LV. MOT 53P119B-MD1	PMT	6M			T					T					RRC	RRC-ERCP	139111	A
1,136	RDCC-53 -53P119B	RDCC-53P119B-M	Regreasing Mot BRG of 53P119B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139544	A
1,137	RDCC-53 -53P119B	RDCC-53P119B-P01	VB. INSP & ANALY M/C 53P119B	INT	4M				I				I				I	IRI	IRI-INVB	130206	A
1,138	RDCC-53 -53P119B	RDCC-53P119B-P01	PM INSP OF M/C NO. 53P119B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129607	A
1,139	RDCC-53 -53P119B	RDCC-53P119B-P01	PM OF 53P119B -P01	PMT	4M			P				P				P		RRC	RRC-MRCP	130662	A
1,140	RDCC-53 -53P120A	RDCC-53P120A-M	STAND BY CHECK LV. MOT 53P120A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139112	A
1,141	RDCC-53 -53P120A	RDCC-53P120A-M	Regreasing Mot BRG of 53P120A-MD1	PMT	4M	L				L			L				L	RRC	RRC-ERCP	139545	A
1,142	RDCC-53 -53P120A	RDCC-53P120A-M	STAND BY CHECK LV. MOT 53P120A-MD1	PMT	1Y					T								RRC	RRC-ERCP	153787	A
1,143	RDCC-53 -53P120A	RDCC-53P120A-P01	VB. INSP & ANALY M/C 53P120A	INT	4M	I				I			I				I	IRI	IRI-INVB	130207	A
1,144	RDCC-53 -53P120A	RDCC-53P120A-P01	VB. INSP & ANALY M/C 53P120A -P01	INT	4M		I				I			I				IRI	IRI-INVB	130985	A
1,145	RDCC-53 -53P120A	RDCC-53P120A-P01	VB. INSP & ANALY M/C 53P120A -P01	INT	4M			I				I			I			IRI	IRI-INVB	131211	A
1,146	RDCC-53 -53P120A	RDCC-53P120A-P01	PM INSP OF M/C NO. 53P120A -P01	PMT	4M	I				I			I					RRC	RRC-MRCP	129608	A
1,147	RDCC-53 -53P120A	RDCC-53P120A-P01	PM OF 53P120A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130663	A
1,148	RDCC-53 -53P120B	RDCC-53P120B-M	STAND BY CHECK LV. MOT 53P120B-MD1	PMT	6M			T					T					RRC	RRC-ERCP	139113	A
1,149	RDCC-53 -53P120B	RDCC-53P120B-M	Regreasing Mot BRG of 53P120B-MD1	PMT	4M					L			L				L	RRC	RRC-ERCP	139546	A
1,150	RDCC-53 -53P120B	RDCC-53P120B-P01	VB. INSP & ANALY M/C 53P120B	INT	4M					I			I				I	IRI	IRI-INVB	130208	A
1,151	RDCC-53 -53P120B	RDCC-53P120B-P01	PM INSP OF M/C NO. 53P120B -P01	PMT	4M					I			I				I	RRC	RRC-MRCP	129609	A
1,152	RDCC-53 -53P120B	RDCC-53P120B-P01	PM OF 53P120B -P01	PMT	4M	P					P			P				RRC	RRC-MRCP	130664	A
1,153	RDCC-53 -53P121A	RDCC-53P121A-M	STAND BY CHECK MV. MOT 53P121A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139114	A
1,154	RDCC-53 -53P121A	RDCC-53P121A-M	Regreasing Mot BRG of 53P121A-MD1	PMT	4M	L				L			L				L	RRC	RRC-ERCP	139396	A
1,155	RDCC-53 -53P121A	RDCC-53P121A-M	STAND BY CHECK MV. MOT 53P121A-MD1	PMT	1Y					T								RRC	RRC-ERCP	153788	A
1,156	RDCC-53 -53P121A	RDCC-53P121A-P01	VB. INSP & ANALY M/C 53P121A	INT	4M	I				I			I				I	IRI	IRI-INVB	130209	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,157	RDCC-53 -53P121A	RDCC-53P121A-P01	VB. INSP & ANALY M/C 53P121A -P01	INT	4M		I				I				I			IRI	IRI-INVB	130986	A
1,158	RDCC-53 -53P121A	RDCC-53P121A-P01	VB. INSP & ANALY M/C 53P121A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131212	A
1,159	RDCC-53 -53P121A	RDCC-53P121A-P01	PM INSP OF M/C NO. 53P121A -P01	PMT	4M		I				I				I			RRC	RRC-MRCP	129610	A
1,160	RDCC-53 -53P121A	RDCC-53P121A-P01	PM OF 53P121A -P01	PMT	4M				P			P				P		RRC	RRC-MRCP	130665	A
1,161	RDCC-53 -53P121B	RDCC-53P121B-M	STAND BY CHECK MV. MOT 53P121B-MD1	PMT	6M			T						T				RRC	RRC-ERCP	139115	A
1,162	RDCC-53 -53P121B	RDCC-53P121B-M	Regreasing Mot BRG of 53P121B-MD1	PMT	4M				L			L				L		RRC	RRC-ERCP	139397	A
1,163	RDCC-53 -53P121B	RDCC-53P121B-P01	VB. INSP & ANALY M/C 53P121B	INT	4M				I			I				I		IRI	IRI-INVB	130210	A
1,164	RDCC-53 -53P121B	RDCC-53P121B-P01	PM INSP OF M/C NO. 53P121B -P01	PMT	4M				I			I				I		RRC	RRC-MRCP	129611	A
1,165	RDCC-53 -53P121B	RDCC-53P121B-P01	PM OF 53P121B -P01	PMT	4M	P				P				P				RRC	RRC-MRCP	130666	A
1,166	RDCC-53 -53P122A	RDCC-53P122A-M	STAND BY CHECK LV. MOT 53P122A-MD1	PMT	1Y							T						RRC	RRC-ERCP	139116	A
1,167	RDCC-53 -53P122A	RDCC-53P122A-M	Regreasing Mot BRG of 53P122A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139547	A
1,168	RDCC-53 -53P122A	RDCC-53P122A-M	STAND BY CHECK LV. MOT 53P122A-MD1	PMT	1Y				T									RRC	RRC-ERCP	153789	A
1,169	RDCC-53 -53P122A	RDCC-53P122A-P01	VB. INSP & ANALY M/C 53P122A	INT	4M	I				I				I				IRI	IRI-INVB	130211	A
1,170	RDCC-53 -53P122A	RDCC-53P122A-P01	VB. INSP & ANALY M/C 53P122A -P01	INT	4M		I				I				I			IRI	IRI-INVB	130987	A
1,171	RDCC-53 -53P122A	RDCC-53P122A-P01	VB. INSP & ANALY M/C 53P122A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131213	A
1,172	RDCC-53 -53P122A	RDCC-53P122A-P01	PM INSP OF M/C NO. 53P122A -P01	PMT	4M		I				I				I			RRC	RRC-MRCP	129612	A
1,173	RDCC-53 -53P122A	RDCC-53P122A-P01	PM OF 53P122A -P01	PMT	4M				P			P				P		RRC	RRC-MRCP	130667	A
1,174	RDCC-53 -53P122B	RDCC-53P122B-M	STAND BY CHECK LV. MOT 53P122B-MD1	PMT	6M			T						T				RRC	RRC-ERCP	139117	A
1,175	RDCC-53 -53P122B	RDCC-53P122B-M	Regreasing Mot BRG of 53P122B-MD1	PMT	4M				L			L				L		RRC	RRC-ERCP	139548	A
1,176	RDCC-53 -53P122B	RDCC-53P122B-P01	VB. INSP & ANALY M/C 53P122B	INT	4M				I			I				I		IRI	IRI-INVB	130212	A
1,177	RDCC-53 -53P122B	RDCC-53P122B-P01	PM INSP OF M/C NO. 53P122B -P01	PMT	4M				I			I				I		RRC	RRC-MRCP	129613	A
1,178	RDCC-53 -53P122B	RDCC-53P122B-P01	PM OF 53P122B -P01	PMT	4M	P				P				P				RRC	RRC-MRCP	130668	A
1,179	RDCC-53 -53P123A	RDCC-53P123A-M	STAND BY CHECK LV. MOT 53P123A-MD1	PMT	1Y							T						RRC	RRC-ERCP	139118	A
1,180	RDCC-53 -53P123A	RDCC-53P123A-M	Regreasing Mot BRG of 53P123A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCP	139549	A
1,181	RDCC-53 -53P123A	RDCC-53P123A-M	STAND BY CHECK LV. MOT 53P123A-MD1	PMT	1Y				T									RRC	RRC-ERCP	153790	A
1,182	RDCC-53 -53P123A	RDCC-53P123A-P01	VB. INSP & ANALY M/C 53P123A	INT	4M	I				I				I				IRI	IRI-INVB	130213	A
1,183	RDCC-53 -53P123A	RDCC-53P123A-P01	VB. INSP & ANALY M/C 53P123A -P01	INT	4M		I				I				I			IRI	IRI-INVB	130988	A
1,184	RDCC-53 -53P123A	RDCC-53P123A-P01	VB. INSP & ANALY M/C 53P123A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131214	A
1,185	RDCC-53 -53P123A	RDCC-53P123A-P01	PM INSP OF M/C NO. 53P123A -P01	PMT	4M		I				I				I			RRC	RRC-MRCP	129614	A
1,186	RDCC-53 -53P123A	RDCC-53P123A-P01	PM OF 53P123A -P01	PMT	4M				P			P				P		RRC	RRC-MRCP	130669	A
1,187	RDCC-53 -53P123B	RDCC-53P123B-M	STAND BY CHECK LV. MOT 53P123B-MD1	PMT	6M			T						T				RRC	RRC-ERCP	139119	A
1,188	RDCC-53 -53P123B	RDCC-53P123B-M	Regreasing Mot BRG of 53P123B-MD1	PMT	4M				L			L				L		RRC	RRC-ERCP	139550	A
1,189	RDCC-53 -53P123B	RDCC-53P123B-P01	VB. INSP & ANALY M/C 53P123B	INT	4M				I			I				I		IRI	IRI-INVB	130214	A
1,190	RDCC-53 -53P123B	RDCC-53P123B-P01	PM INSP OF M/C NO. 53P123B -P01	PMT	4M				I			I				I		RRC	RRC-MRCP	129615	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,191	RDCC-53 -53P123B	RDCC-53P123B-P01	PM OF 53P123B -P01	PMT	4M	P				P			P					RRC	RRC-MRCP	130670	A
1,192	RDCC-53 -53P124A	RDCC-53P124A-M	STAND BY CHECK LV. MOT 53P124A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139120	A
1,193	RDCC-53 -53P124A	RDCC-53P124A-M	Regreasing Mot BRG of 53P124A-MD1	PMT	4M	L				L			L				L	RRC	RRC-ERCP	139551	A
1,194	RDCC-53 -53P124A	RDCC-53P124A-M	STAND BY CHECK LV. MOT 53P124A-MD1	PMT	1Y					T								RRC	RRC-ERCP	153791	A
1,195	RDCC-53 -53P124A	RDCC-53P124A-P01	VB. INSP & ANALY M/C 53P124A	INT	4M	I				I			I				I	IRI	IRI-INVB	130215	A
1,196	RDCC-53 -53P124A	RDCC-53P124A-P01	VB. INSP & ANALY M/C 53P124A -P01	INT	4M		I				I			I				IRI	IRI-INVB	130989	A
1,197	RDCC-53 -53P124A	RDCC-53P124A-P01	VB. INSP & ANALY M/C 53P124A -P01	INT	4M			I				I			I			IRI	IRI-INVB	131215	A
1,198	RDCC-53 -53P124A	RDCC-53P124A-P01	PM INSP OF M/C NO. 53P124A -P01	PMT	4M		I				I			I				RRC	RRC-MRCP	129616	A
1,199	RDCC-53 -53P124A	RDCC-53P124A-P01	PM OF 53P124A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130671	A
1,200	RDCC-53 -53P124B	RDCC-53P124B-M	STAND BY CHECK LV. MOT 53P124B-MD1	PMT	6M			T					T					RRC	RRC-ERCP	139121	A
1,201	RDCC-53 -53P124B	RDCC-53P124B-M	Regreasing Mot BRG of 53P124B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139552	A
1,202	RDCC-53 -53P124B	RDCC-53P124B-P01	VB. INSP & ANALY M/C 53P124B	INT	4M				I				I				I	IRI	IRI-INVB	130216	A
1,203	RDCC-53 -53P124B	RDCC-53P124B-P01	PM INSP OF M/C NO. 53P124B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129617	A
1,204	RDCC-53 -53P124B	RDCC-53P124B-P01	PM OF 53P124B -P01	PMT	4M	P				P			P				P	RRC	RRC-MRCP	130672	A
1,205	RDCC-53 -53P126A	RDCC-53P126A-M	STAND BY CHECK LV. MOT 53P126A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139122	A
1,206	RDCC-53 -53P126A	RDCC-53P126A-M	Regreasing Mot BRG of 53P126A-MD1	PMT	4M	L				L			L				L	RRC	RRC-ERCP	139553	A
1,207	RDCC-53 -53P126A	RDCC-53P126A-M	STAND BY CHECK LV. MOT 53P126A-MD1	PMT	1Y					T								RRC	RRC-ERCP	153792	A
1,208	RDCC-53 -53P126A	RDCC-53P126A-P01	VB. INSP & ANALY M/C 53P126A	INT	4M	I				I			I				I	IRI	IRI-INVB	130217	A
1,209	RDCC-53 -53P126A	RDCC-53P126A-P01	VB. INSP & ANALY M/C 53P126A -P01	INT	4M		I				I			I				IRI	IRI-INVB	130990	A
1,210	RDCC-53 -53P126A	RDCC-53P126A-P01	VB. INSP & ANALY M/C 53P126A -P01	INT	4M			I				I			I			IRI	IRI-INVB	131216	A
1,211	RDCC-53 -53P126A	RDCC-53P126A-P01	PM INSP OF M/C NO. 53P126A -P01	PMT	4M		I				I			I				RRC	RRC-MRCP	129618	A
1,212	RDCC-53 -53P126A	RDCC-53P126A-P01	PM OF 53P126A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130673	A
1,213	RDCC-53 -53P126B	RDCC-53P126B-M	STAND BY CHECK LV. MOT 53P126B-MD1	PMT	6M			T					T					RRC	RRC-ERCP	139123	A
1,214	RDCC-53 -53P126B	RDCC-53P126B-M	Regreasing Mot BRG of 53P126B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139554	A
1,215	RDCC-53 -53P126B	RDCC-53P126B-P01	VB. INSP & ANALY M/C 53P126B	INT	4M				I				I				I	IRI	IRI-INVB	130218	A
1,216	RDCC-53 -53P126B	RDCC-53P126B-P01	PM INSP OF M/C NO. 53P126B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129619	A
1,217	RDCC-53 -53P126B	RDCC-53P126B-P01	PM OF 53P126B -P01	PMT	4M	P				P			P				P	RRC	RRC-MRCP	130674	A
1,218	RDCC-53 -53P127A	RDCC-53P127A-M	STAND BY CHECK LV. MOT 53P127A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139124	A
1,219	RDCC-53 -53P127A	RDCC-53P127A-M	Regreasing Mot BRG of 53P127A-MD1	PMT	4M	L				L			L				L	RRC	RRC-ERCP	139555	A
1,220	RDCC-53 -53P127A	RDCC-53P127A-M	STAND BY CHECK LV. MOT 53P127A-MD1	PMT	1Y				T									RRC	RRC-ERCP	153793	A
1,221	RDCC-53 -53P127A	RDCC-53P127A-P01	VB. INSP & ANALY M/C 53P127A	INT	4M	I				I			I				I	IRI	IRI-INVB	130219	A
1,222	RDCC-53 -53P127A	RDCC-53P127A-P01	VB. INSP & ANALY M/C 53P127A -P01	INT	4M		I				I			I				IRI	IRI-INVB	130991	A
1,223	RDCC-53 -53P127A	RDCC-53P127A-P01	VB. INSP & ANALY M/C 53P127A -P01	INT	4M			I				I			I			IRI	IRI-INVB	131217	A
1,224	RDCC-53 -53P127A	RDCC-53P127A-P01	PM INSP OF M/C NO. 53P127A -P01	PMT	4M			I				I			I			RRC	RRC-MRCP	129620	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,225	RDCC-53 -53P127A	RDCC-53P127A-P01	PM OF 53P127A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130675	A
1,226	RDCC-53 -53P127B	RDCC-53P127B-M	STAND BY CHECK LV. MOT 53P127B-M01	PMT	6M			T						T				RRC	RRC-ERCP	139125	A
1,227	RDCC-53 -53P127B	RDCC-53P127B-M	Regreasing Mot BRG of 53P127B-M01	PMT	4M				L			L					L	RRC	RRC-ERCP	139556	A
1,228	RDCC-53 -53P127B	RDCC-53P127B-P01	VB. INSP & ANALY M/C 53P127B	INT	4M				I			I					I	IRI	IRI-INVB	130220	A
1,229	RDCC-53 -53P127B	RDCC-53P127B-P01	PM INSP OF M/C NO. 53P127B -P01	PMT	4M				I			I					I	RRC	RRC-MRCP	129621	A
1,230	RDCC-53 -53P127B	RDCC-53P127B-P01	PM OF 53P127B -P01	PMT	4M		P				P			P				RRC	RRC-MRCP	130676	A
1,231	RDCC-53 -53P128A	RDCC-53P128A-M	STAND BY CHECK LV. MOT 53P128A-M01	PMT	1Y							T						RRC	RRC-ERCP	139126	A
1,232	RDCC-53 -53P128A	RDCC-53P128A-M	Regreasing Mot BRG of 53P128A-M01	PMT	4M	L				L				L				RRC	RRC-ERCP	139557	A
1,233	RDCC-53 -53P128A	RDCC-53P128A-M	STAND BY CHECK LV. MOT 53P128A-M01	PMT	1Y				T									RRC	RRC-ERCP	153794	A
1,234	RDCC-53 -53P128A	RDCC-53P128A-P01	VB. INSP & ANALY M/C 53P128A	INT	4M	I				I				I				IRI	IRI-INVB	130221	A
1,235	RDCC-53 -53P128A	RDCC-53P128A-P01	VB. INSP & ANALY M/C 53P128A -P01	INT	4M		I				I				I			IRI	IRI-INVB	130992	A
1,236	RDCC-53 -53P128A	RDCC-53P128A-P01	VB. INSP & ANALY M/C 53P128A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131218	A
1,237	RDCC-53 -53P128A	RDCC-53P128A-P01	PM INSP OF M/C NO. 53P128A -P01	PMT	4M			I				I				I		RRC	RRC-MRCP	129622	A
1,238	RDCC-53 -53P128A	RDCC-53P128A-P01	PM OF 53P128A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130677	A
1,239	RDCC-53 -53P128B	RDCC-53P128B-M	STAND BY CHECK LV. MOT 53P128B-M01	PMT	6M			T						T				RRC	RRC-ERCP	139127	A
1,240	RDCC-53 -53P128B	RDCC-53P128B-M	Regreasing Mot BRG of 53P128B-M01	PMT	4M				L			L					L	RRC	RRC-ERCP	139558	A
1,241	RDCC-53 -53P128B	RDCC-53P128B-P01	VB. INSP & ANALY M/C 53P128B	INT	4M				I			I					I	IRI	IRI-INVB	130222	A
1,242	RDCC-53 -53P128B	RDCC-53P128B-P01	PM INSP OF M/C NO. 53P128B -P01	PMT	4M				I			I					I	RRC	RRC-MRCP	129625	A
1,243	RDCC-53 -53P128B	RDCC-53P128B-P01	PM OF 53P128B -P01	PMT	4M		P				P			P				RRC	RRC-MRCP	130678	A
1,244	RDCC-53 -53P129A	RDCC-53P129A-M	STAND BY CHECK LV. MOT 53P129A-M01	PMT	1Y							T						RRC	RRC-ERCP	139128	B
1,245	RDCC-53 -53P129A	RDCC-53P129A-M	STAND BY CHECK LV. MOT 53P129A-M01	PMT	1Y				T									RRC	RRC-ERCP	153795	B
1,246	RDCC-53 -53P129A	RDCC-53P129A-P01	VB. INSP & ANALY M/C 53P129A	INT	4M	I				I				I				IRI	IRI-INVB	130223	B
1,247	RDCC-53 -53P129A	RDCC-53P129A-P01	VB. INSP & ANALY M/C 53P129A -P01	INT	4M		I				I				I			IRI	IRI-INVB	130993	B
1,248	RDCC-53 -53P129A	RDCC-53P129A-P01	VB. INSP & ANALY M/C 53P129A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131219	B
1,249	RDCC-53 -53P129A	RDCC-53P129A-P01	PM INSP OF M/C NO. 53P129A -P01	PMT	4M			I				I				I		RRC	RRC-MRCP	129623	B
1,250	RDCC-53 -53P129A	RDCC-53P129A-P01	PM OF 53P129A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130679	B
1,251	RDCC-53 -53P129B	RDCC-53P129B-M	STAND BY CHECK LV. MOT 53P129B-M01	PMT	6M			T						T				RRC	RRC-ERCP	139129	B
1,252	RDCC-53 -53P129B	RDCC-53P129B-P01	VB. INSP & ANALY M/C 53P129B	INT	4M				I			I					I	IRI	IRI-INVB	130224	B
1,253	RDCC-53 -53P129B	RDCC-53P129B-P01	PM INSP OF M/C NO. 53P129B -P01	PMT	4M				I			I					I	RRC	RRC-MRCP	129624	B
1,254	RDCC-53 -53P129B	RDCC-53P129B-P01	PM OF 53P129B -P01	PMT	4M		P				P			P				RRC	RRC-MRCP	130680	B
1,255	RDCC-53 -53P130A	RDCC-53P130A-M	STAND BY CHECK LV. MOT 53P130A-M01	PMT	1Y							T						RRC	RRC-ERCP	139130	A
1,256	RDCC-53 -53P130A	RDCC-53P130A-M	Regreasing Mot BRG of 53P130A-M01	PMT	4M	L				L				L				RRC	RRC-ERCP	139561	A
1,257	RDCC-53 -53P130A	RDCC-53P130A-M	STAND BY CHECK LV. MOT 53P130A-M01	PMT	1Y				T									RRC	RRC-ERCP	153796	A
1,258	RDCC-53 -53P130A	RDCC-53P130A-P01	VB. INSP & ANALY M/C 53P130A	INT	4M	I				I				I				IRI	IRI-INVB	130225	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,259	RDCC-53 -53P130A	RDCC-53P130A-P01	VB. INSP & ANALY M/C 53P130A -P01	INT	4M		I				I				I			IRI	IRI-INVB	130994	A
1,260	RDCC-53 -53P130A	RDCC-53P130A-P01	VB. INSP & ANALY M/C 53P130A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131220	A
1,261	RDCC-53 -53P130A	RDCC-53P130A-P01	PM INSP OF M/C NO. 53P130A -P01	PMT	4M			I				I				I		RRC	RRC-MRCP	129626	A
1,262	RDCC-53 -53P130A	RDCC-53P130A-P01	PM OF 53P130A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130681	A
1,263	RDCC-53 -53P130B	RDCC-53P130B-M	STAND BY CHECK LV. MOT 53P130B-M01	PMT	6M			T						T				RRC	RRC-ERCP	139131	A
1,264	RDCC-53 -53P130B	RDCC-53P130B-M	Regreasing Mot BRG of 53P130B-M01	PMT	4M				L				L				L	RRC	RRC-ERCP	139562	A
1,265	RDCC-53 -53P130B	RDCC-53P130B-P01	VB. INSP & ANALY M/C 53P130B	INT	4M				I				I				I	IRI	IRI-INVB	130226	A
1,266	RDCC-53 -53P130B	RDCC-53P130B-P01	PM INSP OF M/C NO. 53P130B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129627	A
1,267	RDCC-53 -53P130B	RDCC-53P130B-P01	PM OF 53P130B -P01	PMT	4M		P				P			P				RRC	RRC-MRCP	130682	A
1,268	RDCC-53 -53P131A	RDCC-53P131A-M	STAND BY CHECK LV. MOT 53P131A-M01	PMT	1Y								T					RRC	RRC-ERCP	139132	B
1,269	RDCC-53 -53P131A	RDCC-53P131A-M	Regreasing Mot BRG of 53P131A-M01	PMT	4M	L				L				L				RRC	RRC-ERCP	139563	B
1,270	RDCC-53 -53P131A	RDCC-53P131A-M	STAND BY CHECK LV. MOT 53P131A-M01	PMT	1Y				T									RRC	RRC-ERCP	153797	B
1,271	RDCC-53 -53P131A	RDCC-53P131A-P01	VB. INSP & ANALY M/C 53P131A	INT	4M	I				I				I				IRI	IRI-INVB	130227	B
1,272	RDCC-53 -53P131A	RDCC-53P131A-P01	VB. INSP & ANALY M/C 53P131A -P01	INT	4M		I				I				I			IRI	IRI-INVB	130995	B
1,273	RDCC-53 -53P131A	RDCC-53P131A-P01	VB. INSP & ANALY M/C 53P131A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131221	B
1,274	RDCC-53 -53P131A	RDCC-53P131A-P01	PM INSP OF M/C NO. 53P131A -P01	PMT	4M			I				I				I		RRC	RRC-MRCP	129628	B
1,275	RDCC-53 -53P131A	RDCC-53P131A-P01	PM OF 53P131A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130683	B
1,276	RDCC-53 -53P131B	RDCC-53P131B-M	STAND BY CHECK LV. MOT 53P131B-M01	PMT	6M			T						T				RRC	RRC-ERCP	139133	B
1,277	RDCC-53 -53P131B	RDCC-53P131B-M	Regreasing Mot BRG of 53P131B-M01	PMT	4M				L				L				L	RRC	RRC-ERCP	139564	B
1,278	RDCC-53 -53P131B	RDCC-53P131B-P01	VB. INSP & ANALY M/C 53P131B	INT	4M				I				I				I	IRI	IRI-INVB	130228	B
1,279	RDCC-53 -53P131B	RDCC-53P131B-P01	PM INSP OF M/C NO. 53P131B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129629	B
1,280	RDCC-53 -53P131B	RDCC-53P131B-P01	PM OF 53P131B -P01	PMT	4M		P				P			P				RRC	RRC-MRCP	130684	B
1,281	RDCC-53 -53P132A	RDCC-53P132A-M	STAND BY CHECK LV. MOT 53P132A-M01	PMT	1Y								T					RRC	RRC-ERCP	139134	A
1,282	RDCC-53 -53P132A	RDCC-53P132A-M	Regreasing Mot BRG of 53P132A-M01	PMT	4M	L				L				L				RRC	RRC-ERCP	139565	A
1,283	RDCC-53 -53P132A	RDCC-53P132A-M	STAND BY CHECK LV. MOT 53P132A-M01	PMT	1Y				T									RRC	RRC-ERCP	153798	A
1,284	RDCC-53 -53P132A	RDCC-53P132A-P01	VB. INSP & ANALY M/C 53P132A	INT	4M	I				I				I				IRI	IRI-INVB	130229	A
1,285	RDCC-53 -53P132A	RDCC-53P132A-P01	VB. INSP & ANALY M/C 53P132A -P01	INT	4M			I				I				I		IRI	IRI-INVB	130996	A
1,286	RDCC-53 -53P132A	RDCC-53P132A-P01	VB. INSP & ANALY M/C 53P132A -P01	INT	4M				I			I					I	IRI	IRI-INVB	131222	A
1,287	RDCC-53 -53P132A	RDCC-53P132A-P01	PM INSP OF M/C NO. 53P132A -P01	PMT	4M	I				I			I				I	RRC	RRC-MRCP	129630	A
1,288	RDCC-53 -53P132A	RDCC-53P132A-P01	PM OF 53P132A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130685	A
1,289	RDCC-53 -53P132B	RDCC-53P132B-M	STAND BY CHECK LV. MOT 53P132B-M01	PMT	6M			T						T				RRC	RRC-ERCP	139135	A
1,290	RDCC-53 -53P132B	RDCC-53P132B-M	Regreasing Mot BRG of 53P132B-M01	PMT	4M				L				L				L	RRC	RRC-ERCP	139566	A
1,291	RDCC-53 -53P132B	RDCC-53P132B-P01	VB. INSP & ANALY M/C 53P132B	INT	4M				I				I				I	IRI	IRI-INVB	130230	A
1,292	RDCC-53 -53P132B	RDCC-53P132B-P01	PM INSP OF M/C NO. 53P132B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129631	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,293	RDCC-53 -53P132B	RDCC-53P132B-P01	PM OF 53P132B -P01	PMT	4M		P				P			P				RRC	RRC-MRCP	130686	A
1,294	RDCC-53 -53P133A	RDCC-53P133A-M	STAND BY CHECK LV. MOT 53P133A-M01	PMT	1Y							T						RRC	RRC-ERCP	139136	A
1,295	RDCC-53 -53P133A	RDCC-53P133A-M	Regreasing Mot BRG of 53P133A-M01	PMT	4M	L				L				L				RRC	RRC-ERCP	139567	A
1,296	RDCC-53 -53P133A	RDCC-53P133A-M	STAND BY CHECK LV. MOT 53P133A-M01	PMT	1Y				T									RRC	RRC-ERCP	153799	A
1,297	RDCC-53 -53P133A	RDCC-53P133A-P01	VB. INSP & ANALY M/C 53P133A	INT	4M	I				I				I				IRI	IRI-INVB	130231	A
1,298	RDCC-53 -53P133A	RDCC-53P133A-P01	VB. INSP & ANALY M/C 53P133A -P01	INT	4M		I				I				I			IRI	IRI-INVB	130997	A
1,299	RDCC-53 -53P133A	RDCC-53P133A-P01	VB. INSP & ANALY M/C 53P133A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131223	A
1,300	RDCC-53 -53P133A	RDCC-53P133A-P01	PM INSP OF M/C NO. 53P133A -P01	PMT	4M	I				I				I				RRC	RRC-MRCP	129632	A
1,301	RDCC-53 -53P133A	RDCC-53P133A-P01	PM OF 53P133A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130687	A
1,302	RDCC-53 -53P133B	RDCC-53P133B-M	STAND BY CHECK LV. MOT 53P133B-M01	PMT	6M			T						T				RRC	RRC-ERCP	139137	A
1,303	RDCC-53 -53P133B	RDCC-53P133B-M	Regreasing Mot BRG of 53P133B-M01	PMT	4M				L				L				L	RRC	RRC-ERCP	139568	A
1,304	RDCC-53 -53P133B	RDCC-53P133B-P01	VB. INSP & ANALY M/C 53P133B	INT	4M				I				I				I	IRI	IRI-INVB	130232	A
1,305	RDCC-53 -53P133B	RDCC-53P133B-P01	PM INSP OF M/C NO. 53P133B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129633	A
1,306	RDCC-53 -53P133B	RDCC-53P133B-P01	PM OF 53P133B -P01	PMT	4M			P			P			P				RRC	RRC-MRCP	130688	A
1,307	RDCC-53 -53P134A	RDCC-53P134A-M	STAND BY CHECK LV. MOT 53P134A-M01	PMT	1Y								T					RRC	RRC-ERCP	139138	B
1,308	RDCC-53 -53P134A	RDCC-53P134A-M	Regreasing Mot BRG of 53P134A-M01	PMT	4M	L				L				L				RRC	RRC-ERCP	139569	B
1,309	RDCC-53 -53P134A	RDCC-53P134A-M	STAND BY CHECK LV. MOT 53P134A-M01	PMT	1Y				T									RRC	RRC-ERCP	153800	B
1,310	RDCC-53 -53P134A	RDCC-53P134A-P01	VB. INSP & ANALY M/C 53P134A	INT	4M	I				I				I				IRI	IRI-INVB	130233	B
1,311	RDCC-53 -53P134A	RDCC-53P134A-P01	VB. INSP & ANALY M/C 53P134A	INT	4M		I				I				I			IRI	IRI-INVB	130998	B
1,312	RDCC-53 -53P134A	RDCC-53P134A-P01	VB. INSP & ANALY M/C 53P134A	INT	4M			I				I				I		IRI	IRI-INVB	131224	B
1,313	RDCC-53 -53P134A	RDCC-53P134A-P01	PM INSP OF M/C NO. 53P134A	PMT	4M	I				I				I				RRC	RRC-MRCP	129634	B
1,314	RDCC-53 -53P134A	RDCC-53P134A-P01	PM OF 53P134A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130689	B
1,315	RDCC-53 -53P134B	RDCC-53P134B-M	STAND BY CHECK LV. MOT 53P134B-M01	PMT	6M			T						T				RRC	RRC-ERCP	139139	B
1,316	RDCC-53 -53P134B	RDCC-53P134B-M	Regreasing Mot BRG of 53P134B-M01	PMT	4M				L				L				L	RRC	RRC-ERCP	139570	B
1,317	RDCC-53 -53P134B	RDCC-53P134B-P01	VB. INSP & ANALY M/C 53P134B	INT	4M				I				I				I	IRI	IRI-INVB	130234	B
1,318	RDCC-53 -53P134B	RDCC-53P134B-P01	PM INSP OF M/C NO. 53P134B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129635	B
1,319	RDCC-53 -53P134B	RDCC-53P134B-P01	PM OF 53P134B -P01	PMT	4M			P				P				P		RRC	RRC-MRCP	130690	B
1,320	RDCC-53 -53P136	RDCC-53P136-M	STAND BY CHECK LV. MOT 53P136-M01	PMT	6M			T						T				RRC	RRC-ERCP	139140	B
1,321	RDCC-53 -53P136	RDCC-53P136-P01	VB. INSP & ANALY M/C 53P136	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130235	B
1,322	RDCC-53 -53P136	RDCC-53P136-P01	PM INSP OF M/C NO. 53P136 -P01	PMT	4M	I				I				I				RRC	RRC-MRCP	129636	B
1,323	RDCC-53 -53P136	RDCC-53P136-P01	PM OF 53P136 -P01	PMT	4M			P			P			P				RRC	RRC-MRCP	130691	B
1,324	RDCC-53 -53P138A	RDCC-53P138A-M	STAND BY CHECK LV. MOT 53P138A-M01	PMT	1Y							T						RRC	RRC-ERCP	139141	B
1,325	RDCC-53 -53P138A	RDCC-53P138A-M	Regreasing Mot BRG of 53P138A-M01	PMT	4M	L				L				L				RRC	RRC-ERCP	139571	B
1,326	RDCC-53 -53P138A	RDCC-53P138A-M	STAND BY CHECK LV. MOT 53P138A-M01	PMT	1Y				T									RRC	RRC-ERCP	153801	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,327	RDCC-53 -53P138A	RDCC-53P138A-P01	VB. INSP & ANALY M/C 53P138A	INT	4M	I				I			I					IRI	IRI-INVB	130236	B
1,328	RDCC-53 -53P138A	RDCC-53P138A-P01	VB. INSP & ANALY M/C 53P138A	INT	4M		I				I				I			IRI	IRI-INVB	130999	B
1,329	RDCC-53 -53P138A	RDCC-53P138A-P01	VB. INSP & ANALY M/C 53P138A	INT	4M			I				I				I		IRI	IRI-INVB	131225	B
1,330	RDCC-53 -53P138A	RDCC-53P138A-P01	PM INSP OF M/C NO. 53P138A	PMT	4M	I				I			I					RRC	RRC-MRCP	129637	B
1,331	RDCC-53 -53P138A	RDCC-53P138A-P01	PM OF 53P138A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130692	B
1,332	RDCC-53 -53P138B	RDCC-53P138B-M	STAND BY CHECK LV. MOT 53P138B-M01	PMT	6M			T						T				RRC	RRC-ERCP	139142	B
1,333	RDCC-53 -53P138B	RDCC-53P138B-M	Regreasing Mot BRG of 53P138B-M01	PMT	4M				L				L				L	RRC	RRC-ERCP	139572	B
1,334	RDCC-53 -53P138B	RDCC-53P138B-P01	VB. INSP & ANALY M/C 53P138B	INT	4M				I				I				I	IRI	IRI-INVB	130237	B
1,335	RDCC-53 -53P138B	RDCC-53P138B-P01	PM INSP OF M/C NO. 53P138B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129638	B
1,336	RDCC-53 -53P138B	RDCC-53P138B-P01	PM OF 53P138B -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130693	B
1,337	RDCC-53 -53P139A	RDCC-53P139A-M	STAND BY CHECK LV. MOT 53P139A-M01	PMT	1Y								T					RRC	RRC-ERCP	139143	B
1,338	RDCC-53 -53P139A	RDCC-53P139A-M	Regreasing Mot BRG of 53P139A-M01	PMT	4M	L				L				L				RRC	RRC-ERCP	139573	B
1,339	RDCC-53 -53P139A	RDCC-53P139A-M	STAND BY CHECK LV. MOT 53P139A-M01	PMT	1Y				T									RRC	RRC-ERCP	153802	B
1,340	RDCC-53 -53P139A	RDCC-53P139A-P01	VB. INSP & ANALY M/C 53P139A	INT	4M	I				I			I					IRI	IRI-INVB	130238	B
1,341	RDCC-53 -53P139A	RDCC-53P139A-P01	VB. INSP & ANALY M/C 53P139A	INT	4M		I				I			I				IRI	IRI-INVB	131000	B
1,342	RDCC-53 -53P139A	RDCC-53P139A-P01	VB. INSP & ANALY M/C 53P139A	INT	4M			I				I				I		IRI	IRI-INVB	131226	B
1,343	RDCC-53 -53P139A	RDCC-53P139A-P01	PM INSP OF M/C NO. 53P139A -P01	PMT	4M		I				I				I			RRC	RRC-MRCP	129639	B
1,344	RDCC-53 -53P139A	RDCC-53P139A-P01	PM OF 53P139A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130694	B
1,345	RDCC-53 -53P139B	RDCC-53P139B-M	STAND BY CHECK LV. MOT 53P139B-M01	PMT	6M			T						T				RRC	RRC-ERCP	139144	B
1,346	RDCC-53 -53P139B	RDCC-53P139B-M	Regreasing Mot BRG of 53P139B-M01	PMT	4M				L				L				L	RRC	RRC-ERCP	139574	B
1,347	RDCC-53 -53P139B	RDCC-53P139B-P01	VB. INSP & ANALY M/C 53P139B	INT	4M				I				I				I	IRI	IRI-INVB	130239	B
1,348	RDCC-53 -53P139B	RDCC-53P139B-P01	PM INSP OF M/C NO. 53P139B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129640	B
1,349	RDCC-53 -53P139B	RDCC-53P139B-P01	PM OF 53P139B -P01	PMT	4M			P			P			P				RRC	RRC-MRCP	130695	B
1,350	RDCC-53 -53P140A	RDCC-53P140A-M	Regreasing Mot BRG of RDCC-53P	PMT	4M	L			L				L				L	RRC	RRC-ERCP	255703	C
1,351	RDCC-53 -53P140A	RDCC-53P140A-M	STAND BY CHECK LV.RDCC-53P140A	PMT	4M			T			T			T				RRC	RRC-ERCP	255707	C
1,352	RDCC-53 -53P140A	RDCC-53P140A-P01	PM INSP OF M/C NO. RDCC-53P140	PMT	4M	I			I				I					RRC	RRC-MRCP	255689	C
1,353	RDCC-53 -53P140A	RDCC-53P140A-P01	PM OF RDCC-53P140A-P01	PMT	4M			P			P			P				RRC	RRC-MRCP	255699	C
1,354	RDCC-53 -53P140B	RDCC-53P140B-M	Regreasing Mot BRG of RDCC-53P	PMT	4M		L				L			L				RRC	RRC-ERCP	255704	C
1,355	RDCC-53 -53P140B	RDCC-53P140B-M	STAND BY CHECK LV.RDCC-53P140B	PMT	4M			T			T			T				RRC	RRC-ERCP	255708	C
1,356	RDCC-53 -53P140B	RDCC-53P140B-P01	PM INSP OF M/C NO. RDCC-53P140	PMT	4M		I				I			I				RRC	RRC-MRCP	255690	C
1,357	RDCC-53 -53P140B	RDCC-53P140B-P01	PM OF RDCC-53P140B-P01	PMT	4M				P				P				P	RRC	RRC-MRCP	255700	C
1,358	RDCC-53 -53P140C	RDCC-53P140C-M	Regreasing Mot BRG of RDCC-53P	PMT	4M				L				L				L	RRC	RRC-ERCP	255705	C
1,359	RDCC-53 -53P140C	RDCC-53P140C-M	STAND BY CHECK LV.RDCC-53P140C	PMT	4M		T				T			T				RRC	RRC-ERCP	255709	C
1,360	RDCC-53 -53P140C	RDCC-53P140C-P01	PM INSP OF M/C NO. RDCC-53P140	PMT	4M				I				I				I	RRC	RRC-MRCP	255691	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,361	RDCC-53 -53P140C	RDCC-53P140C-P01	PM OF RDCC-53P140C-P01	PMT	4M		P				P					P			RRC-MRCP	255701	C
1,362	RDCC-53 -53Q001	RDCC-53Q001-P01	PM INSP OF M/C NO. 53Q001-P01	PMT	3M			I			I			I			I		RRC-MRCP	148905	A
1,363	RDCC-53 -53Q001	RDCC-53Q001-P02	PM INSP OF M/C NO. 53Q001-P02	PMT	3M			I			I			I			I		RRC-MRCP	148906	A
1,364	RDCC-53 -53Q001	RDCC-53Q001-P03	PM INSP OF M/C NO. 53Q001-P03	PMT	3M			I			I			I			I		RRC-MRCP	148907	A
1,365	RDCC-53 -53Q002	RDCC-53Q002-P01	PM INSP OF M/C NO. 53Q002-P01	PMT	3M			I			I			I			I		RRC-MRCP	148909	A
1,366	RDCC-53 -53Q002	RDCC-53Q002-P02	PM INSP OF M/C NO. 53Q002-P02	PMT	3M			I			I			I			I		RRC-MRCP	148910	A
1,367	RDCC-53 -53Q002	RDCC-53Q002-P03	PM INSP OF M/C NO. 53Q002-P03	PMT	3M			I			I			I			I		RRC-MRCP	148911	A
1,368	RDCC-53 -53Q003	RDCC-53Q003-P01	PM INSP OF M/C NO. 53Q003-P01	PMT	3M			I			I			I			I		RRC-MRCP	148913	A
1,369	RDCC-53 -53Q003	RDCC-53Q003-P02	PM INSP OF M/C NO. 53Q003-P02	PMT	3M			I			I			I			I		RRC-MRCP	148914	A
1,370	RDCC-53 -53Q003	RDCC-53Q003-P03	PM INSP OF M/C NO. 53Q003-P03	PMT	3M			I			I			I			I		RRC-MRCP	148915	A
1,371	RDCC-53 -53Q004	RDCC-53Q004-P01	PM INSP OF M/C NO. 53Q004-P01	PMT	3M			I			I			I			I		RRC-MRCP	148917	A
1,372	RDCC-53 -53Q005	RDCC-53Q005-P01	PM INSP OF M/C NO. RDCC-53Q005	PMT	3M			I			I			I			I		RRC-MRCP	255697	C
1,373	RDCC-53 -53Q005	RDCC-53Q005-P02	PM INSP OF M/C NO. RDCC-53Q005	PMT	3M			I			I			I			I		RRC-MRCP	255698	C
1,374	RDCC-53 -53Q005	RDCC-53Q005-Q01	REGREASING BRG OF RDCC-53Q005-	PMT	3M			L			L			L			L		RRC-MRCP	255688	C
1,375	RDCC-53 -53R001	RDCC-53R001-R01	FIRE HEATER ON-STREAM INSPECTION#53R001	PMT	6M				I						I				IRI-INRC	150309	A
1,376	RDCC-53 -53R002	RDCC-53R002-R01	FIRE HEATER ON-STREAM INSPECTION#53R002	PMT	6M				I						I				IRI-INRC	150310	A
1,377	RDCC-53 -53T001	RDCC-53T001-T01	Storage tank inspection	PMT	5Y								I						IRI-INRC	169254	C
1,378	RDCC-53 -53T002	RDCC-53T002-T01	Storage tank inspection	PMT	5Y								I						IRI-INRC	169255	C
1,379	RDCC-53 -53X002	RDCC-53X002-K01A	VB. INSP & ANALY M/C 53X002-K01A	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I		IRI-INVB	149161	C
1,380	RDCC-53 -53X002	RDCC-53X002-K01A	PM INSP OF M/C NO. 53X002-K01A	PMT	4M	I				I			I						RRC-MRCP	148918	C
1,381	RDCC-53 -53X002	RDCC-53X002-K01A	REGREASING BRG OF 53X002-K01A	PMT	2M	L		L		L		L		L		L			RRC-MRCP	148919	C
1,382	RDCC-53 -53X002	RDCC-53X002-K01A-M	Regreasing Mot BRG of 53X002-K01A-MD1	PMT	4M	L				L			L			L			RRC-ERCP	139575	C
1,383	RDCC-53 -53X002	RDCC-53X002-K01B	VB. INSP & ANALY M/C 53X002-K01B	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I		IRI-INVB	149162	C
1,384	RDCC-53 -53X002	RDCC-53X002-K01B	PM INSP OF M/C NO. 53X002-K01B	PMT	4M	I				I			I						RRC-MRCP	148920	C
1,385	RDCC-53 -53X002	RDCC-53X002-K01B	REGREASING BRG OF 53X002-K01B	PMT	2M	L		L		L		L		L		L			RRC-MRCP	148921	C
1,386	RDCC-53 -53X002	RDCC-53X002-K01B-M	Regreasing Mot BRG of 53X002-K01B-MD1	PMT	4M				L				L			L			RRC-ERCP	139576	C
1,387	RDCC-53 -53X002	RDCC-53X002-K02A	PM INSP OF M/C NO. 53X002-K02A	PMT	4M	I				I			I						RRC-MRCP	148922	C
1,388	RDCC-53 -53X002	RDCC-53X002-K02A	REGREASING BRG OF 53X002-K02A	PMT	2M	L		L		L		L		L		L			RRC-MRCP	148923	C
1,389	RDCC-53 -53X002	RDCC-53X002-K02A-M	Regreasing Mot BRG of 53X002-K02A-MD1	PMT	4M	L				L				L					RRC-ERCP	139577	C
1,390	RDCC-53 -53X002	RDCC-53X002-K02B	PM INSP OF M/C NO. 53X002-K02B	PMT	4M	I				I				I					RRC-MRCP	148924	C
1,391	RDCC-53 -53X002	RDCC-53X002-K02B	REGREASING BRG OF 53X002-K02B	PMT	2M	L		L		L		L		L		L			RRC-MRCP	148925	C
1,392	RDCC-53 -53X002	RDCC-53X002-K02B-M	Regreasing Mot BRG of 53X002-K02B-MD1	PMT	4M				L				L			L			RRC-ERCP	139578	C
1,393	RDCC-53 -53X002	RDCC-53X002-K03	LUBRICATION OF 53X002 -K03	PMT	3M		L				L			L			L		RRC-MRCP	148926	C
1,394	RDCC-53 -53X002	RDCC-53X002-K04	LUBRICATION OF 53X002 -K04	PMT	3M		L				L			L			L		RRC-MRCP	148927	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,395	RDCC-53 -53X002	RDCC-53X002-K05	LUBRICATION OF 53X002 -K05	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148928	C
1,396	RDCC-53 -53X002	RDCC-53X002-K06	LUBRICATION OF 53X002 -K06	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148929	C
1,397	RDCC-53 -53X002	RDCC-53X002-K07	LUBRICATION OF 53X002 -K07	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148930	C
1,398	RDCC-53 -53X002	RDCC-53X002-K08	LUBRICATION OF 53X002 -K08	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148931	C
1,399	RDCC-53 -53X002	RDCC-53X002-K09	LUBRICATION OF 53X002 -K09	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148932	C
1,400	RDCC-53 -53X002	RDCC-53X002-K10	LUBRICATION OF 53X002 -K10	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148933	C
1,401	RDCC-53 -53X002	RDCC-53X002-K11	LUBRICATION OF 53X002 -K11	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148934	C
1,402	RDCC-53 -53X002	RDCC-53X002-K12	LUBRICATION OF 53X002 -K12	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148935	C
1,403	RDCC-53 -53X002	RDCC-53X002-K13	LUBRICATION OF 53X002 -K13	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148936	C
1,404	RDCC-53 -53X002	RDCC-53X002-K14	LUBRICATION OF 53X002 -K14	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148937	C
1,405	RDCC-53 -53X002	RDCC-53X002-K15	LUBRICATION OF 53X002 -K15	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148938	C
1,406	RDCC-53 -53X002	RDCC-53X002-K16	LUBRICATION OF 53X002 -K16	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148939	C
1,407	RDCC-53 -53X002	RDCC-53X002-K17	LUBRICATION OF 53X002 -K17	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148940	C
1,408	RDCC-53 -53X002	RDCC-53X002-K18	LUBRICATION OF 53X002 -K18	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148941	C
1,409	RDCC-53 -53X002	RDCC-53X002-K19	LUBRICATION OF 53X002 -K19	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148942	C
1,410	RDCC-53 -53X002	RDCC-53X002-K20	LUBRICATION OF 53X002 -K20	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148943	C
1,411	RDCC-53 -53X002	RDCC-53X002-K21	LUBRICATION OF 53X002 -K21	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148944	C
1,412	RDCC-53 -53X002	RDCC-53X002-K22	LUBRICATION OF 53X002 -K22	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148945	C
1,413	RDCC-53 -53X002	RDCC-53X002-K23	LUBRICATION OF 53X002 -K23	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148946	C
1,414	RDCC-53 -53X002	RDCC-53X002-K24	LUBRICATION OF 53X002 -K24	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148947	C
1,415	RDCC-53 -53X002	RDCC-53X002-K25	LUBRICATION OF 53X002 -K25	PMT	3M		L			L			L			L		RRC	RRC-MRCP	148948	C
1,416	RDCC-53 -53X002	RDCC-53X002-K26	LUBRICATION OF 53X002 -K26	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149072	C
1,417	RDCC-53 -53X002	RDCC-53X002-K27	LUBRICATION OF 53X002 -K27	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149073	C
1,418	RDCC-53 -53X002	RDCC-53X002-K28	LUBRICATION OF 53X002 -K28	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149074	C
1,419	RDCC-53 -53X002	RDCC-53X002-K29	LUBRICATION OF 53X002 -K29	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149075	C
1,420	RDCC-53 -53X002	RDCC-53X002-K30	LUBRICATION OF 53X002 -K30	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149076	C
1,421	RDCC-53 -53X002	RDCC-53X002-K31	LUBRICATION OF 53X002 -K31	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149077	C
1,422	RDCC-53 -53X002	RDCC-53X002-K32	LUBRICATION OF 53X002 -K32	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149078	C
1,423	RDCC-53 -53X002	RDCC-53X002-K33	LUBRICATION OF 53X002 -K33	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149079	C
1,424	RDCC-53 -53X002	RDCC-53X002-K34	LUBRICATION OF 53X002 -K34	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149080	C
1,425	RDCC-53 -53X002	RDCC-53X002-K35	LUBRICATION OF 53X002 -K35	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149081	C
1,426	RDCC-53 -53X002	RDCC-53X002-K36	LUBRICATION OF 53X002 -K36	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149082	C
1,427	RDCC-53 -53X002	RDCC-53X002-K37	LUBRICATION OF 53X002 -K37	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149083	C
1,428	RDCC-53 -53X002	RDCC-53X002-K38	LUBRICATION OF 53X002 -K38	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149084	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,429	RDCC-53 -53X002	RDCC-53X002-K39	LUBRICATION OF 53X002 -K39	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149085	C
1,430	RDCC-53 -53X002	RDCC-53X002-K40	LUBRICATION OF 53X002 -K40	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149086	C
1,431	RDCC-53 -53X002	RDCC-53X002-K41	LUBRICATION OF 53X002 -K41	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149087	C
1,432	RDCC-53 -53X002	RDCC-53X002-K42	LUBRICATION OF 53X002 -K42	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149088	C
1,433	RDCC-53 -53X002	RDCC-53X002-K43	LUBRICATION OF 53X002 -K43	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149089	C
1,434	RDCC-53 -53X002	RDCC-53X002-K44	LUBRICATION OF 53X002 -K44	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149090	C
1,435	RDCC-53 -53X002	RDCC-53X002-K45	LUBRICATION OF 53X002 -K45	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149091	C
1,436	RDCC-53 -53X002	RDCC-53X002-K46	LUBRICATION OF 53X002 -K46	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149092	C
1,437	RDCC-53 -53X002	RDCC-53X002-K47	LUBRICATION OF 53X002 -K47	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149093	C
1,438	RDCC-53 -53X002	RDCC-53X002-K48	LUBRICATION OF 53X002 -K48	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149094	C
1,439	RDCC-53 -53X002	RDCC-53X002-K49	LUBRICATION OF 53X002 -K49	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149095	C
1,440	RDCC-53 -53X002	RDCC-53X002-K50	LUBRICATION OF 53X002 -K50	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149096	C
1,441	RDCC-53 -53X002	RDCC-53X002-K51	LUBRICATION OF 53X002 -K51	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149097	C
1,442	RDCC-53 -53X002	RDCC-53X002-K52	LUBRICATION OF 53X002 -K52	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149098	C
1,443	RDCC-53 -53X002	RDCC-53X002-K53	LUBRICATION OF 53X002 -K53	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149099	C
1,444	RDCC-53 -53X002	RDCC-53X002-K54	LUBRICATION OF 53X002 -K54	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149100	C
1,445	RDCC-53 -53X002	RDCC-53X002-K55	LUBRICATION OF 53X002 -K55	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149101	C
1,446	RDCC-53 -53X002	RDCC-53X002-K56	LUBRICATION OF 53X002 -K56	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149102	C
1,447	RDCC-53 -53X002	RDCC-53X002-K57	LUBRICATION OF 53X002 -K57	PMT	3M		L			L			L			L		RRC	RRC-MRCP	149103	C
1,448	RDCC-53 -53X002	RDCC-53X002-P01A	VB. INSP & ANALY M/C 53X002-P01A	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149163	C
1,449	RDCC-53 -53X002	RDCC-53X002-P01A	PM INSP OF M/C NO. 53X002-P01A	PMT	4M	I				I			I					RRC	RRC-MRCP	149104	C
1,450	RDCC-53 -53X002	RDCC-53X002-P01B	VB. INSP & ANALY M/C 53X002-P01B	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149164	C
1,451	RDCC-53 -53X002	RDCC-53X002-P01B	PM INSP OF M/C NO. 53X002-P01B	PMT	4M			I			I			I			I	RRC	RRC-MRCP	149105	C
1,452	RDCC-53 -53X002	RDCC-53X002-PLC	INSPECT PLC SYSTEM	PMT	3M			I			I			I			I	CCS	CCS-SYS	246468	A
1,453	RDCC-53 -53X002	RDCC-53X002-PLC	BACKUP PLC SYSTEM	PMT	6M			I						I				CCS	CCS-SYS	246469	A
1,454	RDCC-53 -53X003	RDCC-53X003-EL01	PM ELECTROSTATIC PRECIPITATORS EL01	PMT	1M	P	P	P	P	P	P	P	P	P	P	P	P	RRC	RRC-ERCP	140425	A
1,455	RDCC-53 -53X003	RDCC-53X003-EL02	PM ELECTROSTATIC PRECIPITATORS EL02	PMT	1M	P	P	P	P	P	P	P	P	P	P	P	P	RRC	RRC-ERCP	140426	A
1,456	RDCC-53 -53X003	RDCC-53X003-EL03	PM ELECTROSTATIC PRECIPITATORS EL03	PMT	1M	P	P	P	P	P	P	P	P	P	P	P	P	RRC	RRC-ERCP	140427	A
1,457	RDCC-53 -53X003	RDCC-53X003-H01	VB. INSP & ANALY M/C 53X003-H01	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149165	C
1,458	RDCC-53 -53X003	RDCC-53X003-H01	PM OF 53X003-H01	PMT	6M					P						P		RRC	RRC-MRCP	148828	C
1,459	RDCC-53 -53X003	RDCC-53X003-H01	PM INSP OF M/C NO. 53X003-H01	PMT	4M			I			I			I			I	RRC	RRC-MRCP	149106	C
1,460	RDCC-53 -53X003	RDCC-53X003-H02	VB. INSP & ANALY M/C 53X003-H02	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149166	C
1,461	RDCC-53 -53X003	RDCC-53X003-H02	PM OF 53X003-H02	PMT	6M					P						P		RRC	RRC-MRCP	148829	C
1,462	RDCC-53 -53X003	RDCC-53X003-H02	PM INSP OF M/C NO. 53X003-H02	PMT	4M			I			I			I			I	RRC	RRC-MRCP	149107	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,463	RDCC-53 -53X003	RDCC-53X003-K01	VB. INSP & ANALY M/C 53X003-K01	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149167	C
1,464	RDCC-53 -53X003	RDCC-53X003-K01	PM INSP OF M/C NO. 53X003-K01	PMT	2M	I		I		I		I		I		I		RRC	RRC-MRCP	149108	C
1,465	RDCC-53 -53X003	RDCC-53X003-K01	REGREASING BRG OF 53X003-K01	PMT	2M	L		L		L		L		L		L		RRC	RRC-MRCP	149109	C
1,466	RDCC-53 -53X003	RDCC-53X003-K02	VB. INSP & ANALY M/C 53X003-K02	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149168	C
1,467	RDCC-53 -53X003	RDCC-53X003-K02	PM INSP OF M/C NO. 53X003-K02	PMT	2M	I		I		I		I		I		I		RRC	RRC-MRCP	149110	C
1,468	RDCC-53 -53X003	RDCC-53X003-K02	REGREASING BRG OF 53X003-K02	PMT	2M	L		L		L		L		L		L		RRC	RRC-MRCP	149111	C
1,469	RDCC-53 -53X003	RDCC-53X003-PLC	INSPECT PLC SYSTEM	PMT	3M			I			I			I			I	CCS	CCS-SYS	246470	A
1,470	RDCC-53 -53X003	RDCC-53X003-PLC	BACKUP PLC SYSTEM	PMT	6M			I						I				CCS	CCS-SYS	246471	A
1,471	RDCC-53 -53X006	RDCC-53X006-PLC	INSPECT PLC SYSTEM	PMT	3M			I			I			I			I	CCS	CCS-SYS	246472	A
1,472	RDCC-53 -53X006	RDCC-53X006-PLC	BACKUP PLC SYSTEM	PMT	6M			I						I				CCS	CCS-SYS	246473	A
1,473	RDCC-53 -53X101	RDCC-53X101-PLC	INSPECT PLC SYSTEM	PMT	3M			I			I			I			I	CCS	CCS-SYS	246474	A
1,474	RDCC-53 -53X101	RDCC-53X101-PLC	BACKUP PLC SYSTEM	PMT	6M			I						I				CCS	CCS-SYS	246475	A
1,475	RDCC-53 -53X106	RDCC-53X106-P01A	VB. INSP & ANALY M/C 53X106-P01A	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	149169	C
1,476	RDCC-53 -53X106	RDCC-53X106-P01A	PM OF 53X106-P01A	PMT	6M					P						P		RRC	RRC-MRCP	148830	C
1,477	RDCC-53 -53X106	RDCC-53X106-P01A	PM INSP OF M/C NO. 53X106-P01A	PMT	2M	L		L		L		L		L		L		RRC	RRC-MRCP	149112	C
1,478	RDCC-53 -53X109	RDCC-53X109-P01A	PM INSP OF M/C NO. RDCC-53X109	PMT	4M	I				I			I			I		RRC	RRC-MRCP	255695	C
1,479	RDCC-53 -53X109	RDCC-53X109-P01B	PM INSP OF M/C NO. RDCC-53X109	PMT	4M	I				I			I			I		RRC	RRC-MRCP	255696	C
1,480	RDCC-56 -AIR	RDCC-56-AH-001	PM ALL TYPE OF AIR 56-AH-001 (Large 2,8)	PMT	2M				P		P			P		P	P	RRC	RRC-ERCP	138223	A
1,481	RDCC-56 -AIR	RDCC-56-AH-001	PM ALL TYPE OF AIR 56-AH-001 (Large 2,8)	PMT	6M		P						P					RRC	RRC-ERCP	138223	A
1,482	RDCC-56 -DVA5601	RDCC-56DV001	TEST LINEAR HEAT DETECTOR RDCC-56DV001	PMT	6M			P						P				RRC	RRC-ERCP	150102	B
1,483	RDCC-56 -DVA5601	RDCC-56DV002	TEST LINEAR HEAT DETECTOR RDCC-56DV002	PMT	6M			P						P				RRC	RRC-ERCP	150103	B
1,484	RDCC-56 -DVA5601	RDCC-56DV003	TEST LINEAR HEAT DETECTOR RDCC-56DV003	PMT	6M			P						P				RRC	RRC-ERCP	150104	B
1,485	RDCC-56 -56P001A	RDCC-56P001A-M	STAND BY CHECK LV. MOT 56P001A-MD1	PMT	1Y								T					RRC	RRC-ERCP	139145	B
1,486	RDCC-56 -56P001A	RDCC-56P001A-M	Regreasing Mot BRG of 56P001A-MD1	PMT	4M	L				L			L					RRC	RRC-ERCP	139631	B
1,487	RDCC-56 -56P001A	RDCC-56P001A-M	STAND BY CHECK LV. MOT 56P001A-MD1	PMT	1Y				T									RRC	RRC-ERCP	153803	B
1,488	RDCC-56 -56P001A	RDCC-56P001A-P01	VB. INSP & ANALY M/C 56P001A	INT	4M	I				I			I					IRI	IRI-INVB	130298	B
1,489	RDCC-56 -56P001A	RDCC-56P001A-P01	VB. INSP & ANALY M/C 56P001A -P01	INT	4M		I				I			I				IRI	IRI-INVB	131030	B
1,490	RDCC-56 -56P001A	RDCC-56P001A-P01	VB. INSP & ANALY M/C 56P001A -P01	INT	4M			I				I			I			IRI	IRI-INVB	131257	B
1,491	RDCC-56 -56P001A	RDCC-56P001A-P01	PM INSP OF M/C NO. 56P001A -P01	PMT	4M		I				I			I				IRI	IRI-INVB	129699	B
1,492	RDCC-56 -56P001A	RDCC-56P001A-P01	PM OF 56P001A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130723	B
1,493	RDCC-56 -56P001B	RDCC-56P001B-M	STAND BY CHECK LV. MOT 56P001B-MD1	PMT	6M			T						T				RRC	RRC-ERCP	139146	B
1,494	RDCC-56 -56P001B	RDCC-56P001B-M	Regreasing Mot BRG of 56P001B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCP	139632	B
1,495	RDCC-56 -56P001B	RDCC-56P001B-P01	VB. INSP & ANALY M/C 56P001B	INT	4M				I				I				I	IRI	IRI-INVB	130299	B
1,496	RDCC-56 -56P001B	RDCC-56P001B-P01	PM INSP OF M/C NO. 56P001B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129700	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,497	RDCC-56 -56P001B	RDCC-56P001B-P01	PM OF 56P001B -P01	PMT	4M			P				P				P		RRC	RRC-MRCP	130724	B
1,498	RDCC-56 -56P002A	RDCC-56P002A-M	STAND BY CHECK LV. MOT 56P002A-M01	PMT	1Y								T					RRC	RRC-ERCP	139147	C
1,499	RDCC-56 -56P002A	RDCC-56P002A-M	Regreasing Mot BRG of 56P002A-M01	PMT	4M	L				L				L				RRC	RRC-ERCP	139633	C
1,500	RDCC-56 -56P002A	RDCC-56P002A-M	STAND BY CHECK LV. MOT 56P002A-M01	PMT	1Y				T									RRC	RRC-ERCP	153804	C
1,501	RDCC-56 -56P002A	RDCC-56P002A-P01	VB. INSP & ANALY M/C 56P002A	INT	4M	I				I				I				IRI	IRI-INVB	130300	C
1,502	RDCC-56 -56P002A	RDCC-56P002A-P01	VB. INSP & ANALY M/C 56P002A -P01	INT	4M		I				I				I			IRI	IRI-INVB	131031	C
1,503	RDCC-56 -56P002A	RDCC-56P002A-P01	VB. INSP & ANALY M/C 56P002A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131258	C
1,504	RDCC-56 -56P002A	RDCC-56P002A-P01	PM INSP OF M/C NO. 56P002A -P01	PMT	4M		I				I				I			RRC	RRC-MRCP	129701	C
1,505	RDCC-56 -56P002A	RDCC-56P002A-P01	PM OF 56P002A -P01	PMT	4M				P			P				P		RRC	RRC-MRCP	130725	C
1,506	RDCC-56 -56P002B	RDCC-56P002B-M	STAND BY CHECK LV. MOT 56P002B-M01	PMT	6M			T						T				RRC	RRC-ERCP	139148	C
1,507	RDCC-56 -56P002B	RDCC-56P002B-M	Regreasing Mot BRG of 56P002B-M01	PMT	4M				L				L				L	RRC	RRC-ERCP	139634	C
1,508	RDCC-56 -56P002B	RDCC-56P002B-P01	VB. INSP & ANALY M/C 56P002B	INT	4M				I				I				I	IRI	IRI-INVB	130301	C
1,509	RDCC-56 -56P002B	RDCC-56P002B-P01	PM INSP OF M/C NO. 56P002B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129702	C
1,510	RDCC-56 -56P002B	RDCC-56P002B-P01	PM OF 56P002B -P01	PMT	4M	P				P				P				RRC	RRC-MRCP	130726	C
1,511	RDCC-56 -56P003A	RDCC-56P003A-M	STAND BY CHECK LV. MOT 56P003A-M01	PMT	1Y								T					RRC	RRC-ERCP	139149	A
1,512	RDCC-56 -56P003A	RDCC-56P003A-M	STAND BY CHECK LV. MOT 56P003A-M01	PMT	1Y				T									RRC	RRC-ERCP	153805	A
1,513	RDCC-56 -56P003A	RDCC-56P003A-P01	VB. INSP & ANALY M/C 56P003A	INT	4M	I				I				I				IRI	IRI-INVB	130302	A
1,514	RDCC-56 -56P003A	RDCC-56P003A-P01	VB. INSP & ANALY M/C 56P003A -P01	INT	4M		I				I				I			IRI	IRI-INVB	131032	A
1,515	RDCC-56 -56P003A	RDCC-56P003A-P01	VB. INSP & ANALY M/C 56P003A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131259	A
1,516	RDCC-56 -56P003A	RDCC-56P003A-P01	PM INSP OF M/C NO. 56P003A -P01	PMT	4M		I				I				I			RRC	RRC-MRCP	129703	A
1,517	RDCC-56 -56P003A	RDCC-56P003A-P01	PM OF 56P003A -P01	PMT	4M				P			P				P		RRC	RRC-MRCP	130727	A
1,518	RDCC-56 -56P003B	RDCC-56P003B-M	STAND BY CHECK LV. MOT 56P003B-M01	PMT	6M			T						T				RRC	RRC-ERCP	139150	A
1,519	RDCC-56 -56P003B	RDCC-56P003B-P01	VB. INSP & ANALY M/C 56P003B	INT	4M				I				I				I	IRI	IRI-INVB	130303	A
1,520	RDCC-56 -56P003B	RDCC-56P003B-P01	PM INSP OF M/C NO. 56P003B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129704	A
1,521	RDCC-56 -56P003B	RDCC-56P003B-P01	PM OF 56P003B -P01	PMT	4M	P				P				P				RRC	RRC-MRCP	130728	A
1,522	RDCC-56 -56P004A	RDCC-56P004A-M	STAND BY CHECK LV. MOT 56P004A-M01	PMT	1Y								T					RRC	RRC-ERCP	139151	B
1,523	RDCC-56 -56P004A	RDCC-56P004A-M	STAND BY CHECK LV. MOT 56P004A-M01	PMT	1Y				T									RRC	RRC-ERCP	153806	B
1,524	RDCC-56 -56P004A	RDCC-56P004A-P01	VB. INSP & ANALY M/C 56P004A	INT	4M	I				I				I				IRI	IRI-INVB	130304	B
1,525	RDCC-56 -56P004A	RDCC-56P004A-P01	VB. INSP & ANALY M/C 56P004A -P01	INT	4M		I				I				I			IRI	IRI-INVB	131033	B
1,526	RDCC-56 -56P004A	RDCC-56P004A-P01	VB. INSP & ANALY M/C 56P004A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131260	B
1,527	RDCC-56 -56P004A	RDCC-56P004A-P01	PM INSP OF M/C NO. 56P004A -P01	PMT	4M		I				I				I			RRC	RRC-MRCP	129705	B
1,528	RDCC-56 -56P004A	RDCC-56P004A-P01	PM OF 56P004A -P01	PMT	4M				P			P				P		RRC	RRC-MRCP	130729	B
1,529	RDCC-56 -56P004B	RDCC-56P004B-M	STAND BY CHECK LV. MOT 56P004B-M01	PMT	6M			T						T				RRC	RRC-ERCP	139152	B
1,530	RDCC-56 -56P004B	RDCC-56P004B-P01	VB. INSP & ANALY M/C 56P004B	INT	4M				I				I				I	IRI	IRI-INVB	130305	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,531	RDCC-56 -56P004B	RDCC-56P004B-P01	PM INSP OF M/C NO. 56P004B -P01	PMT	4M					I			I				I	RRC	RRC-MRCP	129706	B
1,532	RDCC-56 -56P004B	RDCC-56P004B-P01	PM OF 56P004B -P01	PMT	4M	P				P				P				RRC	RRC-MRCP	130730	B
1,533	RDCC-56 -56P005A	RDCC-56P005A-M	STAND BY CHECK LV. MOT 56P005A-M01	PMT	1Y									T				RRC	RRC-ERCP	139153	B
1,534	RDCC-56 -56P005A	RDCC-56P005A-M	STAND BY CHECK LV. MOT 56P005A-M01	PMT	1Y					T								RRC	RRC-ERCP	153807	B
1,535	RDCC-56 -56P005A	RDCC-56P005A-P01	VB. INSP & ANALY M/C 56P005A	INT	4M	I					I			I				IRI	IRI-INVB	130306	B
1,536	RDCC-56 -56P005A	RDCC-56P005A-P01	VB. INSP & ANALY M/C 56P005A -P01	INT	4M		I					I			I			IRI	IRI-INVB	131034	B
1,537	RDCC-56 -56P005A	RDCC-56P005A-P01	VB. INSP & ANALY M/C 56P005A -P01	INT	4M				I				I			I		IRI	IRI-INVB	131261	B
1,538	RDCC-56 -56P005A	RDCC-56P005A-P01	PM INSP OF M/C NO. 56P005A -P01	PMT	4M				I				I			I		RRC	RRC-MRCP	129707	B
1,539	RDCC-56 -56P005A	RDCC-56P005A-P01	PM OF 56P005A -P01	PMT	4M					P				P			P	RRC	RRC-MRCP	130731	B
1,540	RDCC-56 -56P005B	RDCC-56P005B-M	STAND BY CHECK LV. MOT 56P005B-M01	PMT	6M				T						T			RRC	RRC-ERCP	139154	B
1,541	RDCC-56 -56P005B	RDCC-56P005B-P01	VB. INSP & ANALY M/C 56P005B	INT	4M					I				I				IRI	IRI-INVB	130307	B
1,542	RDCC-56 -56P005B	RDCC-56P005B-P01	PM INSP OF M/C NO. 56P005B -P01	PMT	4M					I				I				RRC	RRC-MRCP	129708	B
1,543	RDCC-56 -56P005B	RDCC-56P005B-P01	PM OF 56P005B -P01	PMT	4M	P				P				P				RRC	RRC-MRCP	130732	B
1,544	RDCC-56 -56P006A	RDCC-56P006A-M	STAND BY CHECK LV. MOT 56P006A-M01	PMT	1Y				T									RRC	RRC-ERCP	139155	A
1,545	RDCC-56 -56P006A	RDCC-56P006A-M	Regreasing Mot BRG of 56P006A-M01	PMT	4M	L				L				L				RRC	RRC-ERCP	139635	A
1,546	RDCC-56 -56P006A	RDCC-56P006A-M	STAND BY CHECK LV. MOT 56P006A-M01	PMT	1Y					T								RRC	RRC-ERCP	153808	A
1,547	RDCC-56 -56P006A	RDCC-56P006A-P01	VB. INSP & ANALY M/C 56P006A	INT	4M	I				I				I				IRI	IRI-INVB	130308	A
1,548	RDCC-56 -56P006A	RDCC-56P006A-P01	VB. INSP & ANALY M/C 56P006A -P01	INT	4M		I				I				I			IRI	IRI-INVB	131035	A
1,549	RDCC-56 -56P006A	RDCC-56P006A-P01	VB. INSP & ANALY M/C 56P006A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131262	A
1,550	RDCC-56 -56P006A	RDCC-56P006A-P01	PM INSP OF M/C NO. 56P006A -P01	PMT	4M			I				I				I		RRC	RRC-MRCP	129709	A
1,551	RDCC-56 -56P006A	RDCC-56P006A-P01	PM OF 56P006A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130733	A
1,552	RDCC-56 -56P006B	RDCC-56P006B-M	STAND BY CHECK LV. MOT 56P006B-M01	PMT	6M			T						T				RRC	RRC-ERCP	139156	A
1,553	RDCC-56 -56P006B	RDCC-56P006B-M	Regreasing Mot BRG of 56P006B-M01	PMT	4M				L				L				L	RRC	RRC-ERCP	139636	A
1,554	RDCC-56 -56P006B	RDCC-56P006B-P01	VB. INSP & ANALY M/C 56P006B -P01	INT	4M				I				I				I	IRI	IRI-INVB	130309	A
1,555	RDCC-56 -56P006B	RDCC-56P006B-P01	PM INSP OF M/C NO. 56P006B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129710	A
1,556	RDCC-56 -56P006B	RDCC-56P006B-P01	PM OF 56P006B -P01	PMT	4M	P				P				P				RRC	RRC-MRCP	130734	A
1,557	RDCC-56 -56P007A	RDCC-56P007A-M	STAND BY CHECK LV. MOT 56P007A-M01	PMT	1Y									T				RRC	RRC-ERCP	139157	B
1,558	RDCC-56 -56P007A	RDCC-56P007A-M	STAND BY CHECK LV. MOT 56P007A-M01	PMT	1Y					T								RRC	RRC-ERCP	153809	B
1,559	RDCC-56 -56P007A	RDCC-56P007A-P01	VB. INSP & ANALY M/C 56P007A	INT	4M	I				I				I				IRI	IRI-INVB	130310	B
1,560	RDCC-56 -56P007A	RDCC-56P007A-P01	VB. INSP & ANALY M/C 56P007A -P01	INT	4M		I				I				I			IRI	IRI-INVB	131036	B
1,561	RDCC-56 -56P007A	RDCC-56P007A-P01	VB. INSP & ANALY M/C 56P007A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131263	B
1,562	RDCC-56 -56P007A	RDCC-56P007A-P01	PM INSP OF M/C NO. 56P007A -P01	PMT	4M			I				I				I		RRC	RRC-MRCP	129711	B
1,563	RDCC-56 -56P007A	RDCC-56P007A-P01	PM OF 56P007A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130735	B
1,564	RDCC-56 -56P007B	RDCC-56P007B-M	STAND BY CHECK LV. MOT 56P007B-M01	PMT	6M			T						T				RRC	RRC-ERCP	139158	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,565	RDCC-56 -56P007B	RDCC-56P007B-P01	VB. INSP & ANALY M/C 56P007B	INT	4M				I				I				I	IRI	IRI-INVB	130311	B
1,566	RDCC-56 -56P007B	RDCC-56P007B-P01	PM INSP OF M/C NO. 56P007B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129712	B
1,567	RDCC-56 -56P007B	RDCC-56P007B-P01	PM OF 56P007B -P01	PMT	4M	P				P				P				RRC	RRC-MRCP	130736	B
1,568	RDCC-56 -56P008A	RDCC-56P008A-M	STAND BY CHECK LV. MOT 56P008A-M01	PMT	1Y								T					RRC	RRC-ERCP	139159	B
1,569	RDCC-56 -56P008A	RDCC-56P008A-M	STAND BY CHECK LV. MOT 56P008A-M01	PMT	1Y				T									RRC	RRC-ERCP	153810	B
1,570	RDCC-56 -56P008A	RDCC-56P008A-P01	VB. INSP & ANALY M/C 56P008A	INT	4M	I				I				I				IRI	IRI-INVB	130312	B
1,571	RDCC-56 -56P008A	RDCC-56P008A-P01	VB. INSP & ANALY M/C 56P008A -P01	INT	4M		I				I				I			IRI	IRI-INVB	131037	B
1,572	RDCC-56 -56P008A	RDCC-56P008A-P01	VB. INSP & ANALY M/C 56P008A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131264	B
1,573	RDCC-56 -56P008A	RDCC-56P008A-P01	PM INSP OF M/C NO. 56P008A -P01	PMT	4M			I				I				I		RRC	RRC-MRCP	129713	B
1,574	RDCC-56 -56P008A	RDCC-56P008A-P01	PM OF 56P008A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130737	B
1,575	RDCC-56 -56P008B	RDCC-56P008B-M	STAND BY CHECK LV. MOT 56P008B-M01	PMT	6M			T						T				RRC	RRC-ERCP	139160	B
1,576	RDCC-56 -56P008B	RDCC-56P008B-P01	VB. INSP & ANALY M/C 56P008B	INT	4M				I				I				I	IRI	IRI-INVB	130313	B
1,577	RDCC-56 -56P008B	RDCC-56P008B-P01	PM INSP OF M/C NO. 56P008B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129714	B
1,578	RDCC-56 -56P008B	RDCC-56P008B-P01	PM OF 56P008B -P01	PMT	4M		P				P				P			RRC	RRC-MRCP	130738	B
1,579	RDCC-56 -56P009A	RDCC-56P009A-M	STAND BY CHECK LV. MOT 56P009A-M01	PMT	1Y								T					RRC	RRC-ERCP	139161	B
1,580	RDCC-56 -56P009A	RDCC-56P009A-M	STAND BY CHECK LV. MOT 56P009A-M01	PMT	1Y				T									RRC	RRC-ERCP	153811	B
1,581	RDCC-56 -56P009A	RDCC-56P009A-P01	VB. INSP & ANALY M/C 56P009A	INT	4M	I				I				I				IRI	IRI-INVB	130314	B
1,582	RDCC-56 -56P009A	RDCC-56P009A-P01	VB. INSP & ANALY M/C 56P009A -P01	INT	4M		I				I				I			IRI	IRI-INVB	131038	B
1,583	RDCC-56 -56P009A	RDCC-56P009A-P01	VB. INSP & ANALY M/C 56P009A -P01	INT	4M			I				I				I		IRI	IRI-INVB	131265	B
1,584	RDCC-56 -56P009A	RDCC-56P009A-P01	PM INSP OF M/C NO. 56P009A -P01	PMT	4M			I				I				I		RRC	RRC-MRCP	129715	B
1,585	RDCC-56 -56P009A	RDCC-56P009A-P01	PM OF 56P009A -P01	PMT	4M				P				P				P	RRC	RRC-MRCP	130739	B
1,586	RDCC-56 -56P009B	RDCC-56P009B-M	STAND BY CHECK LV. MOT 56P009B-M01	PMT	6M			T						T				RRC	RRC-ERCP	139162	B
1,587	RDCC-56 -56P009B	RDCC-56P009B-P01	VB. INSP & ANALY M/C 56P009B	INT	4M				I				I				I	IRI	IRI-INVB	130315	B
1,588	RDCC-56 -56P009B	RDCC-56P009B-P01	PM INSP OF M/C NO. 56P009B -P01	PMT	4M				I				I				I	RRC	RRC-MRCP	129716	B
1,589	RDCC-56 -56P009B	RDCC-56P009B-P01	PM OF 56P009B -P01	PMT	4M		P				P				P			RRC	RRC-MRCP	130740	B
1,590	RDCC-56 -56T001	RDCC-56T001-T01	Storage tank inspection	PMT	5Y								I					IRI	IRI-INRC	169257	B
1,591	RDCC-53 -78P003A	RDCC-78P003A-P01	VB. INSP & ANALY M/C 78P003A-P01	INT	4M	I				I				I				IRI	IRI-INVB	149170	C
1,592	RDCC-53 -78P003A	RDCC-78P003A-P01	VB. INSP & ANALY M/C 78P003A-P01	INT	4M		I				I				I			IRI	IRI-INVB	149171	C
1,593	RDCC-53 -78P003A	RDCC-78P003A-P01	VB. INSP & ANALY M/C 78P003A-P01	INT	4M			I				I				I		IRI	IRI-INVB	149172	C
1,594	RDCC-53 -78P003A	RDCC-78P003A-P01	PM INSP OF M/C NO. 78P003A	PMT	4M		I				I				I			RRC	RRC-MRCP	149113	C
1,595	RDCC-53 -78P003A	RDCC-78P003A-P01	REGREASING BRG OF 78P003A	PMT	6M			I						I				RRC	RRC-MRCP	149114	C
1,596	RDCC-53 -78P003B	RDCC-78P003B-P01	VB. INSP & ANALY M/C 78P003B-P01	INT	4M				I				I				I	IRI	IRI-INVB	149173	C
1,597	RDCC-53 -78P003B	RDCC-78P003B-P01	PM INSP OF M/C NO. 78P003B	PMT	4M				I				I				I	RRC	RRC-MRCP	149115	C
1,598	RDCC-53 -78P003B	RDCC-78P003B-P01	REGREASING BRG OF 78P003B	PMT	4M				L				L				L	RRC	RRC-MRCP	149116	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,599	RDCC-53 -78T003	RDCC-78T003-T01	Storage tank inspection	PMT	5Y								I					IRI	IRI-INRC	169256	C
1,600	RDCC-53 -QMI_GAS	RDCC-AT5301401	VERIFY OXYGEN AT5301401	PMT	6M			V						V				CAN	CAN-QUHV	140830	A
1,601	RDCC-53 -QMI_GAS	RDCC-AT5301402	VERIFY IR AT5301402	PMT	6M			V						V				CAN	CAN-QUHV	140831	A
1,602	RDCC-53 -QMI_GAS	RDCC-AT5302001	VERIFY DUST AT5302001	PMT	6M				V						V			CAN	CAN-QUHV	140839	B
1,603	RDCC-53 -QMI_GAS	RDCC-AT5302002	VERIFY CEMS AT5302002	PMT	2M	V		V		V		V		V		V		CAN	CAN-QUHV	140828	B
1,604	RDCC-53 -QMI_GC	RDCC-AT5307001	VERIFY GC AT5307001	PMT	4M	V				V				V				CAN	CAN-QUHV	140832	A
1,605	RDCC-53 -QMI_GC	RDCC-AT5307301	VERIFY GC AT5307301	PMT	4M	V				V				V				CAN	CAN-QUHV	140833	A
1,606	RDCC-53 -QMI_GC	RDCC-AT5309301	VERIFY GC AT5309301	PMT	4M	V				V				V				CAN	CAN-QUHV	140834	A
1,607	RDCC-53 -QMI_GC	RDCC-AT5309401	VERIFY GC AT5309401	PMT	4M	V				V				V				CAN	CAN-QUHV	140835	A
1,608	RDCC-53 -QMI_GC	RDCC-AT5309601	VERIFY GC AT5309601	PMT	4M	V				V				V				CAN	CAN-QUHV	140836	A
1,609	RDCC-53 -QMI_GAS	RDCC-AT5310601	VERIFY CEMS AT5310602	PMT	2M	V		V		V		V		V		V		CAN	CAN-QUHV	140829	B
1,610	RDCC-53 -QMI_GAS	RDCC-AT5310602	VERIFY DUST AT5310601	PMT	6M				V						V			CAN	CAN-QUHV	140840	B
1,611	RDCC-53 -QMI_GAS	RDCC-AT5310603	VERIFY OXYGEN AT5310603	PMT	6M			V						V				CAN	CAN-QUHV	140837	B
1,612	RDCC-53 -53D006	RDCC-AT5312102	VERIFY PH RDCC-AT5312102	PMT	6M				V						V			CAN	CAN-QUHV	255683	C
1,613	RDCC-53 -53D006	RDCC-AT5312108	VERIFY PH RDCC-AT5312108	PMT	6M				V						V			CAN	CAN-QUHV	255682	C
1,614	RDCC-53 -QMI_LIQ	RDCC-AT5352409	VERIFY CONDUCTIVITY-ANA AT5352409	PMT	6M				V						V			CAN	CAN-QUHV	140593	B
1,615	RDCC-53 -QMI_LIQ	RDCC-AT5352502	VERIFY CONDUCTIVITY-ANA AT5352502	PMT	6M				V						V			CAN	CAN-QUHV	140594	B
1,616	RDCC-53 -QMI_LIQ	RDCC-AT5352508	VERIFY PH AT5352508	PMT	6M				V						V			CAN	CAN-QUHV	140595	B
1,617	RDCC-53 -QMI_GAS	RDCC-AT5353030	VERIFY SO2-NO_X AT5353030	PMT	6M				V						V			CAN	CAN-QUHV	140596	B
1,618	RDCC-53 -QMI_GAS	RDCC-AT5353031	VERIFY SO2-NO_X AT5353031	PMT	6M				V						V			CAN	CAN-QUHV	140597	B
1,619	RDCC-53 -QMI_GAS	RDCC-AT5353032	VERIFY SO2-NO_X AT5353032	PMT	6M				V						V			CAN	CAN-QUHV	140598	B
1,620	RDCC-56 -QMI_GC	RDCC-AT5600201	VERIFY GC AT5600201	PMT	4M	V				V			V					CAN	CAN-QUHV	140774	B
1,621	RDCC-56 -QMI_GC	RDCC-AT5600501	VERIFY GC AT5600501	PMT	4M	V				V			V					CAN	CAN-QUHV	140775	B
1,622	RDCC-56 -QMI_GAS	RDCC-AT5600801	VERIFY OXYGEN AT5600801	PMT	6M			V					V					CAN	CAN-QUHV	140776	B
1,623	RDCC-56 -QMI_GAS	RDCC-AT5600802	VERIFY OXYGEN AT5600802	PMT	6M			V					V					CAN	CAN-QUHV	140777	B
1,624	RDCC-53 -AIR	RDCC-B10-HV-401	PM TYPE OF AIR B10-HV-401 (Large 2,8)	PMT	2M				P		P			P		P		RRC	RRC-ERCP	138244	B
1,625	RDCC-53 -AIR	RDCC-B10-HV-401	PM TYPE OF AIR B10-HV-401 (Large 2,8)	PMT	6M		P						P					RRC	RRC-ERCP	138244	B
1,626	RDCC-53 -AIR	RDCC-B10-HV-402	PM TYPE OF AIR B10-HV-402 (Large 2,8)	PMT	2M				P		P			P		P		RRC	RRC-ERCP	138245	B
1,627	RDCC-53 -AIR	RDCC-B10-HV-402	PM TYPE OF AIR B10-HV-402 (Large 2,8)	PMT	6M		P						P					RRC	RRC-ERCP	138245	B
1,628	RDCC-53 -AIR	RDCC-B10-HV-403	PM TYPE OF AIR B10-HV-403 (Large 2,8)	PMT	2M				P		P			P		P		RRC	RRC-ERCP	138246	B
1,629	RDCC-53 -AIR	RDCC-B10-HV-403	PM TYPE OF AIR B10-HV-403 (Large 2,8)	PMT	6M		P						P					RRC	RRC-ERCP	138246	B
1,630	RDCC-53 -AIR	RDCC-B10-HV-404	PM TYPE OF AIR B10-HV-404 (Large 2,8)	PMT	2M				P		P			P		P		RRC	RRC-ERCP	138247	B
1,631	RDCC-53 -AIR	RDCC-B10-HV-404	PM TYPE OF AIR B10-HV-404 (Large 2,8)	PMT	6M		P						P					RRC	RRC-ERCP	138247	B
1,632	RDCC-STR-BUILDING	RDCC-BDG-53KD01	INSPECTION BUILDING FOR RCPP	INT	6Y				I									ENE	ENE-ENDS	204424	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,633	RDCC-STR-BUILDING	RDCC-BDG-53K101	INSPECTION BUILDING FOR RCPP	INT	6Y				I									ENE	ENE-ENGS	204425	A
1,634	RDCC-STR-BUILDING	RDCC-BDG-A-53/56	INSPECTION BUILDING FOR RCPP	INT	6Y				I									ENE	ENE-ENGS	204417	A
1,635	RDCC-STR-BUILDING	RDCC-BDG-B-53	INSPECTION BUILDING FOR RCPP	INT	6Y				I									ENE	ENE-ENGS	204418	A
1,636	RDCC-STR-BUILDING	RDCC-BDG-C-53	INSPECTION BUILDING FOR RCPP	INT	6Y				I									ENE	ENE-ENGS	204419	A
1,637	RDCC-STR-BUILDING	RDCC-BDG-D-53	INSPECTION BUILDING FOR RCPP	INT	6Y				I									ENE	ENE-ENGS	204420	A
1,638	RDCC-STR-BUILDING	RDCC-BDG-E-53	INSPECTION BUILDING FOR RCPP	INT	6Y				I									ENE	ENE-ENGS	204421	A
1,639	RDCC-STR-BUILDING	RDCC-BDG-F-53	INSPECTION BUILDING FOR RCPP	INT	6Y				I									ENE	ENE-ENGS	204422	A
1,640	RDCC-STR-BUILDING	RDCC-BDG-G-53	INSPECTION BUILDING FOR RCPP	INT	6Y				I									ENE	ENE-ENGS	204423	A
1,641	RDCC-53 -DCS	RDCC-DCS	INSPECT DCS SYSTEM	PMT	3M			I			I			I			I	CCS	CCS-SYS	246457	A
1,642	RDCC-53 -DCS	RDCC-DCS	BACKUP DCS SYSTEM	PMT	6M			I						I				CCS	CCS-SYS	246458	A
1,643	RDCC-53 -DCS	RDCC-DCS	UPDATE ANTIVIRUS DCS SYSTEM	PMT	3M			U			U			U			U	CCS	CCS-SYS	246459	A
1,644	RDCC-53 -53Z030	RDCC-DI5311801	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y												I	RRC	RRC-IROP	255810	C
1,645	RDCC-53 -FIRE_ALARM	RDCC-FA-MCP-53	PM F/A PUSH BUTTON (###) (UNIT 53)	PMT	3M		P			P			P			P		RRC	RRC-ERCP	140380	A
1,646	RDCC-56 -FIRE_ALARM	RDCC-FA-MCP-56	PM F/A PUSH BUTTON (###) (UNIT 56)	PMT	3M		P			P			P			P		RRC	RRC-ERCP	140383	A
1,647	RDCC-53 -FGS	RDCC-FGS	INSPECT FGS SYSTEM	PMT	3M			I			I			I			I	CCS	CCS-SYS	246463	A
1,648	RDCC-53 -FGS	RDCC-FGS	BACKUP FGS SYSTEM	PMT	6M			I						I				CCS	CCS-SYS	246464	A
1,649	RDCC-53 -FGS	RDCC-FGS	UPDATE ANTIVIRUS FGS SYSTEM	PMT	3M			U			U			U			U	CCS	CCS-SYS	246465	A
1,650	RDCC-53 -FLOW	RDCC-FT5300101	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133209	C
1,651	RDCC-53 -FLOW	RDCC-FT5300102	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133210	C
1,652	RDCC-53 -FLOW	RDCC-FT5300103	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133211	C
1,653	RDCC-53 -FLOW	RDCC-FT5300104	INSP. FIELD INST. (ตัดศูนย์กลาง)	INS	1Y	I												RRC	RRC-IROP	133212	C
1,654	RDCC-53 -FLOW	RDCC-FT5300104	FT5300104-FULLFUN TEST FLOW TR	PMT	5Y											F		RRC	RRC-IROP	260378	C
1,655	RDCC-53 -FLOW	RDCC-FT5300105	INSP. FIELD INST. (ตัดศูนย์กลาง)	INS	1Y	I												RRC	RRC-IROP	133213	C
1,656	RDCC-53 -FLOW	RDCC-FT5300105	FT5300105-FULLFUN TEST FLOW TR	PMT	5Y											F		RRC	RRC-IROP	260379	C
1,657	RDCC-53 -FLOW	RDCC-FT5300106	INSP. FIELD INST. (ตัดศูนย์กลาง)	INS	1Y	I												RRC	RRC-IROP	133214	C
1,658	RDCC-53 -FLOW	RDCC-FT5300106	FT5300106-FULLFUN TEST FLOW TR	PMT	5Y											F		RRC	RRC-IROP	260380	C
1,659	RDCC-53 -FLOW	RDCC-FT5300107	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133215	C
1,660	RDCC-53 -FLOW	RDCC-FT5300109	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133216	C
1,661	RDCC-53 -FLOW	RDCC-FT5300301	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133217	C
1,662	RDCC-53 -FLOW	RDCC-FT5300401	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133218	C
1,663	RDCC-53 -FLOW	RDCC-FT5300402	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133219	C
1,664	RDCC-53 -FLOW	RDCC-FT5300403	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133220	C
1,665	RDCC-53 -FLOW	RDCC-FT5300404	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133221	C
1,666	RDCC-53 -FLOW	RDCC-FT5300405	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133222	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,667	RDCC-53 -FLOW	RDCC-FT5300406	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133223	C
1,668	RDCC-53 -FLOW	RDCC-FT5300601	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133224	C
1,669	RDCC-53 -FLOW	RDCC-FT5300602	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133200	C
1,670	RDCC-53 -FLOW	RDCC-FT5300701	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133225	C
1,671	RDCC-53 -FLOW	RDCC-FT5300702	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133226	C
1,672	RDCC-53 -FLOW	RDCC-FT5300703	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133227	C
1,673	RDCC-53 -FLOW	RDCC-FT5300704	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133228	C
1,674	RDCC-53 -FLOW	RDCC-FT5300705	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133229	C
1,675	RDCC-53 -FLOW	RDCC-FT5300706	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133230	C
1,676	RDCC-53 -FLOW	RDCC-FT5300712	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133231	C
1,677	RDCC-53 -FLOW	RDCC-FT5300801	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133232	C
1,678	RDCC-53 -FLOW	RDCC-FT5300802	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133233	C
1,679	RDCC-53 -FLOW	RDCC-FT5300803	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133234	C
1,680	RDCC-53 -FLOW	RDCC-FT5300804	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133235	C
1,681	RDCC-53 -FLOW	RDCC-FT5300809	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133236	C
1,682	RDCC-53 -FLOW	RDCC-FT5300810	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133237	C
1,683	RDCC-53 -FLOW	RDCC-FT5300813	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133238	C
1,684	RDCC-53 -FLOW	RDCC-FT5300814	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133239	C
1,685	RDCC-53 -FLOW	RDCC-FT5300815	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133240	C
1,686	RDCC-53 -FLOW	RDCC-FT5300816	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133241	C
1,687	RDCC-53 -FLOW	RDCC-FT5300817	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133242	C
1,688	RDCC-53 -FLOW	RDCC-FT5300818	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133243	C
1,689	RDCC-53 -FLOW	RDCC-FT5300819	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133244	C
1,690	RDCC-53 -FLOW	RDCC-FT5300824	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133245	C
1,691	RDCC-53 -FLOW	RDCC-FT5300901	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133246	C
1,692	RDCC-53 -FLOW	RDCC-FT5300902	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133247	C
1,693	RDCC-53 -FLOW	RDCC-FT5300903	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133248	C
1,694	RDCC-53 -FLOW	RDCC-FT5300904	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133249	C
1,695	RDCC-53 -FLOW	RDCC-FT5300912	INSP. FIELD INST. (ตัดศูนย์กลาง)	INS	1Y	I												RRC	RRC-IROP	133250	C
1,696	RDCC-53 -FLOW	RDCC-FT5300912	FT5300912-FULLFUN TEST FLOW TR	PMT	5Y												F	RRC	RRC-IROP	260384	C
1,697	RDCC-53 -FLOW	RDCC-FT5300915	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133251	C
1,698	RDCC-53 -FLOW	RDCC-FT5301002	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133252	C
1,699	RDCC-53 -FLOW	RDCC-FT5301003	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133253	C
1,700	RDCC-53 -FLOW	RDCC-FT5301008	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133254	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,701	RDCC-53 -FLOW	RDCC-FT5301101	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133255	C
1,702	RDCC-53 -FLOW	RDCC-FT5301102	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133256	C
1,703	RDCC-53 -FLOW	RDCC-FT5301103	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133257	C
1,704	RDCC-53 -FLOW	RDCC-FT5301104	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133258	C
1,705	RDCC-53 -FLOW	RDCC-FT5301105	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133259	C
1,706	RDCC-53 -FLOW	RDCC-FT5301106	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133260	C
1,707	RDCC-53 -FLOW	RDCC-FT5302502	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133261	C
1,708	RDCC-53 -FLOW	RDCC-FT5302503	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133262	C
1,709	RDCC-53 -FLOW	RDCC-FT5302601	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133263	C
1,710	RDCC-53 -FLOW	RDCC-FT5302602	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133201	C
1,711	RDCC-53 -FLOW	RDCC-FT5302701A	INSP. FIELD INST. (ตัดศูนย์กลาง)	INS	1Y	I												RRC	RRC-IROP	133264	C
1,712	RDCC-53 -FLOW	RDCC-FT5302701A	FT5302701A-FULLFUN TEST FLOW T	PMT	5Y											F		RRC	RRC-IROP	260381	C
1,713	RDCC-53 -FLOW	RDCC-FT5302701B	INSP. FIELD INST. (ตัดศูนย์กลาง)	INS	1Y	I												RRC	RRC-IROP	133265	C
1,714	RDCC-53 -FLOW	RDCC-FT5302701B	FT5302701B-FULLFUN TEST FLOW T	PMT	5Y											F		RRC	RRC-IROP	260382	C
1,715	RDCC-53 -FLOW	RDCC-FT5302701C	INSP. FIELD INST. (ตัดศูนย์กลาง)	INS	1Y	I												RRC	RRC-IROP	133266	C
1,716	RDCC-53 -FLOW	RDCC-FT5302701C	FT5302701C-FULLFUN TEST FLOW T	PMT	5Y											F		RRC	RRC-IROP	260383	C
1,717	RDCC-53 -FLOW	RDCC-FT5302702A	INSP. FIELD INST. (ตัดศูนย์กลาง)	INS	1Y	I												RRC	RRC-IROP	133267	C
1,718	RDCC-53 -FLOW	RDCC-FT5302702A	FT5302702A-FULLFUN TEST FLOW T	PMT	5Y											F		RRC	RRC-IROP	260385	C
1,719	RDCC-53 -FLOW	RDCC-FT5302702B	INSP. FIELD INST. (ตัดศูนย์กลาง)	INS	1Y	I												RRC	RRC-IROP	133268	C
1,720	RDCC-53 -FLOW	RDCC-FT5302702B	FT5302702B-FULLFUN TEST FLOW T	PMT	5Y											F		RRC	RRC-IROP	260386	C
1,721	RDCC-53 -FLOW	RDCC-FT5302702C	INSP. FIELD INST. (ตัดศูนย์กลาง)	INS	1Y	I												RRC	RRC-IROP	133269	C
1,722	RDCC-53 -FLOW	RDCC-FT5302702C	FT5302702C-FULLFUN TEST FLOW T	PMT	5Y											F		RRC	RRC-IROP	260387	C
1,723	RDCC-53 -FLOW	RDCC-FT5302702D	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133270	C
1,724	RDCC-53 -FLOW	RDCC-FT5302703A	INSP. FIELD INST. (ตัดศูนย์กลาง)	INS	1Y	I												RRC	RRC-IROP	133271	C
1,725	RDCC-53 -FLOW	RDCC-FT5302703A	FT5302703A-FULLFUN TEST FLOW T	PMT	5Y											F		RRC	RRC-IROP	260388	C
1,726	RDCC-53 -FLOW	RDCC-FT5302703B	INSP. FIELD INST. (ตัดศูนย์กลาง)	INS	1Y	I												RRC	RRC-IROP	133272	C
1,727	RDCC-53 -FLOW	RDCC-FT5302703B	FT5302703B-FULLFUN TEST FLOW T	PMT	5Y											F		RRC	RRC-IROP	260389	C
1,728	RDCC-53 -FLOW	RDCC-FT5302703C	INSP. FIELD INST. (ตัดศูนย์กลาง)	INS	1Y	I												RRC	RRC-IROP	133273	C
1,729	RDCC-53 -FLOW	RDCC-FT5302703C	FT5302703C-FULLFUN TEST FLOW T	PMT	5Y											F		RRC	RRC-IROP	260390	C
1,730	RDCC-53 -FLOW	RDCC-FT5302703D	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133274	C
1,731	RDCC-53 -FLOW	RDCC-FT5302704A	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133275	C
1,732	RDCC-53 -FLOW	RDCC-FT5302704B	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133276	C
1,733	RDCC-53 -FLOW	RDCC-FT5302704C	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133277	C
1,734	RDCC-53 -FLOW	RDCC-FT5302704D	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133278	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,735	RDCC-53 -FLOW	RDCC-FT5302705A	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133279	C
1,736	RDCC-53 -FLOW	RDCC-FT5302705B	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133280	C
1,737	RDCC-53 -FLOW	RDCC-FT5302705C	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133281	C
1,738	RDCC-53 -FLOW	RDCC-FT5302705D	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133282	C
1,739	RDCC-53 -FLOW	RDCC-FT5302752	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133283	C
1,740	RDCC-53 -FLOW	RDCC-FT5302801	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133284	C
1,741	RDCC-53 -FLOW	RDCC-FT5302901	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133285	C
1,742	RDCC-53 -FLOW	RDCC-FT5302902	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133286	C
1,743	RDCC-53 -FLOW	RDCC-FT5302903	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133287	C
1,744	RDCC-53 -FLOW	RDCC-FT5302904	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133288	C
1,745	RDCC-53 -FLOW	RDCC-FT5303201	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133289	C
1,746	RDCC-53 -FLOW	RDCC-FT5303301	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133290	C
1,747	RDCC-53 -FLOW	RDCC-FT5303401	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133291	C
1,748	RDCC-53 -FLOW	RDCC-FT5303402	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133292	C
1,749	RDCC-53 -FLOW	RDCC-FT5303403	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133293	C
1,750	RDCC-53 -FLOW	RDCC-FT5303501	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133294	C
1,751	RDCC-53 -FLOW	RDCC-FT5303602	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133295	C
1,752	RDCC-53 -FLOW	RDCC-FT5303604	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133202	C
1,753	RDCC-53 -FLOW	RDCC-FT5303701	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133296	C
1,754	RDCC-53 -FLOW	RDCC-FT5303703	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133199	C
1,755	RDCC-53 -FLOW	RDCC-FT5303705	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133297	C
1,756	RDCC-53 -FLOW	RDCC-FT5303901	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133298	C
1,757	RDCC-53 -FLOW	RDCC-FT5304001	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133299	C
1,758	RDCC-53 -FLOW	RDCC-FT5304002	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133300	C
1,759	RDCC-53 -FLOW	RDCC-FT5304003	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133301	C
1,760	RDCC-53 -FLOW	RDCC-FT5304004	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133302	C
1,761	RDCC-53 -FLOW	RDCC-FT5304101	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133303	C
1,762	RDCC-53 -FLOW	RDCC-FT5304102	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133304	C
1,763	RDCC-53 -FLOW	RDCC-FT5304103	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133305	C
1,764	RDCC-53 -FLOW	RDCC-FT5304104	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133306	C
1,765	RDCC-53 -FLOW	RDCC-FT5304201	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133307	C
1,766	RDCC-53 -FLOW	RDCC-FT5304202	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133308	C
1,767	RDCC-53 -FLOW	RDCC-FT5304203	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133309	C
1,768	RDCC-53 -FLOW	RDCC-FT5304204	INSP. FIELD INST. (ตัดศูนย์กลาง)	PMT	1Y	I												RRC	RRC-IROP	133310	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,769	RDCC-53 -FLOW	RDCC-FT5304401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IRCP	133311	C
1,770	RDCC-53 -FLOW	RDCC-FT5304501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IRCP	133312	C
1,771	RDCC-53 -FLOW	RDCC-FT5304502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IRCP	133203	C
1,772	RDCC-53 -FLOW	RDCC-FT5304602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IRCP	133313	C
1,773	RDCC-53 -FLOW	RDCC-FT5304701	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IRCP	133314	C
1,774	RDCC-53 -FLOW	RDCC-FT5304702	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IRCP	133315	C
1,775	RDCC-53 -FLOW	RDCC-FT5304802	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IRCP	133316	C
1,776	RDCC-53 -FLOW	RDCC-FT5304901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IRCP	133317	C
1,777	RDCC-53 -FLOW	RDCC-FT5304902	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IRCP	133318	C
1,778	RDCC-53 -FLOW	RDCC-FT5304903	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IRCP	133319	C
1,779	RDCC-53 -FLOW	RDCC-FT5305002	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IRCP	133320	C
1,780	RDCC-53 -FLOW	RDCC-FT5305003	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IRCP	133321	C
1,781	RDCC-53 -FLOW	RDCC-FT5305201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IRCP	133322	C
1,782	RDCC-53 -FLOW	RDCC-FT5305202	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IRCP	133323	C
1,783	RDCC-53 -FLOW	RDCC-FT5305203	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133324	C
1,784	RDCC-53 -FLOW	RDCC-FT5305301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133325	C
1,785	RDCC-53 -FLOW	RDCC-FT5305401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133326	C
1,786	RDCC-53 -53K101	RDCC-FT5305501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	133470	C
1,787	RDCC-53 -FLOW	RDCC-FT5305502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133327	C
1,788	RDCC-53 -FLOW	RDCC-FT5305505	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133328	C
1,789	RDCC-53 -FLOW	RDCC-FT5305601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133329	C
1,790	RDCC-53 -FLOW	RDCC-FT5305602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133330	C
1,791	RDCC-53 -FLOW	RDCC-FT5305702	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133331	C
1,792	RDCC-53 -FLOW	RDCC-FT5305801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133332	C
1,793	RDCC-53 -53K101	RDCC-FT5305803	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	133471	C
1,794	RDCC-53 -FLOW	RDCC-FT5306201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133333	C
1,795	RDCC-53 -FLOW	RDCC-FT5306202	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133334	C
1,796	RDCC-53 -FLOW	RDCC-FT5306203	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133335	C
1,797	RDCC-53 -FLOW	RDCC-FT5306301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133336	C
1,798	RDCC-53 -FLOW	RDCC-FT5306302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133337	C
1,799	RDCC-53 -FLOW	RDCC-FT5306303	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133338	C
1,800	RDCC-53 -FLOW	RDCC-FT5306304	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133339	C
1,801	RDCC-53 -FLOW	RDCC-FT5306402	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133340	C
1,802	RDCC-53 -FLOW	RDCC-FT5306501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133341	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,803	RDCC-53 -FLOW	RDCC-FT5306801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133342	C
1,804	RDCC-53 -FLOW	RDCC-FT5306802	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133343	C
1,805	RDCC-53 -FLOW	RDCC-FT5306901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133344	C
1,806	RDCC-53 -FLOW	RDCC-FT5307301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133345	C
1,807	RDCC-53 -FLOW	RDCC-FT5307302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133346	C
1,808	RDCC-53 -FLOW	RDCC-FT5307401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133347	C
1,809	RDCC-53 -FLOW	RDCC-FT5307402	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133348	C
1,810	RDCC-53 -FLOW	RDCC-FT5307403	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133349	C
1,811	RDCC-53 -FLOW	RDCC-FT5307501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133350	C
1,812	RDCC-53 -FLOW	RDCC-FT5307502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133351	C
1,813	RDCC-53 -FLOW	RDCC-FT5307503	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133352	C
1,814	RDCC-53 -FLOW	RDCC-FT5307601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133353	C
1,815	RDCC-53 -FLOW	RDCC-FT5307602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133354	C
1,816	RDCC-53 -FLOW	RDCC-FT5307801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133355	C
1,817	RDCC-53 -FLOW	RDCC-FT5307802	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133356	C
1,818	RDCC-53 -FLOW	RDCC-FT5307803	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133357	C
1,819	RDCC-53 -FLOW	RDCC-FT5307804	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IRCP	133204	C
1,820	RDCC-53 -FLOW	RDCC-FT5307901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133358	C
1,821	RDCC-53 -FLOW	RDCC-FT5307902	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133359	C
1,822	RDCC-53 -FLOW	RDCC-FT5308001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133360	C
1,823	RDCC-53 -FLOW	RDCC-FT5308101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133361	C
1,824	RDCC-53 -FLOW	RDCC-FT5308102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133362	C
1,825	RDCC-53 -FLOW	RDCC-FT5308103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IRCP	133205	C
1,826	RDCC-53 -FLOW	RDCC-FT5308104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133363	C
1,827	RDCC-53 -FLOW	RDCC-FT5308201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133364	C
1,828	RDCC-53 -FLOW	RDCC-FT5308202	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133365	C
1,829	RDCC-53 -FLOW	RDCC-FT5308203	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133366	C
1,830	RDCC-53 -FLOW	RDCC-FT5308301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133367	C
1,831	RDCC-53 -FLOW	RDCC-FT5308401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133368	C
1,832	RDCC-53 -FLOW	RDCC-FT5308501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133369	C
1,833	RDCC-53 -FLOW	RDCC-FT5308601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133370	C
1,834	RDCC-53 -FLOW	RDCC-FT5308602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IRCP	133206	C
1,835	RDCC-53 -FLOW	RDCC-FT5308801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133371	C
1,836	RDCC-53 -FLOW	RDCC-FT5309101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133372	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,837	RDCC-53 -FLOW	RDCC-FT5309301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IRCP	133207	C
1,838	RDCC-53 -FLOW	RDCC-FT5309302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133373	C
1,839	RDCC-53 -FLOW	RDCC-FT5309303	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133374	C
1,840	RDCC-53 -FLOW	RDCC-FT5309304	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133375	C
1,841	RDCC-53 -FLOW	RDCC-FT5309305	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133376	C
1,842	RDCC-53 -FLOW	RDCC-FT5309306	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133377	C
1,843	RDCC-53 -FLOW	RDCC-FT5309307	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133378	C
1,844	RDCC-53 -FLOW	RDCC-FT5309402	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IRCP	133208	C
1,845	RDCC-53 -FLOW	RDCC-FT5309403	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133379	C
1,846	RDCC-53 -FLOW	RDCC-FT5309501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133380	C
1,847	RDCC-53 -FLOW	RDCC-FT5309602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133381	C
1,848	RDCC-53 -FLOW	RDCC-FT5309701	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133382	C
1,849	RDCC-53 -FLOW	RDCC-FT5309703	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133383	C
1,850	RDCC-53 -FLOW	RDCC-FT5309801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133384	C
1,851	RDCC-53 -FLOW	RDCC-FT5309802	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133385	C
1,852	RDCC-53 -FLOW	RDCC-FT5309803	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133386	C
1,853	RDCC-53 -FLOW	RDCC-FT5309901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133387	C
1,854	RDCC-53 -FLOW	RDCC-FT5310001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133388	C
1,855	RDCC-53 -FLOW	RDCC-FT5310501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133389	C
1,856	RDCC-53 -53K002	RDCC-FT5311802	INSP. FIELD INST.RDCC-FT531180	PMT	1Y									I				RRC	RRC-IRCP	255757	C
1,857	RDCC-53 -53E003	RDCC-FT5311817	INSP. FIELD INST.RDCC-FT531181	PMT	1Y										I			RRC	RRC-IRCP	255770	C
1,858	RDCC-53 -53E003	RDCC-FT5311901	INSP. FIELD INST.RDCC-FT531190	PMT	1Y										I			RRC	RRC-IRCP	255771	C
1,859	RDCC-53 -53E003	RDCC-FT5311902	INSP. FIELD INST.RDCC-FT531190	PMT	1Y									I				RRC	RRC-IRCP	255758	C
1,860	RDCC-53 -53K002	RDCC-FT5312007	INSP. FIELD INST.RDCC-FT531200	PMT	1Y										I			RRC	RRC-IRCP	255772	C
1,861	RDCC-53 -53K002	RDCC-FT5312010	INSP. FIELD INST.RDCC-FT531201	PMT	1Y										I			RRC	RRC-IRCP	255773	C
1,862	RDCC-53 -53D006	RDCC-FT5312104	INSP. FIELD INST.RDCC-FT531210	PMT	1Y									I				RRC	RRC-IRCP	255759	C
1,863	RDCC-53 -53D006	RDCC-FT5312105	INSP. FIELD INST.RDCC-FT531210	PMT	1Y										I			RRC	RRC-IRCP	255760	C
1,864	RDCC-53 -53D006	RDCC-FT5312106	INSP. FIELD INST.RDCC-FT531210	PMT	1Y										I			RRC	RRC-IRCP	255761	C
1,865	RDCC-53 -53P140A	RDCC-FT5312201A	INSP. FIELD INST.RDCC-FT531220	PMT	1Y										I			RRC	RRC-IRCP	255762	C
1,866	RDCC-53 -53P140B	RDCC-FT5312201B	INSP. FIELD INST.RDCC-FT531220	PMT	1Y										I			RRC	RRC-IRCP	255763	C
1,867	RDCC-53 -53P140C	RDCC-FT5312201C	INSP. FIELD INST.RDCC-FT531220	PMT	1Y										I			RRC	RRC-IRCP	255764	C
1,868	RDCC-53 -FLOW	RDCC-FT5330101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133390	C
1,869	RDCC-53 -FLOW	RDCC-FT5330102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133391	C
1,870	RDCC-53 -FLOW	RDCC-FT5330103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133392	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,871	RDCC-53 -FLOW	RDCC-FT5330104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133393	C
1,872	RDCC-53 -FLOW	RDCC-FT5330105	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133394	C
1,873	RDCC-53 -FLOW	RDCC-FT5330106	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133395	C
1,874	RDCC-53 -FLOW	RDCC-FT5331101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133396	C
1,875	RDCC-53 -FLOW	RDCC-FT5331102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133397	C
1,876	RDCC-53 -FLOW	RDCC-FT5331103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133398	C
1,877	RDCC-53 -FLOW	RDCC-FT5331201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133399	C
1,878	RDCC-53 -FLOW	RDCC-FT5331202	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133400	C
1,879	RDCC-53 -FLOW	RDCC-FT5331203	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133401	C
1,880	RDCC-53 -FLOW	RDCC-FT5332101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133402	C
1,881	RDCC-53 -FLOW	RDCC-FT5332103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133403	C
1,882	RDCC-53 -FLOW	RDCC-FT5332104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133404	C
1,883	RDCC-53 -FLOW	RDCC-FT5332201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133405	C
1,884	RDCC-53 -FLOW	RDCC-FT5333101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133406	C
1,885	RDCC-53 -FLOW	RDCC-FT5333401	INSP. FIELD INST.RDCC-FT533340	PMT	1Y										I			RRC	RRC-IRCP	255765	C
1,886	RDCC-53 -FLOW	RDCC-FT5334101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133407	C
1,887	RDCC-53 -FLOW	RDCC-FT5334102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133408	C
1,888	RDCC-53 -FLOW	RDCC-FT5335101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133409	C
1,889	RDCC-53 -FLOW	RDCC-FT5335301	INSP. FIELD INST.RDCC-FT533530	PMT	1Y										I			RRC	RRC-IRCP	255766	C
1,890	RDCC-53 -FLOW	RDCC-FT5336101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133410	C
1,891	RDCC-53 -FLOW	RDCC-FT5336102	INSP. FIELD INST.RDCC-FT533610	PMT	1Y										I			RRC	RRC-IRCP	255767	C
1,892	RDCC-53 -FLOW	RDCC-FT5336501	INSP. FIELD INST.RDCC-FT533650	PMT	1Y										I			RRC	RRC-IRCP	255768	C
1,893	RDCC-53 -FLOW	RDCC-FT5337101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133411	C
1,894	RDCC-53 -FLOW	RDCC-FT5337401	INSP. FIELD INST.RDCC-FT533740	PMT	1Y										I			RRC	RRC-IRCP	255769	C
1,895	RDCC-53 -FLOW	RDCC-FT5340201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IRCP	133412	C
1,896	RDCC-53 -FLOW	RDCC-FT5352403	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	133461	C
1,897	RDCC-53 -FLOW	RDCC-FT5352470	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	133462	C
1,898	RDCC-53 -FLOW	RDCC-FT5352501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	133463	C
1,899	RDCC-53 -FLOW	RDCC-FT5352502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	133464	C
1,900	RDCC-53 -FLOW	RDCC-FT5352505	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	133465	C
1,901	RDCC-53 -FLOW	RDCC-FT5352840A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	133466	C
1,902	RDCC-53 -FLOW	RDCC-FT5352840B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	133467	C
1,903	RDCC-53 -FLOW	RDCC-FT5352841	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	133468	C
1,904	RDCC-53 -FLOW	RDCC-FT5352842	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IRCP	133469	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,905	RDCC-56 -FLOW	RDCC-FT5600101	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133413	C
1,906	RDCC-56 -FLOW	RDCC-FT5600102	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133414	C
1,907	RDCC-56 -FLOW	RDCC-FT5600201	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133415	C
1,908	RDCC-56 -FLOW	RDCC-FT5600202	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133416	C
1,909	RDCC-56 -FLOW	RDCC-FT5600203	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133417	C
1,910	RDCC-56 -FLOW	RDCC-FT5600301	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133418	C
1,911	RDCC-56 -FLOW	RDCC-FT5600302	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133419	C
1,912	RDCC-56 -FLOW	RDCC-FT5600303	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133420	C
1,913	RDCC-56 -FLOW	RDCC-FT5600401	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133421	C
1,914	RDCC-56 -FLOW	RDCC-FT5600402	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133422	C
1,915	RDCC-56 -FLOW	RDCC-FT5600501	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133423	C
1,916	RDCC-56 -FLOW	RDCC-FT5600502	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133424	C
1,917	RDCC-56 -FLOW	RDCC-FT5600503	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133425	C
1,918	RDCC-56 -FLOW	RDCC-FT5600504	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133426	C
1,919	RDCC-56 -FLOW	RDCC-FT5600601	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133427	C
1,920	RDCC-56 -FLOW	RDCC-FT5600602	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133428	C
1,921	RDCC-56 -FLOW	RDCC-FT5600801	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133429	C
1,922	RDCC-56 -FLOW	RDCC-FT5600803	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133430	C
1,923	RDCC-56 -FLOW	RDCC-FT5600804	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133431	C
1,924	RDCC-56 -FLOW	RDCC-FT5600805	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133432	C
1,925	RDCC-56 -FLOW	RDCC-FT5600806	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133433	C
1,926	RDCC-56 -FLOW	RDCC-FT5600807	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC-IRCP	133434	C
1,927	RDCC-56 -FLOW	RDCC-FT5600807	FT5600807-FULLFUN TEST FLOW TR	PMT	5Y											F		RRC	RRC-IRCP	260399	C
1,928	RDCC-56 -FLOW	RDCC-FT5600808	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC-IRCP	133435	C
1,929	RDCC-56 -FLOW	RDCC-FT5600808	FT5600808-FULLFUN TEST FLOW TR	PMT	5Y											F		RRC	RRC-IRCP	260398	C
1,930	RDCC-56 -FLOW	RDCC-FT5600901	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133436	C
1,931	RDCC-56 -FLOW	RDCC-FT5601001	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133437	C
1,932	RDCC-56 -FLOW	RDCC-FT5601002	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133438	C
1,933	RDCC-56 -FLOW	RDCC-FT5601003	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133439	C
1,934	RDCC-56 -FLOW	RDCC-FT5601201	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133440	C
1,935	RDCC-56 -FLOW	RDCC-FT5601202	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133441	C
1,936	RDCC-56 -FLOW	RDCC-FT5601301	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133442	C
1,937	RDCC-56 -FLOW	RDCC-FT5601401	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133443	C
1,938	RDCC-56 -FLOW	RDCC-FT5601402	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133444	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,939	RDCC-56 -FLOW	RDCC-FT5601501	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133445	C
1,940	RDCC-56 -FLOW	RDCC-FT5601502	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133446	C
1,941	RDCC-56 -FLOW	RDCC-FT5601601	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133447	C
1,942	RDCC-56 -FLOW	RDCC-FT5601701	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC-IRCP	133448	C
1,943	RDCC-56 -FLOW	RDCC-FT5601702	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y					I								RRC	RRC-IRCP	133449	C
1,944	RDCC-56 -FLOW	RDCC-FT5601703	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y					I								RRC	RRC-IRCP	133450	C
1,945	RDCC-56 -FLOW	RDCC-FT5631101	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y					I								RRC	RRC-IRCP	133451	C
1,946	RDCC-56 -FLOW	RDCC-FT5631102	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y					I								RRC	RRC-IRCP	133452	C
1,947	RDCC-56 -FLOW	RDCC-FT5631103	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y					I								RRC	RRC-IRCP	133453	C
1,948	RDCC-56 -FLOW	RDCC-FT5632101	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y					I								RRC	RRC-IRCP	133454	C
1,949	RDCC-56 -FLOW	RDCC-FT5632102	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y					I								RRC	RRC-IRCP	133455	C
1,950	RDCC-56 -FLOW	RDCC-FT5633101	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y					I								RRC	RRC-IRCP	133456	C
1,951	RDCC-56 -FLOW	RDCC-FT5634101	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y					I								RRC	RRC-IRCP	133457	C
1,952	RDCC-56 -FLOW	RDCC-FT5635101	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y					I								RRC	RRC-IRCP	133458	C
1,953	RDCC-56 -FLOW	RDCC-FT5636101	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y					I								RRC	RRC-IRCP	133459	C
1,954	RDCC-56 -FLOW	RDCC-FT5637101	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y					I								RRC	RRC-IRCP	133460	C
1,955	RDCC-53 -CV	RDCC-FV5300602	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134278	C
1,956	RDCC-53 -CV	RDCC-FV5300701	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134279	C
1,957	RDCC-53 -CV	RDCC-FV5300712	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134280	C
1,958	RDCC-53 -CV	RDCC-FV5300814	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134281	C
1,959	RDCC-53 -CV	RDCC-FV5300915	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134282	C
1,960	RDCC-53 -CV	RDCC-FV5301002	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134283	C
1,961	RDCC-53 -CV	RDCC-FV5301008	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134284	C
1,962	RDCC-53 -CV	RDCC-FV5301101	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134285	C
1,963	RDCC-53 -CV	RDCC-FV5301104	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134286	C
1,964	RDCC-53 -CV	RDCC-FV5301106	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134287	C
1,965	RDCC-53 -CV	RDCC-FV5302502	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134288	C
1,966	RDCC-53 -CV	RDCC-FV5302601	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134289	C
1,967	RDCC-53 -CV	RDCC-FV5302702	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134290	C
1,968	RDCC-53 -CV	RDCC-FV5302703	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134291	C
1,969	RDCC-53 -CV	RDCC-FV5302704	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134292	C
1,970	RDCC-53 -CV	RDCC-FV5302705	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134293	C
1,971	RDCC-53 -CV	RDCC-FV5302752	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134294	C
1,972	RDCC-53 -CV	RDCC-FV5302801	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134295	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,973	RDCC-53 -CV	RDCC-FV5302901	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134296	C
1,974	RDCC-53 -CV	RDCC-FV5302902	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134297	C
1,975	RDCC-53 -CV	RDCC-FV5302903	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134298	C
1,976	RDCC-53 -CV	RDCC-FV5302904	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134299	C
1,977	RDCC-53 -CV	RDCC-FV5303201	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134300	C
1,978	RDCC-53 -CV	RDCC-FV5303301	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134301	C
1,979	RDCC-53 -CV	RDCC-FV5303401	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134302	C
1,980	RDCC-53 -CV	RDCC-FV5303403	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134303	C
1,981	RDCC-53 -CV	RDCC-FV5303501	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134304	C
1,982	RDCC-53 -CV	RDCC-FV5303604	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134305	C
1,983	RDCC-53 -CV	RDCC-FV5303703	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134306	C
1,984	RDCC-53 -CV	RDCC-FV5303705	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134307	C
1,985	RDCC-53 -CV	RDCC-FV5303901	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134308	C
1,986	RDCC-53 -CV	RDCC-FV5304003	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134309	C
1,987	RDCC-53 -CV	RDCC-FV5304004	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134310	C
1,988	RDCC-53 -CV	RDCC-FV5304101	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134311	C
1,989	RDCC-53 -CV	RDCC-FV5304103	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134312	C
1,990	RDCC-53 -CV	RDCC-FV5304201	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134313	C
1,991	RDCC-53 -CV	RDCC-FV5304203	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134314	C
1,992	RDCC-53 -CV	RDCC-FV5304401	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134315	C
1,993	RDCC-53 -CV	RDCC-FV5304501	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134316	C
1,994	RDCC-53 -CV	RDCC-FV5304602	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134317	C
1,995	RDCC-53 -CV	RDCC-FV5304701	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134318	C
1,996	RDCC-53 -CV	RDCC-FV5304702	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134319	C
1,997	RDCC-53 -CV	RDCC-FV5304802	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134320	C
1,998	RDCC-53 -CV	RDCC-FV5304902	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134321	C
1,999	RDCC-53 -CV	RDCC-FV5304903	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134322	C
2,000	RDCC-53 -CV	RDCC-FV5305002	INSPECT CONTROL VALVE NO. FV53	PMT	1Y									I				RRC	RRC-IRCP	134323	C
2,001	RDCC-53 -CV	RDCC-FV5305003	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134324	C
2,002	RDCC-53 -CV	RDCC-FV5305201	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134325	C
2,003	RDCC-53 -CV	RDCC-FV5305203	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134326	C
2,004	RDCC-53 -CV	RDCC-FV5305301	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134327	C
2,005	RDCC-53 -CV	RDCC-FV5305503	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134343	C
2,006	RDCC-53 -CV	RDCC-FV5305601	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134328	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,007	RDCC-53 -CV	RDCC-FV5305702	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134329	C
2,008	RDCC-53 -CV	RDCC-FV5305803	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134346	C
2,009	RDCC-53 -CV	RDCC-FV5306203	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134330	C
2,010	RDCC-53 -CV	RDCC-FV5306301	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134331	C
2,011	RDCC-53 -CV	RDCC-FV5306302	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134332	C
2,012	RDCC-53 -CV	RDCC-FV5306303	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134333	C
2,013	RDCC-53 -CV	RDCC-FV5306402	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134334	C
2,014	RDCC-53 -CV	RDCC-FV5306501	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134335	C
2,015	RDCC-53 -CV	RDCC-FV5306801	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134336	C
2,016	RDCC-53 -CV	RDCC-FV5306802	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134337	C
2,017	RDCC-53 -CV	RDCC-FV5306901	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134338	C
2,018	RDCC-53 -CV	RDCC-FV5307301	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134339	C
2,019	RDCC-53 -CV	RDCC-FV5307302	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134340	C
2,020	RDCC-53 -CV	RDCC-FV5307401	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134341	C
2,021	RDCC-53 -CV	RDCC-FV5307402	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134342	C
2,022	RDCC-53 -CV	RDCC-FV5307403	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134344	C
2,023	RDCC-53 -CV	RDCC-FV5307501	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134361	C
2,024	RDCC-53 -CV	RDCC-FV5307502	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134345	C
2,025	RDCC-53 -CV	RDCC-FV5307503	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134347	C
2,026	RDCC-53 -CV	RDCC-FV5307601	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134348	C
2,027	RDCC-53 -CV	RDCC-FV5307602	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134349	C
2,028	RDCC-53 -CV	RDCC-FV5307801	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134350	C
2,029	RDCC-53 -CV	RDCC-FV5307802	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134351	C
2,030	RDCC-53 -CV	RDCC-FV5307803	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134352	C
2,031	RDCC-53 -CV	RDCC-FV5307901	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134353	C
2,032	RDCC-53 -CV	RDCC-FV5307902	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134354	C
2,033	RDCC-53 -CV	RDCC-FV5308001	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134355	C
2,034	RDCC-53 -CV	RDCC-FV5308101	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134356	C
2,035	RDCC-53 -CV	RDCC-FV5308102	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134357	C
2,036	RDCC-53 -CV	RDCC-FV5308104	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134358	C
2,037	RDCC-53 -CV	RDCC-FV5308201	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134359	C
2,038	RDCC-53 -CV	RDCC-FV5308202	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134360	C
2,039	RDCC-53 -CV	RDCC-FV5308203	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134362	C
2,040	RDCC-53 -CV	RDCC-FV5308301	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134363	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,041	RDCC-53 -CV	RDCC-FV5308401	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134364	C
2,042	RDCC-53 -CV	RDCC-FV5308501	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134365	C
2,043	RDCC-53 -CV	RDCC-FV5308601	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134366	C
2,044	RDCC-53 -CV	RDCC-FV5308801	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134367	C
2,045	RDCC-53 -CV	RDCC-FV5309101	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134368	C
2,046	RDCC-53 -CV	RDCC-FV5309302	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134369	C
2,047	RDCC-53 -CV	RDCC-FV5309303	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134370	C
2,048	RDCC-53 -CV	RDCC-FV5309305	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134371	C
2,049	RDCC-53 -CV	RDCC-FV5309306	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134372	C
2,050	RDCC-53 -CV	RDCC-FV5309307	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134373	C
2,051	RDCC-53 -CV	RDCC-FV5309402	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134374	C
2,052	RDCC-53 -CV	RDCC-FV5309501	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134375	C
2,053	RDCC-53 -CV	RDCC-FV5309701	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134376	C
2,054	RDCC-53 -CV	RDCC-FV5309801	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134377	C
2,055	RDCC-53 -CV	RDCC-FV5309802	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134378	C
2,056	RDCC-53 -CV	RDCC-FV5309803	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134379	C
2,057	RDCC-53 -CV	RDCC-FV5309901	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134380	C
2,058	RDCC-53 -53E003	RDCC-FV5311817	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y											I		RRC	RRC-IRCP	255802	C
2,059	RDCC-53 -53E003	RDCC-FV5311901	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y											I		RRC	RRC-IRCP	255803	C
2,060	RDCC-53 -53K002	RDCC-FV5312007	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y											I		RRC	RRC-IRCP	255822	C
2,061	RDCC-53 -53K002	RDCC-FV5312010	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y											I		RRC	RRC-IRCP	255804	C
2,062	RDCC-53 -53D006	RDCC-FV5312105	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y											I		RRC	RRC-IRCP	255805	C
2,063	RDCC-53 -53D006	RDCC-FV5312106	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y											I		RRC	RRC-IRCP	255806	C
2,064	RDCC-53 -CV	RDCC-FV5340201	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134381	C
2,065	RDCC-53 -CV	RDCC-FV5352501	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134382	C
2,066	RDCC-53 -CV	RDCC-FV5352505	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134383	C
2,067	RDCC-53 -CV	RDCC-FV5352840	INSPECT CONTROL VALVE NO. FV53	PMT	1Y										I			RRC	RRC-IRCP	134384	C
2,068	RDCC-56 -CV	RDCC-FV5600102	INSPECT CONTROL VALVE NO. FV56	PMT	1Y										I			RRC	RRC-IRCP	134385	C
2,069	RDCC-56 -CV	RDCC-FV5600201	INSPECT CONTROL VALVE NO. FV56	PMT	1Y										I			RRC	RRC-IRCP	134386	C
2,070	RDCC-56 -CV	RDCC-FV5600202	INSPECT CONTROL VALVE NO. FV56	PMT	1Y										I			RRC	RRC-IRCP	134396	C
2,071	RDCC-56 -CV	RDCC-FV5600401	INSPECT CONTROL VALVE NO. FV56	PMT	1Y										I			RRC	RRC-IRCP	134387	C
2,072	RDCC-56 -CV	RDCC-FV5600501	INSPECT CONTROL VALVE NO. FV56	PMT	1Y										I			RRC	RRC-IRCP	134388	C
2,073	RDCC-56 -CV	RDCC-FV5600502	INSPECT CONTROL VALVE NO. FV56	PMT	1Y										I			RRC	RRC-IRCP	134389	C
2,074	RDCC-56 -CV	RDCC-FV5600504	INSPECT CONTROL VALVE NO. FV56	PMT	1Y										I			RRC	RRC-IRCP	134390	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,075	RDCC-56 -CV	RDCC-FV5600601	INSPECT CONTROL VALVE NO. FV56	PMT	1Y											I		RRC	RRC-IRCP	134391	C
2,076	RDCC-56 -CV	RDCC-FV5600602	INSPECT CONTROL VALVE NO. FV56	PMT	1Y											I		RRC	RRC-IRCP	134392	C
2,077	RDCC-56 -CV	RDCC-FV5600801	INSPECT CONTROL VALVE NO. FV56	PMT	1Y											I		RRC	RRC-IRCP	134393	C
2,078	RDCC-56 -CV	RDCC-FV5601001	INSPECT CONTROL VALVE NO. FV56	PMT	1Y											I		RRC	RRC-IRCP	134394	C
2,079	RDCC-56 -CV	RDCC-FV5601401	INSPECT CONTROL VALVE NO. FV56	PMT	1Y											I		RRC	RRC-IRCP	134395	C
2,080	RDCC-53 -QMI_GD	RDCC-GDT5300201	VERIFY GAS_DETECTOR GDT5300201	PMT	4M					V						V		CAN	CAN-QUHV	204681	C
2,081	RDCC-53 -QMI_GD	RDCC-GDT5300202	VERIFY GAS_DETECTOR GDT5300202	PMT	4M					V						V		CAN	CAN-QUHV	204682	C
2,082	RDCC-53 -QMI_GD	RDCC-GDT5300203	VERIFY GAS_DETECTOR GDT5300203	PMT	4M					V						V		CAN	CAN-QUHV	204683	C
2,083	RDCC-53 -QMI_GD	RDCC-GDT5300204	VERIFY GAS_DETECTOR GDT5300204	PMT	4M					V						V		CAN	CAN-QUHV	204684	C
2,084	RDCC-53 -QMI_GD	RDCC-GDT5300205	VERIFY GAS_DETECTOR GDT5300205	PMT	4M					V						V		CAN	CAN-QUHV	204685	C
2,085	RDCC-53 -QMI_GD	RDCC-GDT5300206	VERIFY GAS_DETECTOR GDT5300206	PMT	4M					V						V		CAN	CAN-QUHV	204686	C
2,086	RDCC-53 -QMI_GD	RDCC-GDT5300207	VERIFY GAS_DETECTOR GDT5300207	PMT	4M					V						V		CAN	CAN-QUHV	204687	C
2,087	RDCC-53 -QMI_GD	RDCC-GDT5300208	VERIFY GAS_DETECTOR GDT5300208	PMT	4M					V						V		CAN	CAN-QUHV	204688	C
2,088	RDCC-53 -QMI_GD	RDCC-GDT5300209	VERIFY GAS_DETECTOR GDT5300209	PMT	4M					V						V		CAN	CAN-QUHV	204689	C
2,089	RDCC-53 -QMI_GD	RDCC-GDT5300210	VERIFY GAS_DETECTOR GDT5300210	PMT	4M					V						V		CAN	CAN-QUHV	204690	C
2,090	RDCC-53 -QMI_GD	RDCC-GDT5300211	VERIFY GAS_DETECTOR GDT5300211	PMT	4M					V						V		CAN	CAN-QUHV	204691	C
2,091	RDCC-53 -QMI_GD	RDCC-GDT5300212	VERIFY GAS_DETECTOR GDT5300212	PMT	4M					V						V		CAN	CAN-QUHV	204692	C
2,092	RDCC-53 -QMI_GD	RDCC-GDT5300213	VERIFY GAS_DETECTOR GDT5300213	PMT	4M					V						V		CAN	CAN-QUHV	204693	C
2,093	RDCC-53 -QMI_GD	RDCC-GDT5300214	VERIFY GAS_DETECTOR GDT5300214	PMT	4M					V						V		CAN	CAN-QUHV	204694	C
2,094	RDCC-53 -QMI_GD	RDCC-GDT5300215	VERIFY GAS_DETECTOR GDT5300215	PMT	4M					V						V		CAN	CAN-QUHV	204695	C
2,095	RDCC-53 -QMI_GD	RDCC-GDT5300216	VERIFY GAS_DETECTOR GDT5300216	PMT	4M					V						V		CAN	CAN-QUHV	204696	C
2,096	RDCC-53 -QMI_GD	RDCC-GDT5300217	VERIFY GAS_DETECTOR GDT5300217	PMT	4M					V						V		CAN	CAN-QUHV	204697	C
2,097	RDCC-53 -QMI_GD	RDCC-GDT5300218	VERIFY GAS_DETECTOR GDT5300218	PMT	4M					V						V		CAN	CAN-QUHV	204698	C
2,098	RDCC-53 -QMI_GD	RDCC-GDT5300219	VERIFY GAS_DETECTOR GDT5300219	PMT	4M					V						V		CAN	CAN-QUHV	204699	C
2,099	RDCC-53 -QMI_GD	RDCC-GDT5300220	VERIFY GAS_DETECTOR GDT5300220	PMT	4M					V						V		CAN	CAN-QUHV	204700	C
2,100	RDCC-53 -QMI_GD	RDCC-GDT5300221	VERIFY GAS_DETECTOR GDT5300221	PMT	4M					V						V		CAN	CAN-QUHV	204701	C
2,101	RDCC-53 -QMI_GD	RDCC-GDT5300222	VERIFY GAS_DETECTOR GDT5300222	PMT	4M					V						V		CAN	CAN-QUHV	204702	C
2,102	RDCC-53 -QMI_GD	RDCC-GDT5300223	VERIFY GAS_DETECTOR GDT5300223	PMT	4M					V						V		CAN	CAN-QUHV	204703	C
2,103	RDCC-53 -QMI_GD	RDCC-GDT5300224	VERIFY GAS_DETECTOR GDT5300224	PMT	4M					V						V		CAN	CAN-QUHV	204704	C
2,104	RDCC-53 -QMI_GD	RDCC-GDT5300225	VERIFY GAS_DETECTOR GDT5300225	PMT	4M					V						V		CAN	CAN-QUHV	204705	C
2,105	RDCC-53 -QMI_GD	RDCC-GDT5300226	VERIFY GAS_DETECTOR GDT5300226	PMT	4M					V						V		CAN	CAN-QUHV	204706	C
2,106	RDCC-53 -QMI_GD	RDCC-GDT5300228	VERIFY GAS_DETECTOR GDT5300228	PMT	4M					V						V		CAN	CAN-QUHV	204707	C
2,107	RDCC-53 -QMI_GD	RDCC-GDT5300229	VERIFY GAS_DETECTOR GDT5300229	PMT	4M					V						V		CAN	CAN-QUHV	204708	C
2,108	RDCC-53 -QMI_GD	RDCC-GDT5300230	VERIFY GAS_DETECTOR GDT5300230	PMT	4M					V						V		CAN	CAN-QUHV	204709	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,109	RDCC-53 -QMI_GD	RDCC-GDT5300231	VERIFY GAS_DETECTOR GDT5300231	PMT	4M			V				V				V		CAN	CAN-QUHV	204710	C
2,110	RDCC-53 -QMI_GD	RDCC-GDT5300232	VERIFY GAS_DETECTOR GDT5300232	PMT	4M			V				V				V		CAN	CAN-QUHV	204711	C
2,111	RDCC-53 -QMI_GD	RDCC-GDT5300233	VERIFY GAS_DETECTOR GDT5300233	PMT	4M			V				V				V		CAN	CAN-QUHV	204712	C
2,112	RDCC-53 -QMI_GD	RDCC-GDT5300234	VERIFY GAS_DETECTOR GDT5300234	PMT	4M			V				V				V		CAN	CAN-QUHV	204713	C
2,113	RDCC-53 -QMI_GD	RDCC-GDT5300236	VERIFY GAS_DETECTOR GDT5300236	PMT	4M			V				V				V		CAN	CAN-QUHV	204714	C
2,114	RDCC-53 -QMI_GD	RDCC-GDT5300237	VERIFY GAS_DETECTOR GDT5300237	PMT	4M			V				V				V		CAN	CAN-QUHV	204715	C
2,115	RDCC-53 -QMI_GD	RDCC-GDT5300238	VERIFY GAS_DETECTOR GDT5300238	PMT	4M			V				V				V		CAN	CAN-QUHV	204716	C
2,116	RDCC-53 -QMI_GD	RDCC-GDT5300239	VERIFY GAS_DETECTOR GDT5300239	PMT	4M			V				V				V		CAN	CAN-QUHV	204717	C
2,117	RDCC-53 -QMI_GD	RDCC-GDT5300240	VERIFY GAS_DETECTOR GDT5300240	PMT	4M			V				V				V		CAN	CAN-QUHV	204718	C
2,118	RDCC-53 -QMI_GD	RDCC-GDT5300243	VERIFY GAS_DETECTOR GDT5300243	PMT	4M			V				V				V		CAN	CAN-QUHV	204719	C
2,119	RDCC-53 -QMI_GD	RDCC-GDT5300244	VERIFY GAS_DETECTOR GDT5300244	PMT	4M			V				V				V		CAN	CAN-QUHV	204720	C
2,120	RDCC-53 -QMI_GD	RDCC-GDT5300245	VERIFY GAS_DETECTOR GDT5300245	PMT	4M			V				V				V		CAN	CAN-QUHV	204721	C
2,121	RDCC-53 -QMI_GD	RDCC-GDT5300246	VERIFY GAS_DETECTOR GDT5300246	PMT	4M			V				V				V		CAN	CAN-QUHV	204722	C
2,122	RDCC-53 -QMI_GD	RDCC-GDT5300247	VERIFY GAS_DETECTOR GDT5300247	PMT	4M			V				V				V		CAN	CAN-QUHV	204723	C
2,123	RDCC-53 -QMI_GD	RDCC-GDT5300248	VERIFY GAS_DETECTOR GDT5300248	PMT	4M			V				V				V		CAN	CAN-QUHV	204724	C
2,124	RDCC-53 -QMI_GD	RDCC-GDT5300249	VERIFY GAS_DETECTOR GDT5300249	PMT	4M			V				V				V		CAN	CAN-QUHV	204725	C
2,125	RDCC-53 -QMI_GD	RDCC-GDT5300250	VERIFY GAS_DETECTOR GDT5300250	PMT	4M			V				V				V		CAN	CAN-QUHV	204726	C
2,126	RDCC-53 -QMI_GD	RDCC-GDT5300251	VERIFY GAS_DETECTOR GDT5300251	PMT	4M			V				V				V		CAN	CAN-QUHV	204727	C
2,127	RDCC-53 -QMI_GD	RDCC-GDT5300252	VERIFY GAS_DETECTOR GDT5300252	PMT	4M			V				V				V		CAN	CAN-QUHV	204728	C
2,128	RDCC-53 -QMI_GD	RDCC-GDT5300253	VERIFY GAS_DETECTOR GDT5300253	PMT	4M			V				V				V		CAN	CAN-QUHV	204729	C
2,129	RDCC-53 -QMI_GD	RDCC-GDT5300254	VERIFY GAS_DETECTOR GDT5300254	PMT	4M			V				V				V		CAN	CAN-QUHV	204730	C
2,130	RDCC-53 -QMI_GD	RDCC-GDT5300255	VERIFY GAS_DETECTOR GDT5300255	PMT	4M			V				V				V		CAN	CAN-QUHV	204731	C
2,131	RDCC-53 -QMI_GD	RDCC-GDT5300256	VERIFY GAS_DETECTOR GDT5300256	PMT	4M			V				V				V		CAN	CAN-QUHV	204732	C
2,132	RDCC-53 -QMI_GD	RDCC-GDT5300257	VERIFY GAS_DETECTOR GDT5300257	PMT	4M			V				V				V		CAN	CAN-QUHV	204733	C
2,133	RDCC-53 -QMI_GD	RDCC-GDT5300258	VERIFY GAS_DETECTOR GDT5300258	PMT	4M			V				V				V		CAN	CAN-QUHV	204734	C
2,134	RDCC-53 -QMI_GD	RDCC-GDT5300259	VERIFY GAS_DETECTOR GDT5300259	PMT	4M			V				V				V		CAN	CAN-QUHV	204735	C
2,135	RDCC-53 -QMI_GD	RDCC-GDT5300260	VERIFY GAS_DETECTOR GDT5300260	PMT	4M			V				V				V		CAN	CAN-QUHV	204736	C
2,136	RDCC-53 -QMI_GD	RDCC-GDT5300261	VERIFY GAS_DETECTOR GDT5300261	PMT	4M			V				V				V		CAN	CAN-QUHV	204737	C
2,137	RDCC-53 -QMI_GD	RDCC-GDT5300262	VERIFY GAS_DETECTOR GDT5300262	PMT	4M			V				V				V		CAN	CAN-QUHV	204738	C
2,138	RDCC-53 -QMI_GD	RDCC-GDT5300263	VERIFY GAS_DETECTOR GDT5300263	PMT	4M			V				V				V		CAN	CAN-QUHV	204739	C
2,139	RDCC-53 -QMI_GD	RDCC-GDT5300264	VERIFY GAS_DETECTOR GDT5300264	PMT	4M			V				V				V		CAN	CAN-QUHV	204740	C
2,140	RDCC-53 -QMI_GD	RDCC-GDT5300265	VERIFY GAS_DETECTOR GDT5300265	PMT	4M			V				V				V		CAN	CAN-QUHV	204741	C
2,141	RDCC-53 -QMI_GD	RDCC-GDT5300266	VERIFY GAS_DETECTOR GDT5300266	PMT	4M			V				V				V		CAN	CAN-QUHV	204742	C
2,142	RDCC-53 -QMI_GD	RDCC-GDT5300267	VERIFY GAS_DETECTOR GDT5300267	PMT	4M			V				V				V		CAN	CAN-QUHV	204743	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,143	RDCC-53 -QMI_GD	RDCC-GDT5300268	VERIFY GAS_DETECTOR GDT5300268	PMT	4M			V				V				V		CAN	CAN-QUHV	204744	C
2,144	RDCC-53 -QMI_GD	RDCC-GDT5300269	VERIFY GAS_DETECTOR GDT5300269	PMT	4M			V				V				V		CAN	CAN-QUHV	204745	C
2,145	RDCC-53 -QMI_GD	RDCC-GDT5300270	VERIFY GAS_DETECTOR GDT5300270	PMT	4M			V				V				V		CAN	CAN-QUHV	204746	C
2,146	RDCC-53 -QMI_GD	RDCC-GDT5300271	VERIFY GAS_DETECTOR GDT5300271	PMT	4M			V				V				V		CAN	CAN-QUHV	204747	C
2,147	RDCC-53 -QMI_GD	RDCC-GDT5300272	VERIFY GAS_DETECTOR GDT5300272	PMT	4M			V				V				V		CAN	CAN-QUHV	204748	C
2,148	RDCC-53 -QMI_GD	RDCC-GDT5300273	VERIFY GAS_DETECTOR GDT5300273	PMT	4M			V				V				V		CAN	CAN-QUHV	204749	C
2,149	RDCC-53 -QMI_GD	RDCC-GDT5300274	VERIFY GAS_DETECTOR GDT5300274	PMT	4M			V				V				V		CAN	CAN-QUHV	204750	C
2,150	RDCC-53 -QMI_GD	RDCC-GDT5300275	VERIFY GAS_DETECTOR GDT5300275	PMT	4M			V				V				V		CAN	CAN-QUHV	204751	C
2,151	RDCC-53 -QMI_GD	RDCC-GDT5300276	VERIFY GAS_DETECTOR GDT5300276	PMT	4M			V				V				V		CAN	CAN-QUHV	204752	C
2,152	RDCC-53 -QMI_GD	RDCC-GDT5300277	VERIFY GAS_DETECTOR GDT5300277	PMT	4M			V				V				V		CAN	CAN-QUHV	204753	C
2,153	RDCC-53 -QMI_GD	RDCC-GDT5300278	VERIFY GAS_DETECTOR GDT5300278	PMT	4M			V				V				V		CAN	CAN-QUHV	204754	C
2,154	RDCC-53 -QMI_GD	RDCC-GDT5300279	VERIFY GAS_DETECTOR GDT5300279	PMT	4M			V				V				V		CAN	CAN-QUHV	204755	C
2,155	RDCC-53 -QMI_GD	RDCC-GDT5300280	VERIFY GAS_DETECTOR GDT5300280	PMT	4M			V				V				V		CAN	CAN-QUHV	204756	C
2,156	RDCC-53 -QMI_GD	RDCC-GDT5300281	VERIFY GAS_DETECTOR GDT5300281	PMT	4M			V				V				V		CAN	CAN-QUHV	204757	C
2,157	RDCC-53 -QMI_GD	RDCC-GDT5300282	VERIFY GAS_DETECTOR GDT5300282	PMT	4M			V				V				V		CAN	CAN-QUHV	204758	C
2,158	RDCC-53 -QMI_GD	RDCC-GDT5300283	VERIFY GAS_DETECTOR GDT5300283	PMT	4M			V				V				V		CAN	CAN-QUHV	204759	C
2,159	RDCC-53 -QMI_GD	RDCC-GDT5300284	VERIFY GAS_DETECTOR GDT5300284	PMT	4M			V				V				V		CAN	CAN-QUHV	204760	C
2,160	RDCC-53 -QMI_GD	RDCC-GDT5300285	VERIFY GAS_DETECTOR GDT5300285	PMT	4M			V				V				V		CAN	CAN-QUHV	204761	C
2,161	RDCC-53 -QMI_GD	RDCC-GDT5300286	3RIFY GAS_DETECTOR GDT5300286	PMT	4M			V				V				V		CAN	CAN-QUHV	204762	C
2,162	RDCC-53 -QMI_GD	RDCC-GDT5300287	3RIFY GAS_DETECTOR GDT5300287	PMT	4M			V				V				V		CAN	CAN-QUHV	204763	C
2,163	RDCC-53 -QMI_GD	RDCC-GDT5300288	VERIFY GAS_DETECTOR GDT5300288	PMT	4M			V				V				V		CAN	CAN-QUHV	204764	C
2,164	RDCC-53 -QMI_GD	RDCC-GDT5300289	VERIFY GAS_DETECTOR GDT5300289	PMT	4M			V				V				V		CAN	CAN-QUHV	204765	C
2,165	RDCC-53 -QMI_GD	RDCC-GDT5300290	VERIFY GAS_DETECTOR GDT5300290	PMT	4M			V				V				V		CAN	CAN-QUHV	204766	C
2,166	RDCC-53 -QMI_GD	RDCC-GDT5300291	VERIFY GAS_DETECTOR GDT5300291	PMT	4M			V				V				V		CAN	CAN-QUHV	204767	C
2,167	RDCC-53 -QMI_GD	RDCC-GDT5300292	VERIFY GAS_DETECTOR GDT5300292	PMT	4M			V				V				V		CAN	CAN-QUHV	204768	C
2,168	RDCC-53 -QMI_GD	RDCC-GDT5300293	VERIFY GAS_DETECTOR GDT5300293	PMT	4M			V				V				V		CAN	CAN-QUHV	204769	C
2,169	RDCC-53 -QMI_GD	RDCC-GDT5300294	VERIFY GAS_DETECTOR GDT5300294	PMT	4M			V				V				V		CAN	CAN-QUHV	204770	C
2,170	RDCC-53 -QMI_GD	RDCC-GDT5300295	VERIFY GAS_DETECTOR GDT5300295	PMT	4M			V				V				V		CAN	CAN-QUHV	204771	C
2,171	RDCC-53 -QMI_GD	RDCC-GDT5300296	3ERIFY GAS_DETECTOR GDT5300296	PMT	4M			V				V				V		CAN	CAN-QUHV	204772	C
2,172	RDCC-53 -QMI_GD	RDCC-GDT5300297	VERIFY GAS_DETECTOR GDT5300297	PMT	4M			V				V				V		CAN	CAN-QUHV	204773	C
2,173	RDCC-53 -QMI_GD	RDCC-GDT5300298	VERIFY GAS_DETECTOR GDT5300298	PMT	4M			V				V				V		CAN	CAN-QUHV	204774	C
2,174	RDCC-53 -QMI_GD	RDCC-GDT5300299	VERIFY GAS_DETECTOR GDT5300299	PMT	4M			V				V				V		CAN	CAN-QUHV	204775	C
2,175	RDCC-53 -QMI_GD	RDCC-GDT5300305	VERIFY GAS_DETECTOR GDT5300305	PMT	4M			V				V				V		CAN	CAN-QUHV	140808	C
2,176	RDCC-53 -QMI_GD	RDCC-GDT5300320	VERIFY GAS_DETECTOR GDT5300320	PMT	4M			V				V				V		CAN	CAN-QUHV	140809	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,177	RDCC-53 -QMI_GD	RDCC-GDT5300321	VERIFY GAS_DETECTOR GDT5300321	PMT	4M			V				V				V		CAN	CAN-QUHV	140810	C
2,178	RDCC-53 -QMI_GD	RDCC-GDT5300326	VERIFY GAS_DETECTOR GDT5300326	PMT	4M			V				V				V		CAN	CAN-QUHV	140811	C
2,179	RDCC-53 -QMI_GD	RDCC-GDT5300328	VERIFY GAS_DETECTOR GDT5300328	PMT	4M			V				V				V		CAN	CAN-QUHV	140812	C
2,180	RDCC-53 -QMI_GD	RDCC-GDT5300331	VERIFY GAS_DETECTOR GDT5300331	PMT	4M			V				V				V		CAN	CAN-QUHV	140813	C
2,181	RDCC-53 -QMI_GD	RDCC-GDT5300340	VERIFY GAS_DETECTOR GDT5300340	PMT	4M			V				V				V		CAN	CAN-QUHV	140814	C
2,182	RDCC-53 -QMI_GD	RDCC-GDT5300341	VERIFY GAS_DETECTOR GDT5300341	PMT	4M			V				V				V		CAN	CAN-QUHV	140815	C
2,183	RDCC-53 -QMI_GD	RDCC-GDT5300601	VERIFY GAS_DETECTOR GDT5300601	PMT	4M			V				V				V		CAN	CAN-QUHV	140816	C
2,184	RDCC-53 -QMI_GD	RDCC-GDT5300602	VERIFY GAS_DETECTOR GDT5300602	PMT	4M			V				V				V		CAN	CAN-QUHV	140817	C
2,185	RDCC-53 -QMI_GD	RDCC-GDT5300603	VERIFY GAS_DETECTOR GDT5300603	PMT	4M			V				V				V		CAN	CAN-QUHV	140818	C
2,186	RDCC-56 -QMI_GD	RDCC-GDT5600201	VERIFY GAS_DETECTOR GDT5600201	PMT	4M				V				V				V	CAN	CAN-QUHV	204943	C
2,187	RDCC-56 -QMI_GD	RDCC-GDT5600202	3RIFY GAS_DETECTOR GDT5600202	PMT	4M				V				V					CAN	CAN-QUHV	204944	C
2,188	RDCC-56 -QMI_GD	RDCC-GDT5600203	VERIFY GAS_DETECTOR GDT5600203	PMT	4M				V				V				V	CAN	CAN-QUHV	204945	C
2,189	RDCC-56 -QMI_GD	RDCC-GDT5600204	VERIFY GAS_DETECTOR GDT5600204	PMT	4M				V				V				V	CAN	CAN-QUHV	204946	C
2,190	RDCC-56 -QMI_GD	RDCC-GDT5600205	VERIFY GAS_DETECTOR GDT5600205	PMT	4M				V				V				V	CAN	CAN-QUHV	204947	C
2,191	RDCC-56 -QMI_GD	RDCC-GDT5600206	VERIFY GAS_DETECTOR GDT5600206	PMT	4M				V				V				V	CAN	CAN-QUHV	204948	C
2,192	RDCC-56 -QMI_GD	RDCC-GDT5600207	VERIFY GAS_DETECTOR GDT5600207	PMT	4M				V				V				V	CAN	CAN-QUHV	204949	C
2,193	RDCC-56 -QMI_GD	RDCC-GDT5600208	VERIFY GAS_DETECTOR GDT5600208	PMT	4M				V				V				V	CAN	CAN-QUHV	204950	C
2,194	RDCC-56 -QMI_GD	RDCC-GDT5600209	VERIFY GAS_DETECTOR GDT5600209	PMT	4M				V				V				V	CAN	CAN-QUHV	204951	C
2,195	RDCC-56 -QMI_GD	RDCC-GDT5600210	VERIFY GAS_DETECTOR GDT5600210	PMT	4M				V				V				V	CAN	CAN-QUHV	204952	C
2,196	RDCC-56 -QMI_GD	RDCC-GDT5600212	VERIFY GAS_DETECTOR GDT5600212	PMT	4M				V				V				V	CAN	CAN-QUHV	204953	C
2,197	RDCC-56 -QMI_GD	RDCC-GDT5600213	VERIFY GAS_DETECTOR GDT5600213	PMT	4M				V				V				V	CAN	CAN-QUHV	204954	C
2,198	RDCC-56 -QMI_GD	RDCC-GDT5600214	VERIFY GAS_DETECTOR GDT5600214	PMT	4M				V				V				V	CAN	CAN-QUHV	204955	C
2,199	RDCC-56 -QMI_GD	RDCC-GDT5600215	VERIFY GAS_DETECTOR GDT5600215	PMT	4M				V				V				V	CAN	CAN-QUHV	204956	C
2,200	RDCC-56 -QMI_GD	RDCC-GDT5600216	VERIFY GAS_DETECTOR GDT5600216	PMT	4M				V				V				V	CAN	CAN-QUHV	204957	C
2,201	RDCC-53 -CV	RDCC-HV5300101	INSPECT CONTROL VALVE NO. HV53	INS	1Y											I			RRC	RRC-IRCP	134412	C
2,202	RDCC-53 -CV	RDCC-HV5300101	HV5300101-FULL FUNC. TEST CONT	PMT	5Y											F			RRC	RRC-IRCP	260348	C
2,203	RDCC-53 -CV	RDCC-HV5300102	INSPECT CONTROL VALVE NO. HV53	INS	1Y											I			RRC	RRC-IRCP	134413	C
2,204	RDCC-53 -CV	RDCC-HV5300102	HV5300102-FULL FUNC. TEST CONT	PMT	5Y											F			RRC	RRC-IRCP	260347	C
2,205	RDCC-53 -CV	RDCC-HV5300103	INSPECT CONTROL VALVE NO. HV53	INS	1Y											I			RRC	RRC-IRCP	134414	C
2,206	RDCC-53 -CV	RDCC-HV5300103	HV5300103-FULL FUNC. TEST CONT	PMT	5Y											F			RRC	RRC-IRCP	260349	C
2,207	RDCC-53 -CV	RDCC-HV5300105	INSPECT CONTROL VALVE NO. HV53	INS	1Y											I			RRC	RRC-IRCP	134415	C
2,208	RDCC-53 -CV	RDCC-HV5300105	HV5300105-FULL FUNC. TEST CONT	PMT	5Y											F			RRC	RRC-IRCP	260350	C
2,209	RDCC-53 -CV	RDCC-HV5300601	INSPECT CONTROL VALVE NO. HV53	PMT	1Y											I			RRC	RRC-IRCP	134397	C
2,210	RDCC-53 -CV	RDCC-HV5304901	INSPECT CONTROL VALVE NO. HV53	PMT	1Y											I			RRC	RRC-IRCP	134398	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,211	RDCC-53 -CV	RDCC-HV5306801	INSPECT CONTROL VALVE NO. HV53	PMT	1Y										I			RRC	RRC-IRCP	134399	C
2,212	RDCC-53 -CV	RDCC-HV5307301	INSPECT CONTROL VALVE NO. HV53	PMT	1Y										I			RRC	RRC-IRCP	134400	C
2,213	RDCC-53 -CV	RDCC-HV5307801	INSPECT CONTROL VALVE NO. HV53	PMT	1Y										I			RRC	RRC-IRCP	134401	C
2,214	RDCC-53 -CV	RDCC-HV5307802	INSPECT CONTROL VALVE NO. HV53	PMT	1Y										I			RRC	RRC-IRCP	134402	C
2,215	RDCC-53 -CV	RDCC-HV5308001	INSPECT CONTROL VALVE NO. HV53	PMT	1Y										I			RRC	RRC-IRCP	134403	C
2,216	RDCC-53 -CV	RDCC-HV5308102	INSPECT CONTROL VALVE NO. HV53	PMT	1Y										I			RRC	RRC-IRCP	134404	C
2,217	RDCC-53 -CV	RDCC-HV5309001	INSPECT CONTROL VALVE NO. HV53	PMT	1Y										I			RRC	RRC-IRCP	134416	C
2,218	RDCC-53 -CV	RDCC-HV5309301	INSPECT CONTROL VALVE NO. HV53	PMT	1Y										I			RRC	RRC-IRCP	134405	C
2,219	RDCC-53 -CV	RDCC-HV5309302	INSPECT CONTROL VALVE NO. HV53	PMT	1Y										I			RRC	RRC-IRCP	134406	C
2,220	RDCC-53 -CV	RDCC-HV5309403	INSPECT CONTROL VALVE NO. HV53	PMT	1Y										I			RRC	RRC-IRCP	134407	C
2,221	RDCC-53 -53E003	RDCC-HV5311801	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y												I	RRC	RRC-IRCP	255807	C
2,222	RDCC-53 -53K002	RDCC-HV5312002	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y												I	RRC	RRC-IRCP	255816	C
2,223	RDCC-53 -CV	RDCC-HV5352401	INSPECT CONTROL VALVE NO. HV53	PMT	1Y										I			RRC	RRC-IRCP	134417	C
2,224	RDCC-56 -CV	RDCC-HV5600101	INSPECT CONTROL VALVE NO. HV56	PMT	1Y										I			RRC	RRC-IRCP	134408	C
2,225	RDCC-56 -CV	RDCC-HV5600102	INSPECT CONTROL VALVE NO. HV56	PMT	1Y										I			RRC	RRC-IRCP	134409	C
2,226	RDCC-56 -CV	RDCC-HV5600301	INSPECT CONTROL VALVE NO. HV56	PMT	1Y										I			RRC	RRC-IRCP	134421	C
2,227	RDCC-56 -CV	RDCC-HV5600501	INSPECT CONTROL VALVE NO. HV56	PMT	1Y										I			RRC	RRC-IRCP	134410	C
2,228	RDCC-56 -CV	RDCC-HV5600502	INSPECT CONTROL VALVE NO. HV56	PMT	1Y										I			RRC	RRC-IRCP	134411	C
2,229	RDCC-53 -LEVEL	RDCC-LT5300401	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y				I									RRC	RRC-IRCP	133472	C
2,230	RDCC-53 -LEVEL	RDCC-LT5300402	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y				I									RRC	RRC-IRCP	133473	C
2,231	RDCC-53 -LEVEL	RDCC-LT5300501A	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	INS	1Y				I									RRC	RRC-IRCP	133474	C
2,232	RDCC-53 -LEVEL	RDCC-LT5300501A	LT5300501A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260574	C
2,233	RDCC-53 -LEVEL	RDCC-LT5300501B	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	INS	1Y				I									RRC	RRC-IRCP	133475	C
2,234	RDCC-53 -LEVEL	RDCC-LT5300501B	LT5300501B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260575	C
2,235	RDCC-53 -LEVEL	RDCC-LT5300501C	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	INS	1Y				I									RRC	RRC-IRCP	133476	C
2,236	RDCC-53 -LEVEL	RDCC-LT5300501C	LT5300501C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260576	C
2,237	RDCC-53 -LEVEL	RDCC-LT5300503A	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y				I									RRC	RRC-IRCP	133477	C
2,238	RDCC-53 -LEVEL	RDCC-LT5300503B	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y				I									RRC	RRC-IRCP	133478	C
2,239	RDCC-53 -LEVEL	RDCC-LT5300505A	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y				I									RRC	RRC-IRCP	133479	C
2,240	RDCC-53 -LEVEL	RDCC-LT5300505B	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y				I									RRC	RRC-IRCP	133480	C
2,241	RDCC-53 -53Q001	RDCC-LT5300540	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y				I									RRC	RRC-IRCP	133553	C
2,242	RDCC-53 -53Q003	RDCC-LT5300561	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y				I									RRC	RRC-IRCP	133555	C
2,243	RDCC-53 -53Q004	RDCC-LT5300581	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y				I									RRC	RRC-IRCP	133481	C
2,244	RDCC-53 -LEVEL	RDCC-LT5300601	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y				I									RRC	RRC-IRCP	133560	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,245	RDCC-53 -LEVEL	RDCC-LT5300602	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133482	C
2,246	RDCC-53 -53Q002	RDCC-LT5301240	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133554	C
2,247	RDCC-53 -LEVEL	RDCC-LT5301601	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133556	C
2,248	RDCC-53 -LEVEL	RDCC-LT5301701	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133557	C
2,249	RDCC-53 -LEVEL	RDCC-LT5301702	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133558	C
2,250	RDCC-53 -LEVEL	RDCC-LT5301801	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133559	C
2,251	RDCC-53 -LEVEL	RDCC-LT5302501	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133483	C
2,252	RDCC-53 -LEVEL	RDCC-LT5302503	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133561	C
2,253	RDCC-53 -LEVEL	RDCC-LT5302505A	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	INS	1Y			I										RRC	RRC-IRCP	133484	C
2,254	RDCC-53 -LEVEL	RDCC-LT5302505A	LT5302505A-FULL RUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260586	C
2,255	RDCC-53 -LEVEL	RDCC-LT5302505B	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	INS	1Y			I										RRC	RRC-IRCP	133485	C
2,256	RDCC-53 -LEVEL	RDCC-LT5302505B	LT5302505B-FULL RUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260587	C
2,257	RDCC-53 -LEVEL	RDCC-LT5302505C	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	INS	1Y			I										RRC	RRC-IRCP	133486	C
2,258	RDCC-53 -LEVEL	RDCC-LT5302505C	LT5302505C-FULL RUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260588	C
2,259	RDCC-53 -LEVEL	RDCC-LT5302901A	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133487	C
2,260	RDCC-53 -LEVEL	RDCC-LT5302901B	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133488	C
2,261	RDCC-53 -LEVEL	RDCC-LT5302904	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133489	C
2,262	RDCC-53 -LEVEL	RDCC-LT5303401	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133490	C
2,263	RDCC-53 -LEVEL	RDCC-LT5303602	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133562	C
2,264	RDCC-53 -LEVEL	RDCC-LT5303701	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133491	C
2,265	RDCC-53 -LEVEL	RDCC-LT5303703	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133492	C
2,266	RDCC-53 -LEVEL	RDCC-LT5304003	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133493	C
2,267	RDCC-53 -LEVEL	RDCC-LT5304004	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133494	C
2,268	RDCC-53 -LEVEL	RDCC-LT5304006	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133495	C
2,269	RDCC-53 -LEVEL	RDCC-LT5304008	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133496	C
2,270	RDCC-53 -LEVEL	RDCC-LT5304101	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133497	C
2,271	RDCC-53 -LEVEL	RDCC-LT5304104	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133498	C
2,272	RDCC-53 -LEVEL	RDCC-LT5304106	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133499	C
2,273	RDCC-53 -LEVEL	RDCC-LT5304107	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133500	C
2,274	RDCC-53 -LEVEL	RDCC-LT5304201	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133501	C
2,275	RDCC-53 -LEVEL	RDCC-LT5304204	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133502	C
2,276	RDCC-53 -LEVEL	RDCC-LT5304206	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133503	C
2,277	RDCC-53 -LEVEL	RDCC-LT5304208	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133504	C
2,278	RDCC-53 -LEVEL	RDCC-LT5304701	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133563	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,279	RDCC-53 -LEVEL	RDCC-LT5304902	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133564	C
2,280	RDCC-53 -LEVEL	RDCC-LT5304905	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133505	C
2,281	RDCC-53 -LEVEL	RDCC-LT5305002	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133506	C
2,282	RDCC-53 -LEVEL	RDCC-LT5305203	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133507	C
2,283	RDCC-53 -LEVEL	RDCC-LT5305204	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133565	C
2,284	RDCC-53 -LEVEL	RDCC-LT5305401A	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	INS	1Y			I										RRC	RRC-IRCP	133508	C
2,285	RDCC-53 -LEVEL	RDCC-LT5305401A	LT5305401A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260595	C
2,286	RDCC-53 -LEVEL	RDCC-LT5305401B	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	INS	1Y			I										RRC	RRC-IRCP	133509	C
2,287	RDCC-53 -LEVEL	RDCC-LT5305401B	LT5305401B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260596	C
2,288	RDCC-53 -LEVEL	RDCC-LT5305401C	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	INS	1Y			I										RRC	RRC-IRCP	133510	C
2,289	RDCC-53 -LEVEL	RDCC-LT5305401C	LT5305401C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260597	C
2,290	RDCC-53 -LEVEL	RDCC-LT5305403	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133511	C
2,291	RDCC-53 -LEVEL	RDCC-LT5305404	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133512	C
2,292	RDCC-53 -LEVEL	RDCC-LT5305701A	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	INS	1Y			I										RRC	RRC-IRCP	133513	C
2,293	RDCC-53 -LEVEL	RDCC-LT5305701A	LT5305701A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260598	C
2,294	RDCC-53 -LEVEL	RDCC-LT5305701B	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	INS	1Y			I										RRC	RRC-IRCP	133514	C
2,295	RDCC-53 -LEVEL	RDCC-LT5305701B	LT5305701B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260599	C
2,296	RDCC-53 -LEVEL	RDCC-LT5305701C	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	INS	1Y			I										RRC	RRC-IRCP	133515	C
2,297	RDCC-53 -LEVEL	RDCC-LT5305701C	LT5305701C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260600	C
2,298	RDCC-53 -LEVEL	RDCC-LT5305703	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133516	C
2,299	RDCC-53 -LEVEL	RDCC-LT5306301	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133566	C
2,300	RDCC-53 -LEVEL	RDCC-LT5306305	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133517	C
2,301	RDCC-53 -LEVEL	RDCC-LT5306401	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133518	C
2,302	RDCC-53 -LEVEL	RDCC-LT5306501	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133519	C
2,303	RDCC-53 -LEVEL	RDCC-LT5306503	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133520	C
2,304	RDCC-53 -LEVEL	RDCC-LT5306506	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133521	C
2,305	RDCC-53 -LEVEL	RDCC-LT5306603	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133567	C
2,306	RDCC-53 -LEVEL	RDCC-LT5306703	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133568	C
2,307	RDCC-53 -LEVEL	RDCC-LT5306802	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133569	C
2,308	RDCC-53 -LEVEL	RDCC-LT5306901	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133522	C
2,309	RDCC-53 -LEVEL	RDCC-LT5306903	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133570	C
2,310	RDCC-53 -LEVEL	RDCC-LT5307002	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133523	C
2,311	RDCC-53 -LEVEL	RDCC-LT5307003	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133524	C
2,312	RDCC-53 -LEVEL	RDCC-LT5307302	INSP. FIELD INST. (ต่อหุ้มกำหนด์)	PMT	1Y			I										RRC	RRC-IRCP	133525	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,313	RDCC-53 -LEVEL	RDCC-LT5307602	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133571	C
2,314	RDCC-53 -LEVEL	RDCC-LT5307802	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133526	C
2,315	RDCC-53 -LEVEL	RDCC-LT5307804	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133572	C
2,316	RDCC-53 -LEVEL	RDCC-LT5308003	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133573	C
2,317	RDCC-53 -LEVEL	RDCC-LT5308004	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IRCP	133574	C
2,318	RDCC-53 -LEVEL	RDCC-LT5308004	LT5308004-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IRCP	260419	C
2,319	RDCC-53 -LEVEL	RDCC-LT5308101	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133575	C
2,320	RDCC-53 -LEVEL	RDCC-LT5308201	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133527	C
2,321	RDCC-53 -LEVEL	RDCC-LT5308203	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133528	C
2,322	RDCC-53 -LEVEL	RDCC-LT5308302	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133529	C
2,323	RDCC-53 -LEVEL	RDCC-LT5308303	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133530	C
2,324	RDCC-53 -LEVEL	RDCC-LT5308901	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133576	C
2,325	RDCC-53 -LEVEL	RDCC-LT5308904	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133531	C
2,326	RDCC-53 -LEVEL	RDCC-LT5309001	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133532	C
2,327	RDCC-53 -LEVEL	RDCC-LT5309102	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133577	C
2,328	RDCC-53 -LEVEL	RDCC-LT5309302	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133533	C
2,329	RDCC-53 -LEVEL	RDCC-LT5309304	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133578	C
2,330	RDCC-53 -LEVEL	RDCC-LT5309502	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133534	C
2,331	RDCC-53 -LEVEL	RDCC-LT5309504	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133535	C
2,332	RDCC-53 -LEVEL	RDCC-LT5309602	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133536	C
2,333	RDCC-53 -LEVEL	RDCC-LT5309802	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133537	C
2,334	RDCC-53 -53E003	RDCC-LT5311806	INSP. FIELD INST.RDCC-LT531180	PMT	1Y										I			RRC	RRC-IRCP	255751	C
2,335	RDCC-53 -53D006	RDCC-LT5312101	INSP. FIELD INST.RDCC-LT531210	PMT	1Y										I			RRC	RRC-IRCP	255752	C
2,336	RDCC-53 -53D006	RDCC-LT5312102A	INSP. FIELD INST.RDCC-LT531210	PMT	1Y										I			RRC	RRC-IRCP	255753	C
2,337	RDCC-53 -53D006	RDCC-LT5312102B	INSP. FIELD INST.RDCC-LT531210	PMT	1Y										I			RRC	RRC-IRCP	255754	C
2,338	RDCC-53 -53D006	RDCC-LT5312102C	INSP. FIELD INST.RDCC-LT531210	PMT	1Y										I			RRC	RRC-IRCP	255755	C
2,339	RDCC-53 -53D006	RDCC-LT5312105	INSP. FIELD INST.RDCC-LT531210	PMT	1Y										I			RRC	RRC-IRCP	255756	C
2,340	RDCC-53 -LEVEL	RDCC-LT5340201	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133579	C
2,341	RDCC-53 -LEVEL	RDCC-LT5340202	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133580	C
2,342	RDCC-53 -53K001	RDCC-LT5350550	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133602	C
2,343	RDCC-53 -53K001	RDCC-LT5350552	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133603	C
2,344	RDCC-53 -53K101	RDCC-LT5351001	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133552	C
2,345	RDCC-53 -53K101	RDCC-LT5351201	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133551	C
2,346	RDCC-53 -LEVEL	RDCC-LT5352501	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133544	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,347	RDCC-53 -LEVEL	RDCC-LT5352502A	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y			I										RRC	RRC-IRCP	133545	C
2,348	RDCC-53 -LEVEL	RDCC-LT5352502A	LT5352502A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260570	C
2,349	RDCC-53 -LEVEL	RDCC-LT5352502B	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y			I										RRC	RRC-IRCP	133546	C
2,350	RDCC-53 -LEVEL	RDCC-LT5352502B	LT5352502B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260571	C
2,351	RDCC-53 -LEVEL	RDCC-LT5352502C	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y			I										RRC	RRC-IRCP	133547	C
2,352	RDCC-53 -LEVEL	RDCC-LT5352502C	LT5352502C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260572	C
2,353	RDCC-53 -LEVEL	RDCC-LT5352638A	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133548	C
2,354	RDCC-53 -LEVEL	RDCC-LT5352638B	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133549	C
2,355	RDCC-53 -LEVEL	RDCC-LT5352638C	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133550	C
2,356	RDCC-53 -LEVEL	RDCC-LT5355101	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133538	C
2,357	RDCC-53 -LEVEL	RDCC-LT5355301	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133539	C
2,358	RDCC-53 -LEVEL	RDCC-LT5355301	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133604	C
2,359	RDCC-53 -LEVEL	RDCC-LT5384501	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133581	C
2,360	RDCC-53 -LEVEL	RDCC-LT5384502	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133582	C
2,361	RDCC-56 -LEVEL	RDCC-LT5600201	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133583	C
2,362	RDCC-56 -LEVEL	RDCC-LT5600202	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IRCP	133584	C
2,363	RDCC-56 -LEVEL	RDCC-LT5600202	LT5600202-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IRCP	260422	C
2,364	RDCC-56 -LEVEL	RDCC-LT5600303	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133585	C
2,365	RDCC-56 -LEVEL	RDCC-LT5600304	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133586	C
2,366	RDCC-56 -LEVEL	RDCC-LT5600305A	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IRCP	133587	C
2,367	RDCC-56 -LEVEL	RDCC-LT5600305A	LT5600305A-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC-IRCP	260423	C
2,368	RDCC-56 -LEVEL	RDCC-LT5600305B	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IRCP	133588	C
2,369	RDCC-56 -LEVEL	RDCC-LT5600305B	LT5600305B-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC-IRCP	260424	C
2,370	RDCC-56 -LEVEL	RDCC-LT5600305C	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IRCP	133589	C
2,371	RDCC-56 -LEVEL	RDCC-LT5600305C	LT5600305C-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC-IRCP	260425	C
2,372	RDCC-56 -LEVEL	RDCC-LT5600401	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133590	C
2,373	RDCC-56 -LEVEL	RDCC-LT5600403	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IRCP	133591	C
2,374	RDCC-56 -LEVEL	RDCC-LT5600403	LT5600403-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IRCP	260426	C
2,375	RDCC-56 -LEVEL	RDCC-LT5600802	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IRCP	133540	C
2,376	RDCC-56 -LEVEL	RDCC-LT5600804A	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y			I										RRC	RRC-IRCP	133541	C
2,377	RDCC-56 -LEVEL	RDCC-LT5600804A	LT5600804A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260634	C
2,378	RDCC-56 -LEVEL	RDCC-LT5600804B	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y			I										RRC	RRC-IRCP	133542	C
2,379	RDCC-56 -LEVEL	RDCC-LT5600804B	LT5600804B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260635	C
2,380	RDCC-56 -LEVEL	RDCC-LT5600804C	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y			I										RRC	RRC-IRCP	133543	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,381	RDCC-56 -LEVEL	RDCC-LT5600804C	LT5600804C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260636	C
2,382	RDCC-56 -LEVEL	RDCC-LT5600805	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IRCP	133592	C
2,383	RDCC-56 -LEVEL	RDCC-LT5600805	LT5600805-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IRCP	260427	C
2,384	RDCC-56 -LEVEL	RDCC-LT5600806	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133593	C
2,385	RDCC-56 -LEVEL	RDCC-LT5601201	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133594	C
2,386	RDCC-56 -LEVEL	RDCC-LT5601301	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IRCP	133595	C
2,387	RDCC-56 -LEVEL	RDCC-LT5601301	LT5601301-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IRCP	260428	C
2,388	RDCC-56 -LEVEL	RDCC-LT5601302	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133596	C
2,389	RDCC-56 -LEVEL	RDCC-LT5601401	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133597	C
2,390	RDCC-56 -LEVEL	RDCC-LT5601502	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IRCP	133598	C
2,391	RDCC-56 -LEVEL	RDCC-LT5601502	LT5601502-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IRCP	260429	C
2,392	RDCC-56 -LEVEL	RDCC-LT5601503	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133599	C
2,393	RDCC-56 -LEVEL	RDCC-LT5601701	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133600	C
2,394	RDCC-56 -LEVEL	RDCC-LT5601702	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IRCP	133601	C
2,395	RDCC-56 -CV	RDCC-LV5600401	INSPECT CONTROL VALVE NO. LV56	PMT	1Y										I			RRC	RRC-IRCP	134439	C
2,396	RDCC-56 -CV	RDCC-LV5600802	INSPECT CONTROL VALVE NO. LV56	PMT	1Y										I			RRC	RRC-IRCP	134440	C
2,397	RDCC-56 -CV	RDCC-LV5601201	INSPECT CONTROL VALVE NO. LV56	PMT	1Y										I			RRC	RRC-IRCP	134441	C
2,398	RDCC-53 -CV	RDCC-PCV5300301	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134454	C
2,399	RDCC-53 -CV	RDCC-PCV5300302	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134455	C
2,400	RDCC-53 -CV	RDCC-PCV5302201	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134456	C
2,401	RDCC-53 -CV	RDCC-PCV5302202	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134457	C
2,402	RDCC-53 -CV	RDCC-PCV5302203	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134458	C
2,403	RDCC-53 -CV	RDCC-PCV5302204	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134459	C
2,404	RDCC-53 -CV	RDCC-PCV5302205	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134460	C
2,405	RDCC-53 -CV	RDCC-PCV5302206	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134462	C
2,406	RDCC-53 -CV	RDCC-PCV5302207	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134463	C
2,407	RDCC-53 -CV	RDCC-PCV5302208	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134464	C
2,408	RDCC-53 -CV	RDCC-PCV5302209	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134465	C
2,409	RDCC-53 -CV	RDCC-PCV5302210	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134466	C
2,410	RDCC-53 -CV	RDCC-PCV5302211	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134467	C
2,411	RDCC-53 -CV	RDCC-PCV5302212	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134468	C
2,412	RDCC-53 -CV	RDCC-PCV5302213	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134469	C
2,413	RDCC-53 -CV	RDCC-PCV5302214	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134470	C
2,414	RDCC-53 -CV	RDCC-PCV5302215	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134471	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,415	RDCC-53 -CV	RDCC-PCV5302216	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134472	C
2,416	RDCC-53 -CV	RDCC-PCV5302217	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134473	C
2,417	RDCC-53 -CV	RDCC-PCV5302218	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134474	C
2,418	RDCC-53 -CV	RDCC-PCV5302219	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134475	C
2,419	RDCC-53 -CV	RDCC-PCV5302220	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134476	C
2,420	RDCC-53 -CV	RDCC-PCV5302221	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134477	C
2,421	RDCC-53 -CV	RDCC-PCV5302222	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134478	C
2,422	RDCC-53 -CV	RDCC-PCV5302223	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134479	C
2,423	RDCC-53 -CV	RDCC-PCV5302224	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134480	C
2,424	RDCC-53 -CV	RDCC-PCV5302225	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134481	C
2,425	RDCC-53 -53Z027	RDCC-PCV5302232	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y											I		RRC	RRC-IRCP	255787	C
2,426	RDCC-53 -53Z027	RDCC-PCV5302233	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y											I		RRC	RRC-IRCP	255788	C
2,427	RDCC-53 -53Z027	RDCC-PCV5302234	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y											I		RRC	RRC-IRCP	255789	C
2,428	RDCC-53 -53Z027	RDCC-PCV5302235	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y											I		RRC	RRC-IRCP	255790	C
2,429	RDCC-53 -53Z027	RDCC-PCV5302236	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y											I		RRC	RRC-IRCP	255791	C
2,430	RDCC-53 -53Z027	RDCC-PCV5302237	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y											I		RRC	RRC-IRCP	255792	C
2,431	RDCC-53 -53Z028	RDCC-PCV5302238	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y											I		RRC	RRC-IRCP	255793	C
2,432	RDCC-53 -53Z028	RDCC-PCV5302239	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y											I		RRC	RRC-IRCP	255794	C
2,433	RDCC-53 -53Z028	RDCC-PCV5302240	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y											I		RRC	RRC-IRCP	255795	C
2,434	RDCC-53 -53Z028	RDCC-PCV5302241	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y											I		RRC	RRC-IRCP	255796	C
2,435	RDCC-53 -53E003	RDCC-PCV5302242	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y											I		RRC	RRC-IRCP	255797	C
2,436	RDCC-53 -53E003	RDCC-PCV5302243	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y											I		RRC	RRC-IRCP	255798	C
2,437	RDCC-53 -53E003	RDCC-PCV5302244	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y											I		RRC	RRC-IRCP	255799	C
2,438	RDCC-53 -53E003	RDCC-PCV5302245	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y											I		RRC	RRC-IRCP	255800	C
2,439	RDCC-53 -53E003	RDCC-PCV5302246	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y											I		RRC	RRC-IRCP	255801	C
2,440	RDCC-53 -53P102	RDCC-PCV5310002A	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IRCP	134682	C
2,441	RDCC-53 -53P102	RDCC-PCV5310102B	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IRCP	134683	C
2,442	RDCC-53 -53P102	RDCC-PCV5310102C	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IRCP	134684	C
2,443	RDCC-53 -CV	RDCC-PCV5310510	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134482	C
2,444	RDCC-53 -CV	RDCC-PCV5310511	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134483	C
2,445	RDCC-53 -53K002	RDCC-PCV5312414	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y												I	RRC	RRC-IRCP	255819	C
2,446	RDCC-53 -53K002	RDCC-PCV5312415	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y												I	RRC	RRC-IRCP	255820	C
2,447	RDCC-53 -53K002	RDCC-PCV5312416	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y												I	RRC	RRC-IRCP	255818	C
2,448	RDCC-53 -CV	RDCC-PCV5340201	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134484	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,449	RDCC-53 -CV	RDCC-PCV53526 45	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134680	C
2,450	RDCC-53 -CV	RDCC-PCV53528 40	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IRCP	134681	C
2,451	RDCC-53 -CV	RDCC-PCV53845 01	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y										I			RRC	RRC-IRCP	134485	C
2,452	RDCC-56 -CV	RDCC-PCV56017 01	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y										I			RRC	RRC-IRCP	134486	C
2,453	RDCC-56 -CV	RDCC-PCV56017 02	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y										I			RRC	RRC-IRCP	134487	C
2,454	RDCC-53 -53K002	RDCC-PDI53124 08	INSP. FIELD INST.RDCC-PDI53124	PMT	1Y									I				RRC	RRC-IRCP	255776	C
2,455	RDCC-53 -PRESS	RDCC-PDT53003 01	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y					I								RRC	RRC-IRCP	133605	C
2,456	RDCC-53 -PRESS	RDCC-PDT53003 02	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y					I								RRC	RRC-IRCP	133606	C
2,457	RDCC-53 -PRESS	RDCC-PDT53003 02	PDT53003 02-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260573	C
2,458	RDCC-53 -PRESS	RDCC-PDT53004 02	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133607	C
2,459	RDCC-53 -PRESS	RDCC-PDT53004 06	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133608	C
2,460	RDCC-53 -PRESS	RDCC-PDT53004 07	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133609	C
2,461	RDCC-53 -PRESS	RDCC-PDT53004 08	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133610	C
2,462	RDCC-53 -PRESS	RDCC-PDT53005 01	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133611	C
2,463	RDCC-53 -PRESS	RDCC-PDT5300502A	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y				I									RRC	RRC-IRCP	133612	C
2,464	RDCC-53 -PRESS	RDCC-PDT5300502A	PDT5300502A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260577	C
2,465	RDCC-53 -PRESS	RDCC-PDT5300502B	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y				I									RRC	RRC-IRCP	133613	C
2,466	RDCC-53 -PRESS	RDCC-PDT5300502B	PDT5300502B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260578	C
2,467	RDCC-53 -PRESS	RDCC-PDT5300502C	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y				I									RRC	RRC-IRCP	133614	C
2,468	RDCC-53 -PRESS	RDCC-PDT5300502C	PDT5300502C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260579	C
2,469	RDCC-53 -PRESS	RDCC-PDT5300503	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133615	C
2,470	RDCC-53 -PRESS	RDCC-PDT5300504A	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y				I									RRC	RRC-IRCP	133616	C
2,471	RDCC-53 -PRESS	RDCC-PDT5300504A	PDT5300504A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260580	C
2,472	RDCC-53 -PRESS	RDCC-PDT5300504B	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y				I									RRC	RRC-IRCP	133617	C
2,473	RDCC-53 -PRESS	RDCC-PDT5300504B	PDT5300504B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260581	C
2,474	RDCC-53 -PRESS	RDCC-PDT5300504C	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y				I									RRC	RRC-IRCP	133618	C
2,475	RDCC-53 -PRESS	RDCC-PDT5300504C	PDT5300504C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260582	C
2,476	RDCC-53 -PRESS	RDCC-PDT5300507	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133619	C
2,477	RDCC-53 -PRESS	RDCC-PDT5300511	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133620	C
2,478	RDCC-53 -PRESS	RDCC-PDT5300512	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133621	C
2,479	RDCC-53 -53Q001	RDCC-PDT5300541	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	133930	C
2,480	RDCC-53 -53Q003	RDCC-PDT5300561	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	133940	C
2,481	RDCC-53 -53Q004	RDCC-PDT5300581	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	133945	C
2,482	RDCC-53 -PRESS	RDCC-PDT5300602	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133622	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,483	RDCC-53 -PRESS	RDCC-PDT5301201	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133623	C
2,484	RDCC-53 -PRESS	RDCC-PDT5301202A	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y				I									RRC	RRC-IRCP	133624	C
2,485	RDCC-53 -PRESS	RDCC-PDT5301202A	PDT5301202A-FULL FUN TEST PT &	PMT	5Y										F			RRC	RRC-IRCP	260583	C
2,486	RDCC-53 -PRESS	RDCC-PDT5301202B	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y				I									RRC	RRC-IRCP	133625	C
2,487	RDCC-53 -PRESS	RDCC-PDT5301202B	PDT5301202B-FULL FUN TEST PT &	PMT	5Y										F			RRC	RRC-IRCP	260584	C
2,488	RDCC-53 -PRESS	RDCC-PDT5301202C	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y				I									RRC	RRC-IRCP	133626	C
2,489	RDCC-53 -PRESS	RDCC-PDT5301202C	PDT5301202C-FULL FUN TEST PT &	PMT	5Y										F			RRC	RRC-IRCP	260585	C
2,490	RDCC-53 -53Q002	RDCC-PDT5301241	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133935	C
2,491	RDCC-53 -PRESS	RDCC-PDT5302811	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133627	C
2,492	RDCC-53 -PRESS	RDCC-PDT5302812	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133628	C
2,493	RDCC-53 -PRESS	RDCC-PDT5302903	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133629	C
2,494	RDCC-53 -PRESS	RDCC-PDT5303601	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133630	C
2,495	RDCC-53 -PRESS	RDCC-PDT5303602	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133631	C
2,496	RDCC-53 -PRESS	RDCC-PDT5304601	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133632	C
2,497	RDCC-53 -PRESS	RDCC-PDT5304602	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133633	C
2,498	RDCC-53 -PRESS	RDCC-PDT5304701	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133634	C
2,499	RDCC-53 -PRESS	RDCC-PDT5304702	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133635	C
2,500	RDCC-53 -PRESS	RDCC-PDT5306601	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133636	C
2,501	RDCC-53 -PRESS	RDCC-PDT5306602	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133637	C
2,502	RDCC-53 -PRESS	RDCC-PDT5306701	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133638	C
2,503	RDCC-53 -PRESS	RDCC-PDT5306702	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133639	C
2,504	RDCC-53 -PRESS	RDCC-PDT5307704	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133640	C
2,505	RDCC-53 -PRESS	RDCC-PDT5308003	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133641	C
2,506	RDCC-53 -PRESS	RDCC-PDT5308101	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133642	C
2,507	RDCC-53 -PRESS	RDCC-PDT5308102	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133643	C
2,508	RDCC-53 -PRESS	RDCC-PDT5309204	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133644	C
2,509	RDCC-53 -PRESS	RDCC-PDT5310001	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133645	C
2,510	RDCC-53 -PRESS	RDCC-PDT5310104	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133646	C
2,511	RDCC-53 -PRESS	RDCC-PDT5310107	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133647	C
2,512	RDCC-53 -PRESS	RDCC-PDT5310512	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133648	C
2,513	RDCC-53 -53A002AB	RDCC-PDT5311101	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133950	C
2,514	RDCC-53 -PRESS	RDCC-PDT5311102	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133649	C
2,515	RDCC-53 -53A002AB	RDCC-PDT5311103	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133951	C
2,516	RDCC-53 -53E003	RDCC-PDT5311833	INSP. FIELD INST.RDCC-PDT53118	PMT	1Y								I					RRC	RRC-IRCP	255747	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,517	RDCC-53 -53P140A	RDCC-PDT5312202	INSP. FIELD INST.RDCC-PDT53122	PMT	1Y									I				RRC	RRC-IRCP	255748	C
2,518	RDCC-53 -53P140B	RDCC-PDT5312205	INSP. FIELD INST.RDCC-PDT53122	PMT	1Y									I				RRC	RRC-IRCP	255749	C
2,519	RDCC-53 -53P140C	RDCC-PDT5312207	INSP. FIELD INST.RDCC-PDT53122	PMT	1Y									I				RRC	RRC-IRCP	255750	C
2,520	RDCC-53 -53K002	RDCC-PDT5312401	INSP. FIELD INST.RDCC-PDT53124	PMT	1Y										I			RRC	RRC-IRCP	255775	C
2,521	RDCC-53 -53K002	RDCC-PDT5312406	INSP. FIELD INST.RDCC-PDT53124	PMT	1Y										I			RRC	RRC-IRCP	255785	C
2,522	RDCC-53 -53K002	RDCC-PDT5312407	INSP. FIELD INST.RDCC-PDT53124	PMT	1Y										I			RRC	RRC-IRCP	255786	C
2,523	RDCC-53 -53K001	RDCC-PDT535017 0A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133650	C
2,524	RDCC-53 -53K001	RDCC-PDT535017 0B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133651	C
2,525	RDCC-53 -53K001	RDCC-PDT535017 2A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133652	C
2,526	RDCC-53 -53K001	RDCC-PDT535017 2B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133653	C
2,527	RDCC-53 -53K001	RDCC-PDT535017 2C	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133654	C
2,528	RDCC-53 -53K001	RDCC-PDT5350555	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133655	C
2,529	RDCC-53 -53K101	RDCC-PDT5351002	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	133905	C
2,530	RDCC-53 -53K101	RDCC-PDT5351204	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCP	133910	C
2,531	RDCC-53 -PRESS	RDCC-PDT5353032	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133656	C
2,532	RDCC-53 -PRESS	RDCC-PDT5353033	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133657	C
2,533	RDCC-53 -PRESS	RDCC-PDT5355001	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133658	C
2,534	RDCC-56 -PRESS	RDCC-PDT5600208	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133659	C
2,535	RDCC-56 -PRESS	RDCC-PDT5600406	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133660	C
2,536	RDCC-56 -PRESS	RDCC-PDT5600702	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133661	C
2,537	RDCC-56 -PRESS	RDCC-PDT5600803	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133662	C
2,538	RDCC-56 -PRESS	RDCC-PDT5600902	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133663	C
2,539	RDCC-56 -PRESS	RDCC-PDT5601201	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133664	C
2,540	RDCC-56 -PRESS	RDCC-PDT5601208	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133665	C
2,541	RDCC-56 -PRESS	RDCC-PDT5601301	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133666	C
2,542	RDCC-56 -PRESS	RDCC-PDT5601302	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133667	C
2,543	RDCC-56 -PRESS	RDCC-PDT5601401	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133668	C
2,544	RDCC-56 -PRESS	RDCC-PDT5601407	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133669	C
2,545	RDCC-56 -PRESS	RDCC-PDT5601502	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IRCP	133670	C
2,546	RDCC-53 -CV	RDCC-PDV53003 01	INSPECT CONTROL VALVE NO. PDV5	PMT	1Y										I			RRC	RRC-IRCP	134418	C
2,547	RDCC-53 -CV	RDCC-PDV53006 02	INSPECT CONTROL VALVE NO. PDV5	PMT	1Y										I			RRC	RRC-IRCP	134419	C
2,548	RDCC-53 -CV	RDCC-PDV53077 04	INSPECT CONTROL VALVE NO. PDV5	PMT	1Y										I			RRC	RRC-IRCP	134420	C
2,549	RDCC-53 -CV	RDCC-PDV53092 04	INSPECT CONTROL VALVE NO. PDV5	PMT	1Y											I		RRC	RRC-IRCP	134461	C
2,550	RDCC-STR-PIPE_RACK	RDCC-PR-53-AF	INSPECTION PIPE RACK FOR RCPP	INT	6Y				I									ENE	ENE-ENGS	204426	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,551	RDCC-53 -PRD	RDCC-PSV53006 04	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163360	A
2,552	RDCC-53 -53D004	RDCC-PSV53016 01	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163365	A
2,553	RDCC-53 -53D003A	RDCC-PSV53017 01	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163366	A
2,554	RDCC-53 -53D003B	RDCC-PSV53017 03	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163367	A
2,555	RDCC-53 -PRD	RDCC-PSV53025 02	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163371	A
2,556	RDCC-53 -PRD	RDCC-PSV53025 04	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163373	A
2,557	RDCC-53 -PRD	RDCC-PSV53036 03	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163389	A
2,558	RDCC-53 -53E107	RDCC-PSV53037 01	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163390	A
2,559	RDCC-53 -53E107	RDCC-PSV53037 02	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163391	A
2,560	RDCC-53 -53E107	RDCC-PSV53037 03	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163392	A
2,561	RDCC-53 -53E101A	RDCC-PSV53039 01	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163393	A
2,562	RDCC-53 -53E101C	RDCC-PSV53039 02	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163394	A
2,563	RDCC-53 -53E101E	RDCC-PSV53039 03	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163395	A
2,564	RDCC-53 -53E102A	RDCC-PSV53040 01	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163396	A
2,565	RDCC-53 -53E102A	RDCC-PSV53040 02	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163397	A
2,566	RDCC-53 -53E102B	RDCC-PSV53040 03	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163398	A
2,567	RDCC-53 -53E102B	RDCC-PSV53040 04	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163399	A
2,568	RDCC-53 -53E102C	RDCC-PSV53041 01	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163404	A
2,569	RDCC-53 -53E102C	RDCC-PSV53041 02	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163405	A
2,570	RDCC-53 -53E102D	RDCC-PSV53041 03	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163406	A
2,571	RDCC-53 -53E102D	RDCC-PSV53041 04	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163407	A
2,572	RDCC-53 -53E103A	RDCC-PSV53042 01	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163412	A
2,573	RDCC-53 -53E103A	RDCC-PSV53042 02	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163413	A
2,574	RDCC-53 -53E103B	RDCC-PSV53042 03	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163414	A
2,575	RDCC-53 -53E103B	RDCC-PSV53042 04	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163415	A
2,576	RDCC-53 -53E103A	RDCC-PSV53042 05	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163416	A
2,577	RDCC-53 -53E103B	RDCC-PSV53042 06	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163417	A
2,578	RDCC-53 -PRD	RDCC-PSV53045 01	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163424	A
2,579	RDCC-53 -PRD	RDCC-PSV53045 02	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163425	A
2,580	RDCC-53 -53E114	RDCC-PSV53047 02	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163427	A
2,581	RDCC-53 -53X105	RDCC-PSV53047 03	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163428	A
2,582	RDCC-53 -53D102	RDCC-PSV53049 01	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163430	A
2,583	RDCC-53 -53D104	RDCC-PSV53050 01	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163431	A
2,584	RDCC-53 -53D106	RDCC-PSV53057 01	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163448	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,585	RDCC-53 -53D107	RDCC-PSV5306301	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163454	A
2,586	RDCC-53 -PRD	RDCC-PSV5306302	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163455	A
2,587	RDCC-53 -PRD	RDCC-PSV5306303	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163456	A
2,588	RDCC-53 -53X103	RDCC-PSV5306602	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163462	A
2,589	RDCC-53 -53X104	RDCC-PSV5306702	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163464	A
2,590	RDCC-53 -53D108	RDCC-PSV5306901	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163466	A
2,591	RDCC-53 -53E130	RDCC-PSV5307401	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163472	A
2,592	RDCC-53 -53D110	RDCC-PSV5307801	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163479	A
2,593	RDCC-53 -PRD	RDCC-PSV5308001	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163480	A
2,594	RDCC-53 -53D116	RDCC-PSV5309301	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163499	A
2,595	RDCC-53 -53C106	RDCC-PSV5309501	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163501	A
2,596	RDCC-53 -53D115	RDCC-PSV5309601	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163502	A
2,597	RDCC-53 -53E003	RDCC-PSV5311801	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254740	C
2,598	RDCC-53 -53E003	RDCC-PSV5311802	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254741	C
2,599	RDCC-53 -53E003	RDCC-PSV5311803	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254742	C
2,600	RDCC-53 -53E003	RDCC-PSV5311804	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254743	C
2,601	RDCC-53 -53E003	RDCC-PSV5311805	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254744	C
2,602	RDCC-53 -53E003	RDCC-PSV5311806	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254745	C
2,603	RDCC-53 -53E003	RDCC-PSV5311807	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254746	C
2,604	RDCC-53 -53E003	RDCC-PSV5311808	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254747	C
2,605	RDCC-53 -53E003	RDCC-PSV5311809	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254748	C
2,606	RDCC-53 -53E003	RDCC-PSV5311810	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254749	C
2,607	RDCC-53 -53E003	RDCC-PSV5311811	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254750	C
2,608	RDCC-53 -53E003	RDCC-PSV5311812	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254751	C
2,609	RDCC-53 -53E003	RDCC-PSV5311813	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254752	C
2,610	RDCC-53 -53E003	RDCC-PSV5311814	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254753	C
2,611	RDCC-53 -53E003	RDCC-PSV5311815	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254754	C
2,612	RDCC-53 -53E003	RDCC-PSV5311816	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254755	C
2,613	RDCC-53 -53E003	RDCC-PSV5311817	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254756	C
2,614	RDCC-53 -53E003	RDCC-PSV5311818	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254757	C
2,615	RDCC-53 -53E003	RDCC-PSV5311819	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254758	C
2,616	RDCC-53 -53E003	RDCC-PSV5311820	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254759	C
2,617	RDCC-53 -53E003	RDCC-PSV5311821	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254760	C
2,618	RDCC-53 -53E003	RDCC-PSV5311822	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254761	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,619	RDCC-53 -53E003	RDCC-PSV5311823	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254762	C
2,620	RDCC-53 -53E003	RDCC-PSV5311824	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254763	C
2,621	RDCC-53 -53E003	RDCC-PSV5311840	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254764	C
2,622	RDCC-53 -53E003	RDCC-PSV5311841	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254765	C
2,623	RDCC-53 -53E003	RDCC-PSV5311842	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254766	C
2,624	RDCC-53 -53E003	RDCC-PSV5311843	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254767	C
2,625	RDCC-53 -53E003	RDCC-PSV5311844	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254768	C
2,626	RDCC-53 -53E003	RDCC-PSV5311845	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254769	C
2,627	RDCC-53 -53E003	RDCC-PSV5311846	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254770	C
2,628	RDCC-53 -53E003	RDCC-PSV5311847	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254771	C
2,629	RDCC-53 -53D006	RDCC-PSV5312102A	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254774	C
2,630	RDCC-53 -53D006	RDCC-PSV5312102B	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254775	C
2,631	RDCC-53 -PRD	RDCC-PSV5350563	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163517	A
2,632	RDCC-53 -PRD	RDCC-PSV5350564	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163518	A
2,633	RDCC-53 -PRD	RDCC-PSV5351201	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163520	A
2,634	RDCC-53 -PRD	RDCC-PSV5351202	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163521	A
2,635	RDCC-53 -PRD	RDCC-PSV5351203	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163522	A
2,636	RDCC-53 -53X002	RDCC-PSV5352401A	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163525	A
2,637	RDCC-53 -53X002	RDCC-PSV5352401B	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163526	A
2,638	RDCC-53 -53X002	RDCC-PSV5352502A	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163527	A
2,639	RDCC-53 -53X002	RDCC-PSV5352502B	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163528	A
2,640	RDCC-53 -53X002	RDCC-PSV5352502C	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163529	A
2,641	RDCC-53 -53X006	RDCC-PSV5356801	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254776	C
2,642	RDCC-53 -53X006	RDCC-PSV5356802	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254777	C
2,643	RDCC-53 -53X006	RDCC-PSV5356803	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254778	C
2,644	RDCC-53 -53X006	RDCC-PSV5356804	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	254779	C
2,645	RDCC-56 -PRD	RDCC-PSV5600102	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163546	B
2,646	RDCC-56 -PRD	RDCC-PSV5600201	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163547	B
2,647	RDCC-56 -56C001	RDCC-PSV5600301	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163550	A
2,648	RDCC-56 -56D002	RDCC-PSV5600401	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163551	A
2,649	RDCC-56 -56D005	RDCC-PSV5601201	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163558	A
2,650	RDCC-56 -56D006	RDCC-PSV5601301	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163561	A
2,651	RDCC-56 -56D007	RDCC-PSV5601401	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163564	A
2,652	RDCC-56 -56F002	RDCC-PSV5601501	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCP	163567	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,653	RDCC-53 -PRESS	RDCC-PT5300301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	133671	C
2,654	RDCC-53 -PRESS	RDCC-PT5300302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	133672	C
2,655	RDCC-53 -PRESS	RDCC-PT5300401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	133673	C
2,656	RDCC-53 -PRESS	RDCC-PT5300403A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	133674	C
2,657	RDCC-53 -PRESS	RDCC-PT5300403B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	133675	C
2,658	RDCC-53 -PRESS	RDCC-PT5300404	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	133676	C
2,659	RDCC-53 -PRESS	RDCC-PT5300405	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	133677	C
2,660	RDCC-53 -PRESS	RDCC-PT5300408	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	133678	C
2,661	RDCC-53 -PRESS	RDCC-PT5300409	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	133679	C
2,662	RDCC-53 -PRESS	RDCC-PT5300410	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	133680	C
2,663	RDCC-53 -PRESS	RDCC-PT5300505A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	133681	C
2,664	RDCC-53 -PRESS	RDCC-PT5300505B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	133682	C
2,665	RDCC-53 -PRESS	RDCC-PT5300506	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	133683	C
2,666	RDCC-53 -PRESS	RDCC-PT5300508	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	133684	C
2,667	RDCC-53 -53Q001	RDCC-PT5300541	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133932	C
2,668	RDCC-53 -53Q001	RDCC-PT5300541A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133928	C
2,669	RDCC-53 -53Q001	RDCC-PT5300541B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133929	C
2,670	RDCC-53 -53Q001	RDCC-PT5300546	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133931	C
2,671	RDCC-53 -53Q003	RDCC-PT5300561A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133938	C
2,672	RDCC-53 -53Q003	RDCC-PT5300561B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133939	C
2,673	RDCC-53 -53Q003	RDCC-PT5300562	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133942	C
2,674	RDCC-53 -53Q003	RDCC-PT5300567	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133941	C
2,675	RDCC-53 -53Q004	RDCC-PT5300581A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133943	C
2,676	RDCC-53 -53Q004	RDCC-PT5300581B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133944	C
2,677	RDCC-53 -53Q004	RDCC-PT5300582	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133946	C
2,678	RDCC-53 -53Q004	RDCC-PT5300592	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133947	C
2,679	RDCC-53 -PRESS	RDCC-PT5300601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	133685	C
2,680	RDCC-53 -PRESS	RDCC-PT5300602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	133686	C
2,681	RDCC-53 -PRESS	RDCC-PT5301001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	133687	C
2,682	RDCC-53 -PRESS	RDCC-PT5301002	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IRCP	133688	C
2,683	RDCC-53 -53Q002	RDCC-PT5301241	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133937	C
2,684	RDCC-53 -53Q002	RDCC-PT5301241A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133933	C
2,685	RDCC-53 -53Q002	RDCC-PT5301241B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133934	C
2,686	RDCC-53 -53Q002	RDCC-PT5301246	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133936	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,687	RDCC-53 -PRESS	RDCC-PT5301301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133689	C
2,688	RDCC-53 -PRESS	RDCC-PT5301301B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133690	C
2,689	RDCC-53 -PRESS	RDCC-PT5301303	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133691	C
2,690	RDCC-53 -PRESS	RDCC-PT5301304	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133692	C
2,691	RDCC-53 -PRESS	RDCC-PT5301602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133693	C
2,692	RDCC-53 -PRESS	RDCC-PT5301603	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133694	C
2,693	RDCC-53 -PRESS	RDCC-PT5301702B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133695	C
2,694	RDCC-53 -PRESS	RDCC-PT5301703B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133696	C
2,695	RDCC-53 -PRESS	RDCC-PT5301803	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133697	C
2,696	RDCC-53 -PRESS	RDCC-PT5302208	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133698	C
2,697	RDCC-53 -PRESS	RDCC-PT5302210	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133699	C
2,698	RDCC-53 -PRESS	RDCC-PT5302212	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133700	C
2,699	RDCC-53 -PRESS	RDCC-PT5302214	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133701	C
2,700	RDCC-53 -PRESS	RDCC-PT5302216	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133702	C
2,701	RDCC-53 -PRESS	RDCC-PT5302218	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133703	C
2,702	RDCC-53 -PRESS	RDCC-PT5302220	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133704	C
2,703	RDCC-53 -PRESS	RDCC-PT5302222	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133705	C
2,704	RDCC-53 -53E003	RDCC-PT5302242	INSP. FIELD INST.RDCC-PT530224	PMT	1Y		I											RRC	RRC-IRCP	255731	C
2,705	RDCC-53 -53E003	RDCC-PT5302243	INSP. FIELD INST.RDCC-PT530224	PMT	1Y		I											RRC	RRC-IRCP	255732	C
2,706	RDCC-53 -53E003	RDCC-PT5302244	INSP. FIELD INST.RDCC-PT530224	PMT	1Y		I											RRC	RRC-IRCP	255733	C
2,707	RDCC-53 -PRESS	RDCC-PT5302502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133706	C
2,708	RDCC-53 -PRESS	RDCC-PT5302504	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133707	C
2,709	RDCC-53 -PRESS	RDCC-PT5302505	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133708	C
2,710	RDCC-53 -PRESS	RDCC-PT5302703	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133709	C
2,711	RDCC-53 -PRESS	RDCC-PT5302704	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133710	C
2,712	RDCC-53 -PRESS	RDCC-PT5302707	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133711	C
2,713	RDCC-53 -PRESS	RDCC-PT5302710	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133712	C
2,714	RDCC-53 -PRESS	RDCC-PT5302715	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133713	C
2,715	RDCC-53 -PRESS	RDCC-PT5302716	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133714	C
2,716	RDCC-53 -PRESS	RDCC-PT5302721	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133715	C
2,717	RDCC-53 -PRESS	RDCC-PT5302722	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133716	C
2,718	RDCC-53 -PRESS	RDCC-PT5302723	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133717	C
2,719	RDCC-53 -PRESS	RDCC-PT5302725	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133718	C
2,720	RDCC-53 -PRESS	RDCC-PT5302726	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133719	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,721	RDCC-53 -PRESS	RDCC-PT5302727	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133720	C
2,722	RDCC-53 -PRESS	RDCC-PT5302728	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133721	C
2,723	RDCC-53 -PRESS	RDCC-PT5302801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133722	C
2,724	RDCC-53 -PRESS	RDCC-PT5302802	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133723	C
2,725	RDCC-53 -PRESS	RDCC-PT5302803	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133724	C
2,726	RDCC-53 -PRESS	RDCC-PT5302806	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133725	C
2,727	RDCC-53 -PRESS	RDCC-PT5302807	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133726	C
2,728	RDCC-53 -PRESS	RDCC-PT5302901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133727	C
2,729	RDCC-53 -PRESS	RDCC-PT5302904	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133728	C
2,730	RDCC-53 -PRESS	RDCC-PT5302906	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133729	C
2,731	RDCC-53 -PRESS	RDCC-PT5302908	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133730	C
2,732	RDCC-53 -PRESS	RDCC-PT5303301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133731	C
2,733	RDCC-53 -PRESS	RDCC-PT5303504	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133732	C
2,734	RDCC-53 -PRESS	RDCC-PT5303603	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133733	C
2,735	RDCC-53 -PRESS	RDCC-PT5303704	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133734	C
2,736	RDCC-53 -PRESS	RDCC-PT5303705	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133735	C
2,737	RDCC-53 -PRESS	RDCC-PT5303902	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133736	C
2,738	RDCC-53 -PRESS	RDCC-PT5303906	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133737	C
2,739	RDCC-53 -PRESS	RDCC-PT5304002	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133738	C
2,740	RDCC-53 -PRESS	RDCC-PT5304004	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133739	C
2,741	RDCC-53 -PRESS	RDCC-PT5304105	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133740	C
2,742	RDCC-53 -PRESS	RDCC-PT5304109	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133741	C
2,743	RDCC-53 -PRESS	RDCC-PT5304203	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133742	C
2,744	RDCC-53 -PRESS	RDCC-PT5304205	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133743	C
2,745	RDCC-53 -PRESS	RDCC-PT5304307	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133744	C
2,746	RDCC-53 -PRESS	RDCC-PT5304308	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133745	C
2,747	RDCC-53 -PRESS	RDCC-PT5304501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133746	C
2,748	RDCC-53 -PRESS	RDCC-PT5304503	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133747	C
2,749	RDCC-53 -PRESS	RDCC-PT5304706	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133748	C
2,750	RDCC-53 -PRESS	RDCC-PT5304805	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133749	C
2,751	RDCC-53 -PRESS	RDCC-PT5304906	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133750	C
2,752	RDCC-53 -PRESS	RDCC-PT5305001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133751	C
2,753	RDCC-53 -PRESS	RDCC-PT5305101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133752	C
2,754	RDCC-53 -PRESS	RDCC-PT5305103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133753	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,755	RDCC-53 -PRESS	RDCC-PT5305206	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133754	C
2,756	RDCC-53 -PRESS	RDCC-PT5305301A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133911	C
2,757	RDCC-53 -PRESS	RDCC-PT5305301B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133912	C
2,758	RDCC-53 -PRESS	RDCC-PT5305302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133924	C
2,759	RDCC-53 -PRESS	RDCC-PT5305401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133755	C
2,760	RDCC-53 -PRESS	RDCC-PT5305404	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133756	C
2,761	RDCC-53 -PRESS	RDCC-PT5305405	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133913	C
2,762	RDCC-53 -PRESS	RDCC-PT5305501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133895	C
2,763	RDCC-53 -PRESS	RDCC-PT5305503	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133896	C
2,764	RDCC-53 -PRESS	RDCC-PT5305505A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y					I								RRC	RRC-IRCP	133757	C
2,765	RDCC-53 -PRESS	RDCC-PT5305505A	PT5305505A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260601	C
2,766	RDCC-53 -PRESS	RDCC-PT5305505B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y					I								RRC	RRC-IRCP	133758	C
2,767	RDCC-53 -PRESS	RDCC-PT5305505B	PT5305505B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260602	C
2,768	RDCC-53 -PRESS	RDCC-PT5305505C	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y					I								RRC	RRC-IRCP	133759	C
2,769	RDCC-53 -PRESS	RDCC-PT5305505C	PT5305505C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260603	C
2,770	RDCC-53 -PRESS	RDCC-PT5305801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133898	C
2,771	RDCC-53 -PRESS	RDCC-PT5305803	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133897	C
2,772	RDCC-53 -PRESS	RDCC-PT5305805	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133760	C
2,773	RDCC-53 -PRESS	RDCC-PT5305901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133899	C
2,774	RDCC-53 -PRESS	RDCC-PT5306202	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133761	C
2,775	RDCC-53 -PRESS	RDCC-PT5306302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133762	C
2,776	RDCC-53 -PRESS	RDCC-PT5306307	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133763	C
2,777	RDCC-53 -PRESS	RDCC-PT5306308	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133764	C
2,778	RDCC-53 -PRESS	RDCC-PT5306401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133765	C
2,779	RDCC-53 -PRESS	RDCC-PT5306402	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133766	C
2,780	RDCC-53 -PRESS	RDCC-PT5306404	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133767	C
2,781	RDCC-53 -PRESS	RDCC-PT5306501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133768	C
2,782	RDCC-53 -PRESS	RDCC-PT5306502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133769	C
2,783	RDCC-53 -PRESS	RDCC-PT5306504	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133770	C
2,784	RDCC-53 -PRESS	RDCC-PT5306505	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133771	C
2,785	RDCC-53 -PRESS	RDCC-PT5306803	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133772	C
2,786	RDCC-53 -PRESS	RDCC-PT5306903	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133773	C
2,787	RDCC-53 -PRESS	RDCC-PT5307001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133774	C
2,788	RDCC-53 -PRESS	RDCC-PT5307002	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133775	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,789	RDCC-53 -PRESS	RDCC-PT5307301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133776	C
2,790	RDCC-53 -PRESS	RDCC-PT5307303	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133777	C
2,791	RDCC-53 -PRESS	RDCC-PT5307304	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133778	C
2,792	RDCC-53 -PRESS	RDCC-PT5307309A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y					I								RRC	RRC-IRCP	133779	C
2,793	RDCC-53 -PRESS	RDCC-PT5307309A	PT5307309A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260604	C
2,794	RDCC-53 -PRESS	RDCC-PT5307309B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y					I								RRC	RRC-IRCP	133780	C
2,795	RDCC-53 -PRESS	RDCC-PT5307309B	PT5307309B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260605	C
2,796	RDCC-53 -PRESS	RDCC-PT5307309C	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y					I								RRC	RRC-IRCP	133781	C
2,797	RDCC-53 -PRESS	RDCC-PT5307309C	PT5307309C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260606	C
2,798	RDCC-53 -PRESS	RDCC-PT5307806	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133782	C
2,799	RDCC-53 -PRESS	RDCC-PT5307807	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133783	C
2,800	RDCC-53 -PRESS	RDCC-PT5307809	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133784	C
2,801	RDCC-53 -PRESS	RDCC-PT5308101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133785	C
2,802	RDCC-53P131	RDCC-PT5308102A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133918	C
2,803	RDCC-53P131	RDCC-PT5308102B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133919	C
2,804	RDCC-53 -PRESS	RDCC-PT5308207	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133786	C
2,805	RDCC-53 -PRESS	RDCC-PT5308208	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133787	C
2,806	RDCC-53 -PRESS	RDCC-PT5308301A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y					I								RRC	RRC-IRCP	133788	C
2,807	RDCC-53 -PRESS	RDCC-PT5308301A	PT5308301A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260607	C
2,808	RDCC-53 -PRESS	RDCC-PT5308301B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y					I								RRC	RRC-IRCP	133789	C
2,809	RDCC-53 -PRESS	RDCC-PT5308301B	PT5308301B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260608	C
2,810	RDCC-53 -PRESS	RDCC-PT5308301C	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y					I								RRC	RRC-IRCP	133790	C
2,811	RDCC-53 -PRESS	RDCC-PT5308301C	PT5308301C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260609	C
2,812	RDCC-53 -PRESS	RDCC-PT5308302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133791	C
2,813	RDCC-53 -PRESS	RDCC-PT5308303	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133792	C
2,814	RDCC-53 -PRESS	RDCC-PT5308307	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133793	C
2,815	RDCC-53P126	RDCC-PT5308502A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133914	C
2,816	RDCC-53P126	RDCC-PT5308502B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133915	C
2,817	RDCC-53 -PRESS	RDCC-PT5308602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133794	C
2,818	RDCC-53 -PRESS	RDCC-PT5308901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133795	C
2,819	RDCC-53 -PRESS	RDCC-PT5309001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133796	C
2,820	RDCC-53 -PRESS	RDCC-PT5309002	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133797	C
2,821	RDCC-53 -PRESS	RDCC-PT5309005	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133798	C
2,822	RDCC-53 -PRESS	RDCC-PT5309006A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y					I								RRC	RRC-IRCP	133799	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,823	RDCC-53 -PRESS	RDCC-PT5309006A	PT5309006A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260610	C
2,824	RDCC-53 -PRESS	RDCC-PT5309006B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y						I							RRC	RRC-IRCP	133800	C
2,825	RDCC-53 -PRESS	RDCC-PT5309006B	PT5309006B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260611	C
2,826	RDCC-53 -PRESS	RDCC-PT5309006C	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y						I							RRC	RRC-IRCP	133801	C
2,827	RDCC-53 -PRESS	RDCC-PT5309006C	PT5309006C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260612	C
2,828	RDCC-53 -PRESS	RDCC-PT5309302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133802	C
2,829	RDCC-53 -PRESS	RDCC-PT5309303	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133803	C
2,830	RDCC-53 -PRESS	RDCC-PT5309312	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133804	C
2,831	RDCC-53 -PRESS	RDCC-PT5309406	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133805	C
2,832	RDCC-53 -PRESS	RDCC-PT5309409	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133806	C
2,833	RDCC-53 -PRESS	RDCC-PT5309501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133807	C
2,834	RDCC-53 -PRESS	RDCC-PT5309502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133808	C
2,835	RDCC-53 -PRESS	RDCC-PT5309504	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133809	C
2,836	RDCC-53 -PRESS	RDCC-PT5309506	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133810	C
2,837	RDCC-53 -PRESS	RDCC-PT5309601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133811	C
2,838	RDCC-53 -PRESS	RDCC-PT5309602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133812	C
2,839	RDCC-53 -PRESS	RDCC-PT5309703	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133813	C
2,840	RDCC-53P129	RDCC-PT5309704A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IRCP	133916	C
2,841	RDCC-53P129	RDCC-PT5309704B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IRCP	133917	C
2,842	RDCC-53 -PRESS	RDCC-PT5309810	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133814	C
2,843	RDCC-53 -PRESS	RDCC-PT5309811	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133815	C
2,844	RDCC-53 -PRESS	RDCC-PT5309901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y						I							RRC	RRC-IRCP	133816	C
2,845	RDCC-53 -PRESS	RDCC-PT5310007A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IRCP	133925	C
2,846	RDCC-53 -PRESS	RDCC-PT5310107B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IRCP	133926	C
2,847	RDCC-53 -PRESS	RDCC-PT5310107C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IRCP	133927	C
2,848	RDCC-53 -PRESS	RDCC-PT5310501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133817	C
2,849	RDCC-53 -PRESS	RDCC-PT5310502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133818	C
2,850	RDCC-53 -PRESS	RDCC-PT5310503	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y					I								RRC	RRC-IRCP	133819	C
2,851	RDCC-53 -PRESS	RDCC-PT5310504A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y					I								RRC	RRC-IRCP	133820	C
2,852	RDCC-53 -PRESS	RDCC-PT5310504A	PT5310504A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260589	C
2,853	RDCC-53 -PRESS	RDCC-PT5310504B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y					I								RRC	RRC-IRCP	133821	C
2,854	RDCC-53 -PRESS	RDCC-PT5310504B	PT5310504B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260590	C
2,855	RDCC-53 -PRESS	RDCC-PT5310504C	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y					I								RRC	RRC-IRCP	133822	C
2,856	RDCC-53 -PRESS	RDCC-PT5310504C	PT5310504C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IRCP	260591	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,857	RDCC-53 -PRESS	RDCC-PT5310505	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y					I								RRC	RRC-IRCP	133823	C
2,858	RDCC-53 -PRESS	RDCC-PT5310506A	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y						I							RRC	RRC-IRCP	133824	C
2,859	RDCC-53 -PRESS	RDCC-PT5310506A	PT5310506A-FULL RUN TEST PT &	PMT	5Y										F			RRC	RRC-IRCP	260592	C
2,860	RDCC-53 -PRESS	RDCC-PT5310506B	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y						I							RRC	RRC-IRCP	133825	C
2,861	RDCC-53 -PRESS	RDCC-PT5310506B	PT5310506B-FULL RUN TEST PT &	PMT	5Y										F			RRC	RRC-IRCP	260593	C
2,862	RDCC-53 -PRESS	RDCC-PT5310506C	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y						I							RRC	RRC-IRCP	133826	C
2,863	RDCC-53 -PRESS	RDCC-PT5310506C	PT5310506C-FULL RUN TEST PT &	PMT	5Y										F			RRC	RRC-IRCP	260594	C
2,864	RDCC-53 -PRESS	RDCC-PT5310601	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133827	C
2,865	RDCC-53 -PRESS	RDCC-PT5310602A	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133828	C
2,866	RDCC-53 -PRESS	RDCC-PT5310602B	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133829	C
2,867	RDCC-53 -PRESS	RDCC-PT5310602C	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133830	C
2,868	RDCC-53 -PRESS	RDCC-PT5310603	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133831	C
2,869	RDCC-53 -PRESS	RDCC-PT5310605	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133832	C
2,870	RDCC-53 -PRESS	RDCC-PT5310606	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133833	C
2,871	RDCC-53 -PRESS	RDCC-PT5311101	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133834	C
2,872	RDCC-53 -PRESS	RDCC-PT5311102	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133835	C
2,873	RDCC-53 -53A002AB	RDCC-PT5311103	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133948	C
2,874	RDCC-53 -53A002AB	RDCC-PT5311104	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133949	C
2,875	RDCC-53 -53E003	RDCC-PT5311830	INSP. FIELD INST.RDCC-PT531183	PMT	1Y		I											RRC	RRC-IRCP	255734	C
2,876	RDCC-53 -53E003	RDCC-PT5311831	INSP. FIELD INST.RDCC-PT531183	PMT	1Y		I											RRC	RRC-IRCP	255735	C
2,877	RDCC-53 -53E003	RDCC-PT5311832	INSP. FIELD INST.RDCC-PT531183	PMT	1Y		I											RRC	RRC-IRCP	255736	C
2,878	RDCC-53 -53E003	RDCC-PT5311840	INSP. FIELD INST.RDCC-PT531184	PMT	1Y		I											RRC	RRC-IRCP	255737	C
2,879	RDCC-53 -53Z028	RDCC-PT5311901	INSP. FIELD INST.RDCC-PT531190	PMT	1Y		I											RRC	RRC-IRCP	255738	C
2,880	RDCC-53 -53Z028	RDCC-PT5311902	INSP. FIELD INST.RDCC-PT531190	PMT	1Y		I											RRC	RRC-IRCP	255739	C
2,881	RDCC-53 -53K002	RDCC-PT5312007	INSP. FIELD INST.RDCC-PT531200	PMT	1Y		I											RRC	RRC-IRCP	255740	C
2,882	RDCC-53 -53D006	RDCC-PT5312101	INSP. FIELD INST.RDCC-PT531210	PMT	1Y		I											RRC	RRC-IRCP	255746	C
2,883	RDCC-53 -53D006	RDCC-PT5312103	INSP. FIELD INST.RDCC-PT531210	PMT	1Y		I											RRC	RRC-IRCP	255741	C
2,884	RDCC-53 -53K002	RDCC-PT5312402A	INSP. FIELD INST.RDCC-PT531240	PMT	1Y										I			RRC	RRC-IRCP	255777	C
2,885	RDCC-53 -53K002	RDCC-PT5312402B	INSP. FIELD INST.RDCC-PT531240	PMT	1Y										I			RRC	RRC-IRCP	255778	C
2,886	RDCC-53 -53K002	RDCC-PT5312402C	INSP. FIELD INST.RDCC-PT531240	PMT	1Y										I			RRC	RRC-IRCP	255779	C
2,887	RDCC-53 -53K002	RDCC-PT5312411	INSP. FIELD INST.RDCC-PT531241	PMT	1Y										I			RRC	RRC-IRCP	255782	C
2,888	RDCC-53 -53K002	RDCC-PT5312412	INSP. FIELD INST.RDCC-PT531241	PMT	1Y										I			RRC	RRC-IRCP	255783	C
2,889	RDCC-53 -53K002	RDCC-PT5312413	INSP. FIELD INST.RDCC-PT531241	PMT	1Y										I			RRC	RRC-IRCP	255784	C
2,890	RDCC-53 -PRESS	RDCC-PT5330101	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133836	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,891	RDCC-53 -PRESS	RDCC-PT5330102	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133837	C
2,892	RDCC-53 -PRESS	RDCC-PT5331101	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133838	C
2,893	RDCC-53 -PRESS	RDCC-PT5331201	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133839	C
2,894	RDCC-53 -PRESS	RDCC-PT5334101	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133840	C
2,895	RDCC-53 -PRESS	RDCC-PT5334102	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133841	C
2,896	RDCC-53 -PRESS	RDCC-PT5335301	INSP. FIELD INST.RDCC-PT533530	PMT	1Y			I										RRC	RRC-IRCP	255742	C
2,897	RDCC-53 -PRESS	RDCC-PT5336102	INSP. FIELD INST.RDCC-PT533610	PMT	1Y			I										RRC	RRC-IRCP	255743	C
2,898	RDCC-53 -PRESS	RDCC-PT5336501	INSP. FIELD INST.RDCC-PT533650	PMT	1Y			I										RRC	RRC-IRCP	255744	C
2,899	RDCC-53 -PRESS	RDCC-PT5337401	INSP. FIELD INST.RDCC-PT533740	PMT	1Y			I										RRC	RRC-IRCP	255745	C
2,900	RDCC-53 -53K001	RDCC-PT5350168	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133842	C
2,901	RDCC-53 -53K001	RDCC-PT5350171	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133843	C
2,902	RDCC-53 -53K001	RDCC-PT5350450A	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133844	C
2,903	RDCC-53 -53K001	RDCC-PT5350450B	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133845	C
2,904	RDCC-53 -53K001	RDCC-PT5350450C	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133846	C
2,905	RDCC-53 -53K001	RDCC-PT5350552	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133847	C
2,906	RDCC-53 -53K101	RDCC-PT5350902A	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133900	C
2,907	RDCC-53 -53K101	RDCC-PT5350902B	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133901	C
2,908	RDCC-53 -53K101	RDCC-PT5350902C	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133902	C
2,909	RDCC-53 -53K101	RDCC-PT5351001	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133903	C
2,910	RDCC-53 -53K101	RDCC-PT5351002	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133848	C
2,911	RDCC-53 -53K101	RDCC-PT5351003	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133904	C
2,912	RDCC-53 -53K101	RDCC-PT5351004	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133849	C
2,913	RDCC-53 -53K101	RDCC-PT5351201	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133906	C
2,914	RDCC-53 -53K101	RDCC-PT5351202	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133907	C
2,915	RDCC-53 -53K101	RDCC-PT5351203	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133908	C
2,916	RDCC-53 -53K101	RDCC-PT5351205	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133909	C
2,917	RDCC-53 -PRESS	RDCC-PT5352425	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133850	C
2,918	RDCC-53 -PRESS	RDCC-PT5352449	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133892	C
2,919	RDCC-53 -PRESS	RDCC-PT5352470	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133893	C
2,920	RDCC-53 -PRESS	RDCC-PT5352501	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133851	C
2,921	RDCC-53 -PRESS	RDCC-PT5352503	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133894	C
2,922	RDCC-53 -PRESS	RDCC-PT5352741	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133852	C
2,923	RDCC-53 -PRESS	RDCC-PT5352742	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133853	C
2,924	RDCC-53 -PRESS	RDCC-PT5352840	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133854	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,925	RDCC-53 -PRESS	RDCC-PT5352985	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133855	C
2,926	RDCC-53 -PRESS	RDCC-PT5352989	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133856	C
2,927	RDCC-53 -PRESS	RDCC-PT5353030	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133857	C
2,928	RDCC-53 -PRESS	RDCC-PT5353031	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133858	C
2,929	RDCC-53 -PRESS	RDCC-PT5353032	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133859	C
2,930	RDCC-53 -PRESS	RDCC-PT5353160	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133860	C
2,931	RDCC-53 -PRESS	RDCC-PT5353161	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133861	C
2,932	RDCC-53 -PRESS	RDCC-PT5353162	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133862	C
2,933	RDCC-53 -PRESS	RDCC-PT5353263	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133863	C
2,934	RDCC-53 -PRESS	RDCC-PT5353264	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133864	C
2,935	RDCC-53 -PRESS	RDCC-PT5353365	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133865	C
2,936	RDCC-53 -PRESS	RDCC-PT5353366	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133866	C
2,937	RDCC-53 -PRESS	RDCC-PT5353467	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133867	C
2,938	RDCC-53 -PRESS	RDCC-PT5353468	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133868	C
2,939	RDCC-53 -PRESS	RDCC-PT5355001	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133869	C
2,940	RDCC-53 -PRESS	RDCC-PT5355002	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133870	C
2,941	RDCC-53 -PRESS	RDCC-PT5355003	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133871	C
2,942	RDCC-53 -PRESS	RDCC-PT5355004	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133872	C
2,943	RDCC-53 -PRESS	RDCC-PT5355101	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133873	C
2,944	RDCC-53 -PRESS	RDCC-PT5355102	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133874	C
2,945	RDCC-53 -PRESS	RDCC-PT5355201	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133875	C
2,946	RDCC-53 -PRESS	RDCC-PT5355202	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133876	C
2,947	RDCC-53 -PRESS	RDCC-PT5360101	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133877	C
2,948	RDCC-53 -PRESS	RDCC-PT5360201	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133878	C
2,949	RDCC-56 -PRESS	RDCC-PT5600102	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133879	C
2,950	RDCC-56 -56P001	RDCC-PT5600202A	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133920	C
2,951	RDCC-56 -56P001	RDCC-PT5600202B	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133921	C
2,952	RDCC-56 -PRESS	RDCC-PT5600301	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133880	C
2,953	RDCC-56 -PRESS	RDCC-PT5600302	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133881	C
2,954	RDCC-56 -56P002	RDCC-PT5600401A	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133922	C
2,955	RDCC-56 -56P002	RDCC-PT5600401B	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133923	C
2,956	RDCC-56 -PRESS	RDCC-PT5600501	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133882	C
2,957	RDCC-56 -PRESS	RDCC-PT5600602	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133883	C
2,958	RDCC-56 -PRESS	RDCC-PT5600603	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IRCP	133884	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,959	RDCC-56 -PRESS	RDCC-PT5600701	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133885	C
2,960	RDCC-56 -PRESS	RDCC-PT5600703	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133886	C
2,961	RDCC-56 -PRESS	RDCC-PT5600801	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133887	C
2,962	RDCC-56 -PRESS	RDCC-PT5601209	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133888	C
2,963	RDCC-56 -PRESS	RDCC-PT5601706	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133889	C
2,964	RDCC-56 -PRESS	RDCC-PT5631101	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133890	C
2,965	RDCC-56 -PRESS	RDCC-PT5634101	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IRCP	133891	C
2,966	RDCC-53 -CV	RDCC-PV5300601	INSPECT CONTROL VALVE NO. PV53	PMT	1Y										I			RRC	RRC-IRCP	134422	C
2,967	RDCC-53 -CV	RDCC-PV5302504A	INSPECT CONTROL VALVE NO. PV53	PMT	1Y										I			RRC	RRC-IRCP	134423	C
2,968	RDCC-53 -CV	RDCC-PV5302504B	INSPECT CONTROL VALVE NO. PV53	PMT	1Y										I			RRC	RRC-IRCP	134424	C
2,969	RDCC-53 -CV	RDCC-PV5305401A	INSPECT CONTROL VALVE NO. PV53	PMT	1Y											I		RRC	RRC-IRCP	134488	C
2,970	RDCC-53 -CV	RDCC-PV5305401B	INSPECT CONTROL VALVE NO. PV53	PMT	1Y											I		RRC	RRC-IRCP	134489	C
2,971	RDCC-53 -CV	RDCC-PV5307301	INSPECT CONTROL VALVE NO. PV53	PMT	1Y											I		RRC	RRC-IRCP	134490	C
2,972	RDCC-53 -CV	RDCC-PV5307807	INSPECT CONTROL VALVE NO. PV53	PMT	1Y										I			RRC	RRC-IRCP	134425	C
2,973	RDCC-53 -CV	RDCC-PV5308208A	INSPECT CONTROL VALVE NO. PV53	PMT	1Y										I			RRC	RRC-IRCP	134426	C
2,974	RDCC-53 -CV	RDCC-PV5308208B	INSPECT CONTROL VALVE NO. PV53	PMT	1Y										I			RRC	RRC-IRCP	134427	C
2,975	RDCC-53 -CV	RDCC-PV5308901A	INSPECT CONTROL VALVE NO. PV53	PMT	1Y										I			RRC	RRC-IRCP	134428	C
2,976	RDCC-53 -CV	RDCC-PV5308901B	INSPECT CONTROL VALVE NO. PV53	PMT	1Y										I			RRC	RRC-IRCP	134429	C
2,977	RDCC-53 -CV	RDCC-PV5309005	INSPECT CONTROL VALVE NO. PV53	PMT	1Y											I		RRC	RRC-IRCP	134491	C
2,978	RDCC-53 -CV	RDCC-PV5309303	INSPECT CONTROL VALVE NO. PV53	PMT	1Y										I			RRC	RRC-IRCP	134430	C
2,979	RDCC-53 -CV	RDCC-PV5309601A	INSPECT CONTROL VALVE NO. PV53	PMT	1Y										I			RRC	RRC-IRCP	134431	C
2,980	RDCC-53 -CV	RDCC-PV5309601B	INSPECT CONTROL VALVE NO. PV53	PMT	1Y										I			RRC	RRC-IRCP	134432	C
2,981	RDCC-53 -CV	RDCC-PV5309811A	INSPECT CONTROL VALVE NO. PV53	PMT	1Y										I			RRC	RRC-IRCP	134433	C
2,982	RDCC-53 -CV	RDCC-PV5309811B	INSPECT CONTROL VALVE NO. PV53	PMT	1Y										I			RRC	RRC-IRCP	134434	C
2,983	RDCC-53 -CV	RDCC-PV5309901	INSPECT CONTROL VALVE NO. PV53	PMT	1Y										I			RRC	RRC-IRCP	134435	C
2,984	RDCC-53 -CV	RDCC-PV5310502	INSPECT CONTROL VALVE NO. PV53	PMT	1Y										I			RRC	RRC-IRCP	134436	C
2,985	RDCC-53 -53D006	RDCC-PV5312103	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y												I	RRC	RRC-IRCP	255808	C
2,986	RDCC-53 -CV	RDCC-PV5353160	INSPECT CONTROL VALVE NO. PV53	PMT	1Y											I		RRC	RRC-IRCP	134492	C
2,987	RDCC-53 -CV	RDCC-PV5353263	INSPECT CONTROL VALVE NO. PV53	PMT	1Y											I		RRC	RRC-IRCP	134493	C
2,988	RDCC-53 -CV	RDCC-PV5353365	INSPECT CONTROL VALVE NO. PV53	PMT	1Y											I		RRC	RRC-IRCP	134494	C
2,989	RDCC-53 -CV	RDCC-PV5353467	INSPECT CONTROL VALVE NO. PV53	PMT	1Y											I		RRC	RRC-IRCP	134495	C
2,990	RDCC-56 -CV	RDCC-PV5600501	INSPECT CONTROL VALVE NO. PV56	PMT	1Y										I			RRC	RRC-IRCP	134437	C
2,991	RDCC-56 -CV	RDCC-PV5600801	INSPECT CONTROL VALVE NO. PV56	PMT	1Y										I			RRC	RRC-IRCP	134438	C
2,992	RDCC-53 -53K002	RDCC-PV5312401	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y												I	RRC	RRC-IRCP	255821	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,993	RDCC-53 -SIS	RDCC-SIS	INSPECT ESD SYSTEM	PMT	3M			I			I			I			I	CCS	CCS-SYS	246460	A
2,994	RDCC-53 -SIS	RDCC-SIS	BACKUP ESD SYSTEM	PMT	6M			I						I				CCS	CCS-SYS	246461	A
2,995	RDCC-53 -SIS	RDCC-SIS	UPDATE ANTIVIRUS ESD SYSTEM	PMT	3M			U			U			U			U	CCS	CCS-SYS	246462	A
2,996	RDCC-53 -TEMP	RDCC-T5335301	INSP. FIELD INST.RDCC-T 533530	PMT	1Y	I												RRC	RRC-IRCP	255727	C
2,997	RDCC-53 -53K002	RDCC-TCV5312410	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y												I	RRC	RRC-IRCP	255817	C
2,998	RDCC-53 -53K101	RDCC-TT5250506	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y									I				RRC	RRC-IRCP	134254	C
2,999	RDCC-53 -TEMP	RDCC-TT5300301	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133952	C
3,000	RDCC-53 -TEMP	RDCC-TT5300302	INSP. FIELD INST. (ตัดชุมไกรณ์)	INS	1Y							I						RRC	RRC-IRCP	133953	C
3,001	RDCC-53 -TEMP	RDCC-TT5300302	TT5300302-FULLFUN TEST TEMP.TR	PMT	5Y											F		RRC	RRC-IRCP	261271	C
3,002	RDCC-53 -TEMP	RDCC-TT5300421	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133954	C
3,003	RDCC-53 -TEMP	RDCC-TT5300422	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133955	C
3,004	RDCC-53 -TEMP	RDCC-TT5300423	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133956	C
3,005	RDCC-53 -TEMP	RDCC-TT5300424	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133957	C
3,006	RDCC-53 -TEMP	RDCC-TT5300425	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133958	C
3,007	RDCC-53 -TEMP	RDCC-TT5300426	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133959	C
3,008	RDCC-53 -TEMP	RDCC-TT5300427	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133960	C
3,009	RDCC-53 -TEMP	RDCC-TT5300428	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133961	C
3,010	RDCC-53 -TEMP	RDCC-TT5300429	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133962	C
3,011	RDCC-53 -TEMP	RDCC-TT5300430	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133963	C
3,012	RDCC-53 -TEMP	RDCC-TT5300431	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133964	C
3,013	RDCC-53 -TEMP	RDCC-TT5300432	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133965	C
3,014	RDCC-53 -TEMP	RDCC-TT5300501A	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133966	C
3,015	RDCC-53 -TEMP	RDCC-TT5300501B	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133967	C
3,016	RDCC-53 -TEMP	RDCC-TT5300501C	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133968	C
3,017	RDCC-53 -TEMP	RDCC-TT5300501D	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133969	C
3,018	RDCC-53 -TEMP	RDCC-TT5300502A	INSP. FIELD INST. (ตัดชุมไกรณ์)	INS	1Y							I						RRC	RRC-IRCP	133970	C
3,019	RDCC-53 -TEMP	RDCC-TT5300502A	TT5300502A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261272	C
3,020	RDCC-53 -TEMP	RDCC-TT5300502B	INSP. FIELD INST. (ตัดชุมไกรณ์)	INS	1Y							I						RRC	RRC-IRCP	133971	C
3,021	RDCC-53 -TEMP	RDCC-TT5300502B	TT5300502B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261273	C
3,022	RDCC-53 -TEMP	RDCC-TT5300502C	INSP. FIELD INST. (ตัดชุมไกรณ์)	INS	1Y							I						RRC	RRC-IRCP	133972	C
3,023	RDCC-53 -TEMP	RDCC-TT5300502C	TT5300502C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261274	C
3,024	RDCC-53 -TEMP	RDCC-TT5300502D	INSP. FIELD INST. (ตัดชุมไกรณ์)	INS	1Y							I						RRC	RRC-IRCP	133973	C
3,025	RDCC-53 -TEMP	RDCC-TT5300502D	TT5300502D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261275	C
3,026	RDCC-53 -TEMP	RDCC-TT5300510	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133974	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,027	RDCC-53 -TEMP	RDCC-TT5300515	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133975	C
3,028	RDCC-53 -TEMP	RDCC-TT5300516	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133976	C
3,029	RDCC-53 -TEMP	RDCC-TT5300517	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133977	C
3,030	RDCC-53 -TEMP	RDCC-TT5300518	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133978	C
3,031	RDCC-53 -53Q001	RDCC-TT5300540	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y									I				RRC	RRC-IRCP	134274	C
3,032	RDCC-53 -53Q003	RDCC-TT5300561	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y									I				RRC	RRC-IRCP	134276	C
3,033	RDCC-53 -53Q004	RDCC-TT5300581	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y									I				RRC	RRC-IRCP	134277	C
3,034	RDCC-53 -TEMP	RDCC-TT5300601	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133979	C
3,035	RDCC-53 -TEMP	RDCC-TT5300602	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133980	C
3,036	RDCC-53 -TEMP	RDCC-TT5301101	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133981	C
3,037	RDCC-53 -TEMP	RDCC-TT5301106	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133982	C
3,038	RDCC-53 -TEMP	RDCC-TT5301107	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133983	C
3,039	RDCC-53 -TEMP	RDCC-TT5301108	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133984	C
3,040	RDCC-53 -TEMP	RDCC-TT5301109	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133985	C
3,041	RDCC-53 -TEMP	RDCC-TT5301201A	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133986	C
3,042	RDCC-53 -TEMP	RDCC-TT5301201B	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133987	C
3,043	RDCC-53 -TEMP	RDCC-TT5301201C	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133988	C
3,044	RDCC-53 -TEMP	RDCC-TT5301201D	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133989	C
3,045	RDCC-53 -TEMP	RDCC-TT5301202A	INSP. FIELD INST. (ตัดชุมไกรณ์)	INS	1Y							I						RRC	RRC-IRCP	133990	C
3,046	RDCC-53 -TEMP	RDCC-TT5301202A	TT5301202A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261276	C
3,047	RDCC-53 -TEMP	RDCC-TT5301202B	INSP. FIELD INST. (ตัดชุมไกรณ์)	INS	1Y							I						RRC	RRC-IRCP	133991	C
3,048	RDCC-53 -TEMP	RDCC-TT5301202B	TT5301202B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261277	C
3,049	RDCC-53 -TEMP	RDCC-TT5301202C	INSP. FIELD INST. (ตัดชุมไกรณ์)	INS	1Y							I						RRC	RRC-IRCP	133992	C
3,050	RDCC-53 -TEMP	RDCC-TT5301202C	TT5301202C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261278	C
3,051	RDCC-53 -TEMP	RDCC-TT5301202D	INSP. FIELD INST. (ตัดชุมไกรณ์)	INS	1Y							I						RRC	RRC-IRCP	133993	C
3,052	RDCC-53 -TEMP	RDCC-TT5301202D	TT5301202D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IRCP	261279	C
3,053	RDCC-53 -TEMP	RDCC-TT5301203	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133994	C
3,054	RDCC-53 -TEMP	RDCC-TT5301204	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133995	C
3,055	RDCC-53 -TEMP	RDCC-TT5301205	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133996	C
3,056	RDCC-53 -53Q002	RDCC-TT5301240	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y									I				RRC	RRC-IRCP	134275	C
3,057	RDCC-53 -TEMP	RDCC-TT5301301	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133997	C
3,058	RDCC-53 -TEMP	RDCC-TT5301302	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133998	C
3,059	RDCC-53 -TEMP	RDCC-TT5301303	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	133999	C
3,060	RDCC-53 -TEMP	RDCC-TT5301305	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134000	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,061	RDCC-53 -TEMP	RDCC-TT5301306	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134001	C
3,062	RDCC-53 -TEMP	RDCC-TT5301307	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134002	C
3,063	RDCC-53 -TEMP	RDCC-TT5301308	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134003	C
3,064	RDCC-53 -TEMP	RDCC-TT5301309	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134004	C
3,065	RDCC-53 -TEMP	RDCC-TT5301310	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134005	C
3,066	RDCC-53 -TEMP	RDCC-TT5301502	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134006	C
3,067	RDCC-53 -TEMP	RDCC-TT5301601	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134007	C
3,068	RDCC-53 -TEMP	RDCC-TT5301602	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134008	C
3,069	RDCC-53 -TEMP	RDCC-TT5301701	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134009	C
3,070	RDCC-53 -TEMP	RDCC-TT5301702	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134010	C
3,071	RDCC-53 -TEMP	RDCC-TT5301801	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134011	C
3,072	RDCC-53 -TEMP	RDCC-TT5302001	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134012	C
3,073	RDCC-53 -TEMP	RDCC-TT5302501	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134013	C
3,074	RDCC-53 -TEMP	RDCC-TT5302504	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134014	C
3,075	RDCC-53 -TEMP	RDCC-TT5302701	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134015	C
3,076	RDCC-53 -TEMP	RDCC-TT5302702	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134016	C
3,077	RDCC-53 -TEMP	RDCC-TT5302703	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134017	C
3,078	RDCC-53 -TEMP	RDCC-TT5302704	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134018	C
3,079	RDCC-53 -TEMP	RDCC-TT5302717	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134019	C
3,080	RDCC-53 -TEMP	RDCC-TT5302718	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134020	C
3,081	RDCC-53 -TEMP	RDCC-TT5302719	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134021	C
3,082	RDCC-53 -TEMP	RDCC-TT5302720	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134022	C
3,083	RDCC-53 -TEMP	RDCC-TT5302721A	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134023	C
3,084	RDCC-53 -TEMP	RDCC-TT5302721B	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134024	C
3,085	RDCC-53 -TEMP	RDCC-TT5302721C	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134025	C
3,086	RDCC-53 -TEMP	RDCC-TT5302722	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134026	C
3,087	RDCC-53 -TEMP	RDCC-TT5302801	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134027	C
3,088	RDCC-53 -TEMP	RDCC-TT5302806	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134028	C
3,089	RDCC-53 -TEMP	RDCC-TT5302807	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134029	C
3,090	RDCC-53 -TEMP	RDCC-TT5302808	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134030	C
3,091	RDCC-53 -TEMP	RDCC-TT5302909	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134031	C
3,092	RDCC-53 -TEMP	RDCC-TT5302911	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134032	C
3,093	RDCC-53 -TEMP	RDCC-TT5302912	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134033	C
3,094	RDCC-53 -TEMP	RDCC-TT5303301	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134034	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,095	RDCC-53 -TEMP	RDCC-TT5303303	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134035	C
3,096	RDCC-53 -TEMP	RDCC-TT5303401	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134036	C
3,097	RDCC-53 -TEMP	RDCC-TT5303502	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134037	C
3,098	RDCC-53 -TEMP	RDCC-TT5303509	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134038	C
3,099	RDCC-53 -TEMP	RDCC-TT5303510	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134039	C
3,100	RDCC-53 -TEMP	RDCC-TT5303602	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134040	C
3,101	RDCC-53 -TEMP	RDCC-TT5303704	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134041	C
3,102	RDCC-53 -TEMP	RDCC-TT5303705	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134042	C
3,103	RDCC-53 -TEMP	RDCC-TT5303706	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134043	C
3,104	RDCC-53 -TEMP	RDCC-TT5303712	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134044	C
3,105	RDCC-53 -TEMP	RDCC-TT5303901	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134045	C
3,106	RDCC-53 -TEMP	RDCC-TT5303918	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134046	C
3,107	RDCC-53 -TEMP	RDCC-TT5303919	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134047	C
3,108	RDCC-53 -TEMP	RDCC-TT5303920	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134048	C
3,109	RDCC-53 -TEMP	RDCC-TT5303921	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134049	C
3,110	RDCC-53 -TEMP	RDCC-TT5303922	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134050	C
3,111	RDCC-53 -TEMP	RDCC-TT5304004	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134051	C
3,112	RDCC-53 -TEMP	RDCC-TT5304006	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134052	C
3,113	RDCC-53 -TEMP	RDCC-TT5304008	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134053	C
3,114	RDCC-53 -TEMP	RDCC-TT5304010	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134054	C
3,115	RDCC-53 -TEMP	RDCC-TT5304011	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134055	C
3,116	RDCC-53 -TEMP	RDCC-TT5304101	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134056	C
3,117	RDCC-53 -TEMP	RDCC-TT5304102	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134057	C
3,118	RDCC-53 -TEMP	RDCC-TT5304104	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134058	C
3,119	RDCC-53 -TEMP	RDCC-TT5304107	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134059	C
3,120	RDCC-53 -TEMP	RDCC-TT5304202	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134060	C
3,121	RDCC-53 -TEMP	RDCC-TT5304205	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134061	C
3,122	RDCC-53 -TEMP	RDCC-TT5304207	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134062	C
3,123	RDCC-53 -TEMP	RDCC-TT5304208	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134063	C
3,124	RDCC-53 -TEMP	RDCC-TT5304302	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134064	C
3,125	RDCC-53 -TEMP	RDCC-TT5304303	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134065	C
3,126	RDCC-53 -TEMP	RDCC-TT5304501	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134066	C
3,127	RDCC-53 -TEMP	RDCC-TT5304503	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134067	C
3,128	RDCC-53 -TEMP	RDCC-TT5304701	INSP. FIELD INST. (ตัดชุมไกรณ์)	PMT	1Y							I						RRC	RRC-IRCP	134068	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,129	RDCC-53 -TEMP	RDCC-TT5304705	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IRCP	134069	C
3,130	RDCC-53 -TEMP	RDCC-TT5304706	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IRCP	134070	C
3,131	RDCC-53 -TEMP	RDCC-TT5304707	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IRCP	134071	C
3,132	RDCC-53 -TEMP	RDCC-TT5304801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IRCP	134072	C
3,133	RDCC-53 -TEMP	RDCC-TT5304818	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y							I						RRC	RRC-IRCP	134073	C
3,134	RDCC-53 -TEMP	RDCC-TT5304901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134074	C
3,135	RDCC-53 -TEMP	RDCC-TT5305001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134075	C
3,136	RDCC-53 -TEMP	RDCC-TT5305117	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134076	C
3,137	RDCC-53 -TEMP	RDCC-TT5305201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134077	C
3,138	RDCC-53 -TEMP	RDCC-TT5305203	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134078	C
3,139	RDCC-53 -53P110	RDCC-TT5305301A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	134260	C
3,140	RDCC-53 -53P110	RDCC-TT5305301B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	134261	C
3,141	RDCC-53 -53P111	RDCC-TT5305302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	134273	C
3,142	RDCC-53 -TEMP	RDCC-TT5305401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134079	C
3,143	RDCC-53 -53P113	RDCC-TT5305405	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	134262	C
3,144	RDCC-53 -53K101	RDCC-TT5305501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	134249	C
3,145	RDCC-53 -53K101	RDCC-TT5305502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	134250	C
3,146	RDCC-53 -TEMP	RDCC-TT5305617	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134080	C
3,147	RDCC-53 -TEMP	RDCC-TT5305628	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134081	C
3,148	RDCC-53 -TEMP	RDCC-TT5305629	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134082	C
3,149	RDCC-53 -53K101	RDCC-TT5305801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	134251	C
3,150	RDCC-53 -53K101	RDCC-TT5305802	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	134252	C
3,151	RDCC-53 -TEMP	RDCC-TT5306201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134083	C
3,152	RDCC-53 -TEMP	RDCC-TT5306218	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134084	C
3,153	RDCC-53 -TEMP	RDCC-TT5306219	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134085	C
3,154	RDCC-53 -TEMP	RDCC-TT5306220	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134086	C
3,155	RDCC-53 -TEMP	RDCC-TT5306301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134087	C
3,156	RDCC-53 -TEMP	RDCC-TT5306302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134088	C
3,157	RDCC-53 -TEMP	RDCC-TT5306304	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134089	C
3,158	RDCC-53 -TEMP	RDCC-TT5306401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134090	C
3,159	RDCC-53 -TEMP	RDCC-TT5306404	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134091	C
3,160	RDCC-53 -TEMP	RDCC-TT5306406	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134092	C
3,161	RDCC-53 -TEMP	RDCC-TT5306407	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134093	C
3,162	RDCC-53 -TEMP	RDCC-TT5306501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134094	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,163	RDCC-53 -TEMP	RDCC-TT5306502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134095	C
3,164	RDCC-53 -TEMP	RDCC-TT5306503	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134096	C
3,165	RDCC-53 -TEMP	RDCC-TT5306504	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134097	C
3,166	RDCC-53 -TEMP	RDCC-TT5306602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134098	C
3,167	RDCC-53 -TEMP	RDCC-TT5306605	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134099	C
3,168	RDCC-53 -TEMP	RDCC-TT5306702	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134100	C
3,169	RDCC-53 -TEMP	RDCC-TT5306705	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134101	C
3,170	RDCC-53 -TEMP	RDCC-TT5306801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134102	C
3,171	RDCC-53 -TEMP	RDCC-TT5306803	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134103	C
3,172	RDCC-53 -TEMP	RDCC-TT5306808	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134104	C
3,173	RDCC-53 -TEMP	RDCC-TT5306814	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134105	C
3,174	RDCC-53 -TEMP	RDCC-TT5306902	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134106	C
3,175	RDCC-53 -TEMP	RDCC-TT5306903	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134107	C
3,176	RDCC-53 -TEMP	RDCC-TT5307001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134108	C
3,177	RDCC-53 -TEMP	RDCC-TT5307002	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134109	C
3,178	RDCC-53 -TEMP	RDCC-TT5307003	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134110	C
3,179	RDCC-53 -TEMP	RDCC-TT5307004	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134111	C
3,180	RDCC-53 -TEMP	RDCC-TT5307306	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134112	C
3,181	RDCC-53 -TEMP	RDCC-TT5307317	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134113	C
3,182	RDCC-53 -TEMP	RDCC-TT5307318	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134114	C
3,183	RDCC-53 -TEMP	RDCC-TT5307319	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134115	C
3,184	RDCC-53 -TEMP	RDCC-TT5307320	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134116	C
3,185	RDCC-53 -TEMP	RDCC-TT5307407	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134117	C
3,186	RDCC-53 -TEMP	RDCC-TT5307408	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134118	C
3,187	RDCC-53 -TEMP	RDCC-TT5307501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134119	C
3,188	RDCC-53 -TEMP	RDCC-TT5307502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134120	C
3,189	RDCC-53 -TEMP	RDCC-TT5307510	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134121	C
3,190	RDCC-53 -TEMP	RDCC-TT5307511	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134122	C
3,191	RDCC-53 -TEMP	RDCC-TT5307512	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134123	C
3,192	RDCC-53 -TEMP	RDCC-TT5307514	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134124	C
3,193	RDCC-53 -TEMP	RDCC-TT5307515	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134125	C
3,194	RDCC-53 -TEMP	RDCC-TT5307609	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134126	C
3,195	RDCC-53 -TEMP	RDCC-TT5307610	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134127	C
3,196	RDCC-53 -TEMP	RDCC-TT5307611	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134128	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,197	RDCC-53 -TEMP	RDCC-TT5307717	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134129	C
3,198	RDCC-53 -TEMP	RDCC-TT5307802	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134130	C
3,199	RDCC-53 -TEMP	RDCC-TT5307803	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134131	C
3,200	RDCC-53 -TEMP	RDCC-TT5307805	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134132	C
3,201	RDCC-53 -TEMP	RDCC-TT5308001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134133	C
3,202	RDCC-53 -TEMP	RDCC-TT5308002	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134134	C
3,203	RDCC-53 -TEMP	RDCC-TT5308003	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134135	C
3,204	RDCC-53 -TEMP	RDCC-TT5308101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134136	C
3,205	RDCC-53 -53P131	RDCC-TT5308102A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	134267	C
3,206	RDCC-53 -53P131	RDCC-TT5308102B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	134268	C
3,207	RDCC-53 -TEMP	RDCC-TT5308201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134137	C
3,208	RDCC-53 -TEMP	RDCC-TT5308301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134138	C
3,209	RDCC-53 -TEMP	RDCC-TT5308302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134139	C
3,210	RDCC-53 -TEMP	RDCC-TT5308303	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134140	C
3,211	RDCC-53 -TEMP	RDCC-TT5308304	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134141	C
3,212	RDCC-53 -TEMP	RDCC-TT5308305	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134142	C
3,213	RDCC-53 -TEMP	RDCC-TT5308306	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134143	C
3,214	RDCC-53 -TEMP	RDCC-TT5308409	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134144	C
3,215	RDCC-53 -TEMP	RDCC-TT5308410	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134145	C
3,216	RDCC-53 -TEMP	RDCC-TT5308411	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134146	C
3,217	RDCC-53 -TEMP	RDCC-TT5308501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134147	C
3,218	RDCC-53 -53P126	RDCC-TT5308502A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	134263	C
3,219	RDCC-53 -53P126	RDCC-TT5308502B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	134264	C
3,220	RDCC-53 -TEMP	RDCC-TT5308601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134148	C
3,221	RDCC-53 -TEMP	RDCC-TT5308602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134149	C
3,222	RDCC-53 -TEMP	RDCC-TT5308603	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134150	C
3,223	RDCC-53 -TEMP	RDCC-TT5308901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134151	C
3,224	RDCC-53 -TEMP	RDCC-TT5309006	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134152	C
3,225	RDCC-53 -TEMP	RDCC-TT5309113	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134153	C
3,226	RDCC-53 -TEMP	RDCC-TT5309114	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134154	C
3,227	RDCC-53 -TEMP	RDCC-TT5309115	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134155	C
3,228	RDCC-53 -TEMP	RDCC-TT5309116	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134156	C
3,229	RDCC-53 -TEMP	RDCC-TT5309117	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134157	C
3,230	RDCC-53 -TEMP	RDCC-TT5309118	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134158	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,231	RDCC-53 -TEMP	RDCC-TT5309217	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134159	C
3,232	RDCC-53 -TEMP	RDCC-TT5309302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134160	C
3,233	RDCC-53 -TEMP	RDCC-TT5309303	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134161	C
3,234	RDCC-53 -TEMP	RDCC-TT5309304	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134162	C
3,235	RDCC-53 -TEMP	RDCC-TT5309401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134163	C
3,236	RDCC-53 -TEMP	RDCC-TT5309404	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134164	C
3,237	RDCC-53 -TEMP	RDCC-TT5309410	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134165	C
3,238	RDCC-53 -TEMP	RDCC-TT5309411	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134166	C
3,239	RDCC-53 -TEMP	RDCC-TT5309501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134167	C
3,240	RDCC-53 -TEMP	RDCC-TT5309502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134168	C
3,241	RDCC-53 -TEMP	RDCC-TT5309503	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134169	C
3,242	RDCC-53 -TEMP	RDCC-TT5309504	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134170	C
3,243	RDCC-53 -TEMP	RDCC-TT5309506	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134171	C
3,244	RDCC-53 -TEMP	RDCC-TT5309507	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134172	C
3,245	RDCC-53 -TEMP	RDCC-TT5309602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134173	C
3,246	RDCC-53 -TEMP	RDCC-TT5309701	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134174	C
3,247	RDCC-53 -TEMP	RDCC-TT5309702	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134175	C
3,248	RDCC-53 -53P129	RDCC-TT5309704A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	134265	C
3,249	RDCC-53 -53P129	RDCC-TT5309704B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y									I				RRC	RRC-IRCP	134266	C
3,250	RDCC-53 -TEMP	RDCC-TT5309801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134176	C
3,251	RDCC-53 -TEMP	RDCC-TT5309804	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134177	C
3,252	RDCC-53 -TEMP	RDCC-TT5310001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134178	C
3,253	RDCC-53 -TEMP	RDCC-TT5310101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134179	C
3,254	RDCC-53 -TEMP	RDCC-TT5310501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134180	C
3,255	RDCC-53 -TEMP	RDCC-TT5310601A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	134181	C
3,256	RDCC-53 -TEMP	RDCC-TT5310601A	TT5310601A-FULLFUN TEST TEMP.T	PMT	5Y										F			RRC	RRC-IRCP	261280	C
3,257	RDCC-53 -TEMP	RDCC-TT5310601B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	134182	C
3,258	RDCC-53 -TEMP	RDCC-TT5310601B	TT5310601B-FULLFUN TEST TEMP.T	PMT	5Y										F			RRC	RRC-IRCP	261281	C
3,259	RDCC-53 -TEMP	RDCC-TT5310601C	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y								I					RRC	RRC-IRCP	134183	C
3,260	RDCC-53 -TEMP	RDCC-TT5310601C	TT5310601C-FULLFUN TEST TEMP.T	PMT	5Y										F			RRC	RRC-IRCP	261282	C
3,261	RDCC-53 -TEMP	RDCC-TT5310602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134184	C
3,262	RDCC-53 -TEMP	RDCC-TT5310603	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134185	C
3,263	RDCC-53 -TEMP	RDCC-TT5310604	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y								I					RRC	RRC-IRCP	134186	C
3,264	RDCC-53 -53E003	RDCC-TT5311801	INSP. FIELD INST.RDCC-TT.531180	PMT	1Y	I												RRC	RRC-IRCP	255711	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT : RDCC YEAR : 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,265	RDCC-53 -53E003	RDCC-TT5311826	INSP. FIELD INST.RDCC-TT531182	PMT	1Y	I												RRC	RRC-IRCP	255712	C
3,266	RDCC-53 -53E003	RDCC-TT5311827	INSP. FIELD INST.RDCC-TT531182	PMT	1Y	I												RRC	RRC-IRCP	255713	C
3,267	RDCC-53 -53E003	RDCC-TT5311828	INSP. FIELD INST.RDCC-TT531182	PMT	1Y	I												RRC	RRC-IRCP	255714	C
3,268	RDCC-53 -53E003	RDCC-TT5311829	INSP. FIELD INST.RDCC-TT531182	PMT	1Y	I												RRC	RRC-IRCP	255715	C
3,269	RDCC-53 -53E003	RDCC-TT5311830	INSP. FIELD INST.RDCC-TT531183	PMT	1Y	I												RRC	RRC-IRCP	255716	C
3,270	RDCC-53 -53E003	RDCC-TT5311831	INSP. FIELD INST.RDCC-TT531183	PMT	1Y	I												RRC	RRC-IRCP	255717	C
3,271	RDCC-53 -53E003	RDCC-TT5311832	INSP. FIELD INST.RDCC-TT531183	PMT	1Y	I												RRC	RRC-IRCP	255718	C
3,272	RDCC-53 -53E003	RDCC-TT5311833	INSP. FIELD INST.RDCC-TT531183	PMT	1Y	I												RRC	RRC-IRCP	255719	C
3,273	RDCC-53 -53E003	RDCC-TT5311834	INSP. FIELD INST.RDCC-TT531183	PMT	1Y	I												RRC	RRC-IRCP	255720	C
3,274	RDCC-53 -53Z027	RDCC-TT5311836	INSP. FIELD INST.RDCC-TT531183	PMT	1Y	I												RRC	RRC-IRCP	255721	C
3,275	RDCC-53 -53Z028	RDCC-TT5311837	INSP. FIELD INST.RDCC-TT531183	PMT	1Y	I												RRC	RRC-IRCP	255722	C
3,276	RDCC-53 -53Z028	RDCC-TT5311838	INSP. FIELD INST.RDCC-TT531183	PMT	1Y	I												RRC	RRC-IRCP	255723	C
3,277	RDCC-53 -53E003	RDCC-TT5311840	INSP. FIELD INST.RDCC-TT531184	PMT	1Y	I												RRC	RRC-IRCP	255724	C
3,278	RDCC-53 -53K002	RDCC-TT5312007	INSP. FIELD INST.RDCC-TT531200	PMT	1Y	I												RRC	RRC-IRCP	255725	C
3,279	RDCC-53 -53D006	RDCC-TT5312109	INSP. FIELD INST.RDCC-TT531210	PMT	1Y	I												RRC	RRC-IRCP	255726	C
3,280	RDCC-53 -53K002	RDCC-TT5312401	INSP. FIELD INST.RDCC-TT531240	PMT	1Y										I			RRC	RRC-IRCP	255780	C
3,281	RDCC-53 -53K002	RDCC-TT5312402	INSP. FIELD INST.RDCC-TT531240	PMT	1Y										I			RRC	RRC-IRCP	255781	C
3,282	RDCC-53 -53K002	RDCC-TT5312408	INSP. FIELD INST.RDCC-TT531240	PMT	1Y										I			RRC	RRC-IRCP	255774	C
3,283	RDCC-53 -TEMP	RDCC-TT5330101	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y								I					RRC	RRC-IRCP	134187	C
3,284	RDCC-53 -TEMP	RDCC-TT5330102	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y								I					RRC	RRC-IRCP	134188	C
3,285	RDCC-53 -TEMP	RDCC-TT5331101	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y								I					RRC	RRC-IRCP	134189	C
3,286	RDCC-53 -TEMP	RDCC-TT5331201	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y								I					RRC	RRC-IRCP	134190	C
3,287	RDCC-53 -TEMP	RDCC-TT5334101	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y								I					RRC	RRC-IRCP	134191	C
3,288	RDCC-53 -TEMP	RDCC-TT5334102	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y								I					RRC	RRC-IRCP	134192	C
3,289	RDCC-53 -TEMP	RDCC-TT5336102	INSP. FIELD INST.RDCC-TT533610	PMT	1Y	I												RRC	RRC-IRCP	255728	C
3,290	RDCC-53 -TEMP	RDCC-TT5336501	INSP. FIELD INST.RDCC-TT533650	PMT	1Y	I												RRC	RRC-IRCP	255729	C
3,291	RDCC-53 -TEMP	RDCC-TT5337401	INSP. FIELD INST.RDCC-TT533740	PMT	1Y	I												RRC	RRC-IRCP	255730	C
3,292	RDCC-53 -TEMP	RDCC-TT5340105	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y								I					RRC	RRC-IRCP	134193	C
3,293	RDCC-53 -TEMP	RDCC-TT5340106	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y								I					RRC	RRC-IRCP	134194	C
3,294	RDCC-53 -53K001	RDCC-TT5350182	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134256	C
3,295	RDCC-53 -53K001	RDCC-TT5350183A	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134257	C
3,296	RDCC-53 -53K001	RDCC-TT5350183B	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134258	C
3,297	RDCC-53 -53K001	RDCC-TT5350575	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134259	C
3,298	RDCC-53 -53K101	RDCC-TT5351005	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134253	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT : RDCC YEAR : 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,299	RDCC-53 -53K101	RDCC-TT5351206	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134255	C
3,300	RDCC-53 -TEMP	RDCC-TT5352402A	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134231	C
3,301	RDCC-53 -TEMP	RDCC-TT5352402B	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134232	C
3,302	RDCC-53 -TEMP	RDCC-TT5352403	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134222	C
3,303	RDCC-53 -TEMP	RDCC-TT5352404	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134223	C
3,304	RDCC-53 -TEMP	RDCC-TT5352405	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134224	C
3,305	RDCC-53 -TEMP	RDCC-TT5352408	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134225	C
3,306	RDCC-53 -TEMP	RDCC-TT5352426	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134226	C
3,307	RDCC-53 -TEMP	RDCC-TT5352429	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134227	C
3,308	RDCC-53 -TEMP	RDCC-TT5352430	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134228	C
3,309	RDCC-53 -TEMP	RDCC-TT5352440	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134229	C
3,310	RDCC-53 -TEMP	RDCC-TT5352485	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134230	C
3,311	RDCC-53 -TEMP	RDCC-TT5352501	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134233	C
3,312	RDCC-53 -TEMP	RDCC-TT5352506	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134234	C
3,313	RDCC-53 -TEMP	RDCC-TT5352507	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134235	C
3,314	RDCC-53 -TEMP	RDCC-TT5352509	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134236	C
3,315	RDCC-53 -TEMP	RDCC-TT5352983	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134237	C
3,316	RDCC-53 -TEMP	RDCC-TT5352984	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134238	C
3,317	RDCC-53 -TEMP	RDCC-TT5352985	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134239	C
3,318	RDCC-53 -TEMP	RDCC-TT5353030	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134240	C
3,319	RDCC-53 -TEMP	RDCC-TT5353031A	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134241	C
3,320	RDCC-53 -TEMP	RDCC-TT5353031B	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134242	C
3,321	RDCC-53 -TEMP	RDCC-TT5353031C	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134243	C
3,322	RDCC-53 -TEMP	RDCC-TT5353032	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134244	C
3,323	RDCC-53 -TEMP	RDCC-TT5353160	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134245	C
3,324	RDCC-53 -TEMP	RDCC-TT5353261	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134246	C
3,325	RDCC-53 -TEMP	RDCC-TT5353362	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134247	C
3,326	RDCC-53 -TEMP	RDCC-TT5353467	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134248	C
3,327	RDCC-53 -TEMP	RDCC-TT5384501	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y								I					RRC	RRC-IRCP	134195	C
3,328	RDCC-56 -TEMP	RDCC-TT5600101	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y								I					RRC	RRC-IRCP	134196	C
3,329	RDCC-56 -TEMP	RDCC-TT5600102	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y								I					RRC	RRC-IRCP	134197	C
3,330	RDCC-56 -TEMP	RDCC-TT5600104	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y								I					RRC	RRC-IRCP	134198	C
3,331	RDCC-56 -TEMP	RDCC-TT5600201	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134199	C
3,332	RDCC-56 -56P001	RDCC-TT5600202A	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134269	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT : RDCC YEAR : 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,333	RDCC-56 -56P001	RDCC-TT5600202B	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134270	C
3,334	RDCC-56 -TEMP	RDCC-TT5600301	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134200	C
3,335	RDCC-56 -56P002	RDCC-TT5600401A	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134271	C
3,336	RDCC-56 -56P002	RDCC-TT5600401B	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134272	C
3,337	RDCC-56 -TEMP	RDCC-TT5600501	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134201	C
3,338	RDCC-56 -TEMP	RDCC-TT5600601	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134202	C
3,339	RDCC-56 -TEMP	RDCC-TT5600602	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134203	C
3,340	RDCC-56 -TEMP	RDCC-TT5600603	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134204	C
3,341	RDCC-56 -TEMP	RDCC-TT5600701	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134205	C
3,342	RDCC-56 -TEMP	RDCC-TT5600702	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134206	C
3,343	RDCC-56 -TEMP	RDCC-TT5600703	INSP. FIELD INST. (ต้องปรับหน้า)	INS	1Y									I				RRC	RRC-IRCP	134207	C
3,344	RDCC-56 -TEMP	RDCC-TT5600703	TT5600703-FULLFUN TEST TEMP TR	PMT	5Y											F		RRC	RRC-IRCP	261337	C
3,345	RDCC-56 -TEMP	RDCC-TT5600801	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134208	C
3,346	RDCC-56 -TEMP	RDCC-TT5600901	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134209	C
3,347	RDCC-56 -TEMP	RDCC-TT5601001	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134210	C
3,348	RDCC-56 -TEMP	RDCC-TT5601101	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134211	C
3,349	RDCC-56 -TEMP	RDCC-TT5601102	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134212	C
3,350	RDCC-56 -TEMP	RDCC-TT5601201	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134213	C
3,351	RDCC-56 -TEMP	RDCC-TT5601202	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134214	C
3,352	RDCC-56 -TEMP	RDCC-TT5601301	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134215	C
3,353	RDCC-56 -TEMP	RDCC-TT5601501	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134216	C
3,354	RDCC-56 -TEMP	RDCC-TT5601601	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134217	C
3,355	RDCC-56 -TEMP	RDCC-TT5601701	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134218	C
3,356	RDCC-56 -TEMP	RDCC-TT5601702	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134219	C
3,357	RDCC-56 -TEMP	RDCC-TT5631101	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134220	C
3,358	RDCC-56 -TEMP	RDCC-TT5634101	INSP. FIELD INST. (ต้องปรับหน้า)	PMT	1Y									I				RRC	RRC-IRCP	134221	C
3,359	RDCC-53 -CV	RDCC-TV5301101	INSPECT CONTROL VALVE NO. TV53	PMT	1Y											I		RRC	RRC-IRCP	134498	C
3,360	RDCC-53 -CV	RDCC-TV5303301	INSPECT CONTROL VALVE NO. TV53	PMT	1Y										I			RRC	RRC-IRCP	134442	C
3,361	RDCC-53 -CV	RDCC-TV5303704	INSPECT CONTROL VALVE NO. TV53	PMT	1Y										I			RRC	RRC-IRCP	134443	C
3,362	RDCC-53 -CV	RDCC-TV5303922A	INSPECT CONTROL VALVE NO. TV53	PMT	1Y										I			RRC	RRC-IRCP	134444	C
3,363	RDCC-53 -CV	RDCC-TV5303922B	INSPECT CONTROL VALVE NO. TV53	PMT	1Y										I			RRC	RRC-IRCP	134445	C
3,364	RDCC-53 -CV	RDCC-TV5304302A	INSPECT CONTROL VALVE NO. TV53	PMT	1Y										I			RRC	RRC-IRCP	134446	C
3,365	RDCC-53 -CV	RDCC-TV5304302B	INSPECT CONTROL VALVE NO. TV53	PMT	1Y										I			RRC	RRC-IRCP	134447	C
3,366	RDCC-53 -CV	RDCC-TV5305503	INSPECT CONTROL VALVE NO. TV53	PMT	1Y										I			RRC	RRC-IRCP	134448	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT : RDCC YEAR : 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,367	RDCC-53 -CV	RDCC-TV5307611	INSPECT CONTROL VALVE NO. TV53	PMT	1Y											I		RRC	RRC-IRCP	134449	C
3,368	RDCC-53 -CV	RDCC-TV5309117	INSPECT CONTROL VALVE NO. TV53	PMT	1Y											I		RRC	RRC-IRCP	134450	C
3,369	RDCC-53 -CV	RDCC-TV5309801A	INSPECT CONTROL VALVE NO. TV53	PMT	1Y											I		RRC	RRC-IRCP	134451	C
3,370	RDCC-53 -CV	RDCC-TV5309801B	INSPECT CONTROL VALVE NO. TV53	PMT	1Y											I		RRC	RRC-IRCP	134452	C
3,371	RDCC-53 -CV	RDCC-TV5310001	INSPECT CONTROL VALVE NO. TV53	PMT	1Y											I		RRC	RRC-IRCP	134453	C
3,372	RDCC-53 -53E003	RDCC-TV5311801	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y												I	RRC	RRC-IRCP	255809	C
3,373	RDCC-53 -53E003	RDCC-TV5311835	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y												I	RRC	RRC-IRCP	255814	C
3,374	RDCC-53 -CV	RDCC-TV5352408	INSPECT CONTROL VALVE NO. TV53	PMT	1Y											I		RRC	RRC-IRCP	134496	C
3,375	RDCC-53 -CV	RDCC-TV5352983	INSPECT CONTROL VALVE NO. TV53	PMT	1Y											I		RRC	RRC-IRCP	134497	C
3,376	RDCC-53 -CV	RDCC-XV5300102	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134499	C
3,377	RDCC-53 -CV	RDCC-XV5300301	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134500	C
3,378	RDCC-53 -CV	RDCC-XV5300301	XV5300301-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261446	C
3,379	RDCC-53 -CV	RDCC-XV5300302	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134501	C
3,380	RDCC-53 -CV	RDCC-XV5300303	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134502	C
3,381	RDCC-53 -CV	RDCC-XV5300304	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134503	C
3,382	RDCC-53 -CV	RDCC-XV5300304	XV5300304-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261442	C
3,383	RDCC-53 -CV	RDCC-XV5300305	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134504	C
3,384	RDCC-53 -CV	RDCC-XV5300306	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134505	C
3,385	RDCC-53 -CV	RDCC-XV5300307	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134506	C
3,386	RDCC-53 -CV	RDCC-XV5300401	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134507	C
3,387	RDCC-53 -CV	RDCC-XV5300401	XV5300401-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261443	C
3,388	RDCC-53 -CV	RDCC-XV5300402	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134508	C
3,389	RDCC-53 -CV	RDCC-XV5300402	XV5300402-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261444	C
3,390	RDCC-53 -CV	RDCC-XV5300403	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134509	C
3,391	RDCC-53 -CV	RDCC-XV5300403	XV5300403-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261445	C
3,392	RDCC-53 -CV	RDCC-XV5300701	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134510	C
3,393	RDCC-53 -CV	RDCC-XV5300701	XV5300701-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261450	C
3,394	RDCC-53 -CV	RDCC-XV5300801	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134511	C
3,395	RDCC-53 -CV	RDCC-XV5300801	XV5300801-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261448	C
3,396	RDCC-53 -CV	RDCC-XV5300802	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134512	C
3,397	RDCC-53 -CV	RDCC-XV5300802	XV5300802-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261449	C
3,398	RDCC-53 -CV	RDCC-XV5300901	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134513	C
3,399	RDCC-53 -CV	RDCC-XV5300901	XV5300901-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261452	C
3,400	RDCC-53 -CV	RDCC-XV5300902	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134514	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,401	RDCC-53 -CV	RDCC-XV5300902	XV5300902-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261453	C
3,402	RDCC-53 -CV	RDCC-XV5300903	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134515	C
3,403	RDCC-53 -CV	RDCC-XV5300903	XV5300903-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261454	C
3,404	RDCC-53 -CV	RDCC-XV5301001	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134516	C
3,405	RDCC-53 -CV	RDCC-XV5301001	XV5301001-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261451	C
3,406	RDCC-53 -CV	RDCC-XV5301002	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134517	C
3,407	RDCC-53 -CV	RDCC-XV5301002	XV5301002-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261447	C
3,408	RDCC-53 -CV	RDCC-XV5301102	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134518	C
3,409	RDCC-53 -CV	RDCC-XV5301301	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134519	C
3,410	RDCC-53 -CV	RDCC-XV5301302	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134520	C
3,411	RDCC-53 -CV	RDCC-XV5301303	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134521	C
3,412	RDCC-53 -CV	RDCC-XV5301304	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134522	C
3,413	RDCC-53 -CV	RDCC-XV5301305	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134523	C
3,414	RDCC-53 -CV	RDCC-XV5301306	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134524	C
3,415	RDCC-53 -CV	RDCC-XV5301307	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134525	C
3,416	RDCC-53 -CV	RDCC-XV5301601	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134526	C
3,417	RDCC-53 -CV	RDCC-XV5301603	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134528	C
3,418	RDCC-53 -CV	RDCC-XV5301701A	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134529	C
3,419	RDCC-53 -CV	RDCC-XV5301701B	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134530	C
3,420	RDCC-53 -CV	RDCC-XV5301702A	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134531	C
3,421	RDCC-53 -CV	RDCC-XV5301702B	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134532	C
3,422	RDCC-53 -CV	RDCC-XV5302501	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134542	C
3,423	RDCC-53 -CV	RDCC-XV5302501	XV5302501-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261455	C
3,424	RDCC-53 -CV	RDCC-XV5302601	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251289	C
3,425	RDCC-53 -CV	RDCC-XV5302601	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251128	C
3,426	RDCC-53 -CV	RDCC-XV5302901	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251290	C
3,427	RDCC-53 -CV	RDCC-XV5302901	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251130	C
3,428	RDCC-53 -CV	RDCC-XV5304901	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251291	C
3,429	RDCC-53 -CV	RDCC-XV5304901	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251132	C
3,430	RDCC-53 -CV	RDCC-XV5305201	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251292	C
3,431	RDCC-53 -CV	RDCC-XV5305201	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251134	C
3,432	RDCC-53 -CV	RDCC-XV5305701	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251293	C
3,433	RDCC-53 -CV	RDCC-XV5305701	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251136	C
3,434	RDCC-53 -CV	RDCC-XV5306301	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251294	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,435	RDCC-53 -CV	RDCC-XV5306301	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251138	C
3,436	RDCC-53 -CV	RDCC-XV5306501	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251295	C
3,437	RDCC-53 -CV	RDCC-XV5306501	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251140	C
3,438	RDCC-53 -CV	RDCC-XV5306901	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251296	C
3,439	RDCC-53 -CV	RDCC-XV5306901	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251142	C
3,440	RDCC-53 -CV	RDCC-XV5307301	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251297	C
3,441	RDCC-53 -CV	RDCC-XV5307301	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251144	C
3,442	RDCC-53 -CV	RDCC-XV5307302	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251298	C
3,443	RDCC-53 -CV	RDCC-XV5307302	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251146	C
3,444	RDCC-53 -CV	RDCC-XV5307501	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134553	C
3,445	RDCC-53 -CV	RDCC-XV5307601	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134554	C
3,446	RDCC-53 -CV	RDCC-XV5307801	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251299	C
3,447	RDCC-53 -CV	RDCC-XV5307801	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251148	C
3,448	RDCC-53 -CV	RDCC-XV5308001	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134556	C
3,449	RDCC-53 -CV	RDCC-XV5308001	XV5308001-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261461	C
3,450	RDCC-53 -CV	RDCC-XV5308002	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134557	C
3,451	RDCC-53 -CV	RDCC-XV5308002	XV5308002-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261462	C
3,452	RDCC-53 -CV	RDCC-XV5308003	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134558	C
3,453	RDCC-53 -CV	RDCC-XV5308004	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134559	C
3,454	RDCC-53 -CV	RDCC-XV5308301	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251300	C
3,455	RDCC-53 -CV	RDCC-XV5308301	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251150	C
3,456	RDCC-53 -CV	RDCC-XV5308401	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134561	C
3,457	RDCC-53 -CV	RDCC-XV5308401	XV5308401-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261463	C
3,458	RDCC-53 -CV	RDCC-XV5308901	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251301	C
3,459	RDCC-53 -CV	RDCC-XV5308901	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251152	C
3,460	RDCC-53 -CV	RDCC-XV5309101	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134563	C
3,461	RDCC-53 -CV	RDCC-XV5309101	XV5309101-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261464	C
3,462	RDCC-53 -CV	RDCC-XV5309301	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251302	C
3,463	RDCC-53 -CV	RDCC-XV5309301	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251154	C
3,464	RDCC-53 -CV	RDCC-XV5309303	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134565	C
3,465	RDCC-53 -CV	RDCC-XV5310001	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134566	C
3,466	RDCC-53 -CV	RDCC-XV5310501	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134567	C
3,467	RDCC-53 -CV	RDCC-XV5310501	XV5310501-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261456	C
3,468	RDCC-53 -CV	RDCC-XV5310502	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134568	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,469	RDCC-53 -CV	RDCC-XV5310502	XV5310502-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261457	C
3,470	RDCC-53 -CV	RDCC-XV5310503	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134569	C
3,471	RDCC-53 -CV	RDCC-XV5310503	XV5310503-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261458	C
3,472	RDCC-53 -CV	RDCC-XV5310504	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134570	C
3,473	RDCC-53 -CV	RDCC-XV5310504	XV5310504-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261459	C
3,474	RDCC-53 -CV	RDCC-XV5310505	INSPECT CONTROL VALVE NO. XV53	INS	1Y											I		RRC	RRC-IRCP	134571	C
3,475	RDCC-53 -CV	RDCC-XV5310505	XV5310505-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261460	C
3,476	RDCC-53 -CV	RDCC-XV5310507	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134572	C
3,477	RDCC-53 -CV	RDCC-XV5310508	INSPECT CONTROL VALVE NO. XV53	PMT	1Y											I		RRC	RRC-IRCP	134573	C
3,478	RDCC-53 -CV	RDCC-XV5310509	INSPECT CONTROL VALVE NO. XV53	PMT	1Y												I	RRC	RRC-IRCP	134574	C
3,479	RDCC-53 -CV	RDCC-XV5310510	INSPECT CONTROL VALVE NO. XV53	PMT	1Y												I	RRC	RRC-IRCP	134575	C
3,480	RDCC-53 -CV	RDCC-XV5310511	INSPECT CONTROL VALVE NO. XV53	PMT	1Y												I	RRC	RRC-IRCP	134576	C
3,481	RDCC-53 -CV	RDCC-XV5311103	INSPECT CONTROL VALVE NO. XV53	PMT	1Y												I	RRC	RRC-IRCP	134577	C
3,482	RDCC-53 -53E003	RDCC-XV5311818	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y												I	RRC	RRC-IRCP	255812	C
3,483	RDCC-53 -53E003	RDCC-XV5311903	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y												I	RRC	RRC-IRCP	255811	C
3,484	RDCC-53 -53K002	RDCC-XV5312001	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y												I	RRC	RRC-IRCP	255815	C
3,485	RDCC-53 -53D006	RDCC-XV5312101	INSPECT CONTROL VALVE NO.RDCC-	PMT	1Y												I	RRC	RRC-IRCP	255813	C
3,486	RDCC-53 -CV	RDCC-XV5352512	INSPECT CONTROL VALVE NO. XV53	PMT	1Y												I	RRC	RRC-IRCP	134578	C
3,487	RDCC-53 -CV	RDCC-XV5352513	INSPECT CONTROL VALVE NO. XV53	PMT	1Y												I	RRC	RRC-IRCP	134579	C
3,488	RDCC-53 -CV	RDCC-XV5352535	INSPECT CONTROL VALVE NO. XV53	PMT	1Y												I	RRC	RRC-IRCP	134580	C
3,489	RDCC-53 -CV	RDCC-XV5352840	INSPECT CONTROL VALVE NO. XV53	PMT	1Y												I	RRC	RRC-IRCP	134581	C
3,490	RDCC-53 -CV	RDCC-XV5352984	INSPECT CONTROL VALVE NO. XV53	PMT	1Y												I	RRC	RRC-IRCP	134582	C
3,491	RDCC-53 -CV	RDCC-XV5353160	INSPECT CONTROL VALVE NO. XV53	PMT	1Y												I	RRC	RRC-IRCP	134583	C
3,492	RDCC-53 -CV	RDCC-XV5353161	INSPECT CONTROL VALVE NO. XV53	PMT	1Y												I	RRC	RRC-IRCP	134584	C
3,493	RDCC-53 -CV	RDCC-XV5353262	INSPECT CONTROL VALVE NO. XV53	PMT	1Y												I	RRC	RRC-IRCP	134585	C
3,494	RDCC-53 -CV	RDCC-XV5353264	INSPECT CONTROL VALVE NO. XV53	PMT	1Y												I	RRC	RRC-IRCP	134586	C
3,495	RDCC-53 -CV	RDCC-XV5353365	INSPECT CONTROL VALVE NO. XV53	PMT	1Y												I	RRC	RRC-IRCP	134587	C
3,496	RDCC-53 -CV	RDCC-XV5353366	INSPECT CONTROL VALVE NO. XV53	PMT	1Y												I	RRC	RRC-IRCP	134588	C
3,497	RDCC-53 -CV	RDCC-XV5353467	INSPECT CONTROL VALVE NO. XV53	PMT	1Y												I	RRC	RRC-IRCP	134589	C
3,498	RDCC-53 -CV	RDCC-XV5353468	INSPECT CONTROL VALVE NO. XV53	PMT	1Y												I	RRC	RRC-IRCP	134590	C
3,499	RDCC-56 -CV	RDCC-XV5600201	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251331	C
3,500	RDCC-56 -CV	RDCC-XV5600201	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251212	C
3,501	RDCC-56 -CV	RDCC-XV5600202	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251332	C
3,502	RDCC-56 -CV	RDCC-XV5600202	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251214	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RDCC YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,503	RDCC-56 -CV	RDCC-XV5600203	INSPECT CONTROL VALVE NO. XV56	PMT	1Y												I	RRC	RRC-IRCP	134593	C
3,504	RDCC-56 -CV	RDCC-XV5600204	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251333	C
3,505	RDCC-56 -CV	RDCC-XV5600204	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251216	C
3,506	RDCC-56 -CV	RDCC-XV5600301	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251334	C
3,507	RDCC-56 -CV	RDCC-XV5600301	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251218	C
3,508	RDCC-56 -CV	RDCC-XV5600302	INSPECT CONTROL VALVE NO. XV56	PMT	1Y												I	RRC	RRC-IRCP	134596	C
3,509	RDCC-56 -CV	RDCC-XV5600304	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251335	C
3,510	RDCC-56 -CV	RDCC-XV5600304	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251220	C
3,511	RDCC-56 -CV	RDCC-XV5600401	INSPECT CONTROL VALVE NO. XV56	PMT	1Y												I	RRC	RRC-IRCP	134598	C
3,512	RDCC-56 -CV	RDCC-XV5600402	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251336	C
3,513	RDCC-56 -CV	RDCC-XV5600402	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251222	C
3,514	RDCC-56 -CV	RDCC-XV5600403	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251337	C
3,515	RDCC-56 -CV	RDCC-XV5600403	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251224	C
3,516	RDCC-56 -CV	RDCC-XV5600601	INSPECT CONTROL VALVE NO. XV56	INS	1Y												I	RRC	RRC-IRCP	134601	C
3,517	RDCC-56 -CV	RDCC-XV5600601	XV5600601-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261478	C
3,518	RDCC-56 -CV	RDCC-XV5600602	INSPECT CONTROL VALVE NO. XV56	INS	1Y												I	RRC	RRC-IRCP	134602	C
3,519	RDCC-56 -CV	RDCC-XV5600602	XV5600602-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261477	C
3,520	RDCC-56 -CV	RDCC-XV5600801	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251338	C
3,521	RDCC-56 -CV	RDCC-XV5600801	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251226	C
3,522	RDCC-56 -CV	RDCC-XV5600802	INSPECT CONTROL VALVE NO. XV56	INS	1Y												I	RRC	RRC-IRCP	134604	C
3,523	RDCC-56 -CV	RDCC-XV5600802	XV5600802-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IRCP	261479	C
3,524	RDCC-56 -CV	RDCC-XV5600803	INSPECT CONTROL VALVE NO. XV56	PMT	1Y												I	RRC	RRC-IRCP	134605	C
3,525	RDCC-56 -CV	RDCC-XV5600804	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251339	C
3,526	RDCC-56 -CV	RDCC-XV5600804	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251228	C
3,527	RDCC-56 -CV	RDCC-XV5601501	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IRCP	251340	C
3,528	RDCC-56 -CV	RDCC-XV5601501	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IRCP	251230	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1	RHU		VB. INSP & ANALY M/C RHU PLANT	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	150294	
2	RHU -52 -52K002A		PM COMPRESSOR NO. 52K002A	PMT	1Y								P					CRE	CRE-CHIP	131152	
3	RHU -52 -52K002A		OIL INSP & ANALYSIS M/C 52K002A	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INDL	129992	
4	RHU -52 -GRD_LIGHTN		PM GND SYS (LOOP) (UNIT 52)	PMT	1Y	P								P				RRC	RRC-ERCH	140345	
5	RHU -52 -GRD_LIGHTN		VISUAL GROUNDING SYS (UNIT 52)	PMT	4M	P				P				P				RRC	RRC-ERCH	141705	
6	RHU -55 -GRD_LIGHTN		PM GND SYS (LOOP) (UNIT 55)	PMT	1Y	P								P				RRC	RRC-ERCH	140346	
7	RHU -55 -GRD_LIGHTN		VISUAL GROUNDING SYS (UNIT 55)	PMT	4M	P				P				P				RRC	RRC-ERCH	141706	
8	RHU -52 -PIPING	1-1/2-FA-52016001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175196	B
9	RHU -52 -PIPING	1-1/2-FA-52016002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175197	B
10	RHU -52 -PIPING	1-1/2-FA-52018001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175228	B
11	RHU -52 -PIPING	1-1/2-FA-52018002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175229	B
12	RHU -52 -PIPING	1-1/2-FA-52035001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175690	B
13	RHU -52 -PIPING	1-1/2-FA-52035002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175691	B
14	RHU -52 -PIPING	1-1/2-HBD-52011001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175115	B
15	RHU -52 -PIPING	1-1/2-HBD-52033002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175660	B
16	RHU -52 -PIPING	1-1/2-HFA-52013002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175151	B
17	RHU -52 -PIPING	1-1/2-P-52504502	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175752	B
18	RHU -52 -PIPING	1-AV-52003001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174992	B
19	RHU -52 -PIPING	1-AV-52003002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174993	B
20	RHU -52 -PIPING	1-FA-52013001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175147	B
21	RHU -52 -PIPING	1-FA-52025002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175436	B
22	RHU -52 -PIPING	1-FM-52031301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175608	B
23	RHU -52 -PIPING	1-HBD-52008002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175059	B
24	RHU -52 -PIPING	1-HBD-52021002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175322	B
25	RHU -52 -PIPING	1-HBD-52022008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175342	B
26	RHU -52 -PIPING	1-HBD-52022009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175343	B
27	RHU -52 -PIPING	1-HBD-52027001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175528	B
28	RHU -52 -PIPING	1-HBD-52029001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175585	B
29	RHU -52 -PIPING	1-HBD-52032001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175648	B
30	RHU -52 -PIPING	1-HBD-52034001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175684	B
31	RHU -52 -PIPING	1-P-52004015	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175021	B
32	RHU -52 -PIPING	1-P-52005007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175039	B
33	RHU -52 -PIPING	1-P-52006007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175044	B
34	RHU -52 -PIPING	1-P-52006010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175047	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
35	RHU -52 -PIPING	1-P-52006011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175048	B
36	RHU -52 -PIPING	1-P-52007008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175054	B
37	RHU -52 -PIPING	1-P-52007009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175055	B
38	RHU -52 -PIPING	1-P-52008005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175065	B
39	RHU -52 -PIPING	1/2-FM-52020302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175301	B
40	RHU -52 -PIPING	1/2-FM-52020303	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175302	B
41	RHU -52 -PIPING	1/2-FM-52020305	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175303	B
42	RHU -52 -PIPING	1/2-FM-52020306	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175304	B
43	RHU -52 -PIPING	1/2-FM-52023302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175367	B
44	RHU -52 -PIPING	1/2-FM-52023303	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175368	B
45	RHU -52 -PIPING	1/2-FM-52023305	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175369	B
46	RHU -52 -PIPING	1/2-FM-52023306	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175370	B
47	RHU -52 -PIPING	1/2-FM-52023308	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175371	B
48	RHU -52 -PIPING	1/2-FM-52023309	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175372	B
49	RHU -52 -PIPING	1/2-FM-52031302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175609	B
50	RHU -52 -PIPING	1/2-FM-52031303	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175610	B
51	RHU -52 -PIPING	1/2-FM-52031305	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175611	B
52	RHU -52 -PIPING	1/2-FM-52031306	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175612	B
53	RHU -52 -PIPING	1/2-FM-52031308	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175613	B
54	RHU -52 -PIPING	1/2-FM-52031309	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175614	B
55	RHU -52 -PIPING	1/2-FM-52031311	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175615	B
56	RHU -52 -PIPING	1/2-FM-52031312	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175616	B
57	RHU -52 -PIPING	1/2-FM-52031314	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175617	B
58	RHU -52 -PIPING	1/2-FM-52031315	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175618	B
59	RHU -52 -PIPING	1/2-FM-52032302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175643	B
60	RHU -52 -PIPING	1/2-FM-52032303	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175644	B
61	RHU -52 -PIPING	1/2-FM-52032305	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175645	B
62	RHU -52 -PIPING	1/2-FM-52032306	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175646	B
63	RHU -52 -PIPING	1/2-P-52036019	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175734	B
64	RHU -52 -PIPING	10-HFA-52004005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175003	B
65	RHU -52 -PIPING	10-HFA-52005005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175032	B
66	RHU -52 -PIPING	10-HFA-52010004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175081	B
67	RHU -52 -PIPING	10-HFA-52011001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175117	B
68	RHU -52 -PIPING	10-HFA-52014001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175170	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
69	RHU -52 -PIPING	10-HFA-52015004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175187	B
70	RHU -52 -PIPING	10-HFA-52017001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175218	B
71	RHU -52 -PIPING	10-HFA-52020001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175308	B
72	RHU -52 -PIPING	10-HFA-52021003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175327	B
73	RHU -52 -PIPING	10-P-52001007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174965	B
74	RHU -52 -PIPING	10-P-52001009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174967	B
75	RHU -52 -PIPING	10-P-52008002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175062	B
76	RHU -52 -PIPING	10-P-52008003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175063	B
77	RHU -52 -PIPING	10-P-52009007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175068	B
78	RHU -52 -PIPING	10-P-52011004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175121	B
79	RHU -52 -PIPING	10-P-52012001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175134	B
80	RHU -52 -PIPING	10-P-52012005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175137	B
81	RHU -52 -PIPING	10-P-52020003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175312	B
82	RHU -52 -PIPING	10-P-52021010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175336	B
83	RHU -52 -PIPING	10-P-52023001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175378	B
84	RHU -52 -PIPING	10-P-52023004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175381	B
85	RHU -52 -PIPING	10-P-52023005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175382	B
86	RHU -52 -PIPING	10-P-52025012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175463	B
87	RHU -52 -PIPING	10-P-52031003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175625	B
88	RHU -52 -PIPING	10-P-52031004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175626	B
89	RHU -55 -PIPING	10-P-55016002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177191	B
90	RHU -55 -PIPING	10-P-55016006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177193	B
91	RHU -55 -PIPING	10-P-55016007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177194	B
92	RHU -55 -PIPING	10-P-55018007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177222	B
93	RHU -52 -PIPING	12-FA-52026002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175506	B
94	RHU -52 -PIPING	12-HFA-52010002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175079	B
95	RHU -52 -PIPING	12-HFA-52012003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175133	B
96	RHU -52 -PIPING	12-HFA-52013001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175150	B
97	RHU -52 -PIPING	12-P-52004006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175012	B
98	RHU -52 -PIPING	12-P-52004007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175013	B
99	RHU -52 -PIPING	12-P-52008001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175061	B
100	RHU -52 -PIPING	12-P-52009002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175066	B
101	RHU -52 -PIPING	12-P-52031001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175623	B
102	RHU -52 -PIPING	12-P-52037001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175738	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
103	RHU -52 -PIPING	12-P-52037004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175739	B
104	RHU -52 -PIPING	12-P-52037005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175740	B
105	RHU -52 -PIPING	12-P-52037006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175741	B
106	RHU -55 -PIPING	12-P-55021004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177270	B
107	RHU -52 -PIPING	14-FA-52023001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175361	B
108	RHU -52 -PIPING	14-P-52002004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174984	B
109	RHU -52 -PIPING	16-FA-52028001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175554	B
110	RHU -52 -PIPING	16-P-52002002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174983	B
111	RHU -52 -PIPING	16-P-52002005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174985	B
112	RHU -52 -PIPING	16-P-52003003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174996	B
113	RHU -52 -PIPING	16-P-52004001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175008	B
114	RHU -52 -PIPING	16-P-52004004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175010	B
115	RHU -52 -PIPING	16-P-52004011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175017	B
116	RHU -52 -PIPING	16-P-52004013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175019	B
117	RHU -52 -PIPING	16-P-52004014	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175020	B
118	RHU -52 -PIPING	16-P-52005001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175034	B
119	RHU -52 -PIPING	16-P-52005002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175035	B
120	RHU -52 -PIPING	16-P-52005003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175036	B
121	RHU -52 -PIPING	16-P-52006006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175043	B
122	RHU -55 -PIPING	16-P-55016008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177195	B
123	RHU -55 -PIPING	16-P-55016010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177197	B
124	RHU -55 -PIPING	16-P-55017001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177201	B
125	RHU -55 -PIPING	16-P-55017002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177202	B
126	RHU -55 -PIPING	16-P-55018001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177216	B
127	RHU -55 -PIPING	16-P-55018009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177224	B
128	RHU -55 -PIPING	16-P-55019002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177229	B
129	RHU -55 -PIPING	16-P-55019006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177232	B
130	RHU -55 -PIPING	16-P-55019007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177233	B
131	RHU -55 -PIPING	16-P-55019008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177234	B
132	RHU -55 -PIPING	16-P-55019016	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177241	B
133	RHU -55 -PIPING	16-P-55020002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177248	B
134	RHU -55 -PIPING	16-P-55020003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177249	B
135	RHU -55 -PIPING	16-P-55020007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177253	B
136	RHU -55 -PIPING	16-P-55020008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177254	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
137	RHU -55 -PIPING	16-P-55020012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177258	B
138	RHU -55 -PIPING	16-P-55020016	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177261	B
139	RHU -55 -PIPING	16-P-55021002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177268	B
140	RHU -55 -PIPING	16-P-55021005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177271	B
141	RHU -52 -PIPING	18-FA-52001002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174946	B
142	RHU -52 -PIPING	18-P-52001018	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174976	B
143	RHU -52 -PIPING	18-P-52002011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174990	B
144	RHU -52 -PIPING	18-P-52002013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174991	B
145	RHU -52 -PIPING	18-P-52007006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175052	B
146	RHU -52 -PIPING	2-AV-52013002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175145	B
147	RHU -52 -PIPING	2-FA-52001003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174947	B
148	RHU -52 -PIPING	2-FA-52003001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174994	B
149	RHU -52 -PIPING	2-FA-52019001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175246	B
150	RHU -52 -PIPING	2-FA-52024001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175393	B
151	RHU -52 -PIPING	2-FA-52025003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175437	B
152	RHU -52 -PIPING	2-FA-52032001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175636	B
153	RHU -52 -PIPING	2-FA-52032002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175637	B
154	RHU -52 -PIPING	2-FG-52001001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174949	B
155	RHU -52 -PIPING	2-FG-52019001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175249	B
156	RHU -52 -PIPING	2-FM-52001002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174950	B
157	RHU -52 -PIPING	2-FM-52001301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174951	B
158	RHU -52 -PIPING	2-FM-52023002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175364	B
159	RHU -52 -PIPING	2-FM-52023003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175365	B
160	RHU -52 -PIPING	2-FM-52025001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175440	B
161	RHU -52 -PIPING	2-FM-52025005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175441	B
162	RHU -52 -PIPING	2-FM-52025301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175442	B
163	RHU -52 -PIPING	2-FM-52025302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175443	B
164	RHU -52 -PIPING	2-FM-52025303	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175444	B
165	RHU -52 -PIPING	2-FM-52025304	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175445	B
166	RHU -52 -PIPING	2-FM-52025305	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175446	B
167	RHU -52 -PIPING	2-FM-52025306	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175447	B
168	RHU -52 -PIPING	2-FM-52025307	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175448	B
169	RHU -52 -PIPING	2-FM-52025308	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175449	B
170	RHU -52 -PIPING	2-FM-52025309	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175450	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
171	RHU -52 -PIPING	2-FM-52025310	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175451	B
172	RHU -52 -PIPING	2-FM-52031002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175607	B
173	RHU -52 -PIPING	2-H-52032011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175647	B
174	RHU -52 -PIPING	2-HBD-52010003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175075	B
175	RHU -52 -PIPING	2-HBD-52016002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175198	B
176	RHU -52 -PIPING	2-HBD-52016006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175201	B
177	RHU -52 -PIPING	2-HBD-52018002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175230	B
178	RHU -52 -PIPING	2-HBD-52018005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175233	B
179	RHU -52 -PIPING	2-HBD-52019001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175250	B
180	RHU -52 -PIPING	2-HBD-52024001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175398	B
181	RHU -52 -PIPING	2-HBD-52024004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175399	B
182	RHU -52 -PIPING	2-HBD-52025004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175454	B
183	RHU -52 -PIPING	2-HBD-52033003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175661	B
184	RHU -52 -PIPING	2-HBD-52035005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175694	B
185	RHU -52 -PIPING	2-HBD-52035006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175695	B
186	RHU -52 -PIPING	2-HFA-52010003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175080	B
187	RHU -52 -PIPING	2-HFA-52014002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175171	B
188	RHU -52 -PIPING	2-HFA-52015003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175186	B
189	RHU -52 -PIPING	2-HFA-52017002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175219	B
190	RHU -52 -PIPING	2-HFA-52020002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175309	B
191	RHU -52 -PIPING	2-HFA-52033001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175663	B
192	RHU -52 -PIPING	2-HFA-52033004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175666	B
193	RHU -52 -PIPING	2-HFA-52033005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175667	B
194	RHU -52 -PIPING	2-HFA-52033008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175668	B
195	RHU -52 -PIPING	2-HFA-52034001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175685	B
196	RHU -52 -PIPING	2-P-52032006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175654	B
197	RHU -52 -PIPING	2-P-52032007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175655	B
198	RHU -55 -PIPING	2-P-55006011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177036	B
199	RHU -52 -PIPING	3-AV-52004001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174997	B
200	RHU -52 -PIPING	3-AV-52005001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175026	B
201	RHU -52 -PIPING	3-AV-52013004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175146	B
202	RHU -52 -PIPING	3-FA-52029001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175579	B
203	RHU -52 -PIPING	3-FA-52029002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175580	B
204	RHU -52 -PIPING	3-FG-52003001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174995	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
205	RHU -52 -PIPING	3-HBD-52001001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174952	B
206	RHU -52 -PIPING	3-HBD-52001004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174955	B
207	RHU -52 -PIPING	3-HBD-52004001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174998	B
208	RHU -52 -PIPING	3-HBD-52005001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175027	B
209	RHU -52 -PIPING	3-HBD-52008001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175058	B
210	RHU -52 -PIPING	3-HBD-52010001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175074	B
211	RHU -52 -PIPING	3-HBD-52020001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175305	B
212	RHU -52 -PIPING	3-HBD-52021001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175321	B
213	RHU -52 -PIPING	3-HBD-52021003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175323	B
214	RHU -52 -PIPING	3-HBD-52023003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175375	B
215	RHU -52 -PIPING	3-HBD-52028001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175557	B
216	RHU -52 -PIPING	3-HBD-52031001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175619	B
217	RHU -52 -PIPING	3-HFA-52004001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174999	B
218	RHU -52 -PIPING	3-HFA-52004002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175000	B
219	RHU -52 -PIPING	3-HFA-52004003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175001	B
220	RHU -52 -PIPING	3-HFA-52004004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175002	B
221	RHU -52 -PIPING	3-HFA-52004006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175004	B
222	RHU -52 -PIPING	3-HFA-52004007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175005	B
223	RHU -52 -PIPING	3-HFA-52004008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175006	B
224	RHU -52 -PIPING	3-HFA-52005001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175028	B
225	RHU -52 -PIPING	3-HFA-52005002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175029	B
226	RHU -52 -PIPING	3-HFA-52005003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175030	B
227	RHU -52 -PIPING	3-HFA-52005004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175031	B
228	RHU -52 -PIPING	3-HFA-52012001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175131	B
229	RHU -52 -PIPING	3-HFA-52012002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175132	B
230	RHU -52 -PIPING	3-HFA-52021001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175325	B
231	RHU -52 -PIPING	3-HFA-52027001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175529	B
232	RHU -52 -PIPING	3-HFA-52027002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175530	B
233	RHU -52 -PIPING	3-HFA-52027003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175531	B
234	RHU -52 -PIPING	3-HFA-52033002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175664	B
235	RHU -52 -PIPING	3-P-52004010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175016	B
236	RHU -52 -PIPING	3-P-52005005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175037	B
237	RHU -52 -PIPING	3-P-52009015	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175073	B
238	RHU -52 -PIPING	3-P-52012002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175135	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
239	RHU -52 -PIPING	3-P-52025025	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175476	B
240	RHU -52 -PIPING	3-P-52027001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175535	B
241	RHU -52 -PIPING	3-P-52029001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175586	B
242	RHU -52 -PIPING	3-P-52601001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175807	B
243	RHU -55 -PIPING	3-P-55017010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177210	B
244	RHU -55 -PIPING	3-P-55017050	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177215	B
245	RHU -55 -PIPING	3-P-55018011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177226	B
246	RHU -55 -PIPING	3-P-55018050	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177227	B
247	RHU -55 -PIPING	3-P-55019017	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177242	B
248	RHU -55 -PIPING	3-P-55019050	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177245	B
249	RHU -55 -PIPING	3-P-55020018	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177263	B
250	RHU -55 -PIPING	3-P-55020050	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177264	B
251	RHU -55 -PIPING	3-P-55021018	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177282	B
252	RHU -55 -PIPING	3-P-55021019	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177283	B
253	RHU -55 -PIPING	3-P-55023006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177327	B
254	RHU -55 -PIPING	3-P-55023007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177328	B
255	RHU -55 -PIPING	3-P-55023010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177330	B
256	RHU -52 -PIPING	3-VGD-52031004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175631	B
257	RHU -52 -PIPING	3-VGD-52031005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175632	B
258	RHU -52 -PIPING	3-VGD-52031006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175633	B
259	RHU -52 -PIPING	3-VGD-52031007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175634	B
260	RHU -52 -PIPING	3/4-AV-52019301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175245	B
261	RHU -52 -PIPING	3/4-FA-52001301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174948	B
262	RHU -52 -PIPING	3/4-FA-52019302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175248	B
263	RHU -52 -PIPING	3/4-FA-52020301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175299	B
264	RHU -52 -PIPING	3/4-FA-52021301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175320	B
265	RHU -52 -PIPING	3/4-FA-52023002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175362	B
266	RHU -52 -PIPING	3/4-FA-52023301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175363	B
267	RHU -52 -PIPING	3/4-FA-52024301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175395	B
268	RHU -52 -PIPING	3/4-FA-52024302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175396	B
269	RHU -52 -PIPING	3/4-FA-52024303	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175397	B
270	RHU -52 -PIPING	3/4-FA-52025301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175438	B
271	RHU -52 -PIPING	3/4-FA-52025302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175439	B
272	RHU -52 -PIPING	3/4-FA-52028301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175555	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
273	RHU -52 -PIPING	3/4-FA-52028302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175556	B
274	RHU -52 -PIPING	3/4-FA-52029301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175582	B
275	RHU -52 -PIPING	3/4-FA-52029303	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175583	B
276	RHU -52 -PIPING	3/4-FA-52029304	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175584	B
277	RHU -52 -PIPING	3/4-FA-52031001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175606	B
278	RHU -52 -PIPING	3/4-FA-52032301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175639	B
279	RHU -52 -PIPING	3/4-FA-52032302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175640	B
280	RHU -52 -PIPING	3/4-FA-52032303	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175641	B
281	RHU -52 -PIPING	3/4-FA-52036001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175714	B
282	RHU -52 -PIPING	3/4-FM-52020301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175300	B
283	RHU -52 -PIPING	3/4-FM-52023301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175366	B
284	RHU -52 -PIPING	3/4-FM-52032301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175642	B
285	RHU -52 -PIPING	3/4-H-52014301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175169	B
286	RHU -52 -PIPING	3/4-HBD-52001002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174953	B
287	RHU -52 -PIPING	3/4-HBD-52001003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174954	B
288	RHU -52 -PIPING	3/4-HBD-52001005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174956	B
289	RHU -52 -PIPING	3/4-HBD-52008301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175060	B
290	RHU -52 -PIPING	3/4-HBD-52010005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175076	B
291	RHU -52 -PIPING	3/4-HBD-52010301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175077	B
292	RHU -52 -PIPING	3/4-HBD-52011301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175116	B
293	RHU -52 -PIPING	3/4-HBD-52013001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175148	B
294	RHU -52 -PIPING	3/4-HBD-52013002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175149	B
295	RHU -52 -PIPING	3/4-HBD-52016003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175199	B
296	RHU -52 -PIPING	3/4-HBD-52016004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175200	B
297	RHU -52 -PIPING	3/4-HBD-52018003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175231	B
298	RHU -52 -PIPING	3/4-HBD-52018004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175232	B
299	RHU -52 -PIPING	3/4-HBD-52019002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175251	B
300	RHU -52 -PIPING	3/4-HBD-52019003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175252	B
301	RHU -52 -PIPING	3/4-HBD-52019004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175253	B
302	RHU -52 -PIPING	3/4-HBD-52019005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175254	B
303	RHU -52 -PIPING	3/4-HBD-52020002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175306	B
304	RHU -52 -PIPING	3/4-HBD-52020301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175307	B
305	RHU -52 -PIPING	3/4-HBD-52021004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175324	B
306	RHU -52 -PIPING	3/4-HBD-52022002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175341	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
307	RHU -52 -PIPING	3/4-HBD-52023001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175373	B
308	RHU -52 -PIPING	3/4-HBD-52023002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175374	B
309	RHU -52 -PIPING	3/4-HBD-52023303	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175376	B
310	RHU -52 -PIPING	3/4-HBD-52024005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175400	B
311	RHU -52 -PIPING	3/4-HBD-52024006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175401	B
312	RHU -52 -PIPING	3/4-HBD-52024007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175402	B
313	RHU -52 -PIPING	3/4-HBD-52024304	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175403	B
314	RHU -52 -PIPING	3/4-HBD-52025001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175452	B
315	RHU -52 -PIPING	3/4-HBD-52025003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175453	B
316	RHU -52 -PIPING	3/4-HBD-52031002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175620	B
317	RHU -52 -PIPING	3/4-HBD-52031301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175621	B
318	RHU -52 -PIPING	3/4-HBD-52032301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175649	B
319	RHU -52 -PIPING	3/4-HBD-52033301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175662	B
320	RHU -52 -PIPING	3/4-HBD-52035003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175692	B
321	RHU -52 -PIPING	3/4-HBD-52035004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175693	B
322	RHU -52 -PIPING	3/4-HFA-52010301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175083	B
323	RHU -52 -PIPING	3/4-HFA-52010302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175084	B
324	RHU -52 -PIPING	3/4-HFA-52011301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175118	B
325	RHU -52 -PIPING	3/4-HFA-52013301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175152	B
326	RHU -52 -PIPING	3/4-HFA-52014301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175173	B
327	RHU -52 -PIPING	3/4-HFA-52027301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175532	B
328	RHU -52 -PIPING	3/4-HFA-52027303	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175533	B
329	RHU -52 -PIPING	3/4-HFA-52027304	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175534	B
330	RHU -52 -PIPING	3/4-HFA-52033301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175669	B
331	RHU -52 -PIPING	3/4-HFA-52033302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175670	B
332	RHU -52 -PIPING	3/4-HFA-52035301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175697	B
333	RHU -52 -PIPING	3/4-P-52001301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174979	B
334	RHU -52 -PIPING	3/4-P-52001302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174980	B
335	RHU -52 -PIPING	3/4-P-52001304	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174981	B
336	RHU -52 -PIPING	3/4-P-52004301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175024	B
337	RHU -52 -PIPING	3/4-P-52004302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175025	B
338	RHU -52 -PIPING	3/4-P-52005301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175040	B
339	RHU -52 -PIPING	3/4-P-52006301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175049	B
340	RHU -52 -PIPING	3/4-P-52007301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175057	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
341	RHU -52 -PIPING	3/4-P-52008004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175064	B
342	RHU -52 -PIPING	3/4-P-52013301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175166	B
343	RHU -52 -PIPING	3/4-P-52013302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175167	B
344	RHU -52 -PIPING	3/4-P-52020010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175317	B
345	RHU -52 -PIPING	3/4-P-52020301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175318	B
346	RHU -52 -PIPING	3/4-P-52020302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175319	B
347	RHU -52 -PIPING	3/4-P-52021011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175337	B
348	RHU -52 -PIPING	3/4-P-52021012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175338	B
349	RHU -52 -PIPING	3/4-P-52021301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175339	B
350	RHU -52 -PIPING	3/4-P-52021302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175340	B
351	RHU -52 -PIPING	3/4-P-52023013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175389	B
352	RHU -52 -PIPING	3/4-P-52023303	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175392	B
353	RHU -52 -PIPING	3/4-P-52025028	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175479	B
354	RHU -52 -PIPING	3/4-P-52025301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175482	B
355	RHU -52 -PIPING	3/4-P-52025302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175483	B
356	RHU -52 -PIPING	3/4-P-52025303	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175484	B
357	RHU -52 -PIPING	3/4-P-52025304	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175485	B
358	RHU -52 -PIPING	3/4-P-52031005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175627	B
359	RHU -52 -PIPING	3/4-P-52032012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175658	B
360	RHU -52 -PIPING	3/4-P-52032301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175659	B
361	RHU -52 -PIPING	3/4-P-52035301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175712	B
362	RHU -52 -PIPING	3/4-P-52035302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175713	B
363	RHU -52 -PIPING	3/4-P-52036009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175724	B
364	RHU -52 -PIPING	3/4-P-52036010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175725	B
365	RHU -52 -PIPING	3/4-P-52036011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175726	B
366	RHU -52 -PIPING	3/4-P-52036012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175727	B
367	RHU -52 -PIPING	3/4-P-52036013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175728	B
368	RHU -52 -PIPING	3/4-P-52504501	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175751	B
369	RHU -55 -PIPING	3/4-P-55019301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177246	B
370	RHU -55 -PIPING	3/4-P-55019302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177247	B
371	RHU -55 -PIPING	3/4-P-55020301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177265	B
372	RHU -55 -PIPING	3/4-P-55020302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177266	B
373	RHU -55 -PIPING	3/4-P-55021301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177285	B
374	RHU -55 -PIPING	3/4-P-55021302	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177286	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
375	RHU -55 -PIPING	3/4-P-55023303	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177361	B
376	RHU -55 -PIPING	3/4-P-55023304	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177362	B
377	RHU -52 -PIPING	3/4-VCO-52031301	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175635	B
378	RHU -52 -PIPING	4-FA-52001001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174945	B
379	RHU -52 -PIPING	4-H-52014001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175168	B
380	RHU -52 -PIPING	4-HFA-52021002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175326	B
381	RHU -52 -PIPING	4-P-52009012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175071	B
382	RHU -52 -PIPING	4-P-52009013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175072	B
383	RHU -52 -PIPING	4-P-52015006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175191	B
384	RHU -52 -PIPING	4-P-52017006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175223	B
385	RHU -52 -PIPING	4-P-52032001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175650	B
386	RHU -55 -PIPING	4-P-55002005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	176996	B
387	RHU -55 -PIPING	4-P-55005001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177026	B
388	RHU -55 -PIPING	4-P-55006001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177028	B
389	RHU -55 -PIPING	4-P-55019009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177235	B
390	RHU -52 -PIPING	4-VCO-52031002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175629	B
391	RHU -52 -PIPING	4-VCO-52031003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175630	B
392	RHU -52 -PIPING	6-FA-52025001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175435	B
393	RHU -52 -PIPING	6-FA-52026001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175505	B
394	RHU -52 -PIPING	6-HBD-52000001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174939	B
395	RHU -52 -PIPING	6-HFA-52014003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175172	B
396	RHU -52 -PIPING	6-HFA-52033003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175665	B
397	RHU -52 -PIPING	6-HFA-52035001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175696	B
398	RHU -52 -PIPING	6-MK-52001003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174958	B
399	RHU -52 -PIPING	6-P-52001005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174963	B
400	RHU -52 -PIPING	6-P-52001006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174964	B
401	RHU -52 -PIPING	6-P-52001011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174969	B
402	RHU -52 -PIPING	6-P-52001012	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174970	B
403	RHU -52 -PIPING	6-P-52001013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174971	B
404	RHU -52 -PIPING	6-P-52001014	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174972	B
405	RHU -52 -PIPING	6-P-52001022	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174977	B
406	RHU -52 -PIPING	6-P-52010016	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175093	B
407	RHU -52 -PIPING	6-P-52014003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175176	B
408	RHU -52 -PIPING	6-P-52014013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175185	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
409	RHU -52 -PIPING	6-P-52015004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175190	B
410	RHU -52 -PIPING	6-P-52016006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175208	B
411	RHU -52 -PIPING	6-P-52017004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175222	B
412	RHU -52 -PIPING	6-P-52023006	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175383	B
413	RHU -52 -PIPING	6-P-52023007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175384	B
414	RHU -52 -PIPING	6-P-52025001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175455	B
415	RHU -52 -PIPING	6-P-52025002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175456	B
416	RHU -52 -PIPING	6-P-52025003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175457	B
417	RHU -52 -PIPING	6-P-52025005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175458	B
418	RHU -52 -PIPING	6-P-52025008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175459	B
419	RHU -52 -PIPING	6-P-52025009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175460	B
420	RHU -52 -PIPING	6-P-52025010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175461	B
421	RHU -52 -PIPING	6-P-52025011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175462	B
422	RHU -52 -PIPING	6-P-52025013	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175464	B
423	RHU -52 -PIPING	6-P-52025014	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175465	B
424	RHU -52 -PIPING	6-P-52025015	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175466	B
425	RHU -52 -PIPING	6-P-52025021	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175472	B
426	RHU -52 -PIPING	6-P-52025027	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175478	B
427	RHU -52 -PIPING	6-P-52031002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175624	B
428	RHU -52 -PIPING	6-P-52032003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175651	B
429	RHU -52 -PIPING	6-P-52032004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175652	B
430	RHU -52 -PIPING	6-P-52032005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175653	B
431	RHU -52 -PIPING	6-P-52032008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175656	B
432	RHU -52 -PIPING	6-P-52033009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175679	B
433	RHU -52 -PIPING	6-P-52034003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175686	B
434	RHU -52 -PIPING	6-P-52035009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175705	B
435	RHU -52 -PIPING	6-P-52036005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175721	B
436	RHU -52 -PIPING	6-P-52036007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175722	B
437	RHU -52 -PIPING	6-P-52036008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175723	B
438	RHU -55 -PIPING	6-P-55008002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177047	B
439	RHU -55 -PIPING	6-P-55009002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177055	B
440	RHU -55 -PIPING	6-P-55010002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177063	B
441	RHU -55 -PIPING	6-P-55011001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177076	B
442	RHU -55 -PIPING	6-P-55011002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177077	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
443	RHU -55 -PIPING	6-P-55011003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177078	B
444	RHU -55 -PIPING	6-P-55011004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177079	B
445	RHU -55 -PIPING	6-P-55011005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177080	B
446	RHU -55 -PIPING	6-P-55016009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177196	B
447	RHU -55 -PIPING	6-P-55017003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177203	B
448	RHU -55 -PIPING	6-P-55018002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177217	B
449	RHU -55 -PIPING	6-P-55018008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177223	B
450	RHU -55 -PIPING	6-P-55019010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177236	B
451	RHU -55 -PIPING	6-P-55019018	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177243	B
452	RHU -55 -PIPING	6-P-55021001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177267	B
453	RHU -55 -PIPING	6-P-55021009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177274	B
454	RHU -55 -PIPING	6-P-55021010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177275	B
455	RHU -55 -PIPING	6-P-55021020	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177284	B
456	RHU -55 -PIPING	6-P-55023005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177326	B
457	RHU -55 -PIPING	6-P-55025002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177364	B
458	RHU -55 -PIPING	6-P-55025003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177365	B
459	RHU -55 -PIPING	6-P-55025004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177366	B
460	RHU -55 -PIPING	6-P-55025010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177370	B
461	RHU -55 -PIPING	6-P-55025011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	177371	B
462	RHU -52 -PIPING	8-FA-52019002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175247	B
463	RHU -52 -PIPING	8-FA-52024002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175394	B
464	RHU -52 -PIPING	8-FA-52029003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175581	B
465	RHU -52 -PIPING	8-FA-52032003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175638	B
466	RHU -52 -PIPING	8-HFA-52010001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175078	B
467	RHU -52 -PIPING	8-HFA-52010005	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175082	B
468	RHU -52 -PIPING	8-HFA-52016002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175202	B
469	RHU -52 -PIPING	8-HFA-52018002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175234	B
470	RHU -52 -PIPING	8-P-52000002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174941	B
471	RHU -52 -PIPING	8-P-52001001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174959	B
472	RHU -52 -PIPING	8-P-52001002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174960	B
473	RHU -52 -PIPING	8-P-52001003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174961	B
474	RHU -52 -PIPING	8-P-52001004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174962	B
475	RHU -52 -PIPING	8-P-52001008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174966	B
476	RHU -52 -PIPING	8-P-52001010	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174968	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
477	RHU -52 -PIPING	8-P-52001017	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174975	B
478	RHU -52 -PIPING	8-P-52002001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174982	B
479	RHU -52 -PIPING	8-P-52002007	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174986	B
480	RHU -52 -PIPING	8-P-52002008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	174987	B
481	RHU -52 -PIPING	8-P-52009009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175069	B
482	RHU -52 -PIPING	8-P-52009011	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175070	B
483	RHU -52 -PIPING	8-P-52020002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175311	B
484	RHU -52 -PIPING	8-P-52020008	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175316	B
485	RHU -52 -PIPING	8-P-52021004	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175331	B
486	RHU -52 -PIPING	8-P-52023002	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175379	B
487	RHU -52 -PIPING	8-P-52023003	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175380	B
488	RHU -52 -PIPING	8-P-52025016	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175467	B
489	RHU -52 -PIPING	8-P-52025017	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175468	B
490	RHU -52 -PIPING	8-P-52025018	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175469	B
491	RHU -52 -PIPING	8-P-52025019	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175470	B
492	RHU -52 -PIPING	8-P-52025020	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175471	B
493	RHU -52 -PIPING	8-P-52025022	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175473	B
494	RHU -52 -PIPING	8-P-52025023	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175474	B
495	RHU -52 -PIPING	8-P-52025024	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175475	B
496	RHU -52 -PIPING	8-P-52025026	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175477	B
497	RHU -52 -PIPING	8-P-52032009	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175657	B
498	RHU -52 -PIPING	8-VGD-52031001	Piping inspection	PMT	5Y				I									IRI	IRI-INRC	175628	B
499	RHU -55 -55P101A	MSS-B2-3001-A11	INSPECT MV SAGR & CB B2-3001-A11	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138357	C
500	RHU -52 -52K101	MSS-B2-3001-B05	INSPECT MV SAGR & CB B2-3001-B05	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138316	C
501	RHU -55 -55P101B	MSS-B2-3001-B13	INSPECT MV SAGR & CB B2-3001-B13	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138324	C
502	RHU -52 -AIR	RHU-52-CEMS-001	PM TYPE OF AIR 52-CEMS-001 (Large 2,8)	PMT	2M				P		P					P	P	RRC	RRC-ERCH	138249	A
503	RHU -52 -AIR	RHU-52-CEMS-001	PM TYPE OF AIR 52-CEMS-001 (Large 2,8)	PMT	6M		P						P					RRC	RRC-ERCH	138249	A
504	RHU -52 -AIR	RHU-52-CEMS-101	PM TYPE OF AIR 52-CEMS-101 (Large 2,8)	PMT	2M				P		P					P	P	RRC	RRC-ERCH	138250	A
505	RHU -52 -AIR	RHU-52-CEMS-101	PM TYPE OF AIR 52-CEMS-101 (Large 2,8)	PMT	6M		P						P					RRC	RRC-ERCH	138250	A
506	RHU -52 -52E005	RHU-52000000-K01A-M	Regreasing Mot BRG of 52E005-K01A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139469	A
507	RHU -52 -52E005	RHU-52000000-K01B-M	Regreasing Mot BRG of 52E005-K01B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139470	A
508	RHU -52 -52B001	RHU-52B001-B01	FIRE HEATER ON-STREAM INSPECTION#52B001	PMT	1Y				I									IRI	IRI-INRC	150300	A
509	RHU -52 -52B001	RHU-52B001-K01-M	STAND BY CHECK LV. MOT 52B001-K01-M01	PMT	6M			T						T				RRC	RRC-ERCH	139163	B
510	RHU -52 -52B001	RHU-52B001-K02-M	STAND BY CHECK LV. MOT 52B001-K02-M01	PMT	6M			T						T				RRC	RRC-ERCH	139164	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
511	RHU -52 -52B001	RHU-52B001-PLC	INSPECT PLC SYSTEM	PMT	3M	I			I			I			I			CCS	CCS-SYS	246438	A
512	RHU -52 -52B001	RHU-52B001-PLC	BACKUP PLC SYSTEM	PMT	6M	I						I						CCS	CCS-SYS	246439	A
513	RHU -52 -52B101	RHU-52B101-B01	FIRE HEATER ON-STREAM INSPECTION#52B101	PMT	1Y				I									IRI	IRI-INRC	150299	C
514	RHU -52 -DVA5201	RHU-52DV001	TEST LINEAR HEAT DETECTOR RHU-52DV001	PMT	6M			P						P				RRC	RRC-ERCH	150105	B
515	RHU -52 -DVA5201	RHU-52DV002	TEST LINEAR HEAT DETECTOR RHU-52DV002	PMT	6M			P						P				RRC	RRC-ERCH	150106	B
516	RHU -52 -DVA5201	RHU-52DV003	TEST LINEAR HEAT DETECTOR RHU-52DV003	PMT	6M			P						P				RRC	RRC-ERCH	150107	B
517	RHU -52 -DVA5201	RHU-52DV004	TEST LINEAR HEAT DETECTOR RHU-52DV004	PMT	6M			P						P				RRC	RRC-ERCH	150108	B
518	RHU -52 -DVA5202	RHU-52DV005	TEST LINEAR HEAT DETECTOR RHU-52DV005	PMT	6M			P						P				RRC	RRC-ERCH	150109	B
519	RHU -52 -DVA5202	RHU-52DV006	TEST LINEAR HEAT DETECTOR RHU-52DV006	PMT	6M			P						P				RRC	RRC-ERCH	150110	B
520	RHU -52 -DVA5202	RHU-52DV007	TEST LINEAR HEAT DETECTOR RHU-52DV007	PMT	6M			P						P				RRC	RRC-ERCH	150111	B
521	RHU -52 -DVA5202	RHU-52DV008	TEST LINEAR HEAT DETECTOR RHU-52DV008	PMT	6M			P						P				RRC	RRC-ERCH	150112	B
522	RHU -52 -DVA5202	RHU-52DV009	TEST LINEAR HEAT DETECTOR RHU-52DV009	PMT	6M			P						P				RRC	RRC-ERCH	150113	B
523	RHU -52 -52E004	RHU-52E004A-K01A	VB. INSP & ANALY M/C 52E004A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130114	B
524	RHU -52 -52E004	RHU-52E004A-K01A	PM INSP OF M/C NO. 52E004A-K01A	PMT	3M	I			I			I			I			RRC	RRC-MRCH	129515	B
525	RHU -52 -52E004	RHU-52E004A-K01A	REGREASING BRG OF 52E004A-K01A	PMT	3M	L			L			L			L			RRC	RRC-MRCH	129965	B
526	RHU -52 -52E004A	RHU-52E004A-K01A-M	Regreasing Mot BRG of 52E004A-K01A-M01	PMT	4M	L				L			L					RRC	RRC-ERCH	139461	B
527	RHU -52 -52E004	RHU-52E004A-K01B	VB. INSP & ANALY M/C 52E004A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130115	B
528	RHU -52 -52E004	RHU-52E004A-K01B	PM INSP OF M/C NO. 52E004A-K01B	PMT	3M	I			I			I			I			RRC	RRC-MRCH	129516	B
529	RHU -52 -52E004	RHU-52E004A-K01B	REGREASING BRG OF 52E004A-K01B	PMT	3M	L			L			L			L			RRC	RRC-MRCH	129966	B
530	RHU -52 -52E004A	RHU-52E004A-K01B-M	Regreasing Mot BRG of 52E004A-K01B-M01	PMT	4M				L				L			L	L	RRC	RRC-ERCH	139462	B
531	RHU -52 -52E004	RHU-52E004B-K01A	VB. INSP & ANALY M/C 52E004B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130116	B
532	RHU -52 -52E004	RHU-52E004B-K01A	PM INSP OF M/C NO. 52E004B-K01A	PMT	3M	I			I			I			I			RRC	RRC-MRCH	129517	B
533	RHU -52 -52E004	RHU-52E004B-K01A	REGREASING BRG OF 52E004B-K01A	PMT	3M	L			L			L			L			RRC	RRC-MRCH	129967	B
534	RHU -52 -52E004B	RHU-52E004B-K01A-M	Regreasing Mot BRG of 52E004B-K01A-M01	PMT	4M	L				L			L					RRC	RRC-ERCH	139463	B
535	RHU -52 -52E004	RHU-52E004B-K01B	VB. INSP & ANALY M/C 52E004B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130117	B
536	RHU -52 -52E004	RHU-52E004B-K01B	PM INSP OF M/C NO. 52E004B-K01B	PMT	3M	I			I			I			I			RRC	RRC-MRCH	129518	B
537	RHU -52 -52E004	RHU-52E004B-K01B	REGREASING BRG OF 52E004B-K01B	PMT	3M	L			L			L			L			RRC	RRC-MRCH	129968	B
538	RHU -52 -52E004B	RHU-52E004B-K01B-M	Regreasing Mot BRG of 52E004B-K01B-M01	PMT	4M				L				L			L	L	RRC	RRC-ERCH	139464	B
539	RHU -52 -52E004	RHU-52E004C-K01A	VB. INSP & ANALY M/C 52E004C-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130118	B
540	RHU -52 -52E004	RHU-52E004C-K01A	PM INSP OF M/C NO. 52E004C-K01A	PMT	3M	I			I			I			I			RRC	RRC-MRCH	129519	B
541	RHU -52 -52E004	RHU-52E004C-K01A	REGREASING BRG OF 52E004C-K01A	PMT	3M	L			L			L			L			RRC	RRC-MRCH	129969	B
542	RHU -52 -52E004C	RHU-52E004C-K01A-M	Regreasing Mot BRG of 52E004C-K01A-M01	PMT	4M	L				L			L					RRC	RRC-ERCH	139465	B
543	RHU -52 -52E004	RHU-52E004C-K01B	VB. INSP & ANALY M/C 52E004C-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130119	B
544	RHU -52 -52E004	RHU-52E004C-K01B	PM INSP OF M/C NO. 52E004C-K01B	PMT	3M	I			I			I			I			RRC	RRC-MRCH	129520	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
545	RHU -52 -52E004	RHU-52E004C-K01B	REGREASING BRG OF 52E004C-K01B	PMT	3M	L			L			L			L			RRC	RRC-MRCH	129970	B
546	RHU -52 -52E004C	RHU-52E004C-K01B-M	Regreasing Mot BRG of 52E004C-K01B-MD1	PMT	4M				L				L			L		RRC	RRC-ERCH	139466	B
547	RHU -52 -52E004	RHU-52E004D-K01A	VB. INSP & ANALY M/C 52E004D-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130120	B
548	RHU -52 -52E004	RHU-52E004D-K01A	PM INSP OF M/C NO. 52E004D-K01A	PMT	3M	I			I			I			I			RRC	RRC-MRCH	129521	B
549	RHU -52 -52E004	RHU-52E004D-K01A	REGREASING BRG OF 52E004D-K01A	PMT	3M	L			L			L			L			RRC	RRC-MRCH	129971	B
550	RHU -52 -52E004D	RHU-52E004D-K01A-M	Regreasing Mot BRG of 52E004D-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139467	B
551	RHU -52 -52E004	RHU-52E004D-K01B	VB. INSP & ANALY M/C 52E004D-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130121	B
552	RHU -52 -52E004	RHU-52E004D-K01B	PM INSP OF M/C NO. 52E004D-K01B	PMT	3M	I			I			I			I			RRC	RRC-MRCH	129522	B
553	RHU -52 -52E004	RHU-52E004D-K01B	REGREASING BRG OF 52E004D-K01B	PMT	3M	L			L			L			L			RRC	RRC-MRCH	129972	B
554	RHU -52 -52E004D	RHU-52E004D-K01B-M	Regreasing Mot BRG of 52E004D-K01B-MD1	PMT	4M				L				L			L		RRC	RRC-ERCH	139468	B
555	RHU -52 -52E005	RHU-52E005-K01A	VB. INSP & ANALY M/C 52E005-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130122	A
556	RHU -52 -52E005	RHU-52E005-K01A	PM INSP OF M/C NO. 52E005-K01A	PMT	3M	I			I			I			I			RRC	RRC-MRCH	129523	A
557	RHU -52 -52E005	RHU-52E005-K01A	REGREASING BRG OF 52E005-K01A	PMT	3M	L			L			L			L			RRC	RRC-MRCH	129973	A
558	RHU -52 -52E005	RHU-52E005-K01B	VB. INSP & ANALY M/C 52E005-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130123	A
559	RHU -52 -52E005	RHU-52E005-K01B	PM INSP OF M/C NO. 52E005-K01B	PMT	3M	I			I			I			I			RRC	RRC-MRCH	129524	A
560	RHU -52 -52E005	RHU-52E005-K01B	REGREASING BRG OF 52E005-K01B	PMT	3M	L			L			L			L			RRC	RRC-MRCH	129974	A
561	RHU -52 -52E007	RHU-52E007A-K01A	VB. INSP & ANALY M/C 52E007A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130124	B
562	RHU -52 -52E007	RHU-52E007A-K01A	PM INSP OF M/C NO. 52E007A-K01A	PMT	3M		I			I			I			I		RRC	RRC-MRCH	129525	B
563	RHU -52 -52E007	RHU-52E007A-K01A	REGREASING BRG OF 52E007A-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	129975	B
564	RHU -52 -52E007A	RHU-52E007A-K01A-M	Regreasing Mot BRG of 52E007A-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139471	B
565	RHU -52 -52E007	RHU-52E007A-K01B	VB. INSP & ANALY M/C 52E007A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130125	B
566	RHU -52 -52E007	RHU-52E007A-K01B	PM INSP OF M/C NO. 52E007A-K01B	PMT	3M		I			I			I			I		RRC	RRC-MRCH	129526	B
567	RHU -52 -52E007	RHU-52E007A-K01B	REGREASING BRG OF 52E007A-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	129976	B
568	RHU -52 -52E007A	RHU-52E007A-K01B-M	Regreasing Mot BRG of 52E007A-K01B-MD1	PMT	4M				L				L			L		RRC	RRC-ERCH	139472	B
569	RHU -52 -52E007	RHU-52E007B-K01A	VB. INSP & ANALY M/C 52E007B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130126	B
570	RHU -52 -52E007	RHU-52E007B-K01A	PM INSP OF M/C NO. 52E007B-K01A	PMT	3M		I			I			I			I		RRC	RRC-MRCH	129527	B
571	RHU -52 -52E007	RHU-52E007B-K01A	REGREASING BRG OF 52E007B-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	129977	B
572	RHU -52 -52E007B	RHU-52E007B-K01A-M	Regreasing Mot BRG of 52E007B-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139473	B
573	RHU -52 -52E007	RHU-52E007B-K01B	VB. INSP & ANALY M/C 52E007B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130127	B
574	RHU -52 -52E007	RHU-52E007B-K01B	PM INSP OF M/C NO. 52E007B-K01B	PMT	3M		I			I			I			I		RRC	RRC-MRCH	129528	B
575	RHU -52 -52E007	RHU-52E007B-K01B	REGREASING BRG OF 52E007B-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	129978	B
576	RHU -52 -52E007B	RHU-52E007B-K01B-M	Regreasing Mot BRG of 52E007B-K01B-MD1	PMT	4M				L				L			L		RRC	RRC-ERCH	139474	B
577	RHU -52 -52E009	RHU-52E009-K01A	VB. INSP & ANALY M/C 52E009-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130128	A
578	RHU -52 -52E009	RHU-52E009-K01A	PM INSP OF M/C NO. 52E009-K01A	PMT	3M		I			I			I			I		RRC	RRC-MRCH	129529	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
579	RHU -52 -52E009	RHU-52E009-K01A	REGREASING BRG OF 52E009-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	129979	A
580	RHU -52 -52E009	RHU-52E009-K01A-M	Regreasing Mot BRG of 52E009-K01A-MD1	PMT	4M	L				L			L			L		RRC	RRC-ERCH	139475	A
581	RHU -52 -52E009	RHU-52E009-K01B	VB. INSP & ANALY M/C 52E009-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130129	A
582	RHU -52 -52E009	RHU-52E009-K01B	PM INSP OF M/C NO. 52E009-K01B	PMT	3M		I			I			I			I		RRC	RRC-MRCH	129530	A
583	RHU -52 -52E009	RHU-52E009-K01B	REGREASING BRG OF 52E009-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	129980	A
584	RHU -52 -52E009	RHU-52E009-K01B-M	Regreasing Mot BRG of 52E009-K01B-MD1	PMT	4M				L				L			L		RRC	RRC-ERCH	139476	A
585	RHU -52 -52E011	RHU-52E011A-K01A	VB. INSP & ANALY M/C 52E011A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130130	C
586	RHU -52 -52E011	RHU-52E011A-K01A	PM INSP OF M/C NO. 52E011A-K01A	PMT	3M		I			I			I			I		RRC	RRC-MRCH	129531	C
587	RHU -52 -52E011	RHU-52E011A-K01A	REGREASING BRG OF 52E011A-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	129981	C
588	RHU -52 -52E011A	RHU-52E011A-K01A-M	Regreasing Mot BRG of 52E011A-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139477	C
589	RHU -52 -52E011	RHU-52E011A-K01B	VB. INSP & ANALY M/C 52E011A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130131	C
590	RHU -52 -52E011	RHU-52E011A-K01B	PM INSP OF M/C NO. 52E011A-K01B	PMT	3M		I			I			I			I		RRC	RRC-MRCH	129532	C
591	RHU -52 -52E011	RHU-52E011A-K01B	REGREASING BRG OF 52E011A-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	129982	C
592	RHU -52 -52E011A	RHU-52E011A-K01B-M	Regreasing Mot BRG of 52E011A-K01B-MD1	PMT	4M				L				L			L		RRC	RRC-ERCH	139478	C
593	RHU -52 -52E011	RHU-52E011B-K01A	VB. INSP & ANALY M/C 52E011B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130132	C
594	RHU -52 -52E011	RHU-52E011B-K01A	PM INSP OF M/C NO. 52E011B-K01A	PMT	3M		I			I			I			I		RRC	RRC-MRCH	129533	C
595	RHU -52 -52E011	RHU-52E011B-K01A	REGREASING BRG OF 52E011B-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	129983	C
596	RHU -52 -52E011B	RHU-52E011B-K01A-M	Regreasing Mot BRG of 52E011B-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139479	C
597	RHU -52 -52E011	RHU-52E011B-K01B	VB. INSP & ANALY M/C 52E011B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130133	C
598	RHU -52 -52E011	RHU-52E011B-K01B	PM INSP OF M/C NO. 52E011B-K01B	PMT	3M		I			I			I			I		RRC	RRC-MRCH	129534	C
599	RHU -52 -52E011	RHU-52E011B-K01B	REGREASING BRG OF 52E011B-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	129984	C
600	RHU -52 -52E011B	RHU-52E011B-K01B-M	Regreasing Mot BRG of 52E011B-K01B-MD1	PMT	4M				L				L			L		RRC	RRC-ERCH	139480	C
601	RHU -52 -52E011	RHU-52E011C-K01A	VB. INSP & ANALY M/C 52E011C-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130134	C
602	RHU -52 -52E011	RHU-52E011C-K01A	PM INSP OF M/C NO. 52E011C-K01A	PMT	3M		I			I			I			I		RRC	RRC-MRCH	129535	C
603	RHU -52 -52E011	RHU-52E011C-K01A	REGREASING BRG OF 52E011C-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	129985	C
604	RHU -52 -52E011C	RHU-52E011C-K01A-M	Regreasing Mot BRG of 52E011C-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139481	C
605	RHU -52 -52E011	RHU-52E011C-K01B	VB. INSP & ANALY M/C 52E011C-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130135	C
606	RHU -52 -52E011	RHU-52E011C-K01B	PM INSP OF M/C NO. 52E011C-K01B	PMT	3M		I			I			I			I		RRC	RRC-MRCH	129536	C
607	RHU -52 -52E011	RHU-52E011C-K01B	REGREASING BRG OF 52E011C-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	129986	C
608	RHU -52 -52E011C	RHU-52E011C-K01B-M	Regreasing Mot BRG of 52E011C-K01B-MD1	PMT	4M				L				L			L		RRC	RRC-ERCH	139482	C
609	RHU -52 -52E102	RHU-52E102-K01A	VB. INSP & ANALY M/C 52E102-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130136	C
610	RHU -52 -52E102	RHU-52E102-K01A	PM INSP OF M/C NO. 52E102-K01A	PMT	3M		I			I			I			I		RRC	RRC-MRCH	129537	C
611	RHU -52 -52E102	RHU-52E102-K01A	REGREASING BRG OF 52E102-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	129987	C
612	RHU -52 -52E102	RHU-52E102-K01A-M	Regreasing Mot BRG of 52E102-K01A-MD1	PMT	4M	L				L			L			L		RRC	RRC-ERCH	139483	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
613	RHU -52 -52E102	RHU-52E102-K01B	VB. INSP & ANALY M/C 52E102-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130137	C
614	RHU -52 -52E102	RHU-52E102-K01B	PM INSP OF M/C NO. 52E102-K01B	PMT	3M		I			I			I			I		RRC	RRC-MRCH	129538	C
615	RHU -52 -52E102	RHU-52E102-K01B	REGREASING BRG OF 52E102-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	129988	C
616	RHU -52 -52E102	RHU-52E102-K01B-M	Regreasing Mot BRG of 52E102-K01B-MD1	PMT	4M				L				L			L		RRC	RRC-ERCH	139484	C
617	RHU -52 -52E103	RHU-52E103-K01A	VB. INSP & ANALY M/C 52E103-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130138	C
618	RHU -52 -52E103	RHU-52E103-K01A	PM INSP OF M/C NO. 52E103-K01A	PMT	3M		I			I			I			I		RRC	RRC-MRCH	129539	C
619	RHU -52 -52E103	RHU-52E103-K01A	REGREASING BRG OF 52E103-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	129989	C
620	RHU -52 -52E103	RHU-52E103-K01A-M	Regreasing Mot BRG of 52E103-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139485	C
621	RHU -52 -52E103	RHU-52E103-K01B	VB. INSP & ANALY M/C 52E103-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130139	C
622	RHU -52 -52E103	RHU-52E103-K01B	PM INSP OF M/C NO. 52E103-K01B	PMT	3M		I			I			I			I		RRC	RRC-MRCH	129540	C
623	RHU -52 -52E103	RHU-52E103-K01B	REGREASING BRG OF 52E103-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	129990	C
624	RHU -52 -52E103	RHU-52E103-K01B-M	Regreasing Mot BRG of 52E103-K01B-MD1	PMT	4M				L				L			L		RRC	RRC-ERCH	139486	C
625	RHU -52 -52H001	RHU-52H001-H01	Over Head Crane Inspection By	INT	6M				I					I				IRI	IRI-INSS	130570	C
626	RHU -52 -52H001	RHU-52H001-H01	PM OF 52H001	PMT	6M	P						P						RRC	RRC-MRCH	148837	C
627	RHU -52 -52H001	RHU-52H001-H01	PM INSP OF M/C NO. 52H001	PMT	4M		I			I				I				RRC	RRC-MRCH	149129	C
628	RHU -52 -52K001	RHU-52K001-K01	PM COMPRESSOR NO. 52K001	PMT	1Y								I					CRE	CRE-CHIP	129957	A
629	RHU -52 -52K001	RHU-52K001-K01	PM COMPRESSOR NO. 52K001	PMT	1Y								I					CRE	CRE-CHIP	155802	A
630	RHU -52 -52K001	RHU-52K001-K01	OIL INSP & ANALYSIS M/C 52K001	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INDL	130080	A
631	RHU -52 -52K001	RHU-52K001-K01	VANISH INSP&ANALYSIS	INT	6M				I					I				IRI	IRI-INDL	157624	A
632	RHU -52 -52K001	RHU-52K001-P01	PM INSP OF M/C NO.RHU-52K001 -P01	PMT	4M	I			I				I					RRC	RRC-MRCH	155821	A
633	RHU -52 -52K001	RHU-52K001-P01-M	Regreasing Mot BRG of 52K001-P01-MD1	PMT	4M	L			L				L					RRC	RRC-ERCH	139487	A
634	RHU -52 -52K001	RHU-52K001-P02	PM INSP OF M/C NO.RHU-52K001 -P02	PMT	4M		I			I				I				RRC	RRC-MRCH	155822	A
635	RHU -52 -52K001	RHU-52K001-P02-M	Regreasing Mot BRG of 52K001-P02-MD1	PMT	4M				L				L			L		RRC	RRC-ERCH	139488	A
636	RHU -52 -52K001	RHU-52K001-P03	PM INSP OF M/C NO.RHU-52K001 -P03	PMT	4M			I				I			I			RRC	RRC-MRCH	155823	A
637	RHU -52 -52K002A	RHU-52K002A-M	STAND BY CHECK MV. MOT 52K002A-MD1	PMT	1Y							T						RRC	RRC-ERCH	139191	B
638	RHU -52 -52K002A	RHU-52K002A-M	Change BRG Lube Oil of Mot 52K002A-MD1	PMT	1Y				L									RRC	RRC-ERCH	139380	B
639	RHU -52 -52K002A	RHU-52K002A-M	STAND BY CHECK MV. MOT 52K002A-MD1	PMT	1Y				T									RRC	RRC-ERCH	154275	B
640	RHU -52 -52K002A	RHU-52K002A-P01	PM INSP OF M/C NO.RHU-52K002A -P01	PMT	4M		I			I			I			I		RRC	RRC-MRCH	155824	B
641	RHU -52 -52K002A	RHU-52K002A-P02	PM INSP OF M/C NO.RHU-52K002A -P02	PMT	4M		I			I			I			I		RRC	RRC-MRCH	155825	B
642	RHU -52 -52K002A	RHU-52K002A-P02-M	Regreasing Mot BRG of 52K002A-P02-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139489	B
643	RHU -52 -52K002B	RHU-52K002B-K01	PM COMPRESSOR NO. 52K002B	PMT	1Y								P					CRE	CRE-CHIP	129543	B
644	RHU -52 -52K002B	RHU-52K002B-K01	OIL INSP & ANALYSIS M/C 52K002B	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INDL	129993	B
645	RHU -52 -52K002B	RHU-52K002B-M	STAND BY CHECK MV. MOT 52K002B-MD1	PMT	6M			T					T					RRC	RRC-ERCH	139192	B
646	RHU -52 -52K002B	RHU-52K002B-M	Change BRG Lube Oil of Mot 52K002B-MD1	PMT	1Y				L									RRC	RRC-ERCH	139381	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
647	RHU -52 -52K002B	RHU-52K002B-P01	PM INSP OF M/C NO.RHU -52K002B -P01	PMT	4M				I				I				I	RRC	RRC-MRCH	155826	B
648	RHU -52 -52K002B	RHU-52K002B-P02	PM INSP OF M/C NO.RHU -52K002B -P02	PMT	4M				I				I				I	RRC	RRC-MRCH	155827	B
649	RHU -52 -52K002B	RHU-52K002B-P02-M	Regreasing Mot BRG of 52K002B-P02-MD1	PMT	4M				L				L				L	RRC	RRC-ERCH	139490	B
650	RHU -52 -52K101	RHU-52K101-K01	PM COMPRESSOR NO. 52K101	PMT	1Y												P	CRE	CRE-CHIP	129541	C
651	RHU -52 -52K101	RHU-52K101-K01	OIL INSP & ANALYSIS M/C 52K101	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INDL	129991	C
652	RHU -52 -52K101	RHU-52K101-M	STAND BY CHECK MV. MOT 52K101-MD1	PMT	6M			T					T					RRC	RRC-ERCH	139193	C
653	RHU -52 -52P001A	RHU-52P001A-M	STAND BY CHECK MV. MOT 52P001A-MD1	PMT	1Y								T					RRC	RRC-ERCH	139194	C
654	RHU -52 -52P001A	RHU-52P001A-M	STAND BY CHECK MV. MOT 52P001A-MD1	PMT	1Y				T									RRC	RRC-ERCH	154276	C
655	RHU -52 -52P001A	RHU-52P001A-P01A	OIL INSP & ANALYSIS M/C 52P001A -P01	INT	1M	I	I											IRI	IRI-INDL	152194	C
656	RHU -52 -52P001A	RHU-52P001A-P01A	VB. INSP & ANALY M/C 52P001A	INT	4M	I				I			I			I		IRI	IRI-INVB	130143	C
657	RHU -52 -52P001A	RHU-52P001A-P01A	VB. INSP & ANALY M/C 52P001A	INT	4M		I				I			I				IRI	IRI-INVB	130957	C
658	RHU -52 -52P001A	RHU-52P001A-P01A	VB. INSP & ANALY M/C 52P001A	INT	4M			I				I			I			IRI	IRI-INVB	131182	C
659	RHU -52 -52P001A	RHU-52P001A-P01A	PM INSP OF M/C NO. 52P001A	PMT	4M		I				I			I				RRC	RRC-MRCH	129544	C
660	RHU -52 -52P001B	RHU-52P001B-M	STAND BY CHECK MV. MOT 52P001B-MD1	PMT	6M			T					T					RRC	RRC-ERCH	139195	C
661	RHU -52 -52P001B	RHU-52P001B-P01A	OIL INSP & ANALYSIS M/C 52P001B -P01	INT	1M	I	I											IRI	IRI-INDL	152195	C
662	RHU -52 -52P001B	RHU-52P001B-P01A	VB. INSP & ANALY M/C 52P001B	INT	4M					I			I			I		IRI	IRI-INVB	130144	C
663	RHU -52 -52P001B	RHU-52P001B-P01A	PM INSP OF M/C NO. 52P001B	PMT	4M					I			I			I		RRC	RRC-MRCH	129545	C
664	RHU -52 -52P002A	RHU-52P002A-M	STAND BY CHECK MV. MOT 52P002A-MD1	PMT	1Y								T					RRC	RRC-ERCH	139196	C
665	RHU -52 -52P002A	RHU-52P002A-M	Change BRG Lube Oil of Mot 52P002A-MD1	PMT	1Y					L								RRC	RRC-ERCH	139384	C
666	RHU -52 -52P002A	RHU-52P002A-M	STAND BY CHECK MV. MOT 52P002A-MD1	PMT	1Y					T								RRC	RRC-ERCH	154277	C
667	RHU -52 -52P002A	RHU-52P002A-P01	PM INSP OF M/C NO. 52P002A	PMT	4M			I				I			I			RRC	RRC-MRCH	129546	C
668	RHU -52 -52P002A	RHU-52P002A-P01	PM OF 52P002A	PMT	6M			P						P				RRC	RRC-MRCH	130602	C
669	RHU -52 -52P002B	RHU-52P002B-M	STAND BY CHECK MV. MOT 52P002B-MD1	PMT	6M				T						T			RRC	RRC-ERCH	139197	C
670	RHU -52 -52P002B	RHU-52P002B-M	Change BRG Lube Oil of Mot 52P002B-MD1	PMT	1Y					L								RRC	RRC-ERCH	139385	C
671	RHU -52 -52P002B	RHU-52P002B-P01	PM INSP OF M/C NO. 52P002B	PMT	4M					I			I			I		RRC	RRC-MRCH	129547	C
672	RHU -52 -52P002B	RHU-52P002B-P01	PM OF 52P002B	PMT	4M	P					P			P				RRC	RRC-MRCH	130603	C
673	RHU -52 -52P003A	RHU-52P003A-M	STAND BY CHECK LV. MOT 52P003A-MD1	PMT	1Y								T					RRC	RRC-ERCH	139198	C
674	RHU -52 -52P003A	RHU-52P003A-M	Regreasing Mot BRG of 52P003A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139493	C
675	RHU -52 -52P003A	RHU-52P003A-M	STAND BY CHECK LV. MOT 52P003A-MD1	PMT	1Y					T								RRC	RRC-ERCH	154278	C
676	RHU -52 -52P003A	RHU-52P003A-P01	VB. INSP & ANALY M/C 52P003A	INT	4M	I				I			I			I		IRI	IRI-INVB	130147	C
677	RHU -52 -52P003A	RHU-52P003A-P01	VB. INSP & ANALY M/C 52P003A	INT	4M		I				I			I			I	IRI	IRI-INVB	130959	C
678	RHU -52 -52P003A	RHU-52P003A-P01	VB. INSP & ANALY M/C 52P003A	INT	4M			I				I			I			IRI	IRI-INVB	131184	C
679	RHU -52 -52P003A	RHU-52P003A-P01	PM INSP OF M/C NO. 52P003A	PMT	4M		I				I			I				RRC	RRC-MRCH	129548	C
680	RHU -52 -52P003A	RHU-52P003A-P01	PM OF 52P003A	PMT	6M		P					P						RRC	RRC-MRCH	130604	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
681	RHU -52 -52P003B	RHU-52P003B-M	STAND BY CHECK LV. MOT 52P003B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139199	C
682	RHU -52 -52P003B	RHU-52P003B-M	Regreasing Mot BRG of 52P003B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139494	C
683	RHU -52 -52P003B	RHU-52P003B-P01	VB. INSP & ANALY M/C 52P003B	INT	4M					I			I				I	IRI	IRI-INVB	130148	C
684	RHU -52 -52P003B	RHU-52P003B-P01	PM INSP OF M/C NO. 52P003B	PMT	4M				I				I				I	RRC	RRC-MRCH	129549	C
685	RHU -52 -52P003B	RHU-52P003B-P01	PM OF 52P003B	PMT	4M	P				P				P				RRC	RRC-MRCH	130605	C
686	RHU -52 -52P004A	RHU-52P004A-M	STAND BY CHECK LV. MOT 52P004A-M01	PMT	1Y								T					RRC	RRC-ERCH	139200	C
687	RHU -52 -52P004A	RHU-52P004A-M	STAND BY CHECK LV. MOT 52P004A-M01	PMT	1Y				T									RRC	RRC-ERCH	154279	C
688	RHU -52 -52P004A	RHU-52P004A-P01	VB. INSP & ANALY M/C 52P004A	INT	4M	I				I				I				IRI	IRI-INVB	130149	C
689	RHU -52 -52P004A	RHU-52P004A-P01	VB. INSP & ANALY M/C 52P004A	INT	4M		I				I				I			IRI	IRI-INVB	130960	C
690	RHU -52 -52P004A	RHU-52P004A-P01	VB. INSP & ANALY M/C 52P004A	INT	4M			I				I				I		IRI	IRI-INVB	131185	C
691	RHU -52 -52P004A	RHU-52P004A-P01	PM INSP OF M/C NO. 52P004A	PMT	4M	I				I				I				RRC	RRC-MRCH	129550	C
692	RHU -52 -52P004A	RHU-52P004A-P01	PM OF 52P004A	PMT	4M				P			P					P	RRC	RRC-MRCH	130606	C
693	RHU -52 -52P004B	RHU-52P004B-M	STAND BY CHECK LV. MOT 52P004B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139201	C
694	RHU -52 -52P004B	RHU-52P004B-P01	VB. INSP & ANALY M/C 52P004B	INT	4M				I			I					I	IRI	IRI-INVB	130150	C
695	RHU -52 -52P004B	RHU-52P004B-P01	PM INSP OF M/C NO. 52P004B	PMT	4M				I			I					I	RRC	RRC-MRCH	129551	C
696	RHU -52 -52P004B	RHU-52P004B-P01	PM OF 52P004B	PMT	4M	P				P				P				RRC	RRC-MRCH	130607	C
697	RHU -52 -52P005A	RHU-52P005A-M	STAND BY CHECK LV. MOT 52P005A-M01	PMT	1Y								T					RRC	RRC-ERCH	139202	C
698	RHU -52 -52P005A	RHU-52P005A-M	Regreasing Mot BRG of 52P005A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139495	C
699	RHU -52 -52P005A	RHU-52P005A-M	STAND BY CHECK LV. MOT 52P005A-M01	PMT	1Y				T									RRC	RRC-ERCH	154280	C
700	RHU -52 -52P005A	RHU-52P005A-P01	VB. INSP & ANALY M/C 52P005A	INT	4M	I				I				I				IRI	IRI-INVB	130151	C
701	RHU -52 -52P005A	RHU-52P005A-P01	VB. INSP & ANALY M/C 52P005A	INT	4M		I				I				I			IRI	IRI-INVB	130961	C
702	RHU -52 -52P005A	RHU-52P005A-P01	VB. INSP & ANALY M/C 52P005A	INT	4M			I				I				I		IRI	IRI-INVB	131186	C
703	RHU -52 -52P005A	RHU-52P005A-P01	PM INSP OF M/C NO. 52P005A	PMT	4M	I				I				I				RRC	RRC-MRCH	129552	C
704	RHU -52 -52P005A	RHU-52P005A-P01	PM OF 52P005A	PMT	6M		P					P						RRC	RRC-MRCH	130608	C
705	RHU -52 -52P005B	RHU-52P005B-M	STAND BY CHECK LV. MOT 52P005B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139203	C
706	RHU -52 -52P005B	RHU-52P005B-M	Regreasing Mot BRG of 52P005B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139496	C
707	RHU -52 -52P005B	RHU-52P005B-P01	VB. INSP & ANALY M/C 52P005B	INT	4M				I				I				I	IRI	IRI-INVB	130152	C
708	RHU -52 -52P005B	RHU-52P005B-P01	PM INSP OF M/C NO. 52P005B	PMT	4M				I				I				I	RRC	RRC-MRCH	129553	C
709	RHU -52 -52P005B	RHU-52P005B-P01	PM OF 52P005B	PMT	4M	P				P				P				RRC	RRC-MRCH	130609	C
710	RHU -52 -52P006A	RHU-52P006A-M	STAND BY CHECK LV. MOT 52P006A-M01	PMT	1Y								T					RRC	RRC-ERCH	139204	C
711	RHU -52 -52P006A	RHU-52P006A-M	Regreasing Mot BRG of 52P006A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139497	C
712	RHU -52 -52P006A	RHU-52P006A-M	STAND BY CHECK LV. MOT 52P006A-M01	PMT	1Y				T									RRC	RRC-ERCH	154281	C
713	RHU -52 -52P006A	RHU-52P006A-P01	VB. INSP & ANALY M/C 52P006A	INT	4M	I				I				I				IRI	IRI-INVB	130153	C
714	RHU -52 -52P006A	RHU-52P006A-P01	VB. INSP & ANALY M/C 52P006A	INT	4M		I				I				I			IRI	IRI-INVB	130962	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
715	RHU -52 -52P006A	RHU-52P006A-P01	VB. INSP & ANALY M/C 52P006A	INT	4M			I				I				I		IRI	IRI-INVB	131187	C
716	RHU -52 -52P006A	RHU-52P006A-P01	PM INSP OF M/C NO. 52P006A	PMT	4M	I				I				I				RRC	RRC-MRCH	129554	C
717	RHU -52 -52P006A	RHU-52P006A-P01	PM OF 52P006A	PMT	6M		P						P					RRC	RRC-MRCH	130610	C
718	RHU -52 -52P006B	RHU-52P006B-M	STAND BY CHECK LV. MOT 52P006B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139205	C
719	RHU -52 -52P006B	RHU-52P006B-M	Regreasing Mot BRG of 52P006B-M01	PMT	4M					L				L				RRC	RRC-ERCH	139498	C
720	RHU -52 -52P006B	RHU-52P006B-P01	VB. INSP & ANALY M/C 52P006B	INT	4M					I				I				IRI	IRI-INVB	130154	C
721	RHU -52 -52P006B	RHU-52P006B-P01	PM INSP OF M/C NO. 52P006B	PMT	4M					I				I				RRC	RRC-MRCH	129555	C
722	RHU -52 -52P006B	RHU-52P006B-P01	PM OF 52P006B	PMT	4M	P					P				P			RRC	RRC-MRCH	130611	C
723	RHU -52 -52P007A	RHU-52P007A-M	STAND BY CHECK MV. MOT 52P007A-M01	PMT	1Y									T				RRC	RRC-ERCH	139206	C
724	RHU -52 -52P007A	RHU-52P007A-M	STAND BY CHECK MV. MOT 52P007A-M01	PMT	1Y					T								RRC	RRC-ERCH	154282	C
725	RHU -52 -52P007A	RHU-52P007A-P01A	OIL INSP & ANALYSIS M/C 52P007A -P01	INT	1M	I	I											IRI	IRI-INDL	152196	C
726	RHU -52 -52P007A	RHU-52P007A-P01A	VB. INSP & ANALY M/C 52P007A	INT	4M	I				I				I				IRI	IRI-INVB	130155	C
727	RHU -52 -52P007A	RHU-52P007A-P01A	VB. INSP & ANALY M/C 52P007A	INT	4M		I				I				I			IRI	IRI-INVB	130963	C
728	RHU -52 -52P007A	RHU-52P007A-P01A	VB. INSP & ANALY M/C 52P007A	INT	4M			I				I				I		IRI	IRI-INVB	131188	C
729	RHU -52 -52P007A	RHU-52P007A-P01A	PM INSP OF M/C NO. 52P007A	PMT	4M	I				I				I				RRC	RRC-MRCH	129556	C
730	RHU -52 -52P007B	RHU-52P007B-M	STAND BY CHECK MV. MOT 52P007B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139207	C
731	RHU -52 -52P007B	RHU-52P007B-P01A	OIL INSP & ANALYSIS M/C 52P007B -P01	INT	1M	I	I											IRI	IRI-INDL	152197	C
732	RHU -52 -52P007B	RHU-52P007B-P01A	VB. INSP & ANALY M/C 52P007B	INT	4M					I				I				IRI	IRI-INVB	130156	C
733	RHU -52 -52P007B	RHU-52P007B-P01A	PM INSP OF M/C NO. 52P007B	PMT	4M					I				I				RRC	RRC-MRCH	129557	C
734	RHU -52 -52P009A	RHU-52P009A-M	STAND BY CHECK LV. MOT 52P009A-M01	PMT	1Y									T				RRC	RRC-ERCH	139208	C
735	RHU -52 -52P009A	RHU-52P009A-M	STAND BY CHECK LV. MOT 52P009A-M01	PMT	1Y					T								RRC	RRC-ERCH	154283	C
736	RHU -52 -52P009A	RHU-52P009A-P01	VB. INSP & ANALY M/C 52P009A	INT	4M	I					I			I				IRI	IRI-INVB	130157	C
737	RHU -52 -52P009A	RHU-52P009A-P01	VB. INSP & ANALY M/C 52P009A	INT	4M		I					I			I			IRI	IRI-INVB	130964	C
738	RHU -52 -52P009A	RHU-52P009A-P01	VB. INSP & ANALY M/C 52P009A	INT	4M			I					I			I		IRI	IRI-INVB	131189	C
739	RHU -52 -52P009A	RHU-52P009A-P01	PM INSP OF M/C NO. 52P009A	PMT	4M		I				I				I			RRC	RRC-MRCH	129558	C
740	RHU -52 -52P009A	RHU-52P009A-P01	PM OF 52P009A	PMT	4M				P				P				P	RRC	RRC-MRCH	130613	C
741	RHU -52 -52P009B	RHU-52P009B-M	STAND BY CHECK LV. MOT 52P009B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139209	C
742	RHU -52 -52P009B	RHU-52P009B-P01	VB. INSP & ANALY M/C 52P009B	INT	4M				I				I				I	IRI	IRI-INVB	130158	C
743	RHU -52 -52P009B	RHU-52P009B-P01	PM INSP OF M/C NO. 52P009B	PMT	4M				I				I				I	RRC	RRC-MRCH	129559	C
744	RHU -52 -52P009B	RHU-52P009B-P01	PM OF 52P009B	PMT	4M		P				P			P				RRC	RRC-MRCH	130614	C
745	RHU -52 -52P010A	RHU-52P010A-M	STAND BY CHECK LV. MOT 52P010A-M01	PMT	1Y								T					RRC	RRC-ERCH	139210	C
746	RHU -52 -52P010A	RHU-52P010A-M	STAND BY CHECK LV. MOT 52P010A-M01	PMT	1Y					T								RRC	RRC-ERCH	154284	C
747	RHU -52 -52P010A	RHU-52P010A-P01	VB. INSP & ANALY M/C 52P010A	INT	4M	I				I				I				IRI	IRI-INVB	130159	C
748	RHU -52 -52P010A	RHU-52P010A-P01	VB. INSP & ANALY M/C 52P010A	INT	4M		I				I				I			IRI	IRI-INVB	130965	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
749	RHU -52 -52P010A	RHU-52P010A-P01	VB. INSP & ANALY M/C 52P010A	INT	4M			I				I				I		IRI	IRI-INVB	131190	C
750	RHU -52 -52P010A	RHU-52P010A-P01	PM INSP OF M/C NO. 52P010A	PMT	4M		I				I				I			RRC	RRC-MRCH	129560	C
751	RHU -52 -52P010A	RHU-52P010A-P01	PM OF 52P010A	PMT	4M				P			P				P		RRC	RRC-MRCH	130615	C
752	RHU -52 -52P010B	RHU-52P010B-M	STAND BY CHECK LV. MOT 52P010B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139211	C
753	RHU -52 -52P010B	RHU-52P010B-P01	VB. INSP & ANALY M/C 52P010B	INT	4M				I			I				I		IRI	IRI-INVB	130160	C
754	RHU -52 -52P010B	RHU-52P010B-P01	PM INSP OF M/C NO. 52P010B	PMT	4M				I			I				I		RRC	RRC-MRCH	129561	C
755	RHU -52 -52P010B	RHU-52P010B-P01	PM OF 52P010B	PMT	4M		P				P			P				RRC	RRC-MRCH	130616	C
756	RHU -52 -52P101	RHU-52P101-M	STAND BY CHECK LV. MOT 52P101-M01	PMT	6M		T					T						RRC	RRC-ERCH	139212	C
757	RHU -52 -52P101	RHU-52P101-M	Regreasing Mot BRG of 52P101-M01	PMT	4M	L			L				L					RRC	RRC-ERCH	139499	C
758	RHU -52 -52P101	RHU-52P101-P01	VB. INSP & ANALY M/C 52P101	INT	4M	I			I				I					IRI	IRI-INVB	130161	C
759	RHU -52 -52P101	RHU-52P101-P01	VB. INSP & ANALY M/C 52P101	INT	4M		I			I				I				IRI	IRI-INVB	131065	C
760	RHU -52 -52P101	RHU-52P101-P01	VB. INSP & ANALY M/C 52P101	INT	4M			I			I		I			I		IRI	IRI-INVB	131191	C
761	RHU -52 -52P101	RHU-52P101-P01	PM INSP OF M/C NO. 52P101	PMT	4M		I			I				I				RRC	RRC-MRCH	129562	C
762	RHU -52 -52P101	RHU-52P101-P01	PM OF 52P101	PMT	4M		P				P			P				RRC	RRC-MRCH	130617	C
763	RHU -52 -52P102	RHU-52P102-M	STAND BY CHECK LV. MOT 52P102-M01	PMT	6M		T					T						RRC	RRC-ERCH	139213	C
764	RHU -52 -52P102	RHU-52P102-M	Regreasing Mot BRG of 52P102-M01	PMT	4M	L			L				L					RRC	RRC-ERCH	139500	C
765	RHU -52 -52P102	RHU-52P102-P01	VB. INSP & ANALY M/C 52P102	INT	4M	I				I				I				IRI	IRI-INVB	130162	C
766	RHU -52 -52P102	RHU-52P102-P01	VB. INSP & ANALY M/C 52P102	INT	4M		I				I				I			IRI	IRI-INVB	130966	C
767	RHU -52 -52P102	RHU-52P102-P01	VB. INSP & ANALY M/C 52P102	INT	4M			I				I				I		IRI	IRI-INVB	131192	C
768	RHU -52 -52P102	RHU-52P102-P01	PM INSP OF M/C NO. 52P102	PMT	4M		I				I				I			RRC	RRC-MRCH	129563	C
769	RHU -52 -52P102	RHU-52P102-P01	PM OF 52P102	PMT	4M				P			P					P	RRC	RRC-MRCH	130618	C
770	RHU -52 -52P103	RHU-52P103-M	STAND BY CHECK LV. MOT 52P103-M01	PMT	6M			T						T				RRC	RRC-ERCH	139214	C
771	RHU -52 -52P103	RHU-52P103-M	Regreasing Mot BRG of 52P103-M01	PMT	4M	L			L				L					RRC	RRC-ERCH	139501	C
772	RHU -52 -52P103	RHU-52P103-P01	VB. INSP & ANALY M/C 52P103	INT	4M				I			I				I		IRI	IRI-INVB	130163	C
773	RHU -52 -52P103	RHU-52P103-P01	PM INSP OF M/C NO. 52P103	PMT	4M				I			I				I		RRC	RRC-MRCH	129564	C
774	RHU -52 -52P103	RHU-52P103-P01	PM OF 52P103	PMT	4M			P				P				P		RRC	RRC-MRCH	130619	C
775	RHU -52 -52P104A	RHU-52P104A-M	STAND BY CHECK LV. MOT 52P104A-M01	PMT	1Y								T					RRC	RRC-ERCH	139215	C
776	RHU -52 -52P104A	RHU-52P104A-M	Regreasing Mot BRG of 52P104A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139502	C
777	RHU -52 -52P104A	RHU-52P104A-M	STAND BY CHECK LV. MOT 52P104A-M01	PMT	1Y				T									RRC	RRC-ERCH	154285	C
778	RHU -52 -52P104A	RHU-52P104A-P01	VB. INSP & ANALY M/C 52P104A	INT	4M	I				I				I				IRI	IRI-INVB	130164	C
779	RHU -52 -52P104A	RHU-52P104A-P01	VB. INSP & ANALY M/C 52P104A	INT	4M		I				I				I			IRI	IRI-INVB	130967	C
780	RHU -52 -52P104A	RHU-52P104A-P01	VB. INSP & ANALY M/C 52P104A	INT	4M			I				I				I		IRI	IRI-INVB	131193	C
781	RHU -52 -52P104A	RHU-52P104A-P01	PM INSP OF M/C NO. 52P104A	PMT	4M		I				I				I			RRC	RRC-MRCH	129565	C
782	RHU -52 -52P104A	RHU-52P104A-P01	PM OF 52P104A	PMT	4M				P			P					P	RRC	RRC-MRCH	130620	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
783	RHU -52 -52P104B	RHU-52P104B-M	STAND BY CHECK LV. MOT 52P104B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139216	C
784	RHU -52 -52P104B	RHU-52P104B-M	Regreasing Mot BRG of 52P104B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139503	C
785	RHU -52 -52P104B	RHU-52P104B-P01	VB. INSP & ANALY M/C 52P104B	INT	4M				I				I				I	IRI	IRI-INVB	130165	C
786	RHU -52 -52P104B	RHU-52P104B-P01	PM INSP OF M/C NO. 52P104B	PMT	4M				I				I				I	RRC	RRC-MRCH	129566	C
787	RHU -52 -52P104B	RHU-52P104B-P01	PM OF 52P104B	PMT	4M		P				P			P				RRC	RRC-MRCH	130621	C
788	RHU -52 -52X003	RHU-52X003-P01A	PM OF 52X003 -P01A	PMT	4M			P				P			P			RRC	RRC-MRCH	148831	C
789	RHU -52 -52X003	RHU-52X003-P01A	PM INSP OF M/C NO. 52X003 -P01A	PMT	4M	I				I				I				RRC	RRC-MRCH	149123	C
790	RHU -52 -52X003	RHU-52X003-P01B	PM OF 52X003 -P01B	PMT	4M		P				P				P			RRC	RRC-MRCH	148832	C
791	RHU -52 -52X003	RHU-52X003-P01B	PM INSP OF M/C NO. 52X003 -P01B	PMT	4M		I				I				I			RRC	RRC-MRCH	149124	C
792	RHU -52 -52X003	RHU-52X003-P02A	PM OF 52X003 -P02A	PMT	4M			P			P				P			RRC	RRC-MRCH	148833	C
793	RHU -52 -52X003	RHU-52X003-P02A	PM INSP OF M/C NO. 52X003 -P02A	PMT	4M	I				I				I				RRC	RRC-MRCH	149125	C
794	RHU -52 -52X003	RHU-52X003-P02B	PM OF 52X003 -P02B	PMT	4M		P				P				P			RRC	RRC-MRCH	148834	C
795	RHU -52 -52X003	RHU-52X003-P02B	PM INSP OF M/C NO. 52X003 -P02B	PMT	4M		I				I				I			RRC	RRC-MRCH	149126	C
796	RHU -52 -52X005	RHU-52X005-PLC	INSPECT PLC SYSTEM	PMT	3M	I				I			I					CCS	CCS-SYS	246440	A
797	RHU -52 -52X005	RHU-52X005-PLC	BACKUP PLC SYSTEM	PMT	6M	I						I						CCS	CCS-SYS	246441	A
798	RHU -55 -DVA5501	RHU-55DV001	TEST LINEAR HEAT DETECTOR RHU-55DV001	PMT	6M				P					P				RRC	RRC-ERCH	150114	B
799	RHU -55 -DVA5501	RHU-55DV002	TEST LINEAR HEAT DETECTOR RHU-55DV002	PMT	6M				P					P				RRC	RRC-ERCH	150115	B
800	RHU -55 -DVA5501	RHU-55DV003	TEST LINEAR HEAT DETECTOR RHU-55DV003	PMT	6M				P					P				RRC	RRC-ERCH	150116	B
801	RHU -55 -DVA5501	RHU-55DV004	TEST LINEAR HEAT DETECTOR RHU-55DV004	PMT	6M				P					P				RRC	RRC-ERCH	150117	B
802	RHU -55 -DVA5501	RHU-55DV005	TEST LINEAR HEAT DETECTOR RHU-55DV005	PMT	6M				P					P				RRC	RRC-ERCH	150118	B
803	RHU -55 -DVA5501	RHU-55DV006	TEST LINEAR HEAT DETECTOR RHU-55DV006	PMT	6M				P					P				RRC	RRC-ERCH	150119	B
804	RHU -55 -55E004	RHU-55E004-K01A	VB. INSP & ANALY M/C 55E004-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130266	B
805	RHU -55 -55E004	RHU-55E004-K01A	PM INSP OF M/C NO. 55E004-K01A	PMT	3M				I			I				I		RRC	RRC-MRCH	129667	B
806	RHU -55 -55E004	RHU-55E004-K01A	REGREASING BRG OF 55E004-K01A	PMT	3M				L			L				L		RRC	RRC-MRCH	130006	B
807	RHU -55 -55E004	RHU-55E004-K01A-M	Regreasing Mot BRG of 55E004-K01A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139601	B
808	RHU -55 -55E004	RHU-55E004-K01B	VB. INSP & ANALY M/C 55E004-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130267	B
809	RHU -55 -55E004	RHU-55E004-K01B	PM INSP OF M/C NO. 55E004-K01B	PMT	3M				I			I				I		RRC	RRC-MRCH	129668	B
810	RHU -55 -55E004	RHU-55E004-K01B	REGREASING BRG OF 55E004-K01B	PMT	3M				L			L				L		RRC	RRC-MRCH	130007	B
811	RHU -55 -55E004	RHU-55E004-K01B-M	Regreasing Mot BRG of 55E004-K01B-M01	PMT	4M			L					L					RRC	RRC-ERCH	139602	B
812	RHU -55 -55E007	RHU-55E007-K01A	VB. INSP & ANALY M/C 55E007-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130268	B
813	RHU -55 -55E007	RHU-55E007-K01A	PM INSP OF M/C NO. 55E007-K01A	PMT	3M				I			I				I		RRC	RRC-MRCH	129669	B
814	RHU -55 -55E007	RHU-55E007-K01A	REGREASING BRG OF 55E007-K01A	PMT	3M				L			L				L		RRC	RRC-MRCH	130008	B
815	RHU -55 -55E007	RHU-55E007-K01A-M	Regreasing Mot BRG of 55E007-K01A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139603	B
816	RHU -55 -55E007	RHU-55E007-K01B	VB. INSP & ANALY M/C 55E007-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130269	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
817	RHU -55 -55E007	RHU-55E007-K01B	PM INSP OF M/C NO. 55E007-K01B	PMT	3M			I			I			I			I	RRC	RRC-MRCH	129670	B
818	RHU -55 -55E007	RHU-55E007-K01B	REGREASING BRG OF 55E007-K01B	PMT	3M			L			L			L			L	RRC	RRC-MRCH	130009	B
819	RHU -55 -55E007	RHU-55E007-K01B-M	Regreasing Mot BRG of 55E007-K01B-MD1	PMT	4M				L			L			L			RRC	RRC-ERCH	139604	B
820	RHU -55 -55E103	RHU-55E103-K01A	VB. INSP & ANALY M/C 55E103-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130270	B
821	RHU -55 -55E103	RHU-55E103-K01A	PM INSP OF M/C NO. 55E103-K01A	PMT	3M			I			I			I			I	RRC	RRC-MRCH	129671	B
822	RHU -55 -55E103	RHU-55E103-K01A	REGREASING BRG OF 55E103-K01A	PMT	3M			L			L			L			L	RRC	RRC-MRCH	130010	B
823	RHU -55 -55E103	RHU-55E103-K01A-M	Regreasing Mot BRG of 55E103-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139605	B
824	RHU -55 -55E103	RHU-55E103-K01B	VB. INSP & ANALY M/C 55E103-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130271	B
825	RHU -55 -55E103	RHU-55E103-K01B	PM INSP OF M/C NO. 55E103-K01B	PMT	3M			I			I			I			I	RRC	RRC-MRCH	129672	B
826	RHU -55 -55E103	RHU-55E103-K01B	REGREASING BRG OF 55E103-K01B	PMT	3M			L			L			L			L	RRC	RRC-MRCH	130011	B
827	RHU -55 -55E103	RHU-55E103-K01B-M	Regreasing Mot BRG of 55E103-K01B-MD1	PMT	4M				L			L			L			RRC	RRC-ERCH	139606	B
828	RHU -55 -55E104	RHU-55E104-K01A	VB. INSP & ANALY M/C 55E104-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130272	B
829	RHU -55 -55E104	RHU-55E104-K01A	PM INSP OF M/C NO. 55E104-K01A	PMT	3M			I			I			I			I	RRC	RRC-MRCH	129673	B
830	RHU -55 -55E104	RHU-55E104-K01A	REGREASING BRG OF 55E104-K01A	PMT	3M			L			L			L			L	RRC	RRC-MRCH	130012	B
831	RHU -55 -55E104	RHU-55E104-K01A-M	Regreasing Mot BRG of 55E104-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139607	B
832	RHU -55 -55E104	RHU-55E104-K01B	VB. INSP & ANALY M/C 55E104-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130273	B
833	RHU -55 -55E104	RHU-55E104-K01B	PM INSP OF M/C NO. 55E104-K01B	PMT	3M			I			I			I			I	RRC	RRC-MRCH	129674	B
834	RHU -55 -55E104	RHU-55E104-K01B	REGREASING BRG OF 55E104-K01B	PMT	3M			L			L			L			L	RRC	RRC-MRCH	130013	B
835	RHU -55 -55E104	RHU-55E104-K01B-M	Regreasing Mot BRG of 55E104-K01B-MD1	PMT	4M				L			L			L			RRC	RRC-ERCH	139608	B
836	RHU -55 -55E105A	RHU-55E105A-K01A	VB. INSP & ANALY M/C 55E105A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130274	B
837	RHU -55 -55E105A	RHU-55E105A-K01A	PM INSP OF M/C NO. 55E105A-K01A	PMT	3M			I			I			I			I	RRC	RRC-MRCH	129675	B
838	RHU -55 -55E105A	RHU-55E105A-K01A	REGREASING BRG OF 55E105A-K01A	PMT	3M			L			L			L			L	RRC	RRC-MRCH	130014	B
839	RHU -55 -55E105A	RHU-55E105A-K01A-M	Regreasing Mot BRG of 55E105A-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139609	B
840	RHU -55 -55E105A	RHU-55E105A-K01B	VB. INSP & ANALY M/C 55E105A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130275	B
841	RHU -55 -55E105A	RHU-55E105A-K01B	PM INSP OF M/C NO. 55E105A-K01B	PMT	3M			I			I			I			I	RRC	RRC-MRCH	129676	B
842	RHU -55 -55E105A	RHU-55E105A-K01B	REGREASING BRG OF 55E105A-K01B	PMT	3M			L			L			L			L	RRC	RRC-MRCH	130015	B
843	RHU -55 -55E105A	RHU-55E105A-K01B-M	Regreasing Mot BRG of 55E105A-K01B-MD1	PMT	4M				L			L			L			RRC	RRC-ERCH	139610	B
844	RHU -55 -55E105B	RHU-55E105B-K01A	VB. INSP & ANALY M/C 55E105B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130276	B
845	RHU -55 -55E105B	RHU-55E105B-K01A	PM INSP OF M/C NO. 55E105B-K01A	PMT	3M			I			I			I			I	RRC	RRC-MRCH	129677	B
846	RHU -55 -55E105B	RHU-55E105B-K01A	REGREASING BRG OF 55E105B-K01A	PMT	3M			L			L			L			L	RRC	RRC-MRCH	130016	B
847	RHU -55 -55E105B	RHU-55E105B-K01A-M	Regreasing Mot BRG of 55E105B-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139611	B
848	RHU -55 -55E105B	RHU-55E105B-K01B	VB. INSP & ANALY M/C 55E105B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130277	B
849	RHU -55 -55E105B	RHU-55E105B-K01B	PM INSP OF M/C NO. 55E105B-K01B	PMT	3M			I			I			I			I	RRC	RRC-MRCH	129678	B
850	RHU -55 -55E105B	RHU-55E105B-K01B	REGREASING BRG OF 55E105B-K01B	PMT	3M			L			L			L			L	RRC	RRC-MRCH	130017	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
851	RHU -55 -55E105B	RHU-55E105B-K01B-M	Regreasing Mot BRG of 55E105B-K01B-MD1	PMT	4M				L			L			L			RRC	RRC-ERCH	139612	B
852	RHU -55 -55E105C	RHU-55E105C-K01A	VB. INSP & ANALY M/C 55E105C-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130278	B
853	RHU -55 -55E105C	RHU-55E105C-K01A	PM INSP OF M/C NO. 55E105C-K01A	PMT	3M			I			I			I			I	RRC	RRC-MRCH	129679	B
854	RHU -55 -55E105C	RHU-55E105C-K01A	REGREASING BRG OF 55E105C-K01A	PMT	3M			L			L			L			L	RRC	RRC-MRCH	130018	B
855	RHU -55 -55E105C	RHU-55E105C-K01A-M	Regreasing Mot BRG of 55E105C-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139613	B
856	RHU -55 -55E105C	RHU-55E105C-K01B	VB. INSP & ANALY M/C 55E105C-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130279	B
857	RHU -55 -55E105C	RHU-55E105C-K01B	PM INSP OF M/C NO. 55E105C-K01B	PMT	3M			I			I			I			I	RRC	RRC-MRCH	129680	B
858	RHU -55 -55E105C	RHU-55E105C-K01B	REGREASING BRG OF 55E105C-K01B	PMT	3M			L			L			L			L	RRC	RRC-MRCH	130019	B
859	RHU -55 -55E105C	RHU-55E105C-K01B-M	Regreasing Mot BRG of 55E105C-K01B-MD1	PMT	4M				L			L			L			RRC	RRC-ERCH	139614	B
860	RHU -55 -55E105D	RHU-55E105D-K01A	VB. INSP & ANALY M/C 55E105D-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130280	B
861	RHU -55 -55E105D	RHU-55E105D-K01A	PM INSP OF M/C NO. 55E105D-K01A	PMT	3M			I			I			I			I	RRC	RRC-MRCH	129681	B
862	RHU -55 -55E105D	RHU-55E105D-K01A	REGREASING BRG OF 55E105D-K01A	PMT	3M			L			L			L			L	RRC	RRC-MRCH	130020	B
863	RHU -55 -55E105D	RHU-55E105D-K01A-M	Regreasing Mot BRG of 55E105D-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139615	B
864	RHU -55 -55E105D	RHU-55E105D-K01B	VB. INSP & ANALY M/C 55E105D-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130281	B
865	RHU -55 -55E105D	RHU-55E105D-K01B	PM INSP OF M/C NO. 55E105D-K01B	PMT	3M			I			I			I			I	RRC	RRC-MRCH	129682	B
866	RHU -55 -55E105D	RHU-55E105D-K01B	REGREASING BRG OF 55E105D-K01B	PMT	3M			L			L			L			L	RRC	RRC-MRCH	130021	B
867	RHU -55 -55E105D	RHU-55E105D-K01B-M	Regreasing Mot BRG of 55E105D-K01B-MD1	PMT	4M				L			L			L			RRC	RRC-ERCH	139616	B
868	RHU -55 -55E110	RHU-55E110-K01A	VB. INSP & ANALY M/C 55E110-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130282	B
869	RHU -55 -55E110	RHU-55E110-K01A	PM INSP OF M/C NO. 55E110-K01A	PMT	3M			I			I			I			I	RRC	RRC-MRCH	129683	B
870	RHU -55 -55E110	RHU-55E110-K01A	REGREASING BRG OF 55E110-K01A	PMT	3M			L			L			L			L	RRC	RRC-MRCH	130022	B
871	RHU -55 -55E110	RHU-55E110-K01A-M	Regreasing Mot BRG of 55E110-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139617	B
872	RHU -55 -55E110	RHU-55E110-K01B	VB. INSP & ANALY M/C 55E110-K0	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130283	B
873	RHU -55 -55E110	RHU-55E110-K01B	PM INSP OF M/C NO. 55E110-K01B	PMT	3M			I			I			I			I	RRC	RRC-MRCH	129684	B
874	RHU -55 -55E110	RHU-55E110-K01B	REGREASING BRG OF 55E110-K01B	PMT	3M			L			L			L			L	RRC	RRC-MRCH	130023	B
875	RHU -55 -55E110	RHU-55E110-K01B-M	Regreasing Mot BRG of 55E110-K01B-MD1	PMT	4M				L			L			L			RRC	RRC-ERCH	139618	B
876	RHU -55 -55P001A	RHU-55P001A-M	STAND BY CHECK LV. MOT 55P001A-MD1	PMT	1Y										T			RRC	RRC-ERCH	139237	C
877	RHU -55 -55P001A	RHU-55P001A-M	Regreasing Mot BRG of 55P001A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139619	C
878	RHU -55 -55P001A	RHU-55P001A-M	STAND BY CHECK LV. MOT 55P001A-MD1	PMT	1Y				T									RRC	RRC-ERCH	154287	C
879	RHU -55 -55P001A	RHU-55P001A-P01	VB. INSP & ANALY M/C 55P001A	INT	4M	I				I				I				IRI	IRI-INVB	130284	C
880	RHU -55 -55P001A	RHU-55P001A-P01	VB. INSP & ANALY M/C 55P001A	INT	4M		I				I				I			IRI	IRI-INVB	131023	C
881	RHU -55 -55P001A	RHU-55P001A-P01	VB. INSP & ANALY M/C 55P001A	INT	4M			I				I				I		IRI	IRI-INVB	131250	C
882	RHU -55 -55P001A	RHU-55P001A-P01	PM INSP OF M/C NO. 55P001A	PMT	4M		I				I				I			RRC	RRC-MRCH	129685	C
883	RHU -55 -55P001A	RHU-55P001A-P01	PM OF 55P001A	PMT	4M				P				P				P	RRC	RRC-MRCH	130710	C
884	RHU -55 -55P001B	RHU-55P001B-M	STAND BY CHECK LV. MOT 55P001B-MD1	PMT	6M					T				T				RRC	RRC-ERCH	139238	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
885	RHU -55 -55P001B	RHU-55P001B-M	Regreasing Mot BRG of 55P001B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCH	139620	C
886	RHU -55 -55P001B	RHU-55P001B-P01	VB. INSP & ANALY M/C 55P001B	INT	4M				I				I				I	IRI	IRI-INVB	130285	C
887	RHU -55 -55P001B	RHU-55P001B-P01	PM INSP OF M/C NO. 55P001B	PMT	4M				I				I				I	RRC	RRC-MRCH	129686	C
888	RHU -55 -55P001B	RHU-55P001B-P01	PM OF 55P001B	PMT	4M		P				P			P				RRC	RRC-MRCH	130711	C
889	RHU -55 -55P002A	RHU-55P002A-M	STAND BY CHECK LV. MOT 55P002A-MD1	PMT	1Y		T											RRC	RRC-ERCH	139239	C
890	RHU -55 -55P002A	RHU-55P002A-M	Regreasing Mot BRG of 55P002A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139621	C
891	RHU -55 -55P002A	RHU-55P002A-M	STAND BY CHECK LV. MOT 55P002A-MD1	PMT	1Y				T									RRC	RRC-ERCH	154288	C
892	RHU -55 -55P002A	RHU-55P002A-P01	VB. INSP & ANALY M/C 55P002A	INT	4M	I				I				I				IRI	IRI-INVB	130286	C
893	RHU -55 -55P002A	RHU-55P002A-P01	VB. INSP & ANALY M/C 55P002A	INT	4M		I				I				I			IRI	IRI-INVB	131024	C
894	RHU -55 -55P002A	RHU-55P002A-P01	VB. INSP & ANALY M/C 55P002A	INT	4M			I				I				I		IRI	IRI-INVB	131251	C
895	RHU -55 -55P002A	RHU-55P002A-P01	PM INSP OF M/C NO. 55P002A	PMT	4M		I				I				I			RRC	RRC-MRCH	129687	C
896	RHU -55 -55P002A	RHU-55P002A-P01	PM OF 55P002A	PMT	4M				P			P				P		RRC	RRC-MRCH	130712	C
897	RHU -55 -55P002B	RHU-55P002B-M	STAND BY CHECK LV. MOT 55P002B-MD1	PMT	6M			T						T				RRC	RRC-ERCH	139240	C
898	RHU -55 -55P002B	RHU-55P002B-M	Regreasing Mot BRG of 55P002B-MD1	PMT	4M				L			L			L			RRC	RRC-ERCH	139622	C
899	RHU -55 -55P002B	RHU-55P002B-P01	VB. INSP & ANALY M/C 55P002B	INT	4M				I			I			I			IRI	IRI-INVB	130287	C
900	RHU -55 -55P002B	RHU-55P002B-P01	PM INSP OF M/C NO. 55P002B	PMT	4M				I			I			I			RRC	RRC-MRCH	129688	C
901	RHU -55 -55P002B	RHU-55P002B-P01	PM OF 55P002B	PMT	4M		P				P			P				RRC	RRC-MRCH	130713	C
902	RHU -55 -55P003A	RHU-55P003A-M	STAND BY CHECK LV. MOT 55P003A-MD1	PMT	1Y		T											RRC	RRC-ERCH	139241	C
903	RHU -55 -55P003A	RHU-55P003A-M	Regreasing Mot BRG of 55P003A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139623	C
904	RHU -55 -55P003A	RHU-55P003A-M	STAND BY CHECK LV. MOT 55P003A-MD1	PMT	1Y				T									RRC	RRC-ERCH	154289	C
905	RHU -55 -55P003A	RHU-55P003A-P01	VB. INSP & ANALY M/C 55P003A	INT	4M	I				I				I				IRI	IRI-INVB	130288	C
906	RHU -55 -55P003A	RHU-55P003A-P01	VB. INSP & ANALY M/C 55P003A	INT	4M		I				I				I			IRI	IRI-INVB	131025	C
907	RHU -55 -55P003A	RHU-55P003A-P01	VB. INSP & ANALY M/C 55P003A	INT	4M			I				I				I		IRI	IRI-INVB	131252	C
908	RHU -55 -55P003A	RHU-55P003A-P01	PM INSP OF M/C NO. 55P003A	PMT	4M			I				I				I		RRC	RRC-MRCH	129689	C
909	RHU -55 -55P003A	RHU-55P003A-P01	PM OF 55P003A	PMT	4M				P				P				P	RRC	RRC-MRCH	137923	C
910	RHU -55 -55P003B	RHU-55P003B-M	STAND BY CHECK LV. MOT 55P003B-MD1	PMT	6M			T						T				RRC	RRC-ERCH	139242	C
911	RHU -55 -55P003B	RHU-55P003B-M	Regreasing Mot BRG of 55P003B-MD1	PMT	4M				L			L			L			RRC	RRC-ERCH	139624	C
912	RHU -55 -55P003B	RHU-55P003B-P01	VB. INSP & ANALY M/C 55P003B	INT	4M				I			I			I			IRI	IRI-INVB	130289	C
913	RHU -55 -55P003B	RHU-55P003B-P01	PM INSP OF M/C NO. 55P003B	PMT	4M				I			I			I			RRC	RRC-MRCH	129690	C
914	RHU -55 -55P003B	RHU-55P003B-P01	PM OF 55P003B	PMT	4M			P			P			P				RRC	RRC-MRCH	130714	C
915	RHU -55 -55P005A	RHU-55P005A-M	STAND BY CHECK LV. MOT 55P005A-M	PMT	1Y				T									RRC	RRC-ERCH	162058	B
916	RHU -55 -55P005A	RHU-55P005A-M	STAND BY CHECK LV. MOT 55P005A-M	PMT	1Y							T						RRC	RRC-ERCH	162065	B
917	RHU -55 -55P005A	RHU-55P005A-P	PM INSP OF M/C NO. RHU-55P005A-P	PMT	4M	I				I				I				RRC	RRC-MRCH	162092	B
918	RHU -55 -55P005B	RHU-55P005B-M	STAND BY CHECK LV. MOT 55P005B-M	PMT	6M						T						T	RRC	RRC-ERCH	162074	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
919	RHU -55 -55P005B	RHU-55P005B-P	PM INSP OF M/C NO. RHU-55P005B-P	PMT	4M				I				I				I	RRC	RRC-MRCH	162093	B
920	RHU -55 -55P101A	RHU-55P101A-M	STAND BY CHECK MV. MOT 55P101A-MD1	PMT	1Y		T											RRC	RRC-ERCH	139243	C
921	RHU -55 -55P101A	RHU-55P101A-M	Regreasing Mot BRG of 55P101A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139402	C
922	RHU -55 -55P101A	RHU-55P101A-M	STAND BY CHECK MV. MOT 55P101A-MD1	PMT	1Y				T									RRC	RRC-ERCH	154290	C
923	RHU -55 -55P101A	RHU-55P101A-P01	PM INSP OF M/C NO. 55P101A	PMT	4M				I			I			I			RRC	RRC-MRCH	129691	C
924	RHU -55 -55P101A	RHU-55P101A-P01	PM OF 55P101A	PMT	4M				P				P				P	RRC	RRC-MRCH	130715	C
925	RHU -55 -55P101B	RHU-55P101B-M	STAND BY CHECK MV. MOT 55P101B-MD1	PMT	6M			T						T				RRC	RRC-ERCH	139244	C
926	RHU -55 -55P101B	RHU-55P101B-M	Regreasing Mot BRG of 55P101B-MD1	PMT	4M				L			L			L			RRC	RRC-ERCH	139403	C
927	RHU -55 -55P101B	RHU-55P101B-P01	PM INSP OF M/C NO. 55P101B	PMT	4M				I			I			I			RRC	RRC-MRCH	129692	C
928	RHU -55 -55P101B	RHU-55P101B-P01	PM OF 55P101B	PMT	4M				P				P				P	RRC	RRC-MRCH	130716	C
929	RHU -55 -55P102A	RHU-55P102A-M	STAND BY CHECK LV. MOT 55P102A-MD1	PMT	1Y		T											RRC	RRC-ERCH	139245	C
930	RHU -55 -55P102A	RHU-55P102A-M	Regreasing Mot BRG of 55P102A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139625	C
931	RHU -55 -55P102A	RHU-55P102A-M	STAND BY CHECK LV. MOT 55P102A-MD1	PMT	1Y				T									RRC	RRC-ERCH	154291	C
932	RHU -55 -55P102A	RHU-55P102A-P01	VB. INSP & ANALY M/C 55P102A	INT	4M	I				I				I				IRI	IRI-INVB	130292	C
933	RHU -55 -55P102A	RHU-55P102A-P01	VB. INSP & ANALY M/C 55P102A	INT	4M		I				I				I			IRI	IRI-INVB	131027	C
934	RHU -55 -55P102A	RHU-55P102A-P01	VB. INSP & ANALY M/C 55P102A	INT	4M			I				I				I		IRI	IRI-INVB	131254	C
935	RHU -55 -55P102A	RHU-55P102A-P01	PM INSP OF M/C NO. 55P102A	PMT	4M			I				I				I		RRC	RRC-MRCH	129693	C
936	RHU -55 -55P102A	RHU-55P102A-P01	PM OF 55P102A	PMT	4M				P				P				P	RRC	RRC-MRCH	130717	C
937	RHU -55 -55P102B	RHU-55P102B-M	STAND BY CHECK LV. MOT 55P102B-MD1	PMT	6M			T						T				RRC	RRC-ERCH	139246	C
938	RHU -55 -55P102B	RHU-55P102B-M	Regreasing Mot BRG of 55P102B-MD1	PMT	4M				L			L			L			RRC	RRC-ERCH	139626	C
939	RHU -55 -55P102B	RHU-55P102B-P01	VB. INSP & ANALY M/C 55P102B	INT	4M				I			I			I			IRI	IRI-INVB	130293	C
940	RHU -55 -55P102B	RHU-55P102B-P01	PM INSP OF M/C NO. 55P102B	PMT	4M				I			I			I			RRC	RRC-MRCH	129694	C
941	RHU -55 -55P102B	RHU-55P102B-P01	PM OF 55P102B	PMT	4M			P			P			P				RRC	RRC-MRCH	130718	C
942	RHU -55 -55P103A	RHU-55P103A-M	STAND BY CHECK LV. MOT 55P103A-MD1	PMT	1Y		T											RRC	RRC-ERCH	139247	C
943	RHU -55 -55P103A	RHU-55P103A-M	Regreasing Mot BRG of 55P103A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139627	C
944	RHU -55 -55P103A	RHU-55P103A-M	STAND BY CHECK LV. MOT 55P103A-MD1	PMT	1Y				T									RRC	RRC-ERCH	154292	C
945	RHU -55 -55P103A	RHU-55P103A-P01	VB. INSP & ANALY M/C 55P103A	INT	4M	I				I				I				IRI	IRI-INVB	130294	C
946	RHU -55 -55P103A	RHU-55P103A-P01	VB. INSP & ANALY M/C 55P103A	INT	4M		I				I				I			IRI	IRI-INVB	131028	C
947	RHU -55 -55P103A	RHU-55P103A-P01	VB. INSP & ANALY M/C 55P103A	INT	4M			I				I				I		IRI	IRI-INVB	131255	C
948	RHU -55 -55P103A	RHU-55P103A-P01	PM INSP OF M/C NO. 55P103A	PMT	4M			I				I				I		RRC	RRC-MRCH	129695	C
949	RHU -55 -55P103A	RHU-55P103A-P01	PM OF 55P103A	PMT	4M				P				P				P	RRC	RRC-MRCH	130719	C
950	RHU -55 -55P103B	RHU-55P103B-M	STAND BY CHECK LV. MOT 55P103B-MD1	PMT	6M			T						T				RRC	RRC-ERCH	139248	C
951	RHU -55 -55P103B	RHU-55P103B-M	Regreasing Mot BRG of 55P103B-MD1	PMT	4M				L			L			L			RRC	RRC-ERCH	139628	C
952	RHU -55 -55P103B	RHU-55P103B-P01	VB. INSP & ANALY M/C 55P103B	INT	4M				I			I			I			IRI	IRI-INVB	130295	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
953	RHU -55 -55P103B	RHU-55P103B-P01	PM INSP OF M/C NO. 55P103B	PMT	4M				I				I				I	RRC	RRC-MRCH	129696	C
954	RHU -55 -55P103B	RHU-55P103B-P01	PM OF 55P103B	PMT	4M			P				P				P		RRC	RRC-MRCH	130720	C
955	RHU -55 -55P104A	RHU-55P104A-M	STAND BY CHECK LV. MOT 55P104A-MD1	PMT	1Y		T											RRC	RRC-ERCH	139249	C
956	RHU -55 -55P104A	RHU-55P104A-M	Regreasing Mot BRG of 55P104A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139629	C
957	RHU -55 -55P104A	RHU-55P104A-M	STAND BY CHECK LV. MOT 55P104A-MD1	PMT	1Y				T									RRC	RRC-ERCH	154293	C
958	RHU -55 -55P104A	RHU-55P104A-P01	VB. INSP & ANALY M/C 55P104A	INT	4M	I				I				I				IRI	IRI-INVB	130296	C
959	RHU -55 -55P104A	RHU-55P104A-P01	VB. INSP & ANALY M/C 55P104A	INT	4M			I			I				I			IRI	IRI-INVB	131029	C
960	RHU -55 -55P104A	RHU-55P104A-P01	VB. INSP & ANALY M/C 55P104A	INT	4M				I			I				I		IRI	IRI-INVB	131256	C
961	RHU -55 -55P104A	RHU-55P104A-P01	PM INSP OF M/C NO. 55P104A	PMT	4M				I			I				I		RRC	RRC-MRCH	129697	C
962	RHU -55 -55P104A	RHU-55P104A-P01	PM OF 55P104A	PMT	4M				P			P				P		RRC	RRC-MRCH	130721	C
963	RHU -55 -55P104B	RHU-55P104B-M	STAND BY CHECK LV. MOT 55P104B-MD1	PMT	6M			T						T				RRC	RRC-ERCH	139250	C
964	RHU -55 -55P104B	RHU-55P104B-M	Regreasing Mot BRG of 55P104B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCH	139630	C
965	RHU -55 -55P104B	RHU-55P104B-P01	VB. INSP & ANALY M/C 55P104B	INT	4M				I				I				I	IRI	IRI-INVB	130297	C
966	RHU -55 -55P104B	RHU-55P104B-P01	PM INSP OF M/C NO. 55P104B	PMT	4M				I				I				I	RRC	RRC-MRCH	129698	C
967	RHU -55 -55P104B	RHU-55P104B-P01	PM OF 55P104B	PMT	4M			P				P				P		RRC	RRC-MRCH	130722	C
968	RHU -55 -55P105A	RHU-55P105A-M	STAND BY CHECK LV. MOT 55P105A-M	PMT	1Y				T									RRC	RRC-ERCH	162059	B
969	RHU -55 -55P105A	RHU-55P105A-M	STAND BY CHECK LV. MOT 55P105A-M	PMT	1Y								T					RRC	RRC-ERCH	162066	B
970	RHU -55 -55P105A	RHU-55P105A-M	Regreasing Mot BRG of 55P105A-M	PMT	4M	L				L				L				RRC	RRC-ERCH	162071	B
971	RHU -55 -55P105A	RHU-55P105A-P	PM OF RHU-55P105A-P	PMT	4M				P				P				P	RRC	RRC-MRCH	162080	B
972	RHU -55 -55P105A	RHU-55P105A-P	PM INSP OF M/C NO. RHU-55P105A-P	PMT	4M		I				I			I				RRC	RRC-MRCH	162094	B
973	RHU -55 -55P105A	RHU-55P105A-P01-M	STAND BY CHECK LV. MOT 55P105A-P01-M	PMT	1Y				T									RRC	RRC-ERCH	162060	B
974	RHU -55 -55P105A	RHU-55P105A-P01-M	STAND BY CHECK LV. MOT 55P105A-P01-M	PMT	1Y								T					RRC	RRC-ERCH	162067	B
975	RHU -55 -55P105A	RHU-55P105A-P01-P	PM INSP OF M/C NO. RHU-55P105A-P01-P	PMT	4M		I				I				I			RRC	RRC-MRCH	162095	B
976	RHU -55 -55P105B	RHU-55P105B-M	Regreasing Mot BRG of 55P105B-M	PMT	4M				L				L				L	RRC	RRC-ERCH	162072	B
977	RHU -55 -55P105B	RHU-55P105B-M	STAND BY CHECK LV. MOT 55P105B-M	PMT	6M						T						T	RRC	RRC-ERCH	162075	B
978	RHU -55 -55P105B	RHU-55P105B-P	PM OF RHU-55P105B-P	PMT	4M		P				P			P				RRC	RRC-MRCH	162082	B
979	RHU -55 -55P105B	RHU-55P105B-P	PM INSP OF M/C NO. RHU-55P105B-P	PMT	4M				I				I				I	RRC	RRC-MRCH	162096	B
980	RHU -55 -55P105B	RHU-55P105B-P01-M	STAND BY CHECK LV. MOT 55P105B-P01-M	PMT	6M						T						T	RRC	RRC-ERCH	162076	B
981	RHU -55 -55P105B	RHU-55P105B-P01-P	PM OF RHU-55P105B-P01-P	PMT	4M		P				P			P				RRC	RRC-MRCH	162083	B
982	RHU -55 -55P105B	RHU-55P105B-P01-P	PM INSP OF M/C NO. RHU-55P105B-P01-P	PMT	4M				I				I				I	RRC	RRC-MRCH	162097	B
983	RHU -55 -55P106A	RHU-55P106A-M	STAND BY CHECK LV. MOT 55P106A-M	PMT	1Y				T									RRC	RRC-ERCH	162061	B
984	RHU -55 -55P106A	RHU-55P106A-M	STAND BY CHECK LV. MOT 55P106A-M	PMT	1Y								T					RRC	RRC-ERCH	162068	B
985	RHU -55 -55P106A	RHU-55P106A-P	PM OF RHU-55P106A-P	PMT	4M				P				P				P	RRC	RRC-MRCH	162084	B
986	RHU -55 -55P106A	RHU-55P106A-P	PM INSP OF M/C NO. RHU-55P106A-P	PMT	4M		I				I			I				RRC	RRC-MRCH	162098	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
987	RHU -55 -55P106B	RHU-55P106B-M	STAND BY CHECK LV. MOT 55P106B-M	PMT	6M							T					T	RRC	RRC-ERCH	162077	B
988	RHU -55 -55P106B	RHU-55P106B-P	PM OF RHU-55P106B-P	PMT	4M		P					P				P		RRC	RRC-MRCH	162085	B
989	RHU -55 -55P106B	RHU-55P106B-P	PM INSP OF M/C NO. RHU-55P106B-P	PMT	4M					I			I				I	RRC	RRC-MRCH	162099	B
990	RHU -55 -55X101	RHU-55X101-P01A	PM OF 55X101 -P01A	PMT	4M					P			P				P	RRC	RRC-MRCH	148835	C
991	RHU -55 -55X101	RHU-55X101-P01A	PM INSP OF M/C NO. 55X101 -P01A	PMT	4M				I			I				I		RRC	RRC-MRCH	149127	C
992	RHU -55 -55X101	RHU-55X101-P01B	PM OF 55X101 -P01B	PMT	4M				P			P				P		RRC	RRC-MRCH	148836	C
993	RHU -55 -55X101	RHU-55X101-P01B	PM INSP OF M/C NO. 55X101 -P01B	PMT	4M					I			I				I	RRC	RRC-MRCH	149128	C
994	RHU -55 -55X103	RHU-55X103-P01A-M	STAND BY CHECK LV. MOT 55X103-P01A-M	PMT	1Y					T								RRC	RRC-ERCH	162062	B
995	RHU -55 -55X103	RHU-55X103-P01A-M	STAND BY CHECK LV. MOT 55X103-P01A-M	PMT	1Y								T					RRC	RRC-ERCH	162069	B
996	RHU -55 -55X103	RHU-55X103-P01A-P	PM OF RHU-55X103-P01A-P	PMT	4M					P			P				P	RRC	RRC-MRCH	162086	B
997	RHU -55 -55X103	RHU-55X103-P01A-P	PM INSP OF M/C NO. RHU-55X103-P01A-P	PMT	4M				I			I				I		RRC	RRC-MRCH	162100	B
998	RHU -55 -55X103	RHU-55X103-P01B-M	STAND BY CHECK LV. MOT 55X103-P01B-M	PMT	6M							T					T	RRC	RRC-ERCH	162078	B
999	RHU -55 -55X103	RHU-55X103-P01B-P	PM OF RHU-55X103-P01B-P	PMT	4M				P				P				P	RRC	RRC-MRCH	162087	B
1,000	RHU -55 -55X103	RHU-55X103-P01B-P	PM INSP OF M/C NO. RHU-55X103-P01B-P	PMT	4M					I			I				I	RRC	RRC-MRCH	162101	B
1,001	RHU -55 -55X103	RHU-55X103-P02A-M	STAND BY CHECK LV. MOT 55X103-P02A-M	PMT	1Y					T								RRC	RRC-ERCH	162063	B
1,002	RHU -55 -55X103	RHU-55X103-P02A-M	STAND BY CHECK LV. MOT 55X103-P02A-M	PMT	1Y								T					RRC	RRC-ERCH	162070	B
1,003	RHU -55 -55X103	RHU-55X103-P02A-P	PM OF RHU-55X103-P02A-P	PMT	4M					P			P				P	RRC	RRC-MRCH	162088	B
1,004	RHU -55 -55X103	RHU-55X103-P02A-P	PM INSP OF M/C NO. RHU-55X103-P02A-P	PMT	4M				I			I				I		RRC	RRC-MRCH	162102	B
1,005	RHU -55 -55X103	RHU-55X103-P02B-M	STAND BY CHECK LV. MOT 55X103-P02B-M	PMT	6M							T					T	RRC	RRC-ERCH	162079	B
1,006	RHU -55 -55X103	RHU-55X103-P02B-P	PM OF RHU-55X103-P02B-P	PMT	4M				P				P				P	RRC	RRC-MRCH	162089	B
1,007	RHU -55 -55X103	RHU-55X103-P02B-P	PM INSP OF M/C NO. RHU-55X103-P02B-P	PMT	4M					I			I				I	RRC	RRC-MRCH	162103	B
1,008	RHU -52 -78P008A	RHU-78P008A-M	STAND BY CHECK LV. MOT 78P008A-MD1	PMT	1Y								T					RRC	RRC-ERCH	139217	C
1,009	RHU -52 -78P008A	RHU-78P008A-M	STAND BY CHECK LV. MOT 78P008A-MD1	PMT	1Y					T								RRC	RRC-ERCH	154286	C
1,010	RHU -52 -78P008A	RHU-78P008A-P01	VB. INSP & ANALY M/C 78P008A	INT	4M	I					I			I				IRI	IRI-INVB	130166	C
1,011	RHU -52 -78P008A	RHU-78P008A-P01	VB. INSP & ANALY M/C 78P008A	INT	4M		I				I				I			IRI	IRI-INVB	130968	C
1,012	RHU -52 -78P008A	RHU-78P008A-P01	VB. INSP & ANALY M/C 78P008A	INT	4M				I			I				I		IRI	IRI-INVB	131194	C
1,013	RHU -52 -78P008A	RHU-78P008A-P01	PM INSP OF M/C NO. 78P008A	PMT	4M		I				I				I			RRC	RRC-MRCH	129567	C
1,014	RHU -52 -78P008A	RHU-78P008A-P01	PM OF 78P008A	PMT	4M				P				P				P	RRC	RRC-MRCH	130622	C
1,015	RHU -52 -78P008B	RHU-78P008B-M	STAND BY CHECK LV. MOT 78P008B-MD1	PMT	6M			T						T				RRC	RRC-ERCH	139218	C
1,016	RHU -52 -78P008B	RHU-78P008B-P01	VB. INSP & ANALY M/C 78P008B	INT	4M				I				I				I	IRI	IRI-INVB	130167	C
1,017	RHU -52 -78P008B	RHU-78P008B-P01	PM INSP OF M/C NO. 78P008B	PMT	4M				I				I				I	RRC	RRC-MRCH	129568	C
1,018	RHU -52 -78P008B	RHU-78P008B-P01	PM OF 78P008B	PMT	4M		P				P			P				RRC	RRC-MRCH	130623	C
1,019	RHU -52 -QMI_GC	RHU-AT5201301	VERIFY GC AT5201301	PMT	6M		V						V					CAN	CAN-QUHV	140889	B
1,020	RHU -52 -QMI_GAS	RHU-AT5203901	VERIFY DUST AT5203901	PMT	6M				V					V				CAN	CAN-QUHV	204958	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,021	RHU -52 -QMI_GAS	RHU-AT5203902	VERIFY CEMS AT5203902	PMT	2M	V		V		V		V		V		V		CAN	CAN-QUHV	140887	B
1,022	RHU -52 -QMI_GAS	RHU-AT5203904	VERIFY OXYGEN AT5203904	PMT	6M			V						V				CAN	CAN-QUHV	140890	B
1,023	RHU -52 -QMI_GAS	RHU-AT5204301	VERIFY TOTAL_HYDROCARBON AT5204301	PMT	6M			V						V				CAN	CAN-QUHV	140892	B
1,024	RHU -52 -QMI_GAS	RHU-AT5204302	VERIFY CEMS AT5204302	PMT	2M	V		V		V		V		V		V		CAN	CAN-QUHV	140888	B
1,025	RHU -52 -QMI_GAS	RHU-AT5204303	VERIFY OXYGEN AT5204303	PMT	6M			V						V				CAN	CAN-QUHV	140891	B
1,026	RHU -55 -QMI_GC	RHU-AT5500201	VERIFY GC AT5500201	PMT	4M	V				V				V				CAN	CAN-QUHV	140778	B
1,027	RHU -55 -QMI_GAS	RHU-AT5500401	VERIFY Total Sulfur AT5500401	PMT	4M	V				V				V				CAN	CAN-QUHV	140779	B
1,028	RHU -55 -QMI_GAS	RHU-AT5500402	VERIFY MOISTURE AT5500402	PMT	6M					V						V		CAN	CAN-QUHV	140780	C
1,029	RHU -55 -QMI_GC	RHU-AT5500701	VERIFY GC AT5500701	PMT	4M	V				V				V				CAN	CAN-QUHV	140781	A
1,030	RHU -55 -QMI_GAS	RHU-AT5501001	VERIFY Total Sulfur AT5501001	PMT	4M	V				V				V				CAN	CAN-QUHV	140782	B
1,031	RHU -55 -QMI_GAS	RHU-AT5501002	VERIFY MOISTURE AT5501002	PMT	6M					V						V		CAN	CAN-QUHV	140783	C
1,032	RHU -STR-BUILDING	RHU-BDG-A-52	INSPECTION BUILDING FOR RCHR	INT	6Y					I								ENE	ENE-ENQS	204326	A
1,033	RHU -STR-BUILDING	RHU-BDG-A-55	INSPECTION BUILDING FOR RCHR	INT	6Y					I								ENE	ENE-ENQS	204328	A
1,034	RHU -STR-BUILDING	RHU-BDG-ADM	INSPECTION BUILDING FOR RCHR	INT	6Y					I								ENE	ENE-ENQS	204336	B
1,035	RHU -STR-BUILDING	RHU-BDG-B-52	INSPECTION BUILDING FOR RCHR	INT	6Y					I								ENE	ENE-ENQS	204329	A
1,036	RHU -STR-BUILDING	RHU-BDG-B-55	INSPECTION BUILDING FOR RCHR	INT	6Y					I								ENE	ENE-ENQS	204331	A
1,037	RHU -STR-BUILDING	RHU-BDG-C-52	INSPECTION BUILDING FOR RCHR	INT	6Y					I								ENE	ENE-ENQS	204332	A
1,038	RHU -STR-BUILDING	RHU-BDG-C-55	INSPECTION BUILDING FOR RCHR	INT	6Y					I								ENE	ENE-ENQS	204333	A
1,039	RHU -STR-BUILDING	RHU-BDG-D-52	INSPECTION BUILDING FOR RCHR	INT	6Y					I								ENE	ENE-ENQS	204334	A
1,040	RHU -STR-BUILDING	RHU-BDG-E-52	INSPECTION BUILDING FOR RCHR	INT	6Y					I								ENE	ENE-ENQS	204335	A
1,041	RHU -52 -DCS	RHU-DCS	INSPECT DCS SYSTEM	PMT	3M	I				I		I		I				CCS	CCS-SYS	246429	A
1,042	RHU -52 -DCS	RHU-DCS	BACKUP DCS SYSTEM	PMT	6M	I				I		I						CCS	CCS-SYS	246430	A
1,043	RHU -52 -DCS	RHU-DCS	UPDATE ANTIVIRUS DCS SYSTEM	PMT	3M	U			U			U		U				CCS	CCS-SYS	246431	A
1,044	RHU -52 -FIRE_ALARM	RHU-FA-MCP-52	PM F/A PUSH BUTTON (###) (UNIT 52)	PMT	3M		P			P			P			P		RRC	RRC-ERCH	140379	A
1,045	RHU -55 -FIRE_ALARM	RHU-FA-MCP-55	PM F/A PUSH BUTTON (###) (UNIT 55)	PMT	3M		P			P			P			P		RRC	RRC-ERCH	140382	A
1,046	RHU -52 -FGS	RHU-FGS	INSPECT FGS SYSTEM	PMT	3M	I			I			I		I				CCS	CCS-SYS	246435	A
1,047	RHU -52 -FGS	RHU-FGS	BACKUP FGS SYSTEM	PMT	6M	I						I						CCS	CCS-SYS	246436	A
1,048	RHU -52 -FGS	RHU-FGS	UPDATE ANTIVIRUS FGS SYSTEM	PMT	3M	U			U			U		U				CCS	CCS-SYS	246437	A
1,049	RHU -52 -FLOW	RHU-FT5200101	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131380	C
1,050	RHU -52 -FLOW	RHU-FT5200102	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131381	C
1,051	RHU -52 -FLOW	RHU-FT5200103	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131382	C
1,052	RHU -52 -FLOW	RHU-FT5200104	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131378	C
1,053	RHU -52 -FLOW	RHU-FT5200105A	INSP. FIELD INST. (###ปกติ)	INS	1Y	I												RRC	RRC-IRCH	131383	C
1,054	RHU -52 -FLOW	RHU-FT5200105A	FT5200105A-FULLFUN TEST FLOW T	PMT	5Y												F	RRC	RRC-IRCH	260368	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,055	RHU -52 -FLOW	RHU-FT5200105B	INSP. FIELD INST. (###ปกติ)	INS	1Y	I												RRC	RRC-IRCH	131384	C
1,056	RHU -52 -FLOW	RHU-FT5200105B	FT5200105B-FULLFUN TEST FLOW T	PMT	5Y												F	RRC	RRC-IRCH	260369	C
1,057	RHU -52 -FLOW	RHU-FT5200105C	INSP. FIELD INST. (###ปกติ)	INS	1Y	I												RRC	RRC-IRCH	131385	C
1,058	RHU -52 -FLOW	RHU-FT5200105C	FT5200105C-FULLFUN TEST FLOW T	PMT	5Y												F	RRC	RRC-IRCH	260370	C
1,059	RHU -52 -FLOW	RHU-FT5200106	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131386	C
1,060	RHU -52 -FLOW	RHU-FT5200107	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131377	C
1,061	RHU -52 -FLOW	RHU-FT5200201	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131387	C
1,062	RHU -52 -FLOW	RHU-FT5200401	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131388	C
1,063	RHU -52 -FLOW	RHU-FT5200402	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131389	C
1,064	RHU -52 -FLOW	RHU-FT5200403	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131390	C
1,065	RHU -52 -FLOW	RHU-FT5200405	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131391	C
1,066	RHU -52 -FLOW	RHU-FT5200601	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131392	C
1,067	RHU -52 -FLOW	RHU-FT5200602	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131393	C
1,068	RHU -52 -FLOW	RHU-FT5200701	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131394	C
1,069	RHU -52 -FLOW	RHU-FT5200702	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131395	C
1,070	RHU -52 -FLOW	RHU-FT5200801	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131396	C
1,071	RHU -52 -FLOW	RHU-FT5200901	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131397	C
1,072	RHU -52 -FLOW	RHU-FT5200902A	INSP. FIELD INST. (###ปกติ)	INS	1Y	I												RRC	RRC-IRCH	131398	C
1,073	RHU -52 -FLOW	RHU-FT5200902A	FT5200902A-FULLFUN TEST FLOW T	PMT	5Y												F	RRC	RRC-IRCH	260371	C
1,074	RHU -52 -FLOW	RHU-FT5200902B	INSP. FIELD INST. (###ปกติ)	INS	1Y	I												RRC	RRC-IRCH	131399	C
1,075	RHU -52 -FLOW	RHU-FT5200902B	FT5200902B-FULLFUN TEST FLOW T	PMT	5Y												F	RRC	RRC-IRCH	260372	C
1,076	RHU -52 -FLOW	RHU-FT5200902C	INSP. FIELD INST. (###ปกติ)	INS	1Y	I												RRC	RRC-IRCH	131400	C
1,077	RHU -52 -FLOW	RHU-FT5200902C	FT5200902C-FULLFUN TEST FLOW T	PMT	5Y												F	RRC	RRC-IRCH	260373	C
1,078	RHU -52 -FLOW	RHU-FT5201001	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131401	C
1,079	RHU -52 -FLOW	RHU-FT5201002	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131402	C
1,080	RHU -52 -FLOW	RHU-FT5201101	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131403	C
1,081	RHU -52 -FLOW	RHU-FT5201102	INSP. FIELD INST. (###ปกติ)	INS	1Y	I												RRC	RRC-IRCH	131404	C
1,082	RHU -52 -FLOW	RHU-FT5201102	FT5201102-FULLFUN TEST FLOW TR	PMT	5Y												F	RRC	RRC-IRCH	260377	C
1,083	RHU -52 -FLOW	RHU-FT5201201	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131405	C
1,084	RHU -52 -52K001	RHU-FT5201301	INSP. FIELD INST. (###ปกติ)	PMT	1Y			I										RRC	RRC-IRCH	131539	C
1,085	RHU -52 -FLOW	RHU-FT5201401	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131406	C
1,086	RHU -52 -FLOW	RHU-FT5201601	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131407	C
1,087	RHU -52 -FLOW	RHU-FT5201901	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131408	C
1,088	RHU -52 -FLOW	RHU-FT5201902	INSP. FIELD INST. (###ปกติ)	PMT	1Y	I												RRC	RRC-IRCH	131409	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,089	RHU -52 -FLOW	RHU-FT5201903	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131410	C
1,090	RHU -52 -FLOW	RHU-FT5201904	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131411	C
1,091	RHU -52 -FLOW	RHU-FT5201905	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y	I												RRC	RRC-IROH	131412	C
1,092	RHU -52 -FLOW	RHU-FT5201905	FT5201905-FULLFUN TEST FLOW TR	PMT	5Y											F		RRC	RRC-IROH	260375	C
1,093	RHU -52 -FLOW	RHU-FT5201906	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y	I												RRC	RRC-IROH	131413	C
1,094	RHU -52 -FLOW	RHU-FT5201906	FT5201906-FULLFUN TEST FLOW TR	PMT	5Y											F		RRC	RRC-IROH	260374	C
1,095	RHU -52 -FLOW	RHU-FT5202001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131414	C
1,096	RHU -52 -FLOW	RHU-FT5202101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131415	C
1,097	RHU -52 -FLOW	RHU-FT5202102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131416	C
1,098	RHU -52 -FLOW	RHU-FT5202103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131417	C
1,099	RHU -52 -FLOW	RHU-FT5202104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131418	C
1,100	RHU -52 -FLOW	RHU-FT5202201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131419	C
1,101	RHU -52 -FLOW	RHU-FT5202202	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131420	C
1,102	RHU -52 -FLOW	RHU-FT5202203	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y	I												RRC	RRC-IROH	131421	C
1,103	RHU -52 -FLOW	RHU-FT5202203	FT5202203-FULLFUN TEST FLOW TR	PMT	5Y											F		RRC	RRC-IROH	260376	C
1,104	RHU -52 -FLOW	RHU-FT5202205	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131422	C
1,105	RHU -52 -FLOW	RHU-FT5202301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131423	C
1,106	RHU -52 -FLOW	RHU-FT5202302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131424	C
1,107	RHU -52 -FLOW	RHU-FT5202401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131425	C
1,108	RHU -52 -FLOW	RHU-FT5202402	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131426	C
1,109	RHU -52 -FLOW	RHU-FT5202403	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131427	C
1,110	RHU -52 -FLOW	RHU-FT5202404	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131428	C
1,111	RHU -52 -FLOW	RHU-FT5202501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131429	C
1,112	RHU -52 -FLOW	RHU-FT5202502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131430	C
1,113	RHU -52 -FLOW	RHU-FT5202503	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131431	C
1,114	RHU -52 -FLOW	RHU-FT5202504	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131432	C
1,115	RHU -52 -FLOW	RHU-FT5202505	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131433	C
1,116	RHU -52 -FLOW	RHU-FT5202506	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131434	C
1,117	RHU -52 -FLOW	RHU-FT5202507	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131435	C
1,118	RHU -52 -FLOW	RHU-FT5202508	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131436	C
1,119	RHU -52 -FLOW	RHU-FT5202601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131437	C
1,120	RHU -52 -FLOW	RHU-FT5202602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131438	C
1,121	RHU -52 -FLOW	RHU-FT5202603	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131439	C
1,122	RHU -52 -FLOW	RHU-FT5202701	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131440	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,123	RHU -52 -FLOW	RHU-FT5202702	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131441	C
1,124	RHU -52 -FLOW	RHU-FT5202703	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131442	C
1,125	RHU -52 -FLOW	RHU-FT5202801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131443	C
1,126	RHU -52 -FLOW	RHU-FT5202802	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131444	C
1,127	RHU -52 -FLOW	RHU-FT5202901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131445	C
1,128	RHU -52 -FLOW	RHU-FT5202902	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131446	C
1,129	RHU -52 -FLOW	RHU-FT5202903	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131447	C
1,130	RHU -52 -FLOW	RHU-FT5202904	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131448	C
1,131	RHU -52 -FLOW	RHU-FT5202905	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131449	C
1,132	RHU -52 -FLOW	RHU-FT5203001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131450	C
1,133	RHU -52 -FLOW	RHU-FT5203101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131451	C
1,134	RHU -52 -FLOW	RHU-FT5203102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131452	C
1,135	RHU -52 -FLOW	RHU-FT5203103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131453	C
1,136	RHU -52 -FLOW	RHU-FT5203201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131454	C
1,137	RHU -52 -FLOW	RHU-FT5203202	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131455	C
1,138	RHU -52 -FLOW	RHU-FT5203203	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131456	C
1,139	RHU -52 -FLOW	RHU-FT5203204	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131457	C
1,140	RHU -52 -FLOW	RHU-FT5203301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131458	C
1,141	RHU -52 -FLOW	RHU-FT5203302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131459	C
1,142	RHU -52 -FLOW	RHU-FT5203401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131460	C
1,143	RHU -52 -FLOW	RHU-FT5203501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131461	C
1,144	RHU -52 -FLOW	RHU-FT5203502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131462	C
1,145	RHU -52 -FLOW	RHU-FT5203601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131463	C
1,146	RHU -52 -FLOW	RHU-FT5203602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131464	C
1,147	RHU -52 -FLOW	RHU-FT5203603	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131465	C
1,148	RHU -52 -FLOW	RHU-FT5204201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131466	C
1,149	RHU -52 -FLOW	RHU-FT5230101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131467	C
1,150	RHU -52 -FLOW	RHU-FT5230102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131468	C
1,151	RHU -52 -FLOW	RHU-FT5231101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131469	C
1,152	RHU -52 -FLOW	RHU-FT5231102A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131470	C
1,153	RHU -52 -FLOW	RHU-FT5231102B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131471	C
1,154	RHU -52 -FLOW	RHU-FT5231103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131472	C
1,155	RHU -52 -FLOW	RHU-FT5232101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131473	C
1,156	RHU -52 -FLOW	RHU-FT5232102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131474	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,157	RHU -52 -FLOW	RHU-FT5233101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131475	C
1,158	RHU -52 -FLOW	RHU-FT5234101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131476	C
1,159	RHU -52 -FLOW	RHU-FT5235101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131477	C
1,160	RHU -52 -FLOW	RHU-FT5236101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131478	C
1,161	RHU -52 -FLOW	RHU-FT5237101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131479	C
1,162	RHU -52 -FLOW	RHU-FT5260101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131480	C
1,163	RHU -55 -FLOW	RHU-FT5500101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131481	C
1,164	RHU -55 -FLOW	RHU-FT5500102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131482	C
1,165	RHU -55 -FLOW	RHU-FT5500103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131483	C
1,166	RHU -55 -FLOW	RHU-FT5500104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131484	C
1,167	RHU -55 -FLOW	RHU-FT5500201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131485	C
1,168	RHU -55 -FLOW	RHU-FT5500202A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131486	C
1,169	RHU -55 -FLOW	RHU-FT5500202B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131487	C
1,170	RHU -55 -FLOW	RHU-FT5500202C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131488	C
1,171	RHU -55 -FLOW	RHU-FT5500203	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131489	C
1,172	RHU -55 -FLOW	RHU-FT5500401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131490	C
1,173	RHU -55 -FLOW	RHU-FT5500402	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131491	C
1,174	RHU -55 -FLOW	RHU-FT5500403	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131492	C
1,175	RHU -55 -FLOW	RHU-FT5500404	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131493	C
1,176	RHU -55 -FLOW	RHU-FT5500501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131494	C
1,177	RHU -55 -FLOW	RHU-FT5500701	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131495	C
1,178	RHU -55 -FLOW	RHU-FT5501101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131496	C
1,179	RHU -55 -FLOW	RHU-FT5501102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131497	C
1,180	RHU -55 -FLOW	RHU-FT5501201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131498	C
1,181	RHU -55 -FLOW	RHU-FT5501202	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131499	C
1,182	RHU -55 -FLOW	RHU-FT5501203	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131500	C
1,183	RHU -55 -FLOW	RHU-FT5501204	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y	I												RRC	RRC-IROH	131501	C
1,184	RHU -55 -FLOW	RHU-FT5501204	FT5501204-FULLFUN TEST FLOW TR	PMT	5Y											F		RRC	RRC-IROH	260363	C
1,185	RHU -55 -FLOW	RHU-FT5501301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131502	C
1,186	RHU -55 -FLOW	RHU-FT5501302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131503	C
1,187	RHU -55 -FLOW	RHU-FT5501401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131504	C
1,188	RHU -55 -FLOW	RHU-FT5501501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131505	C
1,189	RHU -55 -FLOW	RHU-FT5501502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131506	C
1,190	RHU -55 -FLOW	RHU-FT5501503	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131507	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,191	RHU -55 -FLOW	RHU-FT5501504	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y	I												RRC	RRC-IROH	131508	C
1,192	RHU -55 -FLOW	RHU-FT5501504	FT5501504-FULLFUN TEST FLOW TR	PMT	5Y											F		RRC	RRC-IROH	260364	C
1,193	RHU -55 -FLOW	RHU-FT5501505	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y	I												RRC	RRC-IROH	131509	C
1,194	RHU -55 -FLOW	RHU-FT5501505	FT5501505-FULLFUN TEST FLOW TR	PMT	5Y											F		RRC	RRC-IROH	260365	C
1,195	RHU -55 -FLOW	RHU-FT5501506	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131510	C
1,196	RHU -55 -FLOW	RHU-FT5501507	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131511	C
1,197	RHU -55 -FLOW	RHU-FT5501601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131512	C
1,198	RHU -55 -FLOW	RHU-FT5501602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131513	C
1,199	RHU -55 -FLOW	RHU-FT5502101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131514	C
1,200	RHU -55 -FLOW	RHU-FT5502102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131515	C
1,201	RHU -55 -FLOW	RHU-FT5502201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131516	C
1,202	RHU -55 -FLOW	RHU-FT5502202	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131517	C
1,203	RHU -55 -FLOW	RHU-FT5502301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131379	C
1,204	RHU -55 -FLOW	RHU-FT5502302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131518	C
1,205	RHU -55 -FLOW	RHU-FT5502303	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131519	C
1,206	RHU -55 -FLOW	RHU-FT5502501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131520	C
1,207	RHU -55 -FLOW	RHU-FT5502502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131521	C
1,208	RHU -55 -FLOW	RHU-FT5502503A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y	I												RRC	RRC-IROH	131522	C
1,209	RHU -55 -FLOW	RHU-FT5502503A	FT5502503A-FULLFUN TEST FLOW T	PMT	5Y											F		RRC	RRC-IROH	260366	C
1,210	RHU -55 -FLOW	RHU-FT5502503B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y	I												RRC	RRC-IROH	131523	C
1,211	RHU -55 -FLOW	RHU-FT5502503B	FT5502503B-FULLFUN TEST FLOW T	PMT	5Y											F		RRC	RRC-IROH	260367	C
1,212	RHU -55 -FLOW	RHU-FT5530101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131524	C
1,213	RHU -55 -FLOW	RHU-FT5530102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131525	C
1,214	RHU -55 -FLOW	RHU-FT5530104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131526	C
1,215	RHU -55 -FLOW	RHU-FT5530105	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131527	C
1,216	RHU -55 -FLOW	RHU-FT5531101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131528	C
1,217	RHU -55 -FLOW	RHU-FT5531102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y	I												RRC	RRC-IROH	131529	C
1,218	RHU -55 -FLOW	RHU-FT5531103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IROH	131530	C
1,219	RHU -55 -FLOW	RHU-FT5531106	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IROH	131531	C
1,220	RHU -55 -FLOW	RHU-FT5532101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IROH	131532	C
1,221	RHU -55 -FLOW	RHU-FT5532102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IROH	131533	C
1,222	RHU -55 -FLOW	RHU-FT5533101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IROH	131534	C
1,223	RHU -55 -FLOW	RHU-FT5534101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IROH	131535	C
1,224	RHU -55 -FLOW	RHU-FT5535101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y		I											RRC	RRC-IROH	131536	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,225	RHU -55 -FLOW	RHU-FT5536102	INSP. FIELD INST. (ต่อหุบไกรมั่น)	PMT	1Y		I											RRC	RRC-IRCH	131537	C
1,226	RHU -55 -FLOW	RHU-FT5537101	INSP. FIELD INST. (ต่อหุบไกรมั่น)	PMT	1Y		I											RRC	RRC-IRCH	131538	C
1,227	RHU -52 -CV	RHU-FV5200101	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132833	C
1,228	RHU -52 -CV	RHU-FV5200102	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132818	C
1,229	RHU -52 -CV	RHU-FV5200103	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132835	C
1,230	RHU -52 -CV	RHU-FV5200104	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132819	C
1,231	RHU -52 -CV	RHU-FV5200106	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132837	C
1,232	RHU -52 -CV	RHU-FV5200401	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132820	C
1,233	RHU -52 -CV	RHU-FV5200402	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132821	C
1,234	RHU -52 -CV	RHU-FV5200403	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132822	C
1,235	RHU -52 -CV	RHU-FV5200601	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132823	C
1,236	RHU -52 -CV	RHU-FV5200602	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132824	C
1,237	RHU -52 -CV	RHU-FV5200701	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132825	C
1,238	RHU -52 -CV	RHU-FV5200702	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132826	C
1,239	RHU -52 -CV	RHU-FV5201101	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132827	C
1,240	RHU -52 -CV	RHU-FV5201201	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132828	C
1,241	RHU -52 -CV	RHU-FV5201301	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132847	C
1,242	RHU -52 -CV	RHU-FV5201901	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132829	C
1,243	RHU -52 -CV	RHU-FV5201902	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132830	C
1,244	RHU -52 -CV	RHU-FV5201903	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132831	C
1,245	RHU -52 -CV	RHU-FV5201904	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132832	C
1,246	RHU -52 -CV	RHU-FV5202001	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132834	C
1,247	RHU -52 -CV	RHU-FV5202101	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132836	C
1,248	RHU -52 -CV	RHU-FV5202102	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132838	C
1,249	RHU -52 -CV	RHU-FV5202201	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132839	C
1,250	RHU -52 -CV	RHU-FV5202202	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132855	C
1,251	RHU -52 -CV	RHU-FV5202205	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132856	C
1,252	RHU -52 -CV	RHU-FV5202301	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132840	C
1,253	RHU -52 -CV	RHU-FV5202302	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132841	C
1,254	RHU -52 -CV	RHU-FV5202501	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132842	C
1,255	RHU -52 -CV	RHU-FV5202502	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132843	C
1,256	RHU -52 -CV	RHU-FV5202601	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132857	C
1,257	RHU -52 -CV	RHU-FV5202602	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132858	C
1,258	RHU -52 -CV	RHU-FV5202901	INSPECT CONTROL VALVE NO. FV52	PMT	1Y									I				RRC	RRC-IRCH	132844	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,259	RHU -52 -CV	RHU-FV5203001	INSPECT CONTROL VALVE NO. FV52	PMT	1Y										I			RRC	RRC-IRCH	132845	C
1,260	RHU -52 -CV	RHU-FV5203101	INSPECT CONTROL VALVE NO. FV52	PMT	1Y										I			RRC	RRC-IRCH	132846	C
1,261	RHU -52 -CV	RHU-FV5203102	INSPECT CONTROL VALVE NO. FV52	PMT	1Y										I			RRC	RRC-IRCH	132848	C
1,262	RHU -52 -CV	RHU-FV5203201	INSPECT CONTROL VALVE NO. FV52	PMT	1Y										I			RRC	RRC-IRCH	132849	C
1,263	RHU -52 -CV	RHU-FV5203202	INSPECT CONTROL VALVE NO. FV52	PMT	1Y										I			RRC	RRC-IRCH	132850	C
1,264	RHU -52 -CV	RHU-FV5203301	INSPECT CONTROL VALVE NO. FV52	PMT	1Y										I			RRC	RRC-IRCH	132851	C
1,265	RHU -52 -CV	RHU-FV5203501	INSPECT CONTROL VALVE NO. FV52	PMT	1Y										I			RRC	RRC-IRCH	132852	C
1,266	RHU -52 -CV	RHU-FV5203601	INSPECT CONTROL VALVE NO. FV52	PMT	1Y										I			RRC	RRC-IRCH	132853	C
1,267	RHU -52 -CV	RHU-FV5203602	INSPECT CONTROL VALVE NO. FV52	PMT	1Y										I			RRC	RRC-IRCH	132854	C
1,268	RHU -52 -CV	RHU-FV5204002	INSPECT CONTROL VALVE NO. FV52	PMT	1Y										I			RRC	RRC-IRCH	132859	C
1,269	RHU -55 -CV	RHU-FV5500101	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132860	C
1,270	RHU -55 -CV	RHU-FV5500102	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132861	C
1,271	RHU -55 -CV	RHU-FV5500201	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132862	C
1,272	RHU -55 -CV	RHU-FV5500203	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132863	C
1,273	RHU -55 -CV	RHU-FV5500401	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132864	C
1,274	RHU -55 -CV	RHU-FV5500402	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132865	C
1,275	RHU -55 -CV	RHU-FV5500501	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132866	C
1,276	RHU -55 -CV	RHU-FV5500701	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132867	C
1,277	RHU -55 -CV	RHU-FV5501101	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132868	C
1,278	RHU -55 -CV	RHU-FV5501201	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132869	C
1,279	RHU -55 -CV	RHU-FV5501202	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132870	C
1,280	RHU -55 -CV	RHU-FV5501203	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132871	C
1,281	RHU -55 -CV	RHU-FV5501301	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132872	C
1,282	RHU -55 -CV	RHU-FV5501401	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132873	C
1,283	RHU -55 -CV	RHU-FV5501402	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132874	C
1,284	RHU -55 -CV	RHU-FV5501501	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132875	C
1,285	RHU -55 -CV	RHU-FV5501502	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132876	C
1,286	RHU -55 -CV	RHU-FV5501503	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132877	C
1,287	RHU -55 -CV	RHU-FV5501507	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132878	C
1,288	RHU -55 -CV	RHU-FV5501601	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132879	C
1,289	RHU -55 -CV	RHU-FV5502101	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132880	C
1,290	RHU -55 -CV	RHU-FV5502201	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132881	C
1,291	RHU -55 -CV	RHU-FV5502301	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132882	C
1,292	RHU -55 -CV	RHU-FV5502302	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132883	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,293	RHU -55 -CV	RHU-FV5502303	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132884	C
1,294	RHU -55 -CV	RHU-FV5502501	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132885	C
1,295	RHU -55 -CV	RHU-FV5502502	INSPECT CONTROL VALVE NO. FV55	PMT	1Y										I			RRC	RRC-IRCH	132886	C
1,296	RHU -52 -QMI_GD	RHU-GDT5200101	VERIFY GAS_DETECTOR GDT5200101	PMT	4M				V				V				V	CAN	CAN-QUHV	140842	C
1,297	RHU -52 -QMI_GD	RHU-GDT5200101	VERIFY GAS_DETECTOR GDT5100101	PMT	4M				V				V				V	CAN	CAN-QUHV	140893	C
1,298	RHU -52 -QMI_GD	RHU-GDT5200102	VERIFY GAS_DETECTOR GDT5200102	PMT	4M				V				V				V	CAN	CAN-QUHV	140844	C
1,299	RHU -52 -QMI_GD	RHU-GDT5200103	VERIFY GAS_DETECTOR GDT5200103	PMT	4M				V				V				V	CAN	CAN-QUHV	140845	C
1,300	RHU -52 -QMI_GD	RHU-GDT5200104	VERIFY GAS_DETECTOR GDT5200104	PMT	4M				V				V				V	CAN	CAN-QUHV	140846	C
1,301	RHU -52 -QMI_GD	RHU-GDT5200105	VERIFY GAS_DETECTOR GDT5200105	PMT	4M				V				V				V	CAN	CAN-QUHV	140847	C
1,302	RHU -52 -QMI_GD	RHU-GDT5200106	VERIFY GAS_DETECTOR GDT5200106	PMT	4M				V				V				V	CAN	CAN-QUHV	140848	C
1,303	RHU -52 -QMI_GD	RHU-GDT5200107	VERIFY GAS_DETECTOR GDT5200107	PMT	4M				V				V				V	CAN	CAN-QUHV	140849	C
1,304	RHU -52 -QMI_GD	RHU-GDT5200108	VERIFY GAS_DETECTOR GDT5200108	PMT	4M				V				V				V	CAN	CAN-QUHV	140850	C
1,305	RHU -52 -QMI_GD	RHU-GDT5200109	VERIFY GAS_DETECTOR GDT5200109	PMT	4M				V				V				V	CAN	CAN-QUHV	140851	C
1,306	RHU -52 -QMI_GD	RHU-GDT5200110	VERIFY GAS_DETECTOR GDT5200110	PMT	4M				V				V				V	CAN	CAN-QUHV	140852	C
1,307	RHU -52 -QMI_GD	RHU-GDT5200111	VERIFY GAS_DETECTOR GDT5200111	PMT	4M				V				V				V	CAN	CAN-QUHV	140853	C
1,308	RHU -52 -QMI_GD	RHU-GDT5200112	VERIFY GAS_DETECTOR GDT5200112	PMT	4M				V				V				V	CAN	CAN-QUHV	140854	C
1,309	RHU -52 -QMI_GD	RHU-GDT5200113	VERIFY GAS_DETECTOR GDT5200113	PMT	4M				V				V				V	CAN	CAN-QUHV	140855	C
1,310	RHU -52 -QMI_GD	RHU-GDT5200201	VERIFY GAS_DETECTOR GDT5200201	PMT	4M				V				V				V	CAN	CAN-QUHV	204959	C
1,311	RHU -52 -QMI_GD	RHU-GDT5200202	VERIFY GAS_DETECTOR GDT5200202	PMT	4M				V				V				V	CAN	CAN-QUHV	204960	C
1,312	RHU -52 -QMI_GD	RHU-GDT5200203	VERIFY GAS_DETECTOR GDT5200203	PMT	4M				V				V				V	CAN	CAN-QUHV	204961	C
1,313	RHU -52 -QMI_GD	RHU-GDT5200204	VERIFY GAS_DETECTOR GDT5200204	PMT	4M				V				V				V	CAN	CAN-QUHV	204962	C
1,314	RHU -52 -QMI_GD	RHU-GDT5200205	VERIFY GAS_DETECTOR GDT5200205	PMT	4M				V				V				V	CAN	CAN-QUHV	204963	C
1,315	RHU -52 -QMI_GD	RHU-GDT5200206	VERIFY GAS_DETECTOR GDT5200206	PMT	4M				V				V				V	CAN	CAN-QUHV	204964	C
1,316	RHU -52 -QMI_GD	RHU-GDT5200207	VERIFY GAS_DETECTOR GDT5200207	PMT	4M				V				V				V	CAN	CAN-QUHV	204965	C
1,317	RHU -52 -QMI_GD	RHU-GDT5200208	VERIFY GAS_DETECTOR GDT5200208	PMT	4M				V				V				V	CAN	CAN-QUHV	204966	C
1,318	RHU -52 -QMI_GD	RHU-GDT5200209	VERIFY GAS_DETECTOR GDT5200209	PMT	4M				V				V				V	CAN	CAN-QUHV	204967	C
1,319	RHU -52 -QMI_GD	RHU-GDT5200214	VERIFY GAS_DETECTOR GDT5200214	PMT	4M				V				V				V	CAN	CAN-QUHV	204968	C
1,320	RHU -52 -QMI_GD	RHU-GDT5200215	VERIFY GAS_DETECTOR GDT5200215	PMT	4M				V				V				V	CAN	CAN-QUHV	204969	C
1,321	RHU -52 -QMI_GD	RHU-GDT5200216	VERIFY GAS_DETECTOR GDT5200216	PMT	4M				V				V				V	CAN	CAN-QUHV	204970	C
1,322	RHU -52 -QMI_GD	RHU-GDT5200217	VERIFY GAS_DETECTOR GDT5200217	PMT	4M				V				V				V	CAN	CAN-QUHV	204971	C
1,323	RHU -52 -QMI_GD	RHU-GDT5200228	VERIFY GAS_DETECTOR GDT5200228	PMT	4M				V				V				V	CAN	CAN-QUHV	204972	C
1,324	RHU -52 -QMI_GD	RHU-GDT5200232	VERIFY GAS_DETECTOR GDT5200232	PMT	4M				V				V				V	CAN	CAN-QUHV	204973	C
1,325	RHU -52 -QMI_GD	RHU-GDT5200234	VERIFY GAS_DETECTOR GDT5200234	PMT	4M				V				V				V	CAN	CAN-QUHV	204974	C
1,326	RHU -52 -QMI_GD	RHU-GDT5200235	VERIFY GAS_DETECTOR GDT5200235	PMT	4M				V				V				V	CAN	CAN-QUHV	204975	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,327	RHU -52 -QMI_GD	RHU-GDT5200236	VERIFY GAS_DETECTOR GDT5200236	PMT	4M				V				V				V	CAN	CAN-QUHV	204976	C
1,328	RHU -52 -QMI_GD	RHU-GDT5200237	VERIFY GAS_DETECTOR GDT5200237	PMT	4M				V				V				V	CAN	CAN-QUHV	204977	C
1,329	RHU -52 -QMI_GD	RHU-GDT5200240	VERIFY GAS_DETECTOR GDT5200240	PMT	4M				V				V				V	CAN	CAN-QUHV	204978	C
1,330	RHU -52 -QMI_GD	RHU-GDT5200242	VERIFY GAS_DETECTOR GDT5200242	PMT	4M				V				V				V	CAN	CAN-QUHV	204979	C
1,331	RHU -52 -QMI_GD	RHU-GDT5200243	VERIFY GAS_DETECTOR GDT5200243	PMT	4M				V				V				V	CAN	CAN-QUHV	204980	C
1,332	RHU -52 -QMI_GD	RHU-GDT5200301	VERIFY GAS_DETECTOR GDT5200301	PMT	4M				V				V				V	CAN	CAN-QUHV	140856	C
1,333	RHU -52 -QMI_GD	RHU-GDT5200303	VERIFY GAS_DETECTOR GDT5200303	PMT	4M				V				V				V	CAN	CAN-QUHV	140857	C
1,334	RHU -52 -QMI_GD	RHU-GDT5200304	VERIFY GAS_DETECTOR GDT5200304	PMT	4M				V				V				V	CAN	CAN-QUHV	140858	C
1,335	RHU -52 -QMI_GD	RHU-GDT5200305	VERIFY GAS_DETECTOR GDT5200305	PMT	4M				V				V				V	CAN	CAN-QUHV	140859	C
1,336	RHU -52 -QMI_GD	RHU-GDT5200308	VERIFY GAS_DETECTOR GDT5200308	PMT	4M				V				V				V	CAN	CAN-QUHV	140860	C
1,337	RHU -52 -QMI_GD	RHU-GDT5200309	VERIFY GAS_DETECTOR GDT5200309	PMT	4M				V				V				V	CAN	CAN-QUHV	140861	C
1,338	RHU -52 -QMI_GD	RHU-GDT5200310	VERIFY GAS_DETECTOR GDT5200310	PMT	4M				V				V				V	CAN	CAN-QUHV	140862	C
1,339	RHU -52 -QMI_GD	RHU-GDT5200311	VERIFY GAS_DETECTOR GDT5200311	PMT	4M				V				V				V	CAN	CAN-QUHV	140863	C
1,340	RHU -52 -QMI_GD	RHU-GDT5200312	VERIFY GAS_DETECTOR GDT5200312	PMT	4M				V				V				V	CAN	CAN-QUHV	140864	C
1,341	RHU -52 -QMI_GD	RHU-GDT5200313	VERIFY GAS_DETECTOR GDT5200313	PMT	4M				V				V				V	CAN	CAN-QUHV	140865	C
1,342	RHU -52 -QMI_GD	RHU-GDT5200314	VERIFY GAS_DETECTOR GDT5200314	PMT	4M				V				V				V	CAN	CAN-QUHV	140866	C
1,343	RHU -52 -QMI_GD	RHU-GDT5200315	VERIFY GAS_DETECTOR GDT5200315	PMT	4M				V				V				V	CAN	CAN-QUHV	140867	C
1,344	RHU -52 -QMI_GD	RHU-GDT5200316	VERIFY GAS_DETECTOR GDT5200316	PMT	4M				V				V				V	CAN	CAN-QUHV	140868	C
1,345	RHU -52 -QMI_GD	RHU-GDT5200317	VERIFY GAS_DETECTOR GDT5200317	PMT	4M				V				V				V	CAN	CAN-QUHV	140869	C
1,346	RHU -52 -QMI_GD	RHU-GDT5200318	VERIFY GAS_DETECTOR GDT5200318	PMT	4M				V				V				V	CAN	CAN-QUHV	140870	C
1,347	RHU -52 -QMI_GD	RHU-GDT5200319	VERIFY GAS_DETECTOR GDT5200319	PMT	4M				V				V				V	CAN	CAN-QUHV	140871	C
1,348	RHU -52 -QMI_GD	RHU-GDT5200322	VERIFY GAS_DETECTOR GDT5200322	PMT	4M				V				V				V	CAN	CAN-QUHV	140872	C
1,349	RHU -52 -QMI_GD	RHU-GDT5200323	VERIFY GAS_DETECTOR GDT5200323	PMT	4M				V				V				V	CAN	CAN-QUHV	140873	C
1,350	RHU -52 -QMI_GD	RHU-GDT5200324	VERIFY GAS_DETECTOR GDT5200324	PMT	4M				V				V				V	CAN	CAN-QUHV	140874	C
1,351	RHU -52 -QMI_GD	RHU-GDT5200326	VERIFY GAS_DETECTOR GDT5200326	PMT	4M				V				V				V	CAN	CAN-QUHV	140875	C
1,352	RHU -52 -QMI_GD	RHU-GDT5200327	VERIFY GAS_DETECTOR GDT5200327	PMT	4M				V				V				V	CAN	CAN-QUHV	140876	C
1,353	RHU -52 -QMI_GD	RHU-GDT5200331	VERIFY GAS_DETECTOR GDT5200331	PMT	4M				V				V				V	CAN	CAN-QUHV	140877	C
1,354	RHU -52 -QMI_GD	RHU-GDT5200332	VERIFY GAS_DETECTOR GDT5200332	PMT	4M				V				V				V	CAN	CAN-QUHV	140878	C
1,355	RHU -52 -QMI_GD	RHU-GDT5200333	VERIFY GAS_DETECTOR GDT5200333	PMT	4M				V				V				V	CAN	CAN-QUHV	140879	C
1,356	RHU -52 -QMI_GD	RHU-GDT5200340	VERIFY GAS_DETECTOR GDT5200340	PMT	4M				V				V				V	CAN	CAN-QUHV	140880	C
1,357	RHU -52 -QMI_GD	RHU-GDT5200341	VERIFY GAS_DETECTOR GDT5200341	PMT	4M				V				V				V	CAN	CAN-QUHV	140881	C
1,358	RHU -52 -QMI_GD	RHU-GDT5200342	VERIFY GAS_DETECTOR GDT5200342	PMT	4M				V				V				V	CAN	CAN-QUHV	140882	C
1,359	RHU -55 -QMI_GD	RHU-GDT5500201	VERIFY GAS_DETECTOR GDT5500201	PMT	4M				V				V				V	CAN	CAN-QUHV	204820	C
1,360	RHU -55 -QMI_GD	RHU-GDT5500202	VERIFY GAS_DETECTOR GDT5500202	PMT	4M				V				V				V	CAN	CAN-QUHV	204821	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,361	RHU -55 -QMI_GD	RHU-GDT5500203	VERIFY GAS_DETECTOR GDT5500203	PMT	4M				V				V				V	CAN	CAN-QUHV	204822	C
1,362	RHU -55 -QMI_GD	RHU-GDT5500204	VERIFY GAS_DETECTOR GDT5500204	PMT	4M				V				V				V	CAN	CAN-QUHV	204823	C
1,363	RHU -55 -QMI_GD	RHU-GDT5500205	VERIFY GAS_DETECTOR GDT5500205	PMT	4M				V				V				V	CAN	CAN-QUHV	204824	C
1,364	RHU -55 -QMI_GD	RHU-GDT5500206	VERIFY GAS_DETECTOR GDT5500206	PMT	4M				V				V				V	CAN	CAN-QUHV	204825	C
1,365	RHU -55 -QMI_GD	RHU-GDT5500207	VERIFY GAS_DETECTOR GDT5500207	PMT	4M				V				V				V	CAN	CAN-QUHV	204826	C
1,366	RHU -55 -QMI_GD	RHU-GDT5500208	VERIFY GAS_DETECTOR GDT5500208	PMT	4M				V				V				V	CAN	CAN-QUHV	204827	C
1,367	RHU -55 -QMI_GD	RHU-GDT5500209	VERIFY GAS_DETECTOR GDT5500209	PMT	4M				V				V				V	CAN	CAN-QUHV	204828	C
1,368	RHU -55 -QMI_GD	RHU-GDT5500210	VERIFY GAS_DETECTOR GDT5500210	PMT	4M				V				V				V	CAN	CAN-QUHV	204829	C
1,369	RHU -55 -QMI_GD	RHU-GDT5500211	VERIFY GAS_DETECTOR GDT5500211	PMT	4M				V				V				V	CAN	CAN-QUHV	204830	C
1,370	RHU -55 -QMI_GD	RHU-GDT5500212	VERIFY GAS_DETECTOR GDT5500212	PMT	4M				V				V				V	CAN	CAN-QUHV	204831	C
1,371	RHU -55 -QMI_GD	RHU-GDT5500213	VERIFY GAS_DETECTOR GDT5500213	PMT	4M				V				V				V	CAN	CAN-QUHV	204832	C
1,372	RHU -55 -QMI_GD	RHU-GDT5500214	VERIFY GAS_DETECTOR GDT5500214	PMT	4M				V				V				V	CAN	CAN-QUHV	204833	C
1,373	RHU -55 -QMI_GD	RHU-GDT5500215	VERIFY GAS_DETECTOR GDT5500215	PMT	4M				V				V				V	CAN	CAN-QUHV	204834	C
1,374	RHU -55 -QMI_GD	RHU-GDT5500216	VERIFY GAS_DETECTOR GDT5500216	PMT	4M				V				V				V	CAN	CAN-QUHV	204835	C
1,375	RHU -55 -QMI_GD	RHU-GDT5500217	VERIFY GAS_DETECTOR GDT5500217	PMT	4M				V				V				V	CAN	CAN-QUHV	204836	C
1,376	RHU -55 -QMI_GD	RHU-GDT5500218	VERIFY GAS_DETECTOR GDT5500218	PMT	4M				V				V				V	CAN	CAN-QUHV	204837	C
1,377	RHU -55 -QMI_GD	RHU-GDT5500219	VERIFY GAS_DETECTOR GDT5500219	PMT	4M				V				V				V	CAN	CAN-QUHV	204838	C
1,378	RHU -55 -QMI_GD	RHU-GDT5500220	VERIFY GAS_DETECTOR GDT5500220	PMT	4M				V				V				V	CAN	CAN-QUHV	204839	C
1,379	RHU -55 -QMI_GD	RHU-GDT5500221	VERIFY GAS_DETECTOR GDT5500221	PMT	4M				V				V				V	CAN	CAN-QUHV	204840	C
1,380	RHU -55 -QMI_GD	RHU-GDT5500222	VERIFY GAS_DETECTOR GDT5500222	PMT	4M				V				V				V	CAN	CAN-QUHV	204841	C
1,381	RHU -55 -QMI_GD	RHU-GDT5500223	VERIFY GAS_DETECTOR GDT5500223	PMT	4M				V				V				V	CAN	CAN-QUHV	204842	C
1,382	RHU -55 -QMI_GD	RHU-GDT5500224	VERIFY GAS_DETECTOR GDT5500224	PMT	4M				V				V				V	CAN	CAN-QUHV	204843	C
1,383	RHU -55 -QMI_GD	RHU-GDT5500225	VERIFY GAS_DETECTOR GDT5500225	PMT	4M				V				V				V	CAN	CAN-QUHV	204844	C
1,384	RHU -55 -QMI_GD	RHU-GDT5500226	VERIFY GAS_DETECTOR GDT5500226	PMT	4M				V				V				V	CAN	CAN-QUHV	204845	C
1,385	RHU -55 -QMI_GD	RHU-GDT5500227	VERIFY GAS_DETECTOR GDT5500227	PMT	4M				V				V				V	CAN	CAN-QUHV	204846	C
1,386	RHU -55 -QMI_GD	RHU-GDT5500229	VERIFY GAS_DETECTOR GDT5500229	PMT	4M				V				V				V	CAN	CAN-QUHV	204847	C
1,387	RHU -55 -QMI_GD	RHU-GDT5500230	VERIFY GAS_DETECTOR GDT5500230	PMT	4M				V				V				V	CAN	CAN-QUHV	204848	C
1,388	RHU -55 -QMI_GD	RHU-GDT5500231	VERIFY GAS_DETECTOR GDT5500231	PMT	4M				V				V				V	CAN	CAN-QUHV	204849	C
1,389	RHU -55 -QMI_GD	RHU-GDT5500232	VERIFY GAS_DETECTOR GDT5500232	PMT	4M				V				V				V	CAN	CAN-QUHV	204850	C
1,390	RHU -55 -QMI_GD	RHU-GDT5500233	VERIFY GAS_DETECTOR GDT5500233	PMT	4M				V				V				V	CAN	CAN-QUHV	204851	C
1,391	RHU -55 -QMI_GD	RHU-GDT5500234	VERIFY GAS_DETECTOR GDT5500234	PMT	4M				V				V				V	CAN	CAN-QUHV	204852	C
1,392	RHU -55 -QMI_GD	RHU-GDT5500235	VERIFY GAS_DETECTOR GDT5500235	PMT	4M				V				V				V	CAN	CAN-QUHV	204853	C
1,393	RHU -55 -QMI_GD	RHU-GDT5500240	VERIFY GAS_DETECTOR GDT5500240	PMT	4M				V				V				V	CAN	CAN-QUHV	204854	C
1,394	RHU -55 -QMI_GD	RHU-GDT5500241	VERIFY GAS_DETECTOR GDT5500241	PMT	4M				V				V				V	CAN	CAN-QUHV	204855	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,395	RHU -55 -QMI_GD	RHU-GDT5500242	VERIFY GAS_DETECTOR GDT5500242	PMT	4M				V				V				V	CAN	CAN-QUHV	204856	C
1,396	RHU -55 -QMI_GD	RHU-GDT5500243	VERIFY GAS_DETECTOR GDT5500243	PMT	4M				V				V				V	CAN	CAN-QUHV	204857	C
1,397	RHU -52 -CV	RHU-HV5200201	INSPECT CONTROL VALVE NO. HV52	PMT	1Y										I			RRC	RRC- IROH	132887	C
1,398	RHU -52 -CV	RHU-HV5201101	INSPECT CONTROL VALVE NO. HV52	PMT	1Y										I			RRC	RRC- IROH	132888	C
1,399	RHU -52 -CV	RHU-HV5201401	INSPECT CONTROL VALVE NO. HV52	PMT	1Y										I			RRC	RRC- IROH	132889	C
1,400	RHU -52 -CV	RHU-HV5202501	INSPECT CONTROL VALVE NO. HV52	PMT	1Y										I			RRC	RRC- IROH	132890	C
1,401	RHU -52 -CV	RHU-HV5202502	INSPECT CONTROL VALVE NO. HV52	PMT	1Y										I			RRC	RRC- IROH	132891	C
1,402	RHU -52 -CV	RHU-HV5202503	INSPECT CONTROL VALVE NO. HV52	PMT	1Y										I			RRC	RRC- IROH	132892	C
1,403	RHU -52 -CV	RHU-HV5202504	INSPECT CONTROL VALVE NO. HV52	PMT	1Y										I			RRC	RRC- IROH	132893	C
1,404	RHU -52 -CV	RHU-HV5202505	INSPECT CONTROL VALVE NO. HV52	PMT	1Y										I			RRC	RRC- IROH	132894	C
1,405	RHU -52 -CV	RHU-HV5202506	INSPECT CONTROL VALVE NO. HV52	PMT	1Y										I			RRC	RRC- IROH	132895	C
1,406	RHU -55 -CV	RHU-HV5500101	INSPECT CONTROL VALVE NO. HV55	PMT	1Y										I			RRC	RRC- IROH	132896	C
1,407	RHU -55 -CV	RHU-HV5500102	INSPECT CONTROL VALVE NO. HV55	PMT	1Y										I			RRC	RRC- IROH	132897	C
1,408	RHU -55 -CV	RHU-HV5500401	INSPECT CONTROL VALVE NO. HV55	PMT	1Y										I			RRC	RRC- IROH	132898	C
1,409	RHU -55 -CV	RHU-HV5502301	INSPECT CONTROL VALVE NO. HV55	PMT	1Y										I			RRC	RRC- IROH	132899	C
1,410	RHU -55 -CV	RHU-HV5502302	INSPECT CONTROL VALVE NO. HV55	PMT	1Y										I			RRC	RRC- IROH	132900	C
1,411	RHU -52 -LEVEL	RHU-LT5201101A	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131540	C
1,412	RHU -52 -LEVEL	RHU-LT5201101A	LT5201101A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260505	C
1,413	RHU -52 -LEVEL	RHU-LT5201101B	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131541	C
1,414	RHU -52 -LEVEL	RHU-LT5201101B	LT5201101B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260506	C
1,415	RHU -52 -LEVEL	RHU-LT5201101C	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131542	C
1,416	RHU -52 -LEVEL	RHU-LT5201101C	LT5201101C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260507	C
1,417	RHU -52 -LEVEL	RHU-LT5201102	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC- IROH	131543	C
1,418	RHU -52 -LEVEL	RHU-LT5201801A	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC- IROH	131544	C
1,419	RHU -52 -LEVEL	RHU-LT5201801B	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC- IROH	131545	C
1,420	RHU -52 -LEVEL	RHU-LT5201802A	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131546	C
1,421	RHU -52 -LEVEL	RHU-LT5201802A	LT5201802A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260508	C
1,422	RHU -52 -LEVEL	RHU-LT5201802B	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131547	C
1,423	RHU -52 -LEVEL	RHU-LT5201802B	LT5201802B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260509	C
1,424	RHU -52 -LEVEL	RHU-LT5201802C	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131548	C
1,425	RHU -52 -LEVEL	RHU-LT5201802C	LT5201802C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260510	C
1,426	RHU -52 -LEVEL	RHU-LT5201001A	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC- IROH	131549	C
1,427	RHU -52 -LEVEL	RHU-LT5201001B	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC- IROH	131550	C
1,428	RHU -52 -LEVEL	RHU-LT5201003A	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131551	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,429	RHU -52 -LEVEL	RHU-LT5201003A	LT5201003A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260518	C
1,430	RHU -52 -LEVEL	RHU-LT5201003B	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131552	C
1,431	RHU -52 -LEVEL	RHU-LT5201003B	LT5201003B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260519	C
1,432	RHU -52 -LEVEL	RHU-LT5201003C	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131553	C
1,433	RHU -52 -LEVEL	RHU-LT5201003C	LT5201003C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260520	C
1,434	RHU -52 -LEVEL	RHU-LT5201004	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131648	C
1,435	RHU -52 -LEVEL	RHU-LT5201004	LT5201004-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC- IROH	260415	C
1,436	RHU -52 -LEVEL	RHU-LT5201005A	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC- IROH	131649	C
1,437	RHU -52 -LEVEL	RHU-LT5201005B	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC- IROH	131650	C
1,438	RHU -52 -LEVEL	RHU-LT5201101	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC- IROH	131554	C
1,439	RHU -52 -LEVEL	RHU-LT5201102A	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC- IROH	131555	C
1,440	RHU -52 -LEVEL	RHU-LT5201102B	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC- IROH	131556	C
1,441	RHU -52 -LEVEL	RHU-LT5201103A	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131557	C
1,442	RHU -52 -LEVEL	RHU-LT5201103A	LT5201103A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260521	C
1,443	RHU -52 -LEVEL	RHU-LT5201103B	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131558	C
1,444	RHU -52 -LEVEL	RHU-LT5201103B	LT5201103B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260522	C
1,445	RHU -52 -LEVEL	RHU-LT5201103C	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131559	C
1,446	RHU -52 -LEVEL	RHU-LT5201103C	LT5201103C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260523	C
1,447	RHU -52 -LEVEL	RHU-LT5201104A	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131560	C
1,448	RHU -52 -LEVEL	RHU-LT5201104A	LT5201104A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260524	C
1,449	RHU -52 -LEVEL	RHU-LT5201104B	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131561	C
1,450	RHU -52 -LEVEL	RHU-LT5201104B	LT5201104B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260525	C
1,451	RHU -52 -LEVEL	RHU-LT5201104C	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131562	C
1,452	RHU -52 -LEVEL	RHU-LT5201104C	LT5201104C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260526	C
1,453	RHU -52 -LEVEL	RHU-LT5201201	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC- IROH	131563	C
1,454	RHU -52 -LEVEL	RHU-LT5201202A	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131564	C
1,455	RHU -52 -LEVEL	RHU-LT5201202A	LT5201202A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260527	C
1,456	RHU -52 -LEVEL	RHU-LT5201202B	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131565	C
1,457	RHU -52 -LEVEL	RHU-LT5201202B	LT5201202B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260528	C
1,458	RHU -52 -LEVEL	RHU-LT5201202C	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131566	C
1,459	RHU -52 -LEVEL	RHU-LT5201202C	LT5201202C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260529	C
1,460	RHU -52 -LEVEL	RHU-LT5201401A	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131567	C
1,461	RHU -52 -LEVEL	RHU-LT5201401A	LT5201401A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260530	C
1,462	RHU -52 -LEVEL	RHU-LT5201401B	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131568	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,463	RHU -52 -LEVEL	RHU-LT5201401B	LT5201401B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260531	C
1,464	RHU -52 -LEVEL	RHU-LT5201401C	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131569	C
1,465	RHU -52 -LEVEL	RHU-LT5201401C	LT5201401C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260532	C
1,466	RHU -52 -LEVEL	RHU-LT5201402	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC- IROH	131570	C
1,467	RHU -52 -LEVEL	RHU-LT5201501	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC- IROH	131571	C
1,468	RHU -52 -LEVEL	RHU-LT5201502A	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131572	C
1,469	RHU -52 -LEVEL	RHU-LT5201502A	LT5201502A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260533	C
1,470	RHU -52 -LEVEL	RHU-LT5201502B	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131573	C
1,471	RHU -52 -LEVEL	RHU-LT5201502B	LT5201502B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260534	C
1,472	RHU -52 -LEVEL	RHU-LT5201502C	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131574	C
1,473	RHU -52 -LEVEL	RHU-LT5201502C	LT5201502C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260535	C
1,474	RHU -52 -LEVEL	RHU-LT5201701	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC- IROH	131575	C
1,475	RHU -52 -LEVEL	RHU-LT5201702A	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131576	C
1,476	RHU -52 -LEVEL	RHU-LT5201702A	LT5201702A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260536	C
1,477	RHU -52 -LEVEL	RHU-LT5201702B	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131577	C
1,478	RHU -52 -LEVEL	RHU-LT5201702B	LT5201702B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260537	C
1,479	RHU -52 -LEVEL	RHU-LT5201702C	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131578	C
1,480	RHU -52 -LEVEL	RHU-LT5201702C	LT5201702C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260538	C
1,481	RHU -52 -LEVEL	RHU-LT5201901	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC- IROH	131579	C
1,482	RHU -52 -LEVEL	RHU-LT5201902	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131580	C
1,483	RHU -52 -LEVEL	RHU-LT5201902	LT5201902-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC- IROH	260539	C
1,484	RHU -52 -LEVEL	RHU-LT5202001	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC- IROH	131581	C
1,485	RHU -52 -LEVEL	RHU-LT5202002	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131582	C
1,486	RHU -52 -LEVEL	RHU-LT5202002	LT5202002-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC- IROH	260514	C
1,487	RHU -52 -LEVEL	RHU-LT5202101	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC- IROH	131651	C
1,488	RHU -52 -LEVEL	RHU-LT5202102A	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC- IROH	131583	C
1,489	RHU -52 -LEVEL	RHU-LT5202102B	INSP. FIELD INST. (ต่อหุ้มไกรน์)	PMT	1Y		I											RRC	RRC- IROH	131584	C
1,490	RHU -52 -LEVEL	RHU-LT5202103A	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131585	C
1,491	RHU -52 -LEVEL	RHU-LT5202103A	LT5202103A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260540	C
1,492	RHU -52 -LEVEL	RHU-LT5202103B	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131586	C
1,493	RHU -52 -LEVEL	RHU-LT5202103B	LT5202103B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260541	C
1,494	RHU -52 -LEVEL	RHU-LT5202103C	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131587	C
1,495	RHU -52 -LEVEL	RHU-LT5202103C	LT5202103C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC- IROH	260542	C
1,496	RHU -52 -LEVEL	RHU-LT5202105	INSP. FIELD INST. (ต่อหุ้มไกรน์)	INS	1Y		I											RRC	RRC- IROH	131652	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,497	RHU -52 -LEVEL	RHU-LT5202105	LT5202105-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260416	C
1,498	RHU -52 -LEVEL	RHU-LT5202301A	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131588	C
1,499	RHU -52 -LEVEL	RHU-LT5202301B	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131589	C
1,500	RHU -52 -LEVEL	RHU-LT5202302	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131590	C
1,501	RHU -52 -LEVEL	RHU-LT5202302	LT5202302-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IROH	260543	C
1,502	RHU -52 -LEVEL	RHU-LT5202401	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131653	C
1,503	RHU -52 -LEVEL	RHU-LT5202402	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131591	C
1,504	RHU -52 -LEVEL	RHU-LT5202403	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131654	C
1,505	RHU -52 -LEVEL	RHU-LT5202403	LT5202403-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260417	C
1,506	RHU -52 -LEVEL	RHU-LT5202404	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131592	C
1,507	RHU -52 -LEVEL	RHU-LT5202404	LT5202404-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IROH	260545	C
1,508	RHU -52 -LEVEL	RHU-LT5202601	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131593	C
1,509	RHU -52 -LEVEL	RHU-LT5202602	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131594	C
1,510	RHU -52 -LEVEL	RHU-LT5202602	LT5202602-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IROH	260546	C
1,511	RHU -52 -LEVEL	RHU-LT5202701	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131595	C
1,512	RHU -52 -LEVEL	RHU-LT5202702A	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131596	C
1,513	RHU -52 -LEVEL	RHU-LT5202702B	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131597	C
1,514	RHU -52 -LEVEL	RHU-LT5202703	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131598	C
1,515	RHU -52 -LEVEL	RHU-LT5202703	LT5202703-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IROH	260548	C
1,516	RHU -52 -LEVEL	RHU-LT5202705	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131599	C
1,517	RHU -52 -LEVEL	RHU-LT5202705	LT5202705-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IROH	260547	C
1,518	RHU -52 -LEVEL	RHU-LT5202801	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131600	C
1,519	RHU -52 -LEVEL	RHU-LT5202802A	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131601	C
1,520	RHU -52 -LEVEL	RHU-LT5202802A	LT5202802A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260549	C
1,521	RHU -52 -LEVEL	RHU-LT5202802B	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131602	C
1,522	RHU -52 -LEVEL	RHU-LT5202802B	LT5202802B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260550	C
1,523	RHU -52 -LEVEL	RHU-LT5202802C	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131603	C
1,524	RHU -52 -LEVEL	RHU-LT5202802C	LT5202802C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260551	C
1,525	RHU -52 -LEVEL	RHU-LT5202901	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131604	C
1,526	RHU -52 -LEVEL	RHU-LT5202902A	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131605	C
1,527	RHU -52 -LEVEL	RHU-LT5202902B	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131606	C
1,528	RHU -52 -LEVEL	RHU-LT5202903	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131607	C
1,529	RHU -52 -LEVEL	RHU-LT5202903	LT5202903-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IROH	260553	C
1,530	RHU -52 -LEVEL	RHU-LT5202905	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131608	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,531	RHU -52 -LEVEL	RHU-LT5202905	LT5202905-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IROH	260552	C
1,532	RHU -52 -LEVEL	RHU-LT5203101A	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131609	C
1,533	RHU -52 -LEVEL	RHU-LT5203101A	LT5203101A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260554	C
1,534	RHU -52 -LEVEL	RHU-LT5203101B	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131610	C
1,535	RHU -52 -LEVEL	RHU-LT5203101B	LT5203101B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260555	C
1,536	RHU -52 -LEVEL	RHU-LT5203101C	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131611	C
1,537	RHU -52 -LEVEL	RHU-LT5203101C	LT5203101C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260556	C
1,538	RHU -52 -LEVEL	RHU-LT5203102A	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131612	C
1,539	RHU -52 -LEVEL	RHU-LT5203102B	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131613	C
1,540	RHU -52 -LEVEL	RHU-LT5203201	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131614	C
1,541	RHU -52 -LEVEL	RHU-LT5203203	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131615	C
1,542	RHU -52 -LEVEL	RHU-LT5203203	LT5203203-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IROH	260560	C
1,543	RHU -52 -LEVEL	RHU-LT5203301A	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131616	C
1,544	RHU -52 -LEVEL	RHU-LT5203301B	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131617	C
1,545	RHU -52 -LEVEL	RHU-LT5203302	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131655	C
1,546	RHU -52 -LEVEL	RHU-LT5203303A	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131618	C
1,547	RHU -52 -LEVEL	RHU-LT5203303A	LT5203303A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260557	C
1,548	RHU -52 -LEVEL	RHU-LT5203303B	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131619	C
1,549	RHU -52 -LEVEL	RHU-LT5203303B	LT5203303B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260558	C
1,550	RHU -52 -LEVEL	RHU-LT5203303C	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131620	C
1,551	RHU -52 -LEVEL	RHU-LT5203303C	LT5203303C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260559	C
1,552	RHU -52 -LEVEL	RHU-LT5203304	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131656	C
1,553	RHU -52 -LEVEL	RHU-LT5203304	LT5203304-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260418	C
1,554	RHU -52 -LEVEL	RHU-LT5203401	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131621	C
1,555	RHU -52 -LEVEL	RHU-LT5203402A	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131622	C
1,556	RHU -52 -LEVEL	RHU-LT5203402A	LT5203402A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260561	C
1,557	RHU -52 -LEVEL	RHU-LT5203402B	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131623	C
1,558	RHU -52 -LEVEL	RHU-LT5203402B	LT5203402B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260562	C
1,559	RHU -52 -LEVEL	RHU-LT5203402C	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131624	C
1,560	RHU -52 -LEVEL	RHU-LT5203402C	LT5203402C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260563	C
1,561	RHU -52 -LEVEL	RHU-LT5250401	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131642	C
1,562	RHU -52 -LEVEL	RHU-LT5250501	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131625	C
1,563	RHU -52 -LEVEL	RHU-LT5250701	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131626	C
1,564	RHU -52 -52K101	RHU-LT5252510	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131643	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,565	RHU -52 -52P001A	RHU-LT5253201A	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131644	C
1,566	RHU -52 -52P001B	RHU-LT5253701B	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131645	C
1,567	RHU -52 -52P007	RHU-LT5254501	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131646	C
1,568	RHU -52 -52P007	RHU-LT5254801	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131647	C
1,569	RHU -52 -LEVEL	RHU-LT5255501	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131627	C
1,570	RHU -52 -LEVEL	RHU-LT5255502	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131671	C
1,571	RHU -52 -LEVEL	RHU-LT5284301	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131657	C
1,572	RHU -52 -LEVEL	RHU-LT5284302	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131658	C
1,573	RHU -55 -LEVEL	RHU-LT5500101	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131659	C
1,574	RHU -55 -LEVEL	RHU-LT5500102	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131660	C
1,575	RHU -55 -LEVEL	RHU-LT5500102	LT5500102-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260413	C
1,576	RHU -55 -LEVEL	RHU-LT5500103	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131661	C
1,577	RHU -55 -LEVEL	RHU-LT5500201	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131662	C
1,578	RHU -55 -LEVEL	RHU-LT5500202	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131629	C
1,579	RHU -55 -LEVEL	RHU-LT5500202	LT5500202-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IROH	260498	C
1,580	RHU -55 -LEVEL	RHU-LT5500203	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131630	C
1,581	RHU -55 -LEVEL	RHU-LT5500204	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131663	C
1,582	RHU -55 -LEVEL	RHU-LT5500204	LT5500204-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260414	C
1,583	RHU -55 -LEVEL	RHU-LT5500301	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131664	C
1,584	RHU -55 -LEVEL	RHU-LT5500501	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131665	C
1,585	RHU -55 -LEVEL	RHU-LT5501101	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131631	C
1,586	RHU -55 -LEVEL	RHU-LT5501102	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131632	C
1,587	RHU -55 -LEVEL	RHU-LT5501102	LT5501102-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IROH	260499	C
1,588	RHU -55 -LEVEL	RHU-LT5501201	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131666	C
1,589	RHU -55 -LEVEL	RHU-LT5501301	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131633	C
1,590	RHU -55 -LEVEL	RHU-LT5501401	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131634	C
1,591	RHU -55 -LEVEL	RHU-LT5501402	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131635	C
1,592	RHU -55 -LEVEL	RHU-LT5501402	LT5501402-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IROH	260500	C
1,593	RHU -55 -LEVEL	RHU-LT5501501	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131636	C
1,594	RHU -55 -LEVEL	RHU-LT5501501	LT5501501-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IROH	260501	C
1,595	RHU -55 -LEVEL	RHU-LT5501502	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131637	C
1,596	RHU -55 -LEVEL	RHU-LT5501601	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131667	C
1,597	RHU -55 -LEVEL	RHU-LT5502101	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131638	C
1,598	RHU -55 -LEVEL	RHU-LT5502102	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131639	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,599	RHU -55 -LEVEL	RHU-LT5502102	LT5502102-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IROH	260502	C
1,600	RHU -55 -LEVEL	RHU-LT5502103	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131668	C
1,601	RHU -55 -LEVEL	RHU-LT5502201	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131640	C
1,602	RHU -55 -LEVEL	RHU-LT5502202	INSP. FIELD INST. (ตัดชุมไกรมนี)	INS	1Y		I											RRC	RRC-IROH	131641	C
1,603	RHU -55 -LEVEL	RHU-LT5502202	LT5502202-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IROH	260503	C
1,604	RHU -55 -LEVEL	RHU-LT5502203	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131669	C
1,605	RHU -55 -55X101	RHU-LT5502401	INSP. FIELD INST. (ตัดชุมไกรมนี)	PMT	1Y		I											RRC	RRC-IROH	131670	C
1,606	RHU -52 -CV	RHU-LV5200801A	INSPECT CONTROL VALVE NO. LV52	PMT	1Y												I	RRC	RRC-IROH	132934	C
1,607	RHU -52 -CV	RHU-LV5200801B	INSPECT CONTROL VALVE NO. LV52	PMT	1Y												I	RRC	RRC-IROH	132935	C
1,608	RHU -52 -CV	RHU-LV5201001A	INSPECT CONTROL VALVE NO. LV52	PMT	1Y												I	RRC	RRC-IROH	132936	C
1,609	RHU -52 -CV	RHU-LV5201001B	INSPECT CONTROL VALVE NO. LV52	PMT	1Y												I	RRC	RRC-IROH	132937	C
1,610	RHU -52 -CV	RHU-LV5201005A	INSPECT CONTROL VALVE NO. LV52	PMT	1Y												I	RRC	RRC-IROH	132938	C
1,611	RHU -52 -CV	RHU-LV5201005B	INSPECT CONTROL VALVE NO. LV52	PMT	1Y												I	RRC	RRC-IROH	132939	C
1,612	RHU -52 -CV	RHU-LV5201101	INSPECT CONTROL VALVE NO. LV52	PMT	1Y												I	RRC	RRC-IROH	132940	C
1,613	RHU -52 -CV	RHU-LV5201102A	INSPECT CONTROL VALVE NO. LV52	PMT	1Y												I	RRC	RRC-IROH	132941	C
1,614	RHU -52 -CV	RHU-LV5201102B	INSPECT CONTROL VALVE NO. LV52	PMT	1Y												I	RRC	RRC-IROH	132942	C
1,615	RHU -52 -CV	RHU-LV5201201	INSPECT CONTROL VALVE NO. LV52	PMT	1Y												I	RRC	RRC-IROH	132943	C
1,616	RHU -52 -CV	RHU-PCV5200301	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y													I	RRC	RRC-IROH	133156	C
1,617	RHU -52 -CV	RHU-PCV5200302	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y													I	RRC	RRC-IROH	133157	C
1,618	RHU -52 -CV	RHU-PCV5204201	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I		RRC	RRC-IROH	132972	C
1,619	RHU -52 -CV	RHU-PCV5204202	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I		RRC	RRC-IROH	132973	C
1,620	RHU -52 -52K002A	RHU-PCV5251120A	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y													I	RRC	RRC-IROH	133158	C
1,621	RHU -52 -CV	RHU-PCV5251122A	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y													I	RRC	RRC-IROH	133159	C
1,622	RHU -52 -CV	RHU-PCV5251122A	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y													I	RRC	RRC-IROH	133179	C
1,623	RHU -52 -52K002A	RHU-PCV5251137A	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y													I	RRC	RRC-IROH	133160	C
1,624	RHU -52 -CV	RHU-PCV5251143A	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y													I	RRC	RRC-IROH	133161	C
1,625	RHU -52 -CV	RHU-PCV5251143A	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y													I	RRC	RRC-IROH	133178	C
1,626	RHU -52 -52K002A	RHU-PCV5251221A	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y													I	RRC	RRC-IROH	133162	C
1,627	RHU -52 -52K002A	RHU-PCV5251505A	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y													I	RRC	RRC-IROH	133163	C
1,628	RHU -52 -52K002B	RHU-PCV5251720B	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y													I	RRC	RRC-IROH	133164	C
1,629	RHU -52 -52K002B	RHU-PCV5251722B	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y													I	RRC	RRC-IROH	133165	C
1,630	RHU -52 -52K002B	RHU-PCV5251737B	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y													I	RRC	RRC-IROH	133166	C
1,631	RHU -52 -52K002B	RHU-PCV5251743B	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y													I	RRC	RRC-IROH	133167	C
1,632	RHU -52 -52K002B	RHU-PCV5251821B	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y													I	RRC	RRC-IROH	133168	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,633	RHU -52 -52K002B	RHU-PCV5252105B	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IROH	133169	C
1,634	RHU -52 -52K101	RHU-PCV5252422	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IROH	133170	C
1,635	RHU -52 -52K101	RHU-PCV5252423	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IROH	133171	C
1,636	RHU -52 -52K101	RHU-PCV5252425	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IROH	133172	C
1,637	RHU -52 -52K101	RHU-PCV5252426	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IROH	133173	C
1,638	RHU -52 -52K101	RHU-PCV5252533	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IROH	133174	C
1,639	RHU -52 -52K101	RHU-PCV5252804	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IROH	133175	C
1,640	RHU -52 -52P007	RHU-PCV5254501	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IROH	133187	C
1,641	RHU -52 -52P007	RHU-PCV5254502	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IROH	133189	C
1,642	RHU -52 -52P007	RHU-PCV5254801	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IROH	133188	C
1,643	RHU -52 -52P007	RHU-PCV5254802	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y												I	RRC	RRC-IROH	133190	C
1,644	RHU -52 -CV	RHU-PCV5255501	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IROH	132974	C
1,645	RHU -52 -CV	RHU-PCV5255502	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IROH	132975	C
1,646	RHU -52 -CV	RHU-PCV5255503	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IROH	132976	C
1,647	RHU -52 -CV	RHU-PCV5284301	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IROH	132977	C
1,648	RHU -55 -CV	RHU-PCV5502401	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IROH	132979	C
1,649	RHU -55 -CV	RHU-PCV5502402	INSPECT CONTROL VALVE NO. PCV5	PMT	1Y											I		RRC	RRC-IROH	132980	C
1,650	RHU -52 -PRESS	RHU-PDT5200405	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y		I											RRC	RRC-IROH	131672	C
1,651	RHU -52 -PRESS	RHU-PDT5200505	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y		I											RRC	RRC-IROH	131673	C
1,652	RHU -52 -PRESS	RHU-PDT5200603	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y		I											RRC	RRC-IROH	131674	C
1,653	RHU -52 -PRESS	RHU-PDT5200604	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y		I											RRC	RRC-IROH	131675	C
1,654	RHU -52 -PRESS	RHU-PDT5200703	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y		I											RRC	RRC-IROH	131676	C
1,655	RHU -52 -PRESS	RHU-PDT5200704	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y		I											RRC	RRC-IROH	131677	C
1,656	RHU -52 -PRESS	RHU-PDT5201101	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y		I											RRC	RRC-IROH	131678	C
1,657	RHU -52 -PRESS	RHU-PDT5202704	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y		I											RRC	RRC-IROH	131679	C
1,658	RHU -52 -PRESS	RHU-PDT5202904	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y		I											RRC	RRC-IROH	131680	C
1,659	RHU -52 -PRESS	RHU-PDT5204216	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y		I											RRC	RRC-IROH	131681	C
1,660	RHU -52 -PRESS	RHU-PDT5250403	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y		I											RRC	RRC-IROH	131682	C
1,661	RHU -52 -PRESS	RHU-PDT5250404	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y			I										RRC	RRC-IROH	131683	C
1,662	RHU -52 -PRESS	RHU-PDT5250405	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y			I										RRC	RRC-IROH	131684	C
1,663	RHU -52 -PRESS	RHU-PDT5250406	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y			I										RRC	RRC-IROH	131685	C
1,664	RHU -52 -PRESS	RHU-PDT5250407A	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y			I										RRC	RRC-IROH	131686	C
1,665	RHU -52 -PRESS	RHU-PDT5250407B	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y			I										RRC	RRC-IROH	131687	C
1,666	RHU -52 -PRESS	RHU-PDT5250407C	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y			I										RRC	RRC-IROH	131688	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,667	RHU -52 -PRESS	RHU-PDT5250408A	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y			I										RRC	RRC-IROH	131689	C
1,668	RHU -52 -PRESS	RHU-PDT5250408B	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y			I										RRC	RRC-IROH	131690	C
1,669	RHU -52 -PRESS	RHU-PDT5250408C	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y			I										RRC	RRC-IROH	131691	C
1,670	RHU -52 -52K001	RHU-PDT5250502	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y			I										RRC	RRC-IROH	131692	C
1,671	RHU -52 -52K001	RHU-PDT5250704	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y			I										RRC	RRC-IROH	131693	C
1,672	RHU -52 -52K002A	RHU-PDT5251005A	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y					I								RRC	RRC-IROH	131926	C
1,673	RHU -52 -52K002A	RHU-PDT5251017A	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y					I								RRC	RRC-IROH	131928	C
1,674	RHU -52 -52K002A	RHU-PDT5251218A	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y					I								RRC	RRC-IROH	131930	C
1,675	RHU -52 -PRESS	RHU-PDT5251233A	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y			I										RRC	RRC-IROH	131694	C
1,676	RHU -52 -52K002A	RHU-PDT5251411A	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y					I								RRC	RRC-IROH	131932	C
1,677	RHU -52 -52K002B	RHU-PDT5251605B	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y					I								RRC	RRC-IROH	131927	C
1,678	RHU -52 -52K002B	RHU-PDT5251617B	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y					I								RRC	RRC-IROH	131929	C
1,679	RHU -52 -52K002B	RHU-PDT5251833B	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y					I								RRC	RRC-IROH	131931	C
1,680	RHU -52 -52K002B	RHU-PDT5252011B	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y					I								RRC	RRC-IROH	131933	C
1,681	RHU -52 -52K101	RHU-PDT5252303	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y					I								RRC	RRC-IROH	131944	C
1,682	RHU -52 -52K101	RHU-PDT5252531	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y					I								RRC	RRC-IROH	131945	C
1,683	RHU -52 -52K101	RHU-PDT5252711	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y					I								RRC	RRC-IROH	131946	C
1,684	RHU -52 -52P001A	RHU-PDT5253201A	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y					I								RRC	RRC-IROH	131953	C
1,685	RHU -52 -52P001B	RHU-PDT5253701B	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y					I								RRC	RRC-IROH	131954	C
1,686	RHU -52 -52P007	RHU-PDT5254501	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y					I								RRC	RRC-IROH	131967	C
1,687	RHU -52 -52P007	RHU-PDT5254801	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y					I								RRC	RRC-IROH	131968	C
1,688	RHU -52 -52P003AB	RHU-PDT5255101	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y					I								RRC	RRC-IROH	131951	C
1,689	RHU -52 -52P003AB	RHU-PDT5255201	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y					I								RRC	RRC-IROH	131952	C
1,690	RHU -55 -PRESS	RHU-PDT5500301	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131695	C
1,691	RHU -55 -PRESS	RHU-PDT5500302	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131696	C
1,692	RHU -55 -PRESS	RHU-PDT5500402	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131697	C
1,693	RHU -55 -PRESS	RHU-PDT5500403	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131698	C
1,694	RHU -55 -PRESS	RHU-PDT5500603	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131699	C
1,695	RHU -55 -PRESS	RHU-PDT5500801	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131700	C
1,696	RHU -55 -PRESS	RHU-PDT5500901	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131701	C
1,697	RHU -55 -PRESS	RHU-PDT5501001	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131702	C
1,698	RHU -55 -PRESS	RHU-PDT5501701	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131703	C
1,699	RHU -55 -PRESS	RHU-PDT5501801	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131704	C
1,700	RHU -55 -PRESS	RHU-PDT5501901	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131705	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,701	RHU -55 -PRESS	RHU-PDT5502001	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y			I										RRC	RRC-IROH	131706	C
1,702	RHU -55 -PRESS	RHU-PDT5502202	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y			I										RRC	RRC-IROH	131707	C
1,703	RHU -55 -CV	RHU-PDV5502202	INSPECT CONTROL VALVE NO. PDV5	PMT	1Y											I		RRC	RRC-IROH	132910	C
1,704	RHU -52 -52R001A	RHU-PSV5200401A	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162642	A
1,705	RHU -52 -52R001A	RHU-PSV5200401B	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162643	A
1,706	RHU -52 -52R001B	RHU-PSV5200501A	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162644	A
1,707	RHU -52 -52R001B	RHU-PSV5200501B	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162645	A
1,708	RHU -52 -52D003	RHU-PSV5201002	Pressure Relief Device Calibra	PMT	2Y											I		RRC	RRC-MROH	162647	B
1,709	RHU -52 -52C001	RHU-PSV5201101	Pressure Relief Device Calibra	PMT	2Y					I								RRC	RRC-MROH	162648	A
1,710	RHU -52 -52C001	RHU-PSV5201102	Pressure Relief Device Calibra	PMT	2Y					I								RRC	RRC-MROH	162649	A
1,711	RHU -52 -52D008	RHU-PSV5201201	Pressure Relief Device Calibra	PMT	2Y					I								RRC	RRC-MROH	162650	A
1,712	RHU -52 -52D008	RHU-PSV5201202	Pressure Relief Device Calibra	PMT	2Y					I								RRC	RRC-MROH	162651	A
1,713	RHU -52 -52K001	RHU-PSV5201301	Pressure Relief Device Calibra	PMT	2Y					I								RRC	RRC-MROH	162652	A
1,714	RHU -52 -52K001	RHU-PSV5201302	Pressure Relief Device Calibra	PMT	2Y					I								RRC	RRC-MROH	162653	A
1,715	RHU -52 -52D010A	RHU-PSV5201501	Pressure Relief Device Calibra	PMT	2Y											I		RRC	RRC-MROH	162658	A
1,716	RHU -52 -52K002A	RHU-PSV5201602	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162660	A
1,717	RHU -52 -52D010B	RHU-PSV5201701	Pressure Relief Device Calibra	PMT	2Y					I								RRC	RRC-MROH	162661	A
1,718	RHU -52 -52K002B	RHU-PSV5201802	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162663	A
1,719	RHU -52 -52D006	RHU-PSV5201903	Pressure Relief Device Calibra	PMT	2Y					I								RRC	RRC-MROH	162666	B
1,720	RHU -52 -52D006	RHU-PSV5201906	Pressure Relief Device Calibra	PMT	2Y					I								RRC	RRC-MROH	162669	B
1,721	RHU -52 -52K101	RHU-PSV5250701	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162698	A
1,722	RHU -52 -52K101	RHU-PSV5250703	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162699	A
1,723	RHU -52 -52K002A	RHU-PSV5251123A	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162702	A
1,724	RHU -52 -52K002A	RHU-PSV5251136A	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162703	A
1,725	RHU -52 -52K002A	RHU-PSV5251138A	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162704	A
1,726	RHU -52 -52K002A	RHU-PSV5251222A	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162705	A
1,727	RHU -52 -52K002A	RHU-PSV5251225A	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162706	A
1,728	RHU -52 -52K002B	RHU-PSV5251723	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162710	A
1,729	RHU -52 -52K002B	RHU-PSV5251736	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162711	A
1,730	RHU -52 -52K002B	RHU-PSV5251738	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162712	A
1,731	RHU -52 -52K002B	RHU-PSV5251822B	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162713	A
1,732	RHU -52 -52K002B	RHU-PSV5251825B	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162714	A
1,733	RHU -52 -52K101	RHU-PSV5252409	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162718	A
1,734	RHU -52 -52K101	RHU-PSV5252424	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162719	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,735	RHU -52 -52K101	RHU-PSV5252427	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162720	A
1,736	RHU -52 -52K101	RHU-PSV5252520	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162721	A
1,737	RHU -52 -52K101	RHU-PSV5252523	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162722	A
1,738	RHU -52 -52P001A	RHU-PSV5253302A	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162727	A
1,739	RHU -52 -52P001A	RHU-PSV5253201A	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162728	A
1,740	RHU -52 -52P001A	RHU-PSV5253301A	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162729	A
1,741	RHU -52 -52P001A	RHU-PSV5253302A	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162730	A
1,742	RHU -52 -52P001A	RHU-PSV5253303A	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162731	A
1,743	RHU -52 -52P001A	RHU-PSV5253304A	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162732	A
1,744	RHU -52 -52P001B	RHU-PSV5253701B	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162733	A
1,745	RHU -52 -52P001B	RHU-PSV5253702B	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162734	A
1,746	RHU -52 -52P001A	RHU-PSV5253801B	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162735	A
1,747	RHU -52 -52P001A	RHU-PSV5253802B	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162736	A
1,748	RHU -52 -52P001A	RHU-PSV5253803B	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162737	A
1,749	RHU -52 -52P001A	RHU-PSV5253804B	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162738	A
1,750	RHU -52 -52D018	RHU-PSV5255501	Pressure Relief Device Calibra	PMT	2Y						I							RRC	RRC-MROH	162745	B
1,751	RHU -52 -52D018	RHU-PSV5255502	Pressure Relief Device Calibra	PMT	2Y						I							RRC	RRC-MROH	162746	B
1,752	RHU -55 -55X001	RHU-PSV5500301	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	162762	A
1,753	RHU -55 -PSV	RHU-PSV5502602	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MROH	254781	B
1,754	RHU -52 -PRESS	RHU-PT5200101	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131708	C
1,755	RHU -52 -PRESS	RHU-PT5200103	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131709	C
1,756	RHU -52 -PRESS	RHU-PT5200105	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131710	C
1,757	RHU -52 -PRESS	RHU-PT5200107	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131711	C
1,758	RHU -52 -PRESS	RHU-PT5200201	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131712	C
1,759	RHU -52 -PRESS	RHU-PT5200202	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131713	C
1,760	RHU -52 -PRESS	RHU-PT5200203	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131714	C
1,761	RHU -52 -PRESS	RHU-PT5200401	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131715	C
1,762	RHU -52 -PRESS	RHU-PT5200403	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131716	C
1,763	RHU -52 -PRESS	RHU-PT5200406	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131717	C
1,764	RHU -52 -PRESS	RHU-PT5200408	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131718	C
1,765	RHU -52 -PRESS	RHU-PT5200410	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131719	C
1,766	RHU -52 -PRESS	RHU-PT5200411	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131720	C
1,767	RHU -52 -PRESS	RHU-PT5200412	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131721	C
1,768	RHU -52 -PRESS	RHU-PT5200413	INSP. FIELD INST. (ตัดทุกปีการณ์)	PMT	1Y				I									RRC	RRC-IROH	131722	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,769	RHU -52 -PRESS	RHU-PT5200415	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131723	C
1,770	RHU -52 -PRESS	RHU-PT5200501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131724	C
1,771	RHU -52 -PRESS	RHU-PT5200503	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131725	C
1,772	RHU -52 -PRESS	RHU-PT5200506	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131726	C
1,773	RHU -52 -PRESS	RHU-PT5200508	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131727	C
1,774	RHU -52 -PRESS	RHU-PT5200510	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131728	C
1,775	RHU -52 -PRESS	RHU-PT5200511	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131729	C
1,776	RHU -52 -PRESS	RHU-PT5200512	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131730	C
1,777	RHU -52 -PRESS	RHU-PT5200513	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131731	C
1,778	RHU -52 -PRESS	RHU-PT5200601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131732	C
1,779	RHU -52 -PRESS	RHU-PT5200602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131733	C
1,780	RHU -52 -PRESS	RHU-PT5200701	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131734	C
1,781	RHU -52 -PRESS	RHU-PT5200702	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131735	C
1,782	RHU -52 -PRESS	RHU-PT5200801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131736	C
1,783	RHU -52 -PRESS	RHU-PT5200901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131737	C
1,784	RHU -52 -PRESS	RHU-PT5200902	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131738	C
1,785	RHU -52 -PRESS	RHU-PT5200903	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131739	C
1,786	RHU -52 -PRESS	RHU-PT5200904	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131740	C
1,787	RHU -52 -PRESS	RHU-PT5200905	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131741	C
1,788	RHU -52 -PRESS	RHU-PT5200906	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131742	C
1,789	RHU -52 -PRESS	RHU-PT5201001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131743	C
1,790	RHU -52 -PRESS	RHU-PT5201002	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131744	C
1,791	RHU -52 -PRESS	RHU-PT5201003	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131745	C
1,792	RHU -52 -PRESS	RHU-PT5201004A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y			I										RRC	RRC-IROH	131746	C
1,793	RHU -52 -PRESS	RHU-PT5201004A	PT5201004A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260515	C
1,794	RHU -52 -PRESS	RHU-PT5201004B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y			I										RRC	RRC-IROH	131747	C
1,795	RHU -52 -PRESS	RHU-PT5201004B	PT5201004B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260516	C
1,796	RHU -52 -PRESS	RHU-PT5201004C	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y			I										RRC	RRC-IROH	131748	C
1,797	RHU -52 -PRESS	RHU-PT5201004C	PT5201004C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260517	C
1,798	RHU -52 -PRESS	RHU-PT5201102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131749	C
1,799	RHU -52 -PRESS	RHU-PT5201103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131750	C
1,800	RHU -52 -PRESS	RHU-PT5201104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131751	C
1,801	RHU -52 -PRESS	RHU-PT5201302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IROH	131902	C
1,802	RHU -52 -PRESS	RHU-PT5201304	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IROH	131903	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,803	RHU -52 -PRESS	RHU-PT5201401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131752	C
1,804	RHU -52 -PRESS	RHU-PT5201404	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131753	C
1,805	RHU -52 -PRESS	RHU-PT5201503	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131754	C
1,806	RHU -52 -PRESS	RHU-PT5201504	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131755	C
1,807	RHU -52 -PRESS	RHU-PT5201505	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131756	C
1,808	RHU -52 -PRESS	RHU-PT5201601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131757	C
1,809	RHU -52 -PRESS	RHU-PT5201703	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131758	C
1,810	RHU -52 -PRESS	RHU-PT5201704	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131759	C
1,811	RHU -52 -PRESS	RHU-PT5201705	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131760	C
1,812	RHU -52 -PRESS	RHU-PT5201901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131761	C
1,813	RHU -52 -PRESS	RHU-PT5201904	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131762	C
1,814	RHU -52 -PRESS	RHU-PT5202001	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131763	C
1,815	RHU -52 -PRESS	RHU-PT5202002	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131764	C
1,816	RHU -52 -PRESS	RHU-PT5202003	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131765	C
1,817	RHU -52 -PRESS	RHU-PT5202101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131766	C
1,818	RHU -52 -PRESS	RHU-PT5202103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131767	C
1,819	RHU -52 -PRESS	RHU-PT5202302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131768	C
1,820	RHU -52 -PRESS	RHU-PT5202303	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131769	C
1,821	RHU -52 -PRESS	RHU-PT5202304	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y			I										RRC	RRC-IROH	131770	C
1,822	RHU -52 -PRESS	RHU-PT5202304	PT5202304-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IROH	260544	C
1,823	RHU -52 -PRESS	RHU-PT5202401	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131771	C
1,824	RHU -52 -PRESS	RHU-PT5202403	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131772	C
1,825	RHU -52 -PRESS	RHU-PT5202404	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131773	C
1,826	RHU -52 -52P005	RHU-PT5202404A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IROH	131975	C
1,827	RHU -52 -52P005	RHU-PT5202404B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IROH	131976	C
1,828	RHU -52 -PRESS	RHU-PT5202405A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131774	C
1,829	RHU -52 -PRESS	RHU-PT5202405B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131775	C
1,830	RHU -52 -PRESS	RHU-PT5202501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131776	C
1,831	RHU -52 -PRESS	RHU-PT5202502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131777	C
1,832	RHU -52 -PRESS	RHU-PT5202503	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131778	C
1,833	RHU -52 -PRESS	RHU-PT5202601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131779	C
1,834	RHU -52 -PRESS	RHU-PT5202602	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131780	C
1,835	RHU -52 -PRESS	RHU-PT5202603	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131781	C
1,836	RHU -52 -PRESS	RHU-PT5202701	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131782	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,837	RHU -52 -PRESS	RHU-PT5202702	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131783	C
1,838	RHU -52 -PRESS	RHU-PT5202703	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131784	C
1,839	RHU -52 -PRESS	RHU-PT5202801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131785	C
1,840	RHU -52 -PRESS	RHU-PT5202901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131786	C
1,841	RHU -52 -PRESS	RHU-PT5202902	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131787	C
1,842	RHU -52 -PRESS	RHU-PT5202903	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131788	C
1,843	RHU -52 -PRESS	RHU-PT5202905	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131789	C
1,844	RHU -52 -PRESS	RHU-PT5203101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131790	C
1,845	RHU -52 -PRESS	RHU-PT5203201	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131791	C
1,846	RHU -52 -PRESS	RHU-PT5203202	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131792	C
1,847	RHU -52 -PRESS	RHU-PT5203301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131793	C
1,848	RHU -52 -PRESS	RHU-PT5203302	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131794	C
1,849	RHU -52 -PRESS	RHU-PT5203303	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131795	C
1,850	RHU -52 -PRESS	RHU-PT5203304	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131796	C
1,851	RHU -52 -PRESS	RHU-PT5203501	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131797	C
1,852	RHU -52 -PRESS	RHU-PT5203502	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131798	C
1,853	RHU -52 -52P103	RHU-PT5203601	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IROH	131979	C
1,854	RHU -52 -PRESS	RHU-PT5203606	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131799	C
1,855	RHU -52 -PRESS	RHU-PT5203801	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131800	C
1,856	RHU -52 -PRESS	RHU-PT5203802	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131801	C
1,857	RHU -52 -PRESS	RHU-PT5203803	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131802	C
1,858	RHU -52 -PRESS	RHU-PT5203804	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131803	C
1,859	RHU -52 -PRESS	RHU-PT5203805	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131804	C
1,860	RHU -52 -PRESS	RHU-PT5203806	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131805	C
1,861	RHU -52 -PRESS	RHU-PT5203807	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131806	C
1,862	RHU -52 -PRESS	RHU-PT5203808	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131807	C
1,863	RHU -52 -PRESS	RHU-PT5203813	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131808	C
1,864	RHU -52 -PRESS	RHU-PT5203901	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131809	C
1,865	RHU -52 -PRESS	RHU-PT5203903A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y			I										RRC	RRC-IROH	131810	C
1,866	RHU -52 -PRESS	RHU-PT5203903A	PT5203903A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260511	C
1,867	RHU -52 -PRESS	RHU-PT5203903B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y			I										RRC	RRC-IROH	131811	C
1,868	RHU -52 -PRESS	RHU-PT5203903B	PT5203903B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260512	C
1,869	RHU -52 -PRESS	RHU-PT5203903C	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y			I										RRC	RRC-IROH	131812	C
1,870	RHU -52 -PRESS	RHU-PT5203903C	PT5203903C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260513	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,871	RHU -52 -PRESS	RHU-PT5203904	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131813	C
1,872	RHU -52 -PRESS	RHU-PT5203907	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131814	C
1,873	RHU -52 -PRESS	RHU-PT5203909	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131815	C
1,874	RHU -52 -PRESS	RHU-PT5204101	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131816	C
1,875	RHU -52 -PRESS	RHU-PT5204102	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131817	C
1,876	RHU -52 -PRESS	RHU-PT5204103	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131818	C
1,877	RHU -52 -PRESS	RHU-PT5204104	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131819	C
1,878	RHU -52 -PRESS	RHU-PT5204105	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131820	C
1,879	RHU -52 -PRESS	RHU-PT5204106	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131821	C
1,880	RHU -52 -PRESS	RHU-PT5204107	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131822	C
1,881	RHU -52 -PRESS	RHU-PT5204108	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131823	C
1,882	RHU -52 -PRESS	RHU-PT5204113	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131824	C
1,883	RHU -52 -PRESS	RHU-PT5204210	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131825	C
1,884	RHU -52 -PRESS	RHU-PT5204211	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131826	C
1,885	RHU -52 -PRESS	RHU-PT5204212	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131827	C
1,886	RHU -52 -PRESS	RHU-PT5204213A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y			I										RRC	RRC-IROH	131828	C
1,887	RHU -52 -PRESS	RHU-PT5204213A	PT5204213A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260564	C
1,888	RHU -52 -PRESS	RHU-PT5204213B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y			I										RRC	RRC-IROH	131829	C
1,889	RHU -52 -PRESS	RHU-PT5204213B	PT5204213B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260565	C
1,890	RHU -52 -PRESS	RHU-PT5204213C	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y			I										RRC	RRC-IROH	131830	C
1,891	RHU -52 -PRESS	RHU-PT5204213C	PT5204213C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260566	C
1,892	RHU -52 -PRESS	RHU-PT5204214	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131831	C
1,893	RHU -52 -PRESS	RHU-PT5204215A	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y			I										RRC	RRC-IROH	131832	C
1,894	RHU -52 -PRESS	RHU-PT5204215A	PT5204215A-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260567	C
1,895	RHU -52 -PRESS	RHU-PT5204215B	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y			I										RRC	RRC-IROH	131833	C
1,896	RHU -52 -PRESS	RHU-PT5204215B	PT5204215B-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260568	C
1,897	RHU -52 -PRESS	RHU-PT5204215C	INSP. FIELD INST. (ตรวจปกติ)	INS	1Y			I										RRC	RRC-IROH	131834	C
1,898	RHU -52 -PRESS	RHU-PT5204215C	PT5204215C-FULL FUN TEST PT &	PMT	5Y											F		RRC	RRC-IROH	260569	C
1,899	RHU -52 -PRESS	RHU-PT5204301	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y			I										RRC	RRC-IROH	131835	C
1,900	RHU -52 -PRESS	RHU-PT5204303A	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IROH	131836	C
1,901	RHU -52 -PRESS	RHU-PT5204303B	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IROH	131837	C
1,902	RHU -52 -PRESS	RHU-PT5204303C	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IROH	131838	C
1,903	RHU -52 -PRESS	RHU-PT5204304	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IROH	131839	C
1,904	RHU -52 -PRESS	RHU-PT5204306	INSP. FIELD INST. (ตรวจปกติ)	PMT	1Y				I									RRC	RRC-IROH	131840	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,905	RHU -52 -PRESS	RHU-PT5204308	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131841	C
1,906	RHU -52 -PRESS	RHU-PT5230101	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131842	C
1,907	RHU -52 -PRESS	RHU-PT5230102	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131843	C
1,908	RHU -52 -PRESS	RHU-PT5231101	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131844	C
1,909	RHU -52 -PRESS	RHU-PT5231102	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131845	C
1,910	RHU -52 -PRESS	RHU-PT5234101	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131846	C
1,911	RHU -52 -52K001	RHU-PT5250401	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131847	C
1,912	RHU -52 -52K001	RHU-PT5250402A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131848	C
1,913	RHU -52 -52K001	RHU-PT5250402B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131849	C
1,914	RHU -52 -52K001	RHU-PT5250402C	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131850	C
1,915	RHU -52 -PRESS	RHU-PT5250406	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131851	C
1,916	RHU -52 -52K001	RHU-PT5250501	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131852	C
1,917	RHU -52 -52K001	RHU-PT5250502	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131853	C
1,918	RHU -52 -52K001	RHU-PT5250503	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131854	C
1,919	RHU -52 -52K001	RHU-PT5250504	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131855	C
1,920	RHU -52 -52K001	RHU-PT5250701	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131856	C
1,921	RHU -52 -52K001	RHU-PT5250702	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131857	C
1,922	RHU -52 -52K001	RHU-PT5250703	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131858	C
1,923	RHU -52 -52K001	RHU-PT5250705	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131859	C
1,924	RHU -52 -52K002A	RHU-PT5251002A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131904	C
1,925	RHU -52 -52K002A	RHU-PT5251012A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131906	C
1,926	RHU -52 -52K002A	RHU-PT5251023A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131908	C
1,927	RHU -52 -52K002A	RHU-PT5251125A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131910	C
1,928	RHU -52 -52K002A	RHU-PT5251129A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131912	C
1,929	RHU -52 -52K002A	RHU-PT5251133A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131914	C
1,930	RHU -52 -52K002A	RHU-PT5251140A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131916	C
1,931	RHU -52 -52K002A	RHU-PT5251230A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131920	C
1,932	RHU -52 -52K002A	RHU-PT5251231A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131918	C
1,933	RHU -52 -52K002A	RHU-PT5251302A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131922	C
1,934	RHU -52 -52K002A	RHU-PT5251509A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131924	C
1,935	RHU -52 -52K002B	RHU-PT5251602B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131905	C
1,936	RHU -52 -52K002B	RHU-PT5251612B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131907	C
1,937	RHU -52 -52K002B	RHU-PT5251623B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131909	C
1,938	RHU -52 -52K002B	RHU-PT5251725B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131911	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,939	RHU -52 -52K002B	RHU-PT5251729B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131913	C
1,940	RHU -52 -52K002B	RHU-PT5251733B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131915	C
1,941	RHU -52 -52K002B	RHU-PT5251740B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131917	C
1,942	RHU -52 -52K002B	RHU-PT5251830B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131921	C
1,943	RHU -52 -52K002B	RHU-PT5251831B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131919	C
1,944	RHU -52 -52K002B	RHU-PT5251902B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131923	C
1,945	RHU -52 -52K002B	RHU-PT5252109B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131925	C
1,946	RHU -52 -52K101	RHU-PT5252302	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131934	C
1,947	RHU -52 -52K101	RHU-PT5252306	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131935	C
1,948	RHU -52 -52K101	RHU-PT5252411	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131936	C
1,949	RHU -52 -52K101	RHU-PT5252415	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131937	C
1,950	RHU -52 -52K101	RHU-PT5252419	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131938	C
1,951	RHU -52 -52K101	RHU-PT5252429	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131939	C
1,952	RHU -52 -52K101	RHU-PT5252528	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131941	C
1,953	RHU -52 -52K101	RHU-PT5252529	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131940	C
1,954	RHU -52 -52K101	RHU-PT5252601	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131942	C
1,955	RHU -52 -52K101	RHU-PT5252808	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131943	C
1,956	RHU -52 -52P001A	RHU-PT5253201A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131955	C
1,957	RHU -52 -52P001A	RHU-PT5253202A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131957	C
1,958	RHU -52 -52P001A	RHU-PT5253203A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131959	C
1,959	RHU -52 -52P001A	RHU-PT5253204A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131961	C
1,960	RHU -52 -52P001A	RHU-PT5253205A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131963	C
1,961	RHU -52 -52P001A	RHU-PT5253206A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131965	C
1,962	RHU -52 -PRESS	RHU-PT5253301A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131860	C
1,963	RHU -52 -PRESS	RHU-PT5253302A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131861	C
1,964	RHU -52 -52P001B	RHU-PT5253701B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131956	C
1,965	RHU -52 -52P001B	RHU-PT5253702B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131958	C
1,966	RHU -52 -52P001B	RHU-PT5253703B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131960	C
1,967	RHU -52 -52P001B	RHU-PT5253704B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131962	C
1,968	RHU -52 -52P001B	RHU-PT5253705B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131964	C
1,969	RHU -52 -52P001B	RHU-PT5253706B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131966	C
1,970	RHU -52 -PRESS	RHU-PT5253801B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131862	C
1,971	RHU -52 -PRESS	RHU-PT5253802B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131863	C
1,972	RHU -52 -52P007	RHU-PT5254501A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131969	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,973	RHU -52 -52P007	RHU-PT5254501B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131970	C
1,974	RHU -52 -52P007	RHU-PT5254501C	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131971	C
1,975	RHU -52 -52P007	RHU-PT5254801A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131972	C
1,976	RHU -52 -52P007	RHU-PT5254801B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131973	C
1,977	RHU -52 -52P007	RHU-PT5254801C	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131974	C
1,978	RHU -52 -52P003A	RHU-PT5255101	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131947	C
1,979	RHU -52 -52P003A	RHU-PT5255102	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131948	C
1,980	RHU -52 -52P003B	RHU-PT5255201	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131949	C
1,981	RHU -52 -52P003B	RHU-PT5255202	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131950	C
1,982	RHU -55 -PRESS	RHU-PT5500101	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131864	C
1,983	RHU -55 -PRESS	RHU-PT5500102	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131865	C
1,984	RHU -55 -PRESS	RHU-PT5500103	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131866	C
1,985	RHU -55 -PRESS	RHU-PT5500201	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131867	C
1,986	RHU -55 -PRESS	RHU-PT5500401	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131868	C
1,987	RHU -55 -PRESS	RHU-PT5500505	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131869	C
1,988	RHU -55 -PRESS	RHU-PT5500601	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131870	C
1,989	RHU -55 -PRESS	RHU-PT5500602	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131871	C
1,990	RHU -55 -PRESS	RHU-PT5500802	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131872	C
1,991	RHU -55 -PRESS	RHU-PT5500902	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131873	C
1,992	RHU -55 -PRESS	RHU-PT5501002	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131874	C
1,993	RHU -55 -PRESS	RHU-PT5501008	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131875	C
1,994	RHU -55 -PRESS	RHU-PT5501101	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131876	C
1,995	RHU -55 -PRESS	RHU-PT5501301	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131877	C
1,996	RHU -55 -PRESS	RHU-PT5501302	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131878	C
1,997	RHU -55 -PRESS	RHU-PT5501303	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131879	C
1,998	RHU -55 -PRESS	RHU-PT5501308	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131880	C
1,999	RHU -55 -PRESS	RHU-PT5501401	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131881	C
2,000	RHU -55 -PRESS	RHU-PT5501406	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131882	C
2,001	RHU -55 -PRESS	RHU-PT5501508	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131883	C
2,002	RHU -55 -PRESS	RHU-PT5501601	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131884	C
2,003	RHU -55 -PRESS	RHU-PT5501602	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131885	C
2,004	RHU -55 -PRESS	RHU-PT5501702	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131886	C
2,005	RHU -55 -PRESS	RHU-PT5501802	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131887	C
2,006	RHU -55 -PRESS	RHU-PT5501902	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131888	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,007	RHU -55 -PRESS	RHU-PT5502002	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131889	C
2,008	RHU -55 -PRESS	RHU-PT5502101	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131890	C
2,009	RHU -55 -PRESS	RHU-PT5502102	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131891	C
2,010	RHU -55 -PRESS	RHU-PT5502103	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131892	C
2,011	RHU -55 -PRESS	RHU-PT5502201	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131893	C
2,012	RHU -55 -PRESS	RHU-PT5502204	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y				I									RRC	RRC-IROH	131894	C
2,013	RHU -55 -PRESS	RHU-PT5502204	PT5502204-FULL FUN TEST PT & P	PMT	5Y											F		RRC	RRC-IROH	260504	C
2,014	RHU -55 -55P103	RHU-PT5502305A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131977	C
2,015	RHU -55 -55P103	RHU-PT5502305B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131978	C
2,016	RHU -55 -PRESS	RHU-PT5502311	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131895	C
2,017	RHU -55 -PRESS	RHU-PT5502501	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131896	C
2,018	RHU -55 -PRESS	RHU-PT5530101	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131897	C
2,019	RHU -55 -PRESS	RHU-PT5530102	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131898	C
2,020	RHU -55 -PRESS	RHU-PT5531101	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131899	C
2,021	RHU -55 -PRESS	RHU-PT5531103	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131900	C
2,022	RHU -55 -PRESS	RHU-PT5534101	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131901	C
2,023	RHU -52 -CV	RHU-PV5200101A	INSPECT CONTROL VALVE NO. PV52	PMT	1Y											I		RRC	RRC-IROH	132911	C
2,024	RHU -52 -CV	RHU-PV5200101B	INSPECT CONTROL VALVE NO. PV52	PMT	1Y											I		RRC	RRC-IROH	132912	C
2,025	RHU -52 -CV	RHU-PV5200303	INSPECT CONTROL VALVE NO. PV52	PMT	1Y											I		RRC	RRC-IROH	132978	C
2,026	RHU -52 -CV	RHU-PV5201402	INSPECT CONTROL VALVE NO. PV52	PMT	1Y											I		RRC	RRC-IROH	132913	C
2,027	RHU -52 -CV	RHU-PV5201501	INSPECT CONTROL VALVE NO. PV52	PMT	1Y											I		RRC	RRC-IROH	132914	C
2,028	RHU -52 -CV	RHU-PV5201502	INSPECT CONTROL VALVE NO. PV52	PMT	1Y											I		RRC	RRC-IROH	132915	C
2,029	RHU -52 -CV	RHU-PV5201701	INSPECT CONTROL VALVE NO. PV52	PMT	1Y											I		RRC	RRC-IROH	132916	C
2,030	RHU -52 -CV	RHU-PV5201702	INSPECT CONTROL VALVE NO. PV52	PMT	1Y											I		RRC	RRC-IROH	132917	C
2,031	RHU -52 -CV	RHU-PV5201901A	INSPECT CONTROL VALVE NO. PV52	PMT	1Y											I		RRC	RRC-IROH	132918	C
2,032	RHU -52 -CV	RHU-PV5201901B	INSPECT CONTROL VALVE NO. PV52	PMT	1Y											I		RRC	RRC-IROH	132919	C
2,033	RHU -52 -CV	RHU-PV5202601A	INSPECT CONTROL VALVE NO. PV52	PMT	1Y											I		RRC	RRC-IROH	132920	C
2,034	RHU -52 -CV	RHU-PV5202601B	INSPECT CONTROL VALVE NO. PV52	PMT	1Y											I		RRC	RRC-IROH	132921	C
2,035	RHU -52 -CV	RHU-PV5202701A	INSPECT CONTROL VALVE NO. PV52	PMT	1Y											I		RRC	RRC-IROH	132922	C
2,036	RHU -52 -CV	RHU-PV5202701B	INSPECT CONTROL VALVE NO. PV52	PMT	1Y											I		RRC	RRC-IROH	132923	C
2,037	RHU -52 -CV	RHU-PV5202901A	INSPECT CONTROL VALVE NO. PV52	PMT	1Y											I		RRC	RRC-IROH	132924	C
2,038	RHU -52 -CV	RHU-PV5202901B	INSPECT CONTROL VALVE NO. PV52	PMT	1Y											I		RRC	RRC-IROH	132925	C
2,039	RHU -52 -CV	RHU-PV5203201A	INSPECT CONTROL VALVE NO. PV52	PMT	1Y											I		RRC	RRC-IROH	132926	C
2,040	RHU -52 -CV	RHU-PV5203201B	INSPECT CONTROL VALVE NO. PV52	PMT	1Y											I		RRC	RRC-IROH	132927	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,041	RHU -52 -CV	RHU-PV5203301	INSPECT CONTROL VALVE NO. PV52	PMT	1Y											I		RRC	RRC-IROH	132928	C
2,042	RHU -52 -CV	RHU-PV5203907	INSPECT CONTROL VALVE NO. PV52	PMT	1Y											I		RRC	RRC-IROH	132981	C
2,043	RHU -52 -CV	RHU-PV5204211	INSPECT CONTROL VALVE NO. PV52	PMT	1Y											I		RRC	RRC-IROH	132929	C
2,044	RHU -52 -52P001A	RHU-PV5253201A	INSPECT CONTROL VALVE NO. PV52	PMT	1Y												I	RRC	RRC-IROH	133183	C
2,045	RHU -52 -52P001A	RHU-PV5253202A	INSPECT CONTROL VALVE NO. PV52	PMT	1Y												I	RRC	RRC-IROH	133181	C
2,046	RHU -52 -52P001B	RHU-PV5253701B	INSPECT CONTROL VALVE NO. PV52	PMT	1Y												I	RRC	RRC-IROH	133184	C
2,047	RHU -52 -52P001B	RHU-PV5253702B	INSPECT CONTROL VALVE NO. PV52	PMT	1Y												I	RRC	RRC-IROH	133182	C
2,048	RHU -55 -CV	RHU-PV5502201A	INSPECT CONTROL VALVE NO. PV55	PMT	1Y											I		RRC	RRC-IROH	132930	C
2,049	RHU -55 -CV	RHU-PV5502201B	INSPECT CONTROL VALVE NO. PV55	PMT	1Y											I		RRC	RRC-IROH	132931	C
2,050	RHU -55 -CV	RHU-PV5502602	INSPECT CONTROL VALVE NO. PV55	PMT	1Y											I		RRC	RRC-IROH	132932	C
2,051	RHU -55 -CV	RHU-PV5501008	INSPECT CONTROL VALVE NO. PV55	PMT	1Y											I		RRC	RRC-IROH	132933	C
2,052	RHU -55 -CV	RHU-PV5501101	INSPECT CONTROL VALVE NO. PV55	PMT	1Y											I		RRC	RRC-IROH	132944	C
2,053	RHU -55 -CV	RHU-PV5501301	INSPECT CONTROL VALVE NO. PV55	PMT	1Y											I		RRC	RRC-IROH	132945	C
2,054	RHU -55 -CV	RHU-PV5501303A	INSPECT CONTROL VALVE NO. PV55	PMT	1Y											I		RRC	RRC-IROH	132946	C
2,055	RHU -55 -CV	RHU-PV5501303B	INSPECT CONTROL VALVE NO. PV55	PMT	1Y											I		RRC	RRC-IROH	132947	C
2,056	RHU -55 -CV	RHU-PV5501401A	INSPECT CONTROL VALVE NO. PV55	PMT	1Y											I		RRC	RRC-IROH	132948	C
2,057	RHU -55 -CV	RHU-PV5501401B	INSPECT CONTROL VALVE NO. PV55	PMT	1Y											I		RRC	RRC-IROH	132949	C
2,058	RHU -55 -CV	RHU-PV5501508A	INSPECT CONTROL VALVE NO. PV55	PMT	1Y											I		RRC	RRC-IROH	132950	C
2,059	RHU -55 -CV	RHU-PV5501508B	INSPECT CONTROL VALVE NO. PV55	PMT	1Y											I		RRC	RRC-IROH	132951	C
2,060	RHU -55 -CV	RHU-PV5501601	INSPECT CONTROL VALVE NO. PV55	PMT	1Y											I		RRC	RRC-IROH	132952	C
2,061	RHU -55 -CV	RHU-PV5502101	INSPECT CONTROL VALVE NO. PV55	PMT	1Y											I		RRC	RRC-IROH	132982	C
2,062	RHU -55 -CV	RHU-PV5502102	INSPECT CONTROL VALVE NO. PV55	PMT	1Y											I		RRC	RRC-IROH	132953	C
2,063	RHU -55 -CV	RHU-PV5502201	INSPECT CONTROL VALVE NO. PV55	PMT	1Y											I		RRC	RRC-IROH	132954	C
2,064	RHU -52 -SIS	RHU-SIS	INSPECT ESD SYSTEM	PMT	3M	I			I			I			I			CCS	CCS-SYS	246432	A
2,065	RHU -52 -SIS	RHU-SIS	BACKUP ESD SYSTEM	PMT	6M	I						I						CCS	CCS-SYS	246433	A
2,066	RHU -52 -SIS	RHU-SIS	UPDATE ANTIVIRUS ESD SYSTEM	PMT	3M	U			U			U			U			CCS	CCS-SYS	246434	A
2,067	RHU -52 -52K002A	RHU-TCV5251234A	INSPECT CONTROL VALVE NO. TCV5	PMT	1Y												I	RRC	RRC-IROH	133176	C
2,068	RHU -52 -52K002B	RHU-TCV5251834B	INSPECT CONTROL VALVE NO. TCV5	PMT	1Y												I	RRC	RRC-IROH	133177	C
2,069	RHU -52 -52K101	RHU-TCV5252532	INSPECT CONTROL VALVE NO. TCV5	PMT	1Y												I	RRC	RRC-IROH	133180	C
2,070	RHU -52 -52P007	RHU-TCV5254501	INSPECT CONTROL VALVE NO. TCV5	PMT	1Y												I	RRC	RRC-IROH	133191	C
2,071	RHU -52 -52P007	RHU-TCV5254801	INSPECT CONTROL VALVE NO. TCV5	PMT	1Y												I	RRC	RRC-IROH	133192	C
2,072	RHU -55 -CV	RHU-TDV5202901A	INSPECT CONTROL VALVE NO. TDV5	PMT	1Y											I		RRC	RRC-IROH	132955	C
2,073	RHU -55 -CV	RHU-TDV5202901B	INSPECT CONTROL VALVE NO. TDV5	PMT	1Y											I		RRC	RRC-IROH	132956	C
2,074	RHU -52 -TEMP	RHU-TT5200101	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131980	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,075	RHU -52 -TEMP	RHU-TT5200102	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131981	C
2,076	RHU -52 -TEMP	RHU-TT5200201	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	131982	C
2,077	RHU -52 -TEMP	RHU-TT5200202	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	131983	C
2,078	RHU -52 -TEMP	RHU-TT5200203	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	131984	C
2,079	RHU -52 -TEMP	RHU-TT5200401A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	131985	C
2,080	RHU -52 -TEMP	RHU-TT5200401B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	131986	C
2,081	RHU -52 -TEMP	RHU-TT5200401C	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	131987	C
2,082	RHU -52 -TEMP	RHU-TT5200401D	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	131988	C
2,083	RHU -52 -TEMP	RHU-TT5200401E	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	131989	C
2,084	RHU -52 -TEMP	RHU-TT5200401F	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	131990	C
2,085	RHU -52 -TEMP	RHU-TT5200412	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	131991	C
2,086	RHU -52 -TEMP	RHU-TT5200413	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	131992	C
2,087	RHU -52 -TEMP	RHU-TT5200501A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	131993	C
2,088	RHU -52 -TEMP	RHU-TT5200501B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	131994	C
2,089	RHU -52 -TEMP	RHU-TT5200501C	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	131995	C
2,090	RHU -52 -TEMP	RHU-TT5200501D	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	131996	C
2,091	RHU -52 -TEMP	RHU-TT5200501E	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	131997	C
2,092	RHU -52 -TEMP	RHU-TT5200501F	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	131998	C
2,093	RHU -52 -TEMP	RHU-TT5200512	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	131999	C
2,094	RHU -52 -TEMP	RHU-TT5200513	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132000	C
2,095	RHU -52 -TEMP	RHU-TT5200601A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132001	C
2,096	RHU -52 -TEMP	RHU-TT5200601B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132002	C
2,097	RHU -52 -TEMP	RHU-TT5200601C	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132003	C
2,098	RHU -52 -TEMP	RHU-TT5200601D	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132004	C
2,099	RHU -52 -TEMP	RHU-TT5200601E	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132005	C
2,100	RHU -52 -TEMP	RHU-TT5200601F	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132006	C
2,101	RHU -52 -TEMP	RHU-TT5200606A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132007	C
2,102	RHU -52 -TEMP	RHU-TT5200606B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132008	C
2,103	RHU -52 -TEMP	RHU-TT5200606C	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132009	C
2,104	RHU -52 -TEMP	RHU-TT5200606D	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132010	C
2,105	RHU -52 -TEMP	RHU-TT5200606E	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132011	C
2,106	RHU -52 -TEMP	RHU-TT5200606F	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132012	C
2,107	RHU -52 -TEMP	RHU-TT5200616	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132013	C
2,108	RHU -52 -TEMP	RHU-TT5200622	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132014	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,109	RHU -52 -TEMP	RHU-TT5200701A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132015	C
2,110	RHU -52 -TEMP	RHU-TT5200701B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132016	C
2,111	RHU -52 -TEMP	RHU-TT5200701C	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132017	C
2,112	RHU -52 -TEMP	RHU-TT5200701D	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132018	C
2,113	RHU -52 -TEMP	RHU-TT5200701E	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132019	C
2,114	RHU -52 -TEMP	RHU-TT5200701F	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132020	C
2,115	RHU -52 -TEMP	RHU-TT5200706A	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132021	C
2,116	RHU -52 -TEMP	RHU-TT5200706B	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132022	C
2,117	RHU -52 -TEMP	RHU-TT5200706C	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132023	C
2,118	RHU -52 -TEMP	RHU-TT5200706D	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132024	C
2,119	RHU -52 -TEMP	RHU-TT5200706E	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132025	C
2,120	RHU -52 -TEMP	RHU-TT5200706F	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132026	C
2,121	RHU -52 -TEMP	RHU-TT5200716	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132027	C
2,122	RHU -52 -TEMP	RHU-TT5200722	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132028	C
2,123	RHU -52 -TEMP	RHU-TT5200801	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132029	C
2,124	RHU -52 -TEMP	RHU-TT5200901	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132030	C
2,125	RHU -52 -TEMP	RHU-TT5200902	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132031	C
2,126	RHU -52 -TEMP	RHU-TT5200903	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132032	C
2,127	RHU -52 -TEMP	RHU-TT5200904	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132033	C
2,128	RHU -52 -TEMP	RHU-TT5200905	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132034	C
2,129	RHU -52 -TEMP	RHU-TT5200906	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132035	C
2,130	RHU -52 -TEMP	RHU-TT5201001	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132036	C
2,131	RHU -52 -TEMP	RHU-TT5201003	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132037	C
2,132	RHU -52 -TEMP	RHU-TT5201004	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132038	C
2,133	RHU -52 -TEMP	RHU-TT5201004A2	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132039	C
2,134	RHU -52 -TEMP	RHU-TT5201004B2	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132040	C
2,135	RHU -52 -TEMP	RHU-TT5201004C2	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132041	C
2,136	RHU -52 -TEMP	RHU-TT5201004D2	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132042	C
2,137	RHU -52 -TEMP	RHU-TT5201101	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132043	C
2,138	RHU -52 -TEMP	RHU-TT5201103	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132044	C
2,139	RHU -52 -TEMP	RHU-TT5201104	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132045	C
2,140	RHU -52 -TEMP	RHU-TT5201105	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132046	C
2,141	RHU -52 -TEMP	RHU-TT5201201	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132047	C
2,142	RHU -52 -TEMP	RHU-TT5201202	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y				I									RRC	RRC-IROH	132048	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,143	RHU -52 -52K001	RHU-TT5201301	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y										I			RRC	RRC-IROH	132794	C
2,144	RHU -52 -52K001	RHU-TT5201302	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y										I			RRC	RRC-IROH	132795	C
2,145	RHU -52 -TEMP	RHU-TT5201303A	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y					I								RRC	RRC-IROH	132049	C
2,146	RHU -52 -TEMP	RHU-TT5201303A	TT5201303A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261249	C
2,147	RHU -52 -TEMP	RHU-TT5201303B	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y					I								RRC	RRC-IROH	132050	C
2,148	RHU -52 -TEMP	RHU-TT5201303B	TT5201303B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261250	C
2,149	RHU -52 -TEMP	RHU-TT5201303C	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y					I								RRC	RRC-IROH	132051	C
2,150	RHU -52 -TEMP	RHU-TT5201303C	TT5201303C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261251	C
2,151	RHU -52 -TEMP	RHU-TT5201304	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132052	C
2,152	RHU -52 -TEMP	RHU-TT5201401	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132053	C
2,153	RHU -52 -TEMP	RHU-TT5201501	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132054	C
2,154	RHU -52 -TEMP	RHU-TT5201502	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132055	C
2,155	RHU -52 -TEMP	RHU-TT5201503	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132056	C
2,156	RHU -52 -TEMP	RHU-TT5201601A	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y					I								RRC	RRC-IROH	132057	C
2,157	RHU -52 -TEMP	RHU-TT5201601A	TT5201601A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261252	C
2,158	RHU -52 -TEMP	RHU-TT5201601B	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y					I								RRC	RRC-IROH	132058	C
2,159	RHU -52 -TEMP	RHU-TT5201601B	TT5201601B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261253	C
2,160	RHU -52 -TEMP	RHU-TT5201601C	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y					I								RRC	RRC-IROH	132059	C
2,161	RHU -52 -TEMP	RHU-TT5201601C	TT5201601C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261254	C
2,162	RHU -52 -TEMP	RHU-TT5201602A	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y					I								RRC	RRC-IROH	132060	C
2,163	RHU -52 -TEMP	RHU-TT5201602A	TT5201602A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261258	C
2,164	RHU -52 -TEMP	RHU-TT5201602B	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y					I								RRC	RRC-IROH	132061	C
2,165	RHU -52 -TEMP	RHU-TT5201602B	TT5201602B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261259	C
2,166	RHU -52 -TEMP	RHU-TT5201602C	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y					I								RRC	RRC-IROH	132062	C
2,167	RHU -52 -TEMP	RHU-TT5201602C	TT5201602C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261260	C
2,168	RHU -52 -TEMP	RHU-TT5201603	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132063	C
2,169	RHU -52 -TEMP	RHU-TT5201701	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132064	C
2,170	RHU -52 -TEMP	RHU-TT5201702	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132065	C
2,171	RHU -52 -TEMP	RHU-TT5201703	INSP. FIELD INST. (ต่อทุปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132066	C
2,172	RHU -52 -TEMP	RHU-TT5201801A	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y					I								RRC	RRC-IROH	132067	C
2,173	RHU -52 -TEMP	RHU-TT5201801A	TT5201801A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261255	C
2,174	RHU -52 -TEMP	RHU-TT5201801B	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y					I								RRC	RRC-IROH	132068	C
2,175	RHU -52 -TEMP	RHU-TT5201801B	TT5201801B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261256	C
2,176	RHU -52 -TEMP	RHU-TT5201801C	INSP. FIELD INST. (ต่อทุปกรณ์)	INS	1Y					I								RRC	RRC-IROH	132069	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,177	RHU -52 -TEMP	RHU-TT5201801C	TT5201801C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261257	C
2,178	RHU -52 -TEMP	RHU-TT5201802A	INSP. FIELD INST. (ตัดฐปกรณ์)	INS	1Y					I								RRC	RRC-IROH	132070	C
2,179	RHU -52 -TEMP	RHU-TT5201802A	TT5201802A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261261	C
2,180	RHU -52 -TEMP	RHU-TT5201802B	INSP. FIELD INST. (ตัดฐปกรณ์)	INS	1Y					I								RRC	RRC-IROH	132071	C
2,181	RHU -52 -TEMP	RHU-TT5201802B	TT5201802B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261262	C
2,182	RHU -52 -TEMP	RHU-TT5201802C	INSP. FIELD INST. (ตัดฐปกรณ์)	INS	1Y					I								RRC	RRC-IROH	132072	C
2,183	RHU -52 -TEMP	RHU-TT5201802C	TT5201802C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261263	C
2,184	RHU -52 -TEMP	RHU-TT5201901	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132073	C
2,185	RHU -52 -TEMP	RHU-TT5201902	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132074	C
2,186	RHU -52 -TEMP	RHU-TT5201903	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132075	C
2,187	RHU -52 -TEMP	RHU-TT5201904	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132076	C
2,188	RHU -52 -TEMP	RHU-TT5202002	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132077	C
2,189	RHU -52 -TEMP	RHU-TT5202003	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132078	C
2,190	RHU -52 -TEMP	RHU-TT5202004	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132079	C
2,191	RHU -52 -TEMP	RHU-TT5202005A3	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132080	C
2,192	RHU -52 -TEMP	RHU-TT5202005A4	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132081	C
2,193	RHU -52 -TEMP	RHU-TT5202101	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132082	C
2,194	RHU -52 -TEMP	RHU-TT5202102	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132083	C
2,195	RHU -52 -TEMP	RHU-TT5202103	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132084	C
2,196	RHU -52 -TEMP	RHU-TT5202302	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132085	C
2,197	RHU -52 -TEMP	RHU-TT5202303	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132086	C
2,198	RHU -52 -TEMP	RHU-TT5202304	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132087	C
2,199	RHU -52 -TEMP	RHU-TT5202305	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132088	C
2,200	RHU -52 -TEMP	RHU-TT5202401	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132089	C
2,201	RHU -52 -TEMP	RHU-TT5202402	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132090	C
2,202	RHU -52 -TEMP	RHU-TT5202403	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132091	C
2,203	RHU -52 -52P005	RHU-TT5202404A	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y										I			RRC	RRC-IROH	132813	C
2,204	RHU -52 -52P005	RHU-TT5202404B	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y										I			RRC	RRC-IROH	132814	C
2,205	RHU -52 -TEMP	RHU-TT5202501	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132092	C
2,206	RHU -52 -TEMP	RHU-TT5202502	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132093	C
2,207	RHU -52 -TEMP	RHU-TT5202503	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132094	C
2,208	RHU -52 -TEMP	RHU-TT5202504	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132095	C
2,209	RHU -52 -TEMP	RHU-TT5202505	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132096	C
2,210	RHU -52 -TEMP	RHU-TT5202506	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132097	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,211	RHU -52 -TEMP	RHU-TT5202507	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132098	C
2,212	RHU -52 -TEMP	RHU-TT5202508	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132099	C
2,213	RHU -52 -TEMP	RHU-TT5202602	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132100	C
2,214	RHU -52 -TEMP	RHU-TT5202603	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132101	C
2,215	RHU -52 -TEMP	RHU-TT5202702	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132102	C
2,216	RHU -52 -TEMP	RHU-TT5202703	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132103	C
2,217	RHU -52 -TEMP	RHU-TT5202704	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132104	C
2,218	RHU -52 -TEMP	RHU-TT5202705	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132105	C
2,219	RHU -52 -TEMP	RHU-TT5202801	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132106	C
2,220	RHU -52 -TEMP	RHU-TT5202802	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132107	C
2,221	RHU -52 -TEMP	RHU-TT5202803	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132108	C
2,222	RHU -52 -TEMP	RHU-TT5202901	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132109	C
2,223	RHU -52 -TEMP	RHU-TT5202902	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132110	C
2,224	RHU -52 -TEMP	RHU-TT5202903	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132111	C
2,225	RHU -52 -TEMP	RHU-TT5202904	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132112	C
2,226	RHU -52 -TEMP	RHU-TT5202905	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132113	C
2,227	RHU -52 -TEMP	RHU-TT5202906	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132114	C
2,228	RHU -52 -TEMP	RHU-TT5203001	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132115	C
2,229	RHU -52 -TEMP	RHU-TT5203101	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132116	C
2,230	RHU -52 -TEMP	RHU-TT5203102	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132117	C
2,231	RHU -52 -TEMP	RHU-TT5203103	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132118	C
2,232	RHU -52 -TEMP	RHU-TT5203201	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132119	C
2,233	RHU -52 -TEMP	RHU-TT5203202	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132120	C
2,234	RHU -52 -TEMP	RHU-TT5203203	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132121	C
2,235	RHU -52 -TEMP	RHU-TT5203204	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132122	C
2,236	RHU -52 -TEMP	RHU-TT5203205	INSP. FIELD INST. (ตัดฐปกรณ์)	INS	1Y					I								RRC	RRC-IROH	132123	C
2,237	RHU -52 -TEMP	RHU-TT5203205	TT5203205-FULLFUN TEST TEMP.TR	PMT	5Y												F	RRC	RRC-IROH	261264	C
2,238	RHU -52 -TEMP	RHU-TT5203301	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132124	C
2,239	RHU -52 -TEMP	RHU-TT5203302	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132125	C
2,240	RHU -52 -TEMP	RHU-TT5203302A3	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132126	C
2,241	RHU -52 -TEMP	RHU-TT5203302A4	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132127	C
2,242	RHU -52 -TEMP	RHU-TT5203303	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132128	C
2,243	RHU -52 -TEMP	RHU-TT5203304	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132129	C
2,244	RHU -52 -TEMP	RHU-TT5203306	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132130	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,245	RHU -52 -TEMP	RHU-TT5203307	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132131	C
2,246	RHU -52 -TEMP	RHU-TT5203401	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132132	C
2,247	RHU -52 -TEMP	RHU-TT5203501	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132133	C
2,248	RHU -52 -TEMP	RHU-TT5203502A	INSP. FIELD INST. (ตัดฐปกรณ์)	INS	1Y					I								RRC	RRC-IROH	132134	C
2,249	RHU -52 -TEMP	RHU-TT5203502A	TT5203502A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261265	C
2,250	RHU -52 -TEMP	RHU-TT5203502B	INSP. FIELD INST. (ตัดฐปกรณ์)	INS	1Y					I								RRC	RRC-IROH	132135	C
2,251	RHU -52 -TEMP	RHU-TT5203502B	TT5203502B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261266	C
2,252	RHU -52 -TEMP	RHU-TT5203502C	INSP. FIELD INST. (ตัดฐปกรณ์)	INS	1Y					I								RRC	RRC-IROH	132136	C
2,253	RHU -52 -TEMP	RHU-TT5203502C	TT5203502C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261267	C
2,254	RHU -52 -TEMP	RHU-TT5203503A	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132137	C
2,255	RHU -52 -TEMP	RHU-TT5203503B	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132138	C
2,256	RHU -52 -TEMP	RHU-TT5203503C	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132139	C
2,257	RHU -52 -52P103	RHU-TT5203601	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y										I			RRC	RRC-IROH	132817	C
2,258	RHU -52 -TEMP	RHU-TT5203801	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132140	C
2,259	RHU -52 -TEMP	RHU-TT5203802	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y					I								RRC	RRC-IROH	132141	C
2,260	RHU -52 -TEMP	RHU-TT5203803	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132142	C
2,261	RHU -52 -TEMP	RHU-TT5203804	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132143	C
2,262	RHU -52 -TEMP	RHU-TT5203817	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132144	C
2,263	RHU -52 -TEMP	RHU-TT5203818	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132145	C
2,264	RHU -52 -TEMP	RHU-TT5203819	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132146	C
2,265	RHU -52 -TEMP	RHU-TT5203820	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132147	C
2,266	RHU -52 -TEMP	RHU-TT5203821	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132148	C
2,267	RHU -52 -TEMP	RHU-TT5203822A	INSP. FIELD INST. (ตัดฐปกรณ์)	INS	1Y						I							RRC	RRC-IROH	132149	C
2,268	RHU -52 -TEMP	RHU-TT5203822A	TT5203822A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261246	C
2,269	RHU -52 -TEMP	RHU-TT5203822B	INSP. FIELD INST. (ตัดฐปกรณ์)	INS	1Y						I							RRC	RRC-IROH	132150	C
2,270	RHU -52 -TEMP	RHU-TT5203822B	TT5203822B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261247	C
2,271	RHU -52 -TEMP	RHU-TT5203822C	INSP. FIELD INST. (ตัดฐปกรณ์)	INS	1Y						I							RRC	RRC-IROH	132151	C
2,272	RHU -52 -TEMP	RHU-TT5203822C	TT5203822C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261248	C
2,273	RHU -52 -TEMP	RHU-TT5203901A	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132152	C
2,274	RHU -52 -TEMP	RHU-TT5203901B	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132153	C
2,275	RHU -52 -TEMP	RHU-TT5203901C	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132154	C
2,276	RHU -52 -TEMP	RHU-TT5203903	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132155	C
2,277	RHU -52 -TEMP	RHU-TT5203904	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132156	C
2,278	RHU -52 -TEMP	RHU-TT5203905	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132157	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,279	RHU -52 -TEMP	RHU-TT5204101	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132158	C
2,280	RHU -52 -TEMP	RHU-TT5204102	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132159	C
2,281	RHU -52 -TEMP	RHU-TT5204103	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132160	C
2,282	RHU -52 -TEMP	RHU-TT5204104	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132161	C
2,283	RHU -52 -TEMP	RHU-TT5204117	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132162	C
2,284	RHU -52 -TEMP	RHU-TT5204118	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132163	C
2,285	RHU -52 -TEMP	RHU-TT5204119	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132164	C
2,286	RHU -52 -TEMP	RHU-TT5204120	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132165	C
2,287	RHU -52 -TEMP	RHU-TT5204121	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132166	C
2,288	RHU -52 -TEMP	RHU-TT5204122	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132167	C
2,289	RHU -52 -TEMP	RHU-TT5204123A	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132168	C
2,290	RHU -52 -TEMP	RHU-TT5204123B	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132169	C
2,291	RHU -52 -TEMP	RHU-TT5204123C	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132170	C
2,292	RHU -52 -TEMP	RHU-TT5204207	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132171	C
2,293	RHU -52 -TEMP	RHU-TT5204301A	INSP. FIELD INST. (ตัดฐปกรณ์)	INS	1Y						I							RRC	RRC-IROH	132172	C
2,294	RHU -52 -TEMP	RHU-TT5204301A	TT5204301A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261268	C
2,295	RHU -52 -TEMP	RHU-TT5204301B	INSP. FIELD INST. (ตัดฐปกรณ์)	INS	1Y						I							RRC	RRC-IROH	132173	C
2,296	RHU -52 -TEMP	RHU-TT5204301B	TT5204301B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261269	C
2,297	RHU -52 -TEMP	RHU-TT5204301C	INSP. FIELD INST. (ตัดฐปกรณ์)	INS	1Y						I							RRC	RRC-IROH	132174	C
2,298	RHU -52 -TEMP	RHU-TT5204301C	TT5204301C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261270	C
2,299	RHU -52 -TEMP	RHU-TT5204303	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132175	C
2,300	RHU -52 -TEMP	RHU-TT5204304	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132176	C
2,301	RHU -52 -TEMP	RHU-TT5204305	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132177	C
2,302	RHU -52 -TEMP	RHU-TT5230101	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132178	C
2,303	RHU -52 -TEMP	RHU-TT5230102	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132179	C
2,304	RHU -52 -TEMP	RHU-TT5231101	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132180	C
2,305	RHU -52 -TEMP	RHU-TT5231102	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132181	C
2,306	RHU -52 -TEMP	RHU-TT5234101	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y						I							RRC	RRC-IROH	132182	C
2,307	RHU -52 -52K001	RHU-TT5250501	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y										I			RRC	RRC-IROH	132796	C
2,308	RHU -52 -52K001	RHU-TT5250502	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y										I			RRC	RRC-IROH	132797	C
2,309	RHU -52 -52K001	RHU-TT5250706	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y										I			RRC	RRC-IROH	132798	C
2,310	RHU -52 -52P001A	RHU-TT5253201A	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y										I			RRC	RRC-IROH	132809	C
2,311	RHU -52 -52P001A	RHU-TT5253204A	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y										I			RRC	RRC-IROH	132811	C
2,312	RHU -52 -52P001A	RHU-TT5253301A	INSP. FIELD INST. (ตัดฐปกรณ์)	PMT	1Y										I			RRC	RRC-IROH	132803	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,313	RHU -52 -52P001A	RHU-TT5253302A	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y										I			RRC	RRC-IROH	132804	C
2,314	RHU -52 -52P001A	RHU-TT5253303A	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y										I			RRC	RRC-IROH	132801	C
2,315	RHU -52 -52P001A	RHU-TT5253304A	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y										I			RRC	RRC-IROH	132802	C
2,316	RHU -52 -52P001B	RHU-TT5253701B	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y										I			RRC	RRC-IROH	132810	C
2,317	RHU -52 -52P001B	RHU-TT5253704B	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y										I			RRC	RRC-IROH	132812	C
2,318	RHU -52 -52P001B	RHU-TT5253801B	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y										I			RRC	RRC-IROH	132806	C
2,319	RHU -52 -52P001B	RHU-TT5253802B	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y										I			RRC	RRC-IROH	132808	C
2,320	RHU -52 -52P001B	RHU-TT5253803B	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y										I			RRC	RRC-IROH	132805	C
2,321	RHU -52 -52P001B	RHU-TT5253804B	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y										I			RRC	RRC-IROH	132807	C
2,322	RHU -52 -52P003A	RHU-TT5255101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y										I			RRC	RRC-IROH	132799	C
2,323	RHU -52 -52P003B	RHU-TT5255201	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y										I			RRC	RRC-IROH	132800	C
2,324	RHU -52 -TEMP	RHU-TT5284301	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	132183	C
2,325	RHU -55 -TEMP	RHU-TT5500101	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	132184	C
2,326	RHU -55 -TEMP	RHU-TT5500102	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	132185	C
2,327	RHU -55 -TEMP	RHU-TT5500103	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	132186	C
2,328	RHU -55 -TEMP	RHU-TT5500104	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	132187	C
2,329	RHU -55 -TEMP	RHU-TT5500105	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	132188	C
2,330	RHU -55 -TEMP	RHU-TT5500301	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	132189	C
2,331	RHU -55 -TEMP	RHU-TT5500302	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	132190	C
2,332	RHU -55 -TEMP	RHU-TT5500401	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	132191	C
2,333	RHU -55 -TEMP	RHU-TT5500501	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	132192	C
2,334	RHU -55 -TEMP	RHU-TT5500502	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y						I							RRC	RRC-IROH	132193	C
2,335	RHU -55 -TEMP	RHU-TT5500601A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132194	C
2,336	RHU -55 -TEMP	RHU-TT5500601A	TT5500601A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260705	C
2,337	RHU -55 -TEMP	RHU-TT5500601B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132195	C
2,338	RHU -55 -TEMP	RHU-TT5500601B	TT5500601B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260706	C
2,339	RHU -55 -TEMP	RHU-TT5500601C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132196	C
2,340	RHU -55 -TEMP	RHU-TT5500601C	TT5500601C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260707	C
2,341	RHU -55 -TEMP	RHU-TT5500602A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132197	C
2,342	RHU -55 -TEMP	RHU-TT5500602A	TT5500602A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260708	C
2,343	RHU -55 -TEMP	RHU-TT5500602B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132198	C
2,344	RHU -55 -TEMP	RHU-TT5500602B	TT5500602B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260709	C
2,345	RHU -55 -TEMP	RHU-TT5500602C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132199	C
2,346	RHU -55 -TEMP	RHU-TT5500602C	TT5500602C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260710	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,347	RHU -55 -TEMP	RHU-TT5500603A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132200	C
2,348	RHU -55 -TEMP	RHU-TT5500603A	TT5500603A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260711	C
2,349	RHU -55 -TEMP	RHU-TT5500603B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132201	C
2,350	RHU -55 -TEMP	RHU-TT5500603B	TT5500603B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260712	C
2,351	RHU -55 -TEMP	RHU-TT5500603C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132202	C
2,352	RHU -55 -TEMP	RHU-TT5500603C	TT5500603C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260713	C
2,353	RHU -55 -TEMP	RHU-TT5500604A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132203	C
2,354	RHU -55 -TEMP	RHU-TT5500604A	TT5500604A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260714	C
2,355	RHU -55 -TEMP	RHU-TT5500604B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132204	C
2,356	RHU -55 -TEMP	RHU-TT5500604B	TT5500604B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260715	C
2,357	RHU -55 -TEMP	RHU-TT5500604C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132205	C
2,358	RHU -55 -TEMP	RHU-TT5500604C	TT5500604C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260716	C
2,359	RHU -55 -TEMP	RHU-TT5500605A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132206	C
2,360	RHU -55 -TEMP	RHU-TT5500605A	TT5500605A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260717	C
2,361	RHU -55 -TEMP	RHU-TT5500605B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132207	C
2,362	RHU -55 -TEMP	RHU-TT5500605B	TT5500605B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260718	C
2,363	RHU -55 -TEMP	RHU-TT5500605C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132208	C
2,364	RHU -55 -TEMP	RHU-TT5500605C	TT5500605C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260719	C
2,365	RHU -55 -TEMP	RHU-TT5500606A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132209	C
2,366	RHU -55 -TEMP	RHU-TT5500606A	TT5500606A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260720	C
2,367	RHU -55 -TEMP	RHU-TT5500606B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132210	C
2,368	RHU -55 -TEMP	RHU-TT5500606B	TT5500606B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260721	C
2,369	RHU -55 -TEMP	RHU-TT5500606C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132211	C
2,370	RHU -55 -TEMP	RHU-TT5500606C	TT5500606C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260722	C
2,371	RHU -55 -TEMP	RHU-TT5500607A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132212	C
2,372	RHU -55 -TEMP	RHU-TT5500607A	TT5500607A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260723	C
2,373	RHU -55 -TEMP	RHU-TT5500607B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132213	C
2,374	RHU -55 -TEMP	RHU-TT5500607B	TT5500607B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260724	C
2,375	RHU -55 -TEMP	RHU-TT5500607C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132214	C
2,376	RHU -55 -TEMP	RHU-TT5500607C	TT5500607C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260725	C
2,377	RHU -55 -TEMP	RHU-TT5500608A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132215	C
2,378	RHU -55 -TEMP	RHU-TT5500608A	TT5500608A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260726	C
2,379	RHU -55 -TEMP	RHU-TT5500608B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132216	C
2,380	RHU -55 -TEMP	RHU-TT5500608B	TT5500608B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260727	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,381	RHU -55 -TEMP	RHU-TT5500608C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132217	C
2,382	RHU -55 -TEMP	RHU-TT5500608C	TT5500608C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260728	C
2,383	RHU -55 -TEMP	RHU-TT5500609A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132218	C
2,384	RHU -55 -TEMP	RHU-TT5500609A	TT5500609A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260729	C
2,385	RHU -55 -TEMP	RHU-TT5500609B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132219	C
2,386	RHU -55 -TEMP	RHU-TT5500609B	TT5500609B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260730	C
2,387	RHU -55 -TEMP	RHU-TT5500609C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132220	C
2,388	RHU -55 -TEMP	RHU-TT5500609C	TT5500609C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260731	C
2,389	RHU -55 -TEMP	RHU-TT5500610A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132221	C
2,390	RHU -55 -TEMP	RHU-TT5500610A	TT5500610A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260732	C
2,391	RHU -55 -TEMP	RHU-TT5500610B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132222	C
2,392	RHU -55 -TEMP	RHU-TT5500610B	TT5500610B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260733	C
2,393	RHU -55 -TEMP	RHU-TT5500610C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132223	C
2,394	RHU -55 -TEMP	RHU-TT5500610C	TT5500610C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260734	C
2,395	RHU -55 -TEMP	RHU-TT5500611A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132224	C
2,396	RHU -55 -TEMP	RHU-TT5500611A	TT5500611A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260735	C
2,397	RHU -55 -TEMP	RHU-TT5500611B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132225	C
2,398	RHU -55 -TEMP	RHU-TT5500611B	TT5500611B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260736	C
2,399	RHU -55 -TEMP	RHU-TT5500611C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132226	C
2,400	RHU -55 -TEMP	RHU-TT5500611C	TT5500611C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260737	C
2,401	RHU -55 -TEMP	RHU-TT5500612A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132227	C
2,402	RHU -55 -TEMP	RHU-TT5500612A	TT5500612A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260738	C
2,403	RHU -55 -TEMP	RHU-TT5500612B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132228	C
2,404	RHU -55 -TEMP	RHU-TT5500612B	TT5500612B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260739	C
2,405	RHU -55 -TEMP	RHU-TT5500612C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132229	C
2,406	RHU -55 -TEMP	RHU-TT5500612C	TT5500612C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260740	C
2,407	RHU -55 -TEMP	RHU-TT5500613A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132230	C
2,408	RHU -55 -TEMP	RHU-TT5500613A	TT5500613A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260741	C
2,409	RHU -55 -TEMP	RHU-TT5500613B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132231	C
2,410	RHU -55 -TEMP	RHU-TT5500613B	TT5500613B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260742	C
2,411	RHU -55 -TEMP	RHU-TT5500613C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132232	C
2,412	RHU -55 -TEMP	RHU-TT5500613C	TT5500613C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260743	C
2,413	RHU -55 -TEMP	RHU-TT5500614A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y						I							RRC	RRC-IROH	132233	C
2,414	RHU -55 -TEMP	RHU-TT5500614A	TT5500614A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260744	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,415	RHU -55 -TEMP	RHU-TT5500614B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132234	C
2,416	RHU -55 -TEMP	RHU-TT5500614B	TT5500614B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260745	C
2,417	RHU -55 -TEMP	RHU-TT5500614C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132235	C
2,418	RHU -55 -TEMP	RHU-TT5500614C	TT5500614C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260746	C
2,419	RHU -55 -TEMP	RHU-TT5500615A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132236	C
2,420	RHU -55 -TEMP	RHU-TT5500615A	TT5500615A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260747	C
2,421	RHU -55 -TEMP	RHU-TT5500615B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132237	C
2,422	RHU -55 -TEMP	RHU-TT5500615B	TT5500615B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260748	C
2,423	RHU -55 -TEMP	RHU-TT5500615C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132238	C
2,424	RHU -55 -TEMP	RHU-TT5500615C	TT5500615C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260749	C
2,425	RHU -55 -TEMP	RHU-TT5500616A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132239	C
2,426	RHU -55 -TEMP	RHU-TT5500616A	TT5500616A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260750	C
2,427	RHU -55 -TEMP	RHU-TT5500616B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132240	C
2,428	RHU -55 -TEMP	RHU-TT5500616B	TT5500616B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260751	C
2,429	RHU -55 -TEMP	RHU-TT5500616C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132241	C
2,430	RHU -55 -TEMP	RHU-TT5500616C	TT5500616C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260752	C
2,431	RHU -55 -TEMP	RHU-TT5500617A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132242	C
2,432	RHU -55 -TEMP	RHU-TT5500617A	TT5500617A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260753	C
2,433	RHU -55 -TEMP	RHU-TT5500617B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132243	C
2,434	RHU -55 -TEMP	RHU-TT5500617B	TT5500617B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260754	C
2,435	RHU -55 -TEMP	RHU-TT5500617C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132244	C
2,436	RHU -55 -TEMP	RHU-TT5500617C	TT5500617C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260755	C
2,437	RHU -55 -TEMP	RHU-TT5500618A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132245	C
2,438	RHU -55 -TEMP	RHU-TT5500618A	TT5500618A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260756	C
2,439	RHU -55 -TEMP	RHU-TT5500618B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132246	C
2,440	RHU -55 -TEMP	RHU-TT5500618B	TT5500618B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260757	C
2,441	RHU -55 -TEMP	RHU-TT5500618C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132247	C
2,442	RHU -55 -TEMP	RHU-TT5500618C	TT5500618C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260758	C
2,443	RHU -55 -TEMP	RHU-TT5500619A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132248	C
2,444	RHU -55 -TEMP	RHU-TT5500619A	TT5500619A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260759	C
2,445	RHU -55 -TEMP	RHU-TT5500619B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132249	C
2,446	RHU -55 -TEMP	RHU-TT5500619B	TT5500619B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260760	C
2,447	RHU -55 -TEMP	RHU-TT5500619C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132250	C
2,448	RHU -55 -TEMP	RHU-TT5500619C	TT5500619C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260761	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,449	RHU -55 -TEMP	RHU-TT5500620	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132251	C
2,450	RHU -55 -TEMP	RHU-TT5500701	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132252	C
2,451	RHU -55 -TEMP	RHU-TT5500702	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132253	C
2,452	RHU -55 -TEMP	RHU-TT5500801	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132254	C
2,453	RHU -55 -TEMP	RHU-TT5500802	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132255	C
2,454	RHU -55 -TEMP	RHU-TT5500901	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132256	C
2,455	RHU -55 -TEMP	RHU-TT5500902	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132257	C
2,456	RHU -55 -TEMP	RHU-TT5501001	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132258	C
2,457	RHU -55 -TEMP	RHU-TT5501002	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132259	C
2,458	RHU -55 -TEMP	RHU-TT5501101	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132260	C
2,459	RHU -55 -TEMP	RHU-TT5501102	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132261	C
2,460	RHU -55 -TEMP	RHU-TT5501103	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132262	C
2,461	RHU -55 -TEMP	RHU-TT5501104	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y						I							RRC	RRC-IROH	132263	C
2,462	RHU -55 -TEMP	RHU-TT5501104	TT5501104-FULLFUN TEST TEMP.TR	PMT	5Y											F		RRC	RRC-IROH	260762	C
2,463	RHU -55 -TEMP	RHU-TT5501201	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132264	C
2,464	RHU -55 -TEMP	RHU-TT5501202	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132265	C
2,465	RHU -55 -TEMP	RHU-TT5501203	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132266	C
2,466	RHU -55 -TEMP	RHU-TT5501204	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132267	C
2,467	RHU -55 -TEMP	RHU-TT5501301	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132268	C
2,468	RHU -55 -TEMP	RHU-TT5501302	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132269	C
2,469	RHU -55 -TEMP	RHU-TT5501401	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132270	C
2,470	RHU -55 -TEMP	RHU-TT5501601	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132271	C
2,471	RHU -55 -TEMP	RHU-TT5501602	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132272	C
2,472	RHU -55 -TEMP	RHU-TT5501604	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132273	C
2,473	RHU -55 -TEMP	RHU-TT5501605	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132274	C
2,474	RHU -55 -TEMP	RHU-TT5501606	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132275	C
2,475	RHU -55 -TEMP	RHU-TT5501607	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132276	C
2,476	RHU -55 -TEMP	RHU-TT5501608	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132277	C
2,477	RHU -55 -TEMP	RHU-TT5501609	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y						I							RRC	RRC-IROH	132278	C
2,478	RHU -55 -TEMP	RHU-TT5501701A	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y						I							RRC	RRC-IROH	132279	C
2,479	RHU -55 -TEMP	RHU-TT5501701A	TT5501701A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261006	C
2,480	RHU -55 -TEMP	RHU-TT5501701B	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y						I							RRC	RRC-IROH	132280	C
2,481	RHU -55 -TEMP	RHU-TT5501701B	TT5501701B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261007	C
2,482	RHU -55 -TEMP	RHU-TT5501701C	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y						I							RRC	RRC-IROH	132281	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,483	RHU -55 -TEMP	RHU-TT5501701C	TT5501701C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261008	C
2,484	RHU -55 -TEMP	RHU-TT5501701D	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132282	C
2,485	RHU -55 -TEMP	RHU-TT5501701D	TT5501701D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261009	C
2,486	RHU -55 -TEMP	RHU-TT5501701E	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132283	C
2,487	RHU -55 -TEMP	RHU-TT5501701E	TT5501701E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261010	C
2,488	RHU -55 -TEMP	RHU-TT5501701F	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132284	C
2,489	RHU -55 -TEMP	RHU-TT5501701F	TT5501701F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261011	C
2,490	RHU -55 -TEMP	RHU-TT5501702A	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132285	C
2,491	RHU -55 -TEMP	RHU-TT5501702A	TT5501702A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261012	C
2,492	RHU -55 -TEMP	RHU-TT5501702B	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132286	C
2,493	RHU -55 -TEMP	RHU-TT5501702B	TT5501702B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261013	C
2,494	RHU -55 -TEMP	RHU-TT5501702C	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132287	C
2,495	RHU -55 -TEMP	RHU-TT5501702C	TT5501702C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261014	C
2,496	RHU -55 -TEMP	RHU-TT5501702D	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132288	C
2,497	RHU -55 -TEMP	RHU-TT5501702D	TT5501702D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261015	C
2,498	RHU -55 -TEMP	RHU-TT5501702E	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132289	C
2,499	RHU -55 -TEMP	RHU-TT5501702E	TT5501702E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261016	C
2,500	RHU -55 -TEMP	RHU-TT5501702F	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132290	C
2,501	RHU -55 -TEMP	RHU-TT5501702F	TT5501702F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261017	C
2,502	RHU -55 -TEMP	RHU-TT5501703A	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132291	C
2,503	RHU -55 -TEMP	RHU-TT5501703A	TT5501703A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261018	C
2,504	RHU -55 -TEMP	RHU-TT5501703B	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132292	C
2,505	RHU -55 -TEMP	RHU-TT5501703B	TT5501703B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261019	C
2,506	RHU -55 -TEMP	RHU-TT5501703C	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132293	C
2,507	RHU -55 -TEMP	RHU-TT5501703C	TT5501703C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261020	C
2,508	RHU -55 -TEMP	RHU-TT5501703D	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132294	C
2,509	RHU -55 -TEMP	RHU-TT5501703D	TT5501703D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261021	C
2,510	RHU -55 -TEMP	RHU-TT5501703E	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y								I					RRC	RRC-IROH	132295	C
2,511	RHU -55 -TEMP	RHU-TT5501703E	TT5501703E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261022	C
2,512	RHU -55 -TEMP	RHU-TT5501703F	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y								I					RRC	RRC-IROH	132296	C
2,513	RHU -55 -TEMP	RHU-TT5501703F	TT5501703F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261023	C
2,514	RHU -55 -TEMP	RHU-TT5501704A	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y								I					RRC	RRC-IROH	132297	C
2,515	RHU -55 -TEMP	RHU-TT5501704A	TT5501704A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261024	C
2,516	RHU -55 -TEMP	RHU-TT5501704B	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y								I					RRC	RRC-IROH	132298	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,517	RHU -55 -TEMP	RHU-TT5501704B	TT5501704B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261025	C
2,518	RHU -55 -TEMP	RHU-TT5501704C	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132299	C
2,519	RHU -55 -TEMP	RHU-TT5501704C	TT5501704C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261026	C
2,520	RHU -55 -TEMP	RHU-TT5501704D	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132300	C
2,521	RHU -55 -TEMP	RHU-TT5501704D	TT5501704D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261027	C
2,522	RHU -55 -TEMP	RHU-TT5501704E	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132301	C
2,523	RHU -55 -TEMP	RHU-TT5501704E	TT5501704E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261028	C
2,524	RHU -55 -TEMP	RHU-TT5501704F	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132302	C
2,525	RHU -55 -TEMP	RHU-TT5501704F	TT5501704F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261029	C
2,526	RHU -55 -TEMP	RHU-TT5501705A	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132303	C
2,527	RHU -55 -TEMP	RHU-TT5501705A	TT5501705A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261030	C
2,528	RHU -55 -TEMP	RHU-TT5501705B	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132304	C
2,529	RHU -55 -TEMP	RHU-TT5501705B	TT5501705B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261031	C
2,530	RHU -55 -TEMP	RHU-TT5501705C	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132305	C
2,531	RHU -55 -TEMP	RHU-TT5501705C	TT5501705C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261032	C
2,532	RHU -55 -TEMP	RHU-TT5501705D	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132306	C
2,533	RHU -55 -TEMP	RHU-TT5501705D	TT5501705D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261033	C
2,534	RHU -55 -TEMP	RHU-TT5501705E	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132307	C
2,535	RHU -55 -TEMP	RHU-TT5501705E	TT5501705E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261034	C
2,536	RHU -55 -TEMP	RHU-TT5501705F	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132308	C
2,537	RHU -55 -TEMP	RHU-TT5501705F	TT5501705F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261035	C
2,538	RHU -55 -TEMP	RHU-TT5501706A	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132309	C
2,539	RHU -55 -TEMP	RHU-TT5501706A	TT5501706A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261036	C
2,540	RHU -55 -TEMP	RHU-TT5501706B	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132310	C
2,541	RHU -55 -TEMP	RHU-TT5501706B	TT5501706B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261037	C
2,542	RHU -55 -TEMP	RHU-TT5501706C	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132311	C
2,543	RHU -55 -TEMP	RHU-TT5501706C	TT5501706C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261038	C
2,544	RHU -55 -TEMP	RHU-TT5501706D	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132312	C
2,545	RHU -55 -TEMP	RHU-TT5501706D	TT5501706D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261039	C
2,546	RHU -55 -TEMP	RHU-TT5501706E	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132313	C
2,547	RHU -55 -TEMP	RHU-TT5501706E	TT5501706E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261040	C
2,548	RHU -55 -TEMP	RHU-TT5501706F	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132314	C
2,549	RHU -55 -TEMP	RHU-TT5501706F	TT5501706F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261041	C
2,550	RHU -55 -TEMP	RHU-TT5501707A	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132315	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,551	RHU -55 -TEMP	RHU-TT5501707A	TT5501707A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261042	C
2,552	RHU -55 -TEMP	RHU-TT5501707B	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132316	C
2,553	RHU -55 -TEMP	RHU-TT5501707B	TT5501707B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261043	C
2,554	RHU -55 -TEMP	RHU-TT5501707C	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132317	C
2,555	RHU -55 -TEMP	RHU-TT5501707C	TT5501707C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261044	C
2,556	RHU -55 -TEMP	RHU-TT5501707D	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132318	C
2,557	RHU -55 -TEMP	RHU-TT5501707D	TT5501707D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261045	C
2,558	RHU -55 -TEMP	RHU-TT5501707E	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132319	C
2,559	RHU -55 -TEMP	RHU-TT5501707E	TT5501707E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261046	C
2,560	RHU -55 -TEMP	RHU-TT5501707F	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132320	C
2,561	RHU -55 -TEMP	RHU-TT5501707F	TT5501707F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261047	C
2,562	RHU -55 -TEMP	RHU-TT5501708A	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132321	C
2,563	RHU -55 -TEMP	RHU-TT5501708A	TT5501708A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261048	C
2,564	RHU -55 -TEMP	RHU-TT5501708B	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132322	C
2,565	RHU -55 -TEMP	RHU-TT5501708B	TT5501708B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261049	C
2,566	RHU -55 -TEMP	RHU-TT5501708C	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132323	C
2,567	RHU -55 -TEMP	RHU-TT5501708C	TT5501708C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261050	C
2,568	RHU -55 -TEMP	RHU-TT5501708D	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132324	C
2,569	RHU -55 -TEMP	RHU-TT5501708D	TT5501708D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261051	C
2,570	RHU -55 -TEMP	RHU-TT5501708E	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132325	C
2,571	RHU -55 -TEMP	RHU-TT5501708E	TT5501708E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261052	C
2,572	RHU -55 -TEMP	RHU-TT5501708F	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132326	C
2,573	RHU -55 -TEMP	RHU-TT5501708F	TT5501708F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261053	C
2,574	RHU -55 -TEMP	RHU-TT5501710	INSP. FIELD INST. (ตัดทุกปีกรณี)	PMT	1Y							I						RRC	RRC-IROH	132327	C
2,575	RHU -55 -TEMP	RHU-TT5501711A	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132328	C
2,576	RHU -55 -TEMP	RHU-TT5501711A	TT5501711A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260763	C
2,577	RHU -55 -TEMP	RHU-TT5501711B	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132329	C
2,578	RHU -55 -TEMP	RHU-TT5501711B	TT5501711B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260764	C
2,579	RHU -55 -TEMP	RHU-TT5501711C	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132330	C
2,580	RHU -55 -TEMP	RHU-TT5501711C	TT5501711C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260765	C
2,581	RHU -55 -TEMP	RHU-TT5501711D	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132331	C
2,582	RHU -55 -TEMP	RHU-TT5501711D	TT5501711D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260766	C
2,583	RHU -55 -TEMP	RHU-TT5501711E	INSP. FIELD INST. (ตัดทุกปีกรณี)	INS	1Y							I						RRC	RRC-IROH	132332	C
2,584	RHU -55 -TEMP	RHU-TT5501711E	TT5501711E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260767	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,585	RHU -55 -TEMP	RHU-TT5501711F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132333	C
2,586	RHU -55 -TEMP	RHU-TT5501711F	TT5501711F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260768	C
2,587	RHU -55 -TEMP	RHU-TT5501712A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132334	C
2,588	RHU -55 -TEMP	RHU-TT5501712A	TT5501712A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260769	C
2,589	RHU -55 -TEMP	RHU-TT5501712B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132335	C
2,590	RHU -55 -TEMP	RHU-TT5501712B	TT5501712B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260770	C
2,591	RHU -55 -TEMP	RHU-TT5501712C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132336	C
2,592	RHU -55 -TEMP	RHU-TT5501712C	TT5501712C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260771	C
2,593	RHU -55 -TEMP	RHU-TT5501712D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132337	C
2,594	RHU -55 -TEMP	RHU-TT5501712D	TT5501712D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260772	C
2,595	RHU -55 -TEMP	RHU-TT5501712E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132338	C
2,596	RHU -55 -TEMP	RHU-TT5501712E	TT5501712E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260773	C
2,597	RHU -55 -TEMP	RHU-TT5501712F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132339	C
2,598	RHU -55 -TEMP	RHU-TT5501712F	TT5501712F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260774	C
2,599	RHU -55 -TEMP	RHU-TT5501713A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132340	C
2,600	RHU -55 -TEMP	RHU-TT5501713A	TT5501713A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260775	C
2,601	RHU -55 -TEMP	RHU-TT5501713B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132341	C
2,602	RHU -55 -TEMP	RHU-TT5501713B	TT5501713B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260776	C
2,603	RHU -55 -TEMP	RHU-TT5501713C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132342	C
2,604	RHU -55 -TEMP	RHU-TT5501713C	TT5501713C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260777	C
2,605	RHU -55 -TEMP	RHU-TT5501713D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132343	C
2,606	RHU -55 -TEMP	RHU-TT5501713D	TT5501713D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260778	C
2,607	RHU -55 -TEMP	RHU-TT5501713E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132344	C
2,608	RHU -55 -TEMP	RHU-TT5501713E	TT5501713E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260779	C
2,609	RHU -55 -TEMP	RHU-TT5501713F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132345	C
2,610	RHU -55 -TEMP	RHU-TT5501713F	TT5501713F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260780	C
2,611	RHU -55 -TEMP	RHU-TT5501714A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132346	C
2,612	RHU -55 -TEMP	RHU-TT5501714A	TT5501714A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260781	C
2,613	RHU -55 -TEMP	RHU-TT5501714B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132347	C
2,614	RHU -55 -TEMP	RHU-TT5501714B	TT5501714B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260782	C
2,615	RHU -55 -TEMP	RHU-TT5501714C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132348	C
2,616	RHU -55 -TEMP	RHU-TT5501714C	TT5501714C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260783	C
2,617	RHU -55 -TEMP	RHU-TT5501714D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132349	C
2,618	RHU -55 -TEMP	RHU-TT5501714D	TT5501714D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260784	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,619	RHU -55 -TEMP	RHU-TT5501714E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132350	C
2,620	RHU -55 -TEMP	RHU-TT5501714E	TT5501714E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260785	C
2,621	RHU -55 -TEMP	RHU-TT5501714F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132351	C
2,622	RHU -55 -TEMP	RHU-TT5501714F	TT5501714F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260786	C
2,623	RHU -55 -TEMP	RHU-TT5501715A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132352	C
2,624	RHU -55 -TEMP	RHU-TT5501715A	TT5501715A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260787	C
2,625	RHU -55 -TEMP	RHU-TT5501715B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132353	C
2,626	RHU -55 -TEMP	RHU-TT5501715B	TT5501715B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260788	C
2,627	RHU -55 -TEMP	RHU-TT5501715C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132354	C
2,628	RHU -55 -TEMP	RHU-TT5501715C	TT5501715C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260789	C
2,629	RHU -55 -TEMP	RHU-TT5501715D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132355	C
2,630	RHU -55 -TEMP	RHU-TT5501715D	TT5501715D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260790	C
2,631	RHU -55 -TEMP	RHU-TT5501715E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132356	C
2,632	RHU -55 -TEMP	RHU-TT5501715E	TT5501715E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260791	C
2,633	RHU -55 -TEMP	RHU-TT5501715F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132357	C
2,634	RHU -55 -TEMP	RHU-TT5501715F	TT5501715F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260792	C
2,635	RHU -55 -TEMP	RHU-TT5501716A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132358	C
2,636	RHU -55 -TEMP	RHU-TT5501716A	TT5501716A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260793	C
2,637	RHU -55 -TEMP	RHU-TT5501716B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132359	C
2,638	RHU -55 -TEMP	RHU-TT5501716B	TT5501716B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260794	C
2,639	RHU -55 -TEMP	RHU-TT5501716C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132360	C
2,640	RHU -55 -TEMP	RHU-TT5501716C	TT5501716C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260795	C
2,641	RHU -55 -TEMP	RHU-TT5501716D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132361	C
2,642	RHU -55 -TEMP	RHU-TT5501716D	TT5501716D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260796	C
2,643	RHU -55 -TEMP	RHU-TT5501716E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132362	C
2,644	RHU -55 -TEMP	RHU-TT5501716E	TT5501716E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260797	C
2,645	RHU -55 -TEMP	RHU-TT5501716F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132363	C
2,646	RHU -55 -TEMP	RHU-TT5501716F	TT5501716F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260798	C
2,647	RHU -55 -TEMP	RHU-TT5501717A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132364	C
2,648	RHU -55 -TEMP	RHU-TT5501717A	TT5501717A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260799	C
2,649	RHU -55 -TEMP	RHU-TT5501717B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132365	C
2,650	RHU -55 -TEMP	RHU-TT5501717B	TT5501717B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260800	C
2,651	RHU -55 -TEMP	RHU-TT5501717C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132366	C
2,652	RHU -55 -TEMP	RHU-TT5501717C	TT5501717C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260801	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,653	RHU -55 -TEMP	RHU-TT5501717D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132367	C
2,654	RHU -55 -TEMP	RHU-TT5501717D	TT5501717D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260802	C
2,655	RHU -55 -TEMP	RHU-TT5501717E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132368	C
2,656	RHU -55 -TEMP	RHU-TT5501717E	TT5501717E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260803	C
2,657	RHU -55 -TEMP	RHU-TT5501717F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132369	C
2,658	RHU -55 -TEMP	RHU-TT5501717F	TT5501717F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260804	C
2,659	RHU -55 -TEMP	RHU-TT5501718A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132370	C
2,660	RHU -55 -TEMP	RHU-TT5501718A	TT5501718A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260805	C
2,661	RHU -55 -TEMP	RHU-TT5501718B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132371	C
2,662	RHU -55 -TEMP	RHU-TT5501718B	TT5501718B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260806	C
2,663	RHU -55 -TEMP	RHU-TT5501718C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132372	C
2,664	RHU -55 -TEMP	RHU-TT5501718C	TT5501718C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260807	C
2,665	RHU -55 -TEMP	RHU-TT5501718D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132373	C
2,666	RHU -55 -TEMP	RHU-TT5501718D	TT5501718D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260808	C
2,667	RHU -55 -TEMP	RHU-TT5501718E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132374	C
2,668	RHU -55 -TEMP	RHU-TT5501718E	TT5501718E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260809	C
2,669	RHU -55 -TEMP	RHU-TT5501718F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132375	C
2,670	RHU -55 -TEMP	RHU-TT5501718F	TT5501718F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260810	C
2,671	RHU -55 -TEMP	RHU-TT5501801A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132376	C
2,672	RHU -55 -TEMP	RHU-TT5501801A	TT5501801A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261054	C
2,673	RHU -55 -TEMP	RHU-TT5501801B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132377	C
2,674	RHU -55 -TEMP	RHU-TT5501801B	TT5501801B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261055	C
2,675	RHU -55 -TEMP	RHU-TT5501801C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132378	C
2,676	RHU -55 -TEMP	RHU-TT5501801C	TT5501801C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261056	C
2,677	RHU -55 -TEMP	RHU-TT5501801D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132379	C
2,678	RHU -55 -TEMP	RHU-TT5501801D	TT5501801D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261057	C
2,679	RHU -55 -TEMP	RHU-TT5501801E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132380	C
2,680	RHU -55 -TEMP	RHU-TT5501801E	TT5501801E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261058	C
2,681	RHU -55 -TEMP	RHU-TT5501801F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132381	C
2,682	RHU -55 -TEMP	RHU-TT5501801F	TT5501801F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261059	C
2,683	RHU -55 -TEMP	RHU-TT5501802A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132382	C
2,684	RHU -55 -TEMP	RHU-TT5501802A	TT5501802A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261060	C
2,685	RHU -55 -TEMP	RHU-TT5501802B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132383	C
2,686	RHU -55 -TEMP	RHU-TT5501802B	TT5501802B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261061	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,687	RHU -55 -TEMP	RHU-TT5501802C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132384	C
2,688	RHU -55 -TEMP	RHU-TT5501802C	TT5501802C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261062	C
2,689	RHU -55 -TEMP	RHU-TT5501802D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132385	C
2,690	RHU -55 -TEMP	RHU-TT5501802D	TT5501802D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261063	C
2,691	RHU -55 -TEMP	RHU-TT5501802E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132386	C
2,692	RHU -55 -TEMP	RHU-TT5501802E	TT5501802E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261064	C
2,693	RHU -55 -TEMP	RHU-TT5501802F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132387	C
2,694	RHU -55 -TEMP	RHU-TT5501802F	TT5501802F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261065	C
2,695	RHU -55 -TEMP	RHU-TT5501803A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132388	C
2,696	RHU -55 -TEMP	RHU-TT5501803A	TT5501803A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261066	C
2,697	RHU -55 -TEMP	RHU-TT5501803B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132389	C
2,698	RHU -55 -TEMP	RHU-TT5501803B	TT5501803B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261067	C
2,699	RHU -55 -TEMP	RHU-TT5501803C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132390	C
2,700	RHU -55 -TEMP	RHU-TT5501803C	TT5501803C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261068	C
2,701	RHU -55 -TEMP	RHU-TT5501803D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132391	C
2,702	RHU -55 -TEMP	RHU-TT5501803D	TT5501803D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261069	C
2,703	RHU -55 -TEMP	RHU-TT5501803E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132392	C
2,704	RHU -55 -TEMP	RHU-TT5501803E	TT5501803E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261070	C
2,705	RHU -55 -TEMP	RHU-TT5501803F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132393	C
2,706	RHU -55 -TEMP	RHU-TT5501803F	TT5501803F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261071	C
2,707	RHU -55 -TEMP	RHU-TT5501804A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132394	C
2,708	RHU -55 -TEMP	RHU-TT5501804A	TT5501804A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261072	C
2,709	RHU -55 -TEMP	RHU-TT5501804B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132395	C
2,710	RHU -55 -TEMP	RHU-TT5501804B	TT5501804B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261073	C
2,711	RHU -55 -TEMP	RHU-TT5501804C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132396	C
2,712	RHU -55 -TEMP	RHU-TT5501804C	TT5501804C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261074	C
2,713	RHU -55 -TEMP	RHU-TT5501804D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132397	C
2,714	RHU -55 -TEMP	RHU-TT5501804D	TT5501804D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261075	C
2,715	RHU -55 -TEMP	RHU-TT5501804E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132398	C
2,716	RHU -55 -TEMP	RHU-TT5501804E	TT5501804E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261076	C
2,717	RHU -55 -TEMP	RHU-TT5501804F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132399	C
2,718	RHU -55 -TEMP	RHU-TT5501804F	TT5501804F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261077	C
2,719	RHU -55 -TEMP	RHU-TT5501805A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y							I						RRC	RRC-IROH	132400	C
2,720	RHU -55 -TEMP	RHU-TT5501805A	TT5501805A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261078	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,721	RHU -55 -TEMP	RHU-TT5501805B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132401	C
2,722	RHU -55 -TEMP	RHU-TT5501805B	TT5501805B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261079	C
2,723	RHU -55 -TEMP	RHU-TT5501805C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132402	C
2,724	RHU -55 -TEMP	RHU-TT5501805C	TT5501805C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261080	C
2,725	RHU -55 -TEMP	RHU-TT5501805D	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132403	C
2,726	RHU -55 -TEMP	RHU-TT5501805D	TT5501805D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261081	C
2,727	RHU -55 -TEMP	RHU-TT5501805E	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132404	C
2,728	RHU -55 -TEMP	RHU-TT5501805E	TT5501805E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261082	C
2,729	RHU -55 -TEMP	RHU-TT5501805F	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132405	C
2,730	RHU -55 -TEMP	RHU-TT5501805F	TT5501805F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261083	C
2,731	RHU -55 -TEMP	RHU-TT5501806A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132406	C
2,732	RHU -55 -TEMP	RHU-TT5501806A	TT5501806A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261084	C
2,733	RHU -55 -TEMP	RHU-TT5501806B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132407	C
2,734	RHU -55 -TEMP	RHU-TT5501806B	TT5501806B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261085	C
2,735	RHU -55 -TEMP	RHU-TT5501806C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132408	C
2,736	RHU -55 -TEMP	RHU-TT5501806C	TT5501806C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261086	C
2,737	RHU -55 -TEMP	RHU-TT5501806D	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132409	C
2,738	RHU -55 -TEMP	RHU-TT5501806D	TT5501806D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261087	C
2,739	RHU -55 -TEMP	RHU-TT5501806E	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132410	C
2,740	RHU -55 -TEMP	RHU-TT5501806E	TT5501806E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261088	C
2,741	RHU -55 -TEMP	RHU-TT5501806F	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132411	C
2,742	RHU -55 -TEMP	RHU-TT5501806F	TT5501806F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261089	C
2,743	RHU -55 -TEMP	RHU-TT5501807A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132412	C
2,744	RHU -55 -TEMP	RHU-TT5501807A	TT5501807A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261090	C
2,745	RHU -55 -TEMP	RHU-TT5501807B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132413	C
2,746	RHU -55 -TEMP	RHU-TT5501807B	TT5501807B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261091	C
2,747	RHU -55 -TEMP	RHU-TT5501807C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132414	C
2,748	RHU -55 -TEMP	RHU-TT5501807C	TT5501807C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261092	C
2,749	RHU -55 -TEMP	RHU-TT5501807D	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132415	C
2,750	RHU -55 -TEMP	RHU-TT5501807D	TT5501807D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261093	C
2,751	RHU -55 -TEMP	RHU-TT5501807E	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132416	C
2,752	RHU -55 -TEMP	RHU-TT5501807E	TT5501807E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261094	C
2,753	RHU -55 -TEMP	RHU-TT5501807F	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132417	C
2,754	RHU -55 -TEMP	RHU-TT5501807F	TT5501807F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261095	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,755	RHU -55 -TEMP	RHU-TT5501808A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132418	C
2,756	RHU -55 -TEMP	RHU-TT5501808A	TT5501808A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261096	C
2,757	RHU -55 -TEMP	RHU-TT5501808B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132419	C
2,758	RHU -55 -TEMP	RHU-TT5501808B	TT5501808B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261097	C
2,759	RHU -55 -TEMP	RHU-TT5501808C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132420	C
2,760	RHU -55 -TEMP	RHU-TT5501808C	TT5501808C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261098	C
2,761	RHU -55 -TEMP	RHU-TT5501808D	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132421	C
2,762	RHU -55 -TEMP	RHU-TT5501808D	TT5501808D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261099	C
2,763	RHU -55 -TEMP	RHU-TT5501808E	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132422	C
2,764	RHU -55 -TEMP	RHU-TT5501808E	TT5501808E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261100	C
2,765	RHU -55 -TEMP	RHU-TT5501808F	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132423	C
2,766	RHU -55 -TEMP	RHU-TT5501808F	TT5501808F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261101	C
2,767	RHU -55 -TEMP	RHU-TT5501810	INSP. FIELD INST. (ตรวจปากน้ำ)	PMT	1Y							I						RRC	RRC-IROH	132424	C
2,768	RHU -55 -TEMP	RHU-TT5501811A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132425	C
2,769	RHU -55 -TEMP	RHU-TT5501811A	TT5501811A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260811	C
2,770	RHU -55 -TEMP	RHU-TT5501811B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132426	C
2,771	RHU -55 -TEMP	RHU-TT5501811B	TT5501811B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260812	C
2,772	RHU -55 -TEMP	RHU-TT5501811C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132427	C
2,773	RHU -55 -TEMP	RHU-TT5501811C	TT5501811C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260813	C
2,774	RHU -55 -TEMP	RHU-TT5501811D	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132428	C
2,775	RHU -55 -TEMP	RHU-TT5501811D	TT5501811D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260814	C
2,776	RHU -55 -TEMP	RHU-TT5501811E	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132429	C
2,777	RHU -55 -TEMP	RHU-TT5501811E	TT5501811E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260815	C
2,778	RHU -55 -TEMP	RHU-TT5501811F	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132430	C
2,779	RHU -55 -TEMP	RHU-TT5501811F	TT5501811F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260816	C
2,780	RHU -55 -TEMP	RHU-TT5501812A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132431	C
2,781	RHU -55 -TEMP	RHU-TT5501812A	TT5501812A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260817	C
2,782	RHU -55 -TEMP	RHU-TT5501812B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132432	C
2,783	RHU -55 -TEMP	RHU-TT5501812B	TT5501812B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260818	C
2,784	RHU -55 -TEMP	RHU-TT5501812C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132433	C
2,785	RHU -55 -TEMP	RHU-TT5501812C	TT5501812C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260819	C
2,786	RHU -55 -TEMP	RHU-TT5501812D	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132434	C
2,787	RHU -55 -TEMP	RHU-TT5501812D	TT5501812D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260820	C
2,788	RHU -55 -TEMP	RHU-TT5501812E	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132435	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,789	RHU -55 -TEMP	RHU-TT5501812E	TT5501812E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260821	C
2,790	RHU -55 -TEMP	RHU-TT5501812F	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132436	C
2,791	RHU -55 -TEMP	RHU-TT5501812F	TT5501812F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260822	C
2,792	RHU -55 -TEMP	RHU-TT5501813A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132437	C
2,793	RHU -55 -TEMP	RHU-TT5501813A	TT5501813A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260823	C
2,794	RHU -55 -TEMP	RHU-TT5501813B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132438	C
2,795	RHU -55 -TEMP	RHU-TT5501813B	TT5501813B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260824	C
2,796	RHU -55 -TEMP	RHU-TT5501813C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132439	C
2,797	RHU -55 -TEMP	RHU-TT5501813C	TT5501813C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260825	C
2,798	RHU -55 -TEMP	RHU-TT5501813D	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132440	C
2,799	RHU -55 -TEMP	RHU-TT5501813D	TT5501813D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260826	C
2,800	RHU -55 -TEMP	RHU-TT5501813E	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132441	C
2,801	RHU -55 -TEMP	RHU-TT5501813E	TT5501813E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260827	C
2,802	RHU -55 -TEMP	RHU-TT5501813F	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132442	C
2,803	RHU -55 -TEMP	RHU-TT5501813F	TT5501813F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260828	C
2,804	RHU -55 -TEMP	RHU-TT5501814A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132443	C
2,805	RHU -55 -TEMP	RHU-TT5501814A	TT5501814A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260829	C
2,806	RHU -55 -TEMP	RHU-TT5501814B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132444	C
2,807	RHU -55 -TEMP	RHU-TT5501814B	TT5501814B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260830	C
2,808	RHU -55 -TEMP	RHU-TT5501814C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132445	C
2,809	RHU -55 -TEMP	RHU-TT5501814C	TT5501814C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260831	C
2,810	RHU -55 -TEMP	RHU-TT5501814D	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y							I						RRC	RRC-IROH	132446	C
2,811	RHU -55 -TEMP	RHU-TT5501814D	TT5501814D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260832	C
2,812	RHU -55 -TEMP	RHU-TT5501814E	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132447	C
2,813	RHU -55 -TEMP	RHU-TT5501814E	TT5501814E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260833	C
2,814	RHU -55 -TEMP	RHU-TT5501814F	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132448	C
2,815	RHU -55 -TEMP	RHU-TT5501814F	TT5501814F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260834	C
2,816	RHU -55 -TEMP	RHU-TT5501815A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132449	C
2,817	RHU -55 -TEMP	RHU-TT5501815A	TT5501815A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260835	C
2,818	RHU -55 -TEMP	RHU-TT5501815B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132450	C
2,819	RHU -55 -TEMP	RHU-TT5501815B	TT5501815B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260836	C
2,820	RHU -55 -TEMP	RHU-TT5501815C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132451	C
2,821	RHU -55 -TEMP	RHU-TT5501815C	TT5501815C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260837	C
2,822	RHU -55 -TEMP	RHU-TT5501815D	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132452	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,823	RHU -55 -TEMP	RHU-TT5501815D	TT5501815D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260838	C
2,824	RHU -55 -TEMP	RHU-TT5501815E	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132453	C
2,825	RHU -55 -TEMP	RHU-TT5501815E	TT5501815E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260839	C
2,826	RHU -55 -TEMP	RHU-TT5501815F	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132454	C
2,827	RHU -55 -TEMP	RHU-TT5501815F	TT5501815F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260840	C
2,828	RHU -55 -TEMP	RHU-TT5501816A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132455	C
2,829	RHU -55 -TEMP	RHU-TT5501816A	TT5501816A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260841	C
2,830	RHU -55 -TEMP	RHU-TT5501816B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132456	C
2,831	RHU -55 -TEMP	RHU-TT5501816B	TT5501816B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260842	C
2,832	RHU -55 -TEMP	RHU-TT5501816C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132457	C
2,833	RHU -55 -TEMP	RHU-TT5501816C	TT5501816C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260843	C
2,834	RHU -55 -TEMP	RHU-TT5501816D	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132458	C
2,835	RHU -55 -TEMP	RHU-TT5501816D	TT5501816D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260844	C
2,836	RHU -55 -TEMP	RHU-TT5501816E	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132459	C
2,837	RHU -55 -TEMP	RHU-TT5501816E	TT5501816E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260845	C
2,838	RHU -55 -TEMP	RHU-TT5501816F	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132460	C
2,839	RHU -55 -TEMP	RHU-TT5501816F	TT5501816F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260846	C
2,840	RHU -55 -TEMP	RHU-TT5501817A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132461	C
2,841	RHU -55 -TEMP	RHU-TT5501817A	TT5501817A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260847	C
2,842	RHU -55 -TEMP	RHU-TT5501817B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132462	C
2,843	RHU -55 -TEMP	RHU-TT5501817B	TT5501817B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260848	C
2,844	RHU -55 -TEMP	RHU-TT5501817C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132463	C
2,845	RHU -55 -TEMP	RHU-TT5501817C	TT5501817C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260849	C
2,846	RHU -55 -TEMP	RHU-TT5501817D	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132464	C
2,847	RHU -55 -TEMP	RHU-TT5501817D	TT5501817D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260850	C
2,848	RHU -55 -TEMP	RHU-TT5501817E	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132465	C
2,849	RHU -55 -TEMP	RHU-TT5501817E	TT5501817E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260851	C
2,850	RHU -55 -TEMP	RHU-TT5501817F	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132466	C
2,851	RHU -55 -TEMP	RHU-TT5501817F	TT5501817F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260852	C
2,852	RHU -55 -TEMP	RHU-TT5501818A	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132467	C
2,853	RHU -55 -TEMP	RHU-TT5501818A	TT5501818A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260853	C
2,854	RHU -55 -TEMP	RHU-TT5501818B	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132468	C
2,855	RHU -55 -TEMP	RHU-TT5501818B	TT5501818B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260854	C
2,856	RHU -55 -TEMP	RHU-TT5501818C	INSP. FIELD INST. (ตรวจปากน้ำ)	INS	1Y								I					RRC	RRC-IROH	132469	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,857	RHU -55 -TEMP	RHU-TT5501818C	TT5501818C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260855	C
2,858	RHU -55 -TEMP	RHU-TT5501818D	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132470	C
2,859	RHU -55 -TEMP	RHU-TT5501818D	TT5501818D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260856	C
2,860	RHU -55 -TEMP	RHU-TT5501818E	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132471	C
2,861	RHU -55 -TEMP	RHU-TT5501818E	TT5501818E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260857	C
2,862	RHU -55 -TEMP	RHU-TT5501818F	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132472	C
2,863	RHU -55 -TEMP	RHU-TT5501818F	TT5501818F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260858	C
2,864	RHU -55 -TEMP	RHU-TT5501822	INSP. FIELD INST. (ต่อฤปากรณ์)	PMT	1Y								I					RRC	RRC-IROH	132473	C
2,865	RHU -55 -TEMP	RHU-TT55501901A	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132474	C
2,866	RHU -55 -TEMP	RHU-TT55501901A	TT5501901A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261102	C
2,867	RHU -55 -TEMP	RHU-TT55501901B	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132475	C
2,868	RHU -55 -TEMP	RHU-TT55501901B	TT5501901B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261103	C
2,869	RHU -55 -TEMP	RHU-TT55501901C	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132476	C
2,870	RHU -55 -TEMP	RHU-TT55501901C	TT5501901C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261104	C
2,871	RHU -55 -TEMP	RHU-TT55501901D	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132477	C
2,872	RHU -55 -TEMP	RHU-TT55501901D	TT5501901D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261105	C
2,873	RHU -55 -TEMP	RHU-TT55501901E	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132478	C
2,874	RHU -55 -TEMP	RHU-TT55501901E	TT5501901E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261106	C
2,875	RHU -55 -TEMP	RHU-TT55501901F	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132479	C
2,876	RHU -55 -TEMP	RHU-TT55501901F	TT5501901F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261107	C
2,877	RHU -55 -TEMP	RHU-TT55501902A	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132480	C
2,878	RHU -55 -TEMP	RHU-TT55501902A	TT5501902A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261108	C
2,879	RHU -55 -TEMP	RHU-TT55501902B	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132481	C
2,880	RHU -55 -TEMP	RHU-TT55501902B	TT5501902B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261109	C
2,881	RHU -55 -TEMP	RHU-TT55501902C	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132482	C
2,882	RHU -55 -TEMP	RHU-TT55501902C	TT5501902C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261110	C
2,883	RHU -55 -TEMP	RHU-TT55501902D	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132483	C
2,884	RHU -55 -TEMP	RHU-TT55501902D	TT5501902D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261111	C
2,885	RHU -55 -TEMP	RHU-TT55501902E	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132484	C
2,886	RHU -55 -TEMP	RHU-TT55501902E	TT5501902E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261112	C
2,887	RHU -55 -TEMP	RHU-TT55501902F	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132485	C
2,888	RHU -55 -TEMP	RHU-TT55501902F	TT5501902F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261113	C
2,889	RHU -55 -TEMP	RHU-TT55501903A	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132486	C
2,890	RHU -55 -TEMP	RHU-TT55501903A	TT5501903A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261114	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,891	RHU -55 -TEMP	RHU-TT55501903B	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132487	C
2,892	RHU -55 -TEMP	RHU-TT55501903B	TT5501903B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261115	C
2,893	RHU -55 -TEMP	RHU-TT55501903C	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132488	C
2,894	RHU -55 -TEMP	RHU-TT55501903C	TT5501903C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261116	C
2,895	RHU -55 -TEMP	RHU-TT55501903D	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132489	C
2,896	RHU -55 -TEMP	RHU-TT55501903D	TT5501903D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261117	C
2,897	RHU -55 -TEMP	RHU-TT55501903E	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132490	C
2,898	RHU -55 -TEMP	RHU-TT55501903E	TT5501903E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261118	C
2,899	RHU -55 -TEMP	RHU-TT55501903F	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132491	C
2,900	RHU -55 -TEMP	RHU-TT55501903F	TT5501903F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261119	C
2,901	RHU -55 -TEMP	RHU-TT55501904A	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132492	C
2,902	RHU -55 -TEMP	RHU-TT55501904A	TT5501904A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261120	C
2,903	RHU -55 -TEMP	RHU-TT55501904B	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132493	C
2,904	RHU -55 -TEMP	RHU-TT55501904B	TT5501904B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261121	C
2,905	RHU -55 -TEMP	RHU-TT55501904C	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132494	C
2,906	RHU -55 -TEMP	RHU-TT55501904C	TT5501904C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261122	C
2,907	RHU -55 -TEMP	RHU-TT55501904D	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132495	C
2,908	RHU -55 -TEMP	RHU-TT55501904D	TT5501904D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261123	C
2,909	RHU -55 -TEMP	RHU-TT55501904E	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132496	C
2,910	RHU -55 -TEMP	RHU-TT55501904E	TT5501904E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261124	C
2,911	RHU -55 -TEMP	RHU-TT55501904F	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132497	C
2,912	RHU -55 -TEMP	RHU-TT55501904F	TT5501904F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261125	C
2,913	RHU -55 -TEMP	RHU-TT55501905A	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132498	C
2,914	RHU -55 -TEMP	RHU-TT55501905A	TT5501905A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261126	C
2,915	RHU -55 -TEMP	RHU-TT55501905B	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132499	C
2,916	RHU -55 -TEMP	RHU-TT55501905B	TT5501905B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261127	C
2,917	RHU -55 -TEMP	RHU-TT55501905C	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132500	C
2,918	RHU -55 -TEMP	RHU-TT55501905C	TT5501905C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261128	C
2,919	RHU -55 -TEMP	RHU-TT55501905D	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132501	C
2,920	RHU -55 -TEMP	RHU-TT55501905D	TT5501905D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261129	C
2,921	RHU -55 -TEMP	RHU-TT55501905E	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132502	C
2,922	RHU -55 -TEMP	RHU-TT55501905E	TT5501905E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261130	C
2,923	RHU -55 -TEMP	RHU-TT55501905F	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132503	C
2,924	RHU -55 -TEMP	RHU-TT55501905F	TT5501905F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261131	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,925	RHU -55 -TEMP	RHU-TT55501906A	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132504	C
2,926	RHU -55 -TEMP	RHU-TT55501906A	TT5501906A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261132	C
2,927	RHU -55 -TEMP	RHU-TT55501906B	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132505	C
2,928	RHU -55 -TEMP	RHU-TT55501906B	TT5501906B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261133	C
2,929	RHU -55 -TEMP	RHU-TT55501906C	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132506	C
2,930	RHU -55 -TEMP	RHU-TT55501906C	TT5501906C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261134	C
2,931	RHU -55 -TEMP	RHU-TT55501906D	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132507	C
2,932	RHU -55 -TEMP	RHU-TT55501906D	TT5501906D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261135	C
2,933	RHU -55 -TEMP	RHU-TT55501906E	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132508	C
2,934	RHU -55 -TEMP	RHU-TT55501906E	TT5501906E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261136	C
2,935	RHU -55 -TEMP	RHU-TT55501906F	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132509	C
2,936	RHU -55 -TEMP	RHU-TT55501906F	TT5501906F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261137	C
2,937	RHU -55 -TEMP	RHU-TT55501907A	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132510	C
2,938	RHU -55 -TEMP	RHU-TT55501907A	TT5501907A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261138	C
2,939	RHU -55 -TEMP	RHU-TT55501907B	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132511	C
2,940	RHU -55 -TEMP	RHU-TT55501907B	TT5501907B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261139	C
2,941	RHU -55 -TEMP	RHU-TT55501907C	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132512	C
2,942	RHU -55 -TEMP	RHU-TT55501907C	TT5501907C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261140	C
2,943	RHU -55 -TEMP	RHU-TT55501907D	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132513	C
2,944	RHU -55 -TEMP	RHU-TT55501907D	TT5501907D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261141	C
2,945	RHU -55 -TEMP	RHU-TT55501907E	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132514	C
2,946	RHU -55 -TEMP	RHU-TT55501907E	TT5501907E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261142	C
2,947	RHU -55 -TEMP	RHU-TT55501907F	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132515	C
2,948	RHU -55 -TEMP	RHU-TT55501907F	TT5501907F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261143	C
2,949	RHU -55 -TEMP	RHU-TT55501908A	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132516	C
2,950	RHU -55 -TEMP	RHU-TT55501908A	TT5501908A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261144	C
2,951	RHU -55 -TEMP	RHU-TT55501908B	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132517	C
2,952	RHU -55 -TEMP	RHU-TT55501908B	TT5501908B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261145	C
2,953	RHU -55 -TEMP	RHU-TT55501908C	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132518	C
2,954	RHU -55 -TEMP	RHU-TT55501908C	TT5501908C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261146	C
2,955	RHU -55 -TEMP	RHU-TT55501908D	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132519	C
2,956	RHU -55 -TEMP	RHU-TT55501908D	TT5501908D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261147	C
2,957	RHU -55 -TEMP	RHU-TT55501908E	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132520	C
2,958	RHU -55 -TEMP	RHU-TT55501908E	TT5501908E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261148	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,959	RHU -55 -TEMP	RHU-TT55501908F	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132521	C
2,960	RHU -55 -TEMP	RHU-TT55501908F	TT5501908F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261149	C
2,961	RHU -55 -TEMP	RHU-TT55501909A	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132522	C
2,962	RHU -55 -TEMP	RHU-TT55501909A	TT5501909A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261150	C
2,963	RHU -55 -TEMP	RHU-TT55501909B	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132523	C
2,964	RHU -55 -TEMP	RHU-TT55501909B	TT5501909B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261151	C
2,965	RHU -55 -TEMP	RHU-TT55501909C	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132524	C
2,966	RHU -55 -TEMP	RHU-TT55501909C	TT5501909C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261152	C
2,967	RHU -55 -TEMP	RHU-TT55501909D	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132525	C
2,968	RHU -55 -TEMP	RHU-TT55501909D	TT5501909D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261153	C
2,969	RHU -55 -TEMP	RHU-TT55501909E	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132526	C
2,970	RHU -55 -TEMP	RHU-TT55501909E	TT5501909E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261154	C
2,971	RHU -55 -TEMP	RHU-TT55501909F	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132527	C
2,972	RHU -55 -TEMP	RHU-TT55501909F	TT5501909F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261155	C
2,973	RHU -55 -TEMP	RHU-TT55501910A	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132528	C
2,974	RHU -55 -TEMP	RHU-TT55501910A	TT5501910A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261156	C
2,975	RHU -55 -TEMP	RHU-TT55501910B	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132529	C
2,976	RHU -55 -TEMP	RHU-TT55501910B	TT5501910B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261157	C
2,977	RHU -55 -TEMP	RHU-TT55501910C	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132530	C
2,978	RHU -55 -TEMP	RHU-TT55501910C	TT5501910C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261158	C
2,979	RHU -55 -TEMP	RHU-TT55501910D	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132531	C
2,980	RHU -55 -TEMP	RHU-TT55501910D	TT5501910D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261159	C
2,981	RHU -55 -TEMP	RHU-TT55501910E	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132532	C
2,982	RHU -55 -TEMP	RHU-TT55501910E	TT5501910E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261160	C
2,983	RHU -55 -TEMP	RHU-TT55501910F	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132533	C
2,984	RHU -55 -TEMP	RHU-TT55501910F	TT5501910F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261161	C
2,985	RHU -55 -TEMP	RHU-TT55501911A	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132534	C
2,986	RHU -55 -TEMP	RHU-TT55501911A	TT5501911A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261162	C
2,987	RHU -55 -TEMP	RHU-TT55501911B	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132535	C
2,988	RHU -55 -TEMP	RHU-TT55501911B	TT5501911B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261163	C
2,989	RHU -55 -TEMP	RHU-TT55501911C	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132536	C
2,990	RHU -55 -TEMP	RHU-TT55501911C	TT5501911C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261164	C
2,991	RHU -55 -TEMP	RHU-TT55501911D	INSP. FIELD INST. (ต่อฤปากรณ์)	INS	1Y								I					RRC	RRC-IROH	132537	C
2,992	RHU -55 -TEMP	RHU-TT55501911D	TT5501911D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261165	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,993	RHU -55 -TEMP	RHU-TT5501911E	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132538	C
2,994	RHU -55 -TEMP	RHU-TT5501911E	TT5501911E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261166	C
2,995	RHU -55 -TEMP	RHU-TT5501911F	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132539	C
2,996	RHU -55 -TEMP	RHU-TT5501911F	TT5501911F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261167	C
2,997	RHU -55 -TEMP	RHU-TT5501912A	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132540	C
2,998	RHU -55 -TEMP	RHU-TT5501912A	TT5501912A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261168	C
2,999	RHU -55 -TEMP	RHU-TT5501912B	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132541	C
3,000	RHU -55 -TEMP	RHU-TT5501912B	TT5501912B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261169	C
3,001	RHU -55 -TEMP	RHU-TT5501912C	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132542	C
3,002	RHU -55 -TEMP	RHU-TT5501912C	TT5501912C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261170	C
3,003	RHU -55 -TEMP	RHU-TT5501912D	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132543	C
3,004	RHU -55 -TEMP	RHU-TT5501912D	TT5501912D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261171	C
3,005	RHU -55 -TEMP	RHU-TT5501912E	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132544	C
3,006	RHU -55 -TEMP	RHU-TT5501912E	TT5501912E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261172	C
3,007	RHU -55 -TEMP	RHU-TT5501912F	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132545	C
3,008	RHU -55 -TEMP	RHU-TT5501912F	TT5501912F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261173	C
3,009	RHU -55 -TEMP	RHU-TT5501914	INSP. FIELD INST. (ต่อทุปากมั)	PMT	1Y								I					RRC	RRC-IROH	132546	C
3,010	RHU -55 -TEMP	RHU-TT5501915	INSP. FIELD INST. (ต่อทุปากมั)	PMT	1Y								I					RRC	RRC-IROH	132547	C
3,011	RHU -55 -TEMP	RHU-TT5501916	INSP. FIELD INST. (ต่อทุปากมั)	PMT	1Y								I					RRC	RRC-IROH	132548	C
3,012	RHU -55 -TEMP	RHU-TT5501917	INSP. FIELD INST. (ต่อทุปากมั)	PMT	1Y								I					RRC	RRC-IROH	132549	C
3,013	RHU -55 -TEMP	RHU-TT5501918A	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132550	C
3,014	RHU -55 -TEMP	RHU-TT5501918A	TT5501918A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260859	C
3,015	RHU -55 -TEMP	RHU-TT5501918B	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132551	C
3,016	RHU -55 -TEMP	RHU-TT5501918B	TT5501918B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260860	C
3,017	RHU -55 -TEMP	RHU-TT5501918C	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132552	C
3,018	RHU -55 -TEMP	RHU-TT5501918C	TT5501918C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260861	C
3,019	RHU -55 -TEMP	RHU-TT5501918D	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132553	C
3,020	RHU -55 -TEMP	RHU-TT5501918D	TT5501918D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260862	C
3,021	RHU -55 -TEMP	RHU-TT5501918E	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132554	C
3,022	RHU -55 -TEMP	RHU-TT5501918E	TT5501918E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260863	C
3,023	RHU -55 -TEMP	RHU-TT5501918F	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132555	C
3,024	RHU -55 -TEMP	RHU-TT5501918F	TT5501918F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260864	C
3,025	RHU -55 -TEMP	RHU-TT5501919A	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132556	C
3,026	RHU -55 -TEMP	RHU-TT5501919A	TT5501919A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260865	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,027	RHU -55 -TEMP	RHU-TT5501919B	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132557	C
3,028	RHU -55 -TEMP	RHU-TT5501919B	TT5501919B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260866	C
3,029	RHU -55 -TEMP	RHU-TT5501919C	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132558	C
3,030	RHU -55 -TEMP	RHU-TT5501919C	TT5501919C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260867	C
3,031	RHU -55 -TEMP	RHU-TT5501919D	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132559	C
3,032	RHU -55 -TEMP	RHU-TT5501919D	TT5501919D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260868	C
3,033	RHU -55 -TEMP	RHU-TT5501919E	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132560	C
3,034	RHU -55 -TEMP	RHU-TT5501919E	TT5501919E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260869	C
3,035	RHU -55 -TEMP	RHU-TT5501919F	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132561	C
3,036	RHU -55 -TEMP	RHU-TT5501919F	TT5501919F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260870	C
3,037	RHU -55 -TEMP	RHU-TT5501920A	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132562	C
3,038	RHU -55 -TEMP	RHU-TT5501920A	TT5501920A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260871	C
3,039	RHU -55 -TEMP	RHU-TT5501920B	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132563	C
3,040	RHU -55 -TEMP	RHU-TT5501920B	TT5501920B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260872	C
3,041	RHU -55 -TEMP	RHU-TT5501920C	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132564	C
3,042	RHU -55 -TEMP	RHU-TT5501920C	TT5501920C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260873	C
3,043	RHU -55 -TEMP	RHU-TT5501920D	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132565	C
3,044	RHU -55 -TEMP	RHU-TT5501920D	TT5501920D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260874	C
3,045	RHU -55 -TEMP	RHU-TT5501920E	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132566	C
3,046	RHU -55 -TEMP	RHU-TT5501920E	TT5501920E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260875	C
3,047	RHU -55 -TEMP	RHU-TT5501920F	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132567	C
3,048	RHU -55 -TEMP	RHU-TT5501920F	TT5501920F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260876	C
3,049	RHU -55 -TEMP	RHU-TT5501921A	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132568	C
3,050	RHU -55 -TEMP	RHU-TT5501921A	TT5501921A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260877	C
3,051	RHU -55 -TEMP	RHU-TT5501921B	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132569	C
3,052	RHU -55 -TEMP	RHU-TT5501921B	TT5501921B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260878	C
3,053	RHU -55 -TEMP	RHU-TT5501921C	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132570	C
3,054	RHU -55 -TEMP	RHU-TT5501921C	TT5501921C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260879	C
3,055	RHU -55 -TEMP	RHU-TT5501921D	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132571	C
3,056	RHU -55 -TEMP	RHU-TT5501921D	TT5501921D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260880	C
3,057	RHU -55 -TEMP	RHU-TT5501921E	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132572	C
3,058	RHU -55 -TEMP	RHU-TT5501921E	TT5501921E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260881	C
3,059	RHU -55 -TEMP	RHU-TT5501921F	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132573	C
3,060	RHU -55 -TEMP	RHU-TT5501921F	TT5501921F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260882	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,061	RHU -55 -TEMP	RHU-TT5501922A	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132574	C
3,062	RHU -55 -TEMP	RHU-TT5501922A	TT5501922A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260883	C
3,063	RHU -55 -TEMP	RHU-TT5501922B	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132575	C
3,064	RHU -55 -TEMP	RHU-TT5501922B	TT5501922B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260884	C
3,065	RHU -55 -TEMP	RHU-TT5501922C	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132576	C
3,066	RHU -55 -TEMP	RHU-TT5501922C	TT5501922C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260885	C
3,067	RHU -55 -TEMP	RHU-TT5501922D	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132577	C
3,068	RHU -55 -TEMP	RHU-TT5501922D	TT5501922D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260886	C
3,069	RHU -55 -TEMP	RHU-TT5501922E	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132578	C
3,070	RHU -55 -TEMP	RHU-TT5501922E	TT5501922E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260887	C
3,071	RHU -55 -TEMP	RHU-TT5501922F	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132579	C
3,072	RHU -55 -TEMP	RHU-TT5501922F	TT5501922F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260888	C
3,073	RHU -55 -TEMP	RHU-TT5501923A	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132580	C
3,074	RHU -55 -TEMP	RHU-TT5501923A	TT5501923A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260889	C
3,075	RHU -55 -TEMP	RHU-TT5501923B	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132581	C
3,076	RHU -55 -TEMP	RHU-TT5501923B	TT5501923B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260890	C
3,077	RHU -55 -TEMP	RHU-TT5501923C	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132582	C
3,078	RHU -55 -TEMP	RHU-TT5501923C	TT5501923C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260891	C
3,079	RHU -55 -TEMP	RHU-TT5501923D	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132583	C
3,080	RHU -55 -TEMP	RHU-TT5501923D	TT5501923D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260892	C
3,081	RHU -55 -TEMP	RHU-TT5501923E	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132584	C
3,082	RHU -55 -TEMP	RHU-TT5501923E	TT5501923E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260893	C
3,083	RHU -55 -TEMP	RHU-TT5501923F	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132585	C
3,084	RHU -55 -TEMP	RHU-TT5501923F	TT5501923F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260894	C
3,085	RHU -55 -TEMP	RHU-TT5501924A	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132586	C
3,086	RHU -55 -TEMP	RHU-TT5501924A	TT5501924A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260895	C
3,087	RHU -55 -TEMP	RHU-TT5501924B	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132587	C
3,088	RHU -55 -TEMP	RHU-TT5501924B	TT5501924B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260896	C
3,089	RHU -55 -TEMP	RHU-TT5501924C	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132588	C
3,090	RHU -55 -TEMP	RHU-TT5501924C	TT5501924C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260897	C
3,091	RHU -55 -TEMP	RHU-TT5501924D	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132589	C
3,092	RHU -55 -TEMP	RHU-TT5501924D	TT5501924D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260898	C
3,093	RHU -55 -TEMP	RHU-TT5501924E	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132590	C
3,094	RHU -55 -TEMP	RHU-TT5501924E	TT5501924E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260899	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,095	RHU -55 -TEMP	RHU-TT5501924F	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132591	C
3,096	RHU -55 -TEMP	RHU-TT5501924F	TT5501924F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260900	C
3,097	RHU -55 -TEMP	RHU-TT5501925A	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132592	C
3,098	RHU -55 -TEMP	RHU-TT5501925A	TT5501925A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260901	C
3,099	RHU -55 -TEMP	RHU-TT5501925B	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132593	C
3,100	RHU -55 -TEMP	RHU-TT5501925B	TT5501925B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260902	C
3,101	RHU -55 -TEMP	RHU-TT5501925C	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132594	C
3,102	RHU -55 -TEMP	RHU-TT5501925C	TT5501925C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260903	C
3,103	RHU -55 -TEMP	RHU-TT5501925D	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132595	C
3,104	RHU -55 -TEMP	RHU-TT5501925D	TT5501925D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260904	C
3,105	RHU -55 -TEMP	RHU-TT5501925E	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132596	C
3,106	RHU -55 -TEMP	RHU-TT5501925E	TT5501925E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260905	C
3,107	RHU -55 -TEMP	RHU-TT5501925F	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132597	C
3,108	RHU -55 -TEMP	RHU-TT5501925F	TT5501925F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260906	C
3,109	RHU -55 -TEMP	RHU-TT5501926A	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y								I					RRC	RRC-IROH	132598	C
3,110	RHU -55 -TEMP	RHU-TT5501926A	TT5501926A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260907	C
3,111	RHU -55 -TEMP	RHU-TT5501926B	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y									I				RRC	RRC-IROH	132599	C
3,112	RHU -55 -TEMP	RHU-TT5501926B	TT5501926B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260908	C
3,113	RHU -55 -TEMP	RHU-TT5501926C	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y									I				RRC	RRC-IROH	132600	C
3,114	RHU -55 -TEMP	RHU-TT5501926C	TT5501926C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260909	C
3,115	RHU -55 -TEMP	RHU-TT5501926D	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y									I				RRC	RRC-IROH	132601	C
3,116	RHU -55 -TEMP	RHU-TT5501926D	TT5501926D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260910	C
3,117	RHU -55 -TEMP	RHU-TT5501926E	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y									I				RRC	RRC-IROH	132602	C
3,118	RHU -55 -TEMP	RHU-TT5501926E	TT5501926E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260911	C
3,119	RHU -55 -TEMP	RHU-TT5501926F	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y									I				RRC	RRC-IROH	132603	C
3,120	RHU -55 -TEMP	RHU-TT5501926F	TT5501926F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260912	C
3,121	RHU -55 -TEMP	RHU-TT5501927A	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y									I				RRC	RRC-IROH	132604	C
3,122	RHU -55 -TEMP	RHU-TT5501927A	TT5501927A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260913	C
3,123	RHU -55 -TEMP	RHU-TT5501927B	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y									I				RRC	RRC-IROH	132605	C
3,124	RHU -55 -TEMP	RHU-TT5501927B	TT5501927B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260914	C
3,125	RHU -55 -TEMP	RHU-TT5501927C	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y									I				RRC	RRC-IROH	132606	C
3,126	RHU -55 -TEMP	RHU-TT5501927C	TT5501927C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260915	C
3,127	RHU -55 -TEMP	RHU-TT5501927D	INSP. FIELD INST. (ต่อทุปากมั)	INS	1Y									I				RRC	RRC-IROH	132607	C
3,128	RHU -55 -TEMP	RHU-TT5501927D	TT5501927D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260916	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,129	RHU -55 -TEMP	RHU-TT5501927E	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132608	C
3,130	RHU -55 -TEMP	RHU-TT5501927E	TT5501927E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260917	C
3,131	RHU -55 -TEMP	RHU-TT5501927F	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132609	C
3,132	RHU -55 -TEMP	RHU-TT5501927F	TT5501927F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260918	C
3,133	RHU -55 -TEMP	RHU-TT5501928A	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132610	C
3,134	RHU -55 -TEMP	RHU-TT5501928A	TT5501928A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260919	C
3,135	RHU -55 -TEMP	RHU-TT5501928B	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132611	C
3,136	RHU -55 -TEMP	RHU-TT5501928B	TT5501928B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260920	C
3,137	RHU -55 -TEMP	RHU-TT5501928C	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132612	C
3,138	RHU -55 -TEMP	RHU-TT5501928C	TT5501928C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260921	C
3,139	RHU -55 -TEMP	RHU-TT5501928D	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132613	C
3,140	RHU -55 -TEMP	RHU-TT5501928D	TT5501928D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260922	C
3,141	RHU -55 -TEMP	RHU-TT5501928E	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132614	C
3,142	RHU -55 -TEMP	RHU-TT5501928E	TT5501928E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260923	C
3,143	RHU -55 -TEMP	RHU-TT5501928F	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132615	C
3,144	RHU -55 -TEMP	RHU-TT5501928F	TT5501928F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260924	C
3,145	RHU -55 -TEMP	RHU-TT5501929A	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132616	C
3,146	RHU -55 -TEMP	RHU-TT5501929A	TT5501929A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260925	C
3,147	RHU -55 -TEMP	RHU-TT5501929B	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132617	C
3,148	RHU -55 -TEMP	RHU-TT5501929B	TT5501929B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260926	C
3,149	RHU -55 -TEMP	RHU-TT5501929C	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132618	C
3,150	RHU -55 -TEMP	RHU-TT5501929C	TT5501929C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260927	C
3,151	RHU -55 -TEMP	RHU-TT5501929D	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132619	C
3,152	RHU -55 -TEMP	RHU-TT5501929D	TT5501929D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260928	C
3,153	RHU -55 -TEMP	RHU-TT5501929E	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132620	C
3,154	RHU -55 -TEMP	RHU-TT5501929E	TT5501929E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260929	C
3,155	RHU -55 -TEMP	RHU-TT5501929F	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132621	C
3,156	RHU -55 -TEMP	RHU-TT5501929F	TT5501929F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260930	C
3,157	RHU -55 -TEMP	RHU-TT5502001A	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132622	C
3,158	RHU -55 -TEMP	RHU-TT5502001A	TT5502001A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261174	C
3,159	RHU -55 -TEMP	RHU-TT5502001B	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132623	C
3,160	RHU -55 -TEMP	RHU-TT5502001B	TT5502001B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261175	C
3,161	RHU -55 -TEMP	RHU-TT5502001C	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132624	C
3,162	RHU -55 -TEMP	RHU-TT5502001C	TT5502001C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261176	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,163	RHU -55 -TEMP	RHU-TT5502001D	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132625	C
3,164	RHU -55 -TEMP	RHU-TT5502001D	TT5502001D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261177	C
3,165	RHU -55 -TEMP	RHU-TT5502001E	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132626	C
3,166	RHU -55 -TEMP	RHU-TT5502001E	TT5502001E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261178	C
3,167	RHU -55 -TEMP	RHU-TT5502001F	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132627	C
3,168	RHU -55 -TEMP	RHU-TT5502001F	TT5502001F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261179	C
3,169	RHU -55 -TEMP	RHU-TT5502002A	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132628	C
3,170	RHU -55 -TEMP	RHU-TT5502002A	TT5502002A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261180	C
3,171	RHU -55 -TEMP	RHU-TT5502002B	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132629	C
3,172	RHU -55 -TEMP	RHU-TT5502002B	TT5502002B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261181	C
3,173	RHU -55 -TEMP	RHU-TT5502002C	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132630	C
3,174	RHU -55 -TEMP	RHU-TT5502002C	TT5502002C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261182	C
3,175	RHU -55 -TEMP	RHU-TT5502002D	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132631	C
3,176	RHU -55 -TEMP	RHU-TT5502002D	TT5502002D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261183	C
3,177	RHU -55 -TEMP	RHU-TT5502002E	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132632	C
3,178	RHU -55 -TEMP	RHU-TT5502002E	TT5502002E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261184	C
3,179	RHU -55 -TEMP	RHU-TT5502002F	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132633	C
3,180	RHU -55 -TEMP	RHU-TT5502002F	TT5502002F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261185	C
3,181	RHU -55 -TEMP	RHU-TT5502003A	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132634	C
3,182	RHU -55 -TEMP	RHU-TT5502003A	TT5502003A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261186	C
3,183	RHU -55 -TEMP	RHU-TT5502003B	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132635	C
3,184	RHU -55 -TEMP	RHU-TT5502003B	TT5502003B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261187	C
3,185	RHU -55 -TEMP	RHU-TT5502003C	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132636	C
3,186	RHU -55 -TEMP	RHU-TT5502003C	TT5502003C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261188	C
3,187	RHU -55 -TEMP	RHU-TT5502003D	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132637	C
3,188	RHU -55 -TEMP	RHU-TT5502003D	TT5502003D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261189	C
3,189	RHU -55 -TEMP	RHU-TT5502003E	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132638	C
3,190	RHU -55 -TEMP	RHU-TT5502003E	TT5502003E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261190	C
3,191	RHU -55 -TEMP	RHU-TT5502003F	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132639	C
3,192	RHU -55 -TEMP	RHU-TT5502003F	TT5502003F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261191	C
3,193	RHU -55 -TEMP	RHU-TT5502004A	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132640	C
3,194	RHU -55 -TEMP	RHU-TT5502004A	TT5502004A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261192	C
3,195	RHU -55 -TEMP	RHU-TT5502004B	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132641	C
3,196	RHU -55 -TEMP	RHU-TT5502004B	TT5502004B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261193	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,197	RHU -55 -TEMP	RHU-TT5502004C	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132642	C
3,198	RHU -55 -TEMP	RHU-TT5502004C	TT5502004C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261194	C
3,199	RHU -55 -TEMP	RHU-TT5502004D	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132643	C
3,200	RHU -55 -TEMP	RHU-TT5502004D	TT5502004D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261195	C
3,201	RHU -55 -TEMP	RHU-TT5502004E	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132644	C
3,202	RHU -55 -TEMP	RHU-TT5502004E	TT5502004E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261196	C
3,203	RHU -55 -TEMP	RHU-TT5502004F	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132645	C
3,204	RHU -55 -TEMP	RHU-TT5502004F	TT5502004F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261197	C
3,205	RHU -55 -TEMP	RHU-TT5502005A	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132646	C
3,206	RHU -55 -TEMP	RHU-TT5502005A	TT5502005A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261198	C
3,207	RHU -55 -TEMP	RHU-TT5502005B	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132647	C
3,208	RHU -55 -TEMP	RHU-TT5502005B	TT5502005B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261199	C
3,209	RHU -55 -TEMP	RHU-TT5502005C	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132648	C
3,210	RHU -55 -TEMP	RHU-TT5502005C	TT5502005C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261200	C
3,211	RHU -55 -TEMP	RHU-TT5502005D	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132649	C
3,212	RHU -55 -TEMP	RHU-TT5502005D	TT5502005D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261201	C
3,213	RHU -55 -TEMP	RHU-TT5502005E	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132650	C
3,214	RHU -55 -TEMP	RHU-TT5502005E	TT5502005E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261202	C
3,215	RHU -55 -TEMP	RHU-TT5502005F	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132651	C
3,216	RHU -55 -TEMP	RHU-TT5502005F	TT5502005F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261203	C
3,217	RHU -55 -TEMP	RHU-TT5502006A	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132652	C
3,218	RHU -55 -TEMP	RHU-TT5502006A	TT5502006A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261204	C
3,219	RHU -55 -TEMP	RHU-TT5502006B	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132653	C
3,220	RHU -55 -TEMP	RHU-TT5502006B	TT5502006B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261205	C
3,221	RHU -55 -TEMP	RHU-TT5502006C	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132654	C
3,222	RHU -55 -TEMP	RHU-TT5502006C	TT5502006C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261206	C
3,223	RHU -55 -TEMP	RHU-TT5502006D	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132655	C
3,224	RHU -55 -TEMP	RHU-TT5502006D	TT5502006D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261207	C
3,225	RHU -55 -TEMP	RHU-TT5502006E	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132656	C
3,226	RHU -55 -TEMP	RHU-TT5502006E	TT5502006E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261208	C
3,227	RHU -55 -TEMP	RHU-TT5502006F	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132657	C
3,228	RHU -55 -TEMP	RHU-TT5502006F	TT5502006F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261209	C
3,229	RHU -55 -TEMP	RHU-TT5502007A	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132658	C
3,230	RHU -55 -TEMP	RHU-TT5502007A	TT5502007A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261210	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,231	RHU -55 -TEMP	RHU-TT5502007B	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132659	C
3,232	RHU -55 -TEMP	RHU-TT5502007B	TT5502007B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261211	C
3,233	RHU -55 -TEMP	RHU-TT5502007C	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132660	C
3,234	RHU -55 -TEMP	RHU-TT5502007C	TT5502007C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261212	C
3,235	RHU -55 -TEMP	RHU-TT5502007D	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132661	C
3,236	RHU -55 -TEMP	RHU-TT5502007D	TT5502007D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261213	C
3,237	RHU -55 -TEMP	RHU-TT5502007E	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132662	C
3,238	RHU -55 -TEMP	RHU-TT5502007E	TT5502007E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261214	C
3,239	RHU -55 -TEMP	RHU-TT5502007F	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132663	C
3,240	RHU -55 -TEMP	RHU-TT5502007F	TT5502007F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261215	C
3,241	RHU -55 -TEMP	RHU-TT5502008A	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132664	C
3,242	RHU -55 -TEMP	RHU-TT5502008A	TT5502008A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261216	C
3,243	RHU -55 -TEMP	RHU-TT5502008B	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132665	C
3,244	RHU -55 -TEMP	RHU-TT5502008B	TT5502008B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261217	C
3,245	RHU -55 -TEMP	RHU-TT5502008C	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132666	C
3,246	RHU -55 -TEMP	RHU-TT5502008C	TT5502008C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261218	C
3,247	RHU -55 -TEMP	RHU-TT5502008D	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132667	C
3,248	RHU -55 -TEMP	RHU-TT5502008D	TT5502008D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261219	C
3,249	RHU -55 -TEMP	RHU-TT5502008E	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132668	C
3,250	RHU -55 -TEMP	RHU-TT5502008E	TT5502008E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261220	C
3,251	RHU -55 -TEMP	RHU-TT5502008F	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132669	C
3,252	RHU -55 -TEMP	RHU-TT5502008F	TT5502008F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261221	C
3,253	RHU -55 -TEMP	RHU-TT5502009A	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132670	C
3,254	RHU -55 -TEMP	RHU-TT5502009A	TT5502009A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261222	C
3,255	RHU -55 -TEMP	RHU-TT5502009B	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132671	C
3,256	RHU -55 -TEMP	RHU-TT5502009B	TT5502009B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261223	C
3,257	RHU -55 -TEMP	RHU-TT5502009C	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132672	C
3,258	RHU -55 -TEMP	RHU-TT5502009C	TT5502009C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261224	C
3,259	RHU -55 -TEMP	RHU-TT5502009D	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132673	C
3,260	RHU -55 -TEMP	RHU-TT5502009D	TT5502009D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261225	C
3,261	RHU -55 -TEMP	RHU-TT5502009E	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132674	C
3,262	RHU -55 -TEMP	RHU-TT5502009E	TT5502009E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261226	C
3,263	RHU -55 -TEMP	RHU-TT5502009F	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132675	C
3,264	RHU -55 -TEMP	RHU-TT5502009F	TT5502009F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261227	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,265	RHU -55 -TEMP	RHU-TT5502010A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132676	C
3,266	RHU -55 -TEMP	RHU-TT5502010A	TT5502010A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261228	C
3,267	RHU -55 -TEMP	RHU-TT5502010B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132677	C
3,268	RHU -55 -TEMP	RHU-TT5502010B	TT5502010B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261229	C
3,269	RHU -55 -TEMP	RHU-TT5502010C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132678	C
3,270	RHU -55 -TEMP	RHU-TT5502010C	TT5502010C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261230	C
3,271	RHU -55 -TEMP	RHU-TT5502010D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132679	C
3,272	RHU -55 -TEMP	RHU-TT5502010D	TT5502010D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261231	C
3,273	RHU -55 -TEMP	RHU-TT5502010E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132680	C
3,274	RHU -55 -TEMP	RHU-TT5502010E	TT5502010E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261232	C
3,275	RHU -55 -TEMP	RHU-TT5502010F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132681	C
3,276	RHU -55 -TEMP	RHU-TT5502010F	TT5502010F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261233	C
3,277	RHU -55 -TEMP	RHU-TT5502011A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132682	C
3,278	RHU -55 -TEMP	RHU-TT5502011A	TT5502011A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261234	C
3,279	RHU -55 -TEMP	RHU-TT5502011B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132683	C
3,280	RHU -55 -TEMP	RHU-TT5502011B	TT5502011B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261235	C
3,281	RHU -55 -TEMP	RHU-TT5502011C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132684	C
3,282	RHU -55 -TEMP	RHU-TT5502011C	TT5502011C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261236	C
3,283	RHU -55 -TEMP	RHU-TT5502011D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132685	C
3,284	RHU -55 -TEMP	RHU-TT5502011D	TT5502011D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261237	C
3,285	RHU -55 -TEMP	RHU-TT5502011E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132686	C
3,286	RHU -55 -TEMP	RHU-TT5502011E	TT5502011E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261238	C
3,287	RHU -55 -TEMP	RHU-TT5502011F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132687	C
3,288	RHU -55 -TEMP	RHU-TT5502011F	TT5502011F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261239	C
3,289	RHU -55 -TEMP	RHU-TT5502012A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132688	C
3,290	RHU -55 -TEMP	RHU-TT5502012A	TT5502012A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261240	C
3,291	RHU -55 -TEMP	RHU-TT5502012B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132689	C
3,292	RHU -55 -TEMP	RHU-TT5502012B	TT5502012B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261241	C
3,293	RHU -55 -TEMP	RHU-TT5502012C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132690	C
3,294	RHU -55 -TEMP	RHU-TT5502012C	TT5502012C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261242	C
3,295	RHU -55 -TEMP	RHU-TT5502012D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132691	C
3,296	RHU -55 -TEMP	RHU-TT5502012D	TT5502012D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261243	C
3,297	RHU -55 -TEMP	RHU-TT5502012E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132692	C
3,298	RHU -55 -TEMP	RHU-TT5502012E	TT5502012E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261244	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,299	RHU -55 -TEMP	RHU-TT5502012F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132693	C
3,300	RHU -55 -TEMP	RHU-TT5502012F	TT5502012F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261245	C
3,301	RHU -55 -TEMP	RHU-TT5502014	INSP. FIELD INST. (ต่อหุ้มฉนวน)	PMT	1Y									I				RRC	RRC-IROH	132694	C
3,302	RHU -55 -TEMP	RHU-TT5502015	INSP. FIELD INST. (ต่อหุ้มฉนวน)	PMT	1Y									I				RRC	RRC-IROH	132695	C
3,303	RHU -55 -TEMP	RHU-TT5502016	INSP. FIELD INST. (ต่อหุ้มฉนวน)	PMT	1Y									I				RRC	RRC-IROH	132696	C
3,304	RHU -55 -TEMP	RHU-TT5502017	INSP. FIELD INST. (ต่อหุ้มฉนวน)	PMT	1Y									I				RRC	RRC-IROH	132697	C
3,305	RHU -55 -TEMP	RHU-TT5502018A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132698	C
3,306	RHU -55 -TEMP	RHU-TT5502018A	TT5502018A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260931	C
3,307	RHU -55 -TEMP	RHU-TT5502018B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132699	C
3,308	RHU -55 -TEMP	RHU-TT5502018B	TT5502018B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260932	C
3,309	RHU -55 -TEMP	RHU-TT5502018C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132700	C
3,310	RHU -55 -TEMP	RHU-TT5502018C	TT5502018C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260933	C
3,311	RHU -55 -TEMP	RHU-TT5502018D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132701	C
3,312	RHU -55 -TEMP	RHU-TT5502018D	TT5502018D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260934	C
3,313	RHU -55 -TEMP	RHU-TT5502018E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132702	C
3,314	RHU -55 -TEMP	RHU-TT5502018E	TT5502018E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260935	C
3,315	RHU -55 -TEMP	RHU-TT5502018F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132703	C
3,316	RHU -55 -TEMP	RHU-TT5502018F	TT5502018F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260936	C
3,317	RHU -55 -TEMP	RHU-TT5502019A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132704	C
3,318	RHU -55 -TEMP	RHU-TT5502019A	TT5502019A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260937	C
3,319	RHU -55 -TEMP	RHU-TT5502019B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132705	C
3,320	RHU -55 -TEMP	RHU-TT5502019B	TT5502019B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260938	C
3,321	RHU -55 -TEMP	RHU-TT5502019C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132706	C
3,322	RHU -55 -TEMP	RHU-TT5502019C	TT5502019C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260939	C
3,323	RHU -55 -TEMP	RHU-TT5502019D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132707	C
3,324	RHU -55 -TEMP	RHU-TT5502019D	TT5502019D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260940	C
3,325	RHU -55 -TEMP	RHU-TT5502019E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132708	C
3,326	RHU -55 -TEMP	RHU-TT5502019E	TT5502019E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260941	C
3,327	RHU -55 -TEMP	RHU-TT5502019F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132709	C
3,328	RHU -55 -TEMP	RHU-TT5502019F	TT5502019F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260942	C
3,329	RHU -55 -TEMP	RHU-TT5502020A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132710	C
3,330	RHU -55 -TEMP	RHU-TT5502020A	TT5502020A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260943	C
3,331	RHU -55 -TEMP	RHU-TT5502020B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132711	C
3,332	RHU -55 -TEMP	RHU-TT5502020B	TT5502020B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260944	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,333	RHU -55 -TEMP	RHU-TT5502020C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132712	C
3,334	RHU -55 -TEMP	RHU-TT5502020C	TT5502020C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260945	C
3,335	RHU -55 -TEMP	RHU-TT5502020D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132713	C
3,336	RHU -55 -TEMP	RHU-TT5502020D	TT5502020D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260946	C
3,337	RHU -55 -TEMP	RHU-TT5502020E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132714	C
3,338	RHU -55 -TEMP	RHU-TT5502020E	TT5502020E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260947	C
3,339	RHU -55 -TEMP	RHU-TT5502020F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132715	C
3,340	RHU -55 -TEMP	RHU-TT5502020F	TT5502020F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260948	C
3,341	RHU -55 -TEMP	RHU-TT5502021A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132716	C
3,342	RHU -55 -TEMP	RHU-TT5502021A	TT5502021A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260949	C
3,343	RHU -55 -TEMP	RHU-TT5502021B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132717	C
3,344	RHU -55 -TEMP	RHU-TT5502021B	TT5502021B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260950	C
3,345	RHU -55 -TEMP	RHU-TT5502021C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132718	C
3,346	RHU -55 -TEMP	RHU-TT5502021C	TT5502021C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260951	C
3,347	RHU -55 -TEMP	RHU-TT5502021D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132719	C
3,348	RHU -55 -TEMP	RHU-TT5502021D	TT5502021D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260952	C
3,349	RHU -55 -TEMP	RHU-TT5502021E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132720	C
3,350	RHU -55 -TEMP	RHU-TT5502021E	TT5502021E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260953	C
3,351	RHU -55 -TEMP	RHU-TT5502021F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132721	C
3,352	RHU -55 -TEMP	RHU-TT5502021F	TT5502021F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260954	C
3,353	RHU -55 -TEMP	RHU-TT5502022A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132722	C
3,354	RHU -55 -TEMP	RHU-TT5502022A	TT5502022A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260955	C
3,355	RHU -55 -TEMP	RHU-TT5502022B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132723	C
3,356	RHU -55 -TEMP	RHU-TT5502022B	TT5502022B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260956	C
3,357	RHU -55 -TEMP	RHU-TT5502022C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132724	C
3,358	RHU -55 -TEMP	RHU-TT5502022C	TT5502022C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260957	C
3,359	RHU -55 -TEMP	RHU-TT5502022D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132725	C
3,360	RHU -55 -TEMP	RHU-TT5502022D	TT5502022D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260958	C
3,361	RHU -55 -TEMP	RHU-TT5502022E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132726	C
3,362	RHU -55 -TEMP	RHU-TT5502022E	TT5502022E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260959	C
3,363	RHU -55 -TEMP	RHU-TT5502022F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132727	C
3,364	RHU -55 -TEMP	RHU-TT5502022F	TT5502022F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260960	C
3,365	RHU -55 -TEMP	RHU-TT5502023A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132728	C
3,366	RHU -55 -TEMP	RHU-TT5502023A	TT5502023A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260961	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,367	RHU -55 -TEMP	RHU-TT5502023B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132729	C
3,368	RHU -55 -TEMP	RHU-TT5502023B	TT5502023B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260962	C
3,369	RHU -55 -TEMP	RHU-TT5502023C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132730	C
3,370	RHU -55 -TEMP	RHU-TT5502023C	TT5502023C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260963	C
3,371	RHU -55 -TEMP	RHU-TT5502023D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132731	C
3,372	RHU -55 -TEMP	RHU-TT5502023D	TT5502023D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260964	C
3,373	RHU -55 -TEMP	RHU-TT5502023E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132732	C
3,374	RHU -55 -TEMP	RHU-TT5502023E	TT5502023E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260965	C
3,375	RHU -55 -TEMP	RHU-TT5502023F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132733	C
3,376	RHU -55 -TEMP	RHU-TT5502023F	TT5502023F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260966	C
3,377	RHU -55 -TEMP	RHU-TT5502024A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132734	C
3,378	RHU -55 -TEMP	RHU-TT5502024A	TT5502024A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260967	C
3,379	RHU -55 -TEMP	RHU-TT5502024B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132735	C
3,380	RHU -55 -TEMP	RHU-TT5502024B	TT5502024B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260968	C
3,381	RHU -55 -TEMP	RHU-TT5502024C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132736	C
3,382	RHU -55 -TEMP	RHU-TT5502024C	TT5502024C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260969	C
3,383	RHU -55 -TEMP	RHU-TT5502024D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132737	C
3,384	RHU -55 -TEMP	RHU-TT5502024D	TT5502024D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260970	C
3,385	RHU -55 -TEMP	RHU-TT5502024E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132738	C
3,386	RHU -55 -TEMP	RHU-TT5502024E	TT5502024E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260971	C
3,387	RHU -55 -TEMP	RHU-TT5502024F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132739	C
3,388	RHU -55 -TEMP	RHU-TT5502024F	TT5502024F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260972	C
3,389	RHU -55 -TEMP	RHU-TT5502025A	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132740	C
3,390	RHU -55 -TEMP	RHU-TT5502025A	TT5502025A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260973	C
3,391	RHU -55 -TEMP	RHU-TT5502025B	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132741	C
3,392	RHU -55 -TEMP	RHU-TT5502025B	TT5502025B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260974	C
3,393	RHU -55 -TEMP	RHU-TT5502025C	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132742	C
3,394	RHU -55 -TEMP	RHU-TT5502025C	TT5502025C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260975	C
3,395	RHU -55 -TEMP	RHU-TT5502025D	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132743	C
3,396	RHU -55 -TEMP	RHU-TT5502025D	TT5502025D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260976	C
3,397	RHU -55 -TEMP	RHU-TT5502025E	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132744	C
3,398	RHU -55 -TEMP	RHU-TT5502025E	TT5502025E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260977	C
3,399	RHU -55 -TEMP	RHU-TT5502025F	INSP. FIELD INST. (ต่อหุ้มฉนวน)	INS	1Y									I				RRC	RRC-IROH	132745	C
3,400	RHU -55 -TEMP	RHU-TT5502025F	TT5502025F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260978	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,401	RHU -55 -TEMP	RHU-TT5502026A	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132746	C
3,402	RHU -55 -TEMP	RHU-TT5502026A	TT5502026A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260979	C
3,403	RHU -55 -TEMP	RHU-TT5502026B	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132747	C
3,404	RHU -55 -TEMP	RHU-TT5502026B	TT5502026B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260980	C
3,405	RHU -55 -TEMP	RHU-TT5502026C	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132748	C
3,406	RHU -55 -TEMP	RHU-TT5502026C	TT5502026C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260981	C
3,407	RHU -55 -TEMP	RHU-TT5502026D	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132749	C
3,408	RHU -55 -TEMP	RHU-TT5502026D	TT5502026D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260982	C
3,409	RHU -55 -TEMP	RHU-TT5502026E	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y									I				RRC	RRC-IROH	132750	C
3,410	RHU -55 -TEMP	RHU-TT5502026E	TT5502026E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260983	C
3,411	RHU -55 -TEMP	RHU-TT5502026F	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y										I			RRC	RRC-IROH	132751	C
3,412	RHU -55 -TEMP	RHU-TT5502026F	TT5502026F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260984	C
3,413	RHU -55 -TEMP	RHU-TT5502027A	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y										I			RRC	RRC-IROH	132752	C
3,414	RHU -55 -TEMP	RHU-TT5502027A	TT5502027A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260985	C
3,415	RHU -55 -TEMP	RHU-TT5502027B	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y										I			RRC	RRC-IROH	132753	C
3,416	RHU -55 -TEMP	RHU-TT5502027B	TT5502027B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260986	C
3,417	RHU -55 -TEMP	RHU-TT5502027C	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y										I			RRC	RRC-IROH	132754	C
3,418	RHU -55 -TEMP	RHU-TT5502027C	TT5502027C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260987	C
3,419	RHU -55 -TEMP	RHU-TT5502027D	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y										I			RRC	RRC-IROH	132755	C
3,420	RHU -55 -TEMP	RHU-TT5502027D	TT5502027D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260988	C
3,421	RHU -55 -TEMP	RHU-TT5502027E	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y										I			RRC	RRC-IROH	132756	C
3,422	RHU -55 -TEMP	RHU-TT5502027E	TT5502027E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260989	C
3,423	RHU -55 -TEMP	RHU-TT5502027F	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y										I			RRC	RRC-IROH	132757	C
3,424	RHU -55 -TEMP	RHU-TT5502027F	TT5502027F-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260990	C
3,425	RHU -55 -TEMP	RHU-TT5502028A	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y										I			RRC	RRC-IROH	132758	C
3,426	RHU -55 -TEMP	RHU-TT5502028A	TT5502028A-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260991	C
3,427	RHU -55 -TEMP	RHU-TT5502028B	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y										I			RRC	RRC-IROH	132759	C
3,428	RHU -55 -TEMP	RHU-TT5502028B	TT5502028B-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260992	C
3,429	RHU -55 -TEMP	RHU-TT5502028C	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y										I			RRC	RRC-IROH	132760	C
3,430	RHU -55 -TEMP	RHU-TT5502028C	TT5502028C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260993	C
3,431	RHU -55 -TEMP	RHU-TT5502028D	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y										I			RRC	RRC-IROH	132761	C
3,432	RHU -55 -TEMP	RHU-TT5502028D	TT5502028D-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260994	C
3,433	RHU -55 -TEMP	RHU-TT5502028E	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y										I			RRC	RRC-IROH	132762	C
3,434	RHU -55 -TEMP	RHU-TT5502028E	TT5502028E-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	260995	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,435	RHU -55 -TEMP	RHU-TT5502028F	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y											I		RRC	RRC-IROH	132763	C
3,436	RHU -55 -TEMP	RHU-TT5502028F	TT5502028F-FULLFUN TEST TEMP.T	PMT	5Y												F	RRC	RRC-IROH	260996	C
3,437	RHU -55 -TEMP	RHU-TT5502029A	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y											I		RRC	RRC-IROH	132764	C
3,438	RHU -55 -TEMP	RHU-TT5502029A	TT5502029A-FULLFUN TEST TEMP.T	PMT	5Y												F	RRC	RRC-IROH	260997	C
3,439	RHU -55 -TEMP	RHU-TT5502029B	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y											I		RRC	RRC-IROH	132765	C
3,440	RHU -55 -TEMP	RHU-TT5502029B	TT5502029B-FULLFUN TEST TEMP.T	PMT	5Y												F	RRC	RRC-IROH	260998	C
3,441	RHU -55 -TEMP	RHU-TT5502029C	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y											I		RRC	RRC-IROH	132766	C
3,442	RHU -55 -TEMP	RHU-TT5502029C	TT5502029C-FULLFUN TEST TEMP.T	PMT	5Y												F	RRC	RRC-IROH	260999	C
3,443	RHU -55 -TEMP	RHU-TT5502029D	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y											I		RRC	RRC-IROH	132767	C
3,444	RHU -55 -TEMP	RHU-TT5502029D	TT5502029D-FULLFUN TEST TEMP.T	PMT	5Y												F	RRC	RRC-IROH	261000	C
3,445	RHU -55 -TEMP	RHU-TT5502029E	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y											I		RRC	RRC-IROH	132768	C
3,446	RHU -55 -TEMP	RHU-TT5502029E	TT5502029E-FULLFUN TEST TEMP.T	PMT	5Y												F	RRC	RRC-IROH	261001	C
3,447	RHU -55 -TEMP	RHU-TT5502029F	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y											I		RRC	RRC-IROH	132769	C
3,448	RHU -55 -TEMP	RHU-TT5502029F	TT5502029F-FULLFUN TEST TEMP.T	PMT	5Y												F	RRC	RRC-IROH	261002	C
3,449	RHU -55 -TEMP	RHU-TT5502101	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y											I		RRC	RRC-IROH	132770	C
3,450	RHU -55 -TEMP	RHU-TT5502104	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y											I		RRC	RRC-IROH	132771	C
3,451	RHU -55 -TEMP	RHU-TT5502109	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y											I		RRC	RRC-IROH	132772	C
3,452	RHU -55 -TEMP	RHU-TT5502110	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y											I		RRC	RRC-IROH	132773	C
3,453	RHU -55 -TEMP	RHU-TT5502112	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y											I		RRC	RRC-IROH	132774	C
3,454	RHU -55 -TEMP	RHU-TT5502113	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y											I		RRC	RRC-IROH	132775	C
3,455	RHU -55 -TEMP	RHU-TT5502115	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y											I		RRC	RRC-IROH	132776	C
3,456	RHU -55 -TEMP	RHU-TT5502201	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y											I		RRC	RRC-IROH	132777	C
3,457	RHU -55 -TEMP	RHU-TT5502202	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y											I		RRC	RRC-IROH	132778	C
3,458	RHU -55 -TEMP	RHU-TT5502203	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y											I		RRC	RRC-IROH	132779	C
3,459	RHU -55 -TEMP	RHU-TT5502301	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y											I		RRC	RRC-IROH	132780	C
3,460	RHU -55 -TEMP	RHU-TT5502302	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y											I		RRC	RRC-IROH	132781	C
3,461	RHU -55 -TEMP	RHU-TT5502303	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y											I		RRC	RRC-IROH	132782	C
3,462	RHU -55 -TEMP	RHU-TT5502304	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y											I		RRC	RRC-IROH	132783	C
3,463	RHU -55 -55P103	RHU-TT5502305A	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y											I		RRC	RRC-IROH	132815	C
3,464	RHU -55 -55P103	RHU-TT5502305B	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y											I		RRC	RRC-IROH	132816	C
3,465	RHU -55 -TEMP	RHU-TT5502501A	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y											I		RRC	RRC-IROH	132784	C
3,466	RHU -55 -TEMP	RHU-TT5502501A	TT5502501A-FULLFUN TEST TEMP.T	PMT	5Y												F	RRC	RRC-IROH	261003	C
3,467	RHU -55 -TEMP	RHU-TT5502501B	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y											I		RRC	RRC-IROH	132785	C
3,468	RHU -55 -TEMP	RHU-TT5502501B	TT5502501B-FULLFUN TEST TEMP.T	PMT	5Y												F	RRC	RRC-IROH	261004	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,469	RHU -55 -TEMP	RHU-TT5502501C	INSP. FIELD INST. (ตรวจบำรุงรักษา)	INS	1Y										I			RRC	RRC-IROH	132786	C
3,470	RHU -55 -TEMP	RHU-TT5502501C	TT5502501C-FULLFUN TEST TEMP.T	PMT	5Y											F		RRC	RRC-IROH	261005	C
3,471	RHU -55 -TEMP	RHU-TT5502502	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y										I			RRC	RRC-IROH	132787	C
3,472	RHU -55 -TEMP	RHU-TT5502503	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y										I			RRC	RRC-IROH	132788	C
3,473	RHU -55 -TEMP	RHU-TT5530101	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y										I			RRC	RRC-IROH	132789	C
3,474	RHU -55 -TEMP	RHU-TT5530102	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y										I			RRC	RRC-IROH	132790	C
3,475	RHU -55 -TEMP	RHU-TT5531101	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y										I			RRC	RRC-IROH	132791	C
3,476	RHU -55 -TEMP	RHU-TT5531103	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y										I			RRC	RRC-IROH	132792	C
3,477	RHU -55 -TEMP	RHU-TT5534101	INSP. FIELD INST. (ตรวจบำรุงรักษา)	PMT	1Y										I			RRC	RRC-IROH	132793	C
3,478	RHU -52 -CV	RHU-TV5200201	INSPECT CONTROL VALVE NO. TV52	PMT	1Y											I		RRC	RRC-IROH	132957	C
3,479	RHU -52 -CV	RHU-TV5200901A	INSPECT CONTROL VALVE NO. TV52	PMT	1Y											I		RRC	RRC-IROH	132958	C
3,480	RHU -52 -CV	RHU-TV5200901B	INSPECT CONTROL VALVE NO. TV52	PMT	1Y											I		RRC	RRC-IROH	132959	C
3,481	RHU -52 -CV	RHU-TV5201304	INSPECT CONTROL VALVE NO. TV52	PMT	1Y											I		RRC	RRC-IROH	132960	C
3,482	RHU -52 -CV	RHU-TV5202501A	INSPECT CONTROL VALVE NO. TV52	PMT	1Y											I		RRC	RRC-IROH	132961	C
3,483	RHU -52 -CV	RHU-TV5202501B	INSPECT CONTROL VALVE NO. TV52	PMT	1Y											I		RRC	RRC-IROH	132962	C
3,484	RHU -52 -CV	RHU-TV5204004	INSPECT CONTROL VALVE NO. TV52	PMT	1Y											I		RRC	RRC-IROH	132983	C
3,485	RHU -52 -52P001AB	RHU-TV5253204A	INSPECT CONTROL VALVE NO. TV52	PMT	1Y												I	RRC	RRC-IROH	133185	C
3,486	RHU -52 -52P001AB	RHU-TV5253704B	INSPECT CONTROL VALVE NO. TV52	PMT	1Y												I	RRC	RRC-IROH	133186	C
3,487	RHU -52 -CV	RHU-TV5284301	INSPECT CONTROL VALVE NO. TV52	PMT	1Y											I		RRC	RRC-IROH	132963	C
3,488	RHU -55 -CV	RHU-TV5501601A	INSPECT CONTROL VALVE NO. TV55	PMT	1Y											I		RRC	RRC-IROH	132964	C
3,489	RHU -55 -CV	RHU-TV5501601B	INSPECT CONTROL VALVE NO. TV55	PMT	1Y											I		RRC	RRC-IROH	132965	C
3,490	RHU -55 -CV	RHU-TV5501602	INSPECT CONTROL VALVE NO. TV55	PMT	1Y											I		RRC	RRC-IROH	132966	C
3,491	RHU -55 -CV	RHU-TV5501901A	INSPECT CONTROL VALVE NO. TV55	PMT	1Y											I		RRC	RRC-IROH	132967	C
3,492	RHU -55 -CV	RHU-TV5501901B	INSPECT CONTROL VALVE NO. TV55	PMT	1Y											I		RRC	RRC-IROH	132968	C
3,493	RHU -55 -CV	RHU-TV5502001A	INSPECT CONTROL VALVE NO. TV55	PMT	1Y											I		RRC	RRC-IROH	132969	C
3,494	RHU -55 -CV	RHU-TV5502001B	INSPECT CONTROL VALVE NO. TV55	PMT	1Y											I		RRC	RRC-IROH	132970	C
3,495	RHU -55 -CV	RHU-TV5502101	INSPECT CONTROL VALVE NO. TV55	PMT	1Y											I		RRC	RRC-IROH	132971	C
3,496	RHU -55 -55E111A	RHU-VSD-B8-4001-07	Inspec VSD FOR 55E111A-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254163	B
3,497	RHU -55 -55E111B	RHU-VSD-B8-4001-08	Inspec VSD FOR 55E111B-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254164	B
3,498	RHU -52 -CV	RHU-XV5200101	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251242	C
3,499	RHU -52 -CV	RHU-XV5200101	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251106	C
3,500	RHU -52 -CV	RHU-XV5200102	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	132985	C
3,501	RHU -52 -CV	RHU-XV5200102	XV5200102-FULL FUNC. TEST SHUT	PMT	5Y												F	RRC	RRC-IROH	261414	C
3,502	RHU -52 -CV	RHU-XV5200201	INSPECT CONTROL VALVE NO. XV52	PMT	1Y											I		RRC	RRC-IROH	132986	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,503	RHU -52 -CV	RHU-XV5200801	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	132987	C
3,504	RHU -52 -CV	RHU-XV5200801	XV5200801-FULL FUNC. TEST SHUT	PMT	5Y												F	RRC	RRC-IROH	261415	C
3,505	RHU -52 -CV	RHU-XV5201001	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	132988	C
3,506	RHU -52 -CV	RHU-XV5201001	XV5201001-FULL FUNC. TEST SHUT	PMT	5Y												F	RRC	RRC-IROH	261416	C
3,507	RHU -52 -CV	RHU-XV5201002	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	132989	C
3,508	RHU -52 -CV	RHU-XV5201002	XV5201002-FULL FUNC. TEST SHUT	PMT	5Y												F	RRC	RRC-IROH	261417	C
3,509	RHU -52 -CV	RHU-XV5201003	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	132990	C
3,510	RHU -52 -CV	RHU-XV5201003	XV5201003-FULL FUNC. TEST SHUT	PMT	5Y												F	RRC	RRC-IROH	261419	C
3,511	RHU -52 -CV	RHU-XV5201004	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	132991	C
3,512	RHU -52 -CV	RHU-XV5201004	XV5201004-FULL FUNC. TEST SHUT	PMT	5Y												F	RRC	RRC-IROH	261418	C
3,513	RHU -52 -CV	RHU-XV5201101	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	132992	C
3,514	RHU -52 -CV	RHU-XV5201101	XV5201101-FULL FUNC. TEST SHUT	PMT	5Y												F	RRC	RRC-IROH	261420	C
3,515	RHU -52 -CV	RHU-XV5201102	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	132993	C
3,516	RHU -52 -CV	RHU-XV5201102	XV5201102-FULL FUNC. TEST SHUT	PMT	5Y												F	RRC	RRC-IROH	261421	C
3,517	RHU -52 -CV	RHU-XV5201103	INSPECT CONTROL VALVE NO. XV52	PMT	1Y											I		RRC	RRC-IROH	132994	C
3,518	RHU -52 -CV	RHU-XV5201201	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	132995	C
3,519	RHU -52 -CV	RHU-XV5201201	XV5201201-FULL FUNC. TEST SHUT	PMT	5Y												F	RRC	RRC-IROH	261422	C
3,520	RHU -52 -CV	RHU-XV5201301	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251243	C
3,521	RHU -52 -CV	RHU-XV5201301	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251108	C
3,522	RHU -52 -CV	RHU-XV5201302	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251244	C
3,523	RHU -52 -CV	RHU-XV5201302	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251110	C
3,524	RHU -52 -CV	RHU-XV5201401	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251245	C
3,525	RHU -52 -CV	RHU-XV5201401	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251112	C
3,526	RHU -52 -CV	RHU-XV5201601	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251282	C
3,527	RHU -52 -CV	RHU-XV5201601	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251114	C
3,528	RHU -52 -CV	RHU-XV5201901	INSPECT CONTROL VALVE NO. XV52	PMT	1Y											I		RRC	RRC-IROH	133000	C
3,529	RHU -52 -CV	RHU-XV5201902	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	133001	C
3,530	RHU -52 -CV	RHU-XV5201902	XV5201902-FULL FUNC. TEST SHUT	PMT	5Y												F	RRC	RRC-IROH	261423	C
3,531	RHU -52 -CV	RHU-XV5201903	INSPECT CONTROL VALVE NO. XV52	PMT	1Y											I		RRC	RRC-IROH	133002	C
3,532	RHU -52 -CV	RHU-XV5202001	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	133003	C
3,533	RHU -52 -CV	RHU-XV5202001	XV5202001-FULL FUNC. TEST SHUT	PMT	5Y												F	RRC	RRC-IROH	261424	C
3,534	RHU -52 -CV	RHU-XV5202101	INSPECT CONTROL VALVE NO. XV52	PMT	1Y											I		RRC	RRC-IROH	133004	C
3,535	RHU -52 -CV	RHU-XV5202102	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	133005	C
3,536	RHU -52 -CV	RHU-XV5202102	XV5202102-FULL FUNC. TEST SHUT	PMT	5Y												F	RRC	RRC-IROH	261425	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,537	RHU -52 -CV	RHU-XV5202103	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251283	C
3,538	RHU -52 -CV	RHU-XV5202103	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251116	C
3,539	RHU -52 -CV	RHU-XV5202202	INSPECT CONTROL VALVE NO. XV52	PMT	1Y											I		RRC	RRC-IROH	133007	C
3,540	RHU -52 -CV	RHU-XV5202301	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251284	C
3,541	RHU -52 -CV	RHU-XV5202301	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251118	C
3,542	RHU -52 -CV	RHU-XV5202302	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	133009	C
3,543	RHU -52 -CV	RHU-XV5202302	XV5202302-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261426	C
3,544	RHU -52 -CV	RHU-XV5202303	INSPECT CONTROL VALVE NO. XV52	PMT	1Y											I		RRC	RRC-IROH	133010	C
3,545	RHU -52 -CV	RHU-XV5202401	INSPECT CONTROL VALVE NO. XV52	PMT	1Y											I		RRC	RRC-IROH	133011	C
3,546	RHU -52 -CV	RHU-XV5202402	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	133012	C
3,547	RHU -52 -CV	RHU-XV5202402	XV5202402-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261428	C
3,548	RHU -52 -CV	RHU-XV5202601	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	133013	C
3,549	RHU -52 -CV	RHU-XV5202601	XV5202601-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261427	C
3,550	RHU -52 -CV	RHU-XV5202701	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	133014	C
3,551	RHU -52 -CV	RHU-XV5202701	XV5202701-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261429	C
3,552	RHU -52 -CV	RHU-XV5202702	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	133015	C
3,553	RHU -52 -CV	RHU-XV5202702	XV5202702-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261430	C
3,554	RHU -52 -CV	RHU-XV5202801	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	133016	C
3,555	RHU -52 -CV	RHU-XV5202801	XV5202801-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261431	C
3,556	RHU -52 -CV	RHU-XV5202901	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	133017	C
3,557	RHU -52 -CV	RHU-XV5202901	XV5202901-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261433	C
3,558	RHU -52 -CV	RHU-XV5202902	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	133018	C
3,559	RHU -52 -CV	RHU-XV5202902	XV5202902-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261432	C
3,560	RHU -52 -CV	RHU-XV5203101	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251285	C
3,561	RHU -52 -CV	RHU-XV5203101	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251120	C
3,562	RHU -52 -CV	RHU-XV5203201	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	133020	C
3,563	RHU -52 -CV	RHU-XV5203201	XV5203201-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261434	C
3,564	RHU -52 -CV	RHU-XV5203202	INSPECT CONTROL VALVE NO. XV52	PMT	1Y											I		RRC	RRC-IROH	133021	C
3,565	RHU -52 -CV	RHU-XV5203301	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251286	C
3,566	RHU -52 -CV	RHU-XV5203301	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251122	C
3,567	RHU -52 -CV	RHU-XV5203302	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	133023	C
3,568	RHU -52 -CV	RHU-XV5203302	XV5203302-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261435	C
3,569	RHU -52 -CV	RHU-XV5203303	INSPECT CONTROL VALVE NO. XV52	PMT	1Y											I		RRC	RRC-IROH	133024	C
3,570	RHU -52 -CV	RHU-XV5203501	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251287	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,571	RHU -52 -CV	RHU-XV5203501	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251124	C
3,572	RHU -52 -CV	RHU-XV5203502	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251288	C
3,573	RHU -52 -CV	RHU-XV5203502	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251126	C
3,574	RHU -52 -CV	RHU-XV5204001A	INSPECT CONTROL VALVE NO. XV52	PMT	1Y											I		RRC	RRC-IROH	133027	C
3,575	RHU -52 -CV	RHU-XV5204201	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	133028	C
3,576	RHU -52 -CV	RHU-XV5204201	XV5204201-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261436	C
3,577	RHU -52 -CV	RHU-XV5204202	INSPECT CONTROL VALVE NO. XV52	PMT	1Y											I		RRC	RRC-IROH	133029	C
3,578	RHU -52 -CV	RHU-XV5204203	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	133030	C
3,579	RHU -52 -CV	RHU-XV5204203	XV5204203-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261437	C
3,580	RHU -52 -CV	RHU-XV5204204	INSPECT CONTROL VALVE NO. XV52	PMT	1Y											I		RRC	RRC-IROH	133031	C
3,581	RHU -52 -CV	RHU-XV5204205	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	133032	C
3,582	RHU -52 -CV	RHU-XV5204205	XV5204205-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261438	C
3,583	RHU -52 -CV	RHU-XV5204206	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	133033	C
3,584	RHU -52 -CV	RHU-XV5204206	XV5204206-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261439	C
3,585	RHU -52 -CV	RHU-XV5204207	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	133034	C
3,586	RHU -52 -CV	RHU-XV5204207	XV5204207-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261440	C
3,587	RHU -52 -CV	RHU-XV5204208	INSPECT CONTROL VALVE NO. XV52	INS	1Y											I		RRC	RRC-IROH	133035	C
3,588	RHU -52 -CV	RHU-XV5204208	XV5204208-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261441	C
3,589	RHU -52 -CV	RHU-XV5250203A	INSPECT CONTROL VALVE NO. XV52	PMT	1Y											I		RRC	RRC-IROH	133036	C
3,590	RHU -52 -CV	RHU-XV5250203B	INSPECT CONTROL VALVE NO. XV52	PMT	1Y											I		RRC	RRC-IROH	133037	C
3,591	RHU -52 -CV	RHU-XV5250203C	INSPECT CONTROL VALVE NO. XV52	PMT	1Y											I		RRC	RRC-IROH	133038	C
3,592	RHU -52 -CV	RHU-XV5284301	INSPECT CONTROL VALVE NO. XV52	PMT	1Y											I		RRC	RRC-IROH	133039	C
3,593	RHU -55 -CV	RHU-XV5500101	INSPECT CONTROL VALVE NO. XV55	INS	1Y											I		RRC	RRC-IROH	133040	C
3,594	RHU -55 -CV	RHU-XV5500101	XV5500101-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261401	C
3,595	RHU -55 -CV	RHU-XV5500102	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251305	C
3,596	RHU -55 -CV	RHU-XV5500102	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251160	C
3,597	RHU -55 -CV	RHU-XV5500103	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251306	C
3,598	RHU -55 -CV	RHU-XV5500103	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251162	C
3,599	RHU -55 -CV	RHU-XV5500201	INSPECT CONTROL VALVE NO. XV55	PMT	1Y											I		RRC	RRC-IROH	133043	C
3,600	RHU -55 -CV	RHU-XV5500202	INSPECT CONTROL VALVE NO. XV55	PMT	1Y											I		RRC	RRC-IROH	133044	C
3,601	RHU -55 -CV	RHU-XV5500203	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251307	C
3,602	RHU -55 -CV	RHU-XV5500203	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251164	C
3,603	RHU -55 -CV	RHU-XV5500204	INSPECT CONTROL VALVE NO. XV55	PMT	1Y											I		RRC	RRC-IROH	133046	C
3,604	RHU -55 -CV	RHU-XV5500401	INSPECT CONTROL VALVE NO. XV55	INS	1Y											I		RRC	RRC-IROH	133047	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,605	RHU -55 -CV	RHU-XV5500401	XV5500401-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261402	C
3,606	RHU -55 -CV	RHU-XV5500402	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251308	C
3,607	RHU -55 -CV	RHU-XV5500402	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251166	C
3,608	RHU -55 -CV	RHU-XV5500403	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251309	C
3,609	RHU -55 -CV	RHU-XV5500403	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251168	C
3,610	RHU -55 -CV	RHU-XV5500501	INSPECT CONTROL VALVE NO. XV55	INS	1Y											I		RRC	RRC-IROH	133050	C
3,611	RHU -55 -CV	RHU-XV5500501	XV5500501-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261403	C
3,612	RHU -55 -CV	RHU-XV5500601	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251310	C
3,613	RHU -55 -CV	RHU-XV5500601	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251170	C
3,614	RHU -55 -CV	RHU-XV5500602	INSPECT CONTROL VALVE NO. XV55	PMT	1Y											I		RRC	RRC-IROH	133052	C
3,615	RHU -55 -CV	RHU-XV5500603	INSPECT CONTROL VALVE NO. XV55	PMT	1Y											I		RRC	RRC-IROH	133053	C
3,616	RHU -55 -CV	RHU-XV5500604	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251311	C
3,617	RHU -55 -CV	RHU-XV5500604	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251172	C
3,618	RHU -55 -CV	RHU-XV5500701	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251312	C
3,619	RHU -55 -CV	RHU-XV5500701	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251174	C
3,620	RHU -55 -CV	RHU-XV5500801	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133056	C
3,621	RHU -55 -CV	RHU-XV5500802	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133057	C
3,622	RHU -55 -CV	RHU-XV5500803	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133058	C
3,623	RHU -55 -CV	RHU-XV5500804	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133059	C
3,624	RHU -55 -CV	RHU-XV5500805	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133060	C
3,625	RHU -55 -CV	RHU-XV5500806	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133061	C
3,626	RHU -55 -CV	RHU-XV5500807	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133062	C
3,627	RHU -55 -CV	RHU-XV5500901	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133063	C
3,628	RHU -55 -CV	RHU-XV5500902	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133064	C
3,629	RHU -55 -CV	RHU-XV5500903	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133065	C
3,630	RHU -55 -CV	RHU-XV5500904	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133066	C
3,631	RHU -55 -CV	RHU-XV5500905	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133067	C
3,632	RHU -55 -CV	RHU-XV5500906	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133068	C
3,633	RHU -55 -CV	RHU-XV5500907	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133069	C
3,634	RHU -55 -CV	RHU-XV5501001	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133070	C
3,635	RHU -55 -CV	RHU-XV5501002	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133071	C
3,636	RHU -55 -CV	RHU-XV5501003	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133072	C
3,637	RHU -55 -CV	RHU-XV5501004	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133073	C
3,638	RHU -55 -CV	RHU-XV5501005	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133074	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,639	RHU -55 -CV	RHU-XV5501006	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133075	C
3,640	RHU -55 -CV	RHU-XV5501007	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133076	C
3,641	RHU -55 -CV	RHU-XV5501008	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251313	C
3,642	RHU -55 -CV	RHU-XV5501008	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251176	C
3,643	RHU -55 -CV	RHU-XV5501101	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133078	C
3,644	RHU -55 -CV	RHU-XV5501102	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133079	C
3,645	RHU -55 -CV	RHU-XV5501103	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133080	C
3,646	RHU -55 -CV	RHU-XV5501104	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133081	C
3,647	RHU -55 -CV	RHU-XV5501105	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133082	C
3,648	RHU -55 -CV	RHU-XV5501106	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133083	C
3,649	RHU -55 -CV	RHU-XV5501107	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133084	C
3,650	RHU -55 -CV	RHU-XV5501108	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133085	C
3,651	RHU -55 -CV	RHU-XV5501201	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133086	C
3,652	RHU -55 -CV	RHU-XV5501202	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133087	C
3,653	RHU -55 -CV	RHU-XV5501203	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133088	C
3,654	RHU -55 -CV	RHU-XV5501204	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133089	C
3,655	RHU -55 -CV	RHU-XV5501205	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133090	C
3,656	RHU -55 -CV	RHU-XV5501206	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133091	C
3,657	RHU -55 -CV	RHU-XV5501301	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133092	C
3,658	RHU -55 -CV	RHU-XV5501302	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133093	C
3,659	RHU -55 -CV	RHU-XV5501303	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133094	C
3,660	RHU -55 -CV	RHU-XV5501304	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133095	C
3,661	RHU -55 -CV	RHU-XV5501305	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133096	C
3,662	RHU -55 -CV	RHU-XV5501306	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133097	C
3,663	RHU -55 -CV	RHU-XV5501307	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133098	C
3,664	RHU -55 -CV	RHU-XV5501401	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251314	C
3,665	RHU -55 -CV	RHU-XV5501401	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251178	C
3,666	RHU -55 -CV	RHU-XV5501501	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251315	C
3,667	RHU -55 -CV	RHU-XV5501501	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251180	C
3,668	RHU -55 -CV	RHU-XV5501502	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251316	C
3,669	RHU -55 -CV	RHU-XV5501502	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251182	C
3,670	RHU -55 -CV	RHU-XV5501503	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133102	C
3,671	RHU -55 -CV	RHU-XV5501504	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251317	C
3,672	RHU -55 -CV	RHU-XV5501504	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251184	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,673	RHU -55 -CV	RHU-XV5501505	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251318	C
3,674	RHU -55 -CV	RHU-XV5501505	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251186	C
3,675	RHU -55 -CV	RHU-XV5501601	INSPECT CONTROL VALVE NO. XV55	PMT	1Y											I		RRC	RRC-IROH	133105	C
3,676	RHU -55 -CV	RHU-XV5501602	INSPECT CONTROL VALVE NO. XV55	PMT	1Y											I		RRC	RRC-IROH	133106	C
3,677	RHU -55 -CV	RHU-XV5501603	INSPECT CONTROL VALVE NO. XV55	PMT	1Y											I		RRC	RRC-IROH	133107	C
3,678	RHU -55 -CV	RHU-XV5501604	INSPECT CONTROL VALVE NO. XV55	PMT	1Y											I		RRC	RRC-IROH	133108	C
3,679	RHU -55 -CV	RHU-XV5501605	INSPECT CONTROL VALVE NO. XV55	INS	1Y											I		RRC	RRC-IROH	133109	C
3,680	RHU -55 -CV	RHU-XV5501605	XV5501605-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261404	C
3,681	RHU -55 -CV	RHU-XV5501701	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251319	C
3,682	RHU -55 -CV	RHU-XV5501701	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251188	C
3,683	RHU -55 -CV	RHU-XV5501702	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251320	C
3,684	RHU -55 -CV	RHU-XV5501702	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251190	C
3,685	RHU -55 -CV	RHU-XV5501703	INSPECT CONTROL VALVE NO. XV55	INS	1Y											I		RRC	RRC-IROH	133112	C
3,686	RHU -55 -CV	RHU-XV5501703	XV5501703-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261405	C
3,687	RHU -55 -CV	RHU-XV5501704	INSPECT CONTROL VALVE NO. XV55	INS	1Y											I		RRC	RRC-IROH	133113	C
3,688	RHU -55 -CV	RHU-XV5501704	XV5501704-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261406	C
3,689	RHU -55 -CV	RHU-XV5501801	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251321	C
3,690	RHU -55 -CV	RHU-XV5501801	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251192	C
3,691	RHU -55 -CV	RHU-XV5501802	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251322	C
3,692	RHU -55 -CV	RHU-XV5501802	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251194	C
3,693	RHU -55 -CV	RHU-XV5501803	INSPECT CONTROL VALVE NO. XV55	INS	1Y											I		RRC	RRC-IROH	133116	C
3,694	RHU -55 -CV	RHU-XV5501803	XV5501803-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261407	C
3,695	RHU -55 -CV	RHU-XV5501804	INSPECT CONTROL VALVE NO. XV55	INS	1Y											I		RRC	RRC-IROH	133117	C
3,696	RHU -55 -CV	RHU-XV5501804	XV5501804-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261408	C
3,697	RHU -55 -CV	RHU-XV5501805	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251323	C
3,698	RHU -55 -CV	RHU-XV5501805	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251196	C
3,699	RHU -55 -CV	RHU-XV5501806	INSPECT CONTROL VALVE NO. XV55	PMT	1Y											I		RRC	RRC-IROH	133119	C
3,700	RHU -55 -CV	RHU-XV5501901	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251324	C
3,701	RHU -55 -CV	RHU-XV5501901	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251198	C
3,702	RHU -55 -CV	RHU-XV5501902	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251325	C
3,703	RHU -55 -CV	RHU-XV5501902	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251200	C
3,704	RHU -55 -CV	RHU-XV5501903	INSPECT CONTROL VALVE NO. XV55	INS	1Y											I		RRC	RRC-IROH	133122	C
3,705	RHU -55 -CV	RHU-XV5501903	XV5501903-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261409	C
3,706	RHU -55 -CV	RHU-XV5501904	INSPECT CONTROL VALVE NO. XV55	INS	1Y											I		RRC	RRC-IROH	133123	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,707	RHU -55 -CV	RHU-XV5501904	XV5501904-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261410	C
3,708	RHU -55 -CV	RHU-XV5502001	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251326	C
3,709	RHU -55 -CV	RHU-XV5502001	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251202	C
3,710	RHU -55 -CV	RHU-XV5502002	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251327	C
3,711	RHU -55 -CV	RHU-XV5502002	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251204	C
3,712	RHU -55 -CV	RHU-XV5502003	INSPECT CONTROL VALVE NO. XV55	INS	1Y												I	RRC	RRC-IROH	133126	C
3,713	RHU -55 -CV	RHU-XV5502003	XV5502003-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261411	C
3,714	RHU -55 -CV	RHU-XV5502004	INSPECT CONTROL VALVE NO. XV55	INS	1Y												I	RRC	RRC-IROH	133127	C
3,715	RHU -55 -CV	RHU-XV5502004	XV5502004-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261412	C
3,716	RHU -55 -CV	RHU-XV5502101	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251328	C
3,717	RHU -55 -CV	RHU-XV5502101	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251206	C
3,718	RHU -55 -CV	RHU-XV5502102	INSPECT CONTROL VALVE NO. XV55	INS	1Y												I	RRC	RRC-IROH	133129	C
3,719	RHU -55 -CV	RHU-XV5502102	XV5502102-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261413	C
3,720	RHU -55 -CV	RHU-XV5502201	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251329	C
3,721	RHU -55 -CV	RHU-XV5502201	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251208	C
3,722	RHU -55 -CV	RHU-XV5502202	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133131	C
3,723	RHU -55 -CV	RHU-XV5502203	TO PREVENT FAILURE ON DEMAND	INS	1Y											I		RRC	RRC-IROH	251330	C
3,724	RHU -55 -CV	RHU-XV5502203	TO PREVENT FAILURE ON DEMAND	PMS	5Y		F											RRC	RRC-IROH	251210	C
3,725	RHU -55 -CV	RHU-XV5502501	INSPECT CONTROL VALVE NO. XV55	PMT	1Y												I	RRC	RRC-IROH	133133	C
3,726	RHU -52 -52E004A	SS1-52E004A-VSD	Inspec VSD FOR 52E004A-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254147	B
3,727	RHU -52 -52E004B	SS1-52E004B-VSD	Inspec VSD FOR 52E004B-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254148	B
3,728	RHU -52 -52E004C	SS1-52E004C-VSD	Inspec VSD FOR 52E004C-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254149	B
3,729	RHU -52 -52E004D	SS1-52E004D-VSD	Inspec VSD FOR 52E004D-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254150	B
3,730	RHU -52 -52E005	SS1-52E005-VSD	Inspec VSD FOR 52E005-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254151	A
3,731	RHU -52 -52E011A	SS1-52E011A-VSD	Inspec VSD FOR 52E011A-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254152	C
3,732	RHU -52 -52E011B	SS1-52E011B-VSD	Inspec VSD FOR 52E011B-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254153	C
3,733	RHU -52 -52E011C	SS1-52E011C-VSD	Inspec VSD FOR 52E011C-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254154	C
3,734	RHU -52 -52E102	SS1-52E102-VSD	Inspec VSD FOR 52E102-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254155	C
3,735	RHU -52 -52E103	SS1-52E103-VSD	Inspec VSD FOR 52E103-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254156	C
3,736	RHU -52 -52K002A	SS1-B7-2001-A09	INSPECT MV SMGR & CB B7-2001-A09	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-EROH	138266	B
3,737	RHU -52 -52P001A	SS1-B7-2001-A10	INSPECT MV SMGR & CB B7-2001-A10	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-EROH	138263	C
3,738	RHU -52 -52P002A	SS1-B7-2001-A11	INSPECT MV SMGR & CB B7-2001-A11	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-EROH	138262	C
3,739	RHU -52 -52P007A	SS1-B7-2001-A12	INSPECT MV SMGR & CB B7-2001-A12	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-EROH	138274	C
3,740	RHU -52 -52K002B	SS1-B7-2001-B08	INSPECT MV SMGR & CB B7-2001-B08	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-EROH	138299	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: RHU YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
3,741	RHU -52 -52P001B	SS1-B7-2001-B09	INSPECT MV SMGR & CB B7-2001-B09	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-EROH	138301	C
3,742	RHU -52 -52P002B	SS1-B7-2001-B10	INSPECT MV SMGR & CB B7-2001-B10	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-EROH	138303	C
3,743	RHU -52 -52P007B	SS1-B7-2001-B12	INSPECT MV SMGR & CB B7-2001-B12	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-EROH	138306	C
3,744	RHU -55 -55E004	SS2-55E004-VSD	Inspec VSD FOR 55E004-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254157	B
3,745	RHU -55 -55E007	SS2-55E007-VSD	Inspec VSD FOR 55E007-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254158	B
3,746	RHU -55 -55E105A	SS2-55E105A-VSD	Inspec VSD FOR 55E105A-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254159	B
3,747	RHU -55 -55E105B	SS2-55E105B-VSD	Inspec VSD FOR 55E105B-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254160	B
3,748	RHU -55 -55E105C	SS2-55E105C-VSD	Inspec VSD FOR 55E105C-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254161	B
3,749	RHU -55 -55E105D	SS2-55E105D-VSD	Inspec VSD FOR 55E105D-K01B-M	PMT	3M		I			I			I			I		RRC	RRC-EROH	254162	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1	UTF		VB. INSP & ANALY M/C UTF PLANT	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	150296	
2	UTF -77 -77X101		Function test FFG7750070	PMT	2M		F		F		F		F		F		F	RRC	RRC-IROH	250303	
3	UTF -77 -77X101		Inspec PG7750101	PMT	6M				I						I			RRC	RRC-IROH	250304	
4	UTF -77 -77X101		Inspec PG7750101	PMT	1Y												I	RRC	RRC-IROH	250305	
5	UTF -77 -77X101		Inspec PG7750101	PMT	6M		I						I					RRC	RRC-IROH	250306	
6	UTF -77 -77X101		Inspec & Calibrate PG7750101	PMT	1Y						I							RRC	RRC-IROH	250307	
7	UTF -77 -77X101		Inspec PG7750102	PMT	6M				I						I			RRC	RRC-IROH	250308	
8	UTF -77 -77X101		Inspec PG7750102	PMT	1Y												I	RRC	RRC-IROH	250309	
9	UTF -77 -77X101		Inspec PG7750102	PMT	6M		I						I					RRC	RRC-IROH	250310	
10	UTF -77 -77X101		Inspec & Calibrate PG7750102	PMT	1Y						I							RRC	RRC-IROH	250311	
11	UTF -77 -77X101		Inspec PG7750104	PMT	6M				I						I			RRC	RRC-IROH	250312	
12	UTF -77 -77X101		Inspec PG7750104	PMT	1Y												I	RRC	RRC-IROH	250313	
13	UTF -77 -77X101		Inspec PG7750104	PMT	6M		I						I					RRC	RRC-IROH	250314	
14	UTF -77 -77X101		Inspec & Calibrate PG7750104	PMT	1Y						I							RRC	RRC-IROH	250315	
15	UTF -77 -77X101		Inspec & Calibrate UTF-PSL7750101	PMT	1Y						I							RRC	RRC-IROH	250316	
16	UTF -77 -77X101		Inspection UTF-TT7750101	PMT	1Y						I							RRC	RRC-IROH	250317	
17	UTF -77 -77X101		Inspection UTF-TT7750104	PMT	1Y						I							RRC	RRC-IROH	250318	
18	UTF -77 -77X101		Inspection UTF-TT7750107	PMT	1Y						I							RRC	RRC-IROH	250319	
19	UTF -77 -77X101		Inspection UTF-TT7750201	PMT	1Y						I							RRC	RRC-IROH	250320	
20	UTF -77 -77X101		Inspection UTF-TT7750203	PMT	1Y						I							RRC	RRC-IROH	250321	
21	UTF -77 -77X101		Inspection UTF-TT7750205	PMT	1Y						I							RRC	RRC-IROH	250322	
22	UTF -77 -77X101		Inspection UTF-TT7750207	PMT	1Y						I							RRC	RRC-IROH	250323	
23	UTF -77 -77X101		Inspection UTF-TT7750209	PMT	1Y						I							RRC	RRC-IROH	250324	
24	UTF -77 -77X101		Inspection UTF-TT7750211	PMT	1Y						I							RRC	RRC-IROH	250325	
25	UTF -77 -77X101		Inspection UTF-TT7750213	PMT	1Y						I							RRC	RRC-IROH	250326	
26	UTF -MA		INSPEC DRINKING UTF-MA-001-004(4 PCS)	PMT	4M	I				I			I					RRC	RRC-EROH	254458	
27	UTF -MA		INSPEC FAN UTF-MA-001-004(4 PCS)	PMT	4M	I				I			I					RRC	RRC-EROH	254459	
28	UTF -MA		INSPEC GRINDING UTF-MA-001	PMT	4M	I				I			I					RRC	RRC-EROH	254460	
29	UTF -MA		INSPEC DRILLING UTF-MA-001	PMT	4M	I				I			I					RRC	RRC-EROH	254461	
30	UTF -MA		INSPEC WELDING UTF-MA-001	PMT	4M	I				I			I					RRC	RRC-EROH	254462	
31	UTF -MA		INSPEC SAW UTF-MA-001	PMT	4M	I				I			I					RRC	RRC-EROH	254463	
32	UTF -MA		INSPEC FIBER CUT UTF-MA-001	PMT	4M	I				I			I					RRC	RRC-EROH	254464	
33	UTF -MA		INSPEC JET GUN UTF-MA-001	PMT	4M	I				I			I					RRC	RRC-EROH	254465	
34	UTF -MA		INSPEC UTF -MA-PDP	PMT	4M	I				I			I					RRC	RRC-EROH	254466	

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
35	UTF -MA		INSPEC AIR PUMP UTF-MA-001-002(2 PCS)	PMT	4M	I				I				I				RRC	RRC-ERCH	254467	
36	UTF -MA		INSPEC SMALL REFRIGERATOR UTF-MA-001-002	PMT	4M	I				I				I				RRC	RRC-ERCH	254468	
37	UTF -74 -GRD_LIGHTN		PM GND SYS (LOOP) (UNIT 74)	PMT	1Y		P											RRC	RRC-ERCH	140352	
38	UTF -74 -GRD_LIGHTN		VISUAL GROUNDING SYS (UNIT 74)	PMT	4M		P				P				P			RRC	RRC-ERCH	141712	
39	UTF -75 -GRD_LIGHTN		PM GND SYS (LOOP) (UNIT 75)	PMT	1Y		P											RRC	RRC-ERCH	140353	
40	UTF -75 -GRD_LIGHTN		VISUAL GROUNDING SYS (UNIT 75)	PMT	4M		P				P				P			RRC	RRC-ERCH	141713	
41	UTF -77 -GRD_LIGHTN		PM GND SYS (LOOP) (UNIT 77)	PMT	1Y			P										RRC	RRC-ERCH	140355	
42	UTF -77 -GRD_LIGHTN		VISUAL GROUNDING SYS (UNIT 77)	PMT	4M			P				P				P		RRC	RRC-ERCH	141715	
43	UTF -78 -GRD_LIGHTN		PM GND SYS (LOOP) (UNIT 78)	PMT	1Y												P	RRC	RRC-ERCH	140356	
44	UTF -78 -GRD_LIGHTN		VISUAL GROUNDING SYS (UNIT 78)	PMT	4M				P				P				P	RRC	RRC-ERCH	141716	
45	UTF -79 -GRD_LIGHTN		PM GND SYS (LOOP) (UNIT 79)	PMT	1Y												P	RRC	RRC-ERCH	140357	
46	UTF -79 -GRD_LIGHTN		VISUAL GROUNDING SYS (UNIT 79)	PMT	4M				P				P				P	RRC	RRC-ERCH	141717	
47	UTF -ADM-GRD_LIGHTN		PM GND SYS (LOOP) (ADMIN)	PMT	1Y												P	RRC	RRC-ERCH	140358	
48	UTF -ADM-GRD_LIGHTN		VISUAL GROUNDING SYS (ADMIN)	PMT	4M				P				P				P	RRC	RRC-ERCH	141718	
49	UTF -FAC-GRD_LIGHTN		PM GND SYS (LOOP) (FACILITIES)	PMT	1Y												P	RRC	RRC-ERCH	140359	
50	UTF -FAC-GRD_LIGHTN		VISUAL GROUNDING SYS (FACILITIES)	PMT	4M				P				P				P	RRC	RRC-ERCH	141719	
51	UTF -GUA-GRD_LIGHTN		PM GND SYS (LOOP) (MAIN GUARD)	PMT	1Y												P	RRC	RRC-ERCH	140360	
52	UTF -GUA-GRD_LIGHTN		VISUAL GROUNDING SYS (MAIN GUARD)	PMT	4M				P				P				P	RRC	RRC-ERCH	141720	
53	UTF -MA -GRD_LIGHTN		PM GND SYS (LOOP) (MA&WS)	PMT	1Y												P	RRC	RRC-ERCH	140361	
54	UTF -MA -GRD_LIGHTN		VISUAL GROUNDING SYS (MA&WS)	PMT	4M				P				P				P	RRC	RRC-ERCH	141721	
55	UTF -MCB-GRD_LIGHTN		PM GND SYS (LOOP) (MAIN CONTROL)	PMT	1Y												P	RRC	RRC-ERCH	140362	
56	UTF -MCB-GRD_LIGHTN		VISUAL GROUNDING SYS (MAIN CONTROL)	PMT	4M				P				P				P	RRC	RRC-ERCH	141722	
57	UTF -MSS-GRD_LIGHTN		PM GND SYS (LOOP) (MAIN SUB)	PMT	1Y												P	RRC	RRC-ERCH	140363	
58	UTF -MSS-GRD_LIGHTN		VISUAL GROUNDING SYS (MAIN SUB)	PMT	4M				P				P				P	RRC	RRC-ERCH	141723	
59	UTF -SS1-GRD_LIGHTN		PM GND SYS (LOOP) (SUB1)	PMT	1Y												P	RRC	RRC-ERCH	140364	
60	UTF -SS1-GRD_LIGHTN		VISUAL GROUNDING SYS (SUB1)	PMT	4M				P				P				P	RRC	RRC-ERCH	141724	
61	UTF -SS2-GRD_LIGHTN		PM GND SYS (LOOP) (SUB2)	PMT	1Y												P	RRC	RRC-ERCH	140365	
62	UTF -SS2-GRD_LIGHTN		VISUAL GROUNDING SYS (SUB2)	PMT	4M				P				P				P	RRC	RRC-ERCH	141725	
63	UTF -80 -80X001		PM F/A PUSH BUTTON (#F) (UNIT	PMT	3M		P				P		P			P		RRC	RRC-ERCH	255679	
64	UTF -80 -80X001		VISUAL GROUNDING SYS (UNIT 80	PMT	4M				P				P				P	RRC	RRC-ERCH	255680	
65	UTF -80 -80X001		PM#GROUND#SYSTEM#(LOOP) (UNIT	PMT	1Y												P	RRC	RRC-ERCH	255681	
66	UTF -77 -PIPING	1-1/2-MK-77058006	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	178340	B
67	UTF -77 -PIPING	1-1/2-MK-77058008	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	178341	B
68	UTF -77 -PIPING	1-AII-77003001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	178008	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
69	UTF -74 -PIPING	1-AIP-74361002	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	177975	C
70	UTF -77 -PIPING	1-AIP-77003001	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178015	C
71	UTF -77 -PIPING	1-AIP-77361002	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178010	C
72	UTF -77 -PIPING	1-AIP-77361003	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178011	C
73	UTF -77 -PIPING	1-AIP-77361004	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178012	C
74	UTF -77 -PIPING	1-AIP-77361006	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178014	C
75	UTF -78 -PIPING	1-AIP-78001301	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178670	C
76	UTF -78 -PIPING	1-AIP-78002001	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178681	C
77	UTF -77 -PIPING	1-MK-77058301	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178532	B
78	UTF -77 -PIPING	1-NL-77002003	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178347	C
79	UTF -77 -PIPING	1-NL-77003002	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178349	C
80	UTF -77 -PIPING	1-NL-77003003	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178350	C
81	UTF -77 -PIPING	1-NL-77003004	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178351	C
82	UTF -77 -PIPING	1-NL-77371004	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178353	C
83	UTF -77 -PIPING	1-NL-77371005	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178354	C
84	UTF -77 -PIPING	1-NL-77371006	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178355	C
85	UTF -77 -PIPING	1-NL-77371007	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178356	C
86	UTF -77 -PIPING	1-NL-77371018	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178346	C
87	UTF -77 -PIPING	1-NL-77371020	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178365	C
88	UTF -77 -PIPING	1/2-NL-77371017	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178363	C
89	UTF -77 -PIPING	10-NL-77371001	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178364	C
90	UTF -74 -PIPING	2-AII-74351002	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	177973	C
91	UTF -77 -PIPING	2-AII-77351001	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178007	C
92	UTF -74 -PIPING	2-AIP-74361001	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	177974	C
93	UTF -78 -PIPING	2-AIP-78003001	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178689	C
94	UTF -77 -PIPING	2-MK-77013501	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178594	B
95	UTF -77 -PIPING	2-MK-77013502	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178595	B
96	UTF -77 -PIPING	2-MK-77056003	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178333	B
97	UTF -77 -PIPING	2-MK-77056004	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178334	B
98	UTF -77 -PIPING	2-MK-77058001	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178335	B
99	UTF -77 -PIPING	2-MK-77058002	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178336	B
100	UTF -77 -PIPING	2-MK-77058003	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178337	B
101	UTF -77 -PIPING	2-MK-77058004	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178338	B
102	UTF -77 -PIPING	2-MK-77058005	Piping inspection	PMT	10Y					I								IRI	IRI-INRC	178339	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
103	UTF -74 -PIPING	2-NL-74371003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	177979	C
104	UTF -74 -PIPING	2-NL-74371004	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	177980	C
105	UTF -77 -PIPING	2-NL-77371013	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	178359	C
106	UTF -77 -PIPING	2-NL-77371016	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	178362	C
107	UTF -74 -PIPING	3-AII-74351001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	177972	C
108	UTF -77 -PIPING	3-AIP-77361001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	178009	C
109	UTF -77 -PIPING	3-AIP-77361005	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	178013	C
110	UTF -77 -PIPING	3-MK-77056002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	178332	B
111	UTF -77 -PIPING	3-MK-77601001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	178343	B
112	UTF -77 -PIPING	3-NL-77003001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	178348	C
113	UTF -77 -PIPING	3-NL-77371002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	178345	C
114	UTF -77 -PIPING	3-NL-77371003	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	178352	C
115	UTF -77 -PIPING	3-NL-77371008	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	178357	C
116	UTF -77 -PIPING	3-NL-77371009	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	178358	C
117	UTF -77 -PIPING	3-NL-77371014	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	178360	C
118	UTF -77 -PIPING	3-NL-77371015	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	178361	C
119	UTF -77 -PIPING	3/4-GCH-77503001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	178190	B
120	UTF -77 -PIPING	3/4-MK-77014301	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	178548	B
121	UTF -77 -PIPING	3/4-MK-77014302	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	178549	B
122	UTF -77 -PIPING	4-GCH-77503002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	178191	B
123	UTF -77 -PIPING	4-MK-77060002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	178342	B
124	UTF -74 -PIPING	4-NL-74371001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	177976	C
125	UTF -74 -PIPING	4-NL-74371002	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	177978	C
126	UTF -74 -PIPING	6-NL-74371001	Piping inspection	PMT	10Y				I									IRI	IRI-INRC	177977	C
127	UTF -ADM-AIR	ADM-A/C-B1-HV-401A	PM TYPE OF AIR B1-HV-401-A (Large 4,10)	PMT	2M		P				P		P				P	RRC	RRC-ERCH	138228	B
128	UTF -ADM-AIR	ADM-A/C-B1-HV-401A	PM TYPE OF AIR B1-HV-401-A (Large 4,10)	PMT	6M				P						P			RRC	RRC-ERCH	138228	B
129	UTF -ADM-AIR	ADM-A/C-B1-HV-401B	PM TYPE OF AIR B1-HV-401-B (Large 4,10)	PMT	2M		P				P		P				P	RRC	RRC-ERCH	138229	B
130	UTF -ADM-AIR	ADM-A/C-B1-HV-401B	PM TYPE OF AIR B1-HV-401-B (Large 4,10)	PMT	6M				P						P			RRC	RRC-ERCH	138229	B
131	UTF -ADM-AIR	ADM-A/C-B1-HV-402	PM TYPE OF AIR B1-HV-402 (Large 4,10)	PMT	2M		P				P		P				P	RRC	RRC-ERCH	138230	B
132	UTF -ADM-AIR	ADM-A/C-B1-HV-402	PM TYPE OF AIR B1-HV-402 (Large 4,10)	PMT	6M				P						P			RRC	RRC-ERCH	138230	B
133	UTF -ADM-AIR	ADM-AHU-B1-HV-101	PM ALL TYPE OF AIR CON B1-HV-101	PMT	6M					P						P		RRC	RRC-ERCH	140551	C
134	UTF -ADM-AIR	ADM-AHU-B1-HV-101	Loop function test For HVAC	PMT	1Y										F			RRC	RRC-ERCH	156004	C
135	UTF -ADM-AIR	ADM-AHU-B1-HV-102	PM ALL TYPE OF AIR CON B1-HV-102	PMT	6M					P						P		RRC	RRC-ERCH	140552	C
136	UTF -ADM-AIR	ADM-CHI-B1-HV-301A	PM CHILLER NO.B1-HV-301-A	PMT	6M					P						P		RRC	RRC-ERCH	140553	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
137	UTF -ADM-AIR	ADM-CHI-B1-HV-301B	PM CHILLER NO. B1-HV-301-B	PMT	6M					P						P		RRC	RRC-ERCH	140554	B
138	UTF -ADM-AIR	ADM-CHI-B1-HV-301C	PM CHILLER NO. B1-HV-301-C	PMT	6M					P						P		RRC	RRC-ERCH	140555	B
139	UTF -ADM-AIR	ADM-CHI-B1-HV-801A	PM INSP OF M/C NO. B1-HV-801-B	PMT	4M					I			I				I	RRC	RRC-MRCH	140591	B
140	UTF -ADM-FIRE_ALARM	ADM-FA-DETECT-SD	PM SMOKE DETECTOR (###) UTF -ADM-FA	PMT	6M									P				RRC	RRC-ERCH	140410	A
141	UTF -ADM-FIRE_ALARM	ADM-FA-DETECT-SD	PM SMOKE DETECTOR (###) UTF -MA -FA	PMT	6M									P				RRC	RRC-ERCH	140412	A
142	UTF -ADM-FIRE_ALARM	ADM-FA-MCP	PM F/A PUSH BUTTON (####) (ADMIN)	PMT	3M		P				P		P			P		RRC	RRC-ERCH	140370	A
143	UTF -ADM-FIRE_ALARM	ADM-FA-MCP	PM F/A PUSH BUTTON (####) (MA&WS)	PMT	3M		P				P		P			P		RRC	RRC-ERCH	140372	A
144	UTF -ADM-AIR	ADM-FCU-B1-HV-501	PM ALL TYPE OF AIR CON B1-HV-501	PMT	6M	P						P						RRC	RRC-ERCH	140556	C
145	UTF -ADM-AIR	ADM-FCU-B1-HV-502A	PM ALL TYPE OF AIR CON B1-HV-502B	PMT	6M	P						P						RRC	RRC-ERCH	140561	C
146	UTF -ADM-AIR	ADM-FCU-B1-HV-502B	PM ALL TYPE OF AIR CON B1-HV-502A	PMT	6M	P						P						RRC	RRC-ERCH	140560	C
147	UTF -ADM-AIR	ADM-FCU-B1-HV-502C	PM ALL TYPE OF AIR CON B1-HV-502C	PMT	6M	P						P						RRC	RRC-ERCH	140562	C
148	UTF -ADM-AIR	ADM-FCU-B1-HV-502D	PM ALL TYPE OF AIR CON B1-HV-502D	PMT	6M	P						P						RRC	RRC-ERCH	140563	C
149	UTF -ADM-AIR	ADM-FCU-B1-HV-503A	PM ALL TYPE OF AIR CON B1-HV-503A	PMT	6M	P						P						RRC	RRC-ERCH	140564	C
150	UTF -ADM-AIR	ADM-FCU-B1-HV-503B	PM ALL TYPE OF AIR CON B1-HV-503B	PMT	6M	P						P						RRC	RRC-ERCH	140565	C
151	UTF -ADM-AIR	ADM-FCU-B1-HV-503C	PM ALL TYPE OF AIR CON B1-HV-503C	PMT	6M	P						P						RRC	RRC-ERCH	140566	C
152	UTF -ADM-AIR	ADM-FCU-B1-HV-503D	PM ALL TYPE OF AIR CON B1-HV-503D	PMT	6M	P						P						RRC	RRC-ERCH	140567	C
153	UTF -ADM-AIR	ADM-FCU-B1-HV-504	PM ALL TYPE OF AIR CON B1-HV-504	PMT	6M	P						P						RRC	RRC-ERCH	140568	C
154	UTF -ADM-AIR	ADM-FCU-B1-HV-505	PM ALL TYPE OF AIR CON B1-HV-505	PMT	6M	P						P						RRC	RRC-ERCH	140569	C
155	UTF -ADM-AIR	ADM-FCU-B1-HV-506	PM ALL TYPE OF AIR CON B1-HV-506	PMT	6M	P						P						RRC	RRC-ERCH	140557	C
156	UTF -ADM-AIR	ADM-FCU-B1-HV-507	PM ALL TYPE OF AIR CON B1-HV-507	PMT	6M	P						P						RRC	RRC-ERCH	140558	C
157	UTF -ADM-AIR	ADM-FCU-B1-HV-508	PM ALL TYPE OF AIR CON B1-HV-508	PMT	6M	P						P						RRC	RRC-ERCH	140559	C
158	UTF -ADM-AIR	ADM-FCU-B1-HV-509	PM ALL TYPE OF AIR CON B1-HV-509	PMT	6M	P						P						RRC	RRC-ERCH	140570	C
159	UTF -ADM-AIR	ADM-FCU-B1-HV-510	PM ALL TYPE OF AIR CON B1-HV-510	PMT	6M	P						P						RRC	RRC-ERCH	140571	C
160	UTF -ADM-AIR	ADM-FCU-B1-HV-511	PM ALL TYPE OF AIR CON B1-HV-511	PMT	6M	P						P						RRC	RRC-ERCH	140572	C
161	UTF -ADM-AIR	ADM-FCU-B1-HV-512	PM ALL TYPE OF AIR CON B1-HV-512	PMT	6M					P				P				RRC	RRC-ERCH	140581	C
162	UTF -ADM-AIR	ADM-FCU-B1-HV-513	PM ALL TYPE OF AIR CON B1-HV-513	PMT	6M					P				P				RRC	RRC-ERCH	140582	C
163	UTF -ADM-AIR	ADM-FCU-B1-HV-514	PM ALL TYPE OF AIR CON B1-HV-514	PMT	6M					P				P				RRC	RRC-ERCH	140583	C
164	UTF -ADM-AIR	ADM-FCU-B1-HV-515	PM ALL TYPE OF AIR CON B1-HV-515	PMT	6M					P				P				RRC	RRC-ERCH	140584	C
165	UTF -ADM-AIR	ADM-FCU-B1-HV-516	PM ALL TYPE OF AIR CON B1-HV-516	PMT	6M					P				P				RRC	RRC-ERCH	140585	C
166	UTF -ADM-AIR	ADM-FCU-B1-HV-517A	PM ALL TYPE OF AIR CON B1-HV-517A	PMT	6M					P				P				RRC	RRC-ERCH	140577	C
167	UTF -ADM-AIR	ADM-FCU-B1-HV-517B	PM ALL TYPE OF AIR CON B1-HV-517B	PMT	6M					P				P				RRC	RRC-ERCH	140578	C
168	UTF -ADM-AIR	ADM-FCU-B1-HV-517C	PM ALL TYPE OF AIR CON B1-HV-517C	PMT	6M					P				P				RRC	RRC-ERCH	140579	C
169	UTF -ADM-AIR	ADM-FCU-B1-HV-517D	PM ALL TYPE OF AIR CON B1-HV-517D	PMT	6M					P				P				RRC	RRC-ERCH	140580	C
170	UTF -ADM-AIR	ADM-FCU-B1-HV-518A	PM ALL TYPE OF AIR CON B1-HV-518A	PMT	6M					P				P				RRC	RRC-ERCH	140575	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT : UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
171	UTF -ADM-AIR	ADM-FCU-B1-HV-518B	PM ALL TYPE OF AIR CON B1-HV-518B	PMT	6M			P						P				RRC	RRC-ERCH	140576	C
172	UTF -ADM-AIR	ADM-FCU-B1-HV-519	PM ALL TYPE OF AIR CON B1-HV-519	PMT	6M	P						P						RRC	RRC-ERCH	140574	C
173	UTF -ADM-AIR	ADM-FCU-B1-HV-520	PM ALL TYPE OF AIR CON B1-HV-520	PMT	6M	P						P						RRC	RRC-ERCH	140573	C
174	UTF -ADM-INERGEN	ADM-ICP-003	INSPECTION INERGEN SYS UTF -ADM-INERGEN	PMT	1Y											I		RRC	RRC-ERCH	140419	A
175	UTF -ADM-FIRE_ALARM	ADM-LFCP-B1-5001	PM F/A PANEL LFCP-B1_5001 EL (ADMIN)	PMT	1Y											P		RRC	RRC-ERCH	140396	A
176	UTF -FAC-AIR	FAC-A/C-B9-HV-401A	PM TYPE OF AIR B9-HV-401-A (Large 4,10)	PMT	2M		P				P		P				P	RRC	RRC-ERCH	138238	B
177	UTF -FAC-AIR	FAC-A/C-B9-HV-401A	PM TYPE OF AIR B9-HV-401-A (Large 4,10)	PMT	6M				P					P				RRC	RRC-ERCH	138238	B
178	UTF -FAC-AIR	FAC-A/C-B9-HV-401B	PM TYPE OF AIR B9-HV-401-B (Large 4,10)	PMT	2M		P				P		P				P	RRC	RRC-ERCH	138239	B
179	UTF -FAC-AIR	FAC-A/C-B9-HV-401B	PM TYPE OF AIR B9-HV-401-B (Large 4,10)	PMT	6M				P					P				RRC	RRC-ERCH	138239	B
180	UTF -FAC-AIR	FAC-A/C-B9-HV-402A	PM TYPE OF AIR B9-HV-402-A (Large 4,10)	PMT	2M		P				P		P				P	RRC	RRC-ERCH	138240	B
181	UTF -FAC-AIR	FAC-A/C-B9-HV-402A	PM TYPE OF AIR B9-HV-402-A (Large 4,10)	PMT	6M				P					P				RRC	RRC-ERCH	138240	B
182	UTF -FAC-AIR	FAC-A/C-B9-HV-402B	PM TYPE OF AIR B9-HV-402-B (Large 4,10)	PMT	2M		P				P		P				P	RRC	RRC-ERCH	138241	B
183	UTF -FAC-AIR	FAC-A/C-B9-HV-402B	PM TYPE OF AIR B9-HV-402-B (Large 4,10)	PMT	6M				P					P				RRC	RRC-ERCH	138241	B
184	UTF -FAC-AIR	FAC-A/C-B9-HV-403A	PM TYPE OF AIR B9-HV-403-A (Large 4,10)	PMT	2M		P				P		P				P	RRC	RRC-ERCH	138242	B
185	UTF -FAC-AIR	FAC-A/C-B9-HV-403A	PM TYPE OF AIR B9-HV-403-A (Large 4,10)	PMT	6M				P					P				RRC	RRC-ERCH	138242	B
186	UTF -FAC-AIR	FAC-A/C-B9-HV-403B	PM TYPE OF AIR B9-HV-403-B (Large 4,10)	PMT	2M		P				P		P				P	RRC	RRC-ERCH	138243	B
187	UTF -FAC-AIR	FAC-A/C-B9-HV-403B	PM TYPE OF AIR B9-HV-403-B (Large 4,10)	PMT	6M				P					P				RRC	RRC-ERCH	138243	B
188	UTF -FAC-FIRE_ALARM	FAC-FA-DETECT-SD	PM SMOKE DETECTOR (###) UTF -FAC-FA	PMT	6M					P						P		RRC	RRC-ERCH	140411	A
189	UTF -FAC-FIRE_ALARM	FAC-FA-MCP	PM F/A PUSH BUTTON (###) (FACILITIES)	PMT	3M		P			P			P			P		RRC	RRC-ERCH	140371	A
190	UTF -FAC-AIR	FAC-FCU-B9-HV-501A	PM ALL TYPE OF AIR CON B9-HV-501-A	PMT	6M			P						P				RRC	RRC-ERCH	140586	C
191	UTF -FAC-AIR	FAC-FCU-B9-HV-501B	PM ALL TYPE OF AIR CON B9-HV-501-B	PMT	6M			P						P				RRC	RRC-ERCH	140587	C
192	UTF -FAC-AIR	FAC-FCU-B9-HV-502	PM ALL TYPE OF AIR CON B9-HV-502	PMT	6M			P						P				RRC	RRC-ERCH	140588	C
193	UTF -FAC-AIR	GUA-A/C-B6-HV-401	PM TYPE OF AIR B6-HV-401 (Large 4,10)	PMT	2M		P				P		P				P	RRC	RRC-ERCH	138236	B
194	UTF -FAC-AIR	GUA-A/C-B6-HV-401	PM TYPE OF AIR B6-HV-401 (Large 4,10)	PMT	6M				P					P				RRC	RRC-ERCH	138236	B
195	UTF -FAC-AIR	GUA-A/C-B6-HV-402	PM TYPE OF AIR B6-HV-402 (Large 4,10)	PMT	2M		P				P		P				P	RRC	RRC-ERCH	138237	B
196	UTF -FAC-AIR	GUA-A/C-B6-HV-402	PM TYPE OF AIR B6-HV-402 (Large 4,10)	PMT	6M				P					P				RRC	RRC-ERCH	138237	B
197	UTF -GUA-FIRE_ALARM	GUA-FA-DETECT-SD	PM SMOKE DETECTOR (###) UTF -GUA-FA	PMT	6M					P						P		RRC	RRC-ERCH	140414	A
198	UTF -GUA-FIRE_ALARM	GUA-FA-MCP	PM F/A PUSH BUTTON (###) (MAIN GUARD)	PMT	3M		P			P			P			P		RRC	RRC-ERCH	140374	A
199	UTF -MCB-AIR	MCB-AHU-B3-HV-101A	PM ALL TYPE OF AIR CON B3-HV-101A	PMT	6M			P						P				RRC	RRC-ERCH	140535	C
200	UTF -MCB-AIR	MCB-AHU-B3-HV-101A	Loop function test For HVAC	PMT	1Y								F					RRC	RRC-ERCH	156011	C
201	UTF -MCB-AIR	MCB-AHU-B3-HV-101B	PM ALL TYPE OF AIR CON B3-HV-101B	PMT	6M			P						P				RRC	RRC-ERCH	140536	C
202	UTF -MCB-AIR	MCB-CDU-B3-HV-201A	PM ALL TYPE OF AIR CON B3-HV-201A	PMT	6M					P						P		RRC	RRC-ERCH	140537	B
203	UTF -MCB-AIR	MCB-CDU-B3-HV-201B	PM ALL TYPE OF AIR CON B3-HV-201B	PMT	6M					P						P		RRC	RRC-ERCH	140538	B
204	UTF -MCB-AIR	MCB-CDU-B3-HV-201C	PM ALL TYPE OF AIR CON B3-HV-201C	PMT	6M					P						P		RRC	RRC-ERCH	140539	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT : UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
205	UTF -MCB-AIR	MCB-CDU-B3-HV-201D	PM ALL TYPE OF AIR CON B3-HV-201D	PMT	6M					P						P		RRC	RRC-ERCH	140540	B
206	UTF -MCB-FIRE_ALARM	MCB-FA-DETECT-SD	PM SMOKE DETECTOR (###) UTF -MCB-FA	PMT	6M					P						P		RRC	RRC-ERCH	140413	A
207	UTF -MCB-FIRE_ALARM	MCB-FA-MCP	PM F/A PUSH BUTTON (###) (MAIN CONTROL)	PMT	3M		P			P			P			P		RRC	RRC-ERCH	140373	A
208	UTF -MCB-INERGEN	MCB-ICP-001	INSPECTION INERGEN SYS UTF -MCB-INERGEN	PMT	1Y											I		RRC	RRC-ERCH	140420	A
209	UTF -MCB-FIRE_ALARM	MCB-LFCP-B3-001	PM F/A PANEL LFCP-001 EL (MAIN CONTROL)	PMT	1Y											P		RRC	RRC-ERCH	140398	A
210	UTF -MSS-AIR	MSS-AHU-B2-HV-101A	PM ALL TYPE OF AIR CON B2-HV-101A	PMT	6M			P						P				RRC	RRC-ERCH	140526	C
211	UTF -MSS-AIR	MSS-AHU-B2-HV-101A	Loop function test For HVAC	PMT	1Y								F					RRC	RRC-ERCH	156013	C
212	UTF -MSS-AIR	MSS-AHU-B2-HV-101B	PM ALL TYPE OF AIR CON B2-HV-101B	PMT	6M			P						P				RRC	RRC-ERCH	140527	C
213	UTF -MSS-AIR	MSS-AHU-B2-HV-101C	PM ALL TYPE OF AIR CON B2-HV-101C	PMT	6M			P						P				RRC	RRC-ERCH	140528	C
214	UTF -MSS-HVS	MSS-B2-2001-A02	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249570	A
215	UTF -MSS-HVS	MSS-B2-2001-A02	INSPECT M/ SWGR & CB B2-2001-A02	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138279	A
216	UTF -MSS-HVS	MSS-B2-2001-A03	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249571	A
217	UTF -MSS-HVS	MSS-B2-2001-A03	INSPECT M/ SWGR & CB B2-2001-A03	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138277	A
218	UTF -MSS-HVS	MSS-B2-2001-A04	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249572	A
219	UTF -MSS-HVS	MSS-B2-2001-A04	INSPECT M/ SWGR & CB B2-2001-A04	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138275	A
220	UTF -MSS-HVS	MSS-B2-2001-A05	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249573	A
221	UTF -MSS-HVS	MSS-B2-2001-A05	INSPECT M/ SWGR & CB B2-2001-A05	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138273	A
222	UTF -MSS-HVS	MSS-B2-2001-A06	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249574	A
223	UTF -MSS-HVS	MSS-B2-2001-A06	INSPECT M/ SWGR & CB B2-2001-A06	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138271	A
224	UTF -MSS-HVS	MSS-B2-2001-A07	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249575	A
225	UTF -MSS-HVS	MSS-B2-2001-A07	INSPECT M/ SWGR & CB B2-2001-A07	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138269	A
226	UTF -MSS-HVS	MSS-B2-2001-A08	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249576	A
227	UTF -MSS-HVS	MSS-B2-2001-A08	INSPECT M/ SWGR & CB B2-2001-A08	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138281	A
228	UTF -MSS-HVS	MSS-B2-2001-A09	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249577	A
229	UTF -MSS-HVS	MSS-B2-2001-A09	INSPECT M/ SWGR & CB B2-2001-A09	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138280	A
230	UTF -MSS-HVS	MSS-B2-2001-A10	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249578	A
231	UTF -MSS-HVS	MSS-B2-2001-A10	INSPECT M/ SWGR & CB B2-2001-A10	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138278	A
232	UTF -MSS-HVS	MSS-B2-2001-AB	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249579	C
233	UTF -MSS-HVS	MSS-B2-2001-AB	INSPECT M/ SWGR & CB B2-2001-AB	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138261	C
234	UTF -MSS-HVS	MSS-B2-2001-B02	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249580	A
235	UTF -MSS-HVS	MSS-B2-2001-B02	INSPECT M/ SWGR & CB B2-2001-B02	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138286	A
236	UTF -MSS-HVS	MSS-B2-2001-B03	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249581	A
237	UTF -MSS-HVS	MSS-B2-2001-B03	INSPECT M/ SWGR & CB B2-2001-B03	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138287	A
238	UTF -MSS-HVS	MSS-B2-2001-B04	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249582	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT : UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
239	UTF -MSS-HVS	MSS-B2-2001-B04	INSPECT M/ SWGR & CB B2-2001-B04	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138291	A
240	UTF -MSS-HVS	MSS-B2-2001-B05	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249583	A
241	UTF -MSS-HVS	MSS-B2-2001-B05	INSPECT M/ SWGR & CB B2-2001-B05	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138293	A
242	UTF -MSS-HVS	MSS-B2-2001-B06	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249584	A
243	UTF -MSS-HVS	MSS-B2-2001-B06	INSPECT M/ SWGR & CB B2-2001-B06	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138295	A
244	UTF -MSS-HVS	MSS-B2-2001-B07	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249585	A
245	UTF -MSS-HVS	MSS-B2-2001-B07	INSPECT M/ SWGR & CB B2-2001-B07	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138298	A
246	UTF -MSS-HVS	MSS-B2-2001-B08	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249586	A
247	UTF -MSS-HVS	MSS-B2-2001-B08	INSPECT M/ SWGR & CB B2-2001-B08	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138300	A
248	UTF -MSS-HVS	MSS-B2-2001-B09	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249587	A
249	UTF -MSS-HVS	MSS-B2-2001-B09	INSPECT M/ SWGR & CB B2-2001-B09	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138302	A
250	UTF -MSS-HVS	MSS-B2-2001-B11	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249589	A
251	UTF -MSS-HVS	MSS-B2-2001-B11	INSPECT M/ SWGR & CB B2-2001-B11	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138305	A
252	UTF -MSS-HVS	MSS-B2-3001-A02	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249590	A
253	UTF -MSS-HVS	MSS-B2-3001-A02	INSPECT M/ SWGR & CB B2-3001-A02	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138366	A
254	UTF -77 -77P007A	MSS-B2-3001-A22	INSPECT M/ SWGR & CB B2-3001-A22	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138346	B
255	UTF -77 -77P009A	MSS-B2-3001-A23	INSPECT M/ SWGR & CB B2-3001-A23	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138345	B
256	UTF -MSS-HVS	MSS-B2-3001-AB	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249611	A
257	UTF -MSS-HVS	MSS-B2-3001-AB	INSPECT M/ SWGR & CB B2-3001-AB	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138312	A
258	UTF -MSS-HVS	MSS-B2-3001-B02	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249612	A
259	UTF -MSS-HVS	MSS-B2-3001-B02	INSPECT M/ SWGR & CB B2-3001-B02	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138313	A
260	UTF -77 -77P007B	MSS-B2-3001-B26	INSPECT M/ SWGR & CB B2-3001-B26	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138337	B
261	UTF -77 -77P009B	MSS-B2-3001-B27	INSPECT M/ SWGR & CB B2-3001-B27	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138338	B
262	UTF -MSS-UPS	MSS-B2-5001	INSPECTION UTF -MSS-UPS_B2 -5001	PMT	6M		I					I			I			CCH	CCH-UPS	140488	A
263	UTF -MSS-UPS	MSS-B2-5001	PM UTF -MSS-UPS_B2 -5001	PMT	1Y					P								CCH	CCH-UPS	251934	A
264	UTF -MSS-UPS	MSS-B2-5002A	INSPECTION UTF -MSS-UPS_B2 -5002A	PMT	6M		I					I			I			CCH	CCH-UPS	140489	A
265	UTF -MSS-UPS	MSS-B2-5002A	PM UTF -MSS-UPS_B2 -5002A	PMT	1Y					P								CCH	CCH-UPS	251935	A
266	UTF -MSS-UPS	MSS-B2-5002B	INSPECTION UTF -MSS-UPS_B2 -5002B	PMT	6M		I					I			I			CCH	CCH-UPS	140490	A
267	UTF -MSS-UPS	MSS-B2-5002B	PM UTF -MSS-UPS_B2 -5002B	PMT	1Y					P								CCH	CCH-UPS	251936	A
268	UTF -MSS-UPS	MSS-B2-5003	INSPECTION UTF -MSS-UPS_B2 -5003	PMT	6M		I					I			I			CCH	CCH-UPS	140491	A
269	UTF -MSS-UPS	MSS-B2-5003	PM UTF -MSS-UPS_B2 -5003	PMT	1Y					P								CCH	CCH-UPS	251937	A
270	UTF -MSS-UPS	MSS-B2-5004	INSPECTION UTF -MSS-UPS_B2 -5004	PMT	6M		I					I			I			CCH	CCH-UPS	140492	A
271	UTF -MSS-UPS	MSS-B2-5004	PM UTF -MSS-UPS_B2 -5004	PMT	1Y					P								CCH	CCH-UPS	251938	A
272	UTF -MSS-BATT	MSS-BB-B2-5001-A	PM BATTERY 425 AH FOR UPS-B2-5001	PMT	1Y											P		CCH	CCH-UPS	140469	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT : UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
273	UTF -MSS-BATT	MSS-BB-B2-5001-B	PM BATTERY 425 AH FOR UPS-B2-5001	PMT	1Y											P		CCH	CCH-UPS	140470	A
274	UTF -MSS-BATT	MSS-BB-B2-5002A-A	PM BATTERY 740 AH FOR UPS-B2-5002A	PMT	1Y											P		CCH	CCH-UPS	140471	A
275	UTF -MSS-BATT	MSS-BB-B2-5002A-B	PM BATTERY 740 AH FOR UPS-B2-5002A	PMT	1Y											P		CCH	CCH-UPS	140472	A
276	UTF -MSS-BATT	MSS-BB-B2-5002B-A	PM BATTERY 420 AH FOR UPS-B2-5002B	PMT	1Y											P		CCH	CCH-UPS	140473	A
277	UTF -MSS-BATT	MSS-BB-B2-5002B-B	PM BATTERY 420 AH FOR UPS-B2-5002B	PMT	1Y											P		CCH	CCH-UPS	140474	A
278	UTF -MSS-BATT	MSS-BB-B2-5003-A	PM BATTERY 220 AH FOR UPS-B2-5003	PMT	1Y											P		CCH	CCH-UPS	140475	A
279	UTF -MSS-BATT	MSS-BB-B2-5003-B	PM BATTERY 220 AH FOR UPS-B2-5003	PMT	1Y											P		CCH	CCH-UPS	140476	A
280	UTF -MSS-BATT	MSS-BB-B2-5004-A	PM BATTERY 1220 AH FOR UPS-B2-5004	PMT	1Y											P		CCH	CCH-UPS	140477	A
281	UTF -MSS-BATT	MSS-BB-B2-5004-B	PM BATTERY 1220 AH FOR UPS-B2-5004	PMT	1Y											P		CCH	CCH-UPS	140478	A
282	UTF -MSS-BATT	MSS-BB-B2-6001	PM BATTERY UNIT	PMT	1Y											P		CCH	CCH-UPS	140479	A
283	UTF -MSS-BC	MSS-BC-B2-6001	INSPECTION 110VDC FOR SWGR CONTROL	PMT	6M		I						I					CCH	CCH-UPS	140497	A
284	UTF -MSS-BC	MSS-BC-B2-6001	PM 110VDC FOR SWGR CONTROL	PMT	1Y						P							CCH	CCH-UPS	251939	A
285	UTF -MSS-AIR	MSS-CDU-B2-HV-201A	PM ALL TYPE OF AIR CON B2-HV-201A	PMT	6M			P						P				RRC	RRC-ERCH	140529	B
286	UTF -MSS-AIR	MSS-CDU-B2-HV-201B	PM ALL TYPE OF AIR CON B2-HV-201B	PMT	6M			P						P				RRC	RRC-ERCH	140530	B
287	UTF -MSS-AIR	MSS-CDU-B2-HV-201C	PM ALL TYPE OF AIR CON B2-HV-201C	PMT	6M			P						P				RRC	RRC-ERCH	140531	B
288	UTF -MSS-AIR	MSS-CDU-B2-HV-201D	PM ALL TYPE OF AIR CON B2-HV-201D	PMT	6M			P						P				RRC	RRC-ERCH	140532	B
289	UTF -MSS-AIR	MSS-CDU-B2-HV-201E	PM ALL TYPE OF AIR CON B2-HV-201E	PMT	6M			P						P				RRC	RRC-ERCH	140533	C
290	UTF -MSS-AIR	MSS-CDU-B2-HV-201F	PM ALL TYPE OF AIR CON B2-HV-201F	PMT	6M			P						P				RRC	RRC-ERCH	140534	B
291	UTF -MSS-FIRE_ALARM	MSS-FA-DETECT-SD	PM SMOKE DETECTOR (###) UTF -MSS-FA	PMT	6M					P						P		RRC	RRC-ERCH	140415	A
292	UTF -MSS-FIRE_ALARM	MSS-FA-MCP	PM F/A PUSH BUTTON (###) (MAIN SUB)	PMT	3M		P			P			P			P		RRC	RRC-ERCH	140375	A
293	UTF -MSS-GIS	MSS-GIS-B2-1001-01	INSPECT 115KV GIS B2-1001-01 (Q1)	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138259	A
294	UTF -MSS-GIS	MSS-GIS-B2-1001-02	INSPECT 115KV GIS B2-1001-02 (Q2)	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138256	A
295	UTF -MSS-GIS	MSS-GIS-B2-1001-03	INSPECT 115KV GIS B2-1001-03 (Q3)	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138258	A
296	UTF -MSS-GIS	MSS-GIS-B2-1001-04	INSPECT 115KV GIS B2-1001-04 (Q4)	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138257	A
297	UTF -MSS-GIS	MSS-GIS-B2-1001-05	INSPECT 115KV GIS B2-1001-05 (Q5)	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138255	A
298	UTF -MSS-GIS	MSS-GIS-B2-1001-06	INSPECT 115KV GIS B2-1001-06 (Q6)	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138260	A
299	UTF -MSS-FIRE_ALARM	MSS-LFCP-B2-002	PM F/A PANEL LFCP-002 EL (MAIN SUB)	PMT	1Y											P		RRC	RRC-ERCH	140399	A
300	UTF -MSS-TRANS	MSS-TR-B2-1001	OIL ANALYSIS (DGA,etc.) TR_B2-1001	PMT	6M					Q						Q		CCH	CCH-TRTL	140443	A
301	UTF -MSS-TRANS	MSS-TR-B2-1001	PM POWER TRANSFORMER (NODLTC)	PMT	5Y											P		CCH	CCH-TRTL	249670	A
302	UTF -MSS-TRANS	MSS-TR-B2-1001	INSPECTION 115KV TRANSFORMER TR_B2-1001	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138376	A
303	UTF -MSS-TRANS	MSS-TR-B2-1002	OIL ANALYSIS (DGA,etc.) TR_B2-1002	PMT	6M					Q						Q		CCH	CCH-TRTL	140444	A
304	UTF -MSS-TRANS	MSS-TR-B2-1002	PM POWER TRANSFORMER (NODLTC)	PMT	5Y											P		CCH	CCH-TRTL	249671	A
305	UTF -MSS-TRANS	MSS-TR-B2-1002	INSPECTION 115KV TRANSFORMER TR_B2-1002	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138377	A
306	UTF -MSS-TRANS	MSS-TR-B2-2001	OIL ANALYSIS (DGA,etc.) TR_B2-2001	PMT	1Y											Q		CCH	CCH-TRTL	140445	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
307	UTF -MSS-TRANS	MSS-TR-B2-2001	PM DISTRIBUTION TRANSFORMER	PMT	5Y											P		CCH	CCH-TRTL	249672	A
308	UTF -MSS-TRANS	MSS-TR-B2-2001	INSPECTION M/ TRANSFORMER TR_B2-2001	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138378	A
309	UTF -MSS-TRANS	MSS-TR-B2-2002	OIL ANALYSIS (DGA,etc.) TR_B2-2002	PMT	1Y										Q			CCH	CCH-TRTL	140446	A
310	UTF -MSS-TRANS	MSS-TR-B2-2002	PM DISTRIBUTION TRANSFORMER	PMT	5Y											P		CCH	CCH-TRTL	249673	A
311	UTF -MSS-TRANS	MSS-TR-B2-2002	INSPECTION M/ TRANSFORMER TR_B2-2002	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138379	A
312	UTF -MSS-TRANS	MSS-TR-B2-2003	OIL ANALYSIS (DGA,etc.) TR_B2-2003	PMT	1Y										Q			CCH	CCH-TRTL	140447	A
313	UTF -MSS-TRANS	MSS-TR-B2-2003	PM DISTRIBUTION TRANSFORMER	PMT	5Y											P		CCH	CCH-TRTL	249674	A
314	UTF -MSS-TRANS	MSS-TR-B2-2003	INSPECTION M/ TRANSFORMER TR_B2-2003	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138380	A
315	UTF -MSS-TRANS	MSS-TR-B2-2004	OIL ANALYSIS (DGA,etc.) TR_B2-2004	PMT	1Y										Q			CCH	CCH-TRTL	140448	A
316	UTF -MSS-TRANS	MSS-TR-B2-2004	PM DISTRIBUTION TRANSFORMER	PMT	5Y											P		CCH	CCH-TRTL	249675	A
317	UTF -MSS-TRANS	MSS-TR-B2-2004	INSPECTION M/ TRANSFORMER TR_B2-2004	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138381	A
318	UTF -MSS-TRANS	MSS-TR-B2-2005	OIL ANALYSIS (DGA,etc.) TR_B2-2005	PMT	1Y										Q			CCH	CCH-TRTL	140449	A
319	UTF -MSS-TRANS	MSS-TR-B2-2005	PM DISTRIBUTION TRANSFORMER	PMT	5Y											P		CCH	CCH-TRTL	249676	A
320	UTF -MSS-TRANS	MSS-TR-B2-2005	INSPECTION M/ TRANSFORMER TR_B2-2005	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138382	A
321	UTF -MSS-TRANS	MSS-TR-B2-2006	OIL ANALYSIS (DGA,etc.) TR_B2-2006	PMT	1Y										Q			CCH	CCH-TRTL	140450	A
322	UTF -MSS-TRANS	MSS-TR-B2-2006	PM DISTRIBUTION TRANSFORMER	PMT	5Y											P		CCH	CCH-TRTL	249677	A
323	UTF -MSS-TRANS	MSS-TR-B2-2006	INSPECTION M/ TRANSFORMER TR_B2-2006	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138383	A
324	UTF -MSS-TRANS	MSS-TR-B2-2007	OIL ANALYSIS (DGA,etc.) TR_B2-2007	PMT	1Y										Q			CCH	CCH-TRTL	140451	A
325	UTF -MSS-TRANS	MSS-TR-B2-2007	PM DISTRIBUTION TRANSFORMER	PMT	5Y											P		CCH	CCH-TRTL	249678	A
326	UTF -MSS-TRANS	MSS-TR-B2-2007	INSPECTION M/ TRANSFORMER TR_B2-2007	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138384	A
327	UTF -MSS-TRANS	MSS-TR-B2-2008	OIL ANALYSIS (DGA,etc.) TR_B2-2008	PMT	1Y										Q			CCH	CCH-TRTL	140452	A
328	UTF -MSS-TRANS	MSS-TR-B2-2008	PM DISTRIBUTION TRANSFORMER	PMT	5Y											P		CCH	CCH-TRTL	249679	A
329	UTF -MSS-TRANS	MSS-TR-B2-2008	INSPECTION M/ TRANSFORMER TR_B2-2008	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138385	A
330	UTF -78 -78X001	SS1-78X001-VSD	Inspec VSD FOR 78X001-P01A/B	PMT	3M			I			I				I			RRC	RRC-ERCH	254165	C
331	UTF -79 -79P009A	SS1-79P009A-VSD	Inspec VSD FOR MOTOR 79P009A-M	PMT	3M			I			I				I			RRC	RRC-ERCH	254166	C
332	UTF -79 -79P009B	SS1-79P009B-VSD	Inspec VSD FOR MOTOR 79P009B-M	PMT	3M			I			I				I			RRC	RRC-ERCH	254167	C
333	UTF -79 -79P102A	SS1-79P102A-VSD	Inspec VSD FOR MOTOR 79P102A-M	PMT	3M			I			I				I			RRC	RRC-ERCH	254168	C
334	UTF -79 -79P102B	SS1-79P102B-VSD	Inspec VSD FOR MOTOR 79P102B-M	PMT	3M			I			I				I			RRC	RRC-ERCH	254169	C
335	UTF -SS1-AIR	SS1-AHU-B7-HV-101A	PM ALL TYPE OF AIR CON B7-HV-101-A	PMT	6M					P					P			RRC	RRC-ERCH	140541	C
336	UTF -SS1-AIR	SS1-AHU-B7-HV-101A	Loop function test For HVAC	PMT	1Y								F					RRC	RRC-ERCH	156016	C
337	UTF -SS1-AIR	SS1-AHU-B7-HV-101B	PM ALL TYPE OF AIR CON B7-HV-101-B	PMT	6M					P					P			RRC	RRC-ERCH	140542	C
338	UTF -SS1-AIR	SS1-AHU-B7-HV-101C	PM ALL TYPE OF AIR CON B7-HV-101-C	PMT	6M					P					P			RRC	RRC-ERCH	140543	C
339	UTF -SS1-HVS	SS1-B7-2001-A02	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249643	A
340	UTF -SS1-HVS	SS1-B7-2001-A02	INSPECT M/ SWGR & CB B7-2001-A02	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138288	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
341	UTF -SS1-HVS	SS1-B7-2001-A03	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249644	A
342	UTF -SS1-HVS	SS1-B7-2001-A03	INSPECT M/ SWGR & CB B7-2001-A03	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138285	A
343	UTF -SS1-HVS	SS1-B7-2001-A05	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249645	A
344	UTF -SS1-HVS	SS1-B7-2001-A05	INSPECT M/ SWGR & CB B7-2001-A05	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138284	A
345	UTF -SS1-HVS	SS1-B7-2001-A06	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249646	A
346	UTF -SS1-HVS	SS1-B7-2001-A06	INSPECT M/ SWGR & CB B7-2001-A06	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138283	A
347	UTF -74 -74P001A	SS1-B7-2001-A13	INSPECT M/ SWGR & CB B7-2001-A13	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138272	A
348	UTF -75 -75P005A	SS1-B7-2001-A14	INSPECT M/ SWGR & CB B7-2001-A14	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138270	B
349	UTF -75 -75P005B	SS1-B7-2001-A15	INSPECT M/ SWGR & CB B7-2001-A15	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138268	B
350	UTF -SS1-HVS	SS1-B7-2001-AB	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249655	A
351	UTF -SS1-HVS	SS1-B7-2001-AB	INSPECT M/ SWGR & CB B7-2001-AB	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138264	A
352	UTF -SS1-HVS	SS1-B7-2001-B02	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249656	A
353	UTF -SS1-HVS	SS1-B7-2001-B02	INSPECT M/ SWGR & CB B7-2001-B02	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138289	A
354	UTF -SS1-HVS	SS1-B7-2001-B03	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249657	A
355	UTF -SS1-HVS	SS1-B7-2001-B03	INSPECT M/ SWGR & CB B7-2001-B03	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138290	A
356	UTF -SS1-HVS	SS1-B7-2001-B04	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249658	A
357	UTF -SS1-HVS	SS1-B7-2001-B04	INSPECT M/ SWGR & CB B7-2001-B04	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138292	A
358	UTF -SS1-HVS	SS1-B7-2001-B05	PM M/ SWITCHGEAR + TEST RELAY	PMT	5Y											P		CCH	CCH-SWRL	249659	A
359	UTF -SS1-HVS	SS1-B7-2001-B05	INSPECT M/ SWGR & CB B7-2001-B05	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138294	A
360	UTF -74 -74P001B	SS1-B7-2001-B13	INSPECT M/ SWGR & CB B7-2001-B13	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138309	A
361	UTF -75 -75P005C	SS1-B7-2001-B14	INSPECT M/ SWGR & CB B7-2001-B14	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138310	B
362	UTF -SS1-UPS	SS1-B7-5001	INSPECTION UTF -SS1-UPS_B7 -5001	PMT	6M	I										I		CCH	CCH-UPS	140493	A
363	UTF -SS1-UPS	SS1-B7-5001	PM UTF -SS1-UPS_B7 -5001	PMT	1Y					P								CCH	CCH-UPS	251940	A
364	UTF -SS1-UPS	SS1-B7-5002	INSPECTION UTF -SS1-UPS_B7 -5002	PMT	6M	I										I		CCH	CCH-UPS	140494	A
365	UTF -SS1-UPS	SS1-B7-5002	PM UTF -SS1-UPS_B7 -5002	PMT	1Y					P								CCH	CCH-UPS	251941	A
366	UTF -SS1-BATT	SS1-BB-B7-5001-A	PM BATTERY 470 AH FOR UPS-B7-5001	PMT	1Y											P		CCH	CCH-UPS	140480	A
367	UTF -SS1-BATT	SS1-BB-B7-5002-A	PM BATTERY 150 AH FOR UPS-B7-5002	PMT	1Y											P		CCH	CCH-UPS	140481	A
368	UTF -SS1-BATT	SS1-BB-B7-5002-B	PM BATTERY 150 AH FOR UPS-B7-5002	PMT	1Y											P		CCH	CCH-UPS	140482	A
369	UTF -SS1-BATT	SS1-BB-B7-6001	PM BATTERY UNIT	PMT	1Y											P		CCH	CCH-UPS	140483	A
370	UTF -SS1-BC	SS1-BC-B7-6001	INSPECTION 110VDC FOR SWGR CONTROL	PMT	6M	I										I		CCH	CCH-UPS	140498	A
371	UTF -SS1-BC	SS1-BC-B7-6001	PM 110VDC FOR SWGR CONTROL	PMT	1Y					P								CCH	CCH-UPS	251944	A
372	UTF -SS1-AIR	SS1-CDU-B7-HV-201A	PM ALL TYPE OF AIR CON B7-HV-201A	PMT	6M						P					P		RRC	RRC-ERCH	140544	B
373	UTF -SS1-AIR	SS1-CDU-B7-HV-201B	PM ALL TYPE OF AIR CON B7-HV-201B	PMT	6M						P					P		RRC	RRC-ERCH	140545	B
374	UTF -SS1-AIR	SS1-CDU-B7-HV-201C	PM ALL TYPE OF AIR CON B7-HV-201C	PMT	6M						P					P		RRC	RRC-ERCH	140546	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
375	UTF -SS1-FIRE_ALARM	SS1-FA-DETECT-SD	PM SMOKE DETECTOR (###) UTF -SS1-FA	PMT	6M					P					P			RRC	RRC-ERCH	140416	A
376	UTF -SS1-FIRE_ALARM	SS1-FA-MCP	PM F/A PUSH BUTTON (###) (SUB1)	PMT	3M		P			P			P			P		RRC	RRC-ERCH	140376	A
377	UTF -SS1-INERGEN	SS1- ICP-004	INSPECTION INERGEN SYS UTF -SS1-INERGEN	PMT	1Y										I			RRC	RRC-ERCH	140421	A
378	UTF -SS1-FIRE_ALARM	SS1-LFCP-B7-5001	PM F/A PANEL LFCP-B7_5001 EL (SUB1)	PMT	1Y											P		RRC	RRC-ERCH	140400	A
379	UTF -SS1-TRANS	SS1-TR-B7-2001	OIL ANALYSIS (DGA,etc.) TR-B7-2001	PMT	1Y										Q			CCH	CCH-TRTL	140460	A
380	UTF -SS1-TRANS	SS1-TR-B7-2001	PM DISTRIBUTION TRANSFORMER	PMT	5Y											P		CCH	CCH-TRTL	249680	A
381	UTF -SS1-TRANS	SS1-TR-B7-2001	INSPECTION M/ TRANSFORMER TR-B7-2001	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138393	A
382	UTF -SS1-TRANS	SS1-TR-B7-2002	OIL ANALYSIS (DGA,etc.) TR-B7-2002	PMT	1Y										Q			CCH	CCH-TRTL	140461	A
383	UTF -SS1-TRANS	SS1-TR-B7-2002	PM DISTRIBUTION TRANSFORMER	PMT	5Y											P		CCH	CCH-TRTL	249681	A
384	UTF -SS1-TRANS	SS1-TR-B7-2002	INSPECTION M/ TRANSFORMER TR-B7-2002	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138394	A
385	UTF -SS1-TRANS	SS1-TR-B7-2003	OIL ANALYSIS (DGA,etc.) TR-B7-2003	PMT	1Y										Q			CCH	CCH-TRTL	140462	A
386	UTF -SS1-TRANS	SS1-TR-B7-2003	PM DISTRIBUTION TRANSFORMER	PMT	5Y											P		CCH	CCH-TRTL	249682	A
387	UTF -SS1-TRANS	SS1-TR-B7-2003	INSPECTION M/ TRANSFORMER TR-B7-2003	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138395	A
388	UTF -SS1-TRANS	SS1-TR-B7-2004	OIL ANALYSIS (DGA,etc.) TR-B7-2004	PMT	1Y										Q			CCH	CCH-TRTL	140463	A
389	UTF -SS1-TRANS	SS1-TR-B7-2004	PM DISTRIBUTION TRANSFORMER	PMT	5Y											P		CCH	CCH-TRTL	249683	A
390	UTF -SS1-TRANS	SS1-TR-B7-2004	INSPECTION M/ TRANSFORMER TR-B7-2004	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138396	A
391	UTF -SS1-TRANS	SS1-TR-B7-2005	OIL ANALYSIS (DGA,etc.) TR-B7-2005	PMT	1Y										Q			CCH	CCH-TRTL	140464	A
392	UTF -SS1-TRANS	SS1-TR-B7-2005	PM DISTRIBUTION TRANSFORMER	PMT	5Y											P		CCH	CCH-TRTL	249684	A
393	UTF -SS1-TRANS	SS1-TR-B7-2005	INSPECTION M/ TRANSFORMER TR-B7-2005	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138397	A
394	UTF -SS1-TRANS	SS1-TR-B7-2006	OIL ANALYSIS (DGA,etc.) TR-B7-2006	PMT	1Y										Q			CCH	CCH-TRTL	140465	A
395	UTF -SS1-TRANS	SS1-TR-B7-2006	PM DISTRIBUTION TRANSFORMER	PMT	5Y											P		CCH	CCH-TRTL	249685	A
396	UTF -SS1-TRANS	SS1-TR-B7-2006	INSPECTION M/ TRANSFORMER TR-B7-2006	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138398	A
397	UTF -SS2-AIR	SS2-AHU-B8-HV-101A	PM ALL TYPE OF AIR CON B8-HV-101A	PMT	6M					P					P			RRC	RRC-ERCH	140547	C
398	UTF -SS2-AIR	SS2-AHU-B8-HV-101A	Loop function test For HVAC	PMT	1Y								F					RRC	RRC-ERCH	156019	C
399	UTF -SS2-AIR	SS2-AHU-B8-HV-101B	PM ALL TYPE OF AIR CON B8-HV-101B	PMT	6M					P					P			RRC	RRC-ERCH	140548	C
400	UTF -SS2-UPS	SS2-B8-5001	INSPECTION UTF -SS2-UPS_B8 -5001	PMT	6M	I						I						CCH	CCH-UPS	140495	A
401	UTF -SS2-UPS	SS2-B8-5001	PM UTF -SS2-UPS_B8 -5001	PMT	1Y				P									CCH	CCH-UPS	251942	A
402	UTF -SS2-UPS	SS2-B8-5002	INSPECTION UTF -SS2-UPS_B8 -5002	PMT	6M	I						I						CCH	CCH-UPS	140496	A
403	UTF -SS2-UPS	SS2-B8-5002	PM UTF -SS2-UPS_B8 -5002	PMT	1Y				P									CCH	CCH-UPS	251943	A
404	UTF -SS2-BATT	SS2-BB-B8-5001	PM BATTERY UNIT	PMT	1Y											P		CCH	CCH-UPS	140484	A
405	UTF -SS2-BATT	SS2-BB-B8-5002-A	PM BATTERY 150 AH FOR UPS-B8-5002	PMT	1Y											P		CCH	CCH-UPS	140485	A
406	UTF -SS2-BATT	SS2-BB-B8-5002-B	PM BATTERY 150 AH FOR UPS-B8-5002	PMT	1Y											P		CCH	CCH-UPS	140486	A
407	UTF -SS2-BATT	SS2-BB-B8-6001	PM BATTERY UNIT	PMT	1Y											P		CCH	CCH-UPS	140487	A
408	UTF -SS2-BC	SS2-BC-B8-6001	INSPECTION 110VDC FOR SWGR CONTROL	PMT	6M	I						I						CCH	CCH-UPS	140499	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
409	UTF -SS2-BC	SS2-BC-B8-6001	PM 110VDC FOR SWGR CONTROL	PMT	1Y				P									CCH	CCH-UPS	251945	A
410	UTF -SS2-AIR	SS2-CDU-B8-HV-201A	PM ALL TYPE OF AIR CON B8-HV-201A	PMT	6M					P						P		RRC	RRC-ERCH	140549	B
411	UTF -SS2-AIR	SS2-CDU-B8-HV-201B	PM ALL TYPE OF AIR CON B8-HV-201B	PMT	6M					P						P		RRC	RRC-ERCH	140550	B
412	UTF -SS2-FIRE_ALARM	SS2-FA-DETECT-SD	PM SMOKE DETECTOR (###) UTF -SS2-FA	PMT	6M					P						P		RRC	RRC-ERCH	140417	A
413	UTF -SS2-FIRE_ALARM	SS2-FA-MCP	PM F/A PUSH BUTTON (###) (SUB2)	PMT	3M		P			P			P			P		RRC	RRC-ERCH	140377	A
414	UTF -SS2-INERGEN	SS2-ICP-002	INSPECTION INERGEN SYS UTF -SS2-INERGEN	PMT	1Y											I		RRC	RRC-ERCH	140422	A
415	UTF -SS2-FIRE_ALARM	SS2-LFCP-B8-003	PM F/A PANEL LFCP-003 EL (SUB2)	PMT	1Y											P		RRC	RRC-ERCH	140401	A
416	UTF -SS2-TRANS	SS2-TR-B8-2001	OIL ANALYSIS (DGA,etc.) TR_B8-2001	PMT	1Y											Q		CCH	CCH-TRTL	140455	A
417	UTF -SS2-TRANS	SS2-TR-B8-2001	PM DISTRIBUTION TRANSFORMER	PMT	5Y											P		CCH	CCH-TRTL	249686	A
418	UTF -SS2-TRANS	SS2-TR-B8-2001	INSPECTION M/ TRANSFORMER TR_B8-2001	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138388	A
419	UTF -SS2-TRANS	SS2-TR-B8-2002	OIL ANALYSIS (DGA,etc.) TR_B8-2002	PMT	1Y											Q		CCH	CCH-TRTL	140456	A
420	UTF -SS2-TRANS	SS2-TR-B8-2002	PM DISTRIBUTION TRANSFORMER	PMT	5Y											P		CCH	CCH-TRTL	249687	A
421	UTF -SS2-TRANS	SS2-TR-B8-2002	INSPECTION M/ TRANSFORMER TR_B8-2002	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138389	A
422	UTF -SS2-TRANS	SS2-TR-B8-2003	OIL ANALYSIS (DGA,etc.) TR_B8-2003	PMT	1Y											Q		CCH	CCH-TRTL	140453	A
423	UTF -SS2-TRANS	SS2-TR-B8-2003	PM DISTRIBUTION TRANSFORMER	PMT	5Y											P		CCH	CCH-TRTL	249688	A
424	UTF -SS2-TRANS	SS2-TR-B8-2003	INSPECTION M/ TRANSFORMER TR_B8-2003	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138386	A
425	UTF -SS2-TRANS	SS2-TR-B8-2004	OIL ANALYSIS (DGA,etc.) TR_B8-2004	PMT	1Y											Q		CCH	CCH-TRTL	140454	A
426	UTF -SS2-TRANS	SS2-TR-B8-2004	PM DISTRIBUTION TRANSFORMER	PMT	5Y											P		CCH	CCH-TRTL	249689	A
427	UTF -SS2-TRANS	SS2-TR-B8-2004	INSPECTION M/ TRANSFORMER TR_B8-2004	PMT	1M	I	I	I	I	I	I	I	I	I	I	I	I	RRC	RRC-ERCH	138387	A
428	UTF -MA -47H001	UTF-47H001-H01	OVERHEAD CRANE INSPECT & LOAD TEST_LAV	INT	6M					I						I		IRI	IRI-INSS	157594	C
429	UTF -74 -74E002A	UTF-74E002A-K01A	VB. INSP & ANALY M/C 74E002A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130432	C
430	UTF -74 -74E002A	UTF-74E002A-K01A	PM INSP OF M/C NO. 74E002A-K01A	PMT	3M	I				I			I		I			RRC	RRC-MRCH	129833	C
431	UTF -74 -74E002A	UTF-74E002A-K01A	REGREASING BRG OF 74E002A-K01A	PMT	3M		L				L			L		L		RRC	RRC-MRCH	130058	C
432	UTF -74 -74E002A	UTF-74E002A-K01A-M	Regreasing Mot BRG of 74E002A-K01A-MD1	PMT	4M	L					L			L				RRC	RRC-ERCH	139737	C
433	UTF -74 -74E002A	UTF-74E002A-K01B	VB. INSP & ANALY M/C 74E002A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130433	C
434	UTF -74 -74E002A	UTF-74E002A-K01B	PM INSP OF M/C NO. 74E002A-K01B	PMT	3M	I				I			I		I			RRC	RRC-MRCH	129834	C
435	UTF -74 -74E002A	UTF-74E002A-K01B	REGREASING BRG OF 74E002A-K01B	PMT	3M		L				L			L		L		RRC	RRC-MRCH	130059	C
436	UTF -74 -74E002A	UTF-74E002A-K01B-M	Regreasing Mot BRG of 74E002A-K01B-MD1	PMT	4M				L					L			L	RRC	RRC-ERCH	139738	C
437	UTF -74 -74E002B	UTF-74E002B-K01A	VB. INSP & ANALY M/C 74E002B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130434	C
438	UTF -74 -74E002B	UTF-74E002B-K01A	PM INSP OF M/C NO. 74E002B-K01A	PMT	3M		I			I			I		I			RRC	RRC-MRCH	129835	C
439	UTF -74 -74E002B	UTF-74E002B-K01A	REGREASING BRG OF 74E002B-K01A	PMT	3M		L			L			L		L			RRC	RRC-MRCH	130060	C
440	UTF -74 -74E002B	UTF-74E002B-K01A-M	Regreasing Mot BRG of 74E002B-K01A-MD1	PMT	4M	L				L			L					RRC	RRC-ERCH	139739	C
441	UTF -74 -74E002B	UTF-74E002B-K01B	VB. INSP & ANALY M/C 74E002B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130435	C
442	UTF -74 -74E002B	UTF-74E002B-K01B	PM INSP OF M/C NO. 74E002B-K01B	PMT	3M		I			I			I		I			RRC	RRC-MRCH	129836	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
443	UTF -74 -74E002B	UTF-74E002B-K01B	REGREASING BRG OF 74E002B-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130061	C
444	UTF -74 -74E002B	UTF-74E002B-K01B-M	Regreasing Mot BRG of 74E002B-K01B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCH	139740	C
445	UTF -74 -74E002C	UTF-74E002C-K01A	VB. INSP & ANALY M/C 74E002C-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130436	C
446	UTF -74 -74E002C	UTF-74E002C-K01A	PM INSP OF M/C NO. 74E002C-K01A	PMT	3M			I			I			I			I	RRC	RRC-MRCH	129837	C
447	UTF -74 -74E002C	UTF-74E002C-K01A	REGREASING BRG OF 74E002C-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130062	C
448	UTF -74 -74E002C	UTF-74E002C-K01A-M	Regreasing Mot BRG of 74E002C-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139741	C
449	UTF -74 -74E002C	UTF-74E002C-K01B	VB. INSP & ANALY M/C 74E002C-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130437	C
450	UTF -74 -74E002C	UTF-74E002C-K01B	PM INSP OF M/C NO. 74E002C-K01B	PMT	3M			I			I			I			I	RRC	RRC-MRCH	129838	C
451	UTF -74 -74E002C	UTF-74E002C-K01B	REGREASING BRG OF 74E002C-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130063	C
452	UTF -74 -74E002C	UTF-74E002C-K01B-M	Regreasing Mot BRG of 74E002C-K01B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCH	139742	C
453	UTF -74 -74E002D	UTF-74E002D-K01A	VB. INSP & ANALY M/C 74E002D-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130438	C
454	UTF -74 -74E002D	UTF-74E002D-K01A	PM INSP OF M/C NO. 74E002D-K01A	PMT	3M	I			I			I		I				RRC	RRC-MRCH	129839	C
455	UTF -74 -74E002D	UTF-74E002D-K01A	REGREASING BRG OF 74E002D-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130064	C
456	UTF -74 -74E002D	UTF-74E002D-K01A-M	Regreasing Mot BRG of 74E002D-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139743	C
457	UTF -74 -74E002D	UTF-74E002D-K01B	VB. INSP & ANALY M/C 74E002D-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130439	C
458	UTF -74 -74E002D	UTF-74E002D-K01B	PM INSP OF M/C NO. 74E002D-K01B	PMT	3M	I			I			I		I				RRC	RRC-MRCH	129840	C
459	UTF -74 -74E002D	UTF-74E002D-K01B	REGREASING BRG OF 74E002D-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130065	C
460	UTF -74 -74E002D	UTF-74E002D-K01B-M	Regreasing Mot BRG of 74E002D-K01B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCH	139744	C
461	UTF -74 -74E004A	UTF-74E004A-K01A	VB. INSP & ANALY M/C 74E004A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130440	C
462	UTF -74 -74E004A	UTF-74E004A-K01A	PM INSP OF M/C NO. 74E004A-K01A	PMT	3M		I			I			I			I		RRC	RRC-MRCH	129841	C
463	UTF -74 -74E004A	UTF-74E004A-K01A	REGREASING BRG OF 74E004A-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130066	C
464	UTF -74 -74E004A	UTF-74E004A-K01A-M	Regreasing Mot BRG of 74E004A-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139745	C
465	UTF -74 -74E004A	UTF-74E004A-K01B	VB. INSP & ANALY M/C 74E004A-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130441	C
466	UTF -74 -74E004A	UTF-74E004A-K01B	PM INSP OF M/C NO. 74E004A-K01B	PMT	3M		I			I			I			I		RRC	RRC-MRCH	129842	C
467	UTF -74 -74E004A	UTF-74E004A-K01B	REGREASING BRG OF 74E004A-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130067	C
468	UTF -74 -74E004A	UTF-74E004A-K01B-M	Regreasing Mot BRG of 74E004A-K01B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCH	139746	C
469	UTF -74 -74E004B	UTF-74E004B-K01A	VB. INSP & ANALY M/C 74E004B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130442	C
470	UTF -74 -74E004B	UTF-74E004B-K01A	PM INSP OF M/C NO. 74E004B-K01A	PMT	3M			I			I			I			I	RRC	RRC-MRCH	129843	C
471	UTF -74 -74E004B	UTF-74E004B-K01A	REGREASING BRG OF 74E004B-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130068	C
472	UTF -74 -74E004B	UTF-74E004B-K01A-M	Regreasing Mot BRG of 74E004B-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139747	C
473	UTF -74 -74E004B	UTF-74E004B-K01B	VB. INSP & ANALY M/C 74E004B-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130443	C
474	UTF -74 -74E004B	UTF-74E004B-K01B	PM INSP OF M/C NO. 74E004B-K01B	PMT	3M			I			I			I			I	RRC	RRC-MRCH	129844	C
475	UTF -74 -74E004B	UTF-74E004B-K01B	REGREASING BRG OF 74E004B-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130069	C
476	UTF -74 -74E004B	UTF-74E004B-K01B-M	Regreasing Mot BRG of 74E004B-K01B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCH	139748	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
477	UTF -74 -74E004C	UTF-74E004C-K01A	VB. INSP & ANALY M/C 74E004C-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130444	C
478	UTF -74 -74E004C	UTF-74E004C-K01A	PM INSP OF M/C NO. 74E004C-K01A	PMT	3M	I			I			I		I				RRC	RRC-MRCH	129845	C
479	UTF -74 -74E004C	UTF-74E004C-K01A	REGREASING BRG OF 74E004C-K01A	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130070	C
480	UTF -74 -74E004C	UTF-74E004C-K01A-M	Regreasing Mot BRG of 74E004C-K01A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139749	C
481	UTF -74 -74E004C	UTF-74E004C-K01B	VB. INSP & ANALY M/C 74E004C-K	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130445	C
482	UTF -74 -74E004C	UTF-74E004C-K01B	PM INSP OF M/C NO. 74E004C-K01B	PMT	3M	I			I			I		I				RRC	RRC-MRCH	129846	C
483	UTF -74 -74E004C	UTF-74E004C-K01B	REGREASING BRG OF 74E004C-K01B	PMT	3M		L			L			L			L		RRC	RRC-MRCH	130071	C
484	UTF -74 -74E004C	UTF-74E004C-K01B-M	Regreasing Mot BRG of 74E004C-K01B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCH	139750	C
485	UTF -74 -74P001A	UTF-74P001A-M	STAND BY CHECK MV. MOT 74P001A-MD1	PMT	1Y		T											RRC	RRC-ERCH	139265	A
486	UTF -74 -74P001A	UTF-74P001A-M	Change BRG Lube Oil of Mot 74P001A-MD1	PMT	1Y				L									RRC	RRC-ERCH	139422	A
487	UTF -74 -74P001A	UTF-74P001A-M	STAND BY CHECK MV. MOT 74P001A-MD1	PMT	1Y				T									RRC	RRC-ERCH	154294	A
488	UTF -74 -74P001A	UTF-74P001A-P01	OIL INSP & ANALYSIS M/C 74P001A -P01	INT	1M	I	I											IRI	IRI-INDL	152198	A
489	UTF -74 -74P001A	UTF-74P001A-P01	VB. INSP & ANALY M/C 74P001A	INT	4M	I				I			I					IRI	IRI-INVB	130446	A
490	UTF -74 -74P001A	UTF-74P001A-P01	VB. INSP & ANALY M/C 74P001A	INT	4M		I				I			I				IRI	IRI-INVB	131102	A
491	UTF -74 -74P001A	UTF-74P001A-P01	VB. INSP & ANALY M/C 74P001A	INT	4M			I				I			I			IRI	IRI-INVB	131328	A
492	UTF -74 -74P001A	UTF-74P001A-P01	PM INSP OF M/C NO. 74P001A	PMT	4M	I				I			I					RRC	RRC-MRCH	129847	A
493	UTF -74 -74P001A	UTF-74P001A-P02	VB. INSP & ANALY M/C 74P001A-P01-P02	INT	4M		I				I			I				IRI	IRI-INVB	149569	A
494	UTF -74 -74P001A	UTF-74P001A-P02	PM INSP OF M/C NO. 74P001A -P01 -P02	PMT	4M		I				I			I				RRC	RRC-MRCH	149191	A
495	UTF -74 -74P001B	UTF-74P001B-M	STAND BY CHECK MV. MOT 74P001B-MD1	PMT	6M			T						T				RRC	RRC-ERCH	139266	A
496	UTF -74 -74P001B	UTF-74P001B-M	Change BRG Lube Oil of Mot 74P001B-MD1	PMT	1Y				L									RRC	RRC-ERCH	139423	A
497	UTF -74 -74P001B	UTF-74P001B-P01	OIL INSP & ANALYSIS M/C 74P001B -P01	INT	1M	I	I											IRI	IRI-INDL	152199	A
498	UTF -74 -74P001B	UTF-74P001B-P01	VB. INSP & ANALY M/C 74P001B	INT	4M				I				I				I	IRI	IRI-INVB	130447	A
499	UTF -74 -74P001B	UTF-74P001B-P01	PM INSP OF M/C NO. 74P001B	PMT	4M				I				I				I	RRC	RRC-MRCH	129848	A
500	UTF -74 -74P001B	UTF-74P001B-P02	VB. INSP & ANALY M/C 74P001B-P01-P02	INT	4M		I				I			I				IRI	IRI-INVB	149570	A
501	UTF -74 -74P001B	UTF-74P001B-P02	PM INSP OF M/C NO. 74P001B -P01 -P02	PMT	4M		I				I			I				RRC	RRC-MRCH	149192	A
502	UTF -74 -74P002A	UTF-74P002A-M	STAND BY CHECK LV. MOT 74P002A-MD1	PMT	1Y		T											RRC	RRC-ERCH	139267	B
503	UTF -74 -74P002A	UTF-74P002A-M	Regreasing Mot BRG of 74P002A-MD1	PMT	4M	L				L			L					RRC	RRC-ERCH	139424	B
504	UTF -74 -74P002A	UTF-74P002A-M	STAND BY CHECK LV. MOT 74P002A-MD1	PMT	1Y				T									RRC	RRC-ERCH	154295	B
505	UTF -74 -74P002A	UTF-74P002A-P01	VB. INSP & ANALY M/C 74P002A	INT	4M	I				I			I					IRI	IRI-INVB	130448	B
506	UTF -74 -74P002A	UTF-74P002A-P01	VB. INSP & ANALY M/C 74P002A	INT	4M		I				I			I				IRI	IRI-INVB	131103	B
507	UTF -74 -74P002A	UTF-74P002A-P01	VB. INSP & ANALY M/C 74P002A	INT	4M			I				I			I			IRI	IRI-INVB	131329	B
508	UTF -74 -74P002A	UTF-74P002A-P01	PM INSP OF M/C NO. 74P002A	PMT	4M	I				I			I					RRC	RRC-MRCH	129849	B
509	UTF -74 -74P002A	UTF-74P002A-P01	PM OF 74P002A	PMT	4M				P				P				P	RRC	RRC-MRCH	130826	B
510	UTF -74 -74P002B	UTF-74P002B-M	STAND BY CHECK LV. MOT 74P002B-MD1	PMT	6M			T					T					RRC	RRC-ERCH	139268	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
511	UTF -74 -74P002B	UTF-74P002B-M	Regreasing Mot BRG of 74P002B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCH	139425	B
512	UTF -74 -74P002B	UTF-74P002B-P01	VB. INSP & ANALY M/C 74P002B	INT	4M				I				I				I	IRI	IRI-INVB	130449	B
513	UTF -74 -74P002B	UTF-74P002B-P01	PM INSP OF M/C NO. 74P002B	PMT	4M				I				I				I	RRC	RRC-MRCH	129850	B
514	UTF -74 -74P002B	UTF-74P002B-P01	PM OF 74P002B	PMT	4M	P				P				P				RRC	RRC-MRCH	130827	B
515	UTF -74 -74P003A	UTF-74P003A-M	STAND BY CHECK LV. MOT 74P003A-MD1	PMT	1Y							T						RRC	RRC-ERCH	139269	B
516	UTF -74 -74P003A	UTF-74P003A-M	Regreasing Mot BRG of 74P003A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139426	B
517	UTF -74 -74P003A	UTF-74P003A-M	STAND BY CHECK LV. MOT 74P003A-MD1	PMT	1Y				T									RRC	RRC-ERCH	154296	B
518	UTF -74 -74P003A	UTF-74P003A-P01	VB. INSP & ANALY M/C 74P003A	INT	4M	I				I				I				IRI	IRI-INVB	130450	B
519	UTF -74 -74P003A	UTF-74P003A-P01	VB. INSP & ANALY M/C 74P003A	INT	4M		I				I				I			IRI	IRI-INVB	131104	B
520	UTF -74 -74P003A	UTF-74P003A-P01	VB. INSP & ANALY M/C 74P003A	INT	4M			I				I				I		IRI	IRI-INVB	131330	B
521	UTF -74 -74P003A	UTF-74P003A-P01	PM INSP OF M/C NO. 74P003A	PMT	4M	I				I				I				RRC	RRC-MRCH	129851	B
522	UTF -74 -74P003A	UTF-74P003A-P01	PM OF 74P003A	PMT	4M				P				P				P	RRC	RRC-MRCH	130828	B
523	UTF -74 -74P003B	UTF-74P003B-M	STAND BY CHECK LV. MOT 74P003B-MD1	PMT	6M			T						T				RRC	RRC-ERCH	139270	B
524	UTF -74 -74P003B	UTF-74P003B-M	Regreasing Mot BRG of 74P003B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCH	139427	B
525	UTF -74 -74P003B	UTF-74P003B-P01	VB. INSP & ANALY M/C 74P003B	INT	4M				I				I				I	IRI	IRI-INVB	130451	B
526	UTF -74 -74P003B	UTF-74P003B-P01	PM INSP OF M/C NO. 74P003B	PMT	4M				I				I				I	RRC	RRC-MRCH	129852	B
527	UTF -74 -74P003B	UTF-74P003B-P01	PM OF 74P003B	PMT	4M	P				P				P				RRC	RRC-MRCH	130829	B
528	UTF -74 -74P004A	UTF-74P004A-M	STAND BY CHECK LV. MOT 74P004A-MD1	PMT	1Y							T						RRC	RRC-ERCH	139271	B
529	UTF -74 -74P004A	UTF-74P004A-M	Regreasing Mot BRG of 74P004A-MD1	PMT	4M	L				L				L				RRC	RRC-ERCH	139428	B
530	UTF -74 -74P004A	UTF-74P004A-M	STAND BY CHECK LV. MOT 74P004A-MD1	PMT	1Y				T									RRC	RRC-ERCH	154297	B
531	UTF -74 -74P004A	UTF-74P004A-P01	VB. INSP & ANALY M/C 74P004A	INT	4M	I				I				I				IRI	IRI-INVB	130452	B
532	UTF -74 -74P004A	UTF-74P004A-P01	VB. INSP & ANALY M/C 74P004A	INT	4M		I				I				I			IRI	IRI-INVB	131105	B
533	UTF -74 -74P004A	UTF-74P004A-P01	VB. INSP & ANALY M/C 74P004A	INT	4M			I				I				I		IRI	IRI-INVB	131331	B
534	UTF -74 -74P004A	UTF-74P004A-P01	PM INSP OF M/C NO. 74P004A	PMT	4M	I				I				I				RRC	RRC-MRCH	129853	B
535	UTF -74 -74P004A	UTF-74P004A-P01	PM OF 74P004A	PMT	4M				P				P				P	RRC	RRC-MRCH	130830	B
536	UTF -74 -74P004B	UTF-74P004B-M	STAND BY CHECK LV. MOT 74P004B-MD1	PMT	6M			T						T				RRC	RRC-ERCH	139272	B
537	UTF -74 -74P004B	UTF-74P004B-M	Regreasing Mot BRG of 74P004B-MD1	PMT	4M				L				L				L	RRC	RRC-ERCH	139429	B
538	UTF -74 -74P004B	UTF-74P004B-P01	VB. INSP & ANALY M/C 74P004B	INT	4M				I				I				I	IRI	IRI-INVB	130453	B
539	UTF -74 -74P004B	UTF-74P004B-P01	PM INSP OF M/C NO. 74P004B	PMT	4M				I				I				I	RRC	RRC-MRCH	129854	B
540	UTF -74 -74P004B	UTF-74P004B-P01	PM OF 74P004B	PMT	4M	P				P				P				RRC	RRC-MRCH	130831	B
541	UTF -74 -74T001	UTF-74T001-4001	INSPECTION CATHODIC PROTECTION 74T001	PMT	2M		I		I		I		I		I		I	RRC	RRC-ERCH	140431	C
542	UTF -74 -74T001	UTF-74T001-T01	Storage tank inspection	PMT	5Y									I				IRI	IRI-INRC	177830	C
543	UTF -74 -74T001	UTF-74T001-T01	PM; FOR Emergency Vent Cover 74T001	PMT	6M					P						P		RRC	RRC-MRCH	254634	C
544	UTF -74 -74T002	UTF-74T002-4002	INSPECTION CATHODIC PROTECTION 74T002	PMT	2M		I		I		I		I		I		I	RRC	RRC-ERCH	140432	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
545	UTF -74 -74T002	UTF-74T002-T01	Storage tank inspection	PMT	5Y									I				IRI	IRI-INRC	177831	C
546	UTF -74 -74T002	UTF-74T002-T01	PM; FOR Emergency Vent Cover 74T002	PMT	6M						P					P		RRC	RRC-MRCH	254635	C
547	UTF -74 -74X001	UTF-74X001-K01A	PM OF 74X001 -K01A	PMT	4M			P				P			P			RRC	RRC-MRCH	148842	B
548	UTF -74 -74X001	UTF-74X001-K01A	PM INSP OF M/C NO. 74X001 -K01A	PMT	4M				I				I			I		RRC	RRC-MRCH	149193	B
549	UTF -74 -74X001	UTF-74X001-K01A-M	STAND BY CHECK LV. MOT 74X001-K01A-MD1	PMT	1Y									T				RRC	RRC-ERCH	139273	B
550	UTF -74 -74X001	UTF-74X001-K01A-M	STAND BY CHECK LV. MOT 74X001-K01A-MD1	PMT	1Y					T								RRC	RRC-ERCH	154298	B
551	UTF -74 -74X001	UTF-74X001-K01B	PM OF 74X001 -K01B	PMT	4M			P				P			P			RRC	RRC-MRCH	148843	B
552	UTF -74 -74X001	UTF-74X001-K01B	PM INSP OF M/C NO. 74X001 -K01B	PMT	4M				I				I			I		RRC	RRC-MRCH	149194	B
553	UTF -74 -74X001	UTF-74X001-K01B-M	STAND BY CHECK LV. MOT 74X001-K01B-MD1	PMT	6M				T					T				RRC	RRC-ERCH	139274	B
554	UTF -74 -74X001	UTF-74X001-P02A	PM INSP OF M/C NO. 74X001 -P02A	PMT	4M	I				I				I				RRC	RRC-MRCH	129855	C
555	UTF -74 -74X001	UTF-74X001-P02A	PM OF 74X001 -P02A	PMT	4M			P				P			P			RRC	RRC-MRCH	130832	C
556	UTF -74 -74X001	UTF-74X001-P02A-M	STAND BY CHECK LV. MOT 74X001-P02A-MD1	PMT	1Y									T				RRC	RRC-ERCH	139275	B
557	UTF -74 -74X001	UTF-74X001-P02A-M	STAND BY CHECK LV. MOT 74X001-P02A-MD1	PMT	1Y					T								RRC	RRC-ERCH	154299	B
558	UTF -74 -74X001	UTF-74X001-P02B	PM INSP OF M/C NO. 74X001 -P02B	PMT	4M				I			I			I			RRC	RRC-MRCH	129856	C
559	UTF -74 -74X001	UTF-74X001-P02B	PM OF 74X001 -P02B	PMT	4M	P				P				P				RRC	RRC-MRCH	130833	C
560	UTF -74 -74X001	UTF-74X001-P02B-M	STAND BY CHECK LV. MOT 74X001-P02B-MD1	PMT	6M				T					T				RRC	RRC-ERCH	139276	B
561	UTF -74 -74X001	UTF-74X001-P03A	PM INSP OF M/C NO. 74X001 -P03A	PMT	4M		I			I				I				RRC	RRC-MRCH	129857	B
562	UTF -74 -74X001	UTF-74X001-P03A	PM OF 74X001 -P03A	PMT	4M				P				P				P	RRC	RRC-MRCH	130834	B
563	UTF -74 -74X001	UTF-74X001-P03A-M	STAND BY CHECK LV. MOT 74X001-P03A-MD1	PMT	1Y									T				RRC	RRC-ERCH	139277	B
564	UTF -74 -74X001	UTF-74X001-P03A-M	STAND BY CHECK LV. MOT 74X001-P03A-MD1	PMT	1Y					T								RRC	RRC-ERCH	154300	B
565	UTF -74 -74X001	UTF-74X001-P03B	PM INSP OF M/C NO. 74X001 -P03B	PMT	4M				I			I			I			RRC	RRC-MRCH	129858	B
566	UTF -74 -74X001	UTF-74X001-P03B	PM OF 74X001 -P03B	PMT	4M	P				P				P				RRC	RRC-MRCH	130835	B
567	UTF -74 -74X001	UTF-74X001-P03B-M	STAND BY CHECK LV. MOT 74X001-P03B-MD1	PMT	6M				T					T				RRC	RRC-ERCH	139278	B
568	UTF -74 -74X001	UTF-74X001-P04A	PM INSP OF M/C NO. 74X001 -P04A	PMT	4M		I			I		I			I			RRC	RRC-MRCH	129859	B
569	UTF -74 -74X001	UTF-74X001-P04A	PM OF 74X001 -P04A	PMT	4M	P				P				P				RRC	RRC-MRCH	130836	B
570	UTF -74 -74X001	UTF-74X001-P04A-M	STAND BY CHECK LV. MOT 74X001-P04A-MD1	PMT	1Y									T				RRC	RRC-ERCH	139279	B
571	UTF -74 -74X001	UTF-74X001-P04A-M	STAND BY CHECK LV. MOT 74X001-P04A-MD1	PMT	1Y					T								RRC	RRC-ERCH	154301	B
572	UTF -74 -74X001	UTF-74X001-P04B	PM INSP OF M/C NO. 74X001 -P04B	PMT	4M				I			I			I			RRC	RRC-MRCH	129860	B
573	UTF -74 -74X001	UTF-74X001-P04B	PM OF 74X001 -P04B	PMT	4M		P				P				P			RRC	RRC-MRCH	130837	B
574	UTF -74 -74X001	UTF-74X001-P04B-M	STAND BY CHECK LV. MOT 74X001-P04B-MD1	PMT	6M				T					T				RRC	RRC-ERCH	139280	B
575	UTF -74 -74X001	UTF-74X001-P05A	PM INSP OF M/C NO. 74X001 -P05A	PMT	4M	I				I			I					RRC	RRC-MRCH	129861	B
576	UTF -74 -74X001	UTF-74X001-P05A	PM OF 74X001 -P05A	PMT	4M			P				P			P			RRC	RRC-MRCH	130838	B
577	UTF -74 -74X001	UTF-74X001-P05A-M	STAND BY CHECK LV. MOT 74X001-P05A-MD1	PMT	1Y									T				RRC	RRC-ERCH	139281	B
578	UTF -74 -74X001	UTF-74X001-P05A-M	STAND BY CHECK LV. MOT 74X001-P05A-MD1	PMT	1Y					T								RRC	RRC-ERCH	154302	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
579	UTF -74 -74X001	UTF-74X001-P05B	PM INSP OF M/C NO. 74X001 -P05B	PMT	4M			I				I				I		RRC	RRC-MRCH	129862	B
580	UTF -74 -74X001	UTF-74X001-P05B	PM OF 74X001 -P05B	PMT	4M		P				P				P			RRC	RRC-MRCH	130839	B
581	UTF -74 -74X001	UTF-74X001-P05B-M	STAND BY CHECK LV. MOT 74X001-P05B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139282	B
582	UTF -74 -74X001	UTF-74X001-P06A	PM INSP OF M/C NO. 74X001 -P06A	PMT	4M	I				I				I				RRC	RRC-MRCH	129863	B
583	UTF -74 -74X001	UTF-74X001-P06A	PM OF 74X001 -P06A	PMT	4M		P				P				P			RRC	RRC-MRCH	130840	B
584	UTF -74 -74X001	UTF-74X001-P06A-M	STAND BY CHECK LV. MOT 74X001-P06A-M01	PMT	1Y								T					RRC	RRC-ERCH	139283	B
585	UTF -74 -74X001	UTF-74X001-P06A-M	STAND BY CHECK LV. MOT 74X001-P06A-M01	PMT	1Y					T								RRC	RRC-ERCH	154303	B
586	UTF -74 -74X001	UTF-74X001-P06B	PM INSP OF M/C NO. 74X001 -P06B	PMT	4M			I				I				I		RRC	RRC-MRCH	129864	B
587	UTF -74 -74X001	UTF-74X001-P06B	PM OF 74X001 -P06B	PMT	4M		P				P			P				RRC	RRC-MRCH	130841	B
588	UTF -74 -74X001	UTF-74X001-P06B-M	STAND BY CHECK LV. MOT 74X001-P06B-M01	PMT	6M			T					T					RRC	RRC-ERCH	139284	B
589	UTF -74 -74X001	UTF-74X001-P07A	VB. INSP & ANALY M/C 74X001	INT	4M	I				I			I					IRI	IRI-INVB	130464	B
590	UTF -74 -74X001	UTF-74X001-P07A	VB. INSP & ANALY M/C 74X001 -P07A	INT	4M			I				I				I		IRI	IRI-INVB	131111	B
591	UTF -74 -74X001	UTF-74X001-P07A	VB. INSP & ANALY M/C 74X001 -P07A	INT	4M					I			I					IRI	IRI-INVB	131337	B
592	UTF -74 -74X001	UTF-74X001-P07A	PM INSP OF M/C NO. 74X001 -P07A	PMT	4M	I					I			I				RRC	RRC-MRCH	129865	B
593	UTF -74 -74X001	UTF-74X001-P07A	PM OF 74X001 -P07A	PMT	4M				P				P				P	RRC	RRC-MRCH	130842	B
594	UTF -74 -74X001	UTF-74X001-P07A-M	STAND BY CHECK LV. MOT 74X001-P07A-M01	PMT	1Y								T					RRC	RRC-ERCH	139285	B
595	UTF -74 -74X001	UTF-74X001-P07A-M	STAND BY CHECK LV. MOT 74X001-P07A-M01	PMT	1Y				T									RRC	RRC-ERCH	154304	B
596	UTF -74 -74X001	UTF-74X001-P07B	VB. INSP & ANALY M/C 74X001	INT	4M				I			I				I		IRI	IRI-INVB	130465	B
597	UTF -74 -74X001	UTF-74X001-P07B	PM INSP OF M/C NO. 74X001 -P07B	PMT	4M			I				I				I		RRC	RRC-MRCH	129866	B
598	UTF -74 -74X001	UTF-74X001-P07B	PM OF 74X001 -P07B	PMT	4M		P				P			P				RRC	RRC-MRCH	130843	B
599	UTF -74 -74X001	UTF-74X001-P07B-M	STAND BY CHECK LV. MOT 74X001-P07B-M01	PMT	6M			T					T					RRC	RRC-ERCH	139286	B
600	UTF -74 -74X001	UTF-74X001-P08A	VB. INSP & ANALY M/C 74X001	INT	4M	I				I			I					IRI	IRI-INVB	130466	B
601	UTF -74 -74X001	UTF-74X001-P08A	VB. INSP & ANALY M/C 74X001 -P08A	INT	4M			I				I				I		IRI	IRI-INVB	131112	B
602	UTF -74 -74X001	UTF-74X001-P08A	VB. INSP & ANALY M/C 74X001 -P08A	INT	4M					I			I					IRI	IRI-INVB	131338	B
603	UTF -74 -74X001	UTF-74X001-P08A	PM INSP OF M/C NO. 74X001 -P08A	PMT	4M	I					I			I				RRC	RRC-MRCH	129867	B
604	UTF -74 -74X001	UTF-74X001-P08A	PM OF 74X001 -P08A	PMT	4M				P				P				P	RRC	RRC-MRCH	130844	B
605	UTF -74 -74X001	UTF-74X001-P08A-M	STAND BY CHECK LV. MOT 74X001-P08A-M01	PMT	1Y								T					RRC	RRC-ERCH	139287	B
606	UTF -74 -74X001	UTF-74X001-P08A-M	STAND BY CHECK LV. MOT 74X001-P08A-M01	PMT	1Y					T								RRC	RRC-ERCH	154305	B
607	UTF -74 -74X001	UTF-74X001-P08B	VB. INSP & ANALY M/C 74X001	INT	4M					I			I				I	IRI	IRI-INVB	130467	B
608	UTF -74 -74X001	UTF-74X001-P08B	PM INSP OF M/C NO. 74X001 -P08B	PMT	4M			I				I				I		RRC	RRC-MRCH	129868	B
609	UTF -74 -74X001	UTF-74X001-P08B	PM OF 74X001 -P08B	PMT	4M		P				P			P				RRC	RRC-MRCH	130845	B
610	UTF -74 -74X001	UTF-74X001-P08B-M	STAND BY CHECK LV. MOT 74X001-P08B-M01	PMT	6M			T					T					RRC	RRC-ERCH	139288	B
611	UTF -74 -74X001	UTF-74X001-PLC	INSPECT PLC SYSTEM	PMT	3M		I			I			I			I		CCS	CCS-SYS	246504	A
612	UTF -74 -74X001	UTF-74X001-PLC	BACKUP PLC SYSTEM	PMT	6M		I						I					CCS	CCS-SYS	246505	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
613	UTF -74 -74X002	UTF-74X002-P01A	PM INSP OF M/C NO. 74X002 -P01A	PMT	4M	I				I				I				RRC	RRC-MRCH	129869	B
614	UTF -74 -74X002	UTF-74X002-P01A	PM OF 74X002 -P01A	PMT	4M				P				P				P	RRC	RRC-MRCH	130846	B
615	UTF -74 -74X002	UTF-74X002-P01A-M	STAND BY CHECK LV. MOT 74X002-P01A-M01	PMT	1Y								T					RRC	RRC-ERCH	139289	B
616	UTF -74 -74X002	UTF-74X002-P01B	PM INSP OF M/C NO. 74X002 -P01B	PMT	4M		I				I			I				RRC	RRC-MRCH	129870	B
617	UTF -74 -74X002	UTF-74X002-P01B	PM OF 74X002 -P01B	PMT	4M				P				P				P	RRC	RRC-MRCH	130847	B
618	UTF -74 -74X002	UTF-74X002-P01B-M	STAND BY CHECK LV. MOT 74X002-P01B-M01	PMT	6M				T					T				RRC	RRC-ERCH	139290	B
619	UTF -75 -75F001A	UTF-75F001A-F01	PM OF 75F001A	PMT	4M		P				P				P			RRC	RRC-MRCH	148844	B
620	UTF -75 -75F001A	UTF-75F001A-F01	PM INSP OF M/C NO. 75F001A	PMT	4M		I				I				I			RRC	RRC-MRCH	149195	B
621	UTF -75 -75F001B	UTF-75F001B-F01	PM OF 75F001B	PMT	4M		P				P				P			RRC	RRC-MRCH	148845	B
622	UTF -75 -75F001B	UTF-75F001B-F01	PM INSP OF M/C NO. 75F001B	PMT	4M		I				I				I			RRC	RRC-MRCH	149196	B
623	UTF -75 -75K001A	UTF-75K001A-M	VB. INSP & ANALY M/C 75K001A	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	150217	B
624	UTF -75 -75K001A	UTF-75K001A-M	Regreasing Mot BRG of UTF-75K001A-M	PMT	4M				L				L				L	RRC	RRC-ERCH	249383	B
625	UTF -75 -75K001A	UTF-75K001A-Z01	PM INSP OF M/C NO. 75K001A -Z01	PMT	3M				I				I				I	RRC	RRC-MRCH	148846	B
626	UTF -75 -75K001A	UTF-75K001A-Z01	PM OF 75K001A -Z01	PMT	3M				P				P				P	RRC	RRC-MRCH	148847	B
627	UTF -75 -75K001B	UTF-75K001B-M	VB. INSP & ANALY M/C 75K001B	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	150218	B
628	UTF -75 -75K001B	UTF-75K001B-M	Regreasing Mot BRG of UTF-75K001B-M	PMT	4M				L				L				L	RRC	RRC-ERCH	249384	B
629	UTF -75 -75K001B	UTF-75K001B-Z01	PM INSP OF M/C NO. 75K001B -Z01	PMT	3M				I				I				I	RRC	RRC-MRCH	148848	B
630	UTF -75 -75K001B	UTF-75K001B-Z01	PM OF 75K001B -Z01	PMT	3M				P				P				P	RRC	RRC-MRCH	148849	B
631	UTF -75 -75K001C	UTF-75K001C-M	VB. INSP & ANALY M/C 75K001C	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	150219	B
632	UTF -75 -75K001C	UTF-75K001C-M	Regreasing Mot BRG of UTF-75K001C-M	PMT	4M				L				L				L	RRC	RRC-ERCH	249385	B
633	UTF -75 -75K001C	UTF-75K001C-Z01	PM INSP OF M/C NO. 75K001C -Z01	PMT	3M				I				I				I	RRC	RRC-MRCH	148850	B
634	UTF -75 -75K001C	UTF-75K001C-Z01	PM OF 75K001C -Z01	PMT	3M				P				P				P	RRC	RRC-MRCH	148851	B
635	UTF -75 -75K001D	UTF-75K001D-M	VB. INSP & ANALY M/C 75K001D	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	150220	B
636	UTF -75 -75K001D	UTF-75K001D-M	Regreasing Mot BRG of UTF-75K001D-M	PMT	4M				L				L				L	RRC	RRC-ERCH	249386	B
637	UTF -75 -75K001D	UTF-75K001D-Z01	PM INSP OF M/C NO. 75K001D -Z01	PMT	3M				I				I				I	RRC	RRC-MRCH	148852	B
638	UTF -75 -75K001D	UTF-75K001D-Z01	PM OF 75K001D -Z01	PMT	3M				P				P				P	RRC	RRC-MRCH	148853	B
639	UTF -75 -75K001E	UTF-75K001E-M	VB. INSP & ANALY M/C 75K001E	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	150221	B
640	UTF -75 -75K001E	UTF-75K001E-M	Regreasing Mot BRG of UTF-75K001E-M	PMT	4M				L				L				L	RRC	RRC-ERCH	249387	B
641	UTF -75 -75K001E	UTF-75K001E-Z01	PM INSP OF M/C NO. 75K001E -Z01	PMT	3M				I				I				I	RRC	RRC-MRCH	148854	B
642	UTF -75 -75K001E	UTF-75K001E-Z01	PM OF 75K001E -Z01	PMT	3M				P				P				P	RRC	RRC-MRCH	148855	B
643	UTF -75 -75K001F	UTF-75K001F-M	VB. INSP & ANALY M/C 75K001F	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	150222	B
644	UTF -75 -75K001F	UTF-75K001F-M	Regreasing Mot BRG of UTF-75K001F-M	PMT	4M				L				L				L	RRC	RRC-ERCH	249388	B
645	UTF -75 -75K001F	UTF-75K001F-Z01	PM INSP OF M/C NO. 75K001F -Z01	PMT	3M				I				I				I	RRC	RRC-MRCH	148856	B
646	UTF -75 -75K001F	UTF-75K001F-Z01	PM OF 75K001F -Z01	PMT	3M				P				P				P	RRC	RRC-MRCH	148857	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
647	UTF -75 -75P005A	UTF-75P005A-M	STAND BY CHECK MV. MOT 75P005A-M01	PMT	1Y								T					RRC	RRC-ERCH	139297	B
648	UTF -75 -75P005A	UTF-75P005A-M	Change BRG Lube Oil of Mot 75P005A-M01	PMT	1Y				L									RRC	RRC-ERCH	139430	B
649	UTF -75 -75P005A	UTF-75P005A-M	STAND BY CHECK MV. MOT 75P005A-M01	PMT	1Y				T									RRC	RRC-ERCH	154307	B
650	UTF -75 -75P005A	UTF-75P005A-P01	VB. INSP & ANALY M/C 75P005A	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130470	A
651	UTF -75 -75P005A	UTF-75P005A-P01	PM INSP OF M/C NO. 75P005A	PMT	4M		I				I			I				RRC	RRC-MRCH	129871	A
652	UTF -75 -75P005A	UTF-75P005A-P01	PM OF 75P005A	PMT	4M	P				P			P					RRC	RRC-MRCH	130848	A
653	UTF -75 -75P005B	UTF-75P005B-M	STAND BY CHECK MV. MOT 75P005B-M01	PMT	6M		T						T					RRC	RRC-ERCH	139298	B
654	UTF -75 -75P005B	UTF-75P005B-M	Change BRG Lube Oil of Mot 75P005B-M01	PMT	1Y				L									RRC	RRC-ERCH	139431	B
655	UTF -75 -75P005B	UTF-75P005B-P01	VB. INSP & ANALY M/C 75P005B	INT	4M	I				I			I					IRI	IRI-INVB	130471	A
656	UTF -75 -75P005B	UTF-75P005B-P01	VB. INSP & ANALY M/C 75P005B	INT	4M		I				I			I				IRI	IRI-INVB	131114	A
657	UTF -75 -75P005B	UTF-75P005B-P01	VB. INSP & ANALY M/C 75P005B	INT	4M			I				I				I		IRI	IRI-INVB	131340	A
658	UTF -75 -75P005B	UTF-75P005B-P01	PM INSP OF M/C NO. 75P005B	PMT	4M		I				I			I				RRC	RRC-MRCH	129872	A
659	UTF -75 -75P005B	UTF-75P005B-P01	PM OF 75P005B	PMT	4M				P				P				P	RRC	RRC-MRCH	130849	A
660	UTF -75 -75P005C	UTF-75P005C-M	STAND BY CHECK MV. MOT 75P005C-M01	PMT	6M			T						T				RRC	RRC-ERCH	139299	B
661	UTF -75 -75P005C	UTF-75P005C-M	Change BRG Lube Oil of Mot 75P005C-M01	PMT	1Y				L									RRC	RRC-ERCH	139432	B
662	UTF -75 -75P005C	UTF-75P005C-P01	VB. INSP & ANALY M/C 75P005C	INT	4M				I				I				I	IRI	IRI-INVB	130472	A
663	UTF -75 -75P005C	UTF-75P005C-P01	PM INSP OF M/C NO. 75P005C	PMT	4M				I				I				I	RRC	RRC-MRCH	129873	A
664	UTF -75 -75P005C	UTF-75P005C-P01	PM OF 75P005C	PMT	4M			P			P			P				RRC	RRC-MRCH	130850	A
665	UTF -75 -75X002	UTF-75X002-P01A	PM INSP OF M/C NO. 75X002 -P01A	PMT	4M	I				I			I					RRC	RRC-MRCH	129874	B
666	UTF -75 -75X002	UTF-75X002-P01A-M	STAND BY CHECK LV. MOT 75X002-P01A-M01	PMT	1Y								T					RRC	RRC-ERCH	139300	B
667	UTF -75 -75X002	UTF-75X002-P01B	PM INSP OF M/C NO. 75X002 -P01B	PMT	4M					I			I				I	RRC	RRC-MRCH	129875	B
668	UTF -75 -75X003	UTF-75X003-P01A	PM INSP OF M/C NO. 75X003 -P01A	PMT	4M	I				I			I					RRC	RRC-MRCH	129876	B
669	UTF -75 -75X003	UTF-75X003-P01A-M	STAND BY CHECK LV. MOT 75X003-P01A-M01	PMT	1Y								T					RRC	RRC-ERCH	139302	B
670	UTF -75 -75X003	UTF-75X003-P01B	PM INSP OF M/C NO. 75X003 -P01B	PMT	4M					I			I				I	RRC	RRC-MRCH	129877	B
671	UTF -75 -75X004	UTF-75X004-P01A	PM INSP OF M/C NO. 75X004 -P01A	PMT	4M	I				I			I					RRC	RRC-MRCH	129878	B
672	UTF -75 -75X004	UTF-75X004-P01A	PM OF 75X004 -P01A	PMT	4M				P				P				P	RRC	RRC-MRCH	130855	B
673	UTF -75 -75X004	UTF-75X004-P01A-M	STAND BY CHECK LV. MOT 75X004-P01A-M01	PMT	1Y								T					RRC	RRC-ERCH	139304	B
674	UTF -75 -75X004	UTF-75X004-P01A-M	STAND BY CHECK LV. MOT 75X004-P01A-M01	PMT	1Y				T									RRC	RRC-ERCH	154310	B
675	UTF -75 -75X004	UTF-75X004-P01B	PM INSP OF M/C NO. 75X004 -P01B	PMT	4M				I				I				I	RRC	RRC-MRCH	129879	B
676	UTF -75 -75X004	UTF-75X004-P01B	PM OF 75X004 -P01B	PMT	4M			P			P				P			RRC	RRC-MRCH	130856	B
677	UTF -75 -75X004	UTF-75X004-P01B-M	STAND BY CHECK LV. MOT 75X004-P01B-M01	PMT	6M			T					T					RRC	RRC-ERCH	139305	B
678	UTF -75 -75X005	UTF-75X005-P01A	PM INSP OF M/C NO. 75X005 -P01A	PMT	4M	I				I			I					RRC	RRC-MRCH	129880	B
679	UTF -75 -75X005	UTF-75X005-P01A	PM OF 75X005 -P01A	PMT	4M				P				P				P	RRC	RRC-MRCH	130857	B
680	UTF -75 -75X005	UTF-75X005-P01A-M	STAND BY CHECK LV. MOT 75X005-P01A-M01	PMT	1Y								T					RRC	RRC-ERCH	139306	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
681	UTF -75 -75X005	UTF-75X005-P01A-M	STAND BY CHECK LV. MOT 75X005-P01A-M01	PMT	1Y					T								RRC	RRC-ERCH	154311	B
682	UTF -75 -75X005	UTF-75X005-P01B	PM INSP OF M/C NO. 75X005 -P01B	PMT	4M					I			I				I	RRC	RRC-MRCH	129881	B
683	UTF -75 -75X005	UTF-75X005-P01B	PM OF 75X005 -P01B	PMT	4M	P				P			P					RRC	RRC-MRCH	130858	B
684	UTF -75 -75X005	UTF-75X005-P01B-M	STAND BY CHECK LV. MOT 75X005-P01B-M01	PMT	6M				T				T					RRC	RRC-ERCH	139307	B
685	UTF -75 -75X006	UTF-75X006-P01A	PM INSP OF M/C NO. 75X006 -P01A	PMT	4M	I				I			I					RRC	RRC-MRCH	129882	B
686	UTF -75 -75X006	UTF-75X006-P01B	PM INSP OF M/C NO. 75X006 -P01B	PMT	4M					I			I				I	RRC	RRC-MRCH	129883	B
687	UTF -75 -75X006	UTF-75X006-P01B	PM OF 75X006 -P01B	PMT	4M	P				P			P					RRC	RRC-MRCH	130860	B
688	UTF -77 -77A101	UTF-77A101-A01	Function test HE7750101	PMT	6M						F						F	RRC	RRC-IRCH	250248	C
689	UTF -77 -77A101	UTF-77A101-A01	Inspect HE7750101	PMT	6M					I				I				RRC	RRC-IRCH	250249	C
690	UTF -77 -77A101	UTF-77A101-A01	Inspect HE7750101	PMT	6M			I				I				I		RRC	RRC-IRCH	250250	C
691	UTF -77 -77A101	UTF-77A101-A01	Function test HE7750102	PMT	6M						F						F	RRC	RRC-IRCH	250251	C
692	UTF -77 -77A101	UTF-77A101-A01	Inspect HE7750102	PMT	6M					I				I				RRC	RRC-IRCH	250252	C
693	UTF -77 -77A101	UTF-77A101-A01	Inspect HE7750102	PMT	6M			I				I				I		RRC	RRC-IRCH	250253	C
694	UTF -77 -77A101	UTF-77A101-A01	Function test HE7750103	PMT	6M						F						F	RRC	RRC-IRCH	250254	C
695	UTF -77 -77A101	UTF-77A101-A01	Inspect HE7750103	PMT	6M					I				I				RRC	RRC-IRCH	250255	C
696	UTF -77 -77A101	UTF-77A101-A01	Inspect HE7750103	PMT	6M			I				I				I		RRC	RRC-IRCH	250256	C
697	UTF -77 -77A102	UTF-77A102-A01	Function test HE7750201	PMT	6M						F						F	RRC	RRC-IRCH	250266	C
698	UTF -77 -77A102	UTF-77A102-A01	Inspect HE7750201	PMT	6M					I				I				RRC	RRC-IRCH	250267	C
699	UTF -77 -77A102	UTF-77A102-A01	Inspect HE7750201	PMT	6M			I				I				I		RRC	RRC-IRCH	250268	C
700	UTF -77 -77A102	UTF-77A102-A01	Function test HE7750202	PMT	6M						F						F	RRC	RRC-IRCH	250269	C
701	UTF -77 -77A102	UTF-77A102-A01	Inspect HE7750202	PMT	6M					I				I				RRC	RRC-IRCH	250270	C
702	UTF -77 -77A102	UTF-77A102-A01	Inspect HE7750202	PMT	6M			I				I				I		RRC	RRC-IRCH	250271	C
703	UTF -77 -77A102	UTF-77A102-A01	Function test HE7750203	PMT	6M						F						F	RRC	RRC-IRCH	250272	C
704	UTF -77 -77A102	UTF-77A102-A01	Inspect HE7750203	PMT	6M					I				I				RRC	RRC-IRCH	250273	C
705	UTF -77 -77A102	UTF-77A102-A01	Inspect HE7750203	PMT	6M			I				I				I		RRC	RRC-IRCH	250274	C
706	UTF -77 -77A102	UTF-77A102-A01	Function test HE7750204	PMT	6M						F						F	RRC	RRC-IRCH	250275	C
707	UTF -77 -77A102	UTF-77A102-A01	Inspect HE7750204	PMT	6M					I				I				RRC	RRC-IRCH	250276	C
708	UTF -77 -77A102	UTF-77A102-A01	Inspect HE7750204	PMT	6M			I				I				I		RRC	RRC-IRCH	250277	C
709	UTF -77 -77A103	UTF-77A103-A01	Function test HE7750105	PMT	6M						F						F	RRC	RRC-IRCH	250257	C
710	UTF -77 -77A103	UTF-77A103-A01	Inspect HE7750105	PMT	6M					I				I				RRC	RRC-IRCH	250258	C
711	UTF -77 -77A103	UTF-77A103-A01	Inspect HE7750105	PMT	6M			I				I				I		RRC	RRC-IRCH	250259	C
712	UTF -77 -77A103	UTF-77A103-A01	Function test HE7750106	PMT	6M						F						F	RRC	RRC-IRCH	250260	C
713	UTF -77 -77A103	UTF-77A103-A01	Inspect HE7750106	PMT	6M					I				I				RRC	RRC-IRCH	250261	C
714	UTF -77 -77A103	UTF-77A103-A01	Inspect HE7750106	PMT	6M			I				I				I		RRC	RRC-IRCH	250262	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
715	UTF -77 -77A103	UTF-77A103-A01	Function test HE7750107	PMT	6M						F						F	RRC	RRC-IRCH	250263	C
716	UTF -77 -77A103	UTF-77A103-A01	Inspect HE7750107	PMT	6M				I						I			RRC	RRC-IRCH	250264	C
717	UTF -77 -77A103	UTF-77A103-A01	Inspect HE7750107	PMT	6M		I						I					RRC	RRC-IRCH	250265	C
718	UTF -77 -DVA7701	UTF-77DV001	TEST LINEAR HEAT DETECTOR UTF-77DV001	PMT	6M					P						P		RRC	RRC-ERCH	150125	B
719	UTF -77 -DVA7701	UTF-77DV002	TEST LINEAR HEAT DETECTOR UTF-77DV002	PMT	6M					P						P		RRC	RRC-ERCH	150126	B
720	UTF -77 -DVA7701	UTF-77DV003	TEST LINEAR HEAT DETECTOR UTF-77DV003	PMT	6M					P						P		RRC	RRC-ERCH	150127	B
721	UTF -77 -DVA7701	UTF-77DV004	TEST LINEAR HEAT DETECTOR UTF-77DV004	PMT	6M					P						P		RRC	RRC-ERCH	150128	B
722	UTF -77 -DVA7701	UTF-77DV005	TEST LINEAR HEAT DETECTOR UTF-77DV005	PMT	6M					P						P		RRC	RRC-ERCH	150129	B
723	UTF -77 -DVA7701	UTF-77DV006	TEST LINEAR HEAT DETECTOR UTF-77DV006	PMT	6M					P						P		RRC	RRC-ERCH	150130	B
724	UTF -77 -DVA7701	UTF-77DV007	TEST LINEAR HEAT DETECTOR UTF-77DV007	PMT	6M					P						P		RRC	RRC-ERCH	150131	B
725	UTF -77 -DVA7701	UTF-77DV008	TEST LINEAR HEAT DETECTOR UTF-77DV008	PMT	6M					P						P		RRC	RRC-ERCH	150132	B
726	UTF -77 -DVA7702	UTF-77DV009	TEST LINEAR HEAT DETECTOR UTF-77DV009	PMT	6M					P						P		RRC	RRC-ERCH	150133	B
727	UTF -77 -DVA7702	UTF-77DV010	TEST LINEAR HEAT DETECTOR UTF-77DV010	PMT	6M					P						P		RRC	RRC-ERCH	150134	B
728	UTF -77 -DVA7702	UTF-77DV011	TEST LINEAR HEAT DETECTOR UTF-77DV011	PMT	6M					P						P		RRC	RRC-ERCH	150135	B
729	UTF -77 -DVA7702	UTF-77DV012	TEST LINEAR HEAT DETECTOR UTF-77DV012	PMT	6M					P						P		RRC	RRC-ERCH	150136	B
730	UTF -77 -DVA7702	UTF-77DV013	TEST LINEAR HEAT DETECTOR UTF-77DV013	PMT	6M					P						P		RRC	RRC-ERCH	150137	B
731	UTF -77 -DVA7702	UTF-77DV014	TEST LINEAR HEAT DETECTOR UTF-77DV014	PMT	6M					P						P		RRC	RRC-ERCH	150138	B
732	UTF -77 -DVA7702	UTF-77DV015	TEST LINEAR HEAT DETECTOR UTF-77DV015	PMT	6M					P						P		RRC	RRC-ERCH	150139	B
733	UTF -77 -DVA7702	UTF-77DV016	TEST LINEAR HEAT DETECTOR UTF-77DV016	PMT	6M					P						P		RRC	RRC-ERCH	150140	B
734	UTF -77 -DVA7703	UTF-77DV017	TEST LINEAR HEAT DETECTOR UTF-77DV017	PMT	6M					P						P		RRC	RRC-ERCH	150141	B
735	UTF -77 -DVA7703	UTF-77DV018	TEST LINEAR HEAT DETECTOR UTF-77DV018	PMT	6M					P						P		RRC	RRC-ERCH	150142	B
736	UTF -77 -DVA7703	UTF-77DV019	TEST LINEAR HEAT DETECTOR UTF-77DV019	PMT	6M					P						P		RRC	RRC-ERCH	150143	B
737	UTF -77 -DVA7703	UTF-77DV020	TEST LINEAR HEAT DETECTOR UTF-77DV020	PMT	6M					P						P		RRC	RRC-ERCH	150144	B
738	UTF -77 -DVA7703	UTF-77DV021	TEST LINEAR HEAT DETECTOR UTF-77DV021	PMT	6M					P						P		RRC	RRC-ERCH	150145	B
739	UTF -77 -DVA7703	UTF-77DV022	TEST LINEAR HEAT DETECTOR UTF-77DV022	PMT	6M					P						P		RRC	RRC-ERCH	150146	B
740	UTF -77 -DVA7703	UTF-77DV023	TEST LINEAR HEAT DETECTOR UTF-77DV023	PMT	6M					P						P		RRC	RRC-ERCH	150147	B
741	UTF -77 -DVA7703	UTF-77DV024	TEST LINEAR HEAT DETECTOR UTF-77DV024	PMT	6M					P						P		RRC	RRC-ERCH	150148	B
742	UTF -77 -DVA7704	UTF-77DV025	TEST LINEAR HEAT DETECTOR UTF-77DV025	PMT	6M					P						P		RRC	RRC-ERCH	150149	B
743	UTF -77 -DVA7704	UTF-77DV026	TEST LINEAR HEAT DETECTOR UTF-77DV026	PMT	6M					P						P		RRC	RRC-ERCH	150150	B
744	UTF -77 -DVA7704	UTF-77DV027	TEST LINEAR HEAT DETECTOR UTF-77DV027	PMT	6M					P						P		RRC	RRC-ERCH	150151	B
745	UTF -77 -DVA7704	UTF-77DV028	TEST LINEAR HEAT DETECTOR UTF-77DV028	PMT	6M					P						P		RRC	RRC-ERCH	150152	B
746	UTF -77 -DVA7705	UTF-77DV029	TEST LINEAR HEAT DETECTOR UTF-77DV029	PMT	6M					P						P		RRC	RRC-ERCH	150153	B
747	UTF -77 -DVA7705	UTF-77DV030	TEST LINEAR HEAT DETECTOR UTF-77DV030	PMT	6M					P						P		RRC	RRC-ERCH	150154	B
748	UTF -77 -DVA7705	UTF-77DV031	TEST LINEAR HEAT DETECTOR UTF-77DV031	PMT	6M					P						P		RRC	RRC-ERCH	150155	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
749	UTF -77 -DVA7705	UTF-77DV032	TEST LINEAR HEAT DETECTOR UTF-77DV032	PMT	6M					P						P		RRC	RRC-ERCH	150156	B
750	UTF -77 -DVA7705	UTF-77DV033	TEST LINEAR HEAT DETECTOR UTF-77DV033	PMT	6M					P						P		RRC	RRC-ERCH	150157	B
751	UTF -77 -DVA7705	UTF-77DV034	TEST LINEAR HEAT DETECTOR UTF-77DV034	PMT	6M					P						P		RRC	RRC-ERCH	150158	B
752	UTF -77 -DVA7705	UTF-77DV035	TEST LINEAR HEAT DETECTOR UTF-77DV035	PMT	6M					P						P		RRC	RRC-ERCH	150159	B
753	UTF -77 -DVA7705	UTF-77DV036	TEST LINEAR HEAT DETECTOR UTF-77DV036	PMT	6M					P						P		RRC	RRC-ERCH	150160	B
754	UTF -77 -DVA7706	UTF-77DV037	TEST LINEAR HEAT DETECTOR UTF-77DV037	PMT	6M					P						P		RRC	RRC-ERCH	150161	B
755	UTF -77 -DVA7706	UTF-77DV038	TEST LINEAR HEAT DETECTOR UTF-77DV038	PMT	6M					P						P		RRC	RRC-ERCH	150162	B
756	UTF -77 -DVA7706	UTF-77DV039	TEST LINEAR HEAT DETECTOR UTF-77DV039	PMT	6M					P						P		RRC	RRC-ERCH	150163	B
757	UTF -77 -DVA7706	UTF-77DV040	TEST LINEAR HEAT DETECTOR UTF-77DV040	PMT	6M					P						P		RRC	RRC-ERCH	150164	B
758	UTF -77 -DVA7706	UTF-77DV041	TEST LINEAR HEAT DETECTOR UTF-77DV041	PMT	6M					P						P		RRC	RRC-ERCH	150165	B
759	UTF -77 -DVA7706	UTF-77DV042	TEST LINEAR HEAT DETECTOR UTF-77DV042	PMT	6M					P						P		RRC	RRC-ERCH	150166	
760	UTF -77 -DVA7706	UTF-77DV043	TEST LINEAR HEAT DETECTOR UTF-77DV043	PMT	6M					P						P		RRC	RRC-ERCH	150167	
761	UTF -77 -DVA7706	UTF-77DV044	TEST LINEAR HEAT DETECTOR UTF-77DV044	PMT	6M					P						P		RRC	RRC-ERCH	150168	B
762	UTF -77 -DVA7706	UTF-77DV045	TEST LINEAR HEAT DETECTOR UTF-77DV045	PMT	6M					P						P		RRC	RRC-ERCH	150169	B
763	UTF -77 -DVA7706	UTF-77DV046	TEST LINEAR HEAT DETECTOR UTF-77DV046	PMT	6M					P						P		RRC	RRC-ERCH	150170	B
764	UTF -77 -DVA7706	UTF-77DV047	TEST LINEAR HEAT DETECTOR UTF-77DV047	PMT	6M					P						P		RRC	RRC-ERCH	150171	B
765	UTF -77 -DVA7706	UTF-77DV048	TEST LINEAR HEAT DETECTOR UTF-77DV048	PMT	6M					P						P		RRC	RRC-ERCH	150172	B
766	UTF -77 -DVA7707	UTF-77DV049	TEST LINEAR HEAT DETECTOR UTF-77DV049	PMT	6M					P						P		RRC	RRC-ERCH	150173	B
767	UTF -77 -DVA7707	UTF-77DV050	TEST LINEAR HEAT DETECTOR UTF-77DV050	PMT	6M					P						P		RRC	RRC-ERCH	150174	B
768	UTF -77 -DVA7707	UTF-77DV051	TEST LINEAR HEAT DETECTOR UTF-77DV051	PMT	6M					P						P		RRC	RRC-ERCH	150175	B
769	UTF -77 -DVA7707	UTF-77DV052	TEST LINEAR HEAT DETECTOR UTF-77DV052	PMT	6M					P						P		RRC	RRC-ERCH	150176	B
770	UTF -77 -DVA7707	UTF-77DV053	TEST LINEAR HEAT DETECTOR UTF-77DV053	PMT	6M					P						P		RRC	RRC-ERCH	150177	B
771	UTF -77 -DVA7707	UTF-77DV054	TEST LINEAR HEAT DETECTOR UTF-77DV054	PMT	6M					P						P		RRC	RRC-ERCH	150178	B
772	UTF -77 -DVA7707	UTF-77DV055	TEST LINEAR HEAT DETECTOR UTF-77DV055	PMT	6M					P						P		RRC	RRC-ERCH	150179	B
773	UTF -77 -DVA7707	UTF-77DV056	TEST LINEAR HEAT DETECTOR UTF-77DV056	PMT	6M					P						P		RRC	RRC-ERCH	150180	B
774	UTF -77 -DVA7707	UTF-77DV057	TEST LINEAR HEAT DETECTOR UTF-77DV057	PMT	6M					P						P		RRC	RRC-ERCH	150181	B
775	UTF -77 -DVA7707	UTF-77DV058	TEST LINEAR HEAT DETECTOR UTF-77DV058	PMT	6M					P						P		RRC	RRC-ERCH	150182	B
776	UTF -77 -DVA7707	UTF-77DV059	TEST LINEAR HEAT DETECTOR UTF-77DV059	PMT	6M					P						P		RRC	RRC-ERCH	150183	B
777	UTF -77 -DVA7707	UTF-77DV060	TEST LINEAR HEAT DETECTOR UTF-77DV060	PMT	6M					P						P		RRC	RRC-ERCH	150184	B
778	UTF -77 -DVA7708	UTF-77DV061	TEST LINEAR HEAT DETECTOR UTF-77DV061	PMT	6M					P						P		RRC	RRC-ERCH	150185	B
779	UTF -77 -DVA7708	UTF-77DV062	TEST LINEAR HEAT DETECTOR UTF-77DV062	PMT	6M					P						P		RRC	RRC-ERCH	150186	B
780	UTF -77 -DVA7708	UTF-77DV063	TEST LINEAR HEAT DETECTOR UTF-77DV063	PMT	6M					P						P		RRC	RRC-ERCH	150187	B
781	UTF -77 -DVA7709	UTF-77DV064	TEST LINEAR HEAT DETECTOR UTF-77DV064	PMT	6M					P						P		RRC	RRC-ERCH	150188	B
782	UTF -77 -DVA7709	UTF-77DV065	TEST LINEAR HEAT DETECTOR UTF-77DV065	PMT	6M					P						P		RRC	RRC-ERCH	150189	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
783	UTF -77 -DVA7709	UTF-77DV066	TEST LINEAR HEAT DETECTOR UTF-77DV066	PMT	6M					P						P		RRC	RRC-ERCH	150190	B
784	UTF -77 -DVA7710	UTF-77DV067	TEST LINEAR HEAT DETECTOR UTF-77DV067	PMT	6M					P						P		RRC	RRC-ERCH	150191	B
785	UTF -77 -DVA7710	UTF-77DV068	TEST LINEAR HEAT DETECTOR UTF-77DV068	PMT	6M					P						P		RRC	RRC-ERCH	150192	B
786	UTF -77 -DVA7710	UTF-77DV069	TEST LINEAR HEAT DETECTOR UTF-77DV069	PMT	6M					P						P		RRC	RRC-ERCH	150193	B
787	UTF -77 -DVA7710	UTF-77DV070	TEST LINEAR HEAT DETECTOR UTF-77DV070	PMT	6M					P						P		RRC	RRC-ERCH	150194	B
788	UTF -77 -DVA7711	UTF-77DV071	TEST LINEAR HEAT DETECTOR UTF-77DV071	PMT	6M					P						P		RRC	RRC-ERCH	150195	B
789	UTF -77 -DVA7712	UTF-77DV072	TEST LINEAR HEAT DETECTOR UTF-77DV072	PMT	6M					P						P		RRC	RRC-ERCH	150196	B
790	UTF -77 -77P002A	UTF-77P002A-M	STAND BY CHECK LV. MOT 77P002A-M01	PMT	1Y								T					RRC	RRC-ERCH	139310	B
791	UTF -77 -77P002A	UTF-77P002A-M	Regreasing Mot BRG of 77P002A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139755	B
792	UTF -77 -77P002A	UTF-77P002A-M	STAND BY CHECK LV. MOT 77P002A-M01	PMT	1Y				T									RRC	RRC-ERCH	154312	B
793	UTF -77 -77P002A	UTF-77P002A-P01	VB. INSP & ANALY M/C 77P002A	INT	4M	I				I				I				IRI	IRI-INVB	130483	B
794	UTF -77 -77P002A	UTF-77P002A-P01	VB. INSP & ANALY M/C 77P002A	INT	4M		I				I				I			IRI	IRI-INVB	131120	B
795	UTF -77 -77P002A	UTF-77P002A-P01	VB. INSP & ANALY M/C 77P002A	INT	4M			I				I				I		IRI	IRI-INVB	131346	B
796	UTF -77 -77P002A	UTF-77P002A-P01	PM INSP OF M/C NO. 77P002A	PMT	4M		I				I			I				IRI	IRI-INVB	129884	B
797	UTF -77 -77P002A	UTF-77P002A-P01	PM OF 77P002A	PMT	4M				P				P			P		RRC	RRC-MRCH	130861	B
798	UTF -77 -77P002B	UTF-77P002B-M	STAND BY CHECK LV. MOT 77P002B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139311	B
799	UTF -77 -77P002B	UTF-77P002B-M	Regreasing Mot BRG of 77P002B-M01	PMT	4M				L				L			L		RRC	RRC-ERCH	139756	B
800	UTF -77 -77P002B	UTF-77P002B-P01	VB. INSP & ANALY M/C 77P002B	INT	4M				I				I			I		IRI	IRI-INVB	130484	B
801	UTF -77 -77P002B	UTF-77P002B-P01	PM INSP OF M/C NO. 77P002B	PMT	4M				I				I			I		RRC	RRC-MRCH	129885	B
802	UTF -77 -77P002B	UTF-77P002B-P01	PM OF 77P002B	PMT	4M	P				P				P				RRC	RRC-MRCH	130862	B
803	UTF -77 -77P003A	UTF-77P003A-M	STAND BY CHECK LV. MOT 77P003A-M01	PMT	1Y								T					RRC	RRC-ERCH	139312	B
804	UTF -77 -77P003A	UTF-77P003A-M	Regreasing Mot BRG of 77P003A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139757	B
805	UTF -77 -77P003A	UTF-77P003A-M	STAND BY CHECK LV. MOT 77P003A-M01	PMT	1Y				T									RRC	RRC-ERCH	154313	B
806	UTF -77 -77P003A	UTF-77P003A-P01	VB. INSP & ANALY M/C 77P003A	INT	4M	I				I				I				IRI	IRI-INVB	130485	B
807	UTF -77 -77P003A	UTF-77P003A-P01	VB. INSP & ANALY M/C 77P003A	INT	4M		I				I				I			IRI	IRI-INVB	131121	B
808	UTF -77 -77P003A	UTF-77P003A-P01	VB. INSP & ANALY M/C 77P003A	INT	4M			I				I				I		IRI	IRI-INVB	131347	B
809	UTF -77 -77P003A	UTF-77P003A-P01	PM INSP OF M/C NO. 77P003A	PMT	4M		I				I			I				RRC	RRC-MRCH	129886	B
810	UTF -77 -77P003A	UTF-77P003A-P01	PM OF 77P003A	PMT	4M				P				P			P		RRC	RRC-MRCH	130863	B
811	UTF -77 -77P003B	UTF-77P003B-M	STAND BY CHECK LV. MOT 77P003B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139313	B
812	UTF -77 -77P003B	UTF-77P003B-M	Regreasing Mot BRG of 77P003B-M01	PMT	4M				L				L			L		RRC	RRC-ERCH	139758	B
813	UTF -77 -77P003B	UTF-77P003B-P01	VB. INSP & ANALY M/C 77P003B	INT	4M				I				I			I		IRI	IRI-INVB	130486	B
814	UTF -77 -77P003B	UTF-77P003B-P01	PM INSP OF M/C NO. 77P003B	PMT	4M				I				I			I		RRC	RRC-MRCH	129887	B
815	UTF -77 -77P003B	UTF-77P003B-P01	PM OF 77P003B	PMT	4M	P				P				P				RRC	RRC-MRCH	130864	B
816	UTF -77 -77P005A	UTF-77P005A-M	STAND BY CHECK LV. MOT 77P005A-M01	PMT	1Y								T					RRC	RRC-ERCH	139314	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
817	UTF -77 -77P005A	UTF-77P005A-M	Regreasing Mot BRG of 77P005A-M01	PMT	4M	L				L			L					RRC	RRC-ERCH	139759	B
818	UTF -77 -77P005A	UTF-77P005A-M	STAND BY CHECK LV. MOT 77P005A-M01	PMT	1Y				T									RRC	RRC-ERCH	154314	B
819	UTF -77 -77P005A	UTF-77P005A-P01	VB. INSP & ANALY M/C 77P005A	INT	4M	I				I			I					IRI	IRI-INVB	130487	B
820	UTF -77 -77P005A	UTF-77P005A-P01	VB. INSP & ANALY M/C 77P005A	INT	4M		I				I			I				IRI	IRI-INVB	131122	B
821	UTF -77 -77P005A	UTF-77P005A-P01	VB. INSP & ANALY M/C 77P005A	INT	4M			I				I			I			IRI	IRI-INVB	131348	B
822	UTF -77 -77P005A	UTF-77P005A-P01	PM INSP OF M/C NO. 77P005A	PMT	4M		I				I			I				RRC	RRC-MRCH	129888	B
823	UTF -77 -77P005A	UTF-77P005A-P01	PM OF 77P005A	PMT	4M				P				P			P		RRC	RRC-MRCH	130865	B
824	UTF -77 -77P005B	UTF-77P005B-M	STAND BY CHECK LV. MOT 77P005B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139315	B
825	UTF -77 -77P005B	UTF-77P005B-M	Regreasing Mot BRG of 77P005B-M01	PMT	4M				L				L			L		RRC	RRC-ERCH	139760	B
826	UTF -77 -77P005B	UTF-77P005B-P01	VB. INSP & ANALY M/C 77P005B	INT	4M				I				I			I		IRI	IRI-INVB	130488	B
827	UTF -77 -77P005B	UTF-77P005B-P01	PM INSP OF M/C NO. 77P005B	PMT	4M				I				I			I		RRC	RRC-MRCH	129889	B
828	UTF -77 -77P005B	UTF-77P005B-P01	PM OF 77P005B	PMT	4M	P				P				P				RRC	RRC-MRCH	130866	B
829	UTF -77 -77P007A	UTF-77P007A-M	STAND BY CHECK MV. MOT 77P007A-M01	PMT	1Y								T					RRC	RRC-ERCH	139316	B
830	UTF -77 -77P007A	UTF-77P007A-M	Regreasing Mot BRG of 77P007A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139433	B
831	UTF -77 -77P007A	UTF-77P007A-M	STAND BY CHECK MV. MOT 77P007A-M01	PMT	1Y				T									RRC	RRC-ERCH	154315	B
832	UTF -77 -77P007A	UTF-77P007A-P01	VB. INSP & ANALY M/C 77P007A	INT	4M	I				I			I					IRI	IRI-INVB	130489	B
833	UTF -77 -77P007A	UTF-77P007A-P01	VB. INSP & ANALY M/C 77P007A	INT	4M		I				I			I				IRI	IRI-INVB	131123	B
834	UTF -77 -77P007A	UTF-77P007A-P01	VB. INSP & ANALY M/C 77P007A	INT	4M			I				I			I			IRI	IRI-INVB	131349	B
835	UTF -77 -77P007A	UTF-77P007A-P01	PM INSP OF M/C NO. 77P007A	PMT	4M		I				I			I				RRC	RRC-MRCH	129890	B
836	UTF -77 -77P007A	UTF-77P007A-P01	PM OF 77P007A	PMT	4M			P				P			P			RRC	RRC-MRCH	130867	B
837	UTF -77 -77P007B	UTF-77P007B-M	STAND BY CHECK MV. MOT 77P007B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139317	B
838	UTF -77 -77P007B	UTF-77P007B-M	Regreasing Mot BRG of 77P007B-M01	PMT	4M				L				L			L		RRC	RRC-ERCH	139434	B
839	UTF -77 -77P007B	UTF-77P007B-P01	VB. INSP & ANALY M/C 77P007B	INT	4M				I				I			I		IRI	IRI-INVB	130490	B
840	UTF -77 -77P007B	UTF-77P007B-P01	PM INSP OF M/C NO. 77P007B	PMT	4M				I				I			I		RRC	RRC-MRCH	129891	B
841	UTF -77 -77P007B	UTF-77P007B-P01	PM OF 77P007B	PMT	4M		P				P			P				RRC	RRC-MRCH	130868	B
842	UTF -77 -77P008A	UTF-77P008A-M	STAND BY CHECK LV. MOT 77P008A-M01	PMT	1Y								T					RRC	RRC-ERCH	139318	B
843	UTF -77 -77P008A	UTF-77P008A-M	Regreasing Mot BRG of 77P008A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139761	B
844	UTF -77 -77P008A	UTF-77P008A-M	STAND BY CHECK LV. MOT 77P008A-M01	PMT	1Y				T									RRC	RRC-ERCH	154316	B
845	UTF -77 -77P008A	UTF-77P008A-P01	VB. INSP & ANALY M/C 77P008A	INT	4M	I				I			I					IRI	IRI-INVB	130491	B
846	UTF -77 -77P008A	UTF-77P008A-P01	VB. INSP & ANALY M/C 77P008A	INT	4M		I				I			I				IRI	IRI-INVB	131124	B
847	UTF -77 -77P008A	UTF-77P008A-P01	VB. INSP & ANALY M/C 77P008A	INT	4M			I				I			I			IRI	IRI-INVB	131350	B
848	UTF -77 -77P008A	UTF-77P008A-P01	PM INSP OF M/C NO. 77P008A	PMT	4M		I				I			I				RRC	RRC-MRCH	129892	B
849	UTF -77 -77P008A	UTF-77P008A-P01	PM OF 77P008A	PMT	4M				P				P			P		RRC	RRC-MRCH	130869	B
850	UTF -77 -77P008B	UTF-77P008B-M	STAND BY CHECK LV. MOT 77P008B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139319	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
851	UTF -77 -77P008B	UTF-77P008B-M	Regreasing Mot BRG of 77P008B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139762	B
852	UTF -77 -77P008B	UTF-77P008B-P01	VB. INSP & ANALY M/C 77P008B	INT	4M				I				I				I	IRI	IRI-INVB	130492	B
853	UTF -77 -77P008B	UTF-77P008B-P01	PM INSP OF M/C NO. 77P008B	PMT	4M				I				I				I	RRC	RRC-MRCH	129893	B
854	UTF -77 -77P008B	UTF-77P008B-P01	PM OF 77P008B	PMT	4M		P				P			P				RRC	RRC-MRCH	130870	B
855	UTF -77 -77P009A	UTF-77P009A-M	STAND BY CHECK MV. MOT 77P009A-M01	PMT	1Y								T					RRC	RRC-ERCH	139320	B
856	UTF -77 -77P009A	UTF-77P009A-M	Regreasing Mot BRG of 77P009A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139435	B
857	UTF -77 -77P009A	UTF-77P009A-M	STAND BY CHECK MV. MOT 77P009A-M01	PMT	1Y				T									RRC	RRC-ERCH	154317	B
858	UTF -77 -77P009A	UTF-77P009A-P01	VB. INSP & ANALY M/C 77P009A	INT	4M	I				I				I				IRI	IRI-INVB	130493	B
859	UTF -77 -77P009A	UTF-77P009A-P01	VB. INSP & ANALY M/C 77P009A	INT	4M		I				I				I			IRI	IRI-INVB	131125	B
860	UTF -77 -77P009A	UTF-77P009A-P01	VB. INSP & ANALY M/C 77P009A	INT	4M			I				I				I		IRI	IRI-INVB	131351	B
861	UTF -77 -77P009A	UTF-77P009A-P01	PM INSP OF M/C NO. 77P009A	PMT	4M		I				I				I			RRC	RRC-MRCH	129894	B
862	UTF -77 -77P009A	UTF-77P009A-P01	PM OF 77P009A	PMT	4M				P			P					P	RRC	RRC-MRCH	130871	B
863	UTF -77 -77P009B	UTF-77P009B-M	STAND BY CHECK MV. MOT 77P009B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139321	B
864	UTF -77 -77P009B	UTF-77P009B-M	Regreasing Mot BRG of 77P009B-M01	PMT	4M				L			L					L	RRC	RRC-ERCH	139436	B
865	UTF -77 -77P009B	UTF-77P009B-P01	VB. INSP & ANALY M/C 77P009B	INT	4M				I			I					I	IRI	IRI-INVB	130494	B
866	UTF -77 -77P009B	UTF-77P009B-P01	PM INSP OF M/C NO. 77P009B	PMT	4M				I			I					I	RRC	RRC-MRCH	129895	B
867	UTF -77 -77P009B	UTF-77P009B-P01	PM OF 77P009B	PMT	4M		P				P			P				RRC	RRC-MRCH	130872	B
868	UTF -77 -77P010A	UTF-77P010A-M	STAND BY CHECK LV. MOT 77P010A-M01	PMT	1Y								T					RRC	RRC-ERCH	139322	B
869	UTF -77 -77P010A	UTF-77P010A-M	Regreasing Mot BRG of 77P010A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139763	B
870	UTF -77 -77P010A	UTF-77P010A-M	STAND BY CHECK LV. MOT 77P010A-M01	PMT	1Y				T									RRC	RRC-ERCH	154318	B
871	UTF -77 -77P010A	UTF-77P010A-P01	VB. INSP & ANALY M/C 77P010A	INT	4M	I				I				I				IRI	IRI-INVB	130495	B
872	UTF -77 -77P010A	UTF-77P010A-P01	VB. INSP & ANALY M/C 77P010A	INT	4M		I				I				I			IRI	IRI-INVB	131126	B
873	UTF -77 -77P010A	UTF-77P010A-P01	VB. INSP & ANALY M/C 77P010A	INT	4M			I				I				I		IRI	IRI-INVB	131352	B
874	UTF -77 -77P010A	UTF-77P010A-P01	PM INSP OF M/C NO. 77P010A	PMT	4M			I				I				I		RRC	RRC-MRCH	129896	B
875	UTF -77 -77P010A	UTF-77P010A-P01	PM OF 77P010A	PMT	4M			P				P				P		RRC	RRC-MRCH	130873	B
876	UTF -77 -77P010B	UTF-77P010B-M	STAND BY CHECK LV. MOT 77P010B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139323	B
877	UTF -77 -77P010B	UTF-77P010B-M	Regreasing Mot BRG of 77P010B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139764	B
878	UTF -77 -77P010B	UTF-77P010B-P01	VB. INSP & ANALY M/C 77P010B	INT	4M				I				I				I	IRI	IRI-INVB	130496	B
879	UTF -77 -77P010B	UTF-77P010B-P01	PM INSP OF M/C NO. 77P010B	PMT	4M				I				I				I	RRC	RRC-MRCH	129897	B
880	UTF -77 -77P010B	UTF-77P010B-P01	PM OF 77P010B	PMT	4M		P				P			P				RRC	RRC-MRCH	130874	B
881	UTF -77 -77P011	UTF-77P011-M	STAND BY CHECK LV. MOT 77P011-M01	PMT	6M			T						T				RRC	RRC-ERCH	139324	B
882	UTF -77 -77P011	UTF-77P011-P01	VB. INSP & ANALY M/C 77P011	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130497	B
883	UTF -77 -77P011	UTF-77P011-P01	PM INSP OF M/C NO. 77P011	PMT	4M	I				I				I				RRC	RRC-MRCH	129898	B
884	UTF -77 -77P011	UTF-77P011-P01	PM OF 77P011	PMT	4M	P				P				P				RRC	RRC-MRCH	130875	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
885	UTF -77 -77P012A	UTF-77P012A-M	STAND BY CHECK LV. MOT 77P012A-M01	PMT	1Y								T					RRC	RRC-ERCH	139325	B
886	UTF -77 -77P012A	UTF-77P012A-M	Regreasing Mot BRG of 77P012A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139765	B
887	UTF -77 -77P012A	UTF-77P012A-M	STAND BY CHECK LV. MOT 77P012A-M01	PMT	1Y					T								RRC	RRC-ERCH	154319	B
888	UTF -77 -77P012A	UTF-77P012A-P01	VB. INSP & ANALY M/C 77P012A	INT	4M	I					I			I				IRI	IRI-INVB	130498	B
889	UTF -77 -77P012A	UTF-77P012A-P01	VB. INSP & ANALY M/C 77P012A	INT	4M		I					I			I			IRI	IRI-INVB	131127	B
890	UTF -77 -77P012A	UTF-77P012A-P01	VB. INSP & ANALY M/C 77P012A	INT	4M			I					I			I		IRI	IRI-INVB	131353	B
891	UTF -77 -77P012A	UTF-77P012A-P01	PM INSP OF M/C NO. 77P012A	PMT	4M		I				I				I			RRC	RRC-MRCH	129899	B
892	UTF -77 -77P012A	UTF-77P012A-P01	PM OF 77P012A	PMT	4M				P				P				P	RRC	RRC-MRCH	130876	B
893	UTF -77 -77P012B	UTF-77P012B-M	STAND BY CHECK LV. MOT 77P012B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139326	B
894	UTF -77 -77P012B	UTF-77P012B-M	Regreasing Mot BRG of 77P012B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139766	B
895	UTF -77 -77P012B	UTF-77P012B-P01	VB. INSP & ANALY M/C 77P012B	INT	4M				I				I				I	IRI	IRI-INVB	130499	B
896	UTF -77 -77P012B	UTF-77P012B-P01	PM INSP OF M/C NO. 77P012B	PMT	4M				I				I				I	RRC	RRC-MRCH	129900	B
897	UTF -77 -77P012B	UTF-77P012B-P01	PM OF 77P012B	PMT	4M		P				P			P				RRC	RRC-MRCH	130877	B
898	UTF -77 -77P013A	UTF-77P013A-M	STAND BY CHECK LV. MOT 77P013A-M01	PMT	1Y								T					RRC	RRC-ERCH	139327	B
899	UTF -77 -77P013A	UTF-77P013A-M	Regreasing Mot BRG of 77P013A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139767	B
900	UTF -77 -77P013A	UTF-77P013A-M	STAND BY CHECK LV. MOT 77P013A-M01	PMT	1Y					T								RRC	RRC-ERCH	154320	B
901	UTF -77 -77P013A	UTF-77P013A-P01	VB. INSP & ANALY M/C 77P013A	INT	4M	I					I			I				IRI	IRI-INVB	130500	B
902	UTF -77 -77P013A	UTF-77P013A-P01	VB. INSP & ANALY M/C 77P013A	INT	4M		I					I			I			IRI	IRI-INVB	131128	B
903	UTF -77 -77P013A	UTF-77P013A-P01	VB. INSP & ANALY M/C 77P013A	INT	4M			I					I			I		IRI	IRI-INVB	131354	B
904	UTF -77 -77P013A	UTF-77P013A-P01	PM INSP OF M/C NO. 77P013A	PMT	4M		I				I				I			RRC	RRC-MRCH	129901	B
905	UTF -77 -77P013A	UTF-77P013A-P01	PM OF 77P013A	PMT	4M				P				P				P	RRC	RRC-MRCH	130878	B
906	UTF -77 -77P013B	UTF-77P013B-M	STAND BY CHECK LV. MOT 77P013B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139328	B
907	UTF -77 -77P013B	UTF-77P013B-M	Regreasing Mot BRG of 77P013B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139768	B
908	UTF -77 -77P013B	UTF-77P013B-P01	VB. INSP & ANALY M/C 77P013B	INT	4M				I				I				I	IRI	IRI-INVB	130501	B
909	UTF -77 -77P013B	UTF-77P013B-P01	PM INSP OF M/C NO. 77P013B	PMT	4M				I				I				I	RRC	RRC-MRCH	129902	B
910	UTF -77 -77P013B	UTF-77P013B-P01	PM OF 77P013B	PMT	4M		P				P			P				RRC	RRC-MRCH	130879	B
911	UTF -77 -77P015A	UTF-77P015A-M	STAND BY CHECK LV. MOT 77P015A-M01	PMT	1Y								T					RRC	RRC-ERCH	139329	B
912	UTF -77 -77P015A	UTF-77P015A-M	STAND BY CHECK LV. MOT 77P015A-M01	PMT	1Y					T								RRC	RRC-ERCH	154321	B
913	UTF -77 -77P015A	UTF-77P015A-P01	VB. INSP & ANALY M/C 77P015A	INT	4M	I					I			I				IRI	IRI-INVB	130502	B
914	UTF -77 -77P015A	UTF-77P015A-P01	VB. INSP & ANALY M/C 77P015A	INT	4M		I					I			I			IRI	IRI-INVB	131129	B
915	UTF -77 -77P015A	UTF-77P015A-P01	VB. INSP & ANALY M/C 77P015A	INT	4M			I					I			I		IRI	IRI-INVB	131355	B
916	UTF -77 -77P015A	UTF-77P015A-P01	PM INSP OF M/C NO. 77P015A	PMT	4M		I				I				I			RRC	RRC-MRCH	129903	B
917	UTF -77 -77P015A	UTF-77P015A-P01	PM OF 77P015A	PMT	4M				P				P				P	RRC	RRC-MRCH	130880	B
918	UTF -77 -77P015B	UTF-77P015B-M	STAND BY CHECK LV. MOT 77P015B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139330	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
919	UTF -77 -77P015B	UTF-77P015B-M	Regreasing Mot BRG of 77P015B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139770	B
920	UTF -77 -77P015B	UTF-77P015B-P01	VB. INSP & ANALY M/C 77P015B	INT	4M				I				I				I	IRI	IRI-INVB	130503	B
921	UTF -77 -77P015B	UTF-77P015B-P01	PM INSP OF M/C NO. 77P015B	PMT	4M				I				I				I	RRC	RRC-MRCH	129904	B
922	UTF -77 -77P015B	UTF-77P015B-P01	PM OF 77P015B	PMT	4M			P				P				P		RRC	RRC-MRCH	130881	B
923	UTF -77 -77P016A	UTF-77P016A-M	STAND BY CHECK LV. MOT 77P016A-M01	PMT	1Y								T					RRC	RRC-ERCH	139331	B
924	UTF -77 -77P016A	UTF-77P016A-M	Regreasing Mot BRG of 77P016A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139771	B
925	UTF -77 -77P016A	UTF-77P016A-M	STAND BY CHECK LV. MOT 77P016A-M01	PMT	1Y				T									RRC	RRC-ERCH	154322	B
926	UTF -77 -77P016A	UTF-77P016A-P01	VB. INSP & ANALY M/C 77P016A	INT	4M	I				I				I				IRI	IRI-INVB	130504	B
927	UTF -77 -77P016A	UTF-77P016A-P01	VB. INSP & ANALY M/C 77P016A	INT	4M		I				I				I			IRI	IRI-INVB	131130	B
928	UTF -77 -77P016A	UTF-77P016A-P01	VB. INSP & ANALY M/C 77P016A	INT	4M			I				I				I		IRI	IRI-INVB	131356	B
929	UTF -77 -77P016A	UTF-77P016A-P01	PM INSP OF M/C NO. 77P016A	PMT	4M		I				I				I			RRC	RRC-MRCH	129905	B
930	UTF -77 -77P016A	UTF-77P016A-P01	PM OF 77P016A	PMT	4M				P			P					P	RRC	RRC-MRCH	130882	B
931	UTF -77 -77P016B	UTF-77P016B-M	STAND BY CHECK LV. MOT 77P016B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139332	B
932	UTF -77 -77P016B	UTF-77P016B-M	Regreasing Mot BRG of 77P016B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139772	B
933	UTF -77 -77P016B	UTF-77P016B-P01	VB. INSP & ANALY M/C 77P016B	INT	4M				I				I				I	IRI	IRI-INVB	130505	B
934	UTF -77 -77P016B	UTF-77P016B-P01	PM INSP OF M/C NO. 77P016B	PMT	4M				I				I				I	RRC	RRC-MRCH	129906	B
935	UTF -77 -77P016B	UTF-77P016B-P01	PM OF 77P016B	PMT	4M			P				P				P		RRC	RRC-MRCH	130883	B
936	UTF -77 -77P017A	UTF-77P017A-M	STAND BY CHECK LV. MOT 77P017A-M01	PMT	1Y								T					RRC	RRC-ERCH	139333	B
937	UTF -77 -77P017A	UTF-77P017A-M	Regreasing Mot BRG of 77P017A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139773	B
938	UTF -77 -77P017A	UTF-77P017A-M	STAND BY CHECK LV. MOT 77P017A-M01	PMT	1Y				T									RRC	RRC-ERCH	154323	B
939	UTF -77 -77P017A	UTF-77P017A-P01	VB. INSP & ANALY M/C 77P017A	INT	4M	I				I				I				IRI	IRI-INVB	130506	B
940	UTF -77 -77P017A	UTF-77P017A-P01	VB. INSP & ANALY M/C 77P017A	INT	4M		I				I				I			IRI	IRI-INVB	131131	B
941	UTF -77 -77P017A	UTF-77P017A-P01	VB. INSP & ANALY M/C 77P017A	INT	4M			I				I				I		IRI	IRI-INVB	131357	B
942	UTF -77 -77P017A	UTF-77P017A-P01	PM INSP OF M/C NO. 77P017A	PMT	4M		I				I				I			RRC	RRC-MRCH	129907	B
943	UTF -77 -77P017A	UTF-77P017A-P01	PM OF 77P017A	PMT	4M				P			P					P	RRC	RRC-MRCH	130884	B
944	UTF -77 -77P017B	UTF-77P017B-M	STAND BY CHECK LV. MOT 77P017B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139334	B
945	UTF -77 -77P017B	UTF-77P017B-M	Regreasing Mot BRG of 77P017B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139774	B
946	UTF -77 -77P017B	UTF-77P017B-P01	VB. INSP & ANALY M/C 77P017B	INT	4M				I				I				I	IRI	IRI-INVB	130507	B
947	UTF -77 -77P017B	UTF-77P017B-P01	PM INSP OF M/C NO. 77P017B	PMT	4M				I				I				I	RRC	RRC-MRCH	129908	B
948	UTF -77 -77P017B	UTF-77P017B-P01	PM OF 77P017B	PMT	4M			P				P				P		RRC	RRC-MRCH	130885	B
949	UTF -77 -77P020A	UTF-77P020A-M	STAND BY CHECK LV. MOT 77P020A-M01	PMT	1Y								T					RRC	RRC-ERCH	139335	B
950	UTF -77 -77P020A	UTF-77P020A-M	Regreasing Mot BRG of 77P020A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139775	B
951	UTF -77 -77P020A	UTF-77P020A-M	STAND BY CHECK LV. MOT 77P020A-M01	PMT	1Y				T									RRC	RRC-ERCH	154324	B
952	UTF -77 -77P020A	UTF-77P020A-P01	VB. INSP & ANALY M/C 77P020A	INT	4M	I				I				I				IRI	IRI-INVB	130508	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
953	UTF -77 -77P020A	UTF-77P020A-P01	VB. INSP & ANALY M/C 77P020A	INT	4M		I				I			I				IRI	IRI-INVB	131132	B
954	UTF -77 -77P020A	UTF-77P020A-P01	VB. INSP & ANALY M/C 77P020A	INT	4M			I				I			I			IRI	IRI-INVB	131358	B
955	UTF -77 -77P020A	UTF-77P020A-P01	PM INSP OF M/C NO. 77P020A	PMT	4M		I				I			I				RRC	RRC-MRCH	129909	B
956	UTF -77 -77P020A	UTF-77P020A-P01	PM OF 77P020A	PMT	4M			P				P			P			RRC	RRC-MRCH	130886	B
957	UTF -77 -77P020B	UTF-77P020B-M	STAND BY CHECK LV. MOT 77P020B-M01	PMT	6M			T					T					RRC	RRC-ERCH	139336	B
958	UTF -77 -77P020B	UTF-77P020B-M	Regreasing Mot BRG of 77P020B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139776	B
959	UTF -77 -77P020B	UTF-77P020B-P01	VB. INSP & ANALY M/C 77P020B	INT	4M				I				I				I	IRI	IRI-INVB	130509	B
960	UTF -77 -77P020B	UTF-77P020B-P01	PM INSP OF M/C NO. 77P020B	PMT	4M				I			I				I		RRC	RRC-MRCH	129910	B
961	UTF -77 -77P020B	UTF-77P020B-P01	PM OF 77P020B	PMT	4M			P				P				P		RRC	RRC-MRCH	130887	B
962	UTF -77 -77P102A	UTF-77P102A-M	STAND BY CHECK LV. MOT 77P102A-M01	PMT	1Y								T					RRC	RRC-ERCH	139337	B
963	UTF -77 -77P102A	UTF-77P102A-M	STAND BY CHECK LV. MOT 77P102A-M01	PMT	1Y					T								RRC	RRC-ERCH	154325	B
964	UTF -77 -77P102A	UTF-77P102A-P01	VB. INSP & ANALY M/C 77P102A	INT	4M	I					I			I				IRI	IRI-INVB	130510	B
965	UTF -77 -77P102A	UTF-77P102A-P01	VB. INSP & ANALY M/C 77P102A	INT	4M		I					I			I			IRI	IRI-INVB	131133	B
966	UTF -77 -77P102A	UTF-77P102A-P01	VB. INSP & ANALY M/C 77P102A	INT	4M			I					I			I		IRI	IRI-INVB	131359	B
967	UTF -77 -77P102A	UTF-77P102A-P01	PM INSP OF M/C NO. 77P102A	PMT	4M		I				I				I			RRC	RRC-MRCH	129911	B
968	UTF -77 -77P102A	UTF-77P102A-P01	PM OF 77P102A	PMT	4M				P				P				P	RRC	RRC-MRCH	130888	B
969	UTF -77 -77P102B	UTF-77P102B-M	STAND BY CHECK LV. MOT 77P102B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139338	B
970	UTF -77 -77P102B	UTF-77P102B-P01	VB. INSP & ANALY M/C 77P102B	INT	4M				I				I				I	IRI	IRI-INVB	130511	B
971	UTF -77 -77P102B	UTF-77P102B-P01	PM INSP OF M/C NO. 77P102B	PMT	4M				I				I				I	RRC	RRC-MRCH	129912	B
972	UTF -77 -77P102B	UTF-77P102B-P01	PM OF 77P102B	PMT	4M	P				P				P				RRC	RRC-MRCH	130889	B
973	UTF -77 -77P105A	UTF-77P105A-M	STAND BY CHECK LV. MOT 77P105A-M01	PMT	1Y								T					RRC	RRC-ERCH	139339	B
974	UTF -77 -77P105A	UTF-77P105A-M	STAND BY CHECK LV. MOT 77P105A-M01	PMT	1Y					T								RRC	RRC-ERCH	154326	B
975	UTF -77 -77P105A	UTF-77P105A-P01	VB. INSP & ANALY M/C 77P105A	INT	4M	I					I			I				IRI	IRI-INVB	130512	B
976	UTF -77 -77P105A	UTF-77P105A-P01	VB. INSP & ANALY M/C 77P105A	INT	4M		I					I			I			IRI	IRI-INVB	131134	B
977	UTF -77 -77P105A	UTF-77P105A-P01	VB. INSP & ANALY M/C 77P105A	INT	4M			I					I			I		IRI	IRI-INVB	131360	B
978	UTF -77 -77P105A	UTF-77P105A-P01	PM INSP OF M/C NO. 77P105A	PMT	4M		I				I				I			RRC	RRC-MRCH	129913	B
979	UTF -77 -77P105A	UTF-77P105A-P01	PM OF 77P105A	PMT	4M				P				P				P	RRC	RRC-MRCH	130890	B
980	UTF -77 -77P105B	UTF-77P105B-M	STAND BY CHECK LV. MOT 77P105B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139340	B
981	UTF -77 -77P105B	UTF-77P105B-P01	VB. INSP & ANALY M/C 77P105B	INT	4M				I				I				I	IRI	IRI-INVB	130513	B
982	UTF -77 -77P105B	UTF-77P105B-P01	PM INSP OF M/C NO. 77P105B	PMT	4M			I				I			I			RRC	RRC-MRCH	129914	B
983	UTF -77 -77P105B	UTF-77P105B-P01	PM OF 77P105B	PMT	4M	P			P				P					RRC	RRC-MRCH	130891	B
984	UTF -77 -77P107	UTF-77P107-M	STAND BY CHECK LV. MOT 77P107-M01	PMT	6M			T					T					RRC	RRC-ERCH	139341	B
985	UTF -77 -77P107	UTF-77P107-P01	VB. INSP & ANALY M/C 77P107	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130514	B
986	UTF -77 -77P107	UTF-77P107-P01	PM INSP OF M/C NO. 77P107	PMT	4M	I				I			I					RRC	RRC-MRCH	129915	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
987	UTF -77 -77P107	UTF-77P107-P01	PM OF 77P107	PMT	4M	P				P				P				RRC	RRC-MRCH	130892	B
988	UTF -77 -77P108A	UTF-77P108A-M	STAND BY CHECK LV. MOT 77P108A-M01	PMT	1Y								T					RRC	RRC-ERCH	139342	B
989	UTF -77 -77P108A	UTF-77P108A-M	STAND BY CHECK LV. MOT 77P108A-M01	PMT	1Y				T									RRC	RRC-ERCH	154327	B
990	UTF -77 -77P108A	UTF-77P108A-P01	VB. INSP & ANALY M/C 77P108A	INT	4M	I				I			I					IRI	IRI-INVB	130515	B
991	UTF -77 -77P108A	UTF-77P108A-P01	VB. INSP & ANALY M/C 77P108A	INT	4M		I				I			I				IRI	IRI-INVB	131135	B
992	UTF -77 -77P108A	UTF-77P108A-P01	VB. INSP & ANALY M/C 77P108A	INT	4M			I				I			I			IRI	IRI-INVB	131361	B
993	UTF -77 -77P108A	UTF-77P108A-P01	PM INSP OF M/C NO. 77P108A	PMT	4M		I				I			I				RRC	RRC-MRCH	129916	B
994	UTF -77 -77P108A	UTF-77P108A-P01	PM OF 77P108A	PMT	4M			P				P			P			RRC	RRC-MRCH	130893	B
995	UTF -77 -77P108B	UTF-77P108B-M	STAND BY CHECK LV. MOT 77P108B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139343	B
996	UTF -77 -77P108B	UTF-77P108B-P01	VB. INSP & ANALY M/C 77P108B	INT	4M				I				I				I	IRI	IRI-INVB	130516	B
997	UTF -77 -77P108B	UTF-77P108B-P01	PM INSP OF M/C NO. 77P108B	PMT	4M			I				I			I			RRC	RRC-MRCH	129917	B
998	UTF -77 -77P108B	UTF-77P108B-P01	PM OF 77P108B	PMT	4M	P				P				P				RRC	RRC-MRCH	130894	B
999	UTF -77 -77P111A	UTF-77P111A-M	STAND BY CHECK LV. MOT 77P111A-M01	PMT	1Y								T					RRC	RRC-ERCH	139344	B
1,000	UTF -77 -77P111A	UTF-77P111A-M	Regreasing Mot BRG of 77P111A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139784	B
1,001	UTF -77 -77P111A	UTF-77P111A-M	STAND BY CHECK LV. MOT 77P111A-M01	PMT	1Y				T									RRC	RRC-ERCH	154328	B
1,002	UTF -77 -77P111A	UTF-77P111A-P01	VB. INSP & ANALY M/C 77P111A	INT	4M	I				I				I				IRI	IRI-INVB	130517	B
1,003	UTF -77 -77P111A	UTF-77P111A-P01	VB. INSP & ANALY M/C 77P111A	INT	4M		I				I				I			IRI	IRI-INVB	131136	B
1,004	UTF -77 -77P111A	UTF-77P111A-P01	VB. INSP & ANALY M/C 77P111A	INT	4M			I				I				I		IRI	IRI-INVB	131362	B
1,005	UTF -77 -77P111A	UTF-77P111A-P01	PM INSP OF M/C NO. 77P111A	PMT	4M		I				I			I				RRC	RRC-MRCH	129918	B
1,006	UTF -77 -77P111A	UTF-77P111A-P01	PM OF 77P111A	PMT	4M			P				P			P			RRC	RRC-MRCH	130895	B
1,007	UTF -77 -77P111B	UTF-77P111B-M	STAND BY CHECK LV. MOT 77P111B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139345	B
1,008	UTF -77 -77P111B	UTF-77P111B-M	Regreasing Mot BRG of 77P111B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139785	B
1,009	UTF -77 -77P111B	UTF-77P111B-P01	VB. INSP & ANALY M/C 77P111B	INT	4M				I				I				I	IRI	IRI-INVB	130518	B
1,010	UTF -77 -77P111B	UTF-77P111B-P01	PM INSP OF M/C NO. 77P111B	PMT	4M			I				I			I			RRC	RRC-MRCH	129919	B
1,011	UTF -77 -77P111B	UTF-77P111B-P01	PM OF 77P111B	PMT	4M	P				P				P				RRC	RRC-MRCH	130896	B
1,012	UTF -77 -77SF001	UTF-77SF001-AUX-E	PM AUKILIARY FOAM PUMP ENGINE	PMT	6M					P						P		CES	CES-AUTO	254308	B
1,013	UTF -77 -77T002A	UTF-77T002A-4001	INSPECTION CATHODIC PROTECTION 77T002A	PMT	2M		I		I		I		I		I		I	RRC	RRC-ERCH	140433	C
1,014	UTF -77 -77T002A	UTF-77T002A-T01	PM; FOR Emergency Vent Cover 77T002A	PMT	6M					P						P		RRC	RRC-MRCH	254638	C
1,015	UTF -77 -77T002B	UTF-77T002B-4002	INSPECTION CATHODIC PROTECTION 77T002B	PMT	2M		I		I		I		I		I		I	RRC	RRC-ERCH	140434	C
1,016	UTF -77 -77T002B	UTF-77T002B-T01	PM; FOR Emergency Vent Cover 77T002B	PMT	6M					P						P		RRC	RRC-MRCH	254639	C
1,017	UTF -77 -77T005A	UTF-77T005A-4003	INSPECTION CATHODIC PROTECTION 77T005A	PMT	2M		I		I		I		I		I		I	RRC	RRC-ERCH	140435	C
1,018	UTF -77 -77T005A	UTF-77T005A-T01	PM; FOR Emergency Vent Cover 77T005A	PMT	6M					P						P		RRC	RRC-MRCH	254640	C
1,019	UTF -77 -77T005B	UTF-77T005B-4004	INSPECTION CATHODIC PROTECTION 77T005B	PMT	2M		I		I		I		I		I		I	RRC	RRC-ERCH	140436	C
1,020	UTF -77 -77T005B	UTF-77T005B-T01	PM; FOR Emergency Vent Cover 77T005B	PMT	6M					P						P		RRC	RRC-MRCH	254641	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,021	UTF -77 -77T006	UTF-77T006-4005	INSPECTION CATHODIC PROTECTION 77T006	PMT	2M		I		I		I		I		I		I	RRC	RRC-ERCH	140437	C
1,022	UTF -77 -77T006	UTF-77T006-T01	PM; FOR Emergency Vent Cover 77T006	PMT	6M					P						P		RRC	RRC-MRCH	254642	C
1,023	UTF -77 -77T007A	UTF-77T007A-4006	INSPECTION CATHODIC PROTECTION 77T007A	PMT	2M		I		I		I		I		I		I	RRC	RRC-ERCH	140438	C
1,024	UTF -77 -77T007A	UTF-77T007A-T01	PM; FOR Emergency Vent Cover 77T007A	PMT	6M					P						P		RRC	RRC-MRCH	254643	C
1,025	UTF -77 -77T007B	UTF-77T007B-4007	INSPECTION CATHODIC PROTECTION 77T007B	PMT	2M		I		I		I		I		I		I	RRC	RRC-ERCH	140439	C
1,026	UTF -77 -77T007B	UTF-77T007B-T01	PM; FOR Emergency Vent Cover 77T007B	PMT	6M					P						P		RRC	RRC-MRCH	254644	C
1,027	UTF -77 -77T008	UTF-77T008-4008	INSPECTION CATHODIC PROTECTION 77T008	PMT	2M		I		I		I		I		I		I	RRC	RRC-ERCH	140440	C
1,028	UTF -77 -77T008	UTF-77T008-T01	PM; FOR Emergency Vent Cover 77T008	PMT	6M			P						P				RRC	RRC-MRCH	254645	C
1,029	UTF -77 -77T010	UTF-77T010-T01	PM; FOR Emergency Vent Cover 77T010	PMT	6M			P						P				RRC	RRC-MRCH	254636	C
1,030	UTF -77 -77T011	UTF-77T011-T01	PM; FOR Emergency Vent Cover 77T011	PMT	6M			P						P				RRC	RRC-MRCH	254637	C
1,031	UTF -77 -77T012	UTF-77T012-4009	INSPECTION CATHODIC PROTECTION 77T012	PMT	2M		I		I		I		I		I		I	RRC	RRC-ERCH	140441	C
1,032	UTF -77 -77T012	UTF-77T012-T01	PM; FOR Emergency Vent Cover 77T012	PMT	6M			P						P				RRC	RRC-MRCH	254646	C
1,033	UTF -77 -77T014	UTF-77T014-4010	INSPECTION CATHODIC PROTECTION 77T014	PMT	2M		I		I		I		I		I		I	RRC	RRC-ERCH	140442	C
1,034	UTF -77 -77T014	UTF-77T014-T01	PM; FOR Emergency Vent Cover 77T014	PMT	6M			P						P				RRC	RRC-MRCH	254647	C
1,035	UTF -77 -77TN002A	UTF-77TN002A-M	STAND BY CHECK LV. MOT 77TN002A-M01	PMT	1Y								T					RRC	RRC-ERCH	139346	B
1,036	UTF -77 -77TN002A	UTF-77TN002A-M	Regreasing Mot BRG of 77TN002A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139795	B
1,037	UTF -77 -77TN002A	UTF-77TN002A-M	STAND BY CHECK LV. MOT 77TN002A-M01	PMT	1Y				T									RRC	RRC-ERCH	154329	B
1,038	UTF -77 -77TN002A	UTF-77TN002A-TN01	VB. INSP & ANALY M/C 77TN002A	INT	4M	I				I				I				IRI	IRI-INVB	130538	B
1,039	UTF -77 -77TN002A	UTF-77TN002A-TN01	VB. INSP & ANALY M/C 77TN002A	INT	4M		I				I				I			IRI	IRI-INVB	131146	B
1,040	UTF -77 -77TN002A	UTF-77TN002A-TN01	VB. INSP & ANALY M/C 77TN002A	INT	4M			I				I				I		IRI	IRI-INVB	131371	B
1,041	UTF -77 -77TN002A	UTF-77TN002A-TN01	PM INSP OF M/C NO. 77TN002A	PMT	4M		I				I			I				RRC	RRC-MRCH	129939	B
1,042	UTF -77 -77TN002A	UTF-77TN002A-TN01	PM OF 77TN002A	PMT	4M	P				P				P				RRC	RRC-MRCH	130916	B
1,043	UTF -77 -77TN002B	UTF-77TN002B-M	STAND BY CHECK LV. MOT 77TN002B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139347	B
1,044	UTF -77 -77TN002B	UTF-77TN002B-M	Regreasing Mot BRG of 77TN002B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139796	B
1,045	UTF -77 -77TN002B	UTF-77TN002B-TN01	VB. INSP & ANALY M/C 77TN002B	INT	4M				I				I				I	IRI	IRI-INVB	130539	B
1,046	UTF -77 -77TN002B	UTF-77TN002B-TN01	PM INSP OF M/C NO. 77TN002B	PMT	4M				I				I				I	RRC	RRC-MRCH	129940	B
1,047	UTF -77 -77TN002B	UTF-77TN002B-TN01	PM OF 77TN002B	PMT	4M	P				P				P				RRC	RRC-MRCH	130917	B
1,048	UTF -77 -77TN005A	UTF-77TN005A-M	STAND BY CHECK LV. MOT 77TN005A-M01	PMT	1Y								T					RRC	RRC-ERCH	139348	B
1,049	UTF -77 -77TN005A	UTF-77TN005A-M	Regreasing Mot BRG of 77TN005A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139797	B
1,050	UTF -77 -77TN005A	UTF-77TN005A-M	STAND BY CHECK LV. MOT 77TN005A-M01	PMT	1Y				T									RRC	RRC-ERCH	154330	B
1,051	UTF -77 -77TN005A	UTF-77TN005A-TN01	VB. INSP & ANALY M/C 77TN005A	INT	4M	I				I				I				IRI	IRI-INVB	130540	B
1,052	UTF -77 -77TN005A	UTF-77TN005A-TN01	VB. INSP & ANALY M/C 77TN005A	INT	4M		I				I				I			IRI	IRI-INVB	131147	B
1,053	UTF -77 -77TN005A	UTF-77TN005A-TN01	VB. INSP & ANALY M/C 77TN005A	INT	4M			I				I				I		IRI	IRI-INVB	131372	B
1,054	UTF -77 -77TN005A	UTF-77TN005A-TN01	PM INSP OF M/C NO. 77TN005A	PMT	4M		I				I			I				RRC	RRC-MRCH	129941	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,055	UTF -77 -77TN005A	UTF-77TN005A-TN01	PM OF 77TN005A	PMT	4M	P				P				P				RRC	RRC-MRCH	130918	B
1,056	UTF -77 -77TN005B	UTF-77TN005B-M	STAND BY CHECK LV. MOT 77TN005B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139349	B
1,057	UTF -77 -77TN005B	UTF-77TN005B-M	Regreasing Mot BRG of 77TN005B -M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139798	B
1,058	UTF -77 -77TN005B	UTF-77TN005B-TN01	VB. INSP & ANALY M/C 77TN005B	INT	4M				I				I				I	IRI	IRI-INVB	130541	B
1,059	UTF -77 -77TN005B	UTF-77TN005B-TN01	PM INSP OF M/C NO. 77TN005B	PMT	4M				I				I				I	RRC	RRC-MRCH	129942	B
1,060	UTF -77 -77TN005B	UTF-77TN005B-TN01	PM OF 77TN005B	PMT	4M	P				P				P				RRC	RRC-MRCH	130919	B
1,061	UTF -77 -77TN006	UTF-77TN006-M	STAND BY CHECK LV. MOT 77TN006-M01	PMT	6M			T						T				RRC	RRC-ERCH	139350	B
1,062	UTF -77 -77TN006	UTF-77TN006-M	Regreasing Mot BRG of 77TN006-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139799	B
1,063	UTF -77 -77TN006	UTF-77TN006-TN01	VB. INSP & ANALY M/C 77TN006	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130542	B
1,064	UTF -77 -77TN006	UTF-77TN006-TN01	PM INSP OF M/C NO. 77TN006	PMT	4M	I				I				I				RRC	RRC-MRCH	129943	B
1,065	UTF -77 -77TN006	UTF-77TN006-TN01	PM OF 77TN006	PMT	4M	P				P				P				RRC	RRC-MRCH	130920	B
1,066	UTF -77 -77TN007A	UTF-77TN007A-M	STAND BY CHECK LV. MOT 77TN007A-M01	PMT	1Y								T					RRC	RRC-ERCH	139351	B
1,067	UTF -77 -77TN007A	UTF-77TN007A-M	Regreasing Mot BRG of 77TN007A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139800	B
1,068	UTF -77 -77TN007A	UTF-77TN007A-M	STAND BY CHECK LV. MOT 77TN007A-M01	PMT	1Y				T									RRC	RRC-ERCH	154331	B
1,069	UTF -77 -77TN007A	UTF-77TN007A-TN01	VB. INSP & ANALY M/C 77TN007A	INT	4M	I				I				I				IRI	IRI-INVB	130543	B
1,070	UTF -77 -77TN007A	UTF-77TN007A-TN01	VB. INSP & ANALY M/C 77TN007A	INT	4M		I				I				I			IRI	IRI-INVB	131148	B
1,071	UTF -77 -77TN007A	UTF-77TN007A-TN01	VB. INSP & ANALY M/C 77TN007A	INT	4M			I				I				I		IRI	IRI-INVB	131373	B
1,072	UTF -77 -77TN007A	UTF-77TN007A-TN01	PM INSP OF M/C NO. 77TN007A	PMT	4M		I				I			I				RRC	RRC-MRCH	129944	B
1,073	UTF -77 -77TN007A	UTF-77TN007A-TN01	PM OF 77TN007A	PMT	4M	P				P				P				RRC	RRC-MRCH	130921	B
1,074	UTF -77 -77TN007B	UTF-77TN007B-M	STAND BY CHECK LV. MOT 77TN007B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139352	B
1,075	UTF -77 -77TN007B	UTF-77TN007B-M	Regreasing Mot BRG of 77TN007B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139801	B
1,076	UTF -77 -77TN007B	UTF-77TN007B-TN01	VB. INSP & ANALY M/C 77TN007B	INT	4M				I				I				I	IRI	IRI-INVB	130544	B
1,077	UTF -77 -77TN007B	UTF-77TN007B-TN01	PM INSP OF M/C NO. 77TN007B	PMT	4M				I				I				I	RRC	RRC-MRCH	129945	B
1,078	UTF -77 -77TN007B	UTF-77TN007B-TN01	PM OF 77TN007B	PMT	4M	P				P				P				RRC	RRC-MRCH	130922	B
1,079	UTF -77 -77TN008	UTF-77TN008-M	STAND BY CHECK LV. MOT 77TN008-M01	PMT	6M			T						T				RRC	RRC-ERCH	139353	B
1,080	UTF -77 -77TN008	UTF-77TN008-TN01	VB. INSP & ANALY M/C 77TN011	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130545	B
1,081	UTF -77 -77TN008	UTF-77TN008-TN01	PM INSP OF M/C NO. 77TN008	PMT	4M	I				I				I				RRC	RRC-MRCH	129946	B
1,082	UTF -77 -77TN008	UTF-77TN008-TN01	PM OF 77TN008	PMT	4M	P				P				P				RRC	RRC-MRCH	130923	B
1,083	UTF -77 -77TN011	UTF-77TN011-M	STAND BY CHECK LV. MOT 77TN011-M01	PMT	6M			T						T				RRC	RRC-ERCH	139354	B
1,084	UTF -77 -77TN011	UTF-77TN011-TN01	VB. INSP & ANALY M/C 77TN008	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130546	B
1,085	UTF -77 -77TN011	UTF-77TN011-TN01	PM INSP OF M/C NO. 77TN011	PMT	4M	I				I				I				RRC	RRC-MRCH	129947	B
1,086	UTF -77 -77TN011	UTF-77TN011-TN01	PM OF 77TN011	PMT	4M	P				P				P				RRC	RRC-MRCH	130924	B
1,087	UTF -77 -77TN014	UTF-77TN014-M	STAND BY CHECK LV. MOT 77TN014-M01	PMT	6M			T						T				RRC	RRC-ERCH	139355	B
1,088	UTF -77 -77TN014	UTF-77TN014-M	Regreasing Mot BRG of 77TN014-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139804	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,089	UTF -77 -77TN014	UTF-77TN014-TN01	VB. INSP & ANALY M/C 77TN014	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130547	B
1,090	UTF -77 -77TN014	UTF-77TN014-TN01	PM INSP OF M/C NO. 77TN014	PMT	4M	I				I				I				RRC	RRC-MRCH	129948	B
1,091	UTF -77 -77TN014	UTF-77TN014-TN01	PM OF 77TN014	PMT	4M	P				P				P				RRC	RRC-MRCH	130925	B
1,092	UTF -77 -77X001	UTF-77X001-P01A	PM INSP OF M/C NO. 77X001 -P01A	PMT	4M		I				I			I				RRC	RRC-MRCH	129920	B
1,093	UTF -77 -77X001	UTF-77X001-P01A	PM OF 77X001 -P01A	PMT	4M				P				P				P	RRC	RRC-MRCH	130897	B
1,094	UTF -77 -77X001	UTF-77X001-P01B	PM INSP OF M/C NO. 77X001 -P01B	PMT	4M				I				I				I	RRC	RRC-MRCH	129921	B
1,095	UTF -77 -77X001	UTF-77X001-P01B	PM OF 77X001 -P01B	PMT	4M	P				P				P				RRC	RRC-MRCH	130898	B
1,096	UTF -78 -78K001A	UTF-78K001A-K01	VB. INSP & ANALY M/C 78K001A	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	150223	B
1,097	UTF -78 -78K001A	UTF-78K001A-M	STAND BY CHECK LV. MOT 78K001A-M01	PMT	1Y								T					RRC	RRC-ERCH	139356	B
1,098	UTF -78 -78K001A	UTF-78K001A-M	STAND BY CHECK LV. MOT 78K001A-M01	PMT	1Y					T								RRC	RRC-ERCH	154332	B
1,099	UTF -78 -78K001B	UTF-78K001B-K01	VB. INSP & ANALY M/C 78K001B	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	150224	B
1,100	UTF -78 -78K001B	UTF-78K001B-M	STAND BY CHECK LV. MOT 78K001B-M01	PMT	6M				T				T					RRC	RRC-ERCH	139357	B
1,101	UTF -78 -78P001A	UTF-78P001A-M	STAND BY CHECK LV. MOT 78P001A-M01	PMT	1Y								T					RRC	RRC-ERCH	139358	B
1,102	UTF -78 -78P001A	UTF-78P001A-M	Regreasing Mot BRG of 78P001A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139786	B
1,103	UTF -78 -78P001A	UTF-78P001A-M	STAND BY CHECK LV. MOT 78P001A-M01	PMT	1Y					T								RRC	RRC-ERCH	154333	B
1,104	UTF -78 -78P001A	UTF-78P001A-P01	VB. INSP & ANALY M/C 78P001A	INT	4M	I				I				I				IRI	IRI-INVB	130521	B
1,105	UTF -78 -78P001A	UTF-78P001A-P01	VB. INSP & ANALY M/C 78P001A	INT	4M		I				I				I			IRI	IRI-INVB	131138	B
1,106	UTF -78 -78P001A	UTF-78P001A-P01	PM INSP OF M/C NO. 78P001A	PMT	4M				I				I				I	IRI	IRI-INVB	131364	B
1,107	UTF -78 -78P001A	UTF-78P001A-P01	PM INSP OF M/C NO. 78P001A	PMT	4M				I				I				I	RRC	RRC-MRCH	129922	B
1,108	UTF -78 -78P001A	UTF-78P001A-P01	PM OF 78P001A	PMT	4M					P				P				RRC	RRC-MRCH	130899	B
1,109	UTF -78 -78P001B	UTF-78P001B-M	STAND BY CHECK LV. MOT 78P001B-M01	PMT	6M				T					T				RRC	RRC-ERCH	139359	B
1,110	UTF -78 -78P001B	UTF-78P001B-M	Regreasing Mot BRG of 78P001B-M01	PMT	4M					L				L				RRC	RRC-ERCH	139787	B
1,111	UTF -78 -78P001B	UTF-78P001B-P01	VB. INSP & ANALY M/C 78P001B	INT	4M					I				I				IRI	IRI-INVB	130522	B
1,112	UTF -78 -78P001B	UTF-78P001B-P01	PM INSP OF M/C NO. 78P001B	PMT	4M				I			I			I			RRC	RRC-MRCH	129923	B
1,113	UTF -78 -78P001B	UTF-78P001B-P01	PM OF 78P001B	PMT	4M				P				P				P	RRC	RRC-MRCH	130900	B
1,114	UTF -78 -78P002A	UTF-78P002A-M	STAND BY CHECK LV. MOT 78P002A-M01	PMT	1Y				T									RRC	RRC-ERCH	139360	B
1,115	UTF -78 -78P002A	UTF-78P002A-M	Regreasing Mot BRG of 78P002A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139438	B
1,116	UTF -78 -78P002A	UTF-78P002A-M	STAND BY CHECK LV. MOT 78P002A-M01	PMT	1Y				T									RRC	RRC-ERCH	154334	B
1,117	UTF -78 -78P002A	UTF-78P002A-P01	VB. INSP & ANALY M/C 78P002A	INT	4M	I				I				I				IRI	IRI-INVB	130523	B
1,118	UTF -78 -78P002A	UTF-78P002A-P01	VB. INSP & ANALY M/C 78P002A	INT	4M		I				I				I			IRI	IRI-INVB	131139	B
1,119	UTF -78 -78P002A	UTF-78P002A-P01	VB. INSP & ANALY M/C 78P002A	INT	4M			I				I				I		IRI	IRI-INVB	131365	B
1,120	UTF -78 -78P002A	UTF-78P002A-P01	PM INSP OF M/C NO. 78P002A	PMT	4M				I				I				I	RRC	RRC-MRCH	129924	B
1,121	UTF -78 -78P002A	UTF-78P002A-P01	PM OF 78P002A	PMT	4M				P				P				P	RRC	RRC-MRCH	130901	B
1,122	UTF -78 -78P002B	UTF-78P002B-M	STAND BY CHECK LV. MOT 78P002B-M01	PMT	6M			T					T					RRC	RRC-ERCH	139361	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,123	UTF -78 -78P002B	UTF-78P002B-M	Regreasing Mot BRG of 78P002B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139439	B
1,124	UTF -78 -78P002B	UTF-78P002B-P01	VB. INSP & ANALY M/C 78P002B	INT	4M				I				I				I	IRI	IRI-INVB	130524	B
1,125	UTF -78 -78P002B	UTF-78P002B-P01	PM INSP OF M/C NO. 78P002B	PMT	4M				I				I				I	RRC	RRC-MRCH	129925	B
1,126	UTF -78 -78P002B	UTF-78P002B-P01	PM OF 78P002B	PMT	4M		P				P			P				RRC	RRC-MRCH	130902	B
1,127	UTF -78 -78P004A	UTF-78P004A-M	STAND BY CHECK LV. MOT 78P004A-M01	PMT	1Y								T					RRC	RRC-ERCH	139362	B
1,128	UTF -78 -78P004A	UTF-78P004A-M	Regreasing Mot BRG of 78P004A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139788	B
1,129	UTF -78 -78P004A	UTF-78P004A-M	STAND BY CHECK LV. MOT 78P004A-M01	PMT	1Y				T									RRC	RRC-ERCH	154335	B
1,130	UTF -78 -78P004A	UTF-78P004A-P01	VB. INSP & ANALY M/C 78P004A	INT	4M	I				I				I				IRI	IRI-INVB	130525	B
1,131	UTF -78 -78P004A	UTF-78P004A-P01	VB. INSP & ANALY M/C 78P004A	INT	4M		I				I				I			IRI	IRI-INVB	131140	B
1,132	UTF -78 -78P004A	UTF-78P004A-P01	VB. INSP & ANALY M/C 78P004A	INT	4M			I				I				I		IRI	IRI-INVB	131366	B
1,133	UTF -78 -78P004A	UTF-78P004A-P01	PM INSP OF M/C NO. 78P004A	PMT	4M				I				I				I	RRC	RRC-MRCH	129926	B
1,134	UTF -78 -78P004A	UTF-78P004A-P01	PM OF 78P004A	PMT	4M				P				P				P	RRC	RRC-MRCH	130903	B
1,135	UTF -78 -78P004B	UTF-78P004B-M	STAND BY CHECK LV. MOT 78P004B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139363	B
1,136	UTF -78 -78P004B	UTF-78P004B-M	Regreasing Mot BRG of 78P004B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139789	B
1,137	UTF -78 -78P004B	UTF-78P004B-P01	VB. INSP & ANALY M/C 78P004B	INT	4M				I				I				I	IRI	IRI-INVB	130526	B
1,138	UTF -78 -78P004B	UTF-78P004B-P01	PM INSP OF M/C NO. 78P004B	PMT	4M				I				I				I	RRC	RRC-MRCH	129927	B
1,139	UTF -78 -78P004B	UTF-78P004B-P01	PM OF 78P004B	PMT	4M		P				P			P				RRC	RRC-MRCH	130904	B
1,140	UTF -78 -78P005A	UTF-78P005A-M	STAND BY CHECK LV. MOT 78P005A-M01	PMT	1Y								T					RRC	RRC-ERCH	139364	B
1,141	UTF -78 -78P005A	UTF-78P005A-M	Regreasing Mot BRG of 78P005A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139790	B
1,142	UTF -78 -78P005A	UTF-78P005A-M	STAND BY CHECK LV. MOT 78P005A-M01	PMT	1Y				T									RRC	RRC-ERCH	154336	B
1,143	UTF -78 -78P005A	UTF-78P005A-P01	VB. INSP & ANALY M/C 78P005A	INT	4M	I				I				I				IRI	IRI-INVB	130527	B
1,144	UTF -78 -78P005A	UTF-78P005A-P01	VB. INSP & ANALY M/C 78P005A	INT	4M		I				I				I			IRI	IRI-INVB	131141	B
1,145	UTF -78 -78P005A	UTF-78P005A-P01	VB. INSP & ANALY M/C 78P005A	INT	4M			I				I				I		IRI	IRI-INVB	131367	B
1,146	UTF -78 -78P005A	UTF-78P005A-P01	PM INSP OF M/C NO. 78P005A	PMT	4M			I				I				I		RRC	RRC-MRCH	129928	B
1,147	UTF -78 -78P005A	UTF-78P005A-P01	PM OF 78P005A	PMT	4M				P				P				P	RRC	RRC-MRCH	130905	B
1,148	UTF -78 -78P005B	UTF-78P005B-M	STAND BY CHECK LV. MOT 78P005B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139365	B
1,149	UTF -78 -78P005B	UTF-78P005B-M	Regreasing Mot BRG of 78P005B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139791	B
1,150	UTF -78 -78P005B	UTF-78P005B-P01	VB. INSP & ANALY M/C 78P005B	INT	4M				I				I				I	IRI	IRI-INVB	130528	B
1,151	UTF -78 -78P005B	UTF-78P005B-P01	PM INSP OF M/C NO. 78P005B	PMT	4M				I				I				I	RRC	RRC-MRCH	129929	B
1,152	UTF -78 -78P005B	UTF-78P005B-P01	PM OF 78P005B	PMT	4M		P				P			P				RRC	RRC-MRCH	130906	B
1,153	UTF -78 -78P006A	UTF-78P006A-M	STAND BY CHECK LV. MOT 78P006A-M01	PMT	1Y								T					RRC	RRC-ERCH	139366	B
1,154	UTF -78 -78P006A	UTF-78P006A-M	STAND BY CHECK LV. MOT 78P006A-M01	PMT	1Y				T									RRC	RRC-ERCH	154337	B
1,155	UTF -78 -78P006A	UTF-78P006A-P01	VB. INSP & ANALY M/C 78P006A	INT	4M	I				I				I				IRI	IRI-INVB	130529	B
1,156	UTF -78 -78P006A	UTF-78P006A-P01	VB. INSP & ANALY M/C 78P006A	INT	4M		I				I				I			IRI	IRI-INVB	131143	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,157	UTF -78 -78P006A	UTF-78P006A-P01	VB. INSP & ANALY M/C 78P006A	INT	4M			I				I				I		IRI	IRI-INVB	131368	B
1,158	UTF -78 -78P006A	UTF-78P006A-P01	PM INSP OF M/C NO. 78P006A	PMT	4M				I				I				I	RRC	RRC-MRCH	129930	B
1,159	UTF -78 -78P006A	UTF-78P006A-P01	PM OF 78P006A	PMT	4M				P				P				P	RRC	RRC-MRCH	130907	B
1,160	UTF -78 -78P006B	UTF-78P006B-M	STAND BY CHECK LV. MOT 78P006B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139367	B
1,161	UTF -78 -78P006B	UTF-78P006B-P01	VB. INSP & ANALY M/C 78P006B	INT	4M				I				I				I	IRI	IRI-INVB	130530	B
1,162	UTF -78 -78P006B	UTF-78P006B-P01	PM INSP OF M/C NO. 78P006B	PMT	4M				I				I				I	RRC	RRC-MRCH	129931	B
1,163	UTF -78 -78P006B	UTF-78P006B-P01	PM OF 78P006B	PMT	4M		P				P			P				RRC	RRC-MRCH	130908	B
1,164	UTF -78 -78P007A	UTF-78P007A-M	STAND BY CHECK LV. MOT 78P007A-M01	PMT	1Y								T					RRC	RRC-ERCH	139368	B
1,165	UTF -78 -78P007A	UTF-78P007A-M	Regreasing Mot BRG of 78P007A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139442	B
1,166	UTF -78 -78P007A	UTF-78P007A-M	STAND BY CHECK LV. MOT 78P007A-M01	PMT	1Y				T									RRC	RRC-ERCH	154338	B
1,167	UTF -78 -78P007A	UTF-78P007A-P01	VB. INSP & ANALY M/C 78P007A	INT	4M	I				I				I				IRI	IRI-INVB	130531	B
1,168	UTF -78 -78P007A	UTF-78P007A-P01	VB. INSP & ANALY M/C 78P007A	INT	4M		I				I				I			IRI	IRI-INVB	131144	B
1,169	UTF -78 -78P007A	UTF-78P007A-P01	VB. INSP & ANALY M/C 78P007A	INT	4M			I				I				I		IRI	IRI-INVB	131369	B
1,170	UTF -78 -78P007A	UTF-78P007A-P01	PM INSP OF M/C NO. 78P007A	PMT	4M				I				I				I	RRC	RRC-MRCH	129932	B
1,171	UTF -78 -78P007A	UTF-78P007A-P01	PM OF 78P007A	PMT	4M				P				P				P	RRC	RRC-MRCH	130909	B
1,172	UTF -78 -78P007B	UTF-78P007B-M	STAND BY CHECK LV. MOT 78P007B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139369	B
1,173	UTF -78 -78P007B	UTF-78P007B-M	Regreasing Mot BRG of 78P007B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139443	B
1,174	UTF -78 -78P007B	UTF-78P007B-P01	VB. INSP & ANALY M/C 78P007B	INT	4M				I				I				I	IRI	IRI-INVB	130532	B
1,175	UTF -78 -78P007B	UTF-78P007B-P01	PM INSP OF M/C NO. 78P007B	PMT	4M				I				I				I	RRC	RRC-MRCH	129933	B
1,176	UTF -78 -78P007B	UTF-78P007B-P01	PM OF 78P007B	PMT	4M		P				P			P				RRC	RRC-MRCH	130910	B
1,177	UTF -78 -78P010A	UTF-78P010A-M	STAND BY CHECK LV. MOT 78P010A-M01	PMT	1Y								T					RRC	RRC-ERCH	139370	B
1,178	UTF -78 -78P010A	UTF-78P010A-M	Regreasing Mot BRG of 78P010A-M01	PMT	4M	L				L				L				RRC	RRC-ERCH	139792	B
1,179	UTF -78 -78P010A	UTF-78P010A-M	STAND BY CHECK LV. MOT 78P010A-M01	PMT	1Y				T									RRC	RRC-ERCH	154339	B
1,180	UTF -78 -78P010A	UTF-78P010A-P01	VB. INSP & ANALY M/C 78P010A	INT	4M	I				I				I				IRI	IRI-INVB	130533	B
1,181	UTF -78 -78P010A	UTF-78P010A-P01	VB. INSP & ANALY M/C 78P010A	INT	4M		I				I				I			IRI	IRI-INVB	131145	B
1,182	UTF -78 -78P010A	UTF-78P010A-P01	VB. INSP & ANALY M/C 78P010A	INT	4M			I				I				I		IRI	IRI-INVB	131370	B
1,183	UTF -78 -78P010A	UTF-78P010A-P01	PM INSP OF M/C NO. 78P010A	PMT	4M			I				I				I		RRC	RRC-MRCH	129934	B
1,184	UTF -78 -78P010A	UTF-78P010A-P01	PM OF 78P010A	PMT	4M				P				P				P	RRC	RRC-MRCH	130911	B
1,185	UTF -78 -78P010B	UTF-78P010B-M	STAND BY CHECK LV. MOT 78P010B-M01	PMT	6M			T						T				RRC	RRC-ERCH	139371	B
1,186	UTF -78 -78P010B	UTF-78P010B-M	Regreasing Mot BRG of 78P010B-M01	PMT	4M				L				L				L	RRC	RRC-ERCH	139793	B
1,187	UTF -78 -78P010B	UTF-78P010B-P01	VB. INSP & ANALY M/C 78P010B	INT	4M				I				I				I	IRI	IRI-INVB	130534	B
1,188	UTF -78 -78P010B	UTF-78P010B-P01	PM INSP OF M/C NO. 78P010B	PMT	4M		I				I				I			RRC	RRC-MRCH	129935	B
1,189	UTF -78 -78P010B	UTF-78P010B-P01	PM OF 78P010B	PMT	4M			P				P				P		RRC	RRC-MRCH	130912	B
1,190	UTF -78 -78P012	UTF-78P012-M	STAND BY CHECK LV. MOT 78P012-M01	PMT	6M			T						T				RRC	RRC-ERCH	139372	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,191	UTF -78 -78P012	UTF-78P012-P01	VB. INSP & ANALY M/C 78P012	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130535	B
1,192	UTF -78 -78P012	UTF-78P012-P01	PM INSP OF M/C NO. 78P012	PMT	4M	I				I				I				RRC	RRC-MRCH	129936	B
1,193	UTF -78 -78P012	UTF-78P012-P01	PM OF 78P012	PMT	4M		P				P			P				RRC	RRC-MRCH	130913	B
1,194	UTF -78 -78T004	UTF-78T004-T01	PM; FOR Emergency Vent Cover 78T004	PMT	6M				P				P				P	RRC	RRC-MRCH	254649	C
1,195	UTF -78 -78T005	UTF-78T005-T01	PM; FOR Emergency Vent Cover 78T005	PMT	6M				P				P				P	RRC	RRC-MRCH	254650	C
1,196	UTF -78 -78T012	UTF-78T012-T01	Storage tank inspection	PMT	5Y					I								IRI	IRI-INRC	177829	C
1,197	UTF -78 -78T012	UTF-78T012-T01	PM; FOR Emergency Vent Cover 78T012	PMT	6M				P				P				P	RRC	RRC-MRCH	254651	C
1,198	UTF -78 -78X001	UTF-78X001-P01A	VB. INSP & ANALY M/C 78X001-P01A	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	150225	C
1,199	UTF -78 -78X001	UTF-78X001-P01A	PM OF 78X001-P01A	PMT	4M				P				P				P	RRC	RRC-MRCH	148858	C
1,200	UTF -78 -78X001	UTF-78X001-P01A	PM INSP OF M/C NO.78X001-P01A	PMT	4M			I				I				I		RRC	RRC-MRCH	149197	C
1,201	UTF -78 -78X001	UTF-78X001-P01B	VB. INSP & ANALY M/C 78X001-P01B	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	150226	C
1,202	UTF -78 -78X001	UTF-78X001-P01B	PM OF 78X001-P01B	PMT	4M			P				P				P		RRC	RRC-MRCH	148859	C
1,203	UTF -78 -78X001	UTF-78X001-P01B	PM INSP OF M/C NO.78X001-P01B	PMT	4M				I				I				I	RRC	RRC-MRCH	149198	C
1,204	UTF -78 -78X001	UTF-78X001-PLC	INSPECT PLC SYSTEM	PMT	3M		I			I			I			I		CCS	CCS-SYS	246506	A
1,205	UTF -78 -78X001	UTF-78X001-PLC	BACKUP PLC SYSTEM	PMT	6M		I						I					CCS	CCS-SYS	246507	A
1,206	UTF -78 -78X002	UTF-78X002-P01A	PM OF 78X002-P01A	PMT	4M				P				P				P	RRC	RRC-MRCH	148860	C
1,207	UTF -78 -78X002	UTF-78X002-P01A	PM INSP OF M/C NO.78X002-P01A	PMT	4M			I				I				I		RRC	RRC-MRCH	149199	C
1,208	UTF -78 -78X002	UTF-78X002-P01B	PM OF 78X002-P01B	PMT	4M			P				P				P		RRC	RRC-MRCH	148861	C
1,209	UTF -78 -78X002	UTF-78X002-P01B	PM INSP OF M/C NO.78X002-P01B	PMT	4M				I				I				I	RRC	RRC-MRCH	149200	C
1,210	UTF -78 -78X002	UTF-78X002-P02A	VB. INSP & ANALY M/C 78X002-P01A	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	150227	C
1,211	UTF -78 -78X002	UTF-78X002-P02A	PM OF 78X002-P02A	PMT	4M				P				P				P	RRC	RRC-MRCH	148862	C
1,212	UTF -78 -78X002	UTF-78X002-P02A	PM INSP OF M/C NO.78X002-P02A	PMT	4M			I				I				I		RRC	RRC-MRCH	149201	C
1,213	UTF -78 -78X002	UTF-78X002-P02B	VB. INSP & ANALY M/C 78X002-P01B	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	150228	C
1,214	UTF -78 -78X002	UTF-78X002-P02B	PM OF 78X002-P02B	PMT	4M			P				P				P		RRC	RRC-MRCH	148863	C
1,215	UTF -78 -78X002	UTF-78X002-P02B	PM INSP OF M/C NO.78X002-P02B	PMT	4M				I				I				I	RRC	RRC-MRCH	149202	C
1,216	UTF -78 -78X002	UTF-78X002-P03A	PM OF 78X002-P03A	PMT	4M				P				P				P	RRC	RRC-MRCH	148864	C
1,217	UTF -78 -78X002	UTF-78X002-P03A	PM INSP OF M/C NO.78X002-P03A	PMT	4M			I				I				I		RRC	RRC-MRCH	149203	C
1,218	UTF -78 -78X002	UTF-78X002-P03B	PM OF 78X002-P03B	PMT	4M			P				P				P		RRC	RRC-MRCH	148865	C
1,219	UTF -78 -78X002	UTF-78X002-P03B	PM INSP OF M/C NO.78X002-P03B	PMT	4M				I				I				I	RRC	RRC-MRCH	149204	C
1,220	UTF -78 -78X002	UTF-78X002-Z03	PM OF 78X002-Z03	PMT	4M		P				P				P			RRC	RRC-MRCH	148866	C
1,221	UTF -78 -78X002	UTF-78X002-Z03	PM INSP OF M/C NO.78X002-Z03	PMT	4M	I				I				I				RRC	RRC-MRCH	149205	C
1,222	UTF -78 -78X003	UTF-78X003-X01	PM OF 78X003	PMT	4M		P				P				P			RRC	RRC-MRCH	148867	C
1,223	UTF -78 -78X003	UTF-78X003-X01	PM INSP OF M/C NO.78X003	PMT	4M	I				I				I				RRC	RRC-MRCH	149206	C
1,224	UTF -78 -78X004	UTF-78X004-X01	PM OF 78X004	PMT	4M		P				P				P			RRC	RRC-MRCH	148868	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,225	UTF -78 -78X004	UTF-78X004-X01	PM INSP OF M/C NO.78X004	PMT	4M	I				I			I					RRC	RRC-MRCH	149207	C
1,226	UTF -78 -78X005	UTF-78X005-X01	PM OF 78X005	PMT	4M		P				P			P				RRC	RRC-MRCH	148869	C
1,227	UTF -78 -78X005	UTF-78X005-X01	PM INSP OF M/C NO.78X005	PMT	4M	I				I			I					RRC	RRC-MRCH	149208	C
1,228	UTF -78 -78X006	UTF-78X006-X01	PM OF 78X006	PMT	4M		P				P			P				RRC	RRC-MRCH	148870	C
1,229	UTF -78 -78X006	UTF-78X006-X01	PM INSP OF M/C NO.78X006	PMT	4M	I				I			I					RRC	RRC-MRCH	149209	C
1,230	UTF -79 -79F101	UTF-79F101-M	STAND BY CHECK LV. MOT 79F101-M	PMT	1Y				T									RRC	RRC-ERCH	245795	C
1,231	UTF -79 -79F101	UTF-79F101-M	STAND BY CHECK LV. MOT 79F101-M	PMT	1Y								T					RRC	RRC-ERCH	245796	C
1,232	UTF -79 -79K101A	UTF-79K101A-K01	PM OF UTF-79K101A-K01	PMT	4M				P				P				P	RRC	RRC-MRCH	245641	C
1,233	UTF -79 -79K101A	UTF-79K101A-K01	PM INSP OF M/C NO.UTF-79K101A-K01	PMT	4M	I				I			I					RRC	RRC-MRCH	245692	C
1,234	UTF -79 -79K101A	UTF-79K101A-K01	REGREASING BRG OF UTF-79K101A-K01	PMT	4M				L				L				L	RRC	RRC-MRCH	245693	C
1,235	UTF -79 -79K101A	UTF-79K101A-M	Regreasing Mot BRG of 79K101A-M	PMT	4M	L				L				L				RRC	RRC-ERCH	245781	C
1,236	UTF -79 -79K101A	UTF-79K101A-M	STAND BY CHECK LV. MOT 79K101A-M	PMT	1Y				T									RRC	RRC-ERCH	245797	C
1,237	UTF -79 -79K101A	UTF-79K101A-M	STAND BY CHECK LV. MOT 79K101A-M	PMT	1Y								T					RRC	RRC-ERCH	245798	C
1,238	UTF -79 -79K101B	UTF-79K101B-K01	PM OF UTF-79K101B-K01	PMT	4M				P				P				P	RRC	RRC-MRCH	245642	C
1,239	UTF -79 -79K101B	UTF-79K101B-K01	PM INSP OF M/C NO.UTF-79K101B-K01	PMT	4M				I				I				I	RRC	RRC-MRCH	245694	C
1,240	UTF -79 -79K101B	UTF-79K101B-K01	REGREASING BRG OF UTF-79K101B-K01	PMT	4M				L				L				L	RRC	RRC-MRCH	245695	C
1,241	UTF -79 -79K101B	UTF-79K101B-M	STAND BY CHECK LV. MOT 79K101B-M	PMT	6M				T					T				RRC	RRC-ERCH	245763	C
1,242	UTF -79 -79K101B	UTF-79K101B-M	Regreasing Mot BRG of 79K101B-M	PMT	4M					L			L				L	RRC	RRC-ERCH	245782	C
1,243	UTF -79 -79K102A	UTF-79K102A-K01	PM OF UTF-79K102A-K01	PMT	4M				P				P				P	RRC	RRC-MRCH	245643	C
1,244	UTF -79 -79K102A	UTF-79K102A-K01	PM INSP OF M/C NO.UTF-79K102A-K01	PMT	4M	I				I			I					RRC	RRC-MRCH	245696	C
1,245	UTF -79 -79K102A	UTF-79K102A-K01	REGREASING BRG OF UTF-79K102A-K01	PMT	4M				L				L				L	RRC	RRC-MRCH	245697	C
1,246	UTF -79 -79K102A	UTF-79K102A-M	STAND BY CHECK LV. MOT 79K102A-M	PMT	6M				T					T				RRC	RRC-ERCH	245764	C
1,247	UTF -79 -79K102A	UTF-79K102A-M	STAND BY CHECK LV. MOT 79K102A-M	PMT	6M		T						T					RRC	RRC-ERCH	245765	C
1,248	UTF -79 -79K102A	UTF-79K102A-M	Regreasing Mot BRG of 79K102A-M	PMT	4M	L				L			L				L	RRC	RRC-ERCH	245783	C
1,249	UTF -79 -79K102B	UTF-79K102B-K01	PM OF UTF-79K102B-K01	PMT	4M				P				P				P	RRC	RRC-MRCH	245644	C
1,250	UTF -79 -79K102B	UTF-79K102B-K01	PM INSP OF M/C NO.UTF-79K102B-K01	PMT	4M				I				I				I	RRC	RRC-MRCH	245698	C
1,251	UTF -79 -79K102B	UTF-79K102B-K01	REGREASING BRG OF UTF-79K102B-K01	PMT	4M				L				L				L	RRC	RRC-MRCH	245699	C
1,252	UTF -79 -79K102B	UTF-79K102B-M	STAND BY CHECK LV. MOT 79K102B-M	PMT	6M				T					T				RRC	RRC-ERCH	245766	C
1,253	UTF -79 -79K102B	UTF-79K102B-M	Regreasing Mot BRG of 79K102B-M	PMT	4M					L			L				L	RRC	RRC-ERCH	245784	C
1,254	UTF -79 -79N001	UTF-79N001-M	STAND BY CHECK LV. MOT 79N001-M	PMT	1Y				T									RRC	RRC-ERCH	245799	C
1,255	UTF -79 -79N001	UTF-79N001-M	STAND BY CHECK LV. MOT 79N001-M	PMT	1Y								T					RRC	RRC-ERCH	245800	C
1,256	UTF -79 -79N001	UTF-79N001-N01	PM OF UTF-79N001-N01	PMT	4M			P			P				P			RRC	RRC-MRCH	245645	C
1,257	UTF -79 -79N001	UTF-79N001-N01	PM INSP OF M/C NO.UTF-79N001-N01	PMT	4M	I				I			I					RRC	RRC-MRCH	245700	C
1,258	UTF -79 -79R002	UTF-79N002A-M	STAND BY CHECK LV. MOT 79N002A-M	PMT	1Y				T									RRC	RRC-ERCH	245801	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,259	UTF -79 -79R002	UTF-79N002A-M	STAND BY CHECK LV. MOT 79N002A-M	PMT	1Y								T					RRC	RRC-ERCH	245802	C
1,260	UTF -79 -79R002	UTF-79N002A-N01	PM OF UTF-79N002A-N01	PMT	4M				P				P				P	RRC	RRC-MRCH	245646	C
1,261	UTF -79 -79R002	UTF-79N002A-N01	PM INSP OF M/C NO.UTF-79N002A-N01	PMT	4M	I				I				I				RRC	RRC-MRCH	245701	C
1,262	UTF -79 -79R002	UTF-79N002B-M	STAND BY CHECK LV. MOT 79N002B-M	PMT	1Y				T									RRC	RRC-ERCH	245803	C
1,263	UTF -79 -79R002	UTF-79N002B-M	STAND BY CHECK LV. MOT 79N002B-M	PMT	1Y								T					RRC	RRC-ERCH	245804	C
1,264	UTF -79 -79R002	UTF-79N002B-N01	PM OF UTF-79N002B-N01	PMT	4M				P				P				P	RRC	RRC-MRCH	245647	C
1,265	UTF -79 -79R002	UTF-79N002B-N01	PM INSP OF M/C NO.UTF-79N002B-N01	PMT	4M	I				I				I				RRC	RRC-MRCH	245702	C
1,266	UTF -79 -79T003	UTF-79N003-M	STAND BY CHECK LV. MOT 79N003-M	PMT	1Y				T									RRC	RRC-ERCH	245805	C
1,267	UTF -79 -79T003	UTF-79N003-M	STAND BY CHECK LV. MOT 79N003-M	PMT	1Y								T					RRC	RRC-ERCH	245806	C
1,268	UTF -79 -79N004	UTF-79N004	PM OF UTF-79N004	PMT	4M			P				P				P		RRC	RRC-MRCH	245648	C
1,269	UTF -79 -79N004	UTF-79N004	PM INSP OF M/C NO.UTF-79N004	PMT	4M	I				I				I				RRC	RRC-MRCH	245703	C
1,270	UTF -79 -79N005	UTF-79N005	PM OF UTF-79N005	PMT	4M			P				P				P		RRC	RRC-MRCH	245649	C
1,271	UTF -79 -79N005	UTF-79N005	PM INSP OF M/C NO.UTF-79N005	PMT	4M	I				I				I				RRC	RRC-MRCH	245704	C
1,272	UTF -79 -79P001	UTF-79P001-P01	VB. INSP & ANALY M/C 79P001	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130536	B
1,273	UTF -79 -79P001	UTF-79P001-P01	PM INSP OF M/C NO.UTF-79P001-P01	PMT	4M	I				I				I				RRC	RRC-MRCH	129937	B
1,274	UTF -79 -79P001	UTF-79P001-P01	PM OF 79P001	PMT	4M		P				P				P			RRC	RRC-MRCH	130914	B
1,275	UTF -79 -79P002	UTF-79P002-M	STAND BY CHECK LV. MOT 79P002-M	PMT	6M			T						T				RRC	RRC-ERCH	139374	B
1,276	UTF -79 -79P002	UTF-79P002-P01	VB. INSP & ANALY M/C 79P002	INT	1M	I	I	I	I	I	I	I	I	I	I	I	I	IRI	IRI-INVB	130537	B
1,277	UTF -79 -79P002	UTF-79P002-P01	PM INSP OF M/C NO.UTF-79P002-P01	PMT	4M	I				I				I				RRC	RRC-MRCH	129938	B
1,278	UTF -79 -79P002	UTF-79P002-P01	PM OF 79P002	PMT	4M		P				P				P			RRC	RRC-MRCH	130915	B
1,279	UTF -79 -79P002	UTF-79P002-P01	PM OF UTF-79P002-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	245650	B
1,280	UTF -79 -79P002	UTF-79P002-P01	REGREASING BRG OF UTF-79P002-P01	PMT	4M			L				L				L		RRC	RRC-MRCH	245705	B
1,281	UTF -79 -79P003A	UTF-79P003A-M	STAND BY CHECK LV. MOT 79P003A-M	PMT	1Y				T									RRC	RRC-ERCH	245807	C
1,282	UTF -79 -79P003A	UTF-79P003A-M	STAND BY CHECK LV. MOT 79P003A-M	PMT	1Y								T					RRC	RRC-ERCH	245808	C
1,283	UTF -79 -79P003A	UTF-79P003A-P01	PM OF UTF-79P003A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	245651	C
1,284	UTF -79 -79P003A	UTF-79P003A-P01	PM INSP OF M/C NO.UTF-79P003A-P01	PMT	4M	I				I				I				RRC	RRC-MRCH	245706	C
1,285	UTF -79 -79P003B	UTF-79P003B-M	STAND BY CHECK LV. MOT 79P003B-M	PMT	6M			T						T				RRC	RRC-ERCH	245768	C
1,286	UTF -79 -79P003B	UTF-79P003B-P01	PM OF UTF-79P003B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	245652	C
1,287	UTF -79 -79P003B	UTF-79P003B-P01	PM INSP OF M/C NO.UTF-79P003B-P01	PMT	4M				I				I				I	RRC	RRC-MRCH	245707	C
1,288	UTF -79 -79P004A	UTF-79P004A-M	STAND BY CHECK LV. MOT 79P004A-M	PMT	1Y				T									RRC	RRC-ERCH	245809	C
1,289	UTF -79 -79P004A	UTF-79P004A-M	STAND BY CHECK LV. MOT 79P004A-M	PMT	1Y								T					RRC	RRC-ERCH	245810	C
1,290	UTF -79 -79P004A	UTF-79P004A-P01	PM OF UTF-79P004A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	245653	C
1,291	UTF -79 -79P004A	UTF-79P004A-P01	PM INSP OF M/C NO.UTF-79P004A-P01	PMT	4M	I				I				I				RRC	RRC-MRCH	245708	C
1,292	UTF -79 -79P004B	UTF-79P004B-M	STAND BY CHECK LV. MOT 79P004B-M	PMT	6M			T						T				RRC	RRC-ERCH	245769	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,293	UTF -79 -79P004B	UTF-79P004B-P01	PM OF UTF-79P004B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	245654	C
1,294	UTF -79 -79P004B	UTF-79P004B-P01	PM INSP OF M/C NO.UTF-79P004B-P01	PMT	4M				I				I				I	RRC	RRC-MRCH	245709	C
1,295	UTF -79 -79P005A	UTF-79P005A-M	STAND BY CHECK LV. MOT 79P005A-M	PMT	1Y				T									RRC	RRC-ERCH	245811	C
1,296	UTF -79 -79P005A	UTF-79P005A-M	STAND BY CHECK LV. MOT 79P005A-M	PMT	1Y								T					RRC	RRC-ERCH	245812	C
1,297	UTF -79 -79P005A	UTF-79P005A-P01	PM OF UTF-79P005A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	245655	C
1,298	UTF -79 -79P005A	UTF-79P005A-P01	PM INSP OF M/C NO.UTF-79P005A-P01	PMT	4M	I				I				I				RRC	RRC-MRCH	245710	C
1,299	UTF -79 -79P005B	UTF-79P005B-M	STAND BY CHECK LV. MOT 79P005B-M	PMT	6M			T					T					RRC	RRC-ERCH	245770	C
1,300	UTF -79 -79P005B	UTF-79P005B-P01	PM OF UTF-79P005B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	245656	C
1,301	UTF -79 -79P005B	UTF-79P005B-P01	PM INSP OF M/C NO.UTF-79P005B-P01	PMT	4M				I				I				I	RRC	RRC-MRCH	245711	C
1,302	UTF -79 -79P006A	UTF-79P006A-M	STAND BY CHECK LV. MOT 79P006A-M	PMT	1Y				T									RRC	RRC-ERCH	245813	C
1,303	UTF -79 -79P006A	UTF-79P006A-M	STAND BY CHECK LV. MOT 79P006A-M	PMT	1Y								T					RRC	RRC-ERCH	245814	C
1,304	UTF -79 -79P006A	UTF-79P006A-P01	PM OF UTF-79P006A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	245657	C
1,305	UTF -79 -79P006A	UTF-79P006A-P01	PM INSP OF M/C NO.UTF-79P006A-P01	PMT	4M	I				I				I				RRC	RRC-MRCH	245712	C
1,306	UTF -79 -79P006B	UTF-79P006B-M	STAND BY CHECK LV. MOT 79P006B-M	PMT	6M			T					T					RRC	RRC-ERCH	245771	C
1,307	UTF -79 -79P006B	UTF-79P006B-P01	PM OF UTF-79P006B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	245658	C
1,308	UTF -79 -79P006B	UTF-79P006B-P01	PM INSP OF M/C NO.UTF-79P006B-P01	PMT	4M				I				I				I	RRC	RRC-MRCH	245713	C
1,309	UTF -79 -79P007A	UTF-79P007A-M	STAND BY CHECK LV. MOT 79P007A-M	PMT	1Y				T									RRC	RRC-ERCH	245815	C
1,310	UTF -79 -79P007A	UTF-79P007A-M	STAND BY CHECK LV. MOT 79P007A-M	PMT	1Y								T					RRC	RRC-ERCH	245816	C
1,311	UTF -79 -79P007A	UTF-79P007A-P01	PM OF UTF-79P007A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	245659	C
1,312	UTF -79 -79P007A	UTF-79P007A-P01	PM INSP OF M/C NO.UTF-79P007A-P01	PMT	4M	I				I				I				RRC	RRC-MRCH	245714	C
1,313	UTF -79 -79P007B	UTF-79P007B-M	STAND BY CHECK LV. MOT 79P007B-M	PMT	6M			T					T					RRC	RRC-ERCH	245772	C
1,314	UTF -79 -79P007B	UTF-79P007B-P01	PM OF UTF-79P007B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	245660	C
1,315	UTF -79 -79P007B	UTF-79P007B-P01	PM INSP OF M/C NO.UTF-79P007B-P01	PMT	4M				I				I				I	RRC	RRC-MRCH	245715	C
1,316	UTF -79 -79P008A	UTF-79P008A-M	Regreasing Mot BRG of 79P008A-M	PMT	4M	L				L				L				RRC	RRC-ERCH	245789	C
1,317	UTF -79 -79P008A	UTF-79P008A-M	STAND BY CHECK LV. MOT 79P008A-M	PMT	1Y				T									RRC	RRC-ERCH	245817	C
1,318	UTF -79 -79P008A	UTF-79P008A-M	STAND BY CHECK LV. MOT 79P008A-M	PMT	1Y								T					RRC	RRC-ERCH	245818	C
1,319	UTF -79 -79P008A	UTF-79P008A-P01	PM OF UTF-79P008A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	245661	C
1,320	UTF -79 -79P008A	UTF-79P008A-P01	PM INSP OF M/C NO.UTF-79P008A-P01	PMT	4M	I				I				I				RRC	RRC-MRCH	245716	C
1,321	UTF -79 -79P008B	UTF-79P008B-M	STAND BY CHECK LV. MOT 79P008B-M	PMT	6M			T					T					RRC	RRC-ERCH	245773	C
1,322	UTF -79 -79P008B	UTF-79P008B-M	Regreasing Mot BRG of 79P008B-M	PMT	4M				L				L				L	RRC	RRC-ERCH	245790	C
1,323	UTF -79 -79P008B	UTF-79P008B-P01	PM OF UTF-79P008B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	245662	C
1,324	UTF -79 -79P008B	UTF-79P008B-P01	PM INSP OF M/C NO.UTF-79P008B-P01	PMT	4M				I				I				I	RRC	RRC-MRCH	245717	C
1,325	UTF -79 -79P009A	UTF-79P009A-M	STAND BY CHECK LV. MOT 79P009A-M	PMT	1Y				T									RRC	RRC-ERCH	245819	C
1,326	UTF -79 -79P009A	UTF-79P009A-M	STAND BY CHECK LV. MOT 79P009A-M	PMT	1Y								T					RRC	RRC-ERCH	245820	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,327	UTF -79 -79P009A	UTF-79P009A-P01	PM OF UTF-79P009A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	245663	C
1,328	UTF -79 -79P009A	UTF-79P009A-P01	PM INSP OF M/C NO.UTF-79P009A-P01	PMT	4M	I				I				I				RRC	RRC-MRCH	245718	C
1,329	UTF -79 -79P009B	UTF-79P009B-M	STAND BY CHECK LV. MOT 79P009B-M	PMT	6M			T						T				RRC	RRC-ERCH	245774	C
1,330	UTF -79 -79P009B	UTF-79P009B-P01	PM OF UTF-79P009B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	245664	C
1,331	UTF -79 -79P009B	UTF-79P009B-P01	PM INSP OF M/C NO.UTF-79P009B-P01	PMT	4M				I				I				I	RRC	RRC-MRCH	245719	C
1,332	UTF -79 -79P010A	UTF-79P010A-M	STAND BY CHECK LV. MOT 79P010A-M	PMT	1Y				T									RRC	RRC-ERCH	245821	C
1,333	UTF -79 -79P010A	UTF-79P010A-M	STAND BY CHECK LV. MOT 79P010A-M	PMT	1Y								T					RRC	RRC-ERCH	245822	C
1,334	UTF -79 -79P010A	UTF-79P010A-P01	PM OF UTF-79P010A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	245665	C
1,335	UTF -79 -79P010A	UTF-79P010A-P01	PM INSP OF M/C NO.UTF-79P010A-P01	PMT	4M	I				I				I				RRC	RRC-MRCH	245720	C
1,336	UTF -79 -79P010B	UTF-79P010B-M	STAND BY CHECK LV. MOT 79P010B-M	PMT	6M			T						T				RRC	RRC-ERCH	245775	C
1,337	UTF -79 -79P010B	UTF-79P010B-P01	PM OF UTF-79P010B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	245666	C
1,338	UTF -79 -79P010B	UTF-79P010B-P01	PM INSP OF M/C NO.UTF-79P010B-P01	PMT	4M				I				I				I	RRC	RRC-MRCH	245721	C
1,339	UTF -79 -79D004	UTF-79P011-M	Regreasing Mot BRG of 79P011-M	PMT	4M	L				L				L				RRC	RRC-ERCH	245791	C
1,340	UTF -79 -79D004	UTF-79P011-M	STAND BY CHECK LV. MOT 79P011-M	PMT	1Y				T									RRC	RRC-ERCH	245823	C
1,341	UTF -79 -79D004	UTF-79P011-M	STAND BY CHECK LV. MOT 79P011-M	PMT	1Y								T					RRC	RRC-ERCH	245824	C
1,342	UTF -79 -79D004	UTF-79P011-P01	PM OF UTF-79P011-P01	PMT	4M		P				P				P			RRC	RRC-MRCH	245667	C
1,343	UTF -79 -79D004	UTF-79P011-P01	PM INSP OF M/C NO.UTF-79P011-P01	PMT	4M			I				I				I		RRC	RRC-MRCH	245722	C
1,344	UTF -79 -79P012	UTF-79P012-P01	PM INSP OF M/C NO.UTF-79P012-P01	PMT	4M			I				I				I		RRC	RRC-MRCH	245723	C
1,345	UTF -79 -79P013	UTF-79P013-M	STAND BY CHECK LV. MOT 79P013-M	PMT	1Y				T									RRC	RRC-ERCH	245825	C
1,346	UTF -79 -79P013	UTF-79P013-M	STAND BY CHECK LV. MOT 79P013-M	PMT	1Y								T					RRC	RRC-ERCH	245826	C
1,347	UTF -79 -79P013	UTF-79P013-P01	PM OF UTF-79P013-P01	PMT	4M		P				P				P			RRC	RRC-MRCH	245668	C
1,348	UTF -79 -79P013	UTF-79P013-P01	PM INSP OF M/C NO.UTF-79P013-P01	PMT	4M			I				I				I		RRC	RRC-MRCH	245724	C
1,349	UTF -79 -79P014	UTF-79P014-P01	PM INSP OF M/C NO.UTF-79P014-P01	PMT	4M			I				I				I		RRC	RRC-MRCH	245725	C
1,350	UTF -79 -79P101A	UTF-79P101A-M	STAND BY CHECK LV. MOT 79P101A-M	PMT	1Y				T									RRC	RRC-ERCH	245827	C
1,351	UTF -79 -79P101A	UTF-79P101A-M	STAND BY CHECK LV. MOT 79P101A-M	PMT	1Y								T					RRC	RRC-ERCH	245828	C
1,352	UTF -79 -79P101A	UTF-79P101A-P01	PM OF UTF-79P101A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	245669	C
1,353	UTF -79 -79P101A	UTF-79P101A-P01	PM INSP OF M/C NO.UTF-79P101A-P01	PMT	4M	I				I				I				RRC	RRC-MRCH	245726	C
1,354	UTF -79 -79P101B	UTF-79P101B-M	STAND BY CHECK LV. MOT 79P101B-M	PMT	6M			T						T				RRC	RRC-ERCH	245776	C
1,355	UTF -79 -79P101B	UTF-79P101B-P01	PM OF UTF-79P101B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	245670	C
1,356	UTF -79 -79P101B	UTF-79P101B-P01	PM INSP OF M/C NO.UTF-79P101B-P01	PMT	4M				I				I				I	RRC	RRC-MRCH	245727	C
1,357	UTF -79 -79P102A	UTF-79P102A-M	STAND BY CHECK LV. MOT 79P102A-M	PMT	1Y			T										RRC	RRC-ERCH	245829	C
1,358	UTF -79 -79P102A	UTF-79P102A-M	STAND BY CHECK LV. MOT 79P102A-M	PMT	1Y								T					RRC	RRC-ERCH	245830	C
1,359	UTF -79 -79P102A	UTF-79P102A-P01	PM OF UTF-79P102A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	245671	C
1,360	UTF -79 -79P102A	UTF-79P102A-P01	PM INSP OF M/C NO.UTF-79P102A-P01	PMT	4M	I				I				I				RRC	RRC-MRCH	245728	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,361	UTF -79 -79P102B	UTF-79P102B-M	STAND BY CHECK LV. MOT 79P102B-M	PMT	6M			T					T					RRC	RRC-ERCH	245777	C
1,362	UTF -79 -79P102B	UTF-79P102B-P01	PM OF UTF-79P102B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	245672	C
1,363	UTF -79 -79P102B	UTF-79P102B-P01	PM INSP OF M/C NO.UTF-79P102B-P01	PMT	4M				I				I				I	RRC	RRC-MRCH	245729	C
1,364	UTF -79 -79P103A	UTF-79P103A-M	STAND BY CHECK LV. MOT 79P103A-M	PMT	1Y				T									RRC	RRC-ERCH	245831	C
1,365	UTF -79 -79P103A	UTF-79P103A-M	STAND BY CHECK LV. MOT 79P103A-M	PMT	1Y								T					RRC	RRC-ERCH	245832	C
1,366	UTF -79 -79P103A	UTF-79P103A-P01	PM OF UTF-79P103A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	245673	C
1,367	UTF -79 -79P103A	UTF-79P103A-P01	PM INSP OF M/C NO.UTF-79P103A-P01	PMT	4M	I				I				I				RRC	RRC-MRCH	245730	C
1,368	UTF -79 -79P103B	UTF-79P103B-M	STAND BY CHECK LV. MOT 79P103B-M	PMT	6M			T					T					RRC	RRC-ERCH	245778	C
1,369	UTF -79 -79P103B	UTF-79P103B-P01	PM OF UTF-79P103B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	245674	C
1,370	UTF -79 -79P103B	UTF-79P103B-P01	PM INSP OF M/C NO.UTF-79P103B-P01	PMT	4M				I				I				I	RRC	RRC-MRCH	245731	C
1,371	UTF -79 -79P105A	UTF-79P105A-M	Regreasing Mot BRG of 79P105A-M	PMT	4M	L				L				L				RRC	RRC-ERCH	245792	C
1,372	UTF -79 -79P105A	UTF-79P105A-M	STAND BY CHECK LV. MOT 79P105A-M	PMT	1Y				T									RRC	RRC-ERCH	245833	C
1,373	UTF -79 -79P105A	UTF-79P105A-M	STAND BY CHECK LV. MOT 79P105A-M	PMT	1Y								T					RRC	RRC-ERCH	245834	C
1,374	UTF -79 -79P105A	UTF-79P105A-P01	PM OF UTF-79P105A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	245675	C
1,375	UTF -79 -79P105A	UTF-79P105A-P01	PM INSP OF M/C NO.UTF-79P105A-P01	PMT	4M	I				I				I				RRC	RRC-MRCH	245732	C
1,376	UTF -79 -79P105B	UTF-79P105B-M	STAND BY CHECK LV. MOT 79P105B-M	PMT	6M			T					T					RRC	RRC-ERCH	245779	C
1,377	UTF -79 -79P105B	UTF-79P105B-M	Regreasing Mot BRG of 79P105B-M	PMT	4M				L				L				L	RRC	RRC-ERCH	245793	C
1,378	UTF -79 -79P105B	UTF-79P105B-P01	PM OF UTF-79P105B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	245676	C
1,379	UTF -79 -79P105B	UTF-79P105B-P01	PM INSP OF M/C NO.UTF-79P105B-P01	PMT	4M				I				I				I	RRC	RRC-MRCH	245733	C
1,380	UTF -79 -79P106A	UTF-79P106A-P01	PM OF UTF-79P106A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	245677	C
1,381	UTF -79 -79P106A	UTF-79P106A-P01	PM INSP OF M/C NO.UTF-79P106A-P01	PMT	4M	I				I				I				RRC	RRC-MRCH	245734	C
1,382	UTF -79 -79P106B	UTF-79P106B-P01	PM OF UTF-79P106B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	245678	C
1,383	UTF -79 -79P106B	UTF-79P106B-P01	PM INSP OF M/C NO.UTF-79P106B-P01	PMT	4M				I				I				I	RRC	RRC-MRCH	245735	C
1,384	UTF -79 -79P107A	UTF-79P107A-P01	PM OF UTF-79P107A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	245679	C
1,385	UTF -79 -79P107A	UTF-79P107A-P01	PM INSP OF M/C NO.UTF-79P107A-P01	PMT	4M	I				I				I				RRC	RRC-MRCH	245736	C
1,386	UTF -79 -79P107B	UTF-79P107B-P01	PM OF UTF-79P107B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	245680	C
1,387	UTF -79 -79P107B	UTF-79P107B-P01	PM INSP OF M/C NO.UTF-79P107B-P01	PMT	4M				I				I				I	RRC	RRC-MRCH	245737	C
1,388	UTF -79 -79P108A	UTF-79P108A-M	STAND BY CHECK LV. MOT 79P108A-M	PMT	1Y				T									RRC	RRC-ERCH	245835	C
1,389	UTF -79 -79P108A	UTF-79P108A-M	STAND BY CHECK LV. MOT 79P108A-M	PMT	1Y								T					RRC	RRC-ERCH	245836	C
1,390	UTF -79 -79P108A	UTF-79P108A-P01	PM OF UTF-79P108A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	245681	C
1,391	UTF -79 -79P108A	UTF-79P108A-P01	PM INSP OF M/C NO.UTF-79P108A-P01	PMT	4M	I				I				I				RRC	RRC-MRCH	245738	C
1,392	UTF -79 -79P108B	UTF-79P108B-M	STAND BY CHECK LV. MOT 79P108B-M	PMT	6M			T					T					RRC	RRC-ERCH	245780	C
1,393	UTF -79 -79P108B	UTF-79P108B-P01	PM OF UTF-79P108B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	245682	C
1,394	UTF -79 -79P108B	UTF-79P108B-P01	PM INSP OF M/C NO.UTF-79P108B-P01	PMT	4M				I				I				I	RRC	RRC-MRCH	245739	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT : UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,395	UTF -79 -79P109A	UTF-79P109A-P01	PM OF UTF-79P109A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	245683	C
1,396	UTF -79 -79P109A	UTF-79P109A-P01	PM INSP OF M/C NO.UTF-79P109A-P01	PMT	4M	I				I				I				RRC	RRC-MRCH	245740	C
1,397	UTF -79 -79P109B	UTF-79P109B-P01	PM OF UTF-79P109B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	245684	C
1,398	UTF -79 -79P109B	UTF-79P109B-P01	PM INSP OF M/C NO.UTF-79P109B-P01	PMT	4M				I				I				I	RRC	RRC-MRCH	245741	C
1,399	UTF -79 -79P110A	UTF-79P110A-P01	PM OF UTF-79P110A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	245685	C
1,400	UTF -79 -79P110A	UTF-79P110A-P01	PM INSP OF M/C NO.UTF-79P110A-P01	PMT	4M	I				I				I				RRC	RRC-MRCH	245742	C
1,401	UTF -79 -79P110B	UTF-79P110B-P01	PM OF UTF-79P110B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	245686	C
1,402	UTF -79 -79P110B	UTF-79P110B-P01	PM INSP OF M/C NO.UTF-79P110B-P01	PMT	4M				I				I				I	RRC	RRC-MRCH	245743	C
1,403	UTF -79 -79P111A	UTF-79P111A-P01	PM OF UTF-79P111A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	245687	C
1,404	UTF -79 -79P111A	UTF-79P111A-P01	PM INSP OF M/C NO.UTF-79P111A-P01	PMT	4M	I				I				I				RRC	RRC-MRCH	245744	C
1,405	UTF -79 -79P111B	UTF-79P111B-P01	PM OF UTF-79P111B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	245688	C
1,406	UTF -79 -79P111B	UTF-79P111B-P01	PM INSP OF M/C NO.UTF-79P111B-P01	PMT	4M				I				I				I	RRC	RRC-MRCH	245745	C
1,407	UTF -79 -79P112A	UTF-79P112A-P01	PM OF UTF-79P112A-P01	PMT	4M				P				P				P	RRC	RRC-MRCH	245689	C
1,408	UTF -79 -79P112A	UTF-79P112A-P01	PM INSP OF M/C NO.UTF-79P112A-P01	PMT	4M	I				I				I				RRC	RRC-MRCH	245746	C
1,409	UTF -79 -79P112B	UTF-79P112B-P01	PM OF UTF-79P112B-P01	PMT	4M			P				P				P		RRC	RRC-MRCH	245690	C
1,410	UTF -79 -79P112B	UTF-79P112B-P01	PM INSP OF M/C NO.UTF-79P112B-P01	PMT	4M				I				I				I	RRC	RRC-MRCH	245747	C
1,411	UTF -79 -79T003	UTF-79TN003-N01	PM OF UTF-79TN003-N01	PMT	4M		P				P				P			RRC	RRC-MRCH	245691	C
1,412	UTF -79 -79T003	UTF-79TN003-N01	PM INSP OF M/C NO.UTF-79TN003-N01	PMT	4M			I				I				I		RRC	RRC-MRCH	245748	C
1,413	UTF -79 -79X001	UTF-79X001-PLC	INSPECT PLC SYSTEM	PMT	3M		I			I			I			I		CCS	CCS-SYS	246508	A
1,414	UTF -79 -79X001	UTF-79X001-PLC	BACKUP PLC SYSTEM	PMT	6M		I						I					CCS	CCS-SYS	246509	A
1,415	UTF -80 -80X001	UTF-80X001-A02	PM TURBINE MAIN GEAR NO.UTF-80	PMT	1Y											I		CRE	CRE-CHIP	255633	C
1,416	UTF -80 -80X001	UTF-80X001-F02	PM;#Change#Filter#UTF-80X001-F02	PMT	1Y									P				RRC	RRC-MRCH	258073	C
1,417	UTF -80 -80X001	UTF-80X001-K01	PM TURBINE DRIVE NO.UTF-80X001	PMT	1Y											I		CRE	CRE-CHIP	255634	C
1,418	UTF -80 -80X001	UTF-80X001-K02	PM INSP OF M/C NO. UTF-80X001-	PMT	1Y							I						RRC	RRC-MRCH	255604	C
1,419	UTF -80 -80X001	UTF-80X001-K02-M	STAND BY CHECK LV.UTF-80X001-K	PMT	6M	T						T						RRC	RRC-ERCH	255504	C
1,420	UTF -80 -80X001	UTF-80X001-P01	PM INSP OF M/C NO. UTF-80X001-	PMT	1Y							I						RRC	RRC-MRCH	255605	C
1,421	UTF -80 -80X001	UTF-80X001-P01-M	STAND BY CHECK LV.UTF-80X001-P	PMT	6M	T						T						RRC	RRC-ERCH	255505	C
1,422	UTF -80 -80X001	UTF-80X001-P02	PM INSP OF M/C NO. UTF-80X001-	PMT	1Y							I						RRC	RRC-MRCH	255606	C
1,423	UTF -80 -80X001	UTF-80X001-P02-M	STAND BY CHECK LV.UTF-80X001-P	PMT	6M	T						T						RRC	RRC-ERCH	255506	C
1,424	UTF -80 -80X001	UTF-80X001-P03	PM INSP OF M/C NO. UTF-80X001-	PMT	1Y							I						RRC	RRC-MRCH	255607	C
1,425	UTF -80 -80X001	UTF-80X001-P04A	PM INSP OF M/C NO. UTF-80X001-	PMT	1Y							I						RRC	RRC-MRCH	255608	C
1,426	UTF -80 -80X001	UTF-80X001-P04A-M	STAND BY CHECK LV.UTF-80X001-P	PMT	6M	T						T						RRC	RRC-ERCH	255507	C
1,427	UTF -80 -80X001	UTF-80X001-P04B	PM INSP OF M/C NO. UTF-80X001-	PMT	1Y							I						RRC	RRC-MRCH	255609	C
1,428	UTF -80 -80X001	UTF-80X001-P04B-M	STAND BY CHECK LV.UTF-80X001-P	PMT	6M	T						T						RRC	RRC-ERCH	255508	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT : UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,429	UTF -80 -80X001	UTF-80X001-P39	PM INSP OF M/C NO. UTF-80X001-	PMT	1Y							I						RRC	RRC-MRCH	255610	C
1,430	UTF -80 -80X001	UTF-80X001-P39-M	STAND BY CHECK LV.UTF-80X001-P	PMT	6M	T						T						RRC	RRC-ERCH	255509	C
1,431	UTF -80 -80X001	UTF-80X001-P40	PM INSP OF M/C NO. UTF-80X001-	PMT	1Y							I						RRC	RRC-MRCH	255611	C
1,432	UTF -80 -80X001	UTF-80X001-P40-M	STAND BY CHECK LV.UTF-80X001-P	PMT	6M	T						T						RRC	RRC-ERCH	255510	C
1,433	UTF -74 -QMI_LIQ	UTF-AT7400601	VERIFY TOTAL_HYDROCARBON AT7400601	PMT	6M						V							CAN	CAN-QUHV	140659	B
1,434	UTF -74 -QMI_LIQ	UTF-AT7450401	VERIFY PH AT7450401	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	140660	B
1,435	UTF -74 -QMI_LIQ	UTF-AT7450402	VERIFY Conductivity AT7450402	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	204779	B
1,436	UTF -74 -QMI_LIQ	UTF-AT7450403	VERIFY SILICA AT7450403	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	204782	B
1,437	UTF -74 -QMI_LIQ	UTF-AT7450501	VERIFY PH AT7450501	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	204776	B
1,438	UTF -74 -QMI_LIQ	UTF-AT7450502	VERIFY Conductivity AT7450502	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	204780	B
1,439	UTF -74 -QMI_LIQ	UTF-AT7450503	VERIFY SILICA AT7450503	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	204783	B
1,440	UTF -74 -QMI_LIQ	UTF-AT7450601	VERIFY PH AT7450601	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	204777	B
1,441	UTF -74 -QMI_LIQ	UTF-AT7450602	VERIFY Conductivity AT7450602	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	204781	B
1,442	UTF -74 -QMI_LIQ	UTF-AT7450603	SRIFY SILICA AT7450603	PMT	1M	V	V	V	V	V	V	V	V	V	V	V		CAN	CAN-QUHV	204784	B
1,443	UTF -74 -QMI_LIQ	UTF-AT7451001	VERIFY NACH AT7451001	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	204785	B
1,444	UTF -74 -QMI_LIQ	UTF-AT7451002	VERIFY H2SO4 AT7451002	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	204786	B
1,445	UTF -74 -QMI_LIQ	UTF-AT7451101	VERIFY PH AT7451101	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	204778	B
1,446	UTF -75 -QMI_LIQ	UTF-AT7500102	VERIFY TOTAL_HYDROCARBON AT7500102	PMT	6M						V							CAN	CAN-QUHV	140635	B
1,447	UTF -75 -QMI_LIQ	UTF-AT7500201	VERIFY PH AT7500201	PMT	6M						V							CAN	CAN-QUHV	140636	B
1,448	UTF -77 -QMI_LIQ	UTF-AT7701701	VERIFY PH AT7701701	PMT	6M						V							CAN	CAN-QUHV	140632	B
1,449	UTF -77 -QMI_GAS	UTF-AT7750101	VERIFY OXYGEN AT7750101	PMT	6M						V							CAN	CAN-QUHV	140633	B
1,450	UTF -77 -QMI_GAS	UTF-AT7750201	VERIFY OXYGEN AT7750201	PMT	6M						V							CAN	CAN-QUHV	140634	B
1,451	UTF -79 -QMI_LIQ	UTF-AT7900501	VERIFY NACH UTF-AT7900501	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	246030	C
1,452	UTF -79 -QMI_LIQ	UTF-AT7900801	VERIFY PH UTF-AT7900801	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	246031	C
1,453	UTF -79 -QMI_LIQ	UTF-AT7900802	VERIFY PH UTF-AT7900802	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	246032	C
1,454	UTF -79 -QMI_LIQ	UTF-AT7901101	VERIFY PH UTF-AT7901101	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	246033	C
1,455	UTF -79 -QMI_LIQ	UTF-AT7901102	VERIFY PH UTF-AT7901102	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	246034	C
1,456	UTF -79 -QMI_LIQ	UTF-AT7901201	VERIFY AZ.TRANS PH NEUT UTF-AT7901201	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	246035	C
1,457	UTF -79 -QMI_LIQ	UTF-AT7901202	VERIFY AZ.TRANS PH NEUT UTF-AT7901202	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	246036	C
1,458	UTF -79 -QMI_LIQ	UTF-AT7901203	VERIFY AZ.TRANS PH NEUT UTF-AT7901203	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	246037	C
1,459	UTF -79 -QMI_LIQ	UTF-AT7901204	VERIFY AZ.TRANS PH NEUT UTF-AT7901204	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	246038	C
1,460	UTF -79 -QMI_LIQ	UTF-AT7910101	VERIFY TDS UTF-AT7910101	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	246039	C
1,461	UTF -79 -QMI_LIQ	UTF-AT7910102	VERIFY PH UTF-AT7910102	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	246045	C
1,462	UTF -79 -QMI_LIQ	UTF-AT7910201	VERIFY DO UTF-AT7910201	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	246040	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT : UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,463	UTF -79 -QMI_LIQ	UTF-AT7910301	VERIFY COD UTF-AT7910301	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	246041	C
1,464	UTF -79 -QMI_LIQ	UTF-AT7910302	VERIFY TDS UTF-AT7910302	PMT	1M	V	V	V	V	V	V	V	V	V	V	V	V	CAN	CAN-QUHV	246042	C
1,465	UTF -ADM-CHILL	UTF-B1 -HV-801A-M	PM INSP OF M/C NO. B1-HV-801-A	PMT	4M		I				I			I				RRC	RRC-MRCH	140589	C
1,466	UTF -MSS-B2H001	UTF-B2H001-H01	OVERHEAD CRANE INSPECT & LOAD TEST_LAW	INT	6M				I						I			IRI	IRI-INSS	157593	C
1,467	UTF -CHE-DVAB501	UTF-B5DV001	TEST INFARED FIRE DETECTOR ERU-B5DV001	PMT	6M			P						P				RRC	RRC-ERCH	150120	B
1,468	UTF -CHE-DVAB501	UTF-B5DV002	TEST INFARED FIRE DETECTOR ERU-B5DV002	PMT	6M			P						P				RRC	RRC-ERCH	150121	B
1,469	UTF -CHE-DVAB501	UTF-B5DV003	TEST INFARED FIRE DETECTOR ERU-B5DV003	PMT	6M			P						P				RRC	RRC-ERCH	150122	B
1,470	UTF -STR-BUILDING	UTF-BDG-74A001	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204390	A
1,471	UTF -STR-BUILDING	UTF-BDG-74D001	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204391	A
1,472	UTF -STR-BUILDING	UTF-BDG-74E002	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204392	A
1,473	UTF -STR-BUILDING	UTF-BDG-74E004	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204393	A
1,474	UTF -STR-BUILDING	UTF-BDG-75D001A	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204394	A
1,475	UTF -STR-BUILDING	UTF-BDG-75D001B	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204395	A
1,476	UTF -STR-BUILDING	UTF-BDG-75D001C	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204396	A
1,477	UTF -STR-BUILDING	UTF-BDG-75D001D	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204397	A
1,478	UTF -STR-BUILDING	UTF-BDG-75D001E	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204398	A
1,479	UTF -STR-BUILDING	UTF-BDG-75D001F	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204399	A
1,480	UTF -STR-BUILDING	UTF-BDG-75X001-CL	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204400	A
1,481	UTF -STR-BUILDING	UTF-BDG-77D101	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204401	A
1,482	UTF -STR-BUILDING	UTF-BDG-77D102	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204402	A
1,483	UTF -STR-BUILDING	UTF-BDG-77D104	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204403	A
1,484	UTF -STR-BUILDING	UTF-BDG-77D105	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204404	A
1,485	UTF -STR-BUILDING	UTF-BDG-77D107	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204405	A
1,486	UTF -STR-BUILDING	UTF-BDG-77D109	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204406	A
1,487	UTF -STR-BUILDING	UTF-BDG-77D110	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204407	A
1,488	UTF -STR-BUILDING	UTF-BDG-77D111	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204408	A
1,489	UTF -STR-BUILDING	UTF-BDG-77E101A	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204409	A
1,490	UTF -STR-BUILDING	UTF-BDG-77E101B	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204410	A
1,491	UTF -STR-BUILDING	UTF-BDG-77E102	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204411	A
1,492	UTF -STR-BUILDING	UTF-BDG-77E103A	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204412	A
1,493	UTF -STR-BUILDING	UTF-BDG-77E103B	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204413	A
1,494	UTF -STR-BUILDING	UTF-BDG-77E104A	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204414	A
1,495	UTF -STR-BUILDING	UTF-BDG-77E104B	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204415	A
1,496	UTF -STR-BUILDING	UTF-BDG-77E105	INSPECTION BUILDING FOR RCHU	INT	6Y					I								ENE	ENE-ENDS	204416	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT : UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,497	UTF -01 -DCS	UTF-DCS	INSPECT DCS SYSTEM	PMT	3M		I						I			I		CCS	CCS-SYS	246495	A
1,498	UTF -01 -DCS	UTF-DCS	BACKUP DCS SYSTEM	PMT	6M		I						I					CCS	CCS-SYS	246496	A
1,499	UTF -01 -DCS	UTF-DCS	UPDATE ANTIVIRUS DCS SYSTEM	PMT	3M		U				U		U			U		CCS	CCS-SYS	246497	A
1,500	UTF -74 -FIRE_ALARM	UTF-FA-MCP-74	PM F/A PUSH BUTTON (###) (UNIT 74)	PMT	3M		P				P		P			P		RRC	RRC-ERCH	140390	A
1,501	UTF -75 -FIRE_ALARM	UTF-FA-MCP-75	PM F/A PUSH BUTTON (###) (UNIT 75)	PMT	3M		P				P		P			P		RRC	RRC-ERCH	140391	A
1,502	UTF -77 -FIRE_ALARM	UTF-FA-MCP-77	PM F/A PUSH BUTTON (###) (UNIT 77)	PMT	3M		P				P		P			P		RRC	RRC-ERCH	140393	A
1,503	UTF -78 -FIRE_ALARM	UTF-FA-MCP-78	PM F/A PUSH BUTTON (###) (UNIT 78)	PMT	3M		P				P		P			P		RRC	RRC-ERCH	140394	A
1,504	UTF -79 -FIRE_ALARM	UTF-FA-MCP-79	PM F/A PUSH BUTTON (###) (UNIT 79)	PMT	3M		P				P		P			P		RRC	RRC-ERCH	245794	A
1,505	UTF -01 -FGS	UTF-FGS	INSPECT FGS SYSTEM	PMT	3M		I				I		I			I		CCS	CCS-SYS	246501	A
1,506	UTF -01 -FGS	UTF-FGS	BACKUP FGS SYSTEM	PMT	6M		I						I					CCS	CCS-SYS	246502	A
1,507	UTF -01 -FGS	UTF-FGS	UPDATE ANTIVIRUS FGS SYSTEM	PMT	3M		U				U		U			U		CCS	CCS-SYS	246503	A
1,508	UTF -80 -80X001	UTF-FIT8050801	INSP. FIELD INST.UTF-FIT805080	PMT	1Y							I						RRC	RRC-IRCH	255612	C
1,509	UTF -80 -80X001	UTF-FSL8050310	INSP. FIELD INST.UTF-FSL805031	PMT	1Y							I						RRC	RRC-IRCH	255613	C
1,510	UTF -80 -80X001	UTF-FSL8050312	INSP. FIELD INST.UTF-FSL805031	PMT	1Y							I						RRC	RRC-IRCH	255614	C
1,511	UTF -01 -FLOW	UTF-FT0103501	INSP. FIELD INST. (ห้องปกติ)	PMT	1Y	I												RRC	RRC-IRCH	137405	C
1,512	UTF -01 -FLOW	UTF-FT0103502	INSP. FIELD INST. (ห้องปกติ)	PMT	1Y	I												RRC	RRC-IRCH	137406	C
1,513	UTF -01 -FLOW	UTF-FT0103504	INSP. FIELD INST. (ห้องปกติ)	PMT	1Y	I												RRC	RRC-IRCH	137407	C
1,514	UTF -01 -FLOW	UTF-FT0103505	INSP. FIELD INST. (ห้องปกติ)	PMT	1Y	I												RRC	RRC-IRCH	137408	C
1,515	UTF -01 -FLOW	UTF-FT0103506	INSP. FIELD INST. (ห้องปกติ)	PMT	1Y	I												RRC	RRC-IRCH	137409	C
1,516	UTF -01 -FLOW	UTF-FT0103507	INSP. FIELD INST. (ห้องปกติ)	PMT	1Y	I												RRC	RRC-IRCH	137410	C
1,517	UTF -01 -FLOW	UTF-FT0103508	INSP. FIELD INST. (ห้องปกติ)	PMT	1Y	I												RRC	RRC-IRCH	137411	C
1,518	UTF -01 -FLOW	UTF-FT0103509	INSP. FIELD INST. (ห้องปกติ)	PMT	1Y	I												RRC	RRC-IRCH	137412	C
1,519	UTF -01 -FLOW	UTF-FT0103510	INSP. FIELD INST. (ห้องปกติ)	PMT	1Y	I												RRC	RRC-IRCH	137413	C
1,520	UTF -01 -FLOW	UTF-FT0103511	INSP. FIELD INST. (ห้องปกติ)	PMT	1Y	I												RRC	RRC-IRCH	137414	C
1,521	UTF -01 -FLOW	UTF-FT0103512	INSP. FIELD INST. (ห้องปกติ)	PMT	1Y	I												RRC	RRC-IRCH	137415	C
1,522	UTF -01 -FLOW	UTF-FT0103901	INSP. FIELD INST. (ห้องปกติ)	PMT	1Y	I												RRC	RRC-IRCH	137416	C
1,523	UTF -01 -FLOW	UTF-FT0103902	INSP. FIELD INST. (ห้องปกติ)	PMT	1Y		I											RRC	RRC-IRCH	137417	C
1,524	UTF -01 -FLOW	UTF-FT0103903	INSP. FIELD INST. (ห้องปกติ)	PMT	1Y		I											RRC	RRC-IRCH	137418	C
1,525	UTF -74 -FLOW	UTF-FT7400101	INSP. FIELD INST. (ห้องปกติ)	PMT	1Y		I											RRC	RRC-IRCH	137419	C
1,526	UTF -74 -FLOW	UTF-FT7400201	INSP. FIELD INST. (ห้องปกติ)	PMT	1Y		I											RRC	RRC-IRCH	137420	C
1,527	UTF -74 -FLOW	UTF-FT7400202	INSP. FIELD INST. (ห้องปกติ)	PMT	1Y		I											RRC	RRC-IRCH	137421	C
1,528	UTF -74 -FLOW	UTF-FT7400301	INSP. FIELD INST. (ห้องปกติ)	PMT	1Y	I												RRC	RRC-IRCH	137402	C
1,529	UTF -74 -FLOW	UTF-FT7400302	INSP. FIELD INST. (ห้องปกติ)	PMT	1Y		I											RRC	RRC-IRCH	137422	C
1,530	UTF -74 -FLOW	UTF-FT7400303	INSP. FIELD INST. (ห้องปกติ)	PMT	1Y	I												RRC	RRC-IRCH	137403	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,531	UTF -74 -FLOW	UTF-FT7400305	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137423	C
1,532	UTF -74 -FLOW	UTF-FT7400306	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137424	C
1,533	UTF -74 -FLOW	UTF-FT7400401	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137425	C
1,534	UTF -74 -FLOW	UTF-FT7400402	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137426	C
1,535	UTF -74 -FLOW	UTF-FT7400403	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137427	C
1,536	UTF -74 -FLOW	UTF-FT7400501	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137428	C
1,537	UTF -74 -FLOW	UTF-FT7400502	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137429	C
1,538	UTF -74 -FLOW	UTF-FT7400602	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137430	C
1,539	UTF -74 -FLOW	UTF-FT7400603	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137431	C
1,540	UTF -74 -FLOW	UTF-FT7400701	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137432	C
1,541	UTF -74 -FLOW	UTF-FT7400702	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137433	C
1,542	UTF -74 -FLOW	UTF-FT7400703	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137434	C
1,543	UTF -74 -FLOW	UTF-FT7431101	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137435	C
1,544	UTF -74 -FLOW	UTF-FT7431103	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137436	C
1,545	UTF -74 -FLOW	UTF-FT7432101	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137437	C
1,546	UTF -74 -FLOW	UTF-FT7432102	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137438	C
1,547	UTF -74 -FLOW	UTF-FT7433101	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137439	C
1,548	UTF -74 -FLOW	UTF-FT7435101	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137440	C
1,549	UTF -74 -FLOW	UTF-FT7436101	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137441	C
1,550	UTF -74 -FLOW	UTF-FT7437101	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137442	C
1,551	UTF -74 -74X001	UTF-FT7450101	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y				I									RRC	RRC-IRCH	137480	C
1,552	UTF -74 -74X001	UTF-FT7450201	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y				I									RRC	RRC-IRCH	137481	C
1,553	UTF -74 -74X001	UTF-FT7450301	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y				I									RRC	RRC-IRCH	137482	C
1,554	UTF -74 -74X001	UTF-FT7450401	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y				I									RRC	RRC-IRCH	137483	C
1,555	UTF -74 -74X001	UTF-FT7450501	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y				I									RRC	RRC-IRCH	137484	C
1,556	UTF -74 -74X001	UTF-FT7450601	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y				I									RRC	RRC-IRCH	137485	C
1,557	UTF -74 -74X001	UTF-FT7451001	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y				I									RRC	RRC-IRCH	137487	C
1,558	UTF -74 -74X001	UTF-FT7451002	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y				I									RRC	RRC-IRCH	137488	C
1,559	UTF -74 -74X001	UTF-FT7451101	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y				I									RRC	RRC-IRCH	137486	C
1,560	UTF -75 -FLOW	UTF-FT7500101	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	137443	C
1,561	UTF -75 -FLOW	UTF-FT7500202	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137444	C
1,562	UTF -75 -FLOW	UTF-FT7500203	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137445	C
1,563	UTF -75 -FLOW	UTF-FT7500204	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137446	C
1,564	UTF -77 -FLOW	UTF-FT7700201	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137447	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,565	UTF -77 -FLOW	UTF-FT7700202	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y	I												RRC	RRC-IRCH	137404	C
1,566	UTF -77 -FLOW	UTF-FT7700501	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	137448	C
1,567	UTF -77 -FLOW	UTF-FT7700503	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	137449	C
1,568	UTF -77 -FLOW	UTF-FT7700601	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	137450	C
1,569	UTF -77 -FLOW	UTF-FT7700602	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	137451	C
1,570	UTF -77 -FLOW	UTF-FT7700901	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	137452	C
1,571	UTF -77 -FLOW	UTF-FT7701101	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	137453	C
1,572	UTF -77 -FLOW	UTF-FT7701102	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	137454	C
1,573	UTF -77 -FLOW	UTF-FT7701103	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	137455	C
1,574	UTF -77 -FLOW	UTF-FT7701104	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	137456	C
1,575	UTF -77 -FLOW	UTF-FT7701301	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	137457	C
1,576	UTF -77 -FLOW	UTF-FT7701402	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	137458	C
1,577	UTF -77 -FLOW	UTF-FT7701502	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	137459	C
1,578	UTF -77 -FLOW	UTF-FT7701503	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	137460	C
1,579	UTF -77 -FLOW	UTF-FT7701601	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	137461	C
1,580	UTF -77 -FLOW	UTF-FT7701602	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y		I											RRC	RRC-IRCH	137462	C
1,581	UTF -77 -FLOW	UTF-FT7701701	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137463	C
1,582	UTF -77 -FLOW	UTF-FT7702201	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137464	C
1,583	UTF -77 -FLOW	UTF-FT7705601	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137465	C
1,584	UTF -77 -FLOW	UTF-FT7705801	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137466	C
1,585	UTF -77 -FLOW	UTF-FT7705901	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137467	C
1,586	UTF -77 -FLOW	UTF-FT7706001	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137489	C
1,587	UTF -77 -FLOW	UTF-FT7706002	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137490	C
1,588	UTF -77 -FLOW	UTF-FT7706201	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137468	C
1,589	UTF -77 -FLOW	UTF-FT7731101	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137469	C
1,590	UTF -77 -FLOW	UTF-FT7731102	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137470	C
1,591	UTF -77 -FLOW	UTF-FT7732101	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137471	C
1,592	UTF -77 -FLOW	UTF-FT7732102	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137472	C
1,593	UTF -77 -FLOW	UTF-FT7733101	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137473	C
1,594	UTF -77 -FLOW	UTF-FT7735101	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137474	C
1,595	UTF -77 -FLOW	UTF-FT7736101	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137475	C
1,596	UTF -77 -FLOW	UTF-FT7737101	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137476	C
1,597	UTF -78 -FLOW	UTF-FT7800701	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137477	C
1,598	UTF -78 -FLOW	UTF-FT7800801	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137478	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,599	UTF -78 -FLOW	UTF-FT7800901	INSP. FIELD INST. (ตรวจปกรณ์)	PMT	1Y			I										RRC	RRC-IRCH	137479	C
1,600	UTF -79 -FLOW	UTF-FT7900401	INSP. FIELD INST.FT7900401	PMT	1Y		I											RRC	RRC-IRCH	245837	C
1,601	UTF -79 -FLOW	UTF-FT7900402	INSP. FIELD INST.FT7900402	PMT	1Y		I											RRC	RRC-IRCH	245838	C
1,602	UTF -79 -FLOW	UTF-FT7900501	INSP. FIELD INST.FT7900501	PMT	1Y		I											RRC	RRC-IRCH	245839	C
1,603	UTF -79 -FLOW	UTF-FT7900502	INSP. FIELD INST.FT7900502	PMT	1Y		I											RRC	RRC-IRCH	245840	C
1,604	UTF -79 -FLOW	UTF-FT7900503	INSP. FIELD INST.FT7900503	PMT	1Y		I											RRC	RRC-IRCH	245841	C
1,605	UTF -79 -FLOW	UTF-FT7900504	INSP. FIELD INST.FT7900504	PMT	1Y		I											RRC	RRC-IRCH	245842	C
1,606	UTF -79 -FLOW	UTF-FT7900601	INSP. FIELD INST.FT7900601	PMT	1Y		I											RRC	RRC-IRCH	245843	C
1,607	UTF -79 -FLOW	UTF-FT7900602	INSP. FIELD INST.FT7900602	PMT	1Y		I											RRC	RRC-IRCH	245844	C
1,608	UTF -79 -FLOW	UTF-FT7900701	INSP. FIELD INST.FT7900701	PMT	1Y		I											RRC	RRC-IRCH	245845	C
1,609	UTF -79 -FLOW	UTF-FT7900702	INSP. FIELD INST.FT7900702	PMT	1Y		I											RRC	RRC-IRCH	245846	C
1,610	UTF -79 -FLOW	UTF-FT7900703	INSP. FIELD INST.FT7900703	PMT	1Y		I											RRC	RRC-IRCH	245847	C
1,611	UTF -79 -FLOW	UTF-FT7900704	INSP. FIELD INST.FT7900704	PMT	1Y		I											RRC	RRC-IRCH	245848	C
1,612	UTF -79 -FLOW	UTF-FT7900801	INSP. FIELD INST.FT7900801	PMT	1Y		I											RRC	RRC-IRCH	245849	C
1,613	UTF -79 -FLOW	UTF-FT7900901	INSP. FIELD INST.FT7900901	PMT	1Y		I											RRC	RRC-IRCH	245850	C
1,614	UTF -79 -FLOW	UTF-FT7900902	INSP. FIELD INST.FT7900902	PMT	1Y		I											RRC	RRC-IRCH	245851	C
1,615	UTF -79 -FLOW	UTF-FT7900903	INSP. FIELD INST.FT7900903	PMT	1Y		I											RRC	RRC-IRCH	245852	C
1,616	UTF -79 -FLOW	UTF-FT7901101	INSP. FIELD INST.FT7901101	PMT	1Y		I											RRC	RRC-IRCH	245853	C
1,617	UTF -79 -FLOW	UTF-FT7901102	INSP. FIELD INST.FT7901102	PMT	1Y		I											RRC	RRC-IRCH	245854	C
1,618	UTF -79 -FLOW	UTF-FT7901201	INSP. FIELD INST.FT7901201	PMT	1Y			I										RRC	RRC-IRCH	245855	C
1,619	UTF -79 -FLOW	UTF-FT7901202	INSP. FIELD INST.FT7901202	PMT	1Y			I										RRC	RRC-IRCH	245856	C
1,620	UTF -79 -FLOW	UTF-FT7910101	INSP. FIELD INST.FT7910101	PMT	1Y			I										RRC	RRC-IRCH	245857	C
1,621	UTF -79 -FLOW	UTF-FT7910102	INSP. FIELD INST.FT7910102	PMT	1Y			I										RRC	RRC-IRCH	245858	C
1,622	UTF -79 -FLOW	UTF-FT7910103	INSP. FIELD INST.FT7910103	PMT	1Y			I										RRC	RRC-IRCH	245859	C
1,623	UTF -79 -FLOW	UTF-FT7910201	INSP. FIELD INST.FT7910201	PMT	1Y			I										RRC	RRC-IRCH	245860	C
1,624	UTF -79 -FLOW	UTF-FT7910202	INSP. FIELD INST.FT7910202	PMT	1Y			I										RRC	RRC-IRCH	245861	C
1,625	UTF -79 -FLOW	UTF-FT7910203	INSP. FIELD INST.FT7910203	PMT	1Y			I										RRC	RRC-IRCH	245862	C
1,626	UTF -79 -FLOW	UTF-FT7910204	INSP. FIELD INST.FT7910204	PMT	1Y			I										RRC	RRC-IRCH	245863	C
1,627	UTF -79 -FLOW	UTF-FT7910205	INSP. FIELD INST.FT7910205	PMT	1Y			I										RRC	RRC-IRCH	245864	C
1,628	UTF -79 -FLOW	UTF-FT7910301	INSP. FIELD INST.FT7910301	PMT	1Y			I										RRC	RRC-IRCH	245865	C
1,629	UTF -79 -FLOW	UTF-FT7931101	INSP. FIELD INST.FT7931101	PMT	1Y			I										RRC	RRC-IRCH	245866	C
1,630	UTF -79 -FLOW	UTF-FT7932101	INSP. FIELD INST.FT7932101	PMT	1Y			I										RRC	RRC-IRCH	245867	C
1,631	UTF -79 -FLOW	UTF-FT7932102	INSP. FIELD INST.FT7932102	PMT	1Y			I										RRC	RRC-IRCH	245868	C
1,632	UTF -79 -FLOW	UTF-FT7934101	INSP. FIELD INST.FT7934101	PMT	1Y			I										RRC	RRC-IRCH	245869	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,633	UTF -79 -FLOW	UTF-FT7935101	INSP. FIELD INST.FT7935101	PMT	1Y			I										RRC	RRC-IRCH	245870	C
1,634	UTF -79 -FLOW	UTF-FT7936101	INSP. FIELD INST.FT7936101	PMT	1Y			I										RRC	RRC-IRCH	245871	C
1,635	UTF -79 -FLOW	UTF-FT7937101	INSP. FIELD INST.FT7937101	PMT	1Y			I										RRC	RRC-IRCH	245872	C
1,636	UTF -74 -CV	UTF-FV7400201	INSPECT CONTROL VALVE NO. FV74	PMT	1Y								I					RRC	RRC-IRCH	137714	C
1,637	UTF -74 -CV	UTF-FV7400501	INSPECT CONTROL VALVE NO. FV74	PMT	1Y								I					RRC	RRC-IRCH	137715	C
1,638	UTF -74 -CV	UTF-FV7400602	INSPECT CONTROL VALVE NO. FV74	PMT	1Y								I					RRC	RRC-IRCH	137716	C
1,639	UTF -74 -CV	UTF-FV7400603	INSPECT CONTROL VALVE NO. FV74	PMT	1Y								I					RRC	RRC-IRCH	137717	C
1,640	UTF -74 -CV	UTF-FV7400702	INSPECT CONTROL VALVE NO. FV74	PMT	1Y								I					RRC	RRC-IRCH	137718	C
1,641	UTF -74 -74X001	UTF-FV7450101	INSPECT CONTROL VALVE NO. FV74	PMT	1Y											I		RRC	RRC-IRCH	137917	C
1,642	UTF -74 -74X001	UTF-FV7450201	INSPECT CONTROL VALVE NO. FV74	PMT	1Y											I		RRC	RRC-IRCH	137918	C
1,643	UTF -74 -74X001	UTF-FV7450301	INSPECT CONTROL VALVE NO. FV74	PMT	1Y											I		RRC	RRC-IRCH	137919	C
1,644	UTF -74 -74X001	UTF-FV7451001	INSPECT CONTROL VALVE NO. FV74	PMT	1Y											I		RRC	RRC-IRCH	137920	C
1,645	UTF -74 -74X001	UTF-FV7451002	INSPECT CONTROL VALVE NO. FV74	PMT	1Y											I		RRC	RRC-IRCH	137921	C
1,646	UTF -75 -CV	UTF-FV7500101	INSPECT CONTROL VALVE NO. FV75	PMT	1Y								I					RRC	RRC-IRCH	137719	C
1,647	UTF -75 -CV	UTF-FV7500202	INSPECT CONTROL VALVE NO. FV75	PMT	1Y								I					RRC	RRC-IRCH	137720	C
1,648	UTF -75 -CV	UTF-FV7500203	INSPECT CONTROL VALVE NO. FV75	PMT	1Y								I					RRC	RRC-IRCH	137721	C
1,649	UTF -77 -CV	UTF-FV7700201	INSPECT CONTROL VALVE NO. FV77	PMT	1Y								I					RRC	RRC-IRCH	137722	C
1,650	UTF -77 -CV	UTF-FV7700501	INSPECT CONTROL VALVE NO. FV77	PMT	1Y								I					RRC	RRC-IRCH	137723	C
1,651	UTF -77 -CV	UTF-FV7700503	INSPECT CONTROL VALVE NO. FV77	PMT	1Y								I					RRC	RRC-IRCH	137724	C
1,652	UTF -77 -CV	UTF-FV7700601	INSPECT CONTROL VALVE NO. FV77	PMT	1Y								I					RRC	RRC-IRCH	137725	C
1,653	UTF -77 -CV	UTF-FV7700901	INSPECT CONTROL VALVE NO. FV77	PMT	1Y								I					RRC	RRC-IRCH	137726	C
1,654	UTF -77 -CV	UTF-FV7701102	INSPECT CONTROL VALVE NO. FV77	PMT	1Y								I					RRC	RRC-IRCH	137727	C
1,655	UTF -77 -CV	UTF-FV7701103	INSPECT CONTROL VALVE NO. FV77	PMT	1Y								I					RRC	RRC-IRCH	137728	C
1,656	UTF -77 -CV	UTF-FV7701301	INSPECT CONTROL VALVE NO. FV77	PMT	1Y								I					RRC	RRC-IRCH	137729	C
1,657	UTF -77 -CV	UTF-FV7701402	INSPECT CONTROL VALVE NO. FV77	PMT	1Y								I					RRC	RRC-IRCH	137730	C
1,658	UTF -77 -CV	UTF-FV7701701	INSPECT CONTROL VALVE NO. FV77	PMT	1Y								I					RRC	RRC-IRCH	137731	C
1,659	UTF -77 -CV	UTF-FV7705601	INSPECT CONTROL VALVE NO. FV77	PMT	1Y								I					RRC	RRC-IRCH	137732	C
1,660	UTF -77 -CV	UTF-FV7705801	INSPECT CONTROL VALVE NO. FV77	PMT	1Y								I					RRC	RRC-IRCH	137733	C
1,661	UTF -77 -CV	UTF-FV7705901	INSPECT CONTROL VALVE NO. FV77	PMT	1Y								I					RRC	RRC-IRCH	137734	C
1,662	UTF -78 -CV	UTF-FV7800701	INSPECT CONTROL VALVE NO. FV78	PMT	1Y								I					RRC	RRC-IRCH	137735	C
1,663	UTF -79 -CV	UTF-FV7900501	INSPECT CONTROL VALVE NO. FV7900501	PMT	1Y										I			RRC	RRC-IRCH	245873	C
1,664	UTF -79 -CV	UTF-FV7900502	INSPECT CONTROL VALVE NO. FV7900502	PMT	1Y										I			RRC	RRC-IRCH	245874	C
1,665	UTF -79 -CV	UTF-FV7900503	INSPECT CONTROL VALVE NO. FV7900503	PMT	1Y										I			RRC	RRC-IRCH	245875	C
1,666	UTF -79 -CV	UTF-FV7900701	INSPECT CONTROL VALVE NO. FV7900701	PMT	1Y										I			RRC	RRC-IRCH	245876	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,667	UTF -79 -CV	UTF-FV7900703	INSPECT CONTROL VALVE NO. FV7900703	PMT	1Y										I			RRC	RRC-IRCH	245877	C
1,668	UTF -79 -CV	UTF-FV7900801	INSPECT CONTROL VALVE NO. FV7900801	PMT	1Y										I			RRC	RRC-IRCH	245878	C
1,669	UTF -79 -CV	UTF-FV7900901	INSPECT CONTROL VALVE NO. FV7900901	PMT	1Y										I			RRC	RRC-IRCH	245879	C
1,670	UTF -79 -CV	UTF-FV7900903	INSPECT CONTROL VALVE NO. FV7900903	PMT	1Y										I			RRC	RRC-IRCH	245880	C
1,671	UTF -79 -CV	UTF-FV7901101	INSPECT CONTROL VALVE NO. FV7901101	PMT	1Y										I			RRC	RRC-IRCH	245881	C
1,672	UTF -79 -CV	UTF-FV7901102	INSPECT CONTROL VALVE NO. FV7901102	PMT	1Y										I			RRC	RRC-IRCH	245882	C
1,673	UTF -79 -CV	UTF-FV7901201	INSPECT CONTROL VALVE NO. FV7901201	PMT	1Y										I			RRC	RRC-IRCH	245883	C
1,674	UTF -79 -CV	UTF-FV7901202	INSPECT CONTROL VALVE NO. FV7901202	PMT	1Y										I			RRC	RRC-IRCH	245884	C
1,675	UTF -79 -CV	UTF-FV7910101	INSPECT CONTROL VALVE NO. FV7910101	PMT	1Y										I			RRC	RRC-IRCH	245885	C
1,676	UTF -79 -CV	UTF-FV7910103	INSPECT CONTROL VALVE NO. FV7910103	PMT	1Y										I			RRC	RRC-IRCH	245886	C
1,677	UTF -80 -80X001	UTF-FV8050801	INSP. FIELD INST.UTF-FV8050801	PMT	1Y							I						RRC	RRC-IRCH	255615	C
1,678	UTF -74 -QMI_GD	UTF-GDT7400201	VERIFY GAS_DETECTOR GDT7400201	PMT	6M				V						V			CAN	CAN-QUHV	140637	C
1,679	UTF -74 -QMI_GD	UTF-GDT7400202	VERIFY GAS_DETECTOR GDT7400202	PMT	6M				V						V			CAN	CAN-QUHV	140638	C
1,680	UTF -74 -QMI_GD	UTF-GDT7400203	VERIFY GAS_DETECTOR GDT7400203	PMT	6M				V						V			CAN	CAN-QUHV	140639	C
1,681	UTF -74 -QMI_GD	UTF-GDT7400204	VERIFY GAS_DETECTOR GDT7400204	PMT	6M				V						V			CAN	CAN-QUHV	140640	C
1,682	UTF -74 -QMI_GD	UTF-GDT7400205	VERIFY GAS_DETECTOR GDT7400205	PMT	6M				V						V			CAN	CAN-QUHV	140641	C
1,683	UTF -74 -QMI_GD	UTF-GDT7400206	VERIFY GAS_DETECTOR GDT7400206	PMT	6M				V						V			CAN	CAN-QUHV	140642	C
1,684	UTF -74 -QMI_GD	UTF-GDT7400207	VERIFY GAS_DETECTOR GDT7400207	PMT	6M				V						V			CAN	CAN-QUHV	140643	C
1,685	UTF -74 -QMI_GD	UTF-GDT7400208	VERIFY GAS_DETECTOR GDT7400208	PMT	6M				V						V			CAN	CAN-QUHV	140644	C
1,686	UTF -74 -QMI_GD	UTF-GDT7400211	VERIFY GAS_DETECTOR GDT7400211	PMT	6M				V						V			CAN	CAN-QUHV	140645	C
1,687	UTF -74 -QMI_GD	UTF-GDT7400212	VERIFY GAS_DETECTOR GDT7400212	PMT	6M				V						V			CAN	CAN-QUHV	140646	C
1,688	UTF -74 -QMI_GD	UTF-GDT7400213	VERIFY GAS_DETECTOR GDT7400213	PMT	6M				V						V			CAN	CAN-QUHV	140647	C
1,689	UTF -74 -QMI_GD	UTF-GDT7400213	Function test GDT7400213 For HVAC	PMT	1Y										F			CAN	CAN-QUHV	156005	C
1,690	UTF -74 -QMI_GD	UTF-GDT7400214	VERIFY GAS_DETECTOR GDT7400214	PMT	6M				V						V			CAN	CAN-QUHV	140648	C
1,691	UTF -74 -QMI_GD	UTF-GDT7400214	Function test GDT7400214 For HVAC	PMT	1Y										F			CAN	CAN-QUHV	156006	C
1,692	UTF -74 -QMI_GD	UTF-GDT7400215	VERIFY GAS_DETECTOR GDT7400215	PMT	6M				V						V			CAN	CAN-QUHV	140649	C
1,693	UTF -74 -QMI_GD	UTF-GDT7400216	VERIFY GAS_DETECTOR GDT7400216	PMT	6M				V						V			CAN	CAN-QUHV	140650	C
1,694	UTF -74 -QMI_GD	UTF-GDT7400216	Function test GDT7400216 For HVAC	PMT	1Y										F			CAN	CAN-QUHV	156007	C
1,695	UTF -74 -QMI_GD	UTF-GDT7400217	VERIFY GAS_DETECTOR GDT7400217	PMT	6M				V						V			CAN	CAN-QUHV	140651	C
1,696	UTF -74 -QMI_GD	UTF-GDT7400217	Function test GDT7400217 For HVAC	PMT	1Y										F			CAN	CAN-QUHV	156008	C
1,697	UTF -74 -QMI_GD	UTF-GDT7400301	VERIFY GAS_DETECTOR GDT7400301	PMT	4M				V				V				V	CAN	CAN-QUHV	140652	C
1,698	UTF -74 -QMI_GD	UTF-GDT7400302	VERIFY GAS_DETECTOR GDT7400302	PMT	4M				V				V				V	CAN	CAN-QUHV	140653	C
1,699	UTF -74 -QMI_GD	UTF-GDT7400303	VERIFY GAS_DETECTOR GDT7400303	PMT	4M				V				V				V	CAN	CAN-QUHV	140654	C
1,700	UTF -74 -QMI_GD	UTF-GDT7400303	Function test GDT7400303 For HVAC	PMT	1Y								F					CAN	CAN-QUHV	156009	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,701	UTF -74 -QMI_GD	UTF-GDT7400304	VERIFY GAS_DETECTOR GDT7400304	PMT	4M				V				V				V	CAN	CAN-QUHV	140655	C
1,702	UTF -74 -QMI_GD	UTF-GDT7400304	Function test GDT7400304 For HVAC	PMT	1Y								F					CAN	CAN-QUHV	156010	C
1,703	UTF -74 -QMI_GD	UTF-GDT7400305	VERIFY GAS_DETECTOR GDT7400305	PMT	4M				V				V				V	CAN	CAN-QUHV	140656	C
1,704	UTF -74 -QMI_GD	UTF-GDT7400306	VERIFY GAS_DETECTOR GDT7400306	PMT	4M				V				V				V	CAN	CAN-QUHV	140657	C
1,705	UTF -74 -QMI_GD	UTF-GDT7400307	VERIFY GAS_DETECTOR GDT7400307	PMT	4M				V				V				V	CAN	CAN-QUHV	140658	C
1,706	UTF -77 -QMI_GD	UTF-GDT7700201	VERIFY GAS_DETECTOR GDT7700201	PMT	6M				V						V			CAN	CAN-QUHV	140602	C
1,707	UTF -77 -QMI_GD	UTF-GDT7700202	VERIFY GAS_DETECTOR GDT7700202	PMT	6M				V						V			CAN	CAN-QUHV	140603	C
1,708	UTF -77 -QMI_GD	UTF-GDT7700203	VERIFY GAS_DETECTOR GDT7700203	PMT	6M				V						V			CAN	CAN-QUHV	140604	C
1,709	UTF -77 -QMI_GD	UTF-GDT7700204	VERIFY GAS_DETECTOR GDT7700204	PMT	6M				V						V			CAN	CAN-QUHV	140605	C
1,710	UTF -77 -QMI_GD	UTF-GDT7700205	VERIFY GAS_DETECTOR GDT7700205	PMT	6M				V						V			CAN	CAN-QUHV	140606	C
1,711	UTF -77 -QMI_GD	UTF-GDT7700206	VERIFY GAS_DETECTOR GDT7700206	PMT	6M				V						V			CAN	CAN-QUHV	140607	C
1,712	UTF -77 -QMI_GD	UTF-GDT7700207	VERIFY GAS_DETECTOR GDT7700207	PMT	6M				V						V			CAN	CAN-QUHV	140608	C
1,713	UTF -77 -QMI_GD	UTF-GDT7700208	VERIFY GAS_DETECTOR GDT7700208	PMT	6M				V						V			CAN	CAN-QUHV	140609	C
1,714	UTF -77 -QMI_GD	UTF-GDT7700209	VERIFY GAS_DETECTOR GDT7700209	PMT	6M				V						V			CAN	CAN-QUHV	140610	C
1,715	UTF -77 -QMI_GD	UTF-GDT7700210	VERIFY GAS_DETECTOR GDT7700210	PMT	6M				V						V			CAN	CAN-QUHV	140611	C
1,716	UTF -77 -QMI_GD	UTF-GDT7700211	VERIFY GAS_DETECTOR GDT7700211	PMT	6M				V						V			CAN	CAN-QUHV	140612	C
1,717	UTF -77 -QMI_GD	UTF-GDT7700212	VERIFY GAS_DETECTOR GDT7700212	PMT	6M				V						V			CAN	CAN-QUHV	140613	C
1,718	UTF -77 -QMI_GD	UTF-GDT7700213	VERIFY GAS_DETECTOR GDT7700213	PMT	6M				V						V			CAN	CAN-QUHV	140614	C
1,719	UTF -77 -QMI_GD	UTF-GDT7700214	VERIFY GAS_DETECTOR GDT7700214	PMT	6M				V						V			CAN	CAN-QUHV	140615	C
1,720	UTF -77 -QMI_GD	UTF-GDT7700215	VERIFY GAS_DETECTOR GDT7700215	PMT	6M				V						V			CAN	CAN-QUHV	140616	C
1,721	UTF -77 -QMI_GD	UTF-GDT7700216	VERIFY GAS_DETECTOR GDT7700216	PMT	6M				V						V			CAN	CAN-QUHV	140617	C
1,722	UTF -77 -QMI_GD	UTF-GDT7700217	VERIFY GAS_DETECTOR GDT7700217	PMT	6M				V						V			CAN	CAN-QUHV	140618	C
1,723	UTF -77 -QMI_GD	UTF-GDT7700218	VERIFY GAS_DETECTOR GDT7700218	PMT	6M				V						V			CAN	CAN-QUHV	140619	C
1,724	UTF -77 -QMI_GD	UTF-GDT7700219	VERIFY GAS_DETECTOR GDT7700219	PMT	6M				V						V			CAN	CAN-QUHV	140620	C
1,725	UTF -77 -QMI_GD	UTF-GDT7700220	VERIFY GAS_DETECTOR GDT7700220	PMT	6M				V						V			CAN	CAN-QUHV	140621	C
1,726	UTF -77 -QMI_GD	UTF-GDT7700221	VERIFY GAS_DETECTOR GDT7700221	PMT	6M				V						V			CAN	CAN-QUHV	140622	C
1,727	UTF -77 -QMI_GD	UTF-GDT7700222	VERIFY GAS_DETECTOR GDT7700222	PMT	6M				V						V			CAN	CAN-QUHV	140623	C
1,728	UTF -77 -QMI_GD	UTF-GDT7700223	VERIFY GAS_DETECTOR GDT7700223	PMT	6M				V						V			CAN	CAN-QUHV	140624	C
1,729	UTF -77 -QMI_GD	UTF-GDT7700224	VERIFY GAS_DETECTOR GDT7700224	PMT	6M				V						V			CAN	CAN-QUHV	140625	C
1,730	UTF -77 -QMI_GD	UTF-GDT7700225	VERIFY GAS_DETECTOR GDT7700225	PMT	6M				V						V			CAN	CAN-QUHV	140626	C
1,731	UTF -77 -QMI_GD	UTF-GDT7700226	VERIFY GAS_DETECTOR GDT7700226	PMT	6M				V						V			CAN	CAN-QUHV	140627	C
1,732	UTF -77 -QMI_GD	UTF-GDT7700227	VERIFY GAS_DETECTOR GDT7700227	PMT	6M				V						V			CAN	CAN-QUHV	140628	C
1,733	UTF -77 -QMI_GD	UTF-GDT7700228	VERIFY GAS_DETECTOR GDT7700228	PMT	6M				V						V			CAN	CAN-QUHV	140629	C
1,734	UTF -77 -QMI_GD	UTF-GDT7700228	Function test GDT7700228 For HVAC	PMT	1Y								F					CAN	CAN-QUHV	156017	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,735	UTF -77 -QMI_GD	UTF-GDT7700229	VERIFY GAS_DETECTOR GDT7700229	PMT	6M				V									CAN	CAN-QUHV	140630	C
1,736	UTF -77 -QMI_GD	UTF-GDT7700301	VERIFY GAS_DETECTOR GDT7700301	PMT	4M				V				V				V	CAN	CAN-QUHV	140631	C
1,737	UTF -77 -QMI_GD	UTF-GDT7700301	Function test GDT7700301 For HVAC	PMT	1Y								F					CAN	CAN-QUHV	156018	C
1,738	UTF -78 -QMI_GD	UTF-GDT7800201	VERIFY GAS_DETECTOR GDT7800201	PMT	6M				V						V			CAN	CAN-QUHV	140600	C
1,739	UTF -78 -QMI_GD	UTF-GDT7800202	VERIFY GAS_DETECTOR GDT7800202	PMT	6M				V						V			CAN	CAN-QUHV	140599	C
1,740	UTF -78 -QMI_GD	UTF-GDT7800203	VERIFY GAS_DETECTOR GDT7800203	PMT	6M				V						V			CAN	CAN-QUHV	140601	C
1,741	UTF -79 -QMI_GD	UTF-GDT7900101	VERIFY GAS_DETECTOR UTF-GDT7900101	PMT	4M				V				V				V	CAN	CAN-QUHV	246043	C
1,742	UTF -79 -QMI_GD	UTF-GDT7900102	VERIFY GAS_DETECTOR UTF-GDT7900102	PMT	4M				V				V				V	CAN	CAN-QUHV	246044	C
1,743	UTF -77 -CV	UTF-HV7706201	INSPECT CONTROL VALVE NO. HV77	PMT	1Y										I			RRC	RRC-IRCH	137792	C
1,744	UTF -77 -CV	UTF-HV7706202	INSPECT CONTROL VALVE NO. HV77	PMT	1Y										I			RRC	RRC-IRCH	137793	C
1,745	UTF -77 -CV	UTF-HV7750101	INSPECT CONTROL VALVE NO. HV77	PMT	1Y								I					RRC	RRC-IRCH	137736	C
1,746	UTF -77 -CV	UTF-HV7750101	Inspection UTF-HV7750101	PMT	1Y						I							RRC	RRC-IRCH	250294	C
1,747	UTF -77 -CV	UTF-HV7750102	INSPECT CONTROL VALVE NO. HV77	PMT	1Y								I					RRC	RRC-IRCH	137737	C
1,748	UTF -77 -CV	UTF-HV7750102	Inspection UTF-HV7750102	PMT	1Y						I							RRC	RRC-IRCH	250295	C
1,749	UTF -77 -CV	UTF-HV7750103	INSPECT CONTROL VALVE NO. HV77	PMT	1Y								I					RRC	RRC-IRCH	137738	C
1,750	UTF -77 -CV	UTF-HV7750103	Inspection UTF-HV7750103	PMT	1Y						I							RRC	RRC-IRCH	250296	C
1,751	UTF -80 -80X001	UTF-KE8050601	INSPECT VIBRATION UTF-KE805060	PMT	1Y				I									RRC	RRC-IRCH	255562	C
1,752	UTF -80 -80X001	UTF-KT8050601	INSPECT VIBRATION UTF-KT805060	PMT	1Y				I									RRC	RRC-IRCH	255563	C
1,753	UTF -77 -LEVEL	UTF-LG7750101	Inspection UTF-LG7750101	PMT	1Y						I							RRC	RRC-IRCH	250301	C
1,754	UTF -77 -LEVEL	UTF-LG7750201	Inspection UTF-LG7750201	PMT	1Y						I							RRC	RRC-IRCH	250302	C
1,755	UTF -79 -79T001	UTF-LG7900401	INSP. FIELD INST.LG7900401	PMT	1Y					I								RRC	RRC-IRCH	245887	C
1,756	UTF -79 -79T004	UTF-LG7900501	INSP. FIELD INST.LG7900501	PMT	1Y					I								RRC	RRC-IRCH	245888	C
1,757	UTF -79 -79T003	UTF-LG7900602	INSP. FIELD INST.LG7900602	PMT	1Y					I								RRC	RRC-IRCH	245890	C
1,758	UTF -79 -79D002	UTF-LG7900701	INSP. FIELD INST.LG7900701	PMT	1Y					I								RRC	RRC-IRCH	245891	C
1,759	UTF -79 -79S001	UTF-LG7900901	INSP. FIELD INST.LG7900901	PMT	1Y					I								RRC	RRC-IRCH	245892	C
1,760	UTF -79 -79S001	UTF-LG7900902	INSP. FIELD INST.LG7900902	PMT	1Y					I								RRC	RRC-IRCH	245893	C
1,761	UTF -79 -79R002	UTF-LG7901001	INSP. FIELD INST.LG7901001	PMT	1Y					I								RRC	RRC-IRCH	245894	C
1,762	UTF -79 -79D003	UTF-LG7901002	INSP. FIELD INST.LG7901002	PMT	1Y					I								RRC	RRC-IRCH	245895	C
1,763	UTF -79 -79C003	UTF-LG7901301	INSP. FIELD INST.LG7901301	PMT	1Y					I								RRC	RRC-IRCH	245896	C
1,764	UTF -80 -80X001	UTF-LG8050401	INSP. FIELD INST.UTF-LG8050401	PMT	1Y							I						RRC	RRC-IRCH	255616	C
1,765	UTF -80 -80X001	UTF-LG8050802	INSP. FIELD INST.UTF-LG8050802	PMT	1Y							I						RRC	RRC-IRCH	255617	C
1,766	UTF -80 -80X001	UTF-LIS8050402	INSP. FIELD INST.UTF-LIS805040	PMT	1Y							I						RRC	RRC-IRCH	255618	C
1,767	UTF -79 -79T101	UTF-LS7910101	INSP. FIELD INST.LS7910101	PMT	1Y					I								RRC	RRC-IRCH	245897	C
1,768	UTF -79 -79T103A	UTF-LS7910202	INSP. FIELD INST.LS7910202	PMT	1Y					I								RRC	RRC-IRCH	245898	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,769	UTF -79 -79T103B	UTF-LS7910203	INSP. FIELD INST.LS7910203	PMT	1Y					I								RRC	RRC-IRCH	245899	C
1,770	UTF -79 -79T105	UTF-LS7910302	INSP. FIELD INST.LS7910302	PMT	1Y					I								RRC	RRC-IRCH	245900	C
1,771	UTF -79 -79T111	UTF-LS7910401	INSP. FIELD INST.LS7910401	PMT	1Y					I								RRC	RRC-IRCH	245901	C
1,772	UTF -80 -80X001	UTF-LSH8050305	INSP. FIELD INST.UTF-LSH805030	PMT	1Y							I						RRC	RRC-IRCH	255619	C
1,773	UTF -80 -80X001	UTF-LSH8050306	INSP. FIELD INST.UTF-LSH805030	PMT	1Y							I						RRC	RRC-IRCH	255620	C
1,774	UTF -74 -LEVEL	UTF-LT7400101	INSP. FIELD INST. (ต่ำสุด,ปกติ)	PMT	1Y					I								RRC	RRC-IRCH	137562	C
1,775	UTF -74 -LEVEL	UTF-LT7400102A	INSP. FIELD INST. (ต่ำสุด,ปกติ)	INS	1Y					I								RRC	RRC-IRCH	137563	C
1,776	UTF -74 -LEVEL	UTF-LT7400102A	LT7400102A-FULLFUN TEST LEV. R	PMT	5Y												F	RRC	RRC-IRCH	260459	C
1,777	UTF -74 -LEVEL	UTF-LT7400102B	INSP. FIELD INST. (ต่ำสุด,ปกติ)	INS	1Y					I								RRC	RRC-IRCH	137564	C
1,778	UTF -74 -LEVEL	UTF-LT7400102B	LT7400102B-FULLFUN TEST LEV. R	PMT	5Y												F	RRC	RRC-IRCH	260460	C
1,779	UTF -74 -LEVEL	UTF-LT7400102C	INSP. FIELD INST. (ต่ำสุด,ปกติ)	INS	1Y					I								RRC	RRC-IRCH	137565	C
1,780	UTF -74 -LEVEL	UTF-LT7400102C	LT7400102C-FULLFUN TEST LEV. R	PMT	5Y												F	RRC	RRC-IRCH	260461	C
1,781	UTF -74 -LEVEL	UTF-LT7400105	INSP. FIELD INST. (ต่ำสุด,ปกติ)	PMT	1Y							I						RRC	RRC-IRCH	137491	C
1,782	UTF -74 -LEVEL	UTF-LT7400401	INSP. FIELD INST. (ต่ำสุด,ปกติ)	PMT	1Y							I						RRC	RRC-IRCH	137492	C
1,783	UTF -74 -LEVEL	UTF-LT7400402	INSP. FIELD INST. (ต่ำสุด,ปกติ)	PMT	1Y							I						RRC	RRC-IRCH	137493	C
1,784	UTF -74 -LEVEL	UTF-LT7400405	INSP. FIELD INST. (ต่ำสุด,ปกติ)	PMT	1Y					I								RRC	RRC-IRCH	137566	C
1,785	UTF -74 -LEVEL	UTF-LT7400406	INSP. FIELD INST. (ต่ำสุด,ปกติ)	PMT	1Y					I								RRC	RRC-IRCH	137567	C
1,786	UTF -74 -LEVEL	UTF-LT7400501	INSP. FIELD INST. (ต่ำสุด,ปกติ)	PMT	1Y							I						RRC	RRC-IRCH	137494	C
1,787	UTF -74 -LEVEL	UTF-LT7400502	INSP. FIELD INST. (ต่ำสุด,ปกติ)	PMT	1Y					I								RRC	RRC-IRCH	137568	C
1,788	UTF -74 -LEVEL	UTF-LT7400601	INSP. FIELD INST. (ต่ำสุด,ปกติ)	INS	1Y							I						RRC	RRC-IRCH	137495	C
1,789	UTF -74 -LEVEL	UTF-LT7400601	LT7400601-FULLFUNTEST CAP&COND	PMT	5Y												F	RRC	RRC-IRCH	260410	C
1,790	UTF -74 -LEVEL	UTF-LT7400701	INSP. FIELD INST. (ต่ำสุด,ปกติ)	INS	1Y							I						RRC	RRC-IRCH	137496	C
1,791	UTF -74 -LEVEL	UTF-LT7400701	LT7400701-FULLFUNTEST CAP&COND	PMT	5Y												F	RRC	RRC-IRCH	260411	C
1,792	UTF -74 -LEVEL	UTF-LT7400702	INSP. FIELD INST. (ต่ำสุด,ปกติ)	PMT	1Y							I						RRC	RRC-IRCH	137497	C
1,793	UTF -74 -74X001	UTF-LT7450701	INSP. FIELD INST. (ต่ำสุด,ปกติ)	PMT	1Y					I								RRC	RRC-IRCH	137587	C
1,794	UTF -74 -74X001	UTF-LT7450702	INSP. FIELD INST. (ต่ำสุด,ปกติ)	PMT	1Y					I								RRC	RRC-IRCH	137588	C
1,795	UTF -74 -74X001	UTF-LT7450801	INSP. FIELD INST. (ต่ำสุด,ปกติ)	PMT	1Y					I								RRC	RRC-IRCH	137589	C
1,796	UTF -74 -74X001	UTF-LT7450901	INSP. FIELD INST. (ต่ำสุด,ปกติ)	PMT	1Y					I								RRC	RRC-IRCH	137590	C
1,797	UTF -74 -74X001	UTF-LT7451101	INSP. FIELD INST. (ต่ำสุด,ปกติ)	PMT	1Y					I								RRC	RRC-IRCH	137591	C
1,798	UTF -75 -LEVEL	UTF-LT7500101	INSP. FIELD INST. (ต่ำสุด,ปกติ)	PMT	1Y							I						RRC	RRC-IRCH	137498	C
1,799	UTF -75 -LEVEL	UTF-LT7500102A	INSP. FIELD INST. (ต่ำสุด,ปกติ)	INS	1Y							I						RRC	RRC-IRCH	137499	C
1,800	UTF -75 -LEVEL	UTF-LT7500102A	LT7500102A-FULLFUN TEST LEV. R	PMT	5Y												F	RRC	RRC-IRCH	260462	C
1,801	UTF -75 -LEVEL	UTF-LT7500102B	INSP. FIELD INST. (ต่ำสุด,ปกติ)	INS	1Y							I						RRC	RRC-IRCH	137500	C
1,802	UTF -75 -LEVEL	UTF-LT7500102B	LT7500102B-FULLFUN TEST LEV. R	PMT	5Y												F	RRC	RRC-IRCH	260463	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,803	UTF -75 -LEVEL	UTF-LT7500102C	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y			I										RRC	RRC-IROH	137501	C
1,804	UTF -75 -LEVEL	UTF-LT7500102C	LT7500102C-FULLFUN TEST LEV. R	PMT	5Y											F		RRC	RRC-IROH	260464	C
1,805	UTF -75 -75X005	UTF-LT7550901	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y					I								RRC	RRC-IROH	137586	C
1,806	UTF -77 -LEVEL	UTF-LT7700101	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137516	C
1,807	UTF -77 -LEVEL	UTF-LT7700101	LT7700101-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260465	C
1,808	UTF -77 -LEVEL	UTF-LT7700102	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IROH	137517	C
1,809	UTF -77 -LEVEL	UTF-LT7700103	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137518	C
1,810	UTF -77 -LEVEL	UTF-LT7700103	LT7700103-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260467	C
1,811	UTF -77 -LEVEL	UTF-LT7700104	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137519	C
1,812	UTF -77 -LEVEL	UTF-LT7700104	LT7700104-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260466	C
1,813	UTF -77 -LEVEL	UTF-LT7700105	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IROH	137520	C
1,814	UTF -77 -LEVEL	UTF-LT7700106	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137521	C
1,815	UTF -77 -LEVEL	UTF-LT7700106	LT7700106-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260468	C
1,816	UTF -77 -LEVEL	UTF-LT7700201	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137522	C
1,817	UTF -77 -LEVEL	UTF-LT7700201	LT7700201-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260469	C
1,818	UTF -77 -LEVEL	UTF-LT7700202	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137523	C
1,819	UTF -77 -LEVEL	UTF-LT7700202	LT7700202-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260470	C
1,820	UTF -77 -LEVEL	UTF-LT7700401	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137524	C
1,821	UTF -77 -LEVEL	UTF-LT7700401	LT7700401-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260471	C
1,822	UTF -77 -LEVEL	UTF-LT7700402	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137525	C
1,823	UTF -77 -LEVEL	UTF-LT7700402	LT7700402-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260472	C
1,824	UTF -77 -LEVEL	UTF-LT7700601	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137526	C
1,825	UTF -77 -LEVEL	UTF-LT7700601	LT7700601-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260477	C
1,826	UTF -77 -LEVEL	UTF-LT7700602	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137527	C
1,827	UTF -77 -LEVEL	UTF-LT7700602	LT7700602-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260478	C
1,828	UTF -77 -LEVEL	UTF-LT7700603	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137528	C
1,829	UTF -77 -LEVEL	UTF-LT7700603	LT7700603-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260479	C
1,830	UTF -77 -LEVEL	UTF-LT7700604	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137529	C
1,831	UTF -77 -LEVEL	UTF-LT7700604	LT7700604-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260480	C
1,832	UTF -77 -LEVEL	UTF-LT7700901	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137530	C
1,833	UTF -77 -LEVEL	UTF-LT7700901	LT7700901-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260481	C
1,834	UTF -77 -LEVEL	UTF-LT7700902	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IROH	137531	C
1,835	UTF -77 -LEVEL	UTF-LT7700903	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137532	C
1,836	UTF -77 -LEVEL	UTF-LT7700903	LT7700903-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260484	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,837	UTF -77 -LEVEL	UTF-LT7700904	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137533	C
1,838	UTF -77 -LEVEL	UTF-LT7700904	LT7700904-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260482	C
1,839	UTF -77 -LEVEL	UTF-LT7700905	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IROH	137534	C
1,840	UTF -77 -LEVEL	UTF-LT7700906	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137535	C
1,841	UTF -77 -LEVEL	UTF-LT7700906	LT7700906-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260485	C
1,842	UTF -77 -LEVEL	UTF-LT7701001	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137536	C
1,843	UTF -77 -LEVEL	UTF-LT7701001	LT7701001-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260483	C
1,844	UTF -77 -LEVEL	UTF-LT7701002	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IROH	137537	C
1,845	UTF -77 -LEVEL	UTF-LT7701003	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137538	C
1,846	UTF -77 -LEVEL	UTF-LT7701003	LT7701003-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260486	C
1,847	UTF -77 -LEVEL	UTF-LT7701101	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137539	C
1,848	UTF -77 -LEVEL	UTF-LT7701101	LT7701101-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260487	C
1,849	UTF -77 -LEVEL	UTF-LT7701102	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IROH	137540	C
1,850	UTF -77 -LEVEL	UTF-LT7701103	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IROH	137541	C
1,851	UTF -77 -LEVEL	UTF-LT7701301	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137542	C
1,852	UTF -77 -LEVEL	UTF-LT7701301	LT7701301-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260488	C
1,853	UTF -77 -LEVEL	UTF-LT7701302	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IROH	137543	C
1,854	UTF -77 -LEVEL	UTF-LT7701303	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137544	C
1,855	UTF -77 -LEVEL	UTF-LT7701303	LT7701303-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260490	C
1,856	UTF -77 -LEVEL	UTF-LT7701304	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137545	C
1,857	UTF -77 -LEVEL	UTF-LT7701304	LT7701304-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260489	C
1,858	UTF -77 -LEVEL	UTF-LT7701305	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IROH	137546	C
1,859	UTF -77 -LEVEL	UTF-LT7701306	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137547	C
1,860	UTF -77 -LEVEL	UTF-LT7701306	LT7701306-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260491	C
1,861	UTF -77 -LEVEL	UTF-LT7701401	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137548	C
1,862	UTF -77 -LEVEL	UTF-LT7701401	LT7701401-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260492	C
1,863	UTF -77 -LEVEL	UTF-LT7701402	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IROH	137549	C
1,864	UTF -77 -LEVEL	UTF-LT7701403	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137550	C
1,865	UTF -77 -LEVEL	UTF-LT7701403	LT7701403-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260493	C
1,866	UTF -77 -LEVEL	UTF-LT7701501	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IROH	137551	C
1,867	UTF -77 -LEVEL	UTF-LT7701502	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137552	C
1,868	UTF -77 -LEVEL	UTF-LT7701502	LT7701502-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260494	C
1,869	UTF -77 -LEVEL	UTF-LT7701601	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IROH	137553	C
1,870	UTF -77 -LEVEL	UTF-LT7701602	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y				I									RRC	RRC-IROH	137554	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,871	UTF -77 -LEVEL	UTF-LT7701602	LT7701602-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260495	C
1,872	UTF -77 -LEVEL	UTF-LT7701701	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y					I								RRC	RRC-IROH	137555	C
1,873	UTF -77 -LEVEL	UTF-LT7701701	LT7701701-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260496	C
1,874	UTF -77 -LEVEL	UTF-LT7701702	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y					I								RRC	RRC-IROH	137556	C
1,875	UTF -77 -LEVEL	UTF-LT7701704	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y					I								RRC	RRC-IROH	137557	C
1,876	UTF -77 -LEVEL	UTF-LT7701801	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y					I								RRC	RRC-IROH	137558	C
1,877	UTF -77 -LEVEL	UTF-LT7701801	LT7701801-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260473	C
1,878	UTF -77 -LEVEL	UTF-LT7701802	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y					I								RRC	RRC-IROH	137559	C
1,879	UTF -77 -LEVEL	UTF-LT7701802	LT7701802-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260474	C
1,880	UTF -77 -LEVEL	UTF-LT7701901	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y					I								RRC	RRC-IROH	137560	C
1,881	UTF -77 -LEVEL	UTF-LT7701901	LT7701901-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260475	C
1,882	UTF -77 -LEVEL	UTF-LT7701902	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y					I								RRC	RRC-IROH	137561	C
1,883	UTF -77 -LEVEL	UTF-LT7701902	LT7701902-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260476	C
1,884	UTF -77 -LEVEL	UTF-LT7702101	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IROH	137502	C
1,885	UTF -77 -LEVEL	UTF-LT7702102	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IROH	137503	C
1,886	UTF -77 -LEVEL	UTF-LT7705601	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y					I								RRC	RRC-IROH	137569	C
1,887	UTF -77 -LEVEL	UTF-LT7705601	LT7705601-FULLFUN TEST LEV. RA	PMT	5Y											F		RRC	RRC-IROH	260497	C
1,888	UTF -77 -LEVEL	UTF-LT7705602	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	INS	1Y			I										RRC	RRC-IROH	137504	C
1,889	UTF -77 -LEVEL	UTF-LT7705602	LT7705602-FULLFUNTEST CAP&COND	PMT	5Y											F		RRC	RRC-IROH	260412	C
1,890	UTF -77 -LEVEL	UTF-LT7705603	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y					I								RRC	RRC-IROH	137570	C
1,891	UTF -77 -LEVEL	UTF-LT7705604	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y					I								RRC	RRC-IROH	137571	C
1,892	UTF -77 -LEVEL	UTF-LT7705701	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y					I								RRC	RRC-IROH	137572	C
1,893	UTF -77 -LEVEL	UTF-LT7705702	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y					I								RRC	RRC-IROH	137573	C
1,894	UTF -77 -LEVEL	UTF-LT7705801	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y					I								RRC	RRC-IROH	137574	C
1,895	UTF -77 -LEVEL	UTF-LT7705802	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y					I								RRC	RRC-IROH	137575	C
1,896	UTF -77 -LEVEL	UTF-LT7705803	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y					I								RRC	RRC-IROH	137576	C
1,897	UTF -77 -LEVEL	UTF-LT7705804	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y					I								RRC	RRC-IROH	137577	C
1,898	UTF -77 -LEVEL	UTF-LT7705901	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y					I								RRC	RRC-IROH	137578	C
1,899	UTF -77 -LEVEL	UTF-LT7705902	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y					I								RRC	RRC-IROH	137579	C
1,900	UTF -77 -LEVEL	UTF-LT7705903	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y					I								RRC	RRC-IROH	137580	C
1,901	UTF -77 -LEVEL	UTF-LT7705904	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y					I								RRC	RRC-IROH	137581	C
1,902	UTF -77 -LEVEL	UTF-LT7706201	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y					I								RRC	RRC-IROH	137582	C
1,903	UTF -77 -LEVEL	UTF-LT7706203	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y					I								RRC	RRC-IROH	137583	C
1,904	UTF -77 -LEVEL	UTF-LT7750101	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y					I								RRC	RRC-IROH	137584	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,905	UTF -77 -LEVEL	UTF-LT7750101	Inspection UTF-LT7750101	PMT	1Y						I							RRC	RRC-IROH	250298	C
1,906	UTF -77 -LEVEL	UTF-LT7750201	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y					I								RRC	RRC-IROH	137585	C
1,907	UTF -77 -LEVEL	UTF-LT7750201	Inspection UTF-LT7750201	PMT	1Y						I							RRC	RRC-IROH	250297	C
1,908	UTF -77 -LEVEL	UTF-LT7750302	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IROH	137505	C
1,909	UTF -78 -LEVEL	UTF-LT7800101	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y	I												RRC	RRC-IROH	137381	C
1,910	UTF -78 -LEVEL	UTF-LT7800201	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y	I												RRC	RRC-IROH	137382	C
1,911	UTF -78 -LEVEL	UTF-LT7800301	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y	I												RRC	RRC-IROH	137383	C
1,912	UTF -78 -LEVEL	UTF-LT7800401	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IROH	137506	C
1,913	UTF -78 -LEVEL	UTF-LT7800501	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IROH	137507	C
1,914	UTF -78 -LEVEL	UTF-LT7800601	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y			I										RRC	RRC-IROH	137508	C
1,915	UTF -78 -LEVEL	UTF-LT7800701	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IROH	137509	C
1,916	UTF -78 -LEVEL	UTF-LT7800801	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IROH	137510	C
1,917	UTF -78 -LEVEL	UTF-LT7800901	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IROH	137511	C
1,918	UTF -78 -LEVEL	UTF-LT7801001	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IROH	137512	C
1,919	UTF -78 -LEVEL	UTF-LT7801201	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y				I									RRC	RRC-IROH	137513	C
1,920	UTF -79 -LEVEL	UTF-LT7900201	INSP. FIELD INST.LT7900201	PMT	1Y				I									RRC	RRC-IROH	137514	C
1,921	UTF -79 -LEVEL	UTF-LT7900202	INSP. FIELD INST.LT7900202	PMT	1Y				I									RRC	RRC-IROH	137515	C
1,922	UTF -79 -79T001	UTF-LT7900401	INSP. FIELD INST.LT7900401	PMT	1Y						I							RRC	RRC-IROH	245902	C
1,923	UTF -79 -79T001	UTF-LT7900402	INSP. FIELD INST.LT7900402	PMT	1Y						I							RRC	RRC-IROH	245903	C
1,924	UTF -79 -79T004	UTF-LT7900501	INSP. FIELD INST.LT7900501	PMT	1Y						I							RRC	RRC-IROH	245904	C
1,925	UTF -79 -79T004	UTF-LT7900502	INSP. FIELD INST.LT7900502	PMT	1Y						I							RRC	RRC-IROH	245905	C
1,926	UTF -79 -79T003	UTF-LT7900601	INSP. FIELD INST.LT7900601	PMT	1Y						I							RRC	RRC-IROH	245906	C
1,927	UTF -79 -79T003	UTF-LT7900602	INSP. FIELD INST.LT7900602	PMT	1Y						I							RRC	RRC-IROH	245907	C
1,928	UTF -79 -79T002	UTF-LT7900603	INSP. FIELD INST.LT7900603	PMT	1Y						I							RRC	RRC-IROH	245908	C
1,929	UTF -79 -79T002	UTF-LT7900604	INSP. FIELD INST.LT7900604	PMT	1Y						I							RRC	RRC-IROH	245909	C
1,930	UTF -79 -79D002	UTF-LT7900701	INSP. FIELD INST.LT7900701	PMT	1Y						I							RRC	RRC-IROH	245910	C
1,931	UTF -79 -79S001	UTF-LT7900901	INSP. FIELD INST.LT7900901	PMT	1Y						I							RRC	RRC-IROH	245911	C
1,932	UTF -79 -79S001	UTF-LT7900902	INSP. FIELD INST.LT7900902	PMT	1Y						I							RRC	RRC-IROH	245912	C
1,933	UTF -79 -79S001	UTF-LT7900903	INSP. FIELD INST.LT7900903	PMT	1Y						I							RRC	RRC-IROH	245913	C
1,934	UTF -79 -79S001	UTF-LT7900904	INSP. FIELD INST.LT7900904	PMT	1Y						I							RRC	RRC-IROH	245914	C
1,935	UTF -79 -79R002	UTF-LT7901001	INSP. FIELD INST.LT7901001	PMT	1Y						I							RRC	RRC-IROH	245915	C
1,936	UTF -79 -79R002	UTF-LT7901002	INSP. FIELD INST.LT7901002	PMT	1Y						I							RRC	RRC-IROH	245916	C
1,937	UTF -79 -79D003	UTF-LT7901003	INSP. FIELD INST.LT7901003	PMT	1Y						I							RRC	RRC-IROH	245917	C
1,938	UTF -79 -79D003	UTF-LT7901004	INSP. FIELD INST.LT7901004	PMT	1Y						I							RRC	RRC-IROH	245918	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,939	UTF -79 -79D004	UTF-LT7901701	INSP. FIELD INST.LT7901701	PMT	1Y							I						RRC	RRC-IRCH	245919	C
1,940	UTF -79 -79D004	UTF-LT7901702	INSP. FIELD INST.LT7901702	PMT	1Y								I					RRC	RRC-IRCH	245920	C
1,941	UTF -79 -79D005	UTF-LT7901801	INSP. FIELD INST.LT7901801	PMT	1Y								I					RRC	RRC-IRCH	245921	C
1,942	UTF -79 -79D005	UTF-LT7901802	INSP. FIELD INST.LT7901802	PMT	1Y								I					RRC	RRC-IRCH	245922	C
1,943	UTF -79 -79T101	UTF-LT7910102	INSP. FIELD INST.LT7910102	PMT	1Y								I					RRC	RRC-IRCH	245923	C
1,944	UTF -79 -79T102	UTF-LT7910201	INSP. FIELD INST.LT7910201	PMT	1Y								I					RRC	RRC-IRCH	245924	C
1,945	UTF -79 -79T104	UTF-LT7910204	INSP. FIELD INST.LT7910204	PMT	1Y								I					RRC	RRC-IRCH	245925	C
1,946	UTF -79 -79T105	UTF-LT7910301	INSP. FIELD INST.LT7910301	PMT	1Y								I					RRC	RRC-IRCH	245926	C
1,947	UTF -79 -79T106	UTF-LT7910303	INSP. FIELD INST.LT7910303	PMT	1Y								I					RRC	RRC-IRCH	245927	C
1,948	UTF -79 -79T107	UTF-LT7910304	INSP. FIELD INST.LT7910304	PMT	1Y								I					RRC	RRC-IRCH	245928	C
1,949	UTF -80 -80X001	UTF-LT8050201	INSP. FIELD INST.UTF-LT8050201	PMT	1Y								I					RRC	RRC-IRCH	255621	C
1,950	UTF -74 -CV	UTF-LV7400101	INSPECT CONTROL VALVE NO. LV74	PMT	1Y									I				RRC	RRC-IRCH	137739	C
1,951	UTF -74 -CV	UTF-LV7400401	INSPECT CONTROL VALVE NO. LV74	PMT	1Y									I				RRC	RRC-IRCH	137740	C
1,952	UTF -74 -CV	UTF-LV7400402	INSPECT CONTROL VALVE NO. LV74	PMT	1Y									I				RRC	RRC-IRCH	137741	C
1,953	UTF -74 -CV	UTF-LV7400501	INSPECT CONTROL VALVE NO. LV74	PMT	1Y									I				RRC	RRC-IRCH	137742	C
1,954	UTF -77 -CV	UTF-LV7705702	INSPECT CONTROL VALVE NO. LV77	PMT	1Y									I				RRC	RRC-IRCH	137743	C
1,955	UTF -77 -CV	UTF-LV7706201	INSPECT CONTROL VALVE NO. LV77	PMT	1Y									I				RRC	RRC-IRCH	137744	C
1,956	UTF -77 -CV	UTF-LV7750101	INSPECT CONTROL VALVE NO. LV77	PMT	1Y									I				RRC	RRC-IRCH	137745	C
1,957	UTF -77 -CV	UTF-LV7750101	Inspection UTF-LV7750101	PMT	1Y						I							RRC	RRC-IRCH	250299	C
1,958	UTF -77 -CV	UTF-LV7750201	INSPECT CONTROL VALVE NO. LV77	PMT	1Y									I				RRC	RRC-IRCH	137746	C
1,959	UTF -77 -CV	UTF-LV7750201	Inspection UTF-LV7750201	PMT	1Y						I							RRC	RRC-IRCH	250300	C
1,960	UTF -78 -CV	UTF-LV7801201	INSPECT CONTROL VALVE NO. LV78	PMT	1Y									I				RRC	RRC-IRCH	137747	C
1,961	UTF -79 -CV	UTF-LV7910102	INSPECT CONTROL VALVE NO. LV7910102	PMT	1Y										I			RRC	RRC-IRCH	245929	C
1,962	UTF -79 -CV	UTF-LV7910301	INSPECT CONTROL VALVE NO. LV7910301	PMT	1Y										I			RRC	RRC-IRCH	245930	C
1,963	UTF -74 -CV	UTF-PCV7400701	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y									I				RRC	RRC-IRCH	137776	C
1,964	UTF -74 -CV	UTF-PCV7400702	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y									I				RRC	RRC-IRCH	137777	C
1,965	UTF -74 -CV	UTF-PCV7451201	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y									I				RRC	RRC-IRCH	137778	C
1,966	UTF -77 -CV	UTF-PCV7700901	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y									I				RRC	RRC-IRCH	137779	C
1,967	UTF -77 -CV	UTF-PCV7700903	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y									I				RRC	RRC-IRCH	137780	C
1,968	UTF -77 -CV	UTF-PCV7701001	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y									I				RRC	RRC-IRCH	137781	C
1,969	UTF -77 -CV	UTF-PCV7701002	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y									I				RRC	RRC-IRCH	137782	C
1,970	UTF -77 -CV	UTF-PCV7701101	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y									I				RRC	RRC-IRCH	137783	C
1,971	UTF -77 -CV	UTF-PCV7701401	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y									I				RRC	RRC-IRCH	137784	C
1,972	UTF -77 -CV	UTF-PCV7701402	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y										I			RRC	RRC-IRCH	137785	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
1,973	UTF -77 -CV	UTF-PCV7701403	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y										I			RRC	RRC-IRCH	137786	C
1,974	UTF -77 -CV	UTF-PCV7701701	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y										I			RRC	RRC-IRCH	137787	C
1,975	UTF -77 -CV	UTF-PCV7701702	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y										I			RRC	RRC-IRCH	137788	C
1,976	UTF -77 -CV	UTF-PCV7702101	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y										I			RRC	RRC-IRCH	137789	C
1,977	UTF -77 -CV	UTF-PCV7706201	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y										I			RRC	RRC-IRCH	137790	C
1,978	UTF -77 -77X101	UTF-PCV7750101	Inspec PCV7750101	PMT	2M		I		I		I		I		I		I	RRC	RRC-IRCH	250278	C
1,979	UTF -77 -77X101	UTF-PCV7750102	Inspec PCV7750102	PMT	2M		I		I		I		I		I		I	RRC	RRC-IRCH	250279	C
1,980	UTF -77 -77X101	UTF-PCV7750104	Inspec PCV7750104	PMT	2M		I		I		I		I		I		I	RRC	RRC-IRCH	250280	C
1,981	UTF -78 -CV	UTF-PCV7800901	INSPECT CONTROL VALVE NO. PCV7	PMT	1Y										I			RRC	RRC-IRCH	137791	C
1,982	UTF -79 -PRESS	UTF-PCV7900401	INSPECT CONTROL VALVE NO.PCV7900401	PMT	1Y										I			RRC	RRC-IRCH	245931	C
1,983	UTF -79 -PRESS	UTF-PCV7900601	INSPECT CONTROL VALVE NO.PCV7900601	PMT	1Y										I			RRC	RRC-IRCH	245932	C
1,984	UTF -79 -PRESS	UTF-PCV7900602	INSPECT CONTROL VALVE NO.PCV7900602	PMT	1Y										I			RRC	RRC-IRCH	245933	C
1,985	UTF -79 -PRESS	UTF-PCV7900701	INSPECT CONTROL VALVE NO.PCV7900701	PMT	1Y										I			RRC	RRC-IRCH	245934	C
1,986	UTF -79 -PRESS	UTF-PCV7900901	INSPECT CONTROL VALVE NO.PCV7900901	PMT	1Y											I		RRC	RRC-IRCH	245935	C
1,987	UTF -79 -PRESS	UTF-PCV7901301	INSPECT CONTROL VALVE NO.PCV7901301	PMT	1Y											I		RRC	RRC-IRCH	245936	C
1,988	UTF -79 -PRESS	UTF-PCV7901801	INSPECT CONTROL VALVE NO.PCV7901801	PMT	1Y											I		RRC	RRC-IRCH	245937	C
1,989	UTF -80 -80X001	UTF-PCV8050103	INSPECT CONTROL VALVE NO.UTF-P	PMT	1Y												I	RRC	RRC-IRCH	255652	C
1,990	UTF -80 -80X001	UTF-PCV8050206	INSPECT CONTROL VALVE NO.UTF-P	PMT	1Y												I	RRC	RRC-IRCH	255653	C
1,991	UTF -80 -80X001	UTF-PCV8050408A	INSPECT CONTROL VALVE NO.UTF-P	PMT	1Y												I	RRC	RRC-IRCH	255654	C
1,992	UTF -80 -80X001	UTF-PCV8050408B	INSPECT CONTROL VALVE NO.UTF-P	PMT	1Y												I	RRC	RRC-IRCH	255655	C
1,993	UTF -80 -80X001	UTF-PCV8050806	INSPECT CONTROL VALVE NO.UTF-P	PMT	1Y												I	RRC	RRC-IRCH	255656	C
1,994	UTF -80 -80X001	UTF-PCV8050807	INSPECT CONTROL VALVE NO.UTF-P	PMT	1Y												I	RRC	RRC-IRCH	255657	C
1,995	UTF -80 -80X001	UTF-PDAH8050407	INSP. FIELD INST.UTF-PDAH8050407	PMT	1Y										I			RRC	RRC-IRCH	255622	C
1,996	UTF -79 -PRESS	UTF-PDG7900901	INSP. FIELD INST.PDG7900901	PMT	1Y								I					RRC	RRC-IRCH	245938	C
1,997	UTF -79 -PRESS	UTF-PDG7900903	INSP. FIELD INST.PDG7900903	PMT	1Y								I					RRC	RRC-IRCH	245939	C
1,998	UTF -79 -PRESS	UTF-PDG7900904	INSP. FIELD INST.PDG7900904	PMT	1Y								I					RRC	RRC-IRCH	245940	C
1,999	UTF -79 -PRESS	UTF-PDG7900905	INSP. FIELD INST.PDG7900905	PMT	1Y								I					RRC	RRC-IRCH	245941	C
2,000	UTF -80 -80X001	UTF-PDIT8050207	INSPECTION PDT TRANS.UTF-PDIT8	PMT	1Y											I		RRC	RRC-IRCH	255623	C
2,001	UTF -80 -80X001	UTF-PDSH8050311	INSP. FIELD INST.UTF-PDSH8050311	PMT	1Y										I			RRC	RRC-IRCH	255624	C
2,002	UTF -80 -80X001	UTF-PDSH8050313	INSP. FIELD INST.UTF-PDSH8050313	PMT	1Y										I			RRC	RRC-IRCH	255625	C
2,003	UTF -80 -80X001	UTF-PDSH8050404A	INSP. FIELD INST.UTF-PDSH8050404	PMT	1Y										I			RRC	RRC-IRCH	255626	C
2,004	UTF -80 -80X001	UTF-PDSH8050404B	INSP. FIELD INST.UTF-PDSH8050404	PMT	1Y										I			RRC	RRC-IRCH	255627	C
2,005	UTF -80 -80X001	UTF-PDSH8050411	INSP. FIELD INST.UTF-PDSH8050404	PMT	1Y										I			RRC	RRC-IRCH	255628	C
2,006	UTF -00 -PRESS	UTF-PDT7400202	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y								I					RRC	RRC-IRCH	137648	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,007	UTF -00 -PRESS	UTF-PDT7400205	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y							I						RRC	RRC-IRCH	137649	C
2,008	UTF -74 -74X001	UTF-PDT7450101	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y							I						RRC	RRC-IRCH	137655	C
2,009	UTF -74 -74X001	UTF-PDT7450102	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y							I						RRC	RRC-IRCH	137656	C
2,010	UTF -74 -74X001	UTF-PDT7450103	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y							I						RRC	RRC-IRCH	137657	C
2,011	UTF -74 -74X001	UTF-PDT7450104	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y							I						RRC	RRC-IRCH	137658	C
2,012	UTF -74 -74X001	UTF-PDT7450201	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y							I						RRC	RRC-IRCH	137659	C
2,013	UTF -74 -74X001	UTF-PDT7450202	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y							I						RRC	RRC-IRCH	137660	C
2,014	UTF -74 -74X001	UTF-PDT7450203	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y							I						RRC	RRC-IRCH	137661	C
2,015	UTF -74 -74X001	UTF-PDT7450204	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y							I						RRC	RRC-IRCH	137662	C
2,016	UTF -74 -74X001	UTF-PDT7450301	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y							I						RRC	RRC-IRCH	137663	C
2,017	UTF -74 -74X001	UTF-PDT7450302	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y							I						RRC	RRC-IRCH	137664	C
2,018	UTF -74 -74X001	UTF-PDT7450303	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y							I						RRC	RRC-IRCH	137665	C
2,019	UTF -74 -74X001	UTF-PDT7450304	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y							I						RRC	RRC-IRCH	137666	C
2,020	UTF -74 -74X001	UTF-PDT7450401	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y							I						RRC	RRC-IRCH	137667	C
2,021	UTF -74 -74X001	UTF-PDT7450501	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y							I						RRC	RRC-IRCH	137668	C
2,022	UTF -74 -74X001	UTF-PDT7450601	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y							I						RRC	RRC-IRCH	137669	C
2,023	UTF -75 -PRESS	UTF-PDT7500203	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y							I						RRC	RRC-IRCH	137650	C
2,024	UTF -75 -PRESS	UTF-PDT7500206	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y							I						RRC	RRC-IRCH	137651	C
2,025	UTF -75 -PRESS	UTF-PDT7500209	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y							I						RRC	RRC-IRCH	137652	C
2,026	UTF -77 -PRESS	UTF-PDT7701301	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y							I						RRC	RRC-IRCH	137653	C
2,027	UTF -77 -PRESS	UTF-PDT7701304	INSP. FIELD INST. (ต่อหูปากมิ้)	PMT	1Y							I						RRC	RRC-IRCH	137654	C
2,028	UTF -79 -PRESS	UTF-PDT7900401	INSP. FIELD INST.PDT7900401	PMT	1Y							I						RRC	RRC-IRCH	245942	C
2,029	UTF -79 -PRESS	UTF-PDT7900402	INSP. FIELD INST.PDT7900402	PMT	1Y							I						RRC	RRC-IRCH	245943	C
2,030	UTF -79 -PRESS	UTF-PDT7900701	INSP. FIELD INST.PDT7900701	PMT	1Y							I						RRC	RRC-IRCH	245944	C
2,031	UTF -79 -PRESS	UTF-PDT7900702	INSP. FIELD INST.PDT7900702	PMT	1Y							I						RRC	RRC-IRCH	245945	C
2,032	UTF -79 -79D002	UTF-PDT7900703	INSP. FIELD INST.PDT7900703	PMT	1Y							I						RRC	RRC-IRCH	245946	C
2,033	UTF -79 -PRESS	UTF-PDT7900801	INSP. FIELD INST.PDT7900801	PMT	1Y							I						RRC	RRC-IRCH	245947	C
2,034	UTF -79 -PRESS	UTF-PDT7900802	INSP. FIELD INST.PDT7900802	PMT	1Y							I						RRC	RRC-IRCH	245948	C
2,035	UTF -79 -PRESS	UTF-PDT7900901	INSP. FIELD INST.PDT7900901	PMT	1Y								I					RRC	RRC-IRCH	245949	C
2,036	UTF -79 -PRESS	UTF-PDT7901101	INSP. FIELD INST.PDT7901101	PMT	1Y								I					RRC	RRC-IRCH	245950	C
2,037	UTF -79 -PRESS	UTF-PDT7901102	INSP. FIELD INST.PDT7901102	PMT	1Y								I					RRC	RRC-IRCH	245951	C
2,038	UTF -79 -PRESS	UTF-PDT7901201	INSP. FIELD INST.PDT7901201	PMT	1Y								I					RRC	RRC-IRCH	245952	C
2,039	UTF -79 -PRESS	UTF-PDT7901202	INSP. FIELD INST.PDT7901202	PMT	1Y								I					RRC	RRC-IRCH	245953	C
2,040	UTF -79 -PRESS	UTF-PDT7901301	INSP. FIELD INST.PDT7901301	PMT	1Y								I					RRC	RRC-IRCH	245954	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,041	UTF -79 -PRESS	UTF-PDT7901302	INSP. FIELD INST.PDT7901302	PMT	1Y								I					RRC	RRC-IRCH	245955	C
2,042	UTF -79 -PRESS	UTF-PDT7901303	INSP. FIELD INST.PDT7901303	PMT	1Y								I					RRC	RRC-IRCH	245956	C
2,043	UTF -79 -PRESS	UTF-PDT7910301	INSP. FIELD INST.PDT7910301	PMT	1Y								I					RRC	RRC-IRCH	245957	C
2,044	UTF -79 -PRESS	UTF-PG7900203	INSP. FIELD INST.PG7900203	PMT	1Y								I					RRC	RRC-IRCH	245958	C
2,045	UTF -79 -PRESS	UTF-PG7900401	INSP. FIELD INST.PG7900401	PMT	1Y								I					RRC	RRC-IRCH	245959	C
2,046	UTF -79 -79P009B	UTF-PG7900402	INSP. FIELD INST.PG7900402	PMT	1Y								I					RRC	RRC-IRCH	245960	C
2,047	UTF -79 -PRESS	UTF-PG7900501	INSP. FIELD INST.PG7900501	PMT	1Y								I					RRC	RRC-IRCH	245961	C
2,048	UTF -79 -PRESS	UTF-PG7900502	INSP. FIELD INST.PG7900502	PMT	1Y								I					RRC	RRC-IRCH	245962	C
2,049	UTF -79 -PRESS	UTF-PG7900601	INSP. FIELD INST.PG7900601	PMT	1Y								I					RRC	RRC-IRCH	245963	C
2,050	UTF -79 -PRESS	UTF-PG7900602	INSP. FIELD INST.PG7900602	PMT	1Y								I					RRC	RRC-IRCH	245964	C
2,051	UTF -79 -PRESS	UTF-PG7900603	INSP. FIELD INST.PG7900603	PMT	1Y								I					RRC	RRC-IRCH	245965	C
2,052	UTF -79 -PRESS	UTF-PG7900604	INSP. FIELD INST.PG7900604	PMT	1Y								I					RRC	RRC-IRCH	245966	C
2,053	UTF -79 -PRESS	UTF-PG7900901	INSP. FIELD INST.PG7900901	PMT	1Y								I					RRC	RRC-IRCH	245967	C
2,054	UTF -79 -PRESS	UTF-PG7900902	INSP. FIELD INST.PG7900902	PMT	1Y								I					RRC	RRC-IRCH	245968	C
2,055	UTF -79 -PRESS	UTF-PG7900904	INSP. FIELD INST.PG7900904	PMT	1Y								I					RRC	RRC-IRCH	245969	C
2,056	UTF -79 -PRESS	UTF-PG7901101	INSP. FIELD INST.PG7901101	PMT	1Y								I					RRC	RRC-IRCH	245970	C
2,057	UTF -79 -PRESS	UTF-PG7901102	INSP. FIELD INST.PG7901102	PMT	1Y									I				RRC	RRC-IRCH	245971	C
2,058	UTF -79 -PRESS	UTF-PG7901201	INSP. FIELD INST.PG7901201	PMT	1Y									I				RRC	RRC-IRCH	245972	C
2,059	UTF -79 -PRESS	UTF-PG7901202	INSP. FIELD INST.PG7901202	PMT	1Y									I				RRC	RRC-IRCH	245973	C
2,060	UTF -79 -PRESS	UTF-PG7901301	INSP. FIELD INST.PG7901301	PMT	1Y									I				RRC	RRC-IRCH	245974	C
2,061	UTF -79 -PRESS	UTF-PG7901302	INSP. FIELD INST.PG7901302	PMT	1Y									I				RRC	RRC-IRCH	245975	C
2,062	UTF -79 -PRESS	UTF-PG7901303	INSP. FIELD INST.PG7901303	PMT	1Y									I				RRC	RRC-IRCH	245976	C
2,063	UTF -79 -PRESS	UTF-PG7901701	INSP. FIELD INST.PG7901701	PMT	1Y									I				RRC	RRC-IRCH	245977	C
2,064	UTF -80 -80X001	UTF-PG8050310	VERIFY PRESSURE GAUGEUTF-PG8050	PMT	1Y									V				RRC	RRC-IRCH	255629	C
2,065	UTF -80 -80X001	UTF-PG8050312	VERIFY PRESSURE GAUGEUTF-PG8050	PMT	1Y									V				RRC	RRC-IRCH	255630	C
2,066	UTF -80 -80X001	UTF-PG8050701	VERIFY PRESSURE GAUGEUTF-PG8050	PMT	1Y									V				RRC	RRC-IRCH	255631	C
2,067	UTF -80 -80X001	UTF-PG8050702	VERIFY PRESSURE GAUGEUTF-PG8050	PMT	1Y									V				RRC	RRC-IRCH	255632	C
2,068	UTF -80 -80X001	UTF-PIT8050101	INSPECTION PT AND PDT.UTF-PIT8	PMT	1Y											I		RRC	RRC-IRCH	255635	C
2,069	UTF -80 -80X001	UTF-PIT8050102	INSPECTION PT AND PDT.UTF-PIT8	PMT	1Y											I		RRC	RRC-IRCH	255636	C
2,070	UTF -80 -80X001	UTF-PIT8050103	INSPECTION PT AND PDT.UTF-PIT8	PMT	1Y											I		RRC	RRC-IRCH	255637	C
2,071	UTF -80 -80X001	UTF-PIT8050106	INSPECTION PT AND PDT.UTF-PIT8	PMT	1Y											I		RRC	RRC-IRCH	255638	C
2,072	UTF -80 -80X001	UTF-PIT8050201	INSPECTION PT AND PDT.UTF-PIT8	PMT	1Y											I		RRC	RRC-IRCH	255639	C
2,073	UTF -80 -80X001	UTF-PIT8050304A	INSPECTION PT AND PDT.UTF-PIT8	PMT	1Y											I		RRC	RRC-IRCH	255640	C
2,074	UTF -80 -80X001	UTF-PIT8050304B	INSPECTION PT AND PDT.UTF-PIT8	PMT	1Y											I		RRC	RRC-IRCH	255641	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,075	UTF -80 -80X001	UTF-PIT8050304C	INSPECTION PT AND PDT.UTF-PIT8	PMT	1Y											I		RRC	RRC-IRCH	255642	C
2,076	UTF -80 -80X001	UTF-PIT8050801	INSPECTION PT AND PDT.UTF-PIT8	PMT	1Y											I		RRC	RRC-IRCH	255643	C
2,077	UTF -80 -80X001	UTF-PIT8050803	INSPECTION PT AND PDT.UTF-PIT8	PMT	1Y											I		RRC	RRC-IRCH	255644	C
2,078	UTF -80 -80X001	UTF-PSL8050310	INSP. FIELD INST.UTF-PSL805031	PMT	1Y											I		RRC	RRC-IRCH	255645	C
2,079	UTF -80 -80X001	UTF-PSL8050312	INSP. FIELD INST.UTF-PSL805031	PMT	1Y											I		RRC	RRC-IRCH	255646	C
2,080	UTF -80 -80X001	UTF-PSL8050401A	INSP. FIELD INST.UTF-PSL805040	PMT	1Y											I		RRC	RRC-IRCH	255647	C
2,081	UTF -80 -80X001	UTF-PSL8050401B	INSP. FIELD INST.UTF-PSL805040	PMT	1Y											I		RRC	RRC-IRCH	255648	C
2,082	UTF -01 -PRD	UTF-PSV0101201	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163013	A
2,083	UTF -01 -PRD	UTF-PSV0103701	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163014	A
2,084	UTF -01 -PRD	UTF-PSV0103702	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163015	A
2,085	UTF -01 -PRD	UTF-PSV0103703	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163016	A
2,086	UTF -01 -PRD	UTF-PSV0103801	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163017	A
2,087	UTF -01 -PRD	UTF-PSV0103802	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163018	A
2,088	UTF -01 -PRD	UTF-PSV0103803	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163019	A
2,089	UTF -01 -PRD	UTF-PSV0103804	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163020	A
2,090	UTF -00 -PRD	UTF-PSV0103901	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163021	A
2,091	UTF -01 -PRD	UTF-PSV0103902	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163022	A
2,092	UTF -01 -PRD	UTF-PSV0103903	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163023	A
2,093	UTF -01 -PRD	UTF-PSV0103904	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163024	A
2,094	UTF -01 -PRD	UTF-PSV0103905	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163025	A
2,095	UTF -01 -PRD	UTF-PSV0103907	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163026	A
2,096	UTF -01 -PRD	UTF-PSV0103908	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163027	A
2,097	UTF -01 -PRD	UTF-PSV0109906	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163028	A
2,098	UTF -74 -74D001	UTF-PSV7400101	Pressure Relief Device Calibra	PMT	5Y									I				RRC	RRC-MRCH	163029	B
2,099	UTF -74 -74Z001	UTF-PSV7400102	Pressure Relief Device Calibra	PMT	5Y									I				RRC	RRC-MRCH	163030	B
2,100	UTF -74 -74Z001	UTF-PSV7400301	Pressure Relief Device Calibra	PMT	5Y									I				RRC	RRC-MRCH	163031	B
2,101	UTF -74 -74Z001	UTF-PSV7400302	Pressure Relief Device Calibra	PMT	5Y									I				RRC	RRC-MRCH	163032	B
2,102	UTF -74 -74Z002	UTF-PSV7400303	Pressure Relief Device Calibra	PMT	5Y									I				RRC	RRC-MRCH	163033	B
2,103	UTF -74 -74Z002	UTF-PSV7400304	Pressure Relief Device Calibra	PMT	5Y									I				RRC	RRC-MRCH	163034	B
2,104	UTF -74 -74Z003	UTF-PSV7400305	Pressure Relief Device Calibra	PMT	5Y										I			RRC	RRC-MRCH	163035	B
2,105	UTF -74 -74Z003	UTF-PSV7400306	Pressure Relief Device Calibra	PMT	5Y										I			RRC	RRC-MRCH	163036	B
2,106	UTF -74 -74Z003	UTF-PSV7400307	Pressure Relief Device Calibra	PMT	5Y										I			RRC	RRC-MRCH	163037	B
2,107	UTF -74 -74Z002	UTF-PSV7400308	Pressure Relief Device Calibra	PMT	5Y										I			RRC	RRC-MRCH	163038	B
2,108	UTF -74 -74Z003	UTF-PSV7400309	Pressure Relief Device Calibra	PMT	5Y										I			RRC	RRC-MRCH	163039	B

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,109	UTF -74 -74E005A	UTF-PSV7400601	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163040	A
2,110	UTF -74 -74X001	UTF-PSV7450101	Pressure Relief Device Calibra	PMT	5Y										I			RRC	RRC-MRCH	163041	B
2,111	UTF -74 -74X001	UTF-PSV7450102	Pressure Relief Device Calibra	PMT	5Y										I			RRC	RRC-MRCH	163042	B
2,112	UTF -74 -74X001	UTF-PSV7450201	Pressure Relief Device Calibra	PMT	5Y										I			RRC	RRC-MRCH	163043	B
2,113	UTF -74 -74X001	UTF-PSV7450202	Pressure Relief Device Calibra	PMT	5Y										I			RRC	RRC-MRCH	163044	B
2,114	UTF -74 -74X001	UTF-PSV7450301	Pressure Relief Device Calibra	PMT	5Y										I			RRC	RRC-MRCH	163045	B
2,115	UTF -74 -74X001	UTF-PSV7450302	Pressure Relief Device Calibra	PMT	5Y										I			RRC	RRC-MRCH	163046	B
2,116	UTF -74 -74X001	UTF-PSV7450401	Pressure Relief Device Calibra	PMT	5Y										I			RRC	RRC-MRCH	163047	B
2,117	UTF -74 -74X001	UTF-PSV7450501	Pressure Relief Device Calibra	PMT	5Y										I			RRC	RRC-MRCH	163048	B
2,118	UTF -74 -74X001	UTF-PSV7450601	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163049	B
2,119	UTF -77 -PRD	UTF-PSV7700101	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163075	A
2,120	UTF -77 -77T003A	UTF-PSV7700201	Pressure Relief Device Calibra	PMT	1Y										I			RRC	RRC-MRCH	163076	B
2,121	UTF -77 -77T003A	UTF-PSV7700202	Pressure Relief Device Calibra	PMT	1Y										I			RRC	RRC-MRCH	163077	B
2,122	UTF -77 -PRD	UTF-PSV7700203	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163078	A
2,123	UTF -77 -PRD	UTF-PSV7700204	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163079	A
2,124	UTF -77 -PRD	UTF-PSV7700205	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163115	A
2,125	UTF -77 -PRD	UTF-PSV7700206	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163080	A
2,126	UTF -77 -PRD	UTF-PSV7700303	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163081	A
2,127	UTF -77 -PRD	UTF-PSV7700305	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163116	A
2,128	UTF -77 -PRD	UTF-PSV7700306	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163082	A
2,129	UTF -77 -PRD	UTF-PSV7700309	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163083	B
2,130	UTF -77 -PRD	UTF-PSV7700310	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163084	B
2,131	UTF -77 -PRD	UTF-PSV7700311	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163085	B
2,132	UTF -77 -PRD	UTF-PSV7700312	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163086	B
2,133	UTF -77 -77T004A	UTF-PSV7700401	Pressure Relief Device Calibra	PMT	1Y										I			RRC	RRC-MRCH	163087	C
2,134	UTF -77 -77T004A	UTF-PSV7700402	Pressure Relief Device Calibra	PMT	1Y										I			RRC	RRC-MRCH	163088	C
2,135	UTF -77 -PRD	UTF-PSV7700403	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163089	A
2,136	UTF -77 -PRD	UTF-PSV7700404	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163090	B
2,137	UTF -77 -PRD	UTF-PSV7700405	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163091	B
2,138	UTF -77 -PRD	UTF-PSV7700501	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163092	A
2,139	UTF -77 -77T013A	UTF-PSV7700601	Pressure Relief Device Calibra	PMT	1Y										I			RRC	RRC-MRCH	163093	C
2,140	UTF -77 -77T013A	UTF-PSV7700602	Pressure Relief Device Calibra	PMT	1Y										I			RRC	RRC-MRCH	163094	C
2,141	UTF -77 -77T013B	UTF-PSV7700603	Pressure Relief Device Calibra	PMT	1Y										I			RRC	RRC-MRCH	163095	C
2,142	UTF -77 -77T013B	UTF-PSV7700604	Pressure Relief Device Calibra	PMT	1Y										I			RRC	RRC-MRCH	163096	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,143	UTF -77 -PRD	UTF-PSV7700605	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163097	A
2,144	UTF -77 -PRD	UTF-PSV7700606	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163098	A
2,145	UTF -77 -PRD	UTF-PSV7700607	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163099	A
2,146	UTF -77 -PRD	UTF-PSV7700609	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163100	A
2,147	UTF -77 -77P017A	UTF-PSV7700691	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163101	A
2,148	UTF -77 -PRD	UTF-PSV7700692	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163102	A
2,149	UTF -77 -77T014	UTF-PSV7701001	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163103	A
2,150	UTF -77 -PRD	UTF-PSV7701002	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163104	A
2,151	UTF -77 -PRD	UTF-PSV7701101	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163105	A
2,152	UTF -77 -PRD	UTF-PSV7701401	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163106	A
2,153	UTF -77 -PRD	UTF-PSV7701405	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163107	B
2,154	UTF -77 -PRD	UTF-PSV7701406	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163108	B
2,155	UTF -77 -77T004B	UTF-PSV7701801	Pressure Relief Device Calibra	PMT	1Y										I			RRC	RRC-MRCH	163109	C
2,156	UTF -77 -77T004B	UTF-PSV7701802	Pressure Relief Device Calibra	PMT	1Y										I			RRC	RRC-MRCH	163110	C
2,157	UTF -77 -PRD	UTF-PSV7701803	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163111	A
2,158	UTF -77 -77T004C	UTF-PSV7701901	Pressure Relief Device Calibra	PMT	1Y										I			RRC	RRC-MRCH	163112	C
2,159	UTF -77 -77T004C	UTF-PSV7701902	Pressure Relief Device Calibra	PMT	1Y										I			RRC	RRC-MRCH	163113	C
2,160	UTF -77 -PRD	UTF-PSV7701903	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163114	A
2,161	UTF -77 -77E102	UTF-PSV7705601	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163117	A
2,162	UTF -77 -77D109	UTF-PSV7706202	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163121	A
2,163	UTF -77 -77X001	UTF-PSV7750301	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163122	A
2,164	UTF -77 -77X001	UTF-PSV7750302	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163123	A
2,165	UTF -78 -78K001A	UTF-PSV7800901	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163124	A
2,166	UTF -78 -78K001B	UTF-PSV7800902	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163125	A
2,167	UTF -78 -78X002	UTF-PSV7850201	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163126	A
2,168	UTF -78 -78X002	UTF-PSV7850401	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163127	A
2,169	UTF -78 -78X002	UTF-PSV7850402	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163128	A
2,170	UTF -78 -78X002	UTF-PSV7850501	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163129	A
2,171	UTF -78 -78X002	UTF-PSV7850502	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	163130	A
2,172	UTF -79 -79D001	UTF-PSV7900201	PRD Calibration of UTF-PSV7900201	PMT	5Y											I		RRC	RRC-MRCH	163132	A
2,173	UTF -79 -79D001	UTF-PSV7900202	Pressure Relief Device Calibra	PMT	5Y											I		RRC	RRC-MRCH	254800	A
2,174	UTF -79 -PRESS	UTF-PSV7900701	PRD Calibration of UTF-PSV7900701	PMT	5Y											I		RRC	RRC-MRCH	245749	C
2,175	UTF -79 -PRESS	UTF-PSV7900702A	PRD Calibration of UTF-PSV7900702A	PMT	5Y											I		RRC	RRC-MRCH	245750	C
2,176	UTF -79 -PRESS	UTF-PSV7900702B	PRD Calibration of UTF-PSV7900702B	PMT	5Y											I		RRC	RRC-MRCH	245751	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,177	UTF -79 -PRESS	UTF-PSV7900801	PRD Calibration of UTF-PSV7900801	PMT	5Y											I		RRC	RRC-MRCH	245752	C
2,178	UTF -79 -PRESS	UTF-PSV7900901	PRD Calibration of UTF-PSV7900901	PMT	5Y											I		RRC	RRC-MRCH	245753	C
2,179	UTF -79 -PRESS	UTF-PSV7901301	PRD Calibration of UTF-PSV7901301	PMT	5Y											I		RRC	RRC-MRCH	245756	C
2,180	UTF -00 -PRESS	UTF-PT0000101	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCH	137592	C
2,181	UTF -00 -PRESS	UTF-PT0103501	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCH	137593	C
2,182	UTF -00 -PRESS	UTF-PT0103504	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCH	137594	C
2,183	UTF -00 -PRESS	UTF-PT0103507	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCH	137595	C
2,184	UTF -00 -PRESS	UTF-PT0103508	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCH	137596	C
2,185	UTF -00 -PRESS	UTF-PT0103511	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCH	137597	C
2,186	UTF -00 -PRESS	UTF-PT0103903	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCH	137598	C
2,187	UTF -00 -PRESS	UTF-PT0103904	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCH	137599	C
2,188	UTF -00 -PRESS	UTF-PT7400101	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y						I							RRC	RRC-IRCH	137600	C
2,189	UTF -00 -PRESS	UTF-PT7400102	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137601	C
2,190	UTF -00 -PRESS	UTF-PT7400301	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137602	C
2,191	UTF -00 -PRESS	UTF-PT7400302	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137603	C
2,192	UTF -00 -PRESS	UTF-PT7400303	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137604	C
2,193	UTF -00 -PRESS	UTF-PT7400304	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137605	C
2,194	UTF -00 -PRESS	UTF-PT7400305	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137606	C
2,195	UTF -00 -PRESS	UTF-PT7400306	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137607	C
2,196	UTF -00 -PRESS	UTF-PT7400308	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137608	C
2,197	UTF -00 -PRESS	UTF-PT7431101	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137609	C
2,198	UTF -00 -PRESS	UTF-PT7431103	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137610	C
2,199	UTF -75 -PRESS	UTF-PT7500101	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137611	C
2,200	UTF -75 -PRESS	UTF-PT7500202	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137612	C
2,201	UTF -77 -PRESS	UTF-PT7700101	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137613	C
2,202	UTF -77 -PRESS	UTF-PT7700102	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137614	C
2,203	UTF -77 -PRESS	UTF-PT7700201	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137615	C
2,204	UTF -77 -PRESS	UTF-PT7700202	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137616	C
2,205	UTF -77 -PRESS	UTF-PT7700210	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137617	C
2,206	UTF -77 -PRESS	UTF-PT7700401	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137618	C
2,207	UTF -77 -PRESS	UTF-PT7700402	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137619	C
2,208	UTF -77 -PRESS	UTF-PT7700507	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137620	C
2,209	UTF -77 -PRESS	UTF-PT7700601	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137621	C
2,210	UTF -77 -PRESS	UTF-PT7700602	INSP. FIELD INST. (ต่อกุปกรณ์)	PMT	1Y							I						RRC	RRC-IRCH	137622	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT : UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,211	UTF -77 -PRESS	UTF-PT7700603	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137623	C
2,212	UTF -77 -PRESS	UTF-PT7700604	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137624	C
2,213	UTF -77 -PRESS	UTF-PT7700908	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137625	C
2,214	UTF -77 -PRESS	UTF-PT7700909	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137626	C
2,215	UTF -77 -PRESS	UTF-PT7700910	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137627	C
2,216	UTF -77 -PRESS	UTF-PT7701009	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137628	C
2,217	UTF -77 -PRESS	UTF-PT7701102	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137629	C
2,218	UTF -77 -PRESS	UTF-PT7701307	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137630	C
2,219	UTF -77 -PRESS	UTF-PT7701309	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137631	C
2,220	UTF -77 -PRESS	UTF-PT7701310	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137632	C
2,221	UTF -77 -PRESS	UTF-PT7701409	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137633	C
2,222	UTF -77 -PRESS	UTF-PT7701701	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137634	C
2,223	UTF -77 -PRESS	UTF-PT7701801	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137635	C
2,224	UTF -77 -PRESS	UTF-PT7701802	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137636	C
2,225	UTF -77 -PRESS	UTF-PT7701901	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137637	C
2,226	UTF -77 -PRESS	UTF-PT7701902	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137638	C
2,227	UTF -77 -PRESS	UTF-PT7702007	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137639	C
2,228	UTF -77 -PRESS	UTF-PT7705602	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137640	C
2,229	UTF -77 -PRESS	UTF-PT7705704	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137641	C
2,230	UTF -77 -PRESS	UTF-PT7705801	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137642	C
2,231	UTF -77 -PRESS	UTF-PT7705901	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137643	C
2,232	UTF -77 -PRESS	UTF-PT7706201	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137644	C
2,233	UTF -77 -PRESS	UTF-PT7706206	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137645	C
2,234	UTF -77 -PRESS	UTF-PT7731101	INSP., FIELD INST., (ต่อหุ้มไกรน์)	PMT	1Y						I							RRC	RRC-IRCH	137646	C
2,235	UTF -79 -PRESS	UTF-PT7900201	INSP., FIELD INST.PT7900201	PMT	1Y							I						RRC	RRC-IRCH	137647	C
2,236	UTF -79 -PRESS	UTF-PT7900901	INSP., FIELD INST.PT7900901	PMT	1Y									I				RRC	RRC-IRCH	245978	C
2,237	UTF -79 -PRESS	UTF-PT7910201	INSP., FIELD INST.PT7910201	PMT	1Y									I				RRC	RRC-IRCH	245979	C
2,238	UTF -79 -PRESS	UTF-PT7910202	INSP., FIELD INST.PT7910202	PMT	1Y									I				RRC	RRC-IRCH	245980	C
2,239	UTF -79 -PRESS	UTF-PT7931101	INSP., FIELD INST.PT7931101	PMT	1Y									I				RRC	RRC-IRCH	245981	C
2,240	UTF -79 -PRESS	UTF-PT7934104	INSP., FIELD INST.PT7934104	PMT	1Y									I				RRC	RRC-IRCH	245982	C
2,241	UTF -80 -80X001	UTF-PT8050409	INSPECTION PT AND PDT.UTF-PT80	PMT	1Y											I		RRC	RRC-IRCH	255649	C
2,242	UTF -80 -80X001	UTF-PT8050412	INSPECTION PT AND PDT.UTF-PT80	PMT	1Y											I		RRC	RRC-IRCH	255650	C
2,243	UTF -74 -CV	UTF-PV7400101	INSPECT CONTROL VALVE NO. PV74	PMT	1Y									I				RRC	RRC-IRCH	137748	C
2,244	UTF -74 -CV	UTF-PV7400102	INSPECT CONTROL VALVE NO. PV74	PMT	1Y									I				RRC	RRC-IRCH	137749	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT : UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,245	UTF -74 -CV	UTF-PV7400301	INSPECT CONTROL VALVE NO. PV74	PMT	1Y									I				RRC	RRC-IRCH	137750	C
2,246	UTF -74 -CV	UTF-PV7400302	INSPECT CONTROL VALVE NO. PV74	PMT	1Y									I				RRC	RRC-IRCH	137751	C
2,247	UTF -74 -CV	UTF-PV7400303A	INSPECT CONTROL VALVE NO. PV74	PMT	1Y									I				RRC	RRC-IRCH	137752	C
2,248	UTF -74 -CV	UTF-PV7400303B	INSPECT CONTROL VALVE NO. PV74	PMT	1Y									I				RRC	RRC-IRCH	137753	C
2,249	UTF -74 -CV	UTF-PV7400308	INSPECT CONTROL VALVE NO. PV74	PMT	1Y									I				RRC	RRC-IRCH	137754	C
2,250	UTF -77 -CV	UTF-PV7700201	INSPECT CONTROL VALVE NO. PV77	PMT	1Y									I				RRC	RRC-IRCH	137755	C
2,251	UTF -77 -CV	UTF-PV7700402	INSPECT CONTROL VALVE NO. PV77	PMT	1Y									I				RRC	RRC-IRCH	137756	C
2,252	UTF -77 -CV	UTF-PV7700602	INSPECT CONTROL VALVE NO. PV77	PMT	1Y									I				RRC	RRC-IRCH	137757	C
2,253	UTF -77 -CV	UTF-PV7700604	INSPECT CONTROL VALVE NO. PV77	PMT	1Y									I				RRC	RRC-IRCH	137758	C
2,254	UTF -77 -CV	UTF-PV7700909	INSPECT CONTROL VALVE NO. PV77	PMT	1Y									I				RRC	RRC-IRCH	137759	C
2,255	UTF -77 -CV	UTF-PV7700910	INSPECT CONTROL VALVE NO. PV77	PMT	1Y									I				RRC	RRC-IRCH	137760	C
2,256	UTF -77 -CV	UTF-PV7701102	INSPECT CONTROL VALVE NO. PV77	PMT	1Y									I				RRC	RRC-IRCH	137761	C
2,257	UTF -77 -CV	UTF-PV7701802	INSPECT CONTROL VALVE NO. PV77	PMT	1Y									I				RRC	RRC-IRCH	137762	C
2,258	UTF -77 -CV	UTF-PV7701902	INSPECT CONTROL VALVE NO. PV77	PMT	1Y									I				RRC	RRC-IRCH	137763	C
2,259	UTF -77 -CV	UTF-PV7706201	INSPECT CONTROL VALVE NO. PV77	PMT	1Y									I				RRC	RRC-IRCH	137764	C
2,260	UTF -79 -CV	UTF-PV7900201A	INSPECT CONTROL VALVE NO.PV7900201A	PMT	1Y									I				RRC	RRC-IRCH	137765	C
2,261	UTF -79 -CV	UTF-PV7900201B	INSPECT CONTROL VALVE NO.PV7900201B	PMT	1Y									I				RRC	RRC-IRCH	137766	C
2,262	UTF -79 -CV	UTF-PV7900801	INSPECT CONTROL VALVE NO. PV7900801	PMT	1Y											I		RRC	RRC-IRCH	245983	C
2,263	UTF -79 -CV	UTF-PV7900901	INSPECT CONTROL VALVE NO. PV7900901	PMT	1Y											I		RRC	RRC-IRCH	245984	C
2,264	UTF -80 -80X001	UTF-PV8050802	INSPECT CONTROL VALVE NO.UTF-P	PMT	1Y												I	RRC	RRC-IRCH	255651	C
2,265	UTF -74 -74T002	UTF-PVSV7400701	PM; FOR Breather Valve UTF-PVSV7400701	PMT	6M									P				RRC	RRC-MRCH	254629	A
2,266	UTF -77 -77T002A	UTF-PVSV7700101	PM; FOR Breather Valve UTF-PVSV7700101	PMT	6M									P				RRC	RRC-MRCH	254620	A
2,267	UTF -77 -77T002A	UTF-PVSV7700102	PM; FOR Breather Valve UTF-PVSV7700102	PMT	6M									P				RRC	RRC-MRCH	254621	A
2,268	UTF -77 -77T002B	UTF-PVSV7700103	PM; FOR Breather Valve UTF-PVSV7700103	PMT	6M									P				RRC	RRC-MRCH	254622	A
2,269	UTF -77 -77T002B	UTF-PVSV7700104	PM; FOR Breather Valve UTF-PVSV7700104	PMT	6M									P				RRC	RRC-MRCH	254623	A
2,270	UTF -77 -77T005A	UTF-PVSV7700901A	PM; FOR Breather Valve UTF-PVSV7700901A	PMT	6M									P				RRC	RRC-MRCH	254613	A
2,271	UTF -77 -77T005A	UTF-PVSV7700901B	PM; FOR Breather Valve UTF-PVSV7700901B	PMT	6M									P				RRC	RRC-MRCH	254614	A
2,272	UTF -77 -77T005B	UTF-PVSV7700902A	PM; FOR Breather Valve UTF-PVSV7700902A	PMT	6M									P				RRC	RRC-MRCH	254615	A
2,273	UTF -77 -77T005B	UTF-PVSV7700902B	PM; FOR Breather Valve UTF-PVSV7700902B	PMT	6M									P				RRC	RRC-MRCH	254616	A
2,274	UTF -77 -77T014	UTF-PVSV7701001	PM; FOR Breather Valve UTF-PVSV7701001	PMT	6M				P									RRC	RRC-MRCH	254628	A
2,275	UTF -77 -77T006	UTF-PVSV7701101	PM; FOR Breather Valve UTF-PVSV7701101	PMT	6M									P				RRC	RRC-MRCH	254617	A
2,276	UTF -77 -77T007A	UTF-PVSV7701301	PM; FOR Breather Valve UTF-PVSV7701301	PMT	6M									P				RRC	RRC-MRCH	254624	A
2,277	UTF -77 -77T007A	UTF-PVSV7701302	PM; FOR Breather Valve UTF-PVSV7701302	PMT	6M									P				RRC	RRC-MRCH	254625	A
2,278	UTF -77 -77T007B	UTF-PVSV7701303	PM; FOR Breather Valve UTF-PVSV7701303	PMT	6M									P				RRC	RRC-MRCH	254626	A

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT : UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,279	UTF -77 -77T007B	UTF-PVSV7701304	PM; FOR Breather Valve UTF-PVSV7701304	PMT	6M					P						P		RRC	RRC-MRCH	254627	A
2,280	UTF -77 -77T008	UTF-PVSV7701401	PM; FOR Breather Valve UTF-PVSV7701401	PMT	6M			P						P				RRC	RRC-MRCH	254618	A
2,281	UTF -77 -77T012	UTF-PVSV7701701	PM; FOR Breather Valve UTF-PVSV7701701	PMT	6M			P						P				RRC	RRC-MRCH	254619	A
2,282	UTF -80 -80X001	UTF-SE8050601A	INSPECTION SPEED/DISPL.UTF-SE8	PMT	1Y			I										RRC	RRC-IRCH	255564	C
2,283	UTF -80 -80X001	UTF-SE8050601B	INSPECTION SPEED/DISPL.UTF-SE8	PMT	1Y			I										RRC	RRC-IRCH	255565	C
2,284	UTF -80 -80X001	UTF-SE8050602A	INSPECTION SPEED/DISPL.UTF-SE8	PMT	1Y			I										RRC	RRC-IRCH	255566	C
2,285	UTF -80 -80X001	UTF-SE8050602B	INSPECTION SPEED/DISPL.UTF-SE8	PMT	1Y			I										RRC	RRC-IRCH	255567	C
2,286	UTF -80 -80X001	UTF-SE8050602C	INSPECTION SPEED/DISPL.UTF-SE8	PMT	1Y			I										RRC	RRC-IRCH	255568	C
2,287	UTF -01 -SIS	UTF-SIS	INSPECT ESD SYSTEM	PMT	3M	I			I			I				I		CCS	CCS-SYS	246498	A
2,288	UTF -01 -SIS	UTF-SIS	BACKUP ESD SYSTEM	PMT	6M	I						I						CCS	CCS-SYS	246499	A
2,289	UTF -01 -SIS	UTF-SIS	UPDATE ANTIVIRUS ESD SYSTEM	PMT	3M	U			U			U				U		CCS	CCS-SYS	246500	A
2,290	UTF -80 -80X001	UTF-ST8050601A	INSPECTION SPEED/DISPL.UTF-ST8	PMT	1Y			I										RRC	RRC-IRCH	255569	C
2,291	UTF -80 -80X001	UTF-ST8050601B	INSPECTION SPEED/DISPL.UTF-ST8	PMT	1Y			I										RRC	RRC-IRCH	255570	C
2,292	UTF -80 -80X001	UTF-ST8050602A	INSPECTION SPEED/DISPL.UTF-ST8	PMT	1Y			I										RRC	RRC-IRCH	255571	C
2,293	UTF -80 -80X001	UTF-ST8050602B	INSPECTION SPEED/DISPL.UTF-ST8	PMT	1Y			I										RRC	RRC-IRCH	255572	C
2,294	UTF -80 -80X001	UTF-ST8050602C	INSPECTION SPEED/DISPL.UTF-ST8	PMT	1Y			I										RRC	RRC-IRCH	255573	C
2,295	UTF -80 -80X001	UTF-SV8050401	INSPECT CONTROL VALVE NO.UTF-S	PMT	1Y											I		RRC	RRC-IRCH	255658	C
2,296	UTF -80 -80X001	UTF-SV8050402A	INSPECT CONTROL VALVE NO.UTF-S	PMT	1Y											I		RRC	RRC-IRCH	255659	C
2,297	UTF -80 -80X001	UTF-SV8050402B	INSPECT CONTROL VALVE NO.UTF-S	PMT	1Y											I		RRC	RRC-IRCH	255660	C
2,298	UTF -80 -80X001	UTF-SV8050403A	INSPECT CONTROL VALVE NO.UTF-S	PMT	1Y											I		RRC	RRC-IRCH	255661	C
2,299	UTF -80 -80X001	UTF-SV8050403B	INSPECT CONTROL VALVE NO.UTF-S	PMT	1Y											I		RRC	RRC-IRCH	255662	C
2,300	UTF -80 -80X001	UTF-SV8050801A	INSPECT CONTROL VALVE NO.UTF-S	PMT	1Y											I		RRC	RRC-IRCH	255663	C
2,301	UTF -80 -80X001	UTF-SV8050801B	INSPECT CONTROL VALVE NO.UTF-S	PMT	1Y											I		RRC	RRC-IRCH	255664	C
2,302	UTF -80 -80X001	UTF-TCV8050201	INSPECT CONTROL VALVE NO.UTF-T	PMT	1Y											I		RRC	RRC-IRCH	255665	C
2,303	UTF -80 -80X001	UTF-TCV8050403	INSPECT CONTROL VALVE NO.UTF-T	PMT	1Y											I		RRC	RRC-IRCH	255666	C
2,304	UTF -77 -77X101	UTF-TE7750102	Inspection UTF-TE7750102	PMT	1Y						I							RRC	RRC-IRCH	250281	C
2,305	UTF -77 -77X101	UTF-TE7750103	Inspection UTF-TE7750103	PMT	1Y						I							RRC	RRC-IRCH	250282	C
2,306	UTF -77 -77X101	UTF-TE7750105	Inspection UTF-TE7750105	PMT	1Y						I							RRC	RRC-IRCH	250283	C
2,307	UTF -77 -77X101	UTF-TE7750106	Inspection UTF-TE7750106	PMT	1Y						I							RRC	RRC-IRCH	250284	C
2,308	UTF -77 -77X101	UTF-TE7750108	Inspection UTF-TE7750108	PMT	1Y						I							RRC	RRC-IRCH	250285	C
2,309	UTF -77 -77X101	UTF-TE7750109	Inspection UTF-TE7750109	PMT	1Y						I							RRC	RRC-IRCH	250286	C
2,310	UTF -77 -77X101	UTF-TE7750202	Inspection UTF-TE7750202	PMT	1Y						I							RRC	RRC-IRCH	250287	C
2,311	UTF -77 -77X101	UTF-TE7750204	Inspection UTF-TE7750204	PMT	1Y						I							RRC	RRC-IRCH	250288	C
2,312	UTF -77 -77X101	UTF-TE7750206	Inspection UTF-TE7750206	PMT	1Y						I							RRC	RRC-IRCH	250289	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT : UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,313	UTF -77 -77X101	UTF-TE7750208	Inspection UTF-TE7750208	PMT	1Y						I							RRC	RRC-IRCH	250290	C
2,314	UTF -77 -77X101	UTF-TE7750210	Inspection UTF-TE7750210	PMT	1Y						I							RRC	RRC-IRCH	250291	C
2,315	UTF -77 -77X101	UTF-TE7750212	Inspection UTF-TE7750212	PMT	1Y						I							RRC	RRC-IRCH	250292	C
2,316	UTF -77 -77X101	UTF-TE7750214	Inspection UTF-TE7750214	PMT	1Y						I							RRC	RRC-IRCH	250293	C
2,317	UTF -80 -80X001	UTF-TE8050102	INSP., FIELD INST.UTF-TE8050102	PMT	1Y	I												RRC	RRC-IRCH	255511	C
2,318	UTF -80 -80X001	UTF-TE8050104	INSP., FIELD INST.UTF-TE8050104	PMT	1Y	I												RRC	RRC-IRCH	255513	C
2,319	UTF -80 -80X001	UTF-TE8050105	INSP., FIELD INST.UTF-TE8050105	PMT	1Y	I												RRC	RRC-IRCH	255514	C
2,320	UTF -80 -80X001	UTF-TE8050601A	INSP., FIELD INST.UTF-TE8050601	PMT	1Y	I												RRC	RRC-IRCH	255515	C
2,321	UTF -80 -80X001	UTF-TE8050601B	INSP., FIELD INST.UTF-TE8050601	PMT	1Y	I												RRC	RRC-IRCH	255516	C
2,322	UTF -80 -80X001	UTF-TE8050602A	INSP., FIELD INST.UTF-TE8050602	PMT	1Y	I												RRC	RRC-IRCH	255517	C
2,323	UTF -80 -80X001	UTF-TE8050602B	INSP., FIELD INST.UTF-TE8050602	PMT	1Y	I												RRC	RRC-IRCH	255518	C
2,324	UTF -80 -80X001	UTF-TE8050603A	INSP., FIELD INST.UTF-TE8050603	PMT	1Y	I												RRC	RRC-IRCH	255519	C
2,325	UTF -80 -80X001	UTF-TE8050603B	INSP., FIELD INST.UTF-TE8050603	PMT	1Y	I												RRC	RRC-IRCH	255520	C
2,326	UTF -80 -80X001	UTF-TE8050604A	INSP., FIELD INST.UTF-TE8050604	PMT	1Y	I												RRC	RRC-IRCH	255521	C
2,327	UTF -80 -80X001	UTF-TE8050604B	INSP., FIELD INST.UTF-TE8050604	PMT	1Y	I												RRC	RRC-IRCH	255522	C
2,328	UTF -80 -80X001	UTF-TE8050605A	INSP., FIELD INST.UTF-TE8050605	PMT	1Y	I												RRC	RRC-IRCH	255523	C
2,329	UTF -80 -80X001	UTF-TE8050605B	INSP., FIELD INST.UTF-TE8050605	PMT	1Y	I												RRC	RRC-IRCH	255524	C
2,330	UTF -80 -80X001	UTF-TE8050606A	INSP., FIELD INST.UTF-TE8050606	PMT	1Y	I												RRC	RRC-IRCH	255525	C
2,331	UTF -80 -80X001	UTF-TE8050606B	INSP., FIELD INST.UTF-TE8050606	PMT	1Y	I												RRC	RRC-IRCH	255526	C
2,332	UTF -80 -80X001	UTF-TE8050607A	INSP., FIELD INST.UTF-TE8050607	PMT	1Y	I												RRC	RRC-IRCH	255527	C
2,333	UTF -80 -80X001	UTF-TE8050607B	INSP., FIELD INST.UTF-TE8050607	PMT	1Y	I												RRC	RRC-IRCH	255528	C
2,334	UTF -80 -80X001	UTF-TE8050608A	INSP., FIELD INST.UTF-TE8050608	PMT	1Y	I												RRC	RRC-IRCH	255529	C
2,335	UTF -80 -80X001	UTF-TE8050608B	INSP., FIELD INST.UTF-TE8050608	PMT	1Y	I												RRC	RRC-IRCH	255530	C
2,336	UTF -80 -80X001	UTF-TE8050609A	INSP., FIELD INST.UTF-TE8050609	PMT	1Y	I												RRC	RRC-IRCH	255531	C
2,337	UTF -80 -80X001	UTF-TE8050609B	INSP., FIELD INST.UTF-TE8050609	PMT	1Y	I												RRC	RRC-IRCH	255532	C
2,338	UTF -80 -80X001	UTF-TE8050610A	INSP., FIELD INST.UTF-TE8050610	PMT	1Y	I												RRC	RRC-IRCH	255533	C
2,339	UTF -80 -80X001	UTF-TE8050610B	INSP., FIELD INST.UTF-TE8050610	PMT	1Y	I												RRC	RRC-IRCH	255534	C
2,340	UTF -80 -80X001	UTF-TE8050611	INSP., FIELD INST.UTF-TE8050611	PMT	1Y	I												RRC	RRC-IRCH	255535	C
2,341	UTF -80 -80X001	UTF-TE8050612A	INSP., FIELD INST.UTF-TE8050612	PMT	1Y	I												RRC	RRC-IRCH	255536	C
2,342	UTF -80 -80X001	UTF-TE8050612B	INSP., FIELD INST.UTF-TE8050612	PMT	1Y	I												RRC	RRC-IRCH	255537	C
2,343	UTF -80 -80X001	UTF-TE8050613A	INSP., FIELD INST.UTF-TE8050613	PMT	1Y	I												RRC	RRC-IRCH	255538	C
2,344	UTF -80 -80X001	UTF-TE8050613B	INSP., FIELD INST.UTF-TE8050613	PMT	1Y	I												RRC	RRC-IRCH	255539	C
2,345	UTF -80 -80X001	UTF-TE8050614A	INSP., FIELD INST.UTF-TE8050614	PMT	1Y	I												RRC	RRC-IRCH	255540	C
2,346	UTF -80 -80X001	UTF-TE8050614B	INSP., FIELD INST.UTF-TE8050614	PMT	1Y	I												RRC	RRC-IRCH	255541	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,347	UTF -80 -80X001	UTF-TE8050615	INSP. FIELD INST.UTF-TE8050615	PMT	1Y	I												RRC	RRC-IROH	255542	C
2,348	UTF -80 -80X001	UTF-TE8050616	INSP. FIELD INST.UTF-TE8050616	PMT	1Y	I												RRC	RRC-IROH	255543	C
2,349	UTF -80 -80X001	UTF-TE8050617	INSP. FIELD INST.UTF-TE8050617	PMT	1Y	I												RRC	RRC-IROH	255544	C
2,350	UTF -80 -80X001	UTF-TE8050618	INSP. FIELD INST.UTF-TE8050618	PMT	1Y	I												RRC	RRC-IROH	255545	C
2,351	UTF -79 -TEMP	UTF-TG7900801	INSP. FIELD INST.TG7900801	PMT	1Y									I				RRC	RRC-IROH	245985	C
2,352	UTF -79 -TEMP	UTF-TG7901102	INSP. FIELD INST.TG7901102	PMT	1Y									I				RRC	RRC-IROH	245986	C
2,353	UTF -80 -80X001	UTF-TG8050202	INSP. FIELD INST.UTF-TG8050202	PMT	1Y	I												RRC	RRC-IROH	255546	C
2,354	UTF -80 -80X001	UTF-TG8050206	INSP. FIELD INST.UTF-TG8050206	PMT	1Y	I												RRC	RRC-IROH	255547	C
2,355	UTF -80 -80X001	UTF-TG8050301	INSP. FIELD INST.UTF-TG8050301	PMT	1Y	I												RRC	RRC-IROH	255548	C
2,356	UTF -80 -80X001	UTF-TG8050302	VERIFY TEMPERATURE GAUGEUTF-TG	PMT	1Y	V												RRC	RRC-IROH	255549	C
2,357	UTF -80 -80X001	UTF-TG8050401	INSP. FIELD INST.UTF-TG8050401	PMT	1Y	I												RRC	RRC-IROH	255550	C
2,358	UTF -80 -80X001	UTF-TIS8050402	INSP. FIELD INST.UTF-TIS8050040	PMT	1Y	I												RRC	RRC-IROH	255551	C
2,359	UTF -80 -80X001	UTF-TIT8050101	INSP. FIELD INST.UTF-TIT805010	PMT	1Y	I												RRC	RRC-IROH	255552	C
2,360	UTF -80 -80X001	UTF-TIT8050105A	INSP. FIELD INST.UTF-TIT805010	PMT	1Y	I												RRC	RRC-IROH	255553	C
2,361	UTF -80 -80X001	UTF-TIT8050105B	INSP. FIELD INST.UTF-TIT805010	PMT	1Y	I												RRC	RRC-IROH	255554	C
2,362	UTF -80 -80X001	UTF-TIT8050203	INSP. FIELD INST.UTF-TIT805020	PMT	1Y	I												RRC	RRC-IROH	255555	C
2,363	UTF -80 -80X001	UTF-TIT8050204	INSP. FIELD INST.UTF-TIT805020	PMT	1Y	I												RRC	RRC-IROH	255556	C
2,364	UTF -80 -80X001	UTF-TIT8050801	INSP. FIELD INST.UTF-TIT805080	PMT	1Y	I												RRC	RRC-IROH	255557	C
2,365	UTF -80 -80X001	UTF-TIT8050802	INSP. FIELD INST.UTF-TIT805080	PMT	1Y	I												RRC	RRC-IROH	255558	C
2,366	UTF -80 -80X001	UTF-TIT8050803	INSP. FIELD INST.UTF-TIT805080	PMT	1Y	I												RRC	RRC-IROH	255559	C
2,367	UTF -80 -80X001	UTF-TSHH8050205	INSP. FIELD INST.UTF-TSHH80502	PMT	1Y	I												RRC	RRC-IROH	255560	C
2,368	UTF -01 -TEMP	UTF-TT0103501	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137670	C
2,369	UTF -01 -TEMP	UTF-TT0103504	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137671	C
2,370	UTF -01 -TEMP	UTF-TT0103507	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137672	C
2,371	UTF -01 -TEMP	UTF-TT0103508	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137673	C
2,372	UTF -01 -TEMP	UTF-TT0103511	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137674	C
2,373	UTF -01 -TEMP	UTF-TT0103903	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137675	C
2,374	UTF -01 -TEMP	UTF-TT0103904	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137676	C
2,375	UTF -74 -TEMP	UTF-TT7400101	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137677	C
2,376	UTF -74 -TEMP	UTF-TT7400301	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137678	C
2,377	UTF -74 -TEMP	UTF-TT7400302	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137679	C
2,378	UTF -74 -TEMP	UTF-TT7400303	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137680	C
2,379	UTF -74 -TEMP	UTF-TT7400304	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137681	C
2,380	UTF -74 -TEMP	UTF-TT7400305	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137682	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,381	UTF -74 -TEMP	UTF-TT7400306	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137683	C
2,382	UTF -74 -TEMP	UTF-TT7400308	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137684	C
2,383	UTF -74 -TEMP	UTF-TT7400601	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137685	C
2,384	UTF -74 -TEMP	UTF-TT7400602	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137686	C
2,385	UTF -74 -TEMP	UTF-TT7431101	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137687	C
2,386	UTF -74 -TEMP	UTF-TT7431103	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137688	C
2,387	UTF -74 -74X001	UTF-TT7450701	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y								I					RRC	RRC-IROH	137710	C
2,388	UTF -74 -74X001	UTF-TT7450901	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y								I					RRC	RRC-IROH	137711	C
2,389	UTF -74 -74X001	UTF-TT7451101	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y								I					RRC	RRC-IROH	137712	C
2,390	UTF -74 -74X001	UTF-TT7451102	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y								I					RRC	RRC-IROH	137713	C
2,391	UTF -75 -TEMP	UTF-TT7500101	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137689	C
2,392	UTF -75 -TEMP	UTF-TT7500202	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137690	C
2,393	UTF -77 -TEMP	UTF-TT7700103	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137691	C
2,394	UTF -77 -TEMP	UTF-TT7700104	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y							I						RRC	RRC-IROH	137692	C
2,395	UTF -77 -TEMP	UTF-TT7700501	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y								I					RRC	RRC-IROH	137693	C
2,396	UTF -77 -TEMP	UTF-TT7701303	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y								I					RRC	RRC-IROH	137694	C
2,397	UTF -77 -TEMP	UTF-TT7701304	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y								I					RRC	RRC-IROH	137695	C
2,398	UTF -77 -TEMP	UTF-TT7701402	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y								I					RRC	RRC-IROH	137696	C
2,399	UTF -77 -TEMP	UTF-TT7701503	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y								I					RRC	RRC-IROH	137697	C
2,400	UTF -77 -TEMP	UTF-TT7702101	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y								I					RRC	RRC-IROH	137698	C
2,401	UTF -77 -TEMP	UTF-TT7705602	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y								I					RRC	RRC-IROH	137699	C
2,402	UTF -77 -TEMP	UTF-TT7705701	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y								I					RRC	RRC-IROH	137700	C
2,403	UTF -77 -TEMP	UTF-TT7705702	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y								I					RRC	RRC-IROH	137701	C
2,404	UTF -77 -TEMP	UTF-TT7705703	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y								I					RRC	RRC-IROH	137702	C
2,405	UTF -77 -TEMP	UTF-TT7705801	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y								I					RRC	RRC-IROH	137703	C
2,406	UTF -77 -TEMP	UTF-TT7705802	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y								I					RRC	RRC-IROH	137704	C
2,407	UTF -77 -TEMP	UTF-TT7705901	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y								I					RRC	RRC-IROH	137705	C
2,408	UTF -77 -TEMP	UTF-TT7706201	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y								I					RRC	RRC-IROH	137706	C
2,409	UTF -77 -TEMP	UTF-TT7706202	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y								I					RRC	RRC-IROH	137707	C
2,410	UTF -77 -TEMP	UTF-TT7706203	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y								I					RRC	RRC-IROH	137708	C
2,411	UTF -77 -TEMP	UTF-TT7731101	INSP. FIELD INST. (ต่อหุ้มไกรมั่)	PMT	1Y								I					RRC	RRC-IROH	137709	C
2,412	UTF -79 -79T002	UTF-TT7900601	INSP. FIELD INST.TT7900601	PMT	1Y									I				RRC	RRC-IROH	245987	C
2,413	UTF -79 -79T002	UTF-TT7900602	INSP. FIELD INST.TT7900602	PMT	1Y									I				RRC	RRC-IROH	245988	C
2,414	UTF -79 -TEMP	UTF-TT7900801	INSP. FIELD INST.TT7900801	PMT	1Y									I				RRC	RRC-IROH	245989	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,415	UTF -79 -TEMP	UTF-TT7900802	INSP. FIELD INST.TT7900802	PMT	1Y									I				RRC	RRC-IROH	245990	C
2,416	UTF -79 -TEMP	UTF-TT7900803	INSP. FIELD INST.TT7900803	PMT	1Y									I				RRC	RRC-IROH	245991	C
2,417	UTF -79 -79R002	UTF-TT7901001	INSP. FIELD INST.TT7901001	PMT	1Y									I				RRC	RRC-IROH	245992	C
2,418	UTF -79 -TEMP	UTF-TT7901101	INSP. FIELD INST.TT7901101	PMT	1Y									I				RRC	RRC-IROH	245993	C
2,419	UTF -79 -TEMP	UTF-TT7910101	INSP. FIELD INST.TT7910101	PMT	1Y									I				RRC	RRC-IROH	245994	C
2,420	UTF -79 -TEMP	UTF-TT7931101	INSP. FIELD INST.TT7931101	PMT	1Y									I				RRC	RRC-IROH	245995	C
2,421	UTF -79 -TEMP	UTF-TT7934102	INSP. FIELD INST.TT7934102	PMT	1Y									I				RRC	RRC-IROH	245996	C
2,422	UTF -74 -CV	UTF-TV7400301	INSPECT CONTROL VALVE NO. TV74	PMT	1Y									I				RRC	RRC-IROH	137767	C
2,423	UTF -74 -CV	UTF-TV7400302	INSPECT CONTROL VALVE NO. TV74	PMT	1Y									I				RRC	RRC-IROH	137768	C
2,424	UTF -74 -CV	UTF-TV7400303	INSPECT CONTROL VALVE NO. TV74	PMT	1Y									I				RRC	RRC-IROH	137769	C
2,425	UTF -77 -CV	UTF-TV7700103	INSPECT CONTROL VALVE NO. TV77	PMT	1Y									I				RRC	RRC-IROH	137770	C
2,426	UTF -77 -CV	UTF-TV7700104	INSPECT CONTROL VALVE NO. TV77	PMT	1Y									I				RRC	RRC-IROH	137771	C
2,427	UTF -77 -CV	UTF-TV7701303	INSPECT CONTROL VALVE NO. TV77	PMT	1Y									I				RRC	RRC-IROH	137772	C
2,428	UTF -77 -CV	UTF-TV7701304	INSPECT CONTROL VALVE NO. TV77	PMT	1Y									I				RRC	RRC-IROH	137773	C
2,429	UTF -77 -CV	UTF-TV7701402	INSPECT CONTROL VALVE NO. TV77	PMT	1Y									I				RRC	RRC-IROH	137774	C
2,430	UTF -77 -CV	UTF-TV7706201	INSPECT CONTROL VALVE NO. TV77	PMT	1Y									I				RRC	RRC-IROH	137775	C
2,431	UTF -79 -CV	UTF-TV7900801	INSPECT CONTROL VALVE NO. TV7900801	PMT	1Y										I			RRC	RRC-IROH	245997	C
2,432	UTF -79 -CV	UTF-TV7901101	INSPECT CONTROL VALVE NO. TV7901101	PMT	1Y										I			RRC	RRC-IROH	245998	C
2,433	UTF -80 -80X001	UTF-TW8050101	INSP. FIELD INST.UTF-TW8050101	PMT	1Y	I												RRC	RRC-IROH	255561	C
2,434	UTF -80 -80X001	UTF-UK8050401	INSPECT CONTROL VALVE NO.UTF-U	PMT	1Y											I		RRC	RRC-IROH	255667	C
2,435	UTF -80 -80X001	UTF-VE8050619	INSPECT VIBRA AND TEMP.UTF-VE8	PMT	1Y					I								RRC	RRC-IROH	255574	C
2,436	UTF -80 -80X001	UTF-VE8050620	INSPECT VIBRA AND TEMP.UTF-VE8	PMT	1Y					I								RRC	RRC-IROH	255575	C
2,437	UTF -80 -80X001	UTF-VEX8050601	INSPECT VIBRA AND TEMP.UTF-VEX	PMT	1Y					I								RRC	RRC-IROH	255576	C
2,438	UTF -80 -80X001	UTF-VEX8050602	INSPECT VIBRA AND TEMP.UTF-VEX	PMT	1Y					I								RRC	RRC-IROH	255577	C
2,439	UTF -80 -80X001	UTF-VEX8050603	INSPECT VIBRA AND TEMP.UTF-VEX	PMT	1Y					I								RRC	RRC-IROH	255578	C
2,440	UTF -80 -80X001	UTF-VEX8050604	INSPECT VIBRA AND TEMP.UTF-VEX	PMT	1Y					I								RRC	RRC-IROH	255579	C
2,441	UTF -80 -80X001	UTF-VEX8050605	INSPECT VIBRA AND TEMP.UTF-VEX	PMT	1Y					I								RRC	RRC-IROH	255580	C
2,442	UTF -80 -80X001	UTF-VEX8050606	INSPECT VIBRA AND TEMP.UTF-VEX	PMT	1Y					I								RRC	RRC-IROH	255581	C
2,443	UTF -80 -80X001	UTF-VEY8050601	INSPECT VIBRA AND TEMP.UTF-VEY	PMT	1Y					I								RRC	RRC-IROH	255582	C
2,444	UTF -80 -80X001	UTF-VEY8050602	INSPECT VIBRA AND TEMP.UTF-VEY	PMT	1Y					I								RRC	RRC-IROH	255583	C
2,445	UTF -80 -80X001	UTF-VEY8050603	INSPECT VIBRA AND TEMP.UTF-VEY	PMT	1Y					I								RRC	RRC-IROH	255584	C
2,446	UTF -80 -80X001	UTF-VEY8050604	INSPECT VIBRA AND TEMP.UTF-VEY	PMT	1Y					I								RRC	RRC-IROH	255585	C
2,447	UTF -80 -80X001	UTF-VEY8050605	INSPECT VIBRA AND TEMP.UTF-VEY	PMT	1Y					I								RRC	RRC-IROH	255586	C
2,448	UTF -80 -80X001	UTF-VEY8050606	INSPECT VIBRA AND TEMP.UTF-VEY	PMT	1Y					I								RRC	RRC-IROH	255587	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,449	UTF -80 -80X001	UTF-VTX8050601	INSPECT VIBRA/AXIAL TRANS.UTF-	PMT	1Y					I								RRC	RRC-IROH	255588	C
2,450	UTF -80 -80X001	UTF-VTX8050602	INSPECT VIBRA/AXIAL TRANS.UTF-	PMT	1Y					I								RRC	RRC-IROH	255589	C
2,451	UTF -80 -80X001	UTF-VTX8050603	INSPECT VIBRA/AXIAL TRANS.UTF-	PMT	1Y					I								RRC	RRC-IROH	255590	C
2,452	UTF -80 -80X001	UTF-VTX8050604	INSPECT VIBRA/AXIAL TRANS.UTF-	PMT	1Y					I								RRC	RRC-IROH	255591	C
2,453	UTF -80 -80X001	UTF-VTX8050605	INSPECT VIBRA/AXIAL TRANS.UTF-	PMT	1Y					I								RRC	RRC-IROH	255592	C
2,454	UTF -80 -80X001	UTF-VTX8050606	INSPECT VIBRA/AXIAL TRANS.UTF-	PMT	1Y					I								RRC	RRC-IROH	255593	C
2,455	UTF -80 -80X001	UTF-VTY8050601	INSPECT VIBRA/AXIAL TRANS.UTF-	PMT	1Y					I								RRC	RRC-IROH	255594	C
2,456	UTF -80 -80X001	UTF-VTY8050602	INSPECT VIBRA/AXIAL TRANS.UTF-	PMT	1Y					I								RRC	RRC-IROH	255595	C
2,457	UTF -80 -80X001	UTF-VTY8050603	INSPECT VIBRA/AXIAL TRANS.UTF-	PMT	1Y					I								RRC	RRC-IROH	255596	C
2,458	UTF -80 -80X001	UTF-VTY8050604	INSPECT VIBRA/AXIAL TRANS.UTF-	PMT	1Y					I								RRC	RRC-IROH	255597	C
2,459	UTF -80 -80X001	UTF-VTY8050605	INSPECT VIBRA/AXIAL TRANS.UTF-	PMT	1Y					I								RRC	RRC-IROH	255598	C
2,460	UTF -80 -80X001	UTF-VTY8050606	INSPECT VIBRA/AXIAL TRANS.UTF-	PMT	1Y					I								RRC	RRC-IROH	255599	C
2,461	UTF -74 -CV	UTF-XV7400101	INSPECT CONTROL VALVE NO. XV74	PMT	1Y										I			RRC	RRC-IROH	137794	C
2,462	UTF -74 -CV	UTF-XV7400601	INSPECT CONTROL VALVE NO. XV74	PMT	1Y										I			RRC	RRC-IROH	137795	C
2,463	UTF -74 -CV	UTF-XV7400602	INSPECT CONTROL VALVE NO. XV74	PMT	1Y										I			RRC	RRC-IROH	137796	C
2,464	UTF -75 -75F001A	UTF-XV7500301	INSPECT CONTROL VALVE NO. XV75	PMT	1Y											I		RRC	RRC-IROH	137915	C
2,465	UTF -75 -75F001A	UTF-XV7500302	INSPECT CONTROL VALVE NO. XV75	PMT	1Y											I		RRC	RRC-IROH	137916	C
2,466	UTF -77 -CV	UTF-XV7700101	INSPECT CONTROL VALVE NO. XV77	PMT	1Y										I			RRC	RRC-IROH	137797	C
2,467	UTF -77 -CV	UTF-XV7700102	INSPECT CONTROL VALVE NO. XV77	PMT	1Y										I			RRC	RRC-IROH	137798	C
2,468	UTF -77 -CV	UTF-XV7700103	INSPECT CONTROL VALVE NO. XV77	PMT	1Y										I			RRC	RRC-IROH	137799	C
2,469	UTF -77 -CV	UTF-XV7700104	INSPECT CONTROL VALVE NO. XV77	PMT	1Y										I			RRC	RRC-IROH	137800	C
2,470	UTF -77 -CV	UTF-XV7700106	INSPECT CONTROL VALVE NO. XV77	PMT	1Y										I			RRC	RRC-IROH	137801	C
2,471	UTF -77 -CV	UTF-XV7700108	INSPECT CONTROL VALVE NO. XV77	PMT	1Y										I			RRC	RRC-IROH	137802	C
2,472	UTF -77 -CV	UTF-XV7700201	INSPECT CONTROL VALVE NO. XV77	INS	1Y										I			RRC	RRC-IROH	137803	C
2,473	UTF -77 -CV	UTF-XV7700201	XV7700201-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261521	C
2,474	UTF -77 -CV	UTF-XV7700202	INSPECT CONTROL VALVE NO. XV77	INS	1Y										I			RRC	RRC-IROH	137804	C
2,475	UTF -77 -CV	UTF-XV7700202	XV7700202-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261522	C
2,476	UTF -77 -CV	UTF-XV7700203	INSPECT CONTROL VALVE NO. XV77	PMT	1Y										I			RRC	RRC-IROH	137805	C
2,477	UTF -77 -CV	UTF-XV7700401	INSPECT CONTROL VALVE NO. XV77	INS	1Y										I			RRC	RRC-IROH	137806	C
2,478	UTF -77 -CV	UTF-XV7700401	XV7700401-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261523	C
2,479	UTF -77 -CV	UTF-XV7700402	INSPECT CONTROL VALVE NO. XV77	INS	1Y										I			RRC	RRC-IROH	137807	C
2,480	UTF -77 -CV	UTF-XV7700402	XV7700402-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261524	C
2,481	UTF -77 -CV	UTF-XV7700403	INSPECT CONTROL VALVE NO. XV77	PMT	1Y										I			RRC	RRC-IROH	137808	C
2,482	UTF -77 -CV	UTF-XV7700404	INSPECT CONTROL VALVE NO. XV77	PMT	1Y										I			RRC	RRC-IROH	137809	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,483	UTF -77 -CV	UTF-XV7700405	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137810	C
2,484	UTF -77 -CV	UTF-XV7700405	XV7700405-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261525	C
2,485	UTF -77 -CV	UTF-XV7700406	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137811	C
2,486	UTF -77 -CV	UTF-XV7700407	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137812	C
2,487	UTF -77 -CV	UTF-XV7700408	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137813	C
2,488	UTF -77 -CV	UTF-XV7700409	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137814	C
2,489	UTF -77 -CV	UTF-XV7700501	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137815	C
2,490	UTF -77 -CV	UTF-XV7700502	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137816	C
2,491	UTF -77 -CV	UTF-XV7700503	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137817	C
2,492	UTF -77 -CV	UTF-XV7700504	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137818	C
2,493	UTF -77 -CV	UTF-XV7700505	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137819	C
2,494	UTF -77 -CV	UTF-XV7700506	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137820	C
2,495	UTF -77 -CV	UTF-XV7700507	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137821	C
2,496	UTF -77 -CV	UTF-XV7700508	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137822	C
2,497	UTF -77 -CV	UTF-XV7700601	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137823	C
2,498	UTF -77 -CV	UTF-XV7700601	XV7700601-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261532	C
2,499	UTF -77 -CV	UTF-XV7700602	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137824	C
2,500	UTF -77 -CV	UTF-XV7700602	XV7700602-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261533	C
2,501	UTF -77 -CV	UTF-XV7700603	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137825	C
2,502	UTF -77 -CV	UTF-XV7700604	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137826	C
2,503	UTF -77 -CV	UTF-XV7700605	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137827	C
2,504	UTF -77 -CV	UTF-XV7700606	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137828	C
2,505	UTF -77 -CV	UTF-XV7700901	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137829	C
2,506	UTF -77 -CV	UTF-XV7700901	XV7700901-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261534	C
2,507	UTF -77 -CV	UTF-XV7700902	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137830	C
2,508	UTF -77 -CV	UTF-XV7700902	XV7700902-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261535	C
2,509	UTF -77 -CV	UTF-XV7700903	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137831	C
2,510	UTF -77 -CV	UTF-XV7700903	XV7700903-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261536	C
2,511	UTF -77 -CV	UTF-XV7700904	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137832	C
2,512	UTF -77 -CV	UTF-XV7700904	XV7700904-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261537	C
2,513	UTF -77 -CV	UTF-XV7701001	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137833	C
2,514	UTF -77 -CV	UTF-XV7701001	XV7701001-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261538	C
2,515	UTF -77 -CV	UTF-XV7701002	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137834	C
2,516	UTF -77 -CV	UTF-XV7701002	XV7701002-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261539	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,517	UTF -77 -CV	UTF-XV7701101	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137835	C
2,518	UTF -77 -CV	UTF-XV7701101	XV7701101-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261540	C
2,519	UTF -77 -CV	UTF-XV7701102	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137836	C
2,520	UTF -77 -CV	UTF-XV7701102	XV7701102-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261541	C
2,521	UTF -77 -CV	UTF-XV7701107	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137837	C
2,522	UTF -77 -CV	UTF-XV7701108	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137838	C
2,523	UTF -77 -CV	UTF-XV7701301	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137839	C
2,524	UTF -77 -CV	UTF-XV7701301	XV7701301-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261542	C
2,525	UTF -77 -CV	UTF-XV7701302	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137840	C
2,526	UTF -77 -CV	UTF-XV7701302	XV7701302-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261543	C
2,527	UTF -77 -CV	UTF-XV7701303	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137841	C
2,528	UTF -77 -CV	UTF-XV7701303	XV7701303-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261545	C
2,529	UTF -77 -CV	UTF-XV7701304	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137842	C
2,530	UTF -77 -CV	UTF-XV7701304	XV7701304-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261546	C
2,531	UTF -77 -CV	UTF-XV7701305	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137843	C
2,532	UTF -77 -CV	UTF-XV7701305	XV7701305-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261544	C
2,533	UTF -77 -CV	UTF-XV7701306	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137844	C
2,534	UTF -77 -CV	UTF-XV7701306	XV7701306-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261547	C
2,535	UTF -77 -CV	UTF-XV7701401	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137845	C
2,536	UTF -77 -CV	UTF-XV7701401	XV7701401-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261548	C
2,537	UTF -77 -CV	UTF-XV7701402	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137846	C
2,538	UTF -77 -CV	UTF-XV7701402	XV7701402-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261549	C
2,539	UTF -77 -CV	UTF-XV7701501	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137847	C
2,540	UTF -77 -CV	UTF-XV7701501	XV7701501-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261550	C
2,541	UTF -77 -CV	UTF-XV7701601	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137848	C
2,542	UTF -77 -CV	UTF-XV7701601	XV7701601-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261551	C
2,543	UTF -77 -CV	UTF-XV7701701	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137849	C
2,544	UTF -77 -CV	UTF-XV7701701	XV7701701-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261552	C
2,545	UTF -77 -CV	UTF-XV7701801	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137850	C
2,546	UTF -77 -CV	UTF-XV7701801	XV7701801-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261526	C
2,547	UTF -77 -CV	UTF-XV7701802	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137851	C
2,548	UTF -77 -CV	UTF-XV7701802	XV7701802-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261527	C
2,549	UTF -77 -CV	UTF-XV7701803	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137852	C
2,550	UTF -77 -CV	UTF-XV7701804	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137853	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,551	UTF -77 -CV	UTF-XV7701805	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137854	C
2,552	UTF -77 -CV	UTF-XV7701805	XV7701805-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261528	C
2,553	UTF -77 -CV	UTF-XV7701806	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137855	C
2,554	UTF -77 -CV	UTF-XV7701807	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137856	C
2,555	UTF -77 -CV	UTF-XV7701808	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137857	C
2,556	UTF -77 -CV	UTF-XV7701809	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137858	C
2,557	UTF -77 -CV	UTF-XV7701901	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137859	C
2,558	UTF -77 -CV	UTF-XV7701901	XV7701901-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261529	C
2,559	UTF -77 -CV	UTF-XV7701902	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137860	C
2,560	UTF -77 -CV	UTF-XV7701902	XV7701902-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261530	C
2,561	UTF -77 -CV	UTF-XV7701903	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137861	C
2,562	UTF -77 -CV	UTF-XV7701904	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137862	C
2,563	UTF -77 -CV	UTF-XV7701905	INSPECT CONTROL VALVE NO. XV77	INS	1Y											I		RRC	RRC-IROH	137863	C
2,564	UTF -77 -CV	UTF-XV7701905	XV7701905-FULL FUNC. TEST SHUT	PMT	5Y											F		RRC	RRC-IROH	261531	C
2,565	UTF -77 -CV	UTF-XV7701906	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137864	C
2,566	UTF -77 -CV	UTF-XV7701907	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137865	C
2,567	UTF -77 -CV	UTF-XV7701908	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137866	C
2,568	UTF -77 -CV	UTF-XV7701909	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137867	C
2,569	UTF -77 -CV	UTF-XV7705801	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137868	C
2,570	UTF -77 -CV	UTF-XV7705901	INSPECT CONTROL VALVE NO. XV77	PMT	1Y											I		RRC	RRC-IROH	137869	C
2,571	UTF -79 -CV	UTF-XV7900401	INSPECT CONTROL VALVE NO. XV7900401	PMT	1Y											I		RRC	RRC-IROH	245999	C
2,572	UTF -79 -CV	UTF-XV7900402	INSPECT CONTROL VALVE NO. XV7900402	PMT	1Y											I		RRC	RRC-IROH	246000	C
2,573	UTF -79 -CV	UTF-XV7900501	INSPECT CONTROL VALVE NO. XV7900501	PMT	1Y											I		RRC	RRC-IROH	246001	C
2,574	UTF -79 -CV	UTF-XV7900601	INSPECT CONTROL VALVE NO. XV7900601	PMT	1Y											I		RRC	RRC-IROH	246002	C
2,575	UTF -79 -CV	UTF-XV7900701	INSPECT CONTROL VALVE NO. XV7900701	PMT	1Y											I		RRC	RRC-IROH	246003	C
2,576	UTF -79 -CV	UTF-XV7900702	INSPECT CONTROL VALVE NO. XV7900702	PMT	1Y											I		RRC	RRC-IROH	246004	C
2,577	UTF -79 -CV	UTF-XV7900801	INSPECT CONTROL VALVE NO. XV7900801	PMT	1Y											I		RRC	RRC-IROH	246005	C
2,578	UTF -79 -CV	UTF-XV7900901	INSPECT CONTROL VALVE NO. XV7900901	PMT	1Y											I		RRC	RRC-IROH	246006	C
2,579	UTF -79 -CV	UTF-XV7900902	INSPECT CONTROL VALVE NO. XV7900902	PMT	1Y											I		RRC	RRC-IROH	246007	C
2,580	UTF -79 -CV	UTF-XV7900903	INSPECT CONTROL VALVE NO. XV7900903	PMT	1Y											I		RRC	RRC-IROH	246008	C
2,581	UTF -79 -CV	UTF-XV7901001	INSPECT CONTROL VALVE NO. XV7901001	PMT	1Y											I		RRC	RRC-IROH	246009	C
2,582	UTF -79 -CV	UTF-XV7901101	INSPECT CONTROL VALVE NO. XV7901101	PMT	1Y												I	RRC	RRC-IROH	246010	C
2,583	UTF -79 -CV	UTF-XV7901201	INSPECT CONTROL VALVE NO. XV7901201	PMT	1Y												I	RRC	RRC-IROH	246011	C
2,584	UTF -79 -CV	UTF-XV7901202	INSPECT CONTROL VALVE NO. XV7901202	PMT	1Y												I	RRC	RRC-IROH	246012	C

PREVENTIVE MAINTENANCE YEARLY SCHEDULE
PLANT: UTF YEAR: 2022

Form No.
Effective Date 20.12.2021
Revision 0

Legend Text : B = Program Back-up C = Calibrate F = Function Test H = Overhaul I = Inspect L = Lubricate M = Strategy Plan P = Preventive Q = Check oil quality
S = Service T = Stand by condition check U = Running condition check V = Verify

Item	FL No.	Equipment No.	Maintenance Plan Description	Maint.	Cycle	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Section	Work Center	Main. Plan	ABC In.
2,585	UTF -79 -CV	UTF-XV7910101	INSPECT CONTROL VALVE NO. XV7910101	PMT	1Y												I	RRC	RRC-IROH	246013	C
2,586	UTF -79 -CV	UTF-XV7910102	INSPECT CONTROL VALVE NO. XV7910102	PMT	1Y												I	RRC	RRC-IROH	246014	C
2,587	UTF -79 -CV	UTF-XV7910103	INSPECT CONTROL VALVE NO. XV7910103	PMT	1Y												I	RRC	RRC-IROH	246015	C
2,588	UTF -79 -CV	UTF-XV7910201	INSPECT CONTROL VALVE NO. XV7910201	PMT	1Y												I	RRC	RRC-IROH	246016	C
2,589	UTF -79 -CV	UTF-XV7910202	INSPECT CONTROL VALVE NO. XV7910202	PMT	1Y												I	RRC	RRC-IROH	246017	C
2,590	UTF -79 -CV	UTF-XV7910203	INSPECT CONTROL VALVE NO. XV7910203	PMT	1Y												I	RRC	RRC-IROH	246018	C
2,591	UTF -79 -CV	UTF-XV7910204	INSPECT CONTROL VALVE NO. XV7910204	PMT	1Y												I	RRC	RRC-IROH	246019	C
2,592	UTF -79 -CV	UTF-XV7910205	INSPECT CONTROL VALVE NO. XV7910205	PMT	1Y												I	RRC	RRC-IROH	246020	C
2,593	UTF -79 -CV	UTF-XV7910206	INSPECT CONTROL VALVE NO. XV7910206	PMT	1Y												I	RRC	RRC-IROH	246021	C
2,594	UTF -79 -CV	UTF-XV7910207	INSPECT CONTROL VALVE NO. XV7910207	PMT	1Y												I	RRC	RRC-IROH	246022	C
2,595	UTF -79 -CV	UTF-XV7910208	INSPECT CONTROL VALVE NO. XV7910208	PMT	1Y												I	RRC	RRC-IROH	246023	C
2,596	UTF -79 -CV	UTF-XV7910301	INSPECT CONTROL VALVE NO. XV7910301	PMT	1Y												I	RRC	RRC-IROH	246024	C
2,597	UTF -79 -CV	UTF-XV7910302	INSPECT CONTROL VALVE NO. XV7910302	PMT	1Y												I	RRC	RRC-IROH	246025	C
2,598	UTF -79 -CV	UTF-XV7910303	INSPECT CONTROL VALVE NO. XV7910303	PMT	1Y												I	RRC	RRC-IROH	246026	C
2,599	UTF -79 -CV	UTF-XV7910308	INSPECT CONTROL VALVE NO. XV7910308	PMT	1Y												I	RRC	RRC-IROH	246027	C
2,600	UTF -79 -CV	UTF-XV7910401	INSPECT CONTROL VALVE NO. XV7910401	PMT	1Y												I	RRC	RRC-IROH	246028	C
2,601	UTF -79 -CV	UTF-XV7910402	INSPECT CONTROL VALVE NO. XV7910402	PMT	1Y												I	RRC	RRC-IROH	246029	C
2,602	UTF -80 -80X001	UTF-XV8050109	INSPECTION SHUT-OFF VALVEUTF-X	PMT	1Y												I	RRC	RRC-IROH	255668	C
2,603	UTF -80 -80X001	UTF-ZE8050601A	INSPECT VIBRA AND TEMP.UTF-ZE8	PMT	1Y					I								RRC	RRC-IROH	255600	C
2,604	UTF -80 -80X001	UTF-ZE8050601B	INSPECT VIBRA AND TEMP.UTF-ZE8	PMT	1Y					I								RRC	RRC-IROH	255601	C
2,605	UTF -80 -80X001	UTF-ZSH8050401	INSPECT CONTROL VALVE NO.UTF-Z	PMT	1Y												I	RRC	RRC-IROH	255669	C
2,606	UTF -80 -80X001	UTF-ZSH8050403A	INSPECT CONTROL VALVE NO.UTF-Z	PMT	1Y												I	RRC	RRC-IROH	255670	C
2,607	UTF -80 -80X001	UTF-ZSH8050403B	INSPECT CONTROL VALVE NO.UTF-Z	PMT	1Y												I	RRC	RRC-IROH	255671	C
2,608	UTF -80 -80X001	UTF-ZSL8050301	INSPECT CONTROL VALVE NO.UTF-Z	PMT	1Y												I	RRC	RRC-IROH	255672	C
2,609	UTF -80 -80X001	UTF-ZSL8050401	INSPECT CONTROL VALVE NO.UTF-Z	PMT	1Y												I	RRC	RRC-IROH	255673	C
2,610	UTF -80 -80X001	UTF-ZSL8050402A	INSPECT CONTROL VALVE NO.UTF-Z	PMT	1Y												I	RRC	RRC-IROH	255674	C
2,611	UTF -80 -80X001	UTF-ZSL8050402B	INSPECT CONTROL VALVE NO.UTF-Z	PMT	1Y												I	RRC	RRC-IROH	255675	C
2,612	UTF -80 -80X001	UTF-ZT8050404	INSPECT CONTROL VALVE NO.UTF-Z	PMT	1Y												I	RRC	RRC-IROH	255676	C
2,613	UTF -80 -80X001	UTF-ZT8050601A	INSPECT VIBRA/AXIAL TRANS.UTF-	PMT	1Y					I								RRC	RRC-IROH	255602	C
2,614	UTF -80 -80X001	UTF-ZT8050601B	INSPECT VIBRA/AXIAL TRANS.UTF-	PMT	1Y					I								RRC	RRC-IROH	255603	C
2,615	UTF -80 -80X001	UTF-ZT8050801	INSPECT VIBRA/AXIAL TRANS.UTF-	PMT	1Y					I								RRC	RRC-IROH	255677	C
2,616	UTF -80 -80X001	UTF-ZT8050802	INSPECT VIBRA/AXIAL TRANS.UTF-	PMT	1Y					I								RRC	RRC-IROH	255678	C

