

ใบรับรองการก่อสร้างอาคาร ตัดแปลงอาคาร หรือเคลื่อนย้ายอาคาร (แบบ อ.6)



ใบรับรองการก่อสร้างอาคาร ตัดแปลงอาคาร หรือเคลื่อนย้ายอาคาร

เลขที่.....53 / 2563

ใบรับรองฉบับนี้แสดงว่า.....บริษัท โอโซ่ กะตะ จำกัด.....เจ้าของอาคาร
อยู่บ้านเลขที่.....๔๔.....ตรอก/ซอย.....ถนน.....กะตะ.....หมู่ที่.....
ตำบล/แขวง.....กระน.....อำเภอ/เขต.....เมืองภูเก็ต.....จังหวัด.....ภูเก็ต.....
ได้ทำการ.....ก่อสร้าง.....อาคารเป็นไปโดยถูกต้องตามที่ได้รับอนุญาตในใบอนุญาต
เลขที่.....๖๐...../.....๒๕๖๐.....ลงวันที่.....๑๐.....เดือน.....กันยายน.....พ.ศ.๒๕๖๐.....ซึ่งอาคารดังกล่าว
เป็นอาคารประเภทควบคุมการใช้ เจ้าพนักงานท้องถิ่นจึงออกใบรับรองให้ดังต่อไปนี้

ข้อ ๑. เป็นอาคาร

(๑) ชนิด.....ค.ส.ล. ๕ ชั้น (อาคาร A).....จำนวน.....๑ หลัง.....
เพื่อใช้เป็น.....โรงแรม (๑๔๘ ห้องพัก).....โดยมีที่จอดรถ ที่กั๊บลร และทางเข้าออกของรถ
จำนวน.....-.....คัน

(๒) ชนิด.....ค.ส.ล. ๕ ชั้น (อาคาร B).....จำนวน.....๑ หลัง.....
เพื่อใช้เป็น.....โรงแรม (๑๐๗ ห้องพัก).....โดยมีที่จอดรถ ที่กั๊บลร และทางเข้าออกของรถ
จำนวน.....-.....คัน

(๓) ชนิด.....ค.ส.ล. ๒ ชั้น (อาคาร C).....จำนวน.....๑ หลัง.....
เพื่อใช้เป็น.....อาคารห้องอาหาร.....โดยมีที่จอดรถ ที่กั๊บลร และทางเข้าออกของรถ
จำนวน.....-.....คัน

ที่บ้านเลขที่.....-.....ตรอก/ซอย.....-.....ถนน.....กะตะ.....
หมู่ที่.....-.....ตำบล/แขวง.....กระน..... อำเภอ/เขต.....เมืองภูเก็ต..... จังหวัด.....ภูเก็ต.....
โดย.....บริษัท โอโซ่ กะตะ จำกัด.....เป็นเจ้าของอาคาร
และ.....บริษัท โอโซ่ กะตะ จำกัด.....เป็นผู้ครอบครองอาคาร
อยู่ในที่ดินโฉนดที่ดิน เลขที่/น.ส.๓/ส.ค.๓ เลขที่.....๓๘๗๕๙ , ๓๘๗๖๐ , ๓๘๗๗๕.....
เป็นที่ดินของ.....บริษัท ยี. เอ็ม. อาร์ จำกัด.....

ข้อ ๒. ผู้ได้รับใบรับรองต้องปฏิบัติตามเงื่อนไข ดังต่อไปนี้

(๑) ผู้ได้รับใบรับรองต้องปฏิบัติตามหลักเกณฑ์ วิธีการ และเงื่อนไขตามที่กำหนดในกฎกระทรวง
และหรือข้อบัญญัติท้องถิ่น ซึ่งออกตามความในมาตรา ๘ (๑๑) มาตรา ๙ หรือมาตรา ๑๐ แห่งพระราชบัญญัติ
ควบคุมอาคาร พ.ศ. ๒๕๒๒

(๒) ผู้ได้รับอนุญาตต้องปฏิบัติตามมาตรการป้องกันและแก้ไขสิ่งแวดล้อมที่แนบท้ายนี้

ออกให้ ณ วันที่ 20 เดือน สิงหาคม พ.ศ. 2563

(ลายมือชื่อ)
นายทวี ทองแถม
(.....)
นายกเทศมนตรีตำบลกระน

ตำแหน่ง

เจ้าพนักงานท้องถิ่นผู้รับรอง

คำเตือน

๑. ห้ามเจ้าของ หรือผู้ครอบครองอาคารใช้หรือยินยอมให้บุคคลใดใช้อาคารเพื่อกิจการอื่น นอกจากที่ระบุไว้ในใบรับรองฉบับนี้
๒. ห้ามเจ้าของ หรือผู้ครอบครองอาคารเปลี่ยนการใช้อาคารประเภทควบคุมการใช้สำหรับกิจการหนึ่งไปใช้สำหรับอีกกิจการหนึ่ง เว้นแต่จะได้รับใบอนุญาตจากเจ้าพนักงานท้องถิ่น
๓. ห้ามเจ้าของ หรือผู้ครอบครองอาคารที่ต้องมีพื้นที่หรือสิ่งก่อสร้างขึ้นเพื่อใช้เป็นที่พักจอดรถ ที่กั๊บลรล และทางเข้าออกของรลตามที่กำหนดในกฎกระทรวง ดัดแปลง หรือใช้ที่พักจอดรถ ที่กั๊บลรล และทางเข้าออกของรลนั้นเพื่อการอื่นไม่ว่าทั้งหมดหรือบางส่วน เว้นแต่จะได้รับใบอนุญาตจากเจ้าพนักงานท้องถิ่น
๔. ผู้ได้รับใบรับรองต้องแสดงใบรับรองฉบับนี้ไว้ในที่เปิดเผยและเห็นได้ง่าย ณ อาคารนั้น



ใบรับรองการก่อสร้างอาคาร ตัดแปลงอาคาร หรือเคลื่อนย้ายอาคาร

เลขที่ 53 / 2563

ใบรับรองฉบับนี้แสดงว่า.....บริษัท โอโซ่ กะตะ จำกัด.....เจ้าของอาคาร
อยู่บ้านเลขที่.....๙๙.....ตรอก/ซอย.....-.....ถนน.....กะตะ.....หมู่ที่.....-.....
ตำบล/แขวง.....กะรน.....อำเภอ/เขต.....เมืองภูเก็ต.....จังหวัด.....ภูเก็ต.....
ได้ทำการ.....ก่อสร้าง.....อาคารเป็นไปโดยถูกต้องตามที่ได้รับอนุญาตในใบอนุญาต
เลขที่.....๖๐...../.....๒๕๖๐.....ลงวันที่.....๑๐.....เดือน.....กันยายน.....พ.ศ.๒๕๖๐.....ซึ่งอาคารดังกล่าว
เป็นอาคารประเภทควบคุมการใช้ เจ้าพนักงานท้องถิ่นจึงออกใบรับรองให้ดังต่อไปนี้

ข้อ ๑. เป็นอาคาร

(๑) ชนิด.....ค.ส.ล. ๒ ชั้น (อาคาร D).....จำนวน.....๑ หลัง.....
เพื่อใช้เป็น.....ร้านค้า , ห้องกำเนิดไฟฟ้า.....โดยมีที่จอดรถ ที่กั๊บลร และทางเข้าออกของรถ
จำนวน.....-.....คัน

(๒) ชนิด.....ค.ส.ล. ชั้นเดียว.....จำนวน.....๑ หลัง.....
เพื่อใช้เป็น.....อาคารห้องพักรยะ.....โดยมีที่จอดรถ ที่กั๊บลร และทางเข้าออกของรถ
จำนวน.....-.....คัน

(๓) ชนิด.....ค.ส.ล. ชั้นเดียว.....จำนวน.....๑ หลัง.....
เพื่อใช้เป็น.....อาคารปั้มน้ำ.....โดยมีที่จอดรถ ที่กั๊บลร และทางเข้าออกของรถ
จำนวน.....-.....คัน

ที่บ้านเลขที่.....-.....ตรอก/ซอย.....-.....ถนน.....กะตะ.....
หมู่ที่.....-.....ตำบล/แขวง.....กะรน..... อำเภอ/เขต.....เมืองภูเก็ต..... จังหวัด.....ภูเก็ต.....
โดย.....บริษัท โอโซ่ กะตะ จำกัด.....เป็นเจ้าของอาคาร
และ.....บริษัท โอโซ่ กะตะ จำกัด.....เป็นผู้ครอบครองอาคาร
อยู่ในที่ดินโฉนดที่ดิน เลขที่/น.ส.๓/ส.๓ เลขที่.....๓๘๗๕๙ , ๓๘๗๖๐ , ๓๘๗๗๕
เป็นที่ดินของ.....บริษัท ยี. เอ็ม. อาร์ จำกัด.....

ข้อ ๒. ผู้ได้รับใบรับรองต้องปฏิบัติตามเงื่อนไข ดังต่อไปนี้

(๑) ผู้ได้รับใบรับรองต้องปฏิบัติตามหลักเกณฑ์ วิธีการ และเงื่อนไขตามที่กำหนดในกฎกระทรวง
และหรือข้อบัญญัติท้องถิ่น ซึ่งออกตามความในมาตรา ๘ (๑๑) มาตรา ๙ หรือมาตรา ๑๐ แห่งพระราชบัญญัติ
ควบคุมอาคาร พ.ศ. ๒๕๖๒

(๒) ผู้ได้รับอนุญาตต้องปฏิบัติตามมาตรการป้องกันและแก้ไขสิ่งแวดล้อมที่แนบท้ายนี้

ออกให้ ณ วันที่ 20 เดือน สิงหาคม พ.ศ. ๒563

(ลายมือชื่อ)

นายทวี ทองแถม

นายกเทศมนตรีตำบลกะรน

ตำแหน่ง

เจ้าพนักงานท้องถิ่นผู้รับรอง

คำเตือน

๑. ห้ามเจ้าของ หรือผู้ครอบครองอาคารใช้หรือยินยอมให้บุคคลใดใช้อาคารเพื่อกิจการอื่น นอกจากที่ระบุไว้ในใบรับรองฉบับนี้
๒. ห้ามเจ้าของ หรือผู้ครอบครองอาคารเปลี่ยนการใช้อาคารประเภทควบคุมการใช้สำหรับกิจการหนึ่งไปใช้สำหรับอีกกิจการหนึ่ง เว้นแต่จะได้รับใบอนุญาตจากเจ้าพนักงานท้องถิ่น
๓. ห้ามเจ้าของ หรือผู้ครอบครองอาคารที่ต้องมีพื้นที่หรือสิ่งก่อสร้างขึ้นเพื่อใช้เป็นที่จอดรถ ที่กักเก็บรถ และทางเข้าออกของรถตามที่กำหนดในกฎกระทรวง ดัดแปลง หรือใช้ที่จอดรถ ที่กักเก็บรถ และทางเข้าออกของรถนั้นเพื่อการอื่นไม่ว่าทั้งหมดหรือบางส่วน เว้นแต่จะได้รับใบอนุญาตจากเจ้าพนักงานท้องถิ่น
๔. ผู้ได้รับใบรับรองต้องแสดงใบรับรองฉบับนี้ไว้ในที่เปิดเผยและเห็นได้ง่าย ณ อาคารนั้น



ใบรับรองการก่อสร้างอาคาร ตัดแปลงอาคาร หรือเคลื่อนย้ายอาคาร

เลขที่.....53 / 2563

ใบรับรองฉบับนี้แสดงว่า.....บริษัท โอโซ่ กะตะ จำกัด.....เจ้าของอาคาร
อยู่บ้านเลขที่.....๔๔.....ตรอก/ซอย.....-.....ถนน.....กะตะ.....หมู่ที่.....-.....
ตำบล/แขวง.....กระน.....อำเภอ/เขต.....เมืองภูเก็ต.....จังหวัด.....ภูเก็ต.....
ได้ทำการ.....ก่อสร้าง.....อาคารเป็นไปโดยถูกต้องตามที่ได้รับอนุญาตในใบอนุญาต
เลขที่.....๖๐...../.....๒๕๖๐.....ลงวันที่.....๑๐.....เดือน.....กันยายน.....พ.ศ. ๒๕๖๐.....ซึ่งอาคารดังกล่าว
เป็นอาคารประเภทควบคุมการใช้ เจ้าพนักงานท้องถิ่นจึงออกใบรับรองให้ดังต่อไปนี้

ข้อ ๑. เป็นอาคาร

(๑) ชนิด.....ค.ส.ล. ชั้นเดียว.....จำนวน.....๑ หลัง.....
เพื่อใช้เป็น.....อาคารห้องน้ำ.....โดยมีที่จอดรถ ที่กั๊บลัด และทางเข้าออกของรถ
จำนวน.....-.....คัน

(๒) ชนิด.....สระว่ายน้ำ.....จำนวน.....๑ สระ.....
เพื่อใช้เป็น.....สระว่ายน้ำ.....โดยมีที่จอดรถ ที่กั๊บลัด และทางเข้าออกของรถ
จำนวน.....-.....คัน

(๓) ชนิด.....สระว่ายน้ำเด็ก.....จำนวน.....๑ สระ.....
เพื่อใช้เป็น.....สระว่ายน้ำเด็ก.....โดยมีที่จอดรถ ที่กั๊บลัด และทางเข้าออกของรถ
จำนวน.....-.....คัน

(๔) ชนิด.....ที่จอดรถ.....จำนวน.....๗๐ คัน.....
เพื่อใช้เป็น.....ที่จอดรถ.....โดยมีที่จอดรถ ที่กั๊บลัด และทางเข้าออกของรถ
จำนวน.....-.....คัน

ที่บ้านเลขที่.....-.....ตรอก/ซอย.....-.....ถนน.....กะตะ.....
หมู่ที่.....-.....ตำบล/แขวง.....กระน.....อำเภอ/เขต.....เมืองภูเก็ต.....จังหวัด.....ภูเก็ต.....
โดย.....บริษัท โอโซ่ กะตะ จำกัด.....เป็นเจ้าของอาคาร
และ.....บริษัท โอโซ่ กะตะ จำกัด.....เป็นผู้ครอบครองอาคาร
อยู่ในที่ดินโฉนดที่ดิน เลขที่/น.ส.๓/ส.ค.๑ เลขที่.....๓๘๗๕๕ , ๓๘๗๖๐ , ๓๘๗๗๕.....
เป็นที่ดินของ.....บริษัท ยี.เอ็ม.อาร์ จำกัด.....

ข้อ ๒. ผู้ได้รับใบรับรองต้องปฏิบัติตามเงื่อนไข ดังต่อไปนี้

(๑) ผู้ได้รับใบรับรองต้องปฏิบัติตามหลักเกณฑ์ วิธีการ และเงื่อนไขตามที่กำหนดในกฎกระทรวง
และหรือข้อบัญญัติท้องถิ่น ซึ่งออกตามความในมาตรา ๘ (๑๑) มาตรา ๙ หรือมาตรา ๑๐ แห่งพระราชบัญญัติ
ควบคุมอาคาร พ.ศ. ๒๕๖๒

(๒) ผู้ได้รับอนุญาตต้องปฏิบัติตามมาตรการป้องกันและแก้ไขสิ่งแวดล้อมที่แนบท้ายนี้

ออกให้ ณ วันที่.....20.....เดือน.....สิงหาคม.....พ.ศ. 2563

(ลายมือชื่อ).....

(นายทวี ทองข้าม)

ตำแหน่ง นายกเทศมนตรีตำบลกระน

เจ้าพนักงานท้องถิ่นผู้รับรอง

คำเตือน

๑. ห้ามเจ้าของ หรือผู้ครอบครองอาคารใช้หรือยินยอมให้บุคคลใดใช้อาคารเพื่อกิจการอื่น นอกจากที่ระบุไว้ในใบรับรองฉบับนี้
๒. ห้ามเจ้าของ หรือผู้ครอบครองอาคารเปลี่ยนการใช้อาคารประเภทควบคุมการใช้สำหรับกิจการหนึ่งไปใช้สำหรับอีกกิจการหนึ่ง เว้นแต่จะได้รับใบอนุญาตจากเจ้าพนักงานท้องถิ่น
๓. ห้ามเจ้าของ หรือผู้ครอบครองอาคารที่ต้องมีพื้นที่หรือสิ่งก่อสร้างขึ้นเพื่อใช้เป็นที่พักจอดรถ ที่กั๊บลรกด และทางเข้าออกของรกดตามที่กำหนดในกฎกระทรวง ดัดแปลง หรือใช้ที่จอดรถ ที่กั๊บลรกด และทางเข้าออกของรกดนั้นเพื่อการอื่นไม่ว่าทั้งหมดหรือบางส่วน เว้นแต่จะได้รับใบอนุญาตจากเจ้าพนักงานท้องถิ่น
๔. ผู้ได้รับใบรับรองต้องแสดงใบรับรองฉบับนี้ไว้ในที่เปิดเผยและเห็นได้ง่าย ณ อาคารนั้น

ภาคผนวกที่ 8

จำนวนพนักงานบริษัท โอโซ่ กระตะ จำกัด

จำนวนพนักงานที่มีภูมิลำเนาอยู่ใน จ.ภูเก็ต ต่อจำนวนพนักงาน
ทั้งหมด

* จำนวนพนักงานทั้งหมด 82 คน

* จำนวนพนักงานที่มีภูมิลำเนาอยู่ใน จ.ภูเก็ต ทั้งหมด 47 คน

= 82 : 47 คน

ภาคผนวกที่ 9

ประกาศแต่งตั้งคณะกรรมการความปลอดภัย อาชีวอนามัย
และสภาพแวดล้อมในการทำงาน

คำสั่ง/ประกาศ
บริษัท โอโซ่ กะตะ จำกัด
(โรงแรมโอโซ่ ภูเก็ต)

เรื่อง แต่งตั้งคณะกรรมการความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงาน

ความปลอดภัยในการทำงานเป็นหน้าที่และความรับผิดชอบร่วมกันระหว่างฝ่ายบริหาร และพนักงานในสถานประกอบกิจการ ดังนั้น เพื่อให้การบริหารงานความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงานได้รับความร่วมมือและมีประสิทธิภาพ จึงขอแต่งตั้งบุคคลดังต่อไปนี้ เป็นคณะกรรมการความปลอดภัยอาชีวอนามัยและสภาพแวดล้อมในการทำงาน

- | | | |
|------------------------------------|---------------|--------------------------------------|
| 1. นางสาวสนธยา ทองมีสุข | 5839990001875 | ประธานกรรมการ |
| 2. นายสุเมศ เนียมมณี | 1809900033834 | กรรมการผู้แทนนายจ้างระดับบังคับบัญชา |
| 3. นางสาวจิราภรณ์ ลักษณะสมบูรณ์ | 3820500103604 | กรรมการผู้แทนนายจ้างระดับบังคับบัญชา |
| 4. นางสาวเปี่ยมบุญย์ ตติยะอภิรักษ์ | 3841200288758 | กรรมการผู้แทนนายจ้างระดับบังคับบัญชา |
| 5. นายวินัย เฟื่องเกิด | 3920100284341 | กรรมการผู้แทนนายจ้างระดับบังคับบัญชา |
| 6. นายชวิวัฒน์ วิบูลย์พรรณา | 1401000018134 | กรรมการผู้แทนนายจ้างระดับบังคับบัญชา |
| 7. นายจักรพันธ์ ชาวปิ่น | 1529900513049 | กรรมการผู้แทนลูกจ้าง |
| 8. นางสาวจิราภรณ์ ใหม่ชู | 1930500187304 | กรรมการผู้แทนลูกจ้าง |
| 9. นายเกียรติศักดิ์ แดงพรม | 1800800023804 | กรรมการผู้แทนลูกจ้าง |
| 10. นายศิวกร อุษย | 1929900413393 | กรรมการผู้แทนลูกจ้าง |
| 11. นายสนานพงศ์ สุภาวรรณ | 1830300062002 | กรรมการผู้แทนลูกจ้าง |
| 12. นางสาวณัฏฐา บำรุง | 1839900308752 | กรรมการผู้แทนลูกจ้าง |
| 13. นางสาวจันทร์เพ็ญ จามจุรี | 1800800239785 | กรรมการและเลขานุการ |

โดยให้คณะกรรมการความปลอดภัยมีหน้าที่และอำนาจ ดังต่อไปนี้

1. จัดทำนโยบายด้านความปลอดภัยอาชีวอนามัยและสภาพแวดล้อมในการทำงานของสถานประกอบกิจการเสนอต่อนายจ้าง
2. จัดทำแนวทางการป้องกันและลดการเกิดอุบัติเหตุ การประสบอันตราย การเจ็บป่วยหรือการเกิดเหตุเดือดร้อนรำคาญอันเนื่องมาจากการทำงานของลูกจ้างหรือความไม่ปลอดภัยในการทำงานเสนอต่อ นายจ้าง

3. รายงาน และเสนอแนะมาตรการหรือแนวทางปรับปรุงแก้ไขสภาพการทำงานและสภาพแวดล้อมในการทำงาน ให้เป็นไปตามกฎหมายเกี่ยวกับความปลอดภัยในการทำงานต่อนายจ้างเพื่อความปลอดภัยในการทำงานของลูกจ้าง ผู้รับเหมาและบุคคลภายนอกที่เข้ามาปฏิบัติงานหรือเข้ามาใช้บริการในสถานประกอบกิจการ
4. ส่งเสริมและสนับสนุนกิจกรรมด้านความปลอดภัยในการทำงานของสถานประกอบกิจการ
5. พิจารณาคู่มือว่าด้วยความปลอดภัยอาชีวอนามัยและสภาพแวดล้อมในการทำงานของสถานประกอบกิจการเพื่อเสนอความเห็นต่อนายจ้าง
6. ดำรงการปฏิบัติการด้านความปลอดภัยในการทำงานและรายงานผลการสำรวจดังกล่าว รวมทั้งสถิติการประสบอันตรายที่เกิดขึ้นในสถานประกอบกิจการนั้น ในการประชุมคณะกรรมการความปลอดภัยทุกครั้ง
7. พิจารณาโครงการหรือแผนการฝึกอบรมเกี่ยวกับความปลอดภัยในการทำงาน รวมถึงโครงการหรือแผนการอบรมเกี่ยวกับบทบาทหน้าที่ความรับผิดชอบในด้านความปลอดภัยของลูกจ้าง หัวหน้างาน ผู้บริหาร นายจ้างและบุคลากรทุกระดับเพื่อเสนอความเห็นต่อนายจ้าง
8. จัดวางระบบให้ลูกจ้างทุกคนทุกระดับมีหน้าที่ต้องรายงานสภาพการทำงานที่ไม่ปลอดภัยต่อนายจ้าง
9. ติดตามผลความคืบหน้าเรื่องที่เสนอต่อนายจ้าง
10. รายงานผลการปฏิบัติงานประจำปี รวมทั้งระบุปัญหา อุปสรรคและข้อเสนอแนะในการปฏิบัติหน้าที่ของคณะกรรมการความปลอดภัยเมื่อปฏิบัติหน้าที่ครบหนึ่งปีเสนอต่อนายจ้าง
11. ประเมินผลการดำเนินงานด้านความปลอดภัยในการทำงานของสถานประกอบกิจการ
12. ปฏิบัติงานด้านความปลอดภัยในการทำงานอื่นตามที่นายจ้างมอบหมาย

ทั้งนี้ ให้คณะกรรมการความปลอดภัย อาชีวอนามัยและสภาพแวดล้อมในการทำงาน ปฏิบัติหน้าที่ตั้งแต่วันที่ 1 สิงหาคม 2565 ถึงวันที่ 31 กรกฎาคม 2567



ประกาศ ณ วันที่ 24 มีนาคม 2566

ลงชื่อ..... *สมพร นพรัตน์*

(นางสาวสนธยา ทองมีสุข)



นายจ้าง/ผู้แทนนายจ้าง

ภาคผนวกที่ 10

Checklist อุปกรณ์ดับเพลิง ประจำเดือนมกราคม – มิถุนายน 2566

Section: 10 – Portable Fire Extinguishers (PFE's)
Title: Monthly Check of all Portable Fire Extinguishers
Responsible Person: Manager Engineer
File Number: FLS 10-02

Property: OZO KATA PHUKET
Month : 1-Jan-23
Pages: 3 pages

Seq.	Asset Tag	Description	Size	Year Purchased/R efilled	Location	Tag		Physical		Pressure Gauge			Weight	Check & Inspection By	Date	Remark
						Normal	Abnormal	Normal	Abnormal	Recharge	195	Over Charged				
01	OKP-PFE-001	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A1/1	/		/			/		Kg			
02	OKP-PFE-002	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A1	/		/			/		Kg			
03	OKP-PFE-003	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A1/2	/		/			/		Kg			
04	OKP-PFE-004	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A2/1	/		/			/		Kg			
05	OKP-PFE-005	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A2	/		/			/		Kg			
06	OKP-PFE-006	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A2/2	/		/			/		Kg			
07	OKP-PFE-007	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A3/1	/		/			/		Kg			
08	OKP-PFE-008	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A3	/		/			/		Kg			
09	OKP-PFE-009	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A3/2	/		/			/		Kg			
10	OKP-PFE-010	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A4/1	/		/			/		Kg			
11	OKP-PFE-011	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A4	/		/			/		Kg			
12	OKP-PFE-012	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A4/2	/		/			/		Kg			
13	OKP-PFE-013	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A5/1	/		/			/		Kg			
14	OKP-PFE-014	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A5	/		/			/		Kg			
15	OKP-PFE-015	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A5/2	/		/			/		Kg			
16	OKP-PFE-016	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B1	/		/			/		Kg			
17	OKP-PFE-017	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B1/1	/		/			/		Kg			
18	OKP-PFE-018	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B1/2	/		/			/		Kg			
19	OKP-PFE-019	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B2	/		/			/		Kg			
20	OKP-PFE-020	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B2/1	/		/			/		Kg			
21	OKP-PFE-021	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B2/2	/		/			/		Kg			
22	OKP-PFE-022	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B3	/		/			/		Kg			
23	OKP-PFE-023	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B3/1	/		/			/		Kg			
24	OKP-PFE-024	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B3/2	/		/			/		Kg			
25	OKP-PFE-025	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B4	/		/			/		Kg			
26	OKP-PFE-026	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B4/1	/		/			/		Kg			
27	OKP-PFE-027	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B4/2	/		/			/		Kg			

Section: 10 – Portable Fire Extinguishers (PFE's)
Title: Monthly Check of all Portable Fire Extinguishers
Responsible Person: Manager Engineer
File Number: FLS 10-02

Property: OZO KATA PHUKET
Month : 1-Jan-23
Pages: 3 pages

Seq.	Asset Tag	Description	Size	Year Purchased/R efilled	Location	Tag		Physical		Pressure Gauge			Weight	Check & Inspection By	Date	Remark
						Normal	Abnormal	Normal	Abnormal	Recharge	195	Over Charged				
28	OKP-PFE-028	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B5	/		/			/		Kg			
29	OKP-PFE-029	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B5/1	/		/			/		Kg			
30	OKP-PFE-030	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B5/2	/		/			/		Kg			
31	OKP-PFE-031	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet Pool bar	/		/			/		Kg			
32	OKP-PFE-032	A,B,C Dry Chemical	6.8 Kg	2019	Engineer office	/		/			/		Kg			
33	OKP-PFE-033	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet EAT Toilet	/		/			/		Kg			
34	OKP-PFE-034	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room C1	/		/			/		Kg			
35	OKP-PFE-035	B,C Carbon Dioxide (Co2)	10 LB	2019	AHU room C2	/		/			/		Kg			
36	OKP-PFE-036	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room C2	/		/			/		Kg			
37	OKP-PFE-037	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet C2	/		/			/		Kg			
38	OKP-PFE-038	B,C Carbon Dioxide (Co2)	10 LB	2019	Staff canteen	/		/			/		Kg			
39	OKP-PFE-039	B,C Carbon Dioxide (Co2)	10 LB	2019	Generator room	/		/			/		Kg			
40	OKP-PFE-040	A,B,C Dry Chemical	6.8 Kg	2019	Fire Cart	/		/			/		Kg			
41	OKP-PFE-041	A,B,C Dry Chemical	6.8 Kg	2019	Fire Cart	/		/			/		Kg			
42	OKP-PFE-042	A,B,C Dry Chemical	6.8 Kg	2019	Fire Cart	/		/			/		Kg			
43	OKP-PFE-043	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet D Floor 1	/		/			/		Kg			
44	OKP-PFE-044	B,C Carbon Dioxide (Co2)	10 LB	2019	MDR room	/		/			/		Kg			
45	OKP-PFE-045	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet D Floor 2	/		/			/		Kg			
46	OKP-PFE-046	A,B,C Dry Chemical	6.8 Kg	2019	Gas Station	/		/			/		Kg			
47	OKP-PFE-047	A,B,C Dry Chemical	6.8 Kg	2019	Gas Station	/		/			/		Kg			
48	OKP-PFE-048	A,B,C Dry Chemical	6.8 Kg	2019	Beside Chill room	/		/			/		Kg			
49	OKP-PFE-049	A,B,C Dry Chemical	6.8 Kg	2019	Spot Area	/		/			/		Kg			
50	OKP-PFE-050	A,B,C Dry Chemical	6.8 Kg	2019	Building A/2	/		/			/		Kg			
51	OKP-PFE-051	A,B,C Dry Chemical	6.8 Kg	2019	Building A/3 (Room 1440)	/		/			/		Kg			
52	OKP-PFE-052	A,B,C Dry Chemical	6.8 Kg	2019	Building A/3 (Room 1401)	/		/			/		Kg			
53	OKP-PFE-053	A,B,C Dry Chemical	6.8 Kg	2019	Building A/4 (Room 1538)	/		/			/		Kg			
54	OKP-PFE-054	A,B,C Dry Chemical	6.8 Kg	2019	Building A/4 (Room 1501)	/		/			/		Kg			

Section: 10 – Portable Fire Extinguishers (PFE's)
Title: Monthly Check of all Portable Fire Extinguishers
Responsible Person: Manager Engineer
File Number: FLS 10-02

Property: OZO KATA PHUKET
Month : 1-Jan-23
Pages: 3 pages

Seq.	Asset Tag	Description	Size	Year Purchased/R efilled	Location	Tag		Physical		Pressure Gate			Weight	Check & Inspection By	Date	Remark
						Normal	Abnormal	Normal	Abnormal	Recharge	195	Over Charged				
55	OKP-PFE-055	A,B,C Dry Chemical	6.8 Kg	2019	Building A/5 (Room 1638)	/		/			/		Kg		20/1/23	
56	OKP-PFE-056	A,B,C Dry Chemical	6.8 Kg	2019	Building A/5 (Room 1601)	/		/			/		Kg			
57	OKP-PFE-057	A,B,C Dry Chemical	6.8 Kg	2019	Building D/2.1	/		/			/		Kg			
58	OKP-PFE-058	A,B,C Dry Chemical	6.8 Kg	2019	Building D/2.2	/		/			/		Kg			
59	OKP-PFE-059	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet D/2	/		/			/		Kg			
60	OKP-PFE-060	A,B,C Dry Chemical	6.8 Kg	2019	Building C/2 (Roof Top)	/		/			/		Kg			
61	OKP-PFE-061	A,B,C Dry Chemical	6.8 Kg	2019	Building A (Lift service)	/		/			/		Kg			
62	OKP-PFE-062	A,B,C Dry Chemical	6.8 Kg	2019	Fir cart Building B/4	/		/			/		Kg			
63																
64																
65																

Manager Engineering :
Name : Mr.Sumet Niammune
Employee Number : 0139

Manager Security:
Name : Mr.Washirawat Wiboonphonthan
Employee Number :



Signed, Dated and Rubber
Stamped by the Chief
Engineer/Manager - Security


Section: 10 – Portable Fire Extinguishers (PFE's)
Title: Monthly Check of all Portable Fire Extinguishers
Responsible Person: Manager Engineer
File Number: FLS 10-02

Property: OZO KATA PHUKET
Month : 1-Feb-23
Pages: 3 pages

Seq.	Asset Tag	Description	Size	Year Purchased/R efilled	Location	Tag		Physical		Pressure Gauge			Weight	Check & Inspection By	Date	Remark
						Normal	Abnormal	Normal	Abnormal	Recharge	195	Over Charged				
01	OKP-PFE-001	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A1/1	✓		✓			✓		Kg			
02	OKP-PFE-002	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A1	✓		✓			✓		Kg			
03	OKP-PFE-003	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A1/2	✓		✓			✓		Kg			
04	OKP-PFE-004	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A2/1	✓		✓			✓		Kg			
05	OKP-PFE-005	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A2	✓		✓			✓		Kg			
06	OKP-PFE-006	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A2/2	✓		✓			✓		Kg			
07	OKP-PFE-007	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A3/1	✓		✓			✓		Kg			
08	OKP-PFE-008	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A3	✓		✓			✓		Kg			
09	OKP-PFE-009	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A3/2	✓		✓			✓		Kg			
10	OKP-PFE-010	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A4/1	✓		✓			✓		Kg			
11	OKP-PFE-011	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A4	✓		✓			✓		Kg			
12	OKP-PFE-012	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A4/2	✓		✓			✓		Kg			
13	OKP-PFE-013	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A5/1	✓		✓			✓		Kg			
14	OKP-PFE-014	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A5	✓		✓			✓		Kg			
15	OKP-PFE-015	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A5/2	✓		✓			✓		Kg			
16	OKP-PFE-016	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B1	✓		✓			✓		Kg			
17	OKP-PFE-017	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B1/1	✓		✓			✓		Kg			
18	OKP-PFE-018	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B1/2	✓		✓			✓		Kg			
19	OKP-PFE-019	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B2	✓		✓			✓		Kg			
20	OKP-PFE-020	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B2/1	✓		✓			✓		Kg			
21	OKP-PFE-021	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B2/2	✓		✓			✓		Kg			
22	OKP-PFE-022	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B3	✓		✓			✓		Kg			
23	OKP-PFE-023	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B3/1	✓		✓			✓		Kg			
24	OKP-PFE-024	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B3/2	✓		✓			✓		Kg			
25	OKP-PFE-025	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B4	✓		✓			✓		Kg			
26	OKP-PFE-026	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B4/1	✓		✓			✓		Kg			
27	OKP-PFE-027	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B4/2	✓		✓			✓		Kg			

Section: 10 – Portable Fire Extinguishers (PFE's)
Title: Monthly Check of all Portable Fire Extinguishers
Responsible Person: Manager Engineer
File Number: FLS 10-02

Property: OZO KATA PHUKET
Month : 1-Feb-23
Pages: 3 pages

Seq.	Asset Tag	Description	Size	Year Purchased/R efilled	Location	Tag		Physical		Pressure Gauge			Weight	Check & Inspection By	Date	Remark
						Normal	Abnormal	Normal	Abnormal	Recharge	195	Over Charged				
28	OKP-PFE-028	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B5	/		/			/		Kg			
29	OKP-PFE-029	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B5/1	/		/			/		Kg			
30	OKP-PFE-030	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B5/2	/		/			/		Kg			
31	OKP-PFE-031	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet Pool bar	/		/			/		Kg			
32	OKP-PFE-032	A,B,C Dry Chemical	6.8 Kg	2019	Engineer office	/		/			/		Kg			
33	OKP-PFE-033	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet EAT Toilet	/		/			/		Kg			
34	OKP-PFE-034	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room C1	/		/			/		Kg			
35	OKP-PFE-035	B,C Carbon Dioxide (Co2)	10 LB	2019	AHU room C2	/		/			/		Kg			
36	OKP-PFE-036	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room C2	/		/			/		Kg			
37	OKP-PFE-037	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet C2	/		/			/		Kg			
38	OKP-PFE-038	B,C Carbon Dioxide (Co2)	10 LB	2019	Staff canteen	/		/			/		Kg			
39	OKP-PFE-039	B,C Carbon Dioxide (Co2)	10 LB	2019	Generator room	/		/			/		Kg			
40	OKP-PFE-040	A,B,C Dry Chemical	6.8 Kg	2019	Fire Cart	/		/			/		Kg			
41	OKP-PFE-041	A,B,C Dry Chemical	6.8 Kg	2019	Fire Cart	/		/			/		Kg			
42	OKP-PFE-042	A,B,C Dry Chemical	6.8 Kg	2019	Fire Cart	/		/			/		Kg			
43	OKP-PFE-043	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet D Floor 1	/		/			/		Kg			
44	OKP-PFE-044	B,C Carbon Dioxide (Co2)	10 LB	2019	MDB room	/		/			/		Kg			
45	OKP-PFE-045	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet D Floor 2	/		/			/		Kg			
46	OKP-PFE-046	A,B,C Dry Chemical	6.8 Kg	2019	Gas Station	/		/			/		Kg			
47	OKP-PFE-047	A,B,C Dry Chemical	6.8 Kg	2019	Gas Station	/		/			/		Kg			
48	OKP-PFE-048	A,B,C Dry Chemical	6.8 Kg	2019	Beside Chill room	/		/			/		Kg			
49	OKP-PFE-049	A,B,C Dry Chemical	6.8 Kg	2019	Spot Area	/		/			/		Kg			
50	OKP-PFE-050	A,B,C Dry Chemical	6.8 Kg	2019	Building A/2	/		/			/		Kg			
51	OKP-PFE-051	A,B,C Dry Chemical	6.8 Kg	2019	Building A/3 (Room 1440)	/		/			/		Kg			
52	OKP-PFE-052	A,B,C Dry Chemical	6.8 Kg	2019	Building A/3 (Room 1401)	/		/			/		Kg			
53	OKP-PFE-053	A,B,C Dry Chemical	6.8 Kg	2019	Building A/4 (Room 1538)	/		/			/		Kg			
54	OKP-PFE-054	A,B,C Dry Chemical	6.8 Kg	2019	Building A/4 (Room 1501)	/		/			/		Kg			

Section: 10 – Portable Fire Extinguishers (PFE's)
Title: Monthly Check of all Portable Fire Extinguishers
Responsible Person: Manager Engineer
File Number: FLS 10-02

Property: OZO KATA PHUKET
Month : 1-Feb-23
Pages: 3 pages

Seq.	Asset Tag	Description	Size	Year Purchased/R efilled	Location	Tag		Physical		Pressure Gate			Weight	Check & Inspection By	Date	Remark
						Normal	Abnormal	Normal	Abnormal	Recharge	195	Over Charged				
55	OKP-PFE-055	A,B,C Dry Chemical	6.8 Kg	2019	Building A/5 (Room 1638)	/		/			/		Kg		25/2/23	
56	OKP-PFE-056	A,B,C Dry Chemical	6.8 Kg	2019	Building A/5 (Room 1601)	/		/			/		Kg			
57	OKP-PFE-057	A,B,C Dry Chemical	6.8 Kg	2019	Building D/2.1	/		/			/		Kg			
58	OKP-PFE-058	A,B,C Dry Chemical	6.8 Kg	2019	Building D/2.2	/		/			/		Kg			
59	OKP-PFE-059	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet D/2	/		/			/		Kg			
60	OKP-PFE-060	A,B,C Dry Chemical	6.8 Kg	2019	Building C/2 (Roof Top)	/		/			/		Kg			
61	OKP-PFE-061	A,B,C Dry Chemical	6.8 Kg	2019	Building A (Lift service)	/		/			/		Kg			
62	OKP-PFE-062	A,B,C Dry Chemical	6.8 Kg	2019	Fir cart Building B/4	/		/			/		Kg			
63																
64																
65																

Manager Engineering :

Name : Mr.Sumet Niammunee

Employee Number : 0139

Manager Security:

Name : Mr.Washirawat Wiboonphonthan

Employee Number :



Signed, Dated and Rubber
Stamped by the Chief
Engineer/Manager - Security

Section: 10 – Portable Fire Extinguishers (PFE's)
Title: Monthly Check of all Portable Fire Extinguishers
Responsible Person: Manager Engineer
File Number: FLS 10-02

Property: OZO KATA PHUKET
Month : 12-Mar-23
Pages: 3 pages

Seq.	Asset Tag	Description	Size	Year Purchased/R efilled	Location	Tag		Physical		Pressure Gauge			Weight	Check & Inspection By	Date	Remark
						Normal	Abnormal	Normal	Abnormal	Recharge	195	Over Charged				
01	OKP-PFE-001	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A1/1	/		/			/		Kg			
02	OKP-PFE-002	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A1	/		/			/		Kg			
03	OKP-PFE-003	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A1/2	/		/			/		Kg			
04	OKP-PFE-004	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A2/1	/		/			/		Kg			
05	OKP-PFE-005	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A2	/		/			/		Kg			
06	OKP-PFE-006	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A2/2	/		/			/		Kg			
07	OKP-PFE-007	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A3/1	/		/			/		Kg			
08	OKP-PFE-008	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A3	/		/			/		Kg			
09	OKP-PFE-009	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A3/2	/		/			/		Kg			
10	OKP-PFE-010	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A4/1	/		/			/		Kg			
11	OKP-PFE-011	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A4	/		/			/		Kg			
12	OKP-PFE-012	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A4/2	/		/			/		Kg			
13	OKP-PFE-013	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A5/1	/		/			/		Kg			
14	OKP-PFE-014	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A5	/		/			/		Kg			
15	OKP-PFE-015	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A5/2	/		/			/		Kg			
16	OKP-PFE-016	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B1	/		/			/		Kg			
17	OKP-PFE-017	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B1/1	/		/			/		Kg			
18	OKP-PFE-018	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B1/2	/		/			/		Kg			
19	OKP-PFE-019	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B2	/		/			/		Kg			
20	OKP-PFE-020	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B2/1	/		/			/		Kg			
21	OKP-PFE-021	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B2/2	/		/			/		Kg			
22	OKP-PFE-022	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B3	/		/			/		Kg			
23	OKP-PFE-023	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B3/1	/		/			/		Kg			
24	OKP-PFE-024	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B3/2	/		/			/		Kg			
25	OKP-PFE-025	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B4	/		/			/		Kg			
26	OKP-PFE-026	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B4/1	/		/			/		Kg			
27	OKP-PFE-027	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B4/2	/		/			/		Kg			

Section: 10 – Portable Fire Extinguishers (PFE's)
Title: Monthly Check of all Portable Fire Extinguishers
Responsible Person: Manager Engineer
File Number: FLS 10-02

Property: OZO KATA PHUKET
Month: 12-Mar-23
Pages: 3 pages

Seq.	Asset Tag	Description	Size	Year Purchased/R efilled	Location	Tag		Physical		Pressure Gauge			Weight	Check & Inspection By	Date	Remark
						Normal	Abnormal	Normal	Abnormal	Recharge	195	Over Charged				
28	OKP-PFE-028	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B5	/		/			/		Kg			
29	OKP-PFE-029	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B5/1	/		/			/		Kg			
30	OKP-PFE-030	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B5/2	/		/			/		Kg			
31	OKP-PFE-031	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet Pool bar	/		/			/		Kg			
32	OKP-PFE-032	A,B,C Dry Chemical	6.8 Kg	2019	Engineer office	/		/			/		Kg			
33	OKP-PFE-033	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet EAT Toilet	/		/			/		Kg			
34	OKP-PFE-034	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room C1	/		/			/		Kg			
35	OKP-PFE-035	B,C Carbon Dioxide (Co2)	10 LB	2019	AHU room C2	/		/			/		Kg			
36	OKP-PFE-036	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room C2	/		/			/		Kg			
37	OKP-PFE-037	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet C2	/		/			/		Kg			
38	OKP-PFE-038	B,C Carbon Dioxide (Co2)	10 LB	2019	Staff canteen	/		/			/		Kg			
39	OKP-PFE-039	B,C Carbon Dioxide (Co2)	10 LB	2019	Generator room	/		/			/		Kg			
40	OKP-PFE-040	A,B,C Dry Chemical	6.8 Kg	2019	Fire Cart	/		/			/		Kg			
41	OKP-PFE-041	A,B,C Dry Chemical	6.8 Kg	2019	Fire Cart	/		/			/		Kg			
42	OKP-PFE-042	A,B,C Dry Chemical	6.8 Kg	2019	Fire Cart	/		/			/		Kg			
43	OKP-PFE-043	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet D Floor 1	/		/			/		Kg			
44	OKP-PFE-044	B,C Carbon Dioxide (Co2)	10 LB	2019	MDB room	/		/			/		Kg			
45	OKP-PFE-045	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet D Floor 2	/		/			/		Kg			
46	OKP-PFE-046	A,B,C Dry Chemical	6.8 Kg	2019	Gas Station	/		/			/		Kg			
47	OKP-PFE-047	A,B,C Dry Chemical	6.8 Kg	2019	Gas Station	/		/			/		Kg			
48	OKP-PFE-048	A,B,C Dry Chemical	6.8 Kg	2019	Beside Chill room	/		/			/		Kg			
49	OKP-PFE-049	A,B,C Dry Chemical	6.8 Kg	2019	Spot Area	/		/			/		Kg			
50	OKP-PFE-050	A,B,C Dry Chemical	6.8 Kg	2019	Building A/2	/		/			/		Kg			
51	OKP-PFE-051	A,B,C Dry Chemical	6.8 Kg	2019	Building A/3 (Room 1440)	/		/			/		Kg			
52	OKP-PFE-052	A,B,C Dry Chemical	6.8 Kg	2019	Building A/3 (Room 1401)	/		/			/		Kg			
53	OKP-PFE-053	A,B,C Dry Chemical	6.8 Kg	2019	Building A/4 (Room 1538)	/		/			/		Kg			
54	OKP-PFE-054	A,B,C Dry Chemical	6.8 Kg	2019	Building A/4 (Room 1501)	/		/			/		Kg			

Section: 10 – Portable Fire Extinguishers (PFE's)
Title: Monthly Check of all Portable Fire Extinguishers
Responsible Person: Manager Engineer
File Number: FLS 10-02

Property: OZO KATA PHUKET
Month : 12-Mar-23
Pages: 3 pages

Seq.	Asset Tag	Description	Size	Year Purchased/R efilled	Location	Tag		Physical		Pressure Gate			Weight	Check & Inspection By	Date	Remark
						Normal	Abnormal	Normal	Abnormal	Recharge	195	Over Charged				
55	OKP-PFE-055	A,B,C Dry Chemical	6.8 Kg	2019	Building A/5 (Room 1638)	/		/			/		Kg			
56	OKP-PFE-056	A,B,C Dry Chemical	6.8 Kg	2019	Building A/5 (Room 1601)	/		/			/		Kg			
57	OKP-PFE-057	A,B,C Dry Chemical	6.8 Kg	2019	Building D/2.1	/		/			/		Kg			
58	OKP-PFE-058	A,B,C Dry Chemical	6.8 Kg	2019	Building D/2.2	/		/			/		Kg			
59	OKP-PFE-059	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet D/2	/		/			/		Kg			
60	OKP-PFE-060	A,B,C Dry Chemical	6.8 Kg	2019	Building C/2 (Roof Top)	/		/			/		Kg			
61	OKP-PFE-061	A,B,C Dry Chemical	6.8 Kg	2019	Building A (Lift service)	/		/			/		Kg			
62	OKP-PFE-062	A,B,C Dry Chemical	6.8 Kg	2019	Fir cart Building B/4	/		/			/		Kg			
63																
64																
65																

Manager Engineering :

Name : Mr.Sumet Niammunee

Employee Number : 0139

Manager Security:

Name : Mr.Washirawat Wiboonphonthan

Employee Number : 154




Signed, Dated and Rubber
Stamped by the Chief
Engineer/Manager Security

OZO
Phuket

OZO PHUKET
DATE 24 MAR 2023
SIGNATURE Sumet N.
MANAGER ENGINEERING

Section: 10 – Portable Fire Extinguishers (PFE's)
Title: Monthly Check of all Portable Fire Extinguishers
Responsible Person: Manager Engineer
File Number: FLS 10-02

Property: OZO KATA PHUKET
Month : 12-Apr-23
Pages: 3 pages

Seq.	Asset Tag	Description	Size	Year Purchased/R efilled	Location	Tag		Physical		Pressure Gate			Weight	Check & Inspection By	Date	Remark
						Normal	Abnormal	Normal	Abnormal	Recharge	195	Over Charged				
01	OKP-PFE-001	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A1/1	/		/			/		Kg			
02	OKP-PFE-002	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A1	/		/			/		Kg			
03	OKP-PFE-003	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A1/2	/		/			/		Kg			
04	OKP-PFE-004	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A2/1	/		/			/		Kg			
05	OKP-PFE-005	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A2	/		/			/		Kg			
06	OKP-PFE-006	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A2/2	/		/			/		Kg			
07	OKP-PFE-007	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A3/1	/		/			/		Kg			
08	OKP-PFE-008	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A3	/		/			/		Kg			
09	OKP-PFE-009	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A3/2	/		/			/		Kg			
10	OKP-PFE-010	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A4/1	/		/			/		Kg			
11	OKP-PFE-011	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A4	/		/			/		Kg			
12	OKP-PFE-012	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A4/2	/		/			/		Kg			
13	OKP-PFE-013	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A5/1	/		/			/		Kg			
14	OKP-PFE-014	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A5	/		/			/		Kg			
15	OKP-PFE-015	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A5/2	/		/			/		Kg			
16	OKP-PFE-016	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B1	/		/			/		Kg			
17	OKP-PFE-017	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B1/1	/		/			/		Kg			
18	OKP-PFE-018	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B1/2	/		/			/		Kg			
19	OKP-PFE-019	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B2	/		/			/		Kg			
20	OKP-PFE-020	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B2/1	/		/			/		Kg			
21	OKP-PFE-021	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B2/2	/		/			/		Kg			
22	OKP-PFE-022	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B3	/		/			/		Kg			
23	OKP-PFE-023	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B3/1	/		/			/		Kg			
24	OKP-PFE-024	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B3/2	/		/			/		Kg			
25	OKP-PFE-025	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B4	/		/			/		Kg			
26	OKP-PFE-026	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B4/1	/		/			/		Kg			
27	OKP-PFE-027	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B4/2	/		/			/		Kg			


Section: 10 – Portable Fire Extinguishers (PFE's)
Title: Monthly Check of all Portable Fire Extinguishers
Responsible Person: Manager Engineer
File Number: FLS 10-02

Property: OZO KATA PHUKET
Month: 12-Apr-23
Pages: 3 pages

Seq.	Asset Tag	Description	Size	Year Purchased/R efilled	Location	Tag		Physical		Pressure Gauge			Weight	Check & Inspection By	Date	Remark
						Normal	Abnormal	Normal	Abnormal	Recharge	195	Over Charged				
28	OKP-PFE-028	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B5	/		/			/		Kg			
29	OKP-PFE-029	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B5/1	/		/			/		Kg			
30	OKP-PFE-030	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B5/2	/		/			/		Kg			
31	OKP-PFE-031	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet Pool bar	/		/			/		Kg			
32	OKP-PFE-032	A,B,C Dry Chemical	6.8 Kg	2019	Engineer office	/		/			/		Kg			
33	OKP-PFE-033	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet EAT Toilet	/		/			/		Kg			
34	OKP-PFE-034	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room C1	/		/			/		Kg			
35	OKP-PFE-035	B,C Carbon Dioxide (Co2)	10 LB	2019	AHU room C2	/		/			/		Kg			
36	OKP-PFE-036	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room C2	/		/			/		Kg			
37	OKP-PFE-037	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet C2	/		/			/		Kg			
38	OKP-PFE-038	B,C Carbon Dioxide (Co2)	10 LB	2019	Staff canteen	/		/			/		Kg			
39	OKP-PFE-039	B,C Carbon Dioxide (Co2)	10 LB	2019	Generator room	/		/			/		Kg			
40	OKP-PFE-040	A,B,C Dry Chemical	6.8 Kg	2019	Fire Cart	/		/			/		Kg			
41	OKP-PFE-041	A,B,C Dry Chemical	6.8 Kg	2019	Fire Cart	/		/			/		Kg			
42	OKP-PFE-042	A,B,C Dry Chemical	6.8 Kg	2019	Fire Cart	/		/			/		Kg			
43	OKP-PFE-043	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet D Floor 1	/		/			/		Kg			
44	OKP-PFE-044	B,C Carbon Dioxide (Co2)	10 LB	2019	MDB room	/		/			/		Kg			
45	OKP-PFE-045	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet D Floor 2	/		/			/		Kg			
46	OKP-PFE-046	A,B,C Dry Chemical	6.8 Kg	2019	Gas Station	/		/			/		Kg			
47	OKP-PFE-047	A,B,C Dry Chemical	6.8 Kg	2019	Gas Station	/		/			/		Kg			
48	OKP-PFE-048	A,B,C Dry Chemical	6.8 Kg	2019	Beside Chill room	/		/			/		Kg			
49	OKP-PFE-049	A,B,C Dry Chemical	6.8 Kg	2019	Spot Area	/		/			/		Kg			
50	OKP-PFE-050	A,B,C Dry Chemical	6.8 Kg	2019	Building A/2	/		/			/		Kg			
51	OKP-PFE-051	A,B,C Dry Chemical	6.8 Kg	2019	Building A/3 (Room 1440)	/		/			/		Kg			
52	OKP-PFE-052	A,B,C Dry Chemical	6.8 Kg	2019	Building A/3 (Room 1401)	/		/			/		Kg			
53	OKP-PFE-053	A,B,C Dry Chemical	6.8 Kg	2019	Building A/4 (Room 1538)	/		/			/		Kg			
54	OKP-PFE-054	A,B,C Dry Chemical	6.8 Kg	2019	Building A/4 (Room 1501)	/		/			/		Kg			

Section: 10 – Portable Fire Extinguishers (PFE's)
Title: Monthly Check of all Portable Fire Extinguishers
Responsible Person: Manager Engineer
File Number: FLS 10-02

Property: OZO KATA PHUKET
Month : 12-Apr-23
Pages: 3 pages

Seq.	Asset Tag	Description	Size	Year Purchased/R efilled	Location	Tag		Physical		Pressure Gate			Weight	Check & Inspection By	Date	Remark
						Normal	Abnormal	Normal	Abnormal	Recharge	195	Over Charged				
55	OKP-PFE-055	A,B,C Dry Chemical	6.8 Kg	2019	Building A/5 (Room 1638)	/		/			/		Kg	}  } 25/4/66		
56	OKP-PFE-056	A,B,C Dry Chemical	6.8 Kg	2019	Building A/5 (Room 1601)	/		/			/		Kg			
57	OKP-PFE-057	A,B,C Dry Chemical	6.8 Kg	2019	Building D/2.1	/		/			/		Kg			
58	OKP-PFE-058	A,B,C Dry Chemical	6.8 Kg	2019	Building D/2.2	/		/			/		Kg			
59	OKP-PFE-059	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet D/2	/		/			/		Kg			
60	OKP-PFE-060	A,B,C Dry Chemical	6.8 Kg	2019	Building C/2 (Roof Top)	/		/			/		Kg			
61	OKP-PFE-061	A,B,C Dry Chemical	6.8 Kg	2019	Building A (Lift service)	/		/			/		Kg	}  } 25/4/66		
62	OKP-PFE-062	A,B,C Dry Chemical	6.8 Kg	2019	Fir cart Building B/4	/		/			/		Kg			
63																
64	OKP-PFE-064	Water < Foam >		2022	Main Kitchen A	/		/			/					
65	OKP-PFE-065	BF 2000		2022	Main Kitchen B	/		/			/					

Manager Engineering :

Name : Mr.Sumet Niammune

Employee Number : 0139

Manager Security:

Name : Mr.Washirawat Wiboonphonthan

Employee Number : 154

Signed, Dated and Rubber
Stamped by the Chief
Engineer/Manager - Security



OZO PHUKET
DATE 26 APR 2023
SIGNATURE 
MANAGER ENGINEERING



ONYX Hospitality Group
Fire Life Safety Management System



Section: 10 – Portable Fire Extinguishers (PFE's)
Title: Monthly Check of all Portable Fire Extinguishers
Responsible Person: Manager Engineer
File Number: FLS 10-02

Property: OZO KATA PHUKET
Month: 10-May-23
Pages: 3 pages

Seq.	Asset Tag	Description	Size	Year Purchased/R efilled	Location	Tag		Physical		Pressure Gauge			Weight	Check & Inspection By	Date	Remark
						Normal	Abnormal	Normal	Abnormal	Recharge	195	Over Charged				
01	OKP-PFE-001	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A1/1	/		/			/		Kg			
02	OKP-PFE-002	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A1	/		/			/		Kg			
03	OKP-PFE-003	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A1/2	/		/			/		Kg			
04	OKP-PFE-004	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A2/1	/		/			/		Kg			
05	OKP-PFE-005	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A2	/		/			/		Kg			
06	OKP-PFE-006	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A2/2	/		/			/		Kg			
07	OKP-PFE-007	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A3/1	/		/			/		Kg			
08	OKP-PFE-008	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A3	/		/			/		Kg			
09	OKP-PFE-009	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A3/2	/		/			/		Kg			
10	OKP-PFE-010	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A4/1	/		/			/		Kg			
11	OKP-PFE-011	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A4	/		/			/		Kg			
12	OKP-PFE-012	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A4/2	/		/			/		Kg			
13	OKP-PFE-013	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A5/1	/		/			/		Kg			
14	OKP-PFE-014	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A5	/		/			/		Kg			
15	OKP-PFE-015	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A5/2	/		/			/		Kg			
16	OKP-PFE-016	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B1	/		/			/		Kg			
17	OKP-PFE-017	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B1/1	/		/			/		Kg			
18	OKP-PFE-018	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B1/2	/		/			/		Kg			
19	OKP-PFE-019	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B2	/		/			/		Kg			
20	OKP-PFE-020	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B2/1	/		/			/		Kg			
21	OKP-PFE-021	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B2/2	/		/			/		Kg			
22	OKP-PFE-022	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B3	/		/			/		Kg			
23	OKP-PFE-023	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B3/1	/		/			/		Kg			
24	OKP-PFE-024	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B3/2	/		/			/		Kg			
25	OKP-PFE-025	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B4	/		/			/		Kg			
26	OKP-PFE-026	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B4/1	/		/			/		Kg			
27	OKP-PFE-027	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B4/2	/		/			/		Kg			



ONYX Hospitality Group
Fire Life Safety Management System



Section: 10 – Portable Fire Extinguishers (PFE's)
Title: Monthly Check of all Portable Fire Extinguishers
Responsible Person: Manager Engineer
File Number: FLS 10-02

Property: OZO KATA PHUKET
Month: 10-May-23
Pages: 3 pages

Seq.	Asset Tag	Description	Size	Year Purchased/R efilled	Location	Tag		Physical		Pressure Gauge			Weight	Check & Inspection By	Date	Remark
						Normal	Abnormal	Normal	Abnormal	Recharge	195	Over Charged				
28	OKP-PFE-028	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B5	/		/			/		Kg			
29	OKP-PFE-029	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B5/1	/		/			/		Kg			
30	OKP-PFE-030	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B5/2	/		/			/		Kg			
31	OKP-PFE-031	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet Pool bar	/		/			/		Kg			
32	OKP-PFE-032	A,B,C Dry Chemical	6.8 Kg	2019	Engineer office	/		/			/		Kg			
33	OKP-PFE-033	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet EAT Toilet	/		/			/		Kg			
34	OKP-PFE-034	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room C1	/		/			/		Kg			
35	OKP-PFE-035	B,C Carbon Dioxide (Co2)	10 LB	2019	AHU room C2	/		/			/		Kg			
36	OKP-PFE-036	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room C2	/		/			/		Kg			
37	OKP-PFE-037	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet C2	/		/			/		Kg			
38	OKP-PFE-038	B,C Carbon Dioxide (Co2)	10 LB	2019	Staff canteen	/		/			/		Kg			
39	OKP-PFE-039	B,C Carbon Dioxide (Co2)	10 LB	2019	Generator room	/		/			/		Kg			
40	OKP-PFE-040	A,B,C Dry Chemical	6.8 Kg	2019	Fire Cart	/		/			/		Kg			
41	OKP-PFE-041	A,B,C Dry Chemical	6.8 Kg	2019	Fire Cart	/		/			/		Kg			
42	OKP-PFE-042	A,B,C Dry Chemical	6.8 Kg	2019	Fire Cart	/		/			/		Kg			
43	OKP-PFE-043	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet D Floor 1	/		/			/		Kg			
44	OKP-PFE-044	B,C Carbon Dioxide (Co2)	10 LB	2019	MDB room	/		/			/		Kg			
45	OKP-PFE-045	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet D Floor 2	/		/			/		Kg			
46	OKP-PFE-046	A,B,C Dry Chemical	6.8 Kg	2019	Gas Station	/		/			/		Kg			
47	OKP-PFE-047	A,B,C Dry Chemical	6.8 Kg	2019	Gas Station	/		/			/		Kg			
48	OKP-PFE-048	A,B,C Dry Chemical	6.8 Kg	2019	Beside Chill room	/		/			/		Kg			
49	OKP-PFE-049	A,B,C Dry Chemical	6.8 Kg	2019	Spot Area	/		/			/		Kg			
50	OKP-PFE-050	A,B,C Dry Chemical	6.8 Kg	2019	Building A/2	/		/			/		Kg			
51	OKP-PFE-051	A,B,C Dry Chemical	6.8 Kg	2019	Building A/3 (Room 1440)	/		/			/		Kg			
52	OKP-PFE-052	A,B,C Dry Chemical	6.8 Kg	2019	Building A/3 (Room 1401)	/		/			/		Kg			
53	OKP-PFE-053	A,B,C Dry Chemical	6.8 Kg	2019	Building A/4 (Room 1538)	/		/			/		Kg			
54	OKP-PFE-054	A,B,C Dry Chemical	6.8 Kg	2019	Building A/4 (Room 1501)	/		/			/		Kg			

Section: 10 – Portable Fire Extinguishers (PFE's)
Title: Monthly Check of all Portable Fire Extinguishers
Responsible Person: Manager Engineer
File Number: FLS 10-02

Property: OZO KATA PHUKET
Month : 10-May-23
Pages: 3 pages

Seq.	Asset Tag	Description	Size	Year Purchased/R efilled	Location	Tag		Physical		Pressure Gate			Weight	Check & Inspection By	Date	Remark
						Normal	Abnormal	Normal	Abnormal	Recharge	195	Over Charged				
55	OKP-PFE-055	A,B,C Dry Chemical	6.8 Kg	2019	Building A/5 (Room 1638)	/		/			/		Kg	} imc	27/5/23	
56	OKP-PFE-056	A,B,C Dry Chemical	6.8 Kg	2019	Building A/5 (Room 1601)	/		/			/		Kg			
57	OKP-PFE-057	A,B,C Dry Chemical	6.8 Kg	2019	Building D/2.1	/		/			/		Kg			
58	OKP-PFE-058	A,B,C Dry Chemical	6.8 Kg	2019	Building D/2.2	/		/			/		Kg			
59	OKP-PFE-059	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet D/2	/		/			/		Kg			
60	OKP-PFE-060	A,B,C Dry Chemical	6.8 Kg	2019	Building C/2 (Roof Top)	/		/			/		Kg			
61	OKP-PFE-061	A,B,C Dry Chemical	6.8 Kg	2019	Building A (Lift service)	/		/			/		Kg	} imc	27/5/23	
62	OKP-PFE-062	A,B,C Dry Chemical	6.8 Kg	2019	Fir cart Building B/4	/		/			/		Kg			
63																
64	OKP-PFE-064	Water (Foam)		2022	Main kitchen A	/		/			/					
65	OKP-PFE-065	BF2000		2022	Main kitchen B	/		/			/					

Manager Engineering :

Name : Mr.Sumet Niammune

Employee Number : 0139

Manager Security:

Name : Mr.Washirawat Wiboonphonthan

Employee Number : 0154


Signed, Dated and Rubber
Stamped by the Chief
Engineer/Manager - Security



OZO PHUKET
DATE... 29 MAY 2023
SIGNATURE... *Sumet*
MANAGER ENGINEERING

Section: 10 – Portable Fire Extinguishers (PFE's)
Title: Monthly Check of all Portable Fire Extinguishers
Responsible Person: Manager Engineer
File Number: FLS 10-02

Property: OZO PHUKET
Month: Jun-23
Pages: 3 pages

Seq.	Asset Tag	Description	Size	Year Purchased/R efilled	Location	Tag		Physical		Pressure Gauge			Weight	Check & Inspection By	Date	Remark
						Normal	Abnormal	Normal	Abnormal	Recharge	195	Over Charged				
01	OKP-PFE-001	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A1/1	/		/			/		Kg			
02	OKP-PFE-002	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A1	/		/			/		Kg			
03	OKP-PFE-003	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A1/2	/		/			/		Kg			
04	OKP-PFE-004	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A2/1	/		/			/		Kg			
05	OKP-PFE-005	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A2	/		/			/		Kg			
06	OKP-PFE-006	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A2/2	/		/			/		Kg			
07	OKP-PFE-007	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A3/1	/		/			/		Kg			
08	OKP-PFE-008	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A3	/		/			/		Kg			
09	OKP-PFE-009	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A3/2	/		/			/		Kg			
10	OKP-PFE-010	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A4/1	/		/			/		Kg			
11	OKP-PFE-011	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A4	/		/			/		Kg			
12	OKP-PFE-012	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A4/2	/		/			/		Kg			
13	OKP-PFE-013	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A5/1	/		/			/		Kg			
14	OKP-PFE-014	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room A5	/		/			/		Kg			
15	OKP-PFE-015	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet A5/2	/		/			/		Kg			
16	OKP-PFE-016	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B1	/		/			/		Kg			
17	OKP-PFE-017	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B1/1	/		/			/		Kg			
18	OKP-PFE-018	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B1/2	/		/			/		Kg			
19	OKP-PFE-019	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B2	/		/			/		Kg			
20	OKP-PFE-020	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B2/1	/		/			/		Kg			
21	OKP-PFE-021	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B2/2	/		/			/		Kg			
22	OKP-PFE-022	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B3	/		/			/		Kg			
23	OKP-PFE-023	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B3/1	/		/			/		Kg			
24	OKP-PFE-024	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B3/2	/		/			/		Kg			
25	OKP-PFE-025	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B4	/		/			/		Kg			
26	OKP-PFE-026	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B4/1	/		/			/		Kg			
27	OKP-PFE-027	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B4/2	/		/			/		Kg			

Section: 10 – Portable Fire Extinguishers (PFE's)
Title: Monthly Check of all Portable Fire Extinguishers
Responsible Person: Manager Engineer
File Number: FLS 10-02

Property: OZO PHUKET
Month : Jun-23
Pages: 3 pages

Seq.	Asset Tag	Description	Size	Year Purchased/R efilled	Location	Tag		Physical		Pressure Gauge			Weight	Check & Inspection By	Date	Remark
						Normal	Abnormal	Normal	Abnormal	Recharge	195	Over Charged				
28	OKP-PFE-028	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room B5	/		/			/		Kg			
29	OKP-PFE-029	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B5/1	/		/			/		Kg			
30	OKP-PFE-030	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet B5/2	/		/			/		Kg			
31	OKP-PFE-031	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet Pool bar	/		/			/		Kg			
32	OKP-PFE-032	A,B,C Dry Chemical	6.8 Kg	2019	Engineer office	/		/			/		Kg			
33	OKP-PFE-033	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet EAT Toilet	/		/			/		Kg			
34	OKP-PFE-034	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room C1	/		/			/		Kg			
35	OKP-PFE-035	B,C Carbon Dioxide (Co2)	10 LB	2019	AHU room C2	/		/			/		Kg			
36	OKP-PFE-036	B,C Carbon Dioxide (Co2)	10 LB	2019	Power room C2	/		/			/		Kg			
37	OKP-PFE-037	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet C2	/		/			/		Kg			
38	OKP-PFE-038	B,C Carbon Dioxide (Co2)	10 LB	2019	Staff canteen	/		/			/		Kg			
39	OKP-PFE-039	B,C Carbon Dioxide (Co2)	10 LB	2019	Generator room	/		/			/		Kg			
40	OKP-PFE-040	A,B,C Dry Chemical	6.8 Kg	2019	Fire Cart	/		/			/		Kg			
41	OKP-PFE-041	A,B,C Dry Chemical	6.8 Kg	2019	Fire Cart	/		/			/		Kg			
42	OKP-PFE-042	A,B,C Dry Chemical	6.8 Kg	2019	Fire Cart	/		/			/		Kg			
43	OKP-PFE-043	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet D Floor 1	/		/			/		Kg			
44	OKP-PFE-044	B,C Carbon Dioxide (Co2)	10 LB	2019	MDB room	/		/			/		Kg			
45	OKP-PFE-045	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet D Floor 2	/		/			/		Kg			
46	OKP-PFE-046	A,B,C Dry Chemical	6.8 Kg	2019	Gas Station	/		/			/		Kg			
47	OKP-PFE-047	A,B,C Dry Chemical	6.8 Kg	2019	Gas Station	/		/			/		Kg			
48	OKP-PFE-048	A,B,C Dry Chemical	6.8 Kg	2019	Beside Chill room	/		/			/		Kg			
49	OKP-PFE-049	A,B,C Dry Chemical	6.8 Kg	2019	Spot Area	/		/			/		Kg			
50	OKP-PFE-050	A,B,C Dry Chemical	6.8 Kg	2019	Building A/2	/		/			/		Kg			
51	OKP-PFE-051	A,B,C Dry Chemical	6.8 Kg	2019	Building A/3 (Room 1440)	/		/			/		Kg			
52	OKP-PFE-052	A,B,C Dry Chemical	6.8 Kg	2019	Building A/3 (Room 1401)	/		/			/		Kg			
53	OKP-PFE-053	A,B,C Dry Chemical	6.8 Kg	2019	Building A/4 (Room 1538)	/		/			/		Kg			
54	OKP-PFE-054	A,B,C Dry Chemical	6.8 Kg	2019	Building A/4 (Room 1501)	/		/			/		Kg			

Section: 10 – Portable Fire Extinguishers (PFE's)
Title: Monthly Check of all Portable Fire Extinguishers
Responsible Person: Manager Engineer
File Number: FLS 10-02

Property: OZO PHUKET
Month: Jun-23
Pages: 3 pages

Seq.	Asset Tag	Description	Size	Year Purchased/R efilled	Location	Tag		Physical		Pressure Gate			Weight	Check & Inspection By	Date	Remark
						Normal	Abnormal	Normal	Abnormal	Recharge	195	Over Charged				
55	OKP-PFE-055	A,B,C Dry Chemical	6.8 Kg	2019	Building A/5 (Room 1638)	/		/			/		Kg		24/6/23	
56	OKP-PFE-056	A,B,C Dry Chemical	6.8 Kg	2019	Building A/5 (Room 1601)	/		/			/		Kg			
57	OKP-PFE-057	A,B,C Dry Chemical	6.8 Kg	2019	Building D/2.1	/		/			/		Kg			
58	OKP-PFE-058	A,B,C Dry Chemical	6.8 Kg	2019	Building D/2.2	/		/			/		Kg			
59	OKP-PFE-059	A,B,C Dry Chemical	6.8 Kg	2019	Fire Hose Carbinet D/2	/		/			/		Kg			
60	OKP-PFE-060	A,B,C Dry Chemical	6.8 Kg	2019	Building C/2 (Roof Top)	/		/			/		Kg			
61	OKP-PFE-061															
62	OKP-PFE-062															
63																
64	OKP-PFE-063	Water (Foam)		2022	Main kitchen A	/		/			/				24/6/23	
65	OKP-PFE-064	BF2000		2022	Main Kitchen B	/		/			/				24/6/23	

Manager Engineering


Name : Mr.Sumet Niammunee

Employee Number : 0139

Manager Security

Name : Mr.Washirawat Wiboonphonthan

Employee Number : 0154




OZO PHUKET
 DATE: 26 June 2023
 SIGNATURE: 
MANAGER ENGINEERING