

ภาคผนวก ช-2

การตรวจสอบประสิทธิภาพถังดับเพลิง

22

4



Travelodge

SUKHUMVIT 11

file tank water

TRAVELODGE SUKHUMVIT
ENGINEERING DEPARTMENT
EXTINGUISHERS CHECKLIST

Tower A			Tower B		
Locations	Pressure Psi.	Remark	Locations	Pressure Psi.	Remark
FL.8 FHC Pump room	195	/	Roof FHC (1)	195	/
FL.8 FHC	195	/	Roof FHC (2)	195	/
FL.7 corridor	100	/	FL.8 FHC 2801	195	/
FL.7 FHC	195	/	FL.8 FHC 2821	195	/
FL.6 corridor	100	/	FL.8 staff lift	100	/
FL.6 FHC	195	/	FL.7 FHC 2701	195	/
FL.5 corridor	100	/	FL.7 FHC 2721	195	/
FL.5 FHC	195	/	FL.7 staff lift	100	/
FL.4 corridor	100	/	FL.6 FHC 2601	195	/
FL.4 FHC	100	/	FL.6 FHC 2621	195	/
FL.3 corridor	100	/	FL.6 staff lift	100	/
FL.3 FHC	195	/	FL.5 FHC 2501	195	/
FL.2 corridor	100	/	FL.5 FHC 2521	195	/
FL.2 FHC	100	/	FL.5 staff lift	100	/
FL.G FHC security	195	/	FL.4 FHC 2401	195	/
FL.G FHC restaurant	195	/	FL.4 FHC 2421	195	/
FL.B1 FHC	195	/	FL.4 staff lift	100	/
FL.B1 kitchen (1)	100	/	FL.3 FHC 2301	195	/
FL.B1 kitchen (2)	100	/	FL.3 FHC 2321	195	/
FL.B1 staff lift	100	/	FL.3 staff lift	100	/
FL.B2 staff lift	100	/	FL.2 FHC 2201	195	/
FL.B2 FHC	195	/	FL.2 FHC 2221	100	/
FL.B2 FHC fire pump	195	/	FL.2 staff lift	100	/
Generator room	100	/	FL.G FHC Lobby	195	/
MDB Room	100	/	FHC front office	195	/
MDB Room	100	/	FL.B1 FHC Car park	195/195	/
			FL.B2 FHC Car park	195/195	/

Checked By Supervisor		Date	10/1/66
Approve By Chief Engineer		Date	11/1/66



Travelodge

SUKHUMVIT 11

TRAVELODGE SUKHUMVIT
ENGINEERING DEPARTMENT
EXTINGUISHERS CHECKLIST

Tower A			Tower B		
Locations	Pressure Psi.	Remark	Locations	Pressure Psi.	Remark
FL.8 FHC Pump room	195	/	Roof FHC (1)	195	/
FL.8 FHC	195	/	Roof FHC (2)	195	/
FL.7 corridor	195	/	FL.8 FHC 2801	195	/
FL.7 FHC	195	/	FL.8 FHC 2821	195	/
FL.6 corridor	100	/	FL.8 staff lift	100	/
FL.6 FHC	195	/	FL.7 FHC 2701	195	/
FL.5 corridor	100	/	FL.7 FHC 2721	195	/
FL.5 FHC	195	along 3rd floor	FL.7 staff lift	100	/
FL.4 corridor	100	/	FL.6 FHC 2601	195	/
FL.4 FHC	CO ₂	/	FL.6 FHC 2621	195	/
FL.3 corridor	100	/	FL.6 staff lift	100	/
FL.3 FHC	195	/	FL.5 FHC 2501	195	/
FL.2 corridor	100	/	FL.5 FHC 2521	195	/
FL.2 FHC	CO ₂	/	FL.5 staff lift	100	/
FL.G FHC security	195	/	FL.4 FHC 2401	195	/
FL.G FHC restaurant	195	/	FL.4 FHC 2421	195	/
FL.B1 FHC	195	/	FL.4 staff lift	100	/
FL.B1 kitchen (1)	100	/	FL.3 FHC 2301	195	/
FL.B1 kitchen (2)	100	/	FL.3 FHC 2321	195	/
FL.B1 staff lift	100	/	FL.3 staff lift	100	/
FL.B2 staff lift	100	/	FL.2 FHC 2201	195	/
FL.B2 FHC	195	/	FL.2 FHC 2221	100	/
FL.B2 FHC fire pump	195	/	FL.2 staff lift	100	/
Generator room	CO ₂	/	FL.G FHC Lobby	195	/
MDB Room	CO ₂	/	FHC front office	195	/
MDB Room	CO ₂	/	FL.B1 FHC Car park	195/195	/
			FL.B2 FHC Car park	195/195	/

Checked By Supervisor		Date	4/2/23
Approve By Chief Engineer		Date	4/2/23

Tower A			Tower B		
Locations	Pressure Psi.	Remark	Locations	Pressure Psi.	Remark
FL.8 FHC Pump room	195	✓	Roof FHC (1)	195	✓
FL.8 FHC	195	✓	Roof FHC (2)	195	✓
FL.7 corridor	100	✓	FL.8 FHC 2801	195	✓
FL.7 FHC	195	✓	FL.8 FHC 2821	195	✓
FL.6 corridor	100	✓	FL.8 staff lift	100	✓
FL.6 FHC	195	✓	FL.7 FHC 2701	195	✓
FL.5 corridor	100	✓	FL.7 FHC 2721	195	✓
FL.5 FHC	195	Not Satisfactory	FL.7 staff lift	100	✓
FL.4 corridor	100	✓	FL.6 FHC 2601	195	✓
FL.4 FHC	Co2	✓	FL.6 FHC 2621	195	✓
FL.3 corridor	100	✓	FL.6 staff lift	100	✓
FL.3 FHC	195	✓	FL.5 FHC 2501	195	✓
FL.2 corridor	100	✓	FL.5 FHC 2521	195	✓
FL.2 FHC	Co2	✓	FL.5 staff lift	100	✓
FL.G FHC security	195	✓	FL.4 FHC 2401	195	✓
FL.G FHC restaurent	195	✓	FL.4 FHC 2421	195/195	✓
FL.B1 FHC	195	✓	FL.4 staff lift	100/195	✓
FL.B1 kitchen (1)	100	✓	FL.3 FHC 2301	195	✓
FL.B1 kitchen (2)	100	✓	FL.3 FHC 2321	195	✓
FL.B1 staff lift	100	✓	FL.3 staff lift	100	✓
FL.B2 staff lift	100	✓	FL.2 FHC 2201	195	✓
FL.B2 FHC	195	✓	FL.2 FHC 2221	100	✓
FL.B2 FHC fire pump	Co2 195	✓	FL.2 staff lift	100	✓
Generator room	Co2	✓	FL.G FHC Lobby	195	✓
MDB Room	Co2	✓	FHC front office	195	✓
MDB Roo	Co2	✓	FL.B1 FHC Car park	195/195	✓
			FL.B2 FHC Car park	195/195	✓

Checked By Supervisor		Date	11/3/23
Approve By Chief Engineer		Date	11/3/23




**Travelodge**

SUKHUMVIT 11

TRAVELODGE SUKHUMVIT
ENGINEERING DEPARTMENT
EXTINGUISHERS CHECKLIST

Tower A			Tower B		
Locations	Pressure Psi.	Remark	Locations	Pressure Psi.	Remark
FL.8 FHC Pump room	195	✓	Roof FHC (1)	195	✓
FL.8 FHC	195	✓	Roof FHC (2)	195	✓
FL.7 corridor	100	✓	FL.8 FHC 2801	195	✓
FL.7 FHC	195	✓	FL.8 FHC 2821	195	✓
FL.6 corridor	100	✓	FL.8 staff lift	100	✓
FL.6 FHC	100	✓	FL.7 FHC 2701	195	✓
FL.5 corridor	195	✓	FL.7 FHC 2721	195	✓
FL.5 FHC	100	✓	FL.7 staff lift	100	✓
FL.4 corridor	102	✓	FL.6 FHC 2601	195	✓
FL.4 FHC	100	✓	FL.6 FHC 2621	195	✓
FL.3 corridor	195	✓	FL.6 staff lift	195	✓
FL.3 FHC	100	✓	FL.5 FHC 2501	195	✓
FL.2 corridor	102	✓	FL.5 FHC 2521	195	✓
FL.2 FHC	195	✓	FL.5 staff lift	100	✓
FL.G FHC security	195	✓	FL.4 FHC 2401	195	✓
FL.G FHC restaurant	195	✓	FL.4 FHC 2421	195	✓
FL.B1 FHC	100	✓	FL.4 staff lift	100	✓
FL.B1 kitchen (1)	100	✓	FL.3 FHC 2301	195	✓
FL.B1 kitchen (2)	100	✓	FL.3 FHC 2321	195	✓
FL.B1 staff lift	100	✓	FL.3 staff lift	100	✓
FL.B2 staff lift	195	✓	FL.2 FHC 2201	195	✓
FL.B2 FHC	195	✓	FL.2 FHC 2221	100	✓
FL.B2 FHC fire pump	195	✓	FL.2 staff lift	100	✓
Generator room	102	✓	FL.G FHC Lobby	195	✓
MDB Room	102	✓	FHC front office	195	✓
MDB Room.	102		FL.B1 FHC Car park	195/195	✓
			FL.B2 FHC Car park	195/195	✓



Checked By Supervisor		Date	10/6/23
Approve By Chief Engineer		Date	10/6/23

**Travelodge**

SUKHUMVIT 11

TRAVELODGE SUKHUMVIT
ENGINEERING DEPARTMENT
EXTINGUISHERS CHECKLIST

Tower A			Tower B		
Locations	Pressure Psi.	Remark	Locations	Pressure Psi.	Remark
FL.8 FHC Pump room	195	/	Roof FHC (1)	195	/
FL.8 FHC	195	/	Roof FHC (2)	195	/
FL.7 corridor	100	/	FL.8 FHC 2801	195	/
FL.7 FHC	195	/	FL.8 FHC 2821	195	/
FL.6 corridor	100	/	FL.8 staff lift	100	/
FL.6 FHC	100	/	FL.7 FHC 2701	195	/
FL.5 corridor	195	/	FL.7 FHC 2721	195	/
FL.5 FHC	100	/	FL.7 staff lift	100	/
FL.4 corridor	CO2	/	FL.6 FHC 2601	195	/
FL.4 FHC	100	/	FL.6 FHC 2621	195	/
FL.3 corridor	195	/	FL.6 staff lift	195	/
FL.3 FHC	100	/	FL.5 FHC 2501	195	/
FL.2 corridor	CO2	/	FL.5 FHC 2521	195	/
FL.2 FHC	195	/	FL.5 staff lift	100	/
FL.G FHC security	195	/	FL.4 FHC 2401	195	/
FL.G FHC restaurant	100	/	FL.4 FHC 2421	195	/
FL.B1 FHC	100	/	FL.4 staff lift	100	/
FL.B1 kitchen (1)	100	/	FL.3 FHC 2301	195	/
FL.B1 kitchen (2)	100	/	FL.3 FHC 2321	195	/
FL.B1 staff lift	100	/	FL.3 staff lift	100	/
FL.B2 staff lift	195	/	FL.2 FHC 2201	195	/
FL.B2 FHC	195	/	FL.2 FHC 2221	100	/
FL.B2 FHC fire pump	195	/	FL.2 staff lift	100	/
Generator room	CO2	/	FL.G FHC Lobby	195	/
MDB Room	CO2	/	FHC front office	195	/
MDB Room	CO2	/	FL.B1 FHC Car park	195/195	/
			FL.B2 FHC Car park	195/195	/



Checked By Supervisor		Date	3/5/23
Approve By Chief Engineer		Date	3/5/23

**Travelodge**

SUKHUMVIT 11

TRAVELODGE SUKHUMVIT
ENGINEERING DEPARTMENT
EXTINGUISHERS CHECKLIST

Tower A			Tower B		
Locations	Pressure Psi.	Remark	Locations	Pressure Psi.	Remark
FL.8 FHC Pump room	195	/	Roof FHC (1)	195	/
FL.8 FHC	195	/	Roof FHC (2)	195	/
FL.7 corridor	100	/	FL.8 FHC 2801	195	/
FL.7 FHC	195	/	FL.8 FHC 2821	195	/
FL.6 corridor	100	/	FL.8 staff lift	100	/
FL.6 FHC	100	/	FL.7 FHC 2701	195	/
FL.5 corridor	195	/	FL.7 FHC 2721	195	/
FL.5 FHC	100	/	FL.7 staff lift	100	/
FL.4 corridor	CO2	/	FL.6 FHC 2601	195	/
FL.4 FHC	100	/	FL.6 FHC 2621	195	/
FL.3 corridor	195	/	FL.6 staff lift	195	/
FL.3 FHC	100	/	FL.5 FHC 2501	195	/
FL.2 corridor	CO2	/	FL.5 FHC 2521	195	/
FL.2 FHC	195	/	FL.5 staff lift	100	/
FL.G FHC security	195	/	FL.4 FHC 2401	195	/
FL.G FHC restaurant	100	/	FL.4 FHC 2421	195	/
FL.B1 FHC	100	/	FL.4 staff lift	100	/
FL.B1 kitchen (1)	100	/	FL.3 FHC 2301	195	/
FL.B1 kitchen (2)	100	/	FL.3 FHC 2321	195	/
FL.B1 staff lift	100	/	FL.3 staff lift	100	/
FL.B2 staff lift	195	/	FL.2 FHC 2201	195	/
FL.B2 FHC	195	/	FL.2 FHC 2221	100	/
FL.B2 FHC fire pump	195	/	FL.2 staff lift	100	/
Generator room	CO2	/	FL.G FHC Lobby	195	/
MDB Room	CO2	/	FHC front office	195	/
MDB Room	CO2	/	FL.B1 FHC Car park	195/195	/
			FL.B2 FHC Car park	195/195	/

Checked By Supervisor		Date	4/6/23
Approve By Chief Engineer		Date	4/6/23