

## ภาคผนวก ค-2

---

เอกสารตรวจสอบระบบ Aeration tank



MARRIOTT RESORT  
HUA HIN



Aeration Tank

Date: 15/5/23 Time 9:00		AAE-D-01	
<p>Pump Type : Submersible Model : TOS 37-BER5 Pump Serial No. : B-10913652 Brand : TSURUMI Model Motor : TOS 37-BER5 Motor Serial No. : B-10913652 Volte 380 - 400 V / 3.7 Kw / 50 Hz Pump Speed : 1500 Rpm. Auto Start Stop</p>			
Item	Detail		Remark
Voltage	V1 = 401 V		
	V2 = 402 V		
	V3 = 404 V		
Ampare	L1 = 3.2 A		
	L2 = 3.1 A		
	L3 = 3.0 A		
Auto Start	Psig		
Auto Stop	Psig		
Control (คอนโทรล)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Pump Head (แรงดัน)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Pump Run	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Pump Stop	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Overload set	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
High Alarm	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Check valve	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Butterfly Valve	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Note : ..... ..... ..... .....			
Inspect By : Name : <u>Technician</u> Position : <u>Technician</u> Date : <u>15/5/23</u>	Engineer incharge : Name : <u>[Signature]</u> Position : <u>Duty Eng.</u> Date : <u>15/5/23</u>	Manager : Name : Position : Date :	



MARRIOTT RESORT  
HUA HIN

Aeration Tank

Date: 15/5/23 Time: .....		AAE-D-02	
<p>Pump Type : Submersible Model : TOS 37-BER5 Pump Serial No. B-10913651 Brand : TSURUMI Model Motor : TOS 37-BER5 Motor Serial No. : B-10913651 Volts 380 - 400 V / 3.7 Kw / 50 Hz Pump Speed : 1500 Rpm. Auto Start Stop</p>			
Item		Detail	
Voltage		V1 = 400 V	
		V2 = 401 V	
		V3 = 402 V	
Ampere		L1 = 3.2 A	
		L2 = 2.0 A	
		L3 = 3.1 A	
Auto Start		Psig	
Auto Stop		Psig	
Control	(คอนโทรล)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Head	(แรงดัน)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Run		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Stop		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Overload set		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
High Alarm		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Check valve		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Butterfly Valve		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Note : .....			
Inspect By : 		Engineer incharge : 	
Name : .....		Name : .....	
Position : Technician		Position : Duty Org	
Date : 15/5/23		Date : 15/5/23	
		Manager : .....	
		Name : .....	
		Position : .....	
		Date : .....	



MARRIOTT RESORT  
HUA HIN

# Aeration Tank

Date: 15/5/23.. Time.....		AAE-D-03	
Pump Type : Submersible Model : TOS 37-BER5 Pump Serial No. B-10913654 Brand : TSURUMI Model Motor : TOS 37-BER5 Motor Serial No. : B-10913654 Volte 380 - 400 V / 3.7 Kw / 50 Hz Pump Speed : 1500 Rpm. Auto Start Stop			
Item	Detail		Remark
Voltage	V1 = 401 V		
	V2 = 404 V		
	V3 = 403 V		
Ampare	L1 = 3.5 A		
	L2 = 3.6 A		
	L3 = 3.4 A		
Auto Start	Psig		
Auto Stop	Psig		
Control	(คอนโทรล)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Head	(แรงดัน)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Run		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Stop		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Overload set		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
High Alarm		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Check valve		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Butterfly Valve		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Note :    			
Inspect By : Name : Position : Date : 15/5/23	Engineer incharge : Name : Position : Date : 15/5/23		Manager : Name : Position : Date :





MARRIOTT RESORT  
HUA HIN



Aeration Tank

Date: 15/5/23. Time: .....		AAE-D-04	
<p>Pump Type : Submersible Model : TOS 37-BER5 Pump Serial No. B-10913655 Brand : TSURUMI Model Motor : TOS 37-BER5 Motor Serial No. : B-10913655 Volte 380 - 400 V / 3.7 Kw / 50 Hz Pump Speed : 1500 Rpm. Auto Start Stop</p>			
Item	Detail	Remark	
Voltage	V1 = 401 V		
	V2 = 404 V		
	V3 = 400 V		
Ampare	L1 = 3.1 A		
	L2 = 3.5 A		
	L3 = 3.2 A		
Auto Start	Psig		
Auto Stop	Psig		
Control (คอนโทรล)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Pump Head (แรงดัน)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Pump Run	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Pump Stop	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Overload set	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
High Alarm	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Check valve	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Butterfly Valve	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Note : .....			
.....			
.....			
.....			
Inspect By : <u>Teenichin</u> Name : <u>Teenichin</u> Position : <u>15/5/23</u> Date : <u>15/5/23</u>		Engineer incharge : <u>Duty</u> Name : <u>Duty</u> Position : <u>309</u> Date : <u>15/5/23</u>	
		Manager : Name : Position : Date :	



MARRIOTT RESORT  
HUA HIN

Circulation Tank

Date: 15/5/23 Time: .....		CIP-D-01		
<p>Pump Type : Submersible Model : TOS 50B2.75H53 Pump Serial No. B-2129450 Brand : TSURUMI Model Motor : TOS 50B2H75-53 Motor Serial No. : B-2129450 Volte 380 - 400 V / 1.9A / 0.75 Kw / 50 Hz Pump Speed : 3000 Rpm. Auto Start Stop</p>				
Item		Detail		Remark
Voltage		V1 = 100 V		
		V2 = 102 V		
		V3 = 104 V		
Ampare		L1 = 1.8 A		
		L2 = 1.7 A		
		L3 = 1.6 A		
Auto Start		Psig		
Auto Stop		Psig		
Control	(คอนโทรล)	<input checked="" type="checkbox"/> O.K.	<input type="checkbox"/> Not.O.K.	
Pump Head	(แรงดัน)	<input checked="" type="checkbox"/> O.K.	<input type="checkbox"/> Not.O.K.	
Pump Run		<input checked="" type="checkbox"/> O.K.	<input type="checkbox"/> Not.O.K.	
Pump Stop		<input checked="" type="checkbox"/> O.K.	<input type="checkbox"/> Not.O.K.	
Overload set		<input checked="" type="checkbox"/> O.K.	<input type="checkbox"/> Not.O.K.	
High Alarm		<input checked="" type="checkbox"/> O.K.	<input type="checkbox"/> Not.O.K.	
Check valve		<input checked="" type="checkbox"/> O.K.	<input type="checkbox"/> Not.O.K.	
Butterfly Valve		<input checked="" type="checkbox"/> O.K.	<input type="checkbox"/> Not.O.K.	
Note : .....				
.....				
.....				
.....				
Inspect By : 		Engineer incharge : 		Manager :
Name : Technician		Name : Duly Sng		Name : .....
Position : Technician		Position : Duly Sng		Position : .....
Date : 15/5/23		Date : 15/5/23		Date : .....



MARRIOTT RESORT  
HUA HIN

# Circulation Tank



Date: ..... Time: .....		CIP-D-02	
Pump Type : Submersible Model : TOS 50B2.75H53 Pump Serial No. B-2129486 Brand : TSURUMI Model Motor : TOS 50B2H75-53 Motor Serial No. : B-2129486 Volte 380 - 400 V/ 1.9A / 0.75 Kw / 50 Hz Pump Speed : 3000 Rpm. Auto Start Stop			
Item	Detail		Remark
Voltage	V1 = <u>100</u> V		
	V2 = <u>101</u> V		
	V3 = <u>104</u> V		
Ampare	L1 = <u>1.6</u> A		
	L2 = <u>1.6</u> A		
	L3 = <u>1.7</u> A		
Auto Start		Psig	
Auto Stop		Psig	
Control	(คอนโทรล)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Head	(แรงดัน)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Run		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Stop		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Overload set		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
High Alarm		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Check valve		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Butterfly Valve		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Note : ..... ..... ..... .....			
Inspect By : <u>Technichin</u> Name : ..... Position : ..... Date : <u>15/5/23</u>		Engineer incharge : <u>Dutayong</u> Name : ..... Position : ..... Date : <u>15/5/23</u>	
		Manager : ..... Name : ..... Position : ..... Date : .....	





MARRIOTT RESORT  
HUA HIN

# Effluent Tank

Date: 15/5/23 Time: .....		EEP-D-01	
<p>Pump Type : Submersible Model : TOS 50B2.75H53 Pump Serial No. B-2129447 Brand : TSURUMI Model Motor : TOS 50B2H75-53 Motor Serial No. : B-2129447 Volte 380 - 400 V / 1.9A / 0.75 Kw / 50 Hz Pump Speed : 3000 Rpm. Auto Start Stop</p>			
Item	Detail	Remark	
Voltage	V1 = 100 V		
	V2 = 101 V		
	V3 = 102 V		
Ampare	L1 = 1.7 A		
	L2 = 1.5 A		
	L3 = 1.6 A		
Auto Start	Psig		
Auto Stop	Psig		
Control (คอนโทรล)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Pump Head (แรงดัน)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Pump Run	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Pump Stop	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Overload set.	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
High Alarm	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Check valve	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Butterfly Valve	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Note : .....			
.....			
.....			
.....			
.....			
Inspect By : 	Engineer Incharge : 	Manager : .....	
Name : Technician	Name : Duty SW	Name : .....	
Position : 15/5/23	Position : 15/5/23	Position : .....	
Date : 15/5/23	Date : 15/5/23	Date : .....	





MARRIOTT RESORT  
HUA HIN

Effluent Tank

Date: 15/5/23 Time: .....		EFP-D-02	
<p>Pump Type : Submersible Model : TOS 50B2.75H53 Pump Serial No. B-2129493 Brand : TSURUMI Model Motor : TOS 50B2H75-53 Motor Serial No. : B-2129493 Volts 380 - 400 V / 1.9A / 0.75 Kw / 50 Hz Pump Speed : 3000 Rpm. Auto Start Stop</p>			
Item	Detail	Remark	
Voltage	V1 = 400 V		
	V2 = 401 V		
	V3 = 402 V		
Ampere	L1 = 1.6 A		
	L2 = 1.7 A		
	L3 = 1.7 A		
Auto Start	Psig		
Auto Stop	Psig		
Control	(คอนโทรล)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Head	(แรงดัน)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Run		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Stop		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Overload set		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
High Alarm		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Check valve		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Butterfly Valve		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Note : .....			
.....			
.....			
.....			
Inspect By : <u>                    </u> Name : <u>                    </u> Position : <u>Technician</u> Date : <u>15/5/23</u>		Engineer incharge : <u>                    </u> Name : <u>                    </u> Position : <u>Duty eng</u> Date : <u>15/5/23</u>	
		Manager : Name : ..... Position : ..... Date : .....	

Date: 15/5/23. Time: .....		SAE-D-01	
Pump Type : Submersible Model : TOS 15-BER3 Pump Serial No. B-10892221 Brand : TSURUMI Model Motor : TOS 15-BER3 Motor Serial No. : B-10892221 Volte 380 - 400 V / 1.5 Kw / 50 Hz Pump Speed : 3000 Rpm. Auto Start Stop			
Item	Detail	Remark	
Voltage	V1 = 400 V		
	V2 = 398 V		
	V3 = 401 V		
Ampare	L1 = 2.2 A		
	L2 = 2.5 A		
	L3 = 2.5 A		
Auto Start	Psig		
Auto Stop	Psig		
Control (คอนโทรล)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Pump Head (แรงดัน)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Pump Run	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Pump Stop	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Overload set	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
High Alarm	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Check valve	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Butterfly Valve	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Note : ..... ..... ..... .....			
Inspect By : <u>Technician</u> Name : ..... Position : ..... Date : 15/5/23	Engineer incharge : <u>Duta eng</u> Name : ..... Position : ..... Date : 15/5/23	Manager : ..... Name : ..... Position : ..... Date : .....	



MARRIOTT RESORT  
HUA HIN

Sludge Storage Tank

Date: ..... Time: .....		SAE-D-02	
<p>Pump Type : Submersible Model : TOS 15-BER3 Pump Serial No. B-10892219 Brand : TSURUMI Model Motor : TOS 15-BER3 Motor Serial No. : B-10892219 Volts 380 - 400 V / 1.5 Kw / 50 Hz Pump Speed : 3000 Rpm. Auto Start Stop.</p>			
Item	Detail	Remark	
Voltage	V1 = <u>401</u> V		
	V2 = <u>402</u> V		
	V3 = <u>404</u> V		
Ampere	L1 = <u>2.4</u> A		
	L2 = <u>2.5</u> A		
	L3 = <u>2.5</u> A		
Auto Start	Psig		
Auto Stop	Psig		
Control	(คอนโทรล)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Head	(แรงดัน)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Run		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Stop		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Overload set		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
High Alarm		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Check valve		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Butterfly Valve		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Note : .....			
.....			
.....			
.....			
.....			
Inspect By : <u>Technician</u> Name : <u>15/5/23</u> Position : <u>Technician</u> Date : <u>15/5/23</u>		Engineer incharge : <u>15/5/23</u> Name : <u>15/5/23</u> Position : <u>15/5/23</u> Date : <u>15/5/23</u>	
		Manager : Name : ..... Position : ..... Date : .....	



# Equalization Tank

Date: ..... Time: .....		EQP-D-01	
Pump Type : Submersible Model : TOS 50B2.75-53 Pump Serial No. B-2136373 Brand : TSURUMI Model Motor : TOS 50B2.75-53 Motor Serial No. : B-2136373 Volte 380 - 400 V / 0.75 Kw / 50 Hz Pump Speed : 3000 Rpm. Auto Start Stop			
Item	Detail	Remark	
Voltage	V1 = <u>402</u> V		
	V2 = <u>400</u> V		
	V3 = <u>401</u> V		
Ampare	L1 = <u>1.9</u> A		
	L2 = <u>1.6</u> A		
	L3 = <u>1.5</u> A		
Auto Start	Psig		
Auto Stop	Psig		
Control	(คอนโทรล)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Head	(แรงดัน)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Run		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Stop		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Overload set		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
High Alarm		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Check valve		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Butterfly Valve		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Note : ..... ..... ..... .....			
Inspect By : <u>Technician</u> Name : ..... Position : <u>Technician</u> Date : <u>15/5/23</u>		Engineer incharge : <u>Duty Sng</u> Name : ..... Position : ..... Date : <u>15/5/23</u>	
		Manager : ..... Name : ..... Position : ..... Date : .....	



Date: ..... Time: .....		EQE-D-01	
Pump Type : Submersible Model : TOS 15-BER3 Pump Serial No. B-10892223 Brand : TSURUMI Model Motor : TOS 15-BER3 Motor Serial No. : B-10892223 Volte 380 - 400 V / 1.5 Kw / 50 Hz Pump Speed : 3000 Rpm. Auto Start Stop			
Item	Detail	Remark	
Voltage	V1 = <u>401</u> V		
	V2 = <u>402</u> V		
	V3 = <u>400</u> V		
Ampare	L1 = <u>2.4</u> A		
	L2 = <u>2.4</u> A		
	L3 = <u>2.5</u> A		
Auto Start	Psig		
Auto Stop	Psig		
Control	(คอนโทรล)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Head	(แรงดัน)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Run		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Stop		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Overload set		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
High Alarm		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Check valve		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Butterfly Valve		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Note : ..... ..... ..... .....			
Inspect By : <u>Teenichin</u> Name : ..... Position : ..... Date : <u>15/5/23</u>	Engineer incharge : <u>Duty Eng</u> Name : ..... Position : ..... Date : <u>15/5/23</u>	Manager : ..... Name : ..... Position : ..... Date : .....	

Date: <u>15/5/23</u> Time: .....		EQE-D-02	
Pump Type : Submersible Model : TOS 15-BER3 Pump Serial No. B-10892219 Brand : TSURUMI Model Motor : TOS 15-BER3 Motor Serial No. : B-10892219 Volte 380 - 400 V / 1.5 Kw / 50 Hz Pump Speed : 3000 Rpm. Auto Start Stop			
Item	Detail	Remark	
Voltage	V1 = <u>398</u> V		
	V2 = <u>400</u> V		
	V3 = <u>401</u> V		
Ampare	L1 = <u>2.5</u> A		
	L2 = <u>2.4</u> A		
	L3 = <u>2.3</u> A		
Auto Start	Psig		
Auto Stop	Psig		
Control (คอนโทรล)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Pump Head (แรงดัน)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Pump Run	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Pump Stop	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Overload set	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
High Alarm	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Check valve	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Butterfly Valve	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Note : ..... ..... ..... .....			
Inspect By : <u>Technician</u>	Engineer incharge : <u>Duty Eng</u>	Manager :	
Name : .....	Name : .....	Name : .....	
Position : .....	Position : .....	Position : .....	
Date : <u>15/5/23</u>	Date : <u>15/5/23</u>	Date : .....	



Date: 15/5/23 Time: .....		EQE-D-03	
Pump Type : Submersible Model : TOS 15-BER3 Pump Serial No. B-10892220 Brand : TSURUMI Model Motor : TOS 15-BER3 Motor Serial No. : B-10892220 Volte 380 - 400 V / 1.5 Kw / 50 Hz Pump Speed : 3,000 Rpm. Auto Start Stop			
Item	Detail	Remark	
Voltage	V1 = 400 V		
	V2 = 401 V		
	V3 = 404 V		
Ampare	L1 = 2.4 A		
	L2 = 2.4 A		
	L3 = 2.5 A		
Auto Start	Psig		
Auto Stop	Psig		
Control (คอนโทรล)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Pump Head (แรงดัน)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Pump Run	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Pump Stop	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Overload set	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
High Alarm	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Check valve	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Butterfly Valve	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.		
Note : ..... ..... ..... .....			
Inspect By : Name : ..... Position : Technician Date : 10/5/23	Engineer incharge : Name : ..... Position : Duty Eng. Date : 15/5/23	Manager : ..... Name : ..... Position : ..... Date : .....	





MARRIOTT RESORT  
HUA HIN

# Equalization Tank

Date: 15/5/23 Time: .....		EQE-D-04	
<p>Pump Type : Submersible Model : TOS 15-BER3 Pump Serial No. B-10892210 Brand : TSURUMI Model Motor : TOS 15-BER3 Motor Serial No. : B-10892210 Volte 380 - 400 V / 1.5 Kw / 50 Hz Pump Speed : 3000 Rpm. Auto Start Stop</p>			
Item	Detail		Remark
Voltage	V1 = 400 V		
	V2 = 401 V		
	V3 = 402 V		
Ampare	L1 = 2.5 A		
	L2 = 2.4 A		
	L3 = 2.5 A		
Auto Start	Psig		
Auto Stop	Psig		
Control	(คอนโทรล)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Head	(แรงดัน)	<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Run		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Pump Stop		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Overload set		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
High Alarm		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Check valve		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Butterfly Valve		<input checked="" type="checkbox"/> O.K. <input type="checkbox"/> Not.O.K.	
Note : .....			
.....			
.....			
.....			
Inspect By :  Name : .....		Engineer incharge :  Name : .....	
Position : Technician		Position : Duty Eng	
Date : 15/5/23		Date : 15/5/23	
		Manager : Name : ..... Position : ..... Date : .....	