

LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01							
Rev. Date : 31/01/2015							
Month : JANUARY Year : 2023							
BUILDING : The Strand thonglor (Adult swimming pool)							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
1	Morning	1.0	7.4	17	[Redacted]	[Redacted]	
	Afternoon	1.0	7.8	17			
2	Morning	1.0	7.8	17	[Redacted]	[Redacted]	
	Afternoon	1.0	7.4	18			
3	Morning	1.0	7.4	16	[Redacted]	[Redacted]	
	Afternoon	1.0	7.8	18			
4	Morning	1.0	7.8	16	[Redacted]	[Redacted]	BACK WASH
	Afternoon	1.0	7.8	16			
5	Morning	1.0	7.8	16	[Redacted]	[Redacted]	
	Afternoon	1.0	7.8	16			
6	Morning	1.0	7.8	16	[Redacted]	[Redacted]	
	Afternoon	1.0	7.4	16			
7	Morning	1.0	7.8	16	[Redacted]	[Redacted]	
	Afternoon	1.0	7.8	17			
Comment : _____ _____ _____							

7 / 1 / 20

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: JANUARY		Year: 2023							
BUILDING: The Strand thonglor (Kid swimming pool)									
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
1	Morning	06.00	1.5	7.4	17	[Redacted]			
	Afternoon	18.00	1.5	7.8	17				
2	Morning	06.00	1.5	7.4	17				
	Afternoon	17.00	1.5	7.8	17				
3	Morning	06.00	1.5	7.4	17				
	Afternoon	17.00	1.5	7.8	17				
4	Morning	06.00	1.5	7.4	17				
	Afternoon	17.00	1.5	7.8	17				
5	Morning	06.00	1.5	7.4	17				
	Afternoon	17.00	1.5	7.8	17				
6	Morning	06.00	1.5	7.4	17				
	Afternoon	17.00	1.5	7.8	17				
7	Morning	06.00	1.5	7.4	17				
	Afternoon	17.00	1.5	7.8	17				
Comment: _____ BSE: 7 / 7 / 66									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



25

LOG SHEET OF SWIMMING POOL / POND									
BUILDING : The Strand thonglor (Adult swimming pool)					Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015				
					Month : JANUARY Year : 2023				
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
8	Morning	06:00	0.5	7.8	11	[Redacted]			
	Afternoon	17:00	2.0	7.8	12				
9	Morning	06:00	1.5	7.8	17				
	Afternoon	17:00	0.5	7.8	17				
10	Morning	06:00	0.5	7.8	17				
	Afternoon	17:00	0.5	7.8	16				
11	Morning	06:00	0.5	7.8	16			Back Wash	
	Afternoon	17:00	0.5	7.8	16				
12	Morning	06:00	0.6	7.8	16				
	Afternoon	17:00	1.0	7.8	16				
13	Morning	06:00	1.0	7.8	16				
	Afternoon	16:00	0.8	7.8	16				
14	Morning	06:00	0.5	7.8	16			Back Wash	
	Afternoon	17:00	0.6	7.8	16				
Comment :					BSE : 14, 1, 00				

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date : 31/01/2015									
Month : JANUARY		Year : 2023							
BUILDING : The Strand thonglor (Kid swimming pool)									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
8	Morning	0.5	7.8	16	[Redacted]				
	Afternoon	1.5	8.8	12					
9	Morning	1.0	7.8	16					
	Afternoon	1.0	7.8	16					
10	Morning	0.9	7.8	16					
	Afternoon	1.0	8.8	16					
11	Morning	1.0	7.8	16				Back wash	
	Afternoon	1.0	7.8	16					
12	Morning	1.0	7.8	16					
	Afternoon	1.0	7.8	16					
13	Morning	0.5	7.8	16					
	Afternoon	0.9	7.8	16					
14	Morning	1.0	7.8	16				Back wash	
	Afternoon	1.0	8.8	16					
Comment : _____ _____ _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: JANUARY		Year: 2023							
BUILDING: The Strand thonglor (Adult swimming pool)									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
15	Morning	06:10	0.3	7.8	[Redacted]				
	Afternoon	18:00	1.0	7.8					
16	Morning	06:00	0.3	7.8					
	Afternoon	18:00	0.5	7.8					
17	Morning	06:00	0.5	7.8					
	Afternoon	16:30	0.5	7.8					
18	Morning	06:00	0.5	7.8					
	Afternoon	16:30	0.3	7.8					
19	Morning	06:00	0.5	7.8					
	Afternoon	16:30	0.5	7.8					
20	Morning	06:00	0.3	7.8					
	Afternoon	18:00	0.5	7.8					
21	Morning	06:00	1.0	7.8					
	Afternoon	18:00	0.3	7.8					
Comment:		23, 7 / 66							

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND																								
Ref No: JLL-OP-SN-004/01																								
Rev. Date: 31/01/2015																								
Month: JANUARY		Year: 2023																						
BUILDING: The Strand thonglor (Kid swimming pool)																								
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark																
			Chlorine (ppm)	pH																				
15	Morning	05:00	0.5	7.8	16	[Redacted]																		
	Afternoon	19:00	1.5	7.5	16																			
16	Morning	06:00	0.5	7.8	16				[Redacted]		Back wash													
	Afternoon	18:00	0.5	7.8	16																			
17	Morning	06:00	0.5	7.8	16							[Redacted]		Back wash										
	Afternoon	16:30	0.5	7.8	16																			
18	Morning	06:00	0.5	7.4	16										[Redacted]		Back wash							
	Afternoon	16:30	0.5	7.8	16																			
19	Morning	06:00	0.5	7.4	16													[Redacted]		Back wash				
	Afternoon	17:00	0.5	7.4	16																			
20	Morning	05:00	0.3	7.4	18																[Redacted]		Back wash	
	Afternoon	17:00	1.0	7.8	16																			
21	Morning	04:00	1.5	7.8	18	[Redacted]		Back wash																
	Afternoon	17:00	1.0	7.4	16																			
Comment: _____ BSE: _____ 29/1 / 66																								

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: JANUARY		Year: 2023							
BUILDING: The Strand thonglor		(Adult swimming pool)							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
22	Morning	0.7	7.4	16	[Redacted]				
	Afternoon	0.5	7.8	16					
23	Morning	1.0	7.8	16					
	Afternoon	0.6	7.8	16					
24	Morning	0.5	7.8	16					
	Afternoon	0.6	7.4	16					
25	Morning	0.5	7.8	16					
	Afternoon	0.5	7.8	16					
26	Morning	0.3	7.8	16					
	Afternoon	0.5	7.8	16					
27	Morning	0.3	7.4	16					
	Afternoon	0.6	7.8	16					
28	Morning	0.5	7.4	16					
	Afternoon	0.3	7.8	16					
Comment:								20/1/26	

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: JANUARY		Year: 2023							
BUILDING: The Strand thonglor (Kid swimming pool)									
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
22	Morning	06:00	0.5	7.8	14	[Redacted]	[Redacted]		
	Afternoon	17:00	0.5	7.8	16				
23	Morning	06:00	1.0	7.8	16	[Redacted]	[Redacted]	Back wash	
	Afternoon	17:00	1.0	7.8	16				
24	Morning	06:00	1.0	7.8	16	[Redacted]	[Redacted]	Back wash	
	Afternoon	17:00	0.5	7.8	11				
25	Morning	06:00	1.0	7.8	16	[Redacted]	[Redacted]	Back wash	
	Afternoon	17:00	0.5	7.8	16				
26	Morning	06:00	0.5	7.8	16	[Redacted]	[Redacted]		
	Afternoon	17:00	0.5	7.8	16				
27	Morning	06:00	0.5	7.8	15	[Redacted]	[Redacted]		
	Afternoon	17:00	1.0	7.8	16				
28	Morning	06:30	1.0	7.8	15	[Redacted]	[Redacted]		
	Afternoon	17:00	0.5	7.9	16				
Comment: _____ _____ _____									

30 / 1 / 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor (Adult swimming pool)				Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015 Month : JANUARY Year : 2023			
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
29	Morning	06:30	0.3	7.8	16	[REDACTED]			
	Afternoon	17:00	0.3	7.8	16				
30	Morning	06:40	1.0	7.8	16				
	Afternoon	17:40	0.5	7.8	16				
31	Morning	06:00	0.5	7.8	16				
	Afternoon	17:40	0.5	7.8	16				
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								

Comment : _____
 BSE : _____ / _____ / _____

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							
Ref No: JLL-OP-SN-004/01							
Rev. Date : 31/01/2015							
Month : JANUARY		Year : 2023					
BUILDING : The Strand thonglor (Kid swimming pool)							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
29	Morning	0.3	7.8	16			
	Afternoon	0.6	7.8	16			
30	Morning	1.5	7.8	16			
	Afternoon	0.6	7.8	16			
31	Morning	0.3	7.8	16			
	Afternoon	0.3	7.8	16			
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						

Comment : _____

BSE : _____ / _____ / _____

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date : 31/01/2015									
Month : FEBRUARY		Year : 2023							
BUILDING : The Strand thonglor		(Adult swimming pool)							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
1	Morning	06:00	0.3	7.8	[Redacted]	[Redacted]	Back WASH		
	Afternoon	17:00	0.3	7.8					
2	Morning	06:00	0.3	7.8					
	Afternoon	17:00	0.3	7.8					
3	Morning	06:00	0.3	7.8					
	Afternoon	17:00	0.3	7.8					
4	Morning	06:00	0.3	7.8					
	Afternoon	17:00	0.3	7.8					
5	Morning	06:00	0.5	7.8					
	Afternoon	17:00	0.3	7.8					
6	Morning	06:00	0.3	7.8					
	Afternoon	18:00	0.3	7.8					
7	Morning	06:00	0.5	7.8					
	Afternoon	18:00	0.3	7.8					
Comment : _____ BSE : _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date : 31/01/2015									
Month : FEBRUARY		Year : 2023							
BUILDING : The Strand thonglor		(Kid swimming pool)							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
1	Morning	06.00	0.3	7.8	[Redacted]		BLACK WASH		
	Afternoon	17.00	0.5	7.8					
2	Morning	06.00	0.5	7.8					
	Afternoon	17.00	1.0	7.8					
3	Morning	06.00	1.0	7.8					
	Afternoon	17.00	1.5	7.8					
4	Morning	06.00	0.3	7.8					
	Afternoon	17.00	0.3	7.8					
5	Morning	06.00	1.0	7.8					
	Afternoon	17.00	1.0	7.8					
6	Morning	06.00	0.5	7.8					
	Afternoon	17.00	1.0	7.8					
7	Morning	06.00	1.0	7.8					
	Afternoon	17.00	0.5	7.8					
Comment : _____ _____ _____									

8 / 2 / 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01 Rev. Date: 31/01/2015									
BUILDING : The Strand thonglor (Adult swimming pool)									
Month : FEBRUARY Year : 2023									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
8	Morning	06.00	0.3	7.8	[Redacted]	[Redacted]	Back wash		
	Afternoon	18.00	0.3	7.8					
9	Morning	06.00	0.3	7.8					
	Afternoon	18.00	0.3	7.8					
10	Morning	06.00	0.3	7.8					
	Afternoon	18.00	0.3	7.8					
11	Morning	06.00	0.3	7.8					
	Afternoon	18.00	0.3	7.8					
12	Morning	06.00	0.3	7.8					
	Afternoon	17.00	0.3	7.8					
13	Morning	06.00	0.3	7.8					
	Afternoon	07.00	0.3	7.8					
14	Morning	06.00	0.3	7.8					
	Afternoon	06.00	0.3	7.8					

Comment : _____
 BSE _____

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: FEBRUARY		Year: 2023							
BUILDING: The Strand thonglor		(Kid swimming pool)							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
8	Morning	0.3	7.8	16	[Redacted]				
	Afternoon	0.3	7.8	16					
9	Morning	0.3	7.8	16					
	Afternoon	1.0	7.8	16					
10	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
11	Morning	0.3	7.8	16				Back Wash	
	Afternoon	0.5	7.8	16					
12	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
13	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
14	Morning	0.3	7.8	16				Back Wash	
	Afternoon	0.3	7.8	16					

Comment: _____

BSE: 15/2/16

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING : The Strand thonglor (Adult swimming pool)									
Date	Shift / Time		Water Quality			Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
			Chlorine (ppm)	pH					
15	Morning	06:00	0.3	7.8	16				
	Afternoon	18:00	0.3	7.8	16				
16	Morning	06:00	0.3	7.4	16				
	Afternoon	18:00	0.3	7.8	16				
17	Morning	06:00	0.3	7.8	16				
	Afternoon	18:00	0.3	7.8	16				
18	Morning	06:00	0.3	7.8	16				
	Afternoon	18:00	0.3	7.8	16				
19	Morning	06:00	0.3	7.8	16				
	Afternoon	18:00	0.3	7.8	16				
20	Morning	06:00	0.3	7.8	16				
	Afternoon	18:00	0.3	7.8	16				
21	Morning	06:00	0.4	7.4	16				
	Afternoon	18:00	0.3	7.8	16				

Ref No: JLL-OP-SN-004/01

Rev. Date : 31/01/2015

Month : FEBRUARY Year : 2023

22/2 / 68

Comment : 21/2/68 SPARK 18:00
WTS OFF 18:00 WTS OFF 18:00

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND										
Ref No: JLL-OP-SN-004/01										
Rev. Date: 31/01/2015										
Month: FEBRUARY		Year: 2023								
BUILDING: The Strand thonglor		(Kid swimming pool)		167						
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark			
		Chlorine (ppm)	pH							
15	Morning	0.3	7.4	16						
	Afternoon	0.3	7.8	16						
16	Morning	0.3	7.8	16						
	Afternoon	0.3	7.8	16						
17	Morning	0.3	7.7	16						
	Afternoon	0.3	7.8	16						
18	Morning	0.3	7.8	16						
	Afternoon	0.3	7.4	16						
19	Morning	0.3	7.8	16						
	Afternoon	0.3	7.8	16						
20	Morning	0.3	7.8	16						
	Afternoon	0.3	7.8	16						
21	Morning	0.3	7.8	16						
	Afternoon	0.3	7.8	16						
Comment: 22/2/23										

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01 Rev. Date: 31/01/2015									
BUILDING :		The Strand thonglor		(Adult swimming pool)		Month : FEBRUARY		Year : 2023	
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
22	Morning	0.3	7.8	16	[Redacted]	[Redacted]	Back wash		
	Afternoon	0.3	7.8	16					
23	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
24	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
25	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
26	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
27	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
28	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
Comment : _____								1/3 / 60	

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date : 31/01/2015									
Month : FEBRUARY		Year : 2023							
BUILDING : The Strand thonglor		(Kid swimming pool)		150					
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
22	Morning	0.3	7.8	16	[Redacted]		Back wash		
	Afternoon	0.3	7.8	16					
23	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
24	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
25	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
26	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
27	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
28	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					

Comment : _____

9, 27 / 68

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor (Adult swimming pool)				Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015 Month : MARCH Year : 2023			
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
1	Morning	06:00	0.3	7.8	16	[Redacted]			
	Afternoon	18:00	0.3	7.8	16				
2	Morning	06:00	0.3	7.8	16				
	Afternoon	18:00	0.3	7.8	16				
3	Morning	06:00	0.3	7.8	16				
	Afternoon	18:00	0.3	7.8	16				
4	Morning	06:00	0.3	7.8	16				
	Afternoon	18:00	0.3	7.8	16				
5	Morning	06:00	0.3	7.8	16				
	Afternoon	18:00	0.3	7.8	16				
6	Morning	06:00	1.0	7.8	16				Back wash
	Afternoon	18:00	0.3	7.8	16				
7	Morning	06:00	0.5	7.8	16				
	Afternoon	18:00	0.3	7.8	16				
8	Morning	06:00	0.3	7.8	16				
	Afternoon	18:00	0.3	7.8	16				
Comment : _____ _____ _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND										Ref No: JLL-OP-SN-004/01
										Rev. Date : 31/01/2015
BUILDING :		The Strand thonglor		(Kid swimming pool)				Month : MARCH	Year : 2023	
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
			Chlorine (ppm)	pH						
1	Morning	06:00	0.3	7.8	16	[Redacted]				
	Afternoon	18:00	0.3	7.8	16					
2	Morning	06:00	0.3	7.8	16					
	Afternoon	18:00	0.3	7.8	16					
3	Morning	06:00	0.3	7.8	16					
	Afternoon	18:00	0.3	7.8	16					
4	Morning	06:00	0.3	7.8	16					
	Afternoon	18:00	0.3	7.8	16					
5	Morning	06:00	0.3	7.8	16					
	Afternoon	18:00	0.3	7.8	16					
6	Morning	06:00	0.3	7.8	16					
	Afternoon	18:00	0.3	7.8	16					
7	Morning	06:00	0.3	7.8	16					
	Afternoon	18:00	0.3	7.8	16					

Back Wash

1 / 4 / 66

Comment : _____

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date : 31/01/2015									
Month : MARCH		Year : 2023							
BUILDING : The Strand thonglor		(Adult swimming pool)							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
8	Morning	06:00	1.5	7.9	[Redacted]		Back wash		
	Afternoon	18:00	0.3	7.8					
9	Morning	06:00	0.3	7.8					
	Afternoon	18:00	0.3	7.9					
10	Morning	06:00	0.3	7.8					
	Afternoon	18:00	0.3	7.8					
11	Morning	06:00	0.3	7.8					
	Afternoon	18:00	0.3	7.8					
12	Morning	06:00	0.3	7.8					
	Afternoon	18:00	0.3	7.8					
13	Morning	06:00	0.3	7.8					
	Afternoon	18:00	0.3	7.8					
14	Morning	06:00	0.3	7.8					
	Afternoon	18:00	0.3	7.8					
Comment : _____ BSE : 9, 4 / 68									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm




LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date : 31/01/2015									
Month : MARCH		Year : 2023							
BUILDING : The Strand thonglor		(Kid swimming pool)		107					
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
8	Morning	3.0	7.8	16	[Redacted]	[Redacted]	Back Wash		
	Afternoon	0.3	7.8	16					
9	Morning	0.5	7.8	16					
	Afternoon	0.3	7.8	16					
10	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
11	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
12	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
13	Morning	1.0	7.8	16					
	Afternoon	1.0	7.8	16					
14	Morning	1.0	7.8	16					
	Afternoon	1.0	7.8	16					
Comment : 1/1 / bb									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor (Adult swimming pool) <i>Phong</i>				Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015 Month : MARCH Year : 2023			
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
15	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
16	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
17	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
18	Morning	0.3	7.8	16				Back wash	
	Afternoon	0.3	7.8	16					
19	Morning	0.3	7.8	16				Back wash	
	Afternoon	0.3	7.8	16					
20	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
21	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
Comment : _____ _____ _____									

1 / 4 / 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm










LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date : 31/01/2015									
Month : MARCH		Year : 2023							
BUILDING : The Strand thonglor		(Kid swimming pool) 6071							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
15	Morning	0.5	7.8	16	[Redacted]				
	Afternoon	1.0	7.8	16					
16	Morning	1.0	7.8	16					
	Afternoon	0.5	7.8	16					
17	Morning	0.5	8.8	16					
	Afternoon	0.5	7.8	16					
18	Morning	1.0	7.8	16					
	Afternoon	0.5	7.8	16					
19	Morning	0.5	7.8	16					
	Afternoon	0.5	7.8	16					
20	Morning	0.5	7.8	16					
	Afternoon	1.0	7.8	16					
21	Morning	1.0	7.8	16					
	Afternoon	1.0	7.8	16					
Comment :									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm




LOG SHEET OF SWIMMING POOL / POND																		
Ref No: JLL-OP-SN-004/01																		
Rev. Date: 31/01/2015																		
Month: MARCH		Year: 2023																
BUILDING: The Strand thonglor		(Adult swimming pool) <i>7022</i>																
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark											
		Chlorine (ppm)	pH															
<i>22</i>	Morning	<i>0.3</i>	<i>7.8</i>	<i>16</i>			<i>back wash</i>											
	Afternoon	<i>0.3</i>	<i>7.8</i>	<i>16</i>														
<i>23</i>	Morning	<i>0.3</i>	<i>7.8</i>	<i>16</i>					<i>back wash</i>									
	Afternoon	<i>0.3</i>	<i>7.8</i>	<i>16</i>														
<i>24</i>	Morning	<i>0.3</i>	<i>7.8</i>	<i>16</i>							<i>back wash</i>							
	Afternoon	<i>0.3</i>	<i>7.8</i>	<i>16</i>														
<i>25</i>	Morning	<i>0.5</i>	<i>7.8</i>	<i>16</i>									<i>back wash</i>					
	Afternoon	<i>0.3</i>	<i>7.8</i>	<i>16</i>														
<i>26</i>	Morning	<i>0.3</i>	<i>7.8</i>	<i>16</i>											<i>back wash</i>			
	Afternoon	<i>0.3</i>	<i>7.8</i>	<i>16</i>														
<i>27</i>	Morning	<i>0.3</i>	<i>7.8</i>	<i>16</i>														
	Afternoon	<i>0.3</i>	<i>7.8</i>	<i>16</i>														
<i>28</i>	Morning	<i>0.3</i>	<i>7.8</i>	<i>16</i>													<i>back wash</i>	
	Afternoon	<i>0.3</i>	<i>7.8</i>	<i>16</i>														
Comment: _____								BS										
_____								<i>1 / 4 / 66</i>										

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor				(Kid swimming pool)		Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015	
								Month : MARCH	Year : 2023
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
22	Morning	06.00	0.5	7.8	16				
	Afternoon	18.00	0.5	7.8	16				
23	Morning	06.00	0.5	7.8	16				
	Afternoon	18.00	0.5	7.8	16				
24	Morning	06.00	0.5	7.8	16				back wash
	Afternoon	18.00	0.5	7.8	16				
25	Morning	06.00	1.0	7.8	16				back wash
	Afternoon	18.00	1.0	7.8	16				
26	Morning	06.00	1.0	7.8	16				back wash
	Afternoon	18.00	0.5	7.8	16				
27	Morning	06.00	0.5	7.8	16				
	Afternoon	06.00	0.5	7.8	16				
28	Morning	06.00	0.5	7.8	16				back wash
	Afternoon	18.00	1.0	7.8	16				
Comment : _____ _____ _____									

1 / 4 / 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor				(Adult swimming pool) 1202			
Ref No:		JLL-OP-SN-004/01							
Rev. Date :		31/01/2015							
Month :		MARCH		Year :		2023			
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
29	Morning	0.3	7.8	1.6	[Redacted]		Back wash Rinse		
	Afternoon	0.3	7.8	1.6					
30	Morning	0.3	7.8	1.6					
	Afternoon	0.3	7.8	1.6					
31	Morning	0.3	7.8	1.6					
	Afternoon	0.3	7.8	1.6					
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
Comment : _____ _____ _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date : 31/01/2015									
Month : MARCH		Year : 2023							
BUILDING : The Strand thonglor		(Kid swimming pool) 6077							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
29	Morning	0.5	7.8	16	[Redacted]				
	Afternoon	1.0	7.8	16					
30	Morning	0.5	7.8	16					
	Afternoon	0.5	7.8	16					
31	Morning	1.0	7.8	16					
	Afternoon	0.5	7.8	16					
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
Comment : _____ _____ _____									

BS
1/4 / 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND										Ref No: JLL-OP-SN-004/01
										Rev. Date: 31/01/2015
BUILDING :		The Strand thonglor		(Adult swimming pool)		Month : APRIL		Year : 2023		
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark			
		Chlorine (ppm)	pH							
1	Morning	0600	0.3	7.8	[Redacted]		Back wash Rinse			
	Afternoon	1800	0.3	7.8						
2	Morning	0600	0.3	7.8			1.6			
	Afternoon	1800	0.3	7.8						
3	Morning	0600	0.3	7.8			1.6			
	Afternoon	1700	0.3	7.8						
4	Morning	0600	0.3	7.8			1.6	Back wash Rinse		
	Afternoon	1700	0.3	7.8						
5	Morning	0600	0.3	7.8			1.6	Back wash Rinse		
	Afternoon	1700	0.3	7.8						
6	Morning	0600	0.3	7.8			1.6	Back wash Rinse		
	Afternoon	1700	0.3	7.8						
7	Morning	0600	1.0	7.8			1.6			
	Afternoon	1700	1.0	7.8						
Comment : _____ BSE : 7 / 4 / 66										

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND										Ref No: JLL-OP-SN-004/01
										Rev. Date : 31/01/2015
BUILDING :		The Strand thonglor		(Kid swimming pool)		Month : APRIL		Year : 2023		
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark			
		Chlorine (ppm)	pH							
1	Morning	06.00	1.0	7.8	[Redacted]		Back wisk 21.00			
	Afternoon	18.00	1.0	7.8						
2	Morning	06.00	1.0	7.8						
	Afternoon	18.00	1.0	7.8						
3	Morning	06.00	1.0	7.8						
	Afternoon	18.00	1.0	7.8						
4	Morning	06.00	1.0	7.8						
	Afternoon	17.00	1.0	7.8						
5	Morning	06.00	1.0	7.8						
	Afternoon	17.00	1.0	7.8						
6	Morning	06.00	1.0	7.8						
	Afternoon	18.00	1.0	7.8						
7	Morning	06.00	1.5	7.8						
	Afternoon	17.00	1.0	7.8						
Comment :								7 / 4 / 66		

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		(Kid swimming pool)		Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015 Month : APRIL Year : 2023			
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
8	Morning	06.00	1.5	7.8	[Redacted]				
	Afternoon	17.00	1.5	7.8					
9	Morning	06.00	1.5	7.8				Back wash	
	Afternoon	18.00	1.5	7.8					
10	Morning	06.00	1.5	7.8					Back wash
	Afternoon	18.00	1.5	7.8					
11	Morning	06.00	1.5	7.8					Back wash
	Afternoon	17.00	1.0	7.8					
12	Morning	06.00	1.0	7.8					
	Afternoon	17.00	1.0	7.8					
13	Morning	06.00	1.0	7.8					
	Afternoon	17.00	1.0	7.8					
14	Morning	06.00	1.0	7.8				back wash	
	Afternoon	18.00	1.0	7.8					
Comment : _____ _____ _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: APRIL		Year: 2023							
BUILDING: The Strand thonglor (Adult swimming pool)		24/04/23							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
8	Morning	06.00	1.6	7.8	[Redacted]				
	Afternoon	17.00	1.0	7.8					
9	Morning	06.00	1.0	7.8					
	Afternoon	18.00	1.0	7.8					
10	Morning	06.00	1.0	7.8					
	Afternoon	18.00	0.5	7.8					
11	Morning	06.00	0.5	7.4					
	Afternoon	17.00	0.5	7.8					
12	Morning	06.09	0.3	7.8					
	Afternoon	17.00	0.3	7.8					
13	Morning	06.09	0.3	7.8					
	Afternoon	17.00	0.3	7.8					
14	Morning	06.00	0.5	7.4					
	Afternoon	17.00	0.5	7.8					
Comment: _____ _____ _____									

14/4/23

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND																														
Ref No: JLL-OP-SN-004/01																														
Rev. Date: 31/01/2015																														
Month: APRIL		Year: 2023																												
BUILDING: The Strand thonglor		(Kid swimming pool)																												
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark																							
		Chlorine (ppm)	pH																											
15	Morning	06.00	1.0	7.8	[Redacted]		Black Wash																							
	Afternoon	17.00	1.0	7.8																										
16	Morning	06.00	1.0	7.8				[Redacted]		Black Wash																				
	Afternoon	17.00	1.0	7.8																										
17	Morning	06.00	1.5	7.8							[Redacted]		Back wash																	
	Afternoon	17.00	1.0	7.8																										
18	Morning	06.00	1.0	7.8										[Redacted]		Black Wash														
	Afternoon	17.00	1.0	7.8																										
19	Morning	06.00	1.0	7.8													[Redacted]		Black Wash											
	Afternoon	17.00	1.0	7.8																										
20	Morning	06.00	1.5	7.8																[Redacted]		Black Wash								
	Afternoon	17.00	1.5	7.8																										
21	Morning	06.00	1.5	7.8																			[Redacted]		Black Wash					
	Afternoon	17.00	1.5	7.8																										
Comment: _____ _____ _____																														

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: APRIL		Year: 2023							
BUILDING: The Strand thonglor (Adult swimming pool)		9002							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
15	Morning	0.5	7.4	16	[Redacted]		Black Wash		
	Afternoon	0.5	7.4	16					
16	Morning	0.5	7.4	16			Black Wash		
	Afternoon	0.5	7.4	16					
17	Morning	1.0	7.8	16					
	Afternoon	1.0	7.4	16					
18	Morning	0.3	7.8	16			Back wash		
	Afternoon	0.5	7.4	16					
19	Morning	0.3	7.8	16					
	Afternoon	0.5	7.4	16					
20	Morning	0.5	7.4	16			Black Wash		
	Afternoon	0.5	7.4	16					
21	Morning	0.5	7.4	16					
	Afternoon	0.5	7.4	16					
Comment: _____									
By: 21, 4 / 66									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: APRIL		Year: 2023							
BUILDING: The Strand thonglor (Adult swimming pool)		190							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
22	Morning	1.5	7.4	16	[Redacted]		Back was K-Rage		
	Afternoon	1.5	7.8	16					
23	Morning	1.5	7.8	16					
	Afternoon	1.5	7.8	16					
24	Morning	1.5	7.8	16					
	Afternoon	1.5	7.8	16					
25	Morning	1.5	7.8	16					
	Afternoon	1.5	7.8	16					
26	Morning	1.5	7.8	16					
	Afternoon	1.5	7.8	16					
27	Morning	1.5	7.8	16					
	Afternoon	1.5	7.8	16					
28	Morning	1.5	7.8	16					
	Afternoon	1.5	7.8	16					
Comment:								28 / 4 / 66	

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND										
BUILDING :		The Strand thonglor				(Kid swimming pool)		Ref No: JLL-OP-SN-004/01 Rev. Date: 31/01/2015		
								Month : APRIL	Year : 2023	
Date	Shift / Time		Water Quality			Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH						
22	Morning	06:00	0.5	7.4		16	[Redacted]			
	Afternoon	18:00	0.5	7.8		16				
23	Morning	06:00	0.5	7.4		16				
	Afternoon	18:00	0.5	7.8		16				
24	Morning	06:00	0.5	7.4		16			BLACK WASH FENCE	
	Afternoon	18:00	0.5	7.8		16			POISONOUS	
25	Morning	06:00	0.5	7.4		16				
	Afternoon	18:00	0.5	7.8		16				
26	Morning	06:00	0.5	7.4		16				
	Afternoon	18:00	0.5	7.8		16				
27	Morning	06:00	0.5	7.4		16				
	Afternoon	18:00	0.5	7.8		16				
28	Morning	06:00	0.5	7.4		16				
	Afternoon	18:00	0.5	7.8		16				
Comment : _____ _____ _____										

28 / 4 / 2023

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: APRIL		Year: 2023							
BUILDING: The Strand thonglor (Adult swimming pool)									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
29	Morning	0.9	7.8	16	[Redacted]				
	Afternoon	0.5	7.9	16					
30	Morning	0.1	7.9	16					
	Afternoon	0.2	7.9	16					
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								

Comment: _____

1 / 5 / 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							
BUILDING :		The Strand thonglor (Kid swimming pool)				Ref No: JLL-OP-SN-004/01 Rev. Date: 31/01/2015 Month: APRIL Year: 2023	
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
29	Morning	0.8	7.8	16	[Redacted]	[Redacted]	
	Afternoon	1.0	7.8	16			
30	Morning	1.0	7.8	16			
	Afternoon	0.5	7.8	16			
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						

Comment : _____

1, 5, 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND										Ref No: JLL-OP-SN-004/01
										Rev. Date: 31/01/2015
BUILDING: The Strand thonglor (Kid swimming pool)										Month: MAY Year: 2023
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark			
		Chlorine (ppm)	pH							
1	Morning	06.00	0.1	7.6	[Redacted]		BACK WASH			
	Afternoon	17.00	0.1	7.8						
2	Morning	06.00	0.1	7.8						
	Afternoon	17.00	0.1	7.4						
3	Morning	06.00	0.1	7.8						
	Afternoon	17.00	0.1	7.6						
4	Morning	06.00	0.1	7.8						
	Afternoon	17.00	0.1	7.6						
5	Morning	06.00	0.1	7.8						
	Afternoon	17.00	0.1	7.8						
6	Morning	06.00	0.1	7.8						
	Afternoon	17.00	0.1	7.8						
7	Morning	06.00	0.3	7.8						
	Afternoon	17.00	0.3	7.8						
Comment: _____ _____ _____										

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		(Kid swimming pool)		Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015 Month : MAY Year : 2023			
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
1	Morning	0.3	7.8	16	[Redacted]				
	Afternoon	0.3	7.8	16					
2	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
3	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
4	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
5	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
6	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
7	Morning	0.3	7.8	16					
	Afternoon	0.3	7.8	16					
Comment : _____ BOB : 1 / 6 / 66									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND										Ref No: JLL-OP-SN-007/01	
										Rev. Date: 31/01/2015	
BUILDING : The Strand thonglor (Kid swimming pool)										Month : MAY Year : 2023	
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark			
			Chlorine (ppm)	pH							
8	Morning	06.00	0.5	7.8	16	[Redacted]		Back wash			
	Afternoon	17.00	0.9	7.5	16						
9	Morning	06.00	0.3	7.8	16						
	Afternoon	17.00	0.3	7.5	16						
10	Morning	06.00	0.3	7.8	16						
	Afternoon	17.00	0.3	7.8	16						
11	Morning	06.00	1.0	7.8	16						
	Afternoon	17.00	0.3	7.5	16						
12	Morning	06.00	0.3	7.8	16						
	Afternoon	17.00	0.3	7.5	16						
13	Morning	06.00	0.3	7.8	16						
	Afternoon	17.00	0.3	7.4	16						
14	Morning	06.00	0.3	7.8	16						
	Afternoon	17.00	0.3	7.4	16						
Comment: _____ _____ _____											

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		(Kid swimming pool)		Ref No: JLL-OP-SN-004/01 Rev. Date: 31/01/2015 Month: MAY Year: 2023			
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
8	Morning	06.00	7.0	7.8	[Redacted Signature]		Back wash		
	Afternoon	17.00	1.7	7.5					
9	Morning	06.00	0.3	7.8					
	Afternoon	17.00	0.3	7.5					
10	Morning	06.00	0.5	7.8					
	Afternoon	17.00	0.5	7.5					
11	Morning	06.00	1.5	7.8					
	Afternoon	17.00	0.5	7.5					
12	Morning	06.00	0.5	7.8					
	Afternoon	17.00	0.5	7.5					
13	Morning	06.00	0.5	7.8					
	Afternoon	17.00	0.5	7.5					
14	Morning	06.00	0.5	7.8					
	Afternoon	17.00	0.5	7.5					
Comment: _____ BSE: 1 / 6 / 66									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JIL-OP-SN-004/01 Rev. Date: 31/01/2016									
BUILDING :		The Strand thonglor (Kid swimming pool)				Month : MAY Year : 2023			
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
15	Morning	06.00	0.5	7.8	[Redacted]		Back Wash		
	Afternoon	17.00	0.3	7.8					
16	Morning	06.00	0.1	7.8					
	Afternoon	17.00	0.0	7.8					
17	Morning	06.00	0.5	7.4					
	Afternoon	17.00	0.3	7.8					
18	Morning	06.00	0.3	7.4					
	Afternoon	17.00	0.3	7.8					
19	Morning	06.00	0.3	7.8					
	Afternoon	17.00	0.3	7.8					
20	Morning	06.00	0.3	7.4					
	Afternoon	17.00	0.3	7.8					
21	Morning	06.00	0.3	7.8					
	Afternoon	17.00	0.1	7.8					
Comment : _____ _____ _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		(Kid swimming pool)		Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015 Month : MAY Year : 2023			
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
15	Morning	06.00	0.0	7.8	16	[Redacted]		Back wash	
	Afternoon	17.00	1.0	7.8	16				
16	Morning	06.00	0.3	7.8	16				
	Afternoon	17.00	0.1	7.8	16				
17	Morning	06.00	0.3	7.4	16				
	Afternoon	17.00	1.0	7.8	16				
18	Morning	06.00	1.5	7.4	16				
	Afternoon	17.00	1.0	7.8	16				
19	Morning	06.00	0.5	7.4	16				
	Afternoon	17.00	1.0	7.8	16				
20	Morning	06.00	1.5	7.8	16				
	Afternoon	17.00	1.0	7.8	16				
21	Morning	06.00	0.5	7.8	16				
	Afternoon	17.00	1.0	7.8	16				
Comment : _____ _____ _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



212

LOG SHEET OF SWIMMING POOL / POND									
Ref No: JIL-OP-SN-004/01 Rev. Date: 31/01/2015									
BUILDING :		The Strand thonglor				(Kid swimming pool)		Month : MAY Year : 2023	
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
22	Morning	06.00	0.3	7.4	16	[Redacted]			
	Afternoon	17.00	0.3	7.8	16				
23	Morning	06.00	0.3	7.4	16				
	Afternoon	17.00	0.3	7.8	16				
24	Morning	06.00	0.5	7.4	16				
	Afternoon	17.00	0.3	7.8	16				
25	Morning	06.00	0.3	7.8	16				Back wash
	Afternoon	17.00	0.3	7.8	16				
26	Morning	06.00	0.3	7.8	16				
	Afternoon	17.00	0.3	7.8	16				
27	Morning	06.00	0.3	7.8	16				
	Afternoon	17.00	0.3	7.8	16				
28	Morning	06.00	0.1	7.8	16				
	Afternoon	17.00	0.3	7.8	16				
Comment : _____ _____ _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							Ref No: JLL-OP-SN-004/01			
							Rev. Date: 31/01/2015			
BUILDING :		The Strand thonglor		(Kid swimming pool)		Month : MAY	Year : 2023			
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Remark					
		Chlorine (ppm)	pH							
22	Morning	06.00	1.0	7.4	[Redacted]					
	Afternoon	17.00	1.0	7.7						
23	Morning	06.00	1.0	7.8						
	Afternoon	17.00	1.0	7.5						
24	Morning	06.00	0.5	7.8						
	Afternoon	17.00	1.0	7.5						
25	Morning	06.00	1.0	7.8				Back wash		
	Afternoon	17.00	1.0	7.8						
26	Morning	06.00	1.0	7.5						
	Afternoon	17.00	1.0	7.5						
27	Morning	06.00	0.5	7.8						
	Afternoon	17.00	1.0	7.5						
28	Morning	06.00	0.1	7.8						
	Afternoon	17.00	1.0	7.5						
Comment : _____ _____ _____							BSE : _____ 1 / 6 / 66			

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01

Rev. Date: 31/01/2015

Month: MAY Year: 2023

BUILDING: The Strand thonglor

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
29	Morning	0.3	7.8	16	[Redacted]	[Redacted]	Back wash
	Afternoon	0.3	7.8	16			
30	Morning	0.1	7.8	16			
	Afternoon	0.3	7.8	16			
31	Morning	0.1	7.8	16			
	Afternoon	0.1	7.8	16			
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						

Comment:

BSL: 1.6, 60

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01								
Rev. Date: 31/01/2015								
Month: MAY Year: 2018								
BUILDING : The Strand thonglor 157	Date	Shift / Time	Water Quality		Filter Pressure (nsi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
			Chlorine (ppm)	pH				
29	Morning	06:00	0.5	7.8	[REDACTED]	[REDACTED]	[REDACTED]	Back Wash.
	Afternoon	17:00	0.1	7.8				
30	Morning	06:00	0.1	7.8				
	Afternoon	17:00	0.1	7.8				
31	Morning	06:00	0.1	7.8				
	Afternoon	17:00	0.1	7.8				
	Morning							
	Afternoon							
	Morning							
	Afternoon							
	Morning							
	Afternoon							
	Morning							
	Afternoon							

BSE : 1, 6, 66

Comment:

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor				(Kid swimming pool)			
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
1	Morning	06:00	0.5	7.8	16	[Redacted]			
	Afternoon	17:00	0.3	7.8	16				
2	Morning	06:00	0.5	7.8	16				
	Afternoon	17:00	0.3	7.5	16				
3	Morning	06:00	0.5	7.5	16				
	Afternoon	17:00	0.3	7.5	16				
4	Morning	06:00	0.6	7.8	16				
	Afternoon	17:00	0.3	7.5	16				
5	Morning	06:00	0.3	7.8	16				
	Afternoon	17:00	0.3	7.5	16				
6	Morning	06:00	0.3	7.8	16				
	Afternoon	17:00	0.3	7.5	16				
7	Morning	06:00	0.6	7.8	16				
	Afternoon	17:00	0.3	7.5	16				
Comment : _____ BSE : _____ / 17 / 66									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		(Kid swimming pool)		Ref No: JLL-OP-SN-004/01		Rev. Date : 31/01/2015	
		Month : JUNE		Year : 2023					
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
1	Morning	1.0	7.8	16	[Redacted]				
	Afternoon	1.0	7.8	16					
2	Morning	1.0	7.8	16					
	Afternoon	1.0	7.8	16					
3	Morning	1.0	7.8	16					
	Afternoon	1.0	7.8	16					
4	Morning	1.0	7.8	16					
	Afternoon	1.0	7.8	16					
5	Morning	1.0	7.8	16					
	Afternoon	1.0	7.8	16					
6	Morning	0.5	7.8	16					
	Afternoon	1.0	7.8	16					
7	Morning	1.0	7.8	16					
	Afternoon	1.0	7.8	16					
Comment : _____ _____ _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01 Rev. Date: 31/01/2015									
BUILDING : The Strand thonglor (Kid swimming pool)									
Month : JUNE Year : 2023									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
8	Morning	06:00	0.3	7.8	[Redacted]	[Redacted]	[Redacted]		
	Afternoon	17:00	0.3	7.8					
9	Morning	06:00	0.3	7.8					
	Afternoon	17:00	0.3	7.8					
10	Morning	06:00	1.5	7.4					
	Afternoon	17:00	0.3	7.8					
11	Morning	06:00	1.5	7.4					
	Afternoon	17:00	0.3	7.8					
12	Morning	06:00	1.5	7.8					
	Afternoon	17:00	0.5	7.8					
13	Morning	06:00	0.5	7.8					
	Afternoon	17:00	0.5	7.8					
14	Morning	06:00	0.5	7.8					
	Afternoon	17:00	0.5	7.8					
Comment : _____									

7, 7 / 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		(Kid swimming pool)		Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015 Month : JUNE Year : 2023			
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Remark			
			Chlorine (ppm)	pH					
8	Morning	06:00	0.5	7.8	16				
	Afternoon	17:00	0.5	7.8	16				
9	Morning	06:00	0.5	7.8	16				
	Afternoon	17:00	0.5	7.8	16				
10	Morning	06:00	1.5	7.8	16				
	Afternoon	17:00	1.0	7.8	16				
11	Morning	06:00	1.5	7.8	16				
	Afternoon	17:00	1.0	7.8	16				
12	Morning	06:00	1.5	7.8	16				
	Afternoon	17:00	1.0	7.8	16				
13	Morning	06:00	1.0	7.8	16				
	Afternoon	17:00	1.0	7.8	16				
14	Morning	06:00	1.0	7.8	16				
	Afternoon	17:00	1.0	7.8	16				
Comment : _____ BSE : _____ 9, 7, 66									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: JUN Year: 2023									
BUILDING: The Strand thonglor (Adult swimming pool)		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
Date	Shift / Time	Chlorine (ppm)	pH						
16	Morning	1.5	7.5	16	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]
	Afternoon	0.5	7.5	16					
16	Morning	1.5	7.5	16					
	Afternoon	0.5	7.5	16					
17	Morning	1.0	7.5	16					
	Afternoon	0.5	7.5	16					
18	Morning	1.0	7.8	16					
	Afternoon	0.5	7.8	16					
19	Morning	1.0	7.8	16					
	Afternoon	0.5	7.8	16					
20	Morning	0.5	7.8	16					
	Afternoon	0.5	7.8	16					
21	Morning	1.0	7.8	16					
	Afternoon	0.5	7.8	16					
Comment: _____ _____ _____									

7, 7, 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND											
Ref No: JLL-OP-SN-004/01											
Rev. Date : 31/01/2015											
Month : JUNE		Year : 2023									
BUILDING : The Strand thonglor		(Adult swimming pool)									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark				
		Chlorine (ppm)	pH								
16	Morning	1.5	7.5	16	[Redacted]						
	Afternoon	1	7.8	16							
16	Morning	1.5	7.5	16							
	Afternoon	1	7.9	16							
17	Morning	1.5	7.5	16							
	Afternoon	1	7.8	16							
18	Morning	1.5	7.8	16							
	Afternoon	1	7.8	16							
19	Morning	1.5	7.8	16							
	Afternoon	1	7.8	16							
20	Morning	1.0	7.8	16							
	Afternoon	1.0	7.8	16							
21	Morning	1.0	7.8	16							
	Afternoon	1.0	7.8	16							
Comment :								1, 2, 66			

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: JUNE		Year: 2023							
BUILDING: The Strand thonglor		(Adult swimming pool)		Recorded By (Technician)		Verified By (Sr. Technician)		Remark	
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Chlorine (ppm)	pH	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH						
22	Morning	06.00	1.0	7.8	16				
	Afternoon	17.00	1.5	7.8	16				
23	Morning	06.00	1.5	7.8	16				
	Afternoon	17.00	1.0	7.8	16				
24	Morning	06.00	1.5	7.8	16				
	Afternoon	17.00	1.0	7.8	16				
25	Morning	06.00	1.5	7.8	16				
	Afternoon	17.00	1.0	7.8	16				
26	Morning	06.00	1.5	7.8	16				
	Afternoon	17.00	0.3	7.8	16				
27	Morning	06.00	1.5	7.8	16				
	Afternoon	17.00	0.3	7.8	16				
28	Morning	06.00	0.5	7.8	16				
	Afternoon	17.00	0.3	7.8	16				
Comment: _____ _____ _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: JUNE		Year: 2023							
BUILDING: The Strand thonglor		(Adult swimming pool)		1st		Recorded By (Technician)		Verified By (Sr. Technician)	
Date		Shift / Time		Water Quality		Filter Pressure (psi)		Remark	
				Chlorine (ppm)	pH				
22	Morning	06:00	1.5	7.8	16				
	Afternoon	17:00	1.5	7.8	16				
23	Morning	06:00	1.5	7.8	16				
	Afternoon	17:00	1.5	7.8	16				
24	Morning	06:00	1.5	7.8	16				
	Afternoon	17:00	1.5	7.8	16				
25	Morning	06:00	1.5	7.8	16				
	Afternoon	17:00	1.5	7.8	16				
26	Morning	06:00	1.5	7.8	16				
	Afternoon	17:00	1.5	7.8	16				
27	Morning	06:00	1.5	7.8	16				
	Afternoon	17:00	1.5	7.8	16				
28	Morning	06:00	1.5	7.8	16				
	Afternoon	17:00	1.5	7.8	16				
Comment: _____ _____ _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND										Ref No: JLL-OP-SN-004/01
										Rev. Date: 31/01/2015
BUILDING :		The Strand thonglor		(Adult swimming pool)			Month : JUNE		Year : 2023	
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark			
		Chlorine (ppm)	pH							
29	Morning	1.5	7.8	16	[Redacted]	[Redacted]	[Redacted]			
	Afternoon	0.5	7.8	16						
30	Morning	1.5	7.8	16				[Redacted]	[Redacted]	[Redacted]
	Afternoon	7.5	7.8	16						
	Morning				[Redacted]	[Redacted]	[Redacted]			
	Afternoon									
	Morning									
	Afternoon									
	Morning				[Redacted]	[Redacted]	[Redacted]			
	Afternoon									
	Morning									
	Afternoon									
	Morning				[Redacted]	[Redacted]	[Redacted]			
	Afternoon									
	Morning									
	Afternoon									
Comment :								BSE : 7, 7, 66		

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		(Adult swimming pool)		Ref No: JLL-OP-SN-004/01		Rev. Date : 31/01/2015	
						Month : JUNE		Year : 2023	
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
29	Morning	1.5	7.4	16	[Redacted]	[Redacted]			
	Afternoon	1.5	7.2	16					
30	Morning	1.5	7.8	16	[Redacted]	[Redacted]			
	Afternoon	1.5	7.8	16					
	Morning				[Redacted]	[Redacted]			
	Afternoon								
	Morning				[Redacted]	[Redacted]			
	Afternoon								
	Morning				[Redacted]	[Redacted]			
	Afternoon								
	Morning				[Redacted]	[Redacted]			
	Afternoon								
	Morning				[Redacted]	[Redacted]			
	Afternoon								
	Morning				[Redacted]	[Redacted]			
	Afternoon								
Comment : _____ BSE : _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm

