

เอกสารแนบ 8

ผลการวิเคราะห์คลอรีนอิสระในน้ำประปา



Analysis Report

Customer Name : บริษัท เค.จี.คอร์ปอเรชั่น จำกัด
Address : เลขที่ 6 ซอยเรวัติ 7 ต.ตลาดขวัญ
อ.เมืองนนทบุรี จ.นนทบุรี 11000
Tel : 089-992-7667

Fax: -

Page 1 of 1

Report No: 230426024

Sampling Source : โรงพยาบาล สันแพทย์เสรีรักษ์

:

Sampling Date : 22-Apr-23

Sampling Method : Grab

Received Date : 26-Apr-23

Sampling By : Customer

Testing Date : Apr 26 - May 2, 2023

Approved Date : 10-May-23

Item	Unit	Method of Analysis	Result
Sample Name			Raw Water(น้ำดิบ)
Sample Type			Raw water
Analysis No.			230426024
Sampling Time			12:40 PM
Physical Appearance			Clear
pH at 25 deg C	-	APHA:4500-H(B)	6.1
#Conductivity	micro S/cm	APHA:2510 B	298
#TDS	mg/L	APHA:2540 C	184
#Alkalinity, Total	mg/L CaCO ₃	Calculate	86
#Total Hardness	mg/L CaCO ₃	APHA:2340 C	<2
#Calcium-H	mg/L CaCO ₃	APHA:3500-Ca(B)	<2
#Chloride	mg/L Cl	APHA:4500-Cl(B)	26

Remark : APHA : Standard Method for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd Edition 2017

: " Test marked # in this report are not included in the TISI Accreditation Schedule for our Laboratory "

Sampling By Customer : "Reported results refer to samples received from customer only"

Environment & Laboratory Co.,Ltd.

Lab