

# ผลวิเคราะห์คุณภาพน้ำทิ้ง โครงการ โรงแรม แคนทารี บ้านฉาง



**United Analyst and Engineering Consultant Co., Ltd.**

3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260

Tel. 0 2763 2828 Fax 0 2763 2800 www.uaec consultant.com E-mail: uae@uaec consultant.com



NSC-TISI-TIS 17025  
TESTING 0207




TESTING  
No. 0063

## ANALYSIS REPORT

**CUSTOMER NAME** : KASEMKIJ COMPANY LIMITED (KANTARY BANCHANG HOTEL)  
**ADDRESS** : 91, 91/1 MOO 3 PHLA BANCHANG RAYONG 21130  
**CONTACT INFORMATION** : TEL : 0 2233 8989-98 e-mail : kj-qc@kasemkij.com  
**SAMPLING SOURCE** : KANTARY HOTEL BANCHANG  
**SAMPLE TYPE** : EFFLUENT  
**SAMPLING DATE** : JULY 5, 2023  
**SAMPLING TIME** : -  
**SAMPLING METHOD** : -  
**SAMPLING BY** : CUSTOMER  
**ANALYZED BY** : MISS NAPAPORN KHUNNOKKHUM

**RECEIVED DATE** : JULY 6, 2023  
**ANALYTICAL DATE** : JULY 6-14, 2023  
**REPORT NO.** : 2023-U062882  
**WORK NO.** : 2023-004990  
**ANALYSIS NO.** : T23AM948-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			EFFLUENT T23AM948-0001		
pH <sup>a</sup>	-	ELECTROMETRIC METHOD (SM: PART 4500-H <sup>+</sup> B)	7.4 (25°C)	5-9	-
BIOCHEMICAL OXYGEN DEMAND <sup>c</sup>	mg/L	AZIDE MODIFICATION METHOD (SM: PART 5210 B AND PART 4500-O C)	3.2	≤ 30	2.0
SUSPENDED SOLIDS <sup>a</sup>	mg/L	SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: PART 2540 D)	8.9	≤ 40	5.0
TOTAL DISSOLVED SOLIDS <sup>a b</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAO.007 (TOTAL DISSOLVED SOLIDS DRIED AT 103-105 °C); SM: PART 2540 C	216	500*	25
SETTLABLE SOLIDS <sup>c</sup>	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	≤ 0.5	0.1
SULPHIDE <sup>b</sup>	mg/L	IODOMETRIC METHOD (SM: PART 4500-S <sup>2-</sup> F)	< 0.50	≤ 1.0	0.50
TOTAL KJELDAHL NITROGEN <sup>b</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	11.2	≤ 35	1.5
FAT, OIL AND GREASE <sup>c</sup>	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	ND	≤ 20	3



- PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
- THIS ANALYSIS REPORT APPROVES ONLY FOR SUBMITTED SAMPLES.

1/2



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			EFFLUENT T23AM948-0001		
MICROBIOLOGY					
COLIFORM BACTERIA <sup>b</sup>	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221B)	< 18	-	18
SAMPLE CONDITION					
WATER'S COLOUR/TURBID			YELLOW/CLEAR		
SEDIMENT			BROWN		

<sup>a</sup> : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

<sup>b</sup> : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

<sup>c</sup> : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

IN-HOUSE : BASED ON STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE  
MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 122,  
PART 125 D, DATED DECEMBER 29, 2005.

500\* : PERMITTED EXCESS VALUE TO TOTAL DISSOLVED SOLIDS OF ACTUAL TAP WATER USED.

ND : NON-DETECTABLE.

<sup>A</sup> : SAMPLING ON JULY 20, 2023, ANALYSIS NO. T23AO093-0001 (ANALYTICAL DATE : JULY 21-26, 2023).

THE REASON FOR ISSUING THE NEW REPORT IS SUBSTITUTE RESULT.

SUBSTITUTED REPORT FOR REPORT NO. 2023-U058238, DATED JULY 17, 2023.

*Piyapat S.*

(MRS PIYAPAT SUTTAMANUTWONG)  
LABORATORY SUPERVISOR

AUGUST 3, 2023

ISO 9001:2015 CERTIFIED  
ISO 14001:2015 CERTIFIED  
BY BSI GROUP (THAILAND) CO., LTD.

• PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.  
• THIS ANALYSIS REPORT APPROVES ONLY FOR SUBMITTED SAMPLES.

2/2

2023-U062882

- End of Analysis Report -

## ANALYSIS REPORT

**CUSTOMER NAME** : KASEMKIJ COMPANY LIMITED (KANTARY BANCHANG HOTEL)  
**ADDRESS** : 91, 91/1 MOO 3 PHLA BANCHANG RAYONG 21130  
**CONTACT INFORMATION** : TEL : 0 2233 8989-98 e-mail : kj-qc@kasemkij.com  
**SAMPLING SOURCE** : KANTARY HOTEL BANCHANG  
**SAMPLE TYPE** : EFFLUENT  
**SAMPLING DATE** : AUGUST 2, 2023  
**SAMPLING TIME** : -  
**SAMPLING METHOD** : -  
**SAMPLING BY** : CUSTOMER  
**ANALYZED BY** : MISS NAPAPORN KHUNNOKKHUM

**RECEIVED DATE** : AUGUST 3, 2023  
**ANALYTICAL DATE** : AUGUST 3-10, 2023  
**REPORT NO.** : 2023-U066122  
**WORK NO.** : 2023-005624  
**ANALYSIS NO.** : T23AO824-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			EFFLUENT T23AO824-0001		
pH <sup>a</sup>	-	ELECTROMETRIC METHOD (SM: PART 4500-H <sup>+</sup> B)	6.6 (25°C)	5-9	-
BIOCHEMICAL OXYGEN DEMAND <sup>c</sup>	mg/L	AZIDE MODIFICATION METHOD (SM: PART 5210 B AND PART 4500-O C)	ND	≤ 30	2.0
SUSPENDED SOLIDS <sup>a</sup>	mg/L	SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: PART 2540 D)	5.1	≤ 40	5.0
TOTAL DISSOLVED SOLIDS <sup>b</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAO.007 (TOTAL DISSOLVED SOLIDS DRIED AT 103-105 °C); SM: PART 2540 C	404	500*	25
SETTLEABLE SOLIDS <sup>c</sup>	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	≤ 0.5	0.1
SULPHIDE <sup>b</sup>	mg/L	IODOMETRIC METHOD (SM: PART 4500 -S <sup>2-</sup> F)	< 0.50	≤ 1.0	0.50
TOTAL KJELDAHL NITROGEN <sup>b</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	22.0	≤ 35	1.5
FAT, OIL AND GREASE <sup>c</sup>	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	ND	≤ 20	3



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			EFFLUENT T23A0824-0001		
MICROBIOLOGY					
COLIFORM BACTERIA <sup>b</sup>	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221B)	23	-	1.8
SAMPLE CONDITION					
WATER'S COLOUR/TURBID			YELLOW/CLEAR		
SEDIMENT			BROWN		

<sup>a</sup> : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

<sup>b</sup> : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

<sup>c</sup> : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

IN-HOUSE : BASED ON STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE  
MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 122,  
PART 125 D, DATED DECEMBER 29, 2005.


500\* : PERMITTED EXCESS VALUE TO TOTAL DISSOLVED SOLIDS OF ACTUAL TAP WATER USED.

ND : NON-DETECTABLE.

*Piyapat S.*

(MRS PIYAPAT SUTTAMANUTWONG)  
LABORATORY SUPERVISOR

AUGUST 11, 2023



- PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
- THIS ANALYSIS REPORT APPROVES ONLY FOR SUBMITTED SAMPLES.

2/2

2023-U066122

- End of Analysis Report -



## ANALYSIS REPORT

**CUSTOMER NAME** : KASEMKIJ COMPANY LIMITED (KANTARY BANCHANG HOTEL)  
**ADDRESS** : 91, 91/1 MOO 3 PHLA BANCHANG RAYONG 21130  
**CONTACT INFORMATION** : TEL : 0 2233 8989-98 e-mail : kj-qc@kasemkij.com  
**SAMPLING SOURCE** : KANTARY HOTEL BANCHANG  
**SAMPLE TYPE** : EFFLUENT  
**SAMPLING DATE** : SEPTEMBER 6, 2023  
**SAMPLING TIME** : -  
**SAMPLING METHOD** : -  
**SAMPLING BY** : CUSTOMER  
**ANALYZED BY** : MISS NAPAPORN KHUNNOKKHUM

**RECEIVED DATE** : SEPTEMBER 7, 2023  
**ANALYTICAL DATE** : SEPTEMBER 7-14, 2023  
**REPORT NO.** : 2023-U077672  
**WORK NO.** : 2023-006534  
**ANALYSIS NO.** : T23AR592-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			EFFLUENT T23AR592-0001		
pH <sup>^ c</sup>	-	ELECTROMETRIC METHOD AT SITE (SM: PART 4500-H <sup>+</sup> B)	5.0 (25°C)	5-9	-
BIOCHEMICAL OXYGEN DEMAND <sup>c</sup>	mg/L	AZIDE MODIFICATION METHOD (SM: PART 5210 B AND PART 4500-O C)	ND	≤ 30	2.0
SUSPENDED SOLIDS <sup>a</sup>	mg/L	SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: PART 2540 D)	6.3	≤ 40	5.0
TOTAL DISSOLVED SOLIDS <sup>b</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAO.007 (TOTAL DISSOLVED SOLIDS DRIED AT 103-105 °C); SM: PART 2540 C	386	500*	25
SETTLEABLE SOLIDS <sup>c</sup>	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	≤ 0.5	0.1
SULPHIDE <sup>b</sup>	mg/L	IODOMETRIC METHOD (SM: PART 4500-S <sub>2</sub> F)	< 0.50	≤ 1.0	0.50
TOTAL KJELDAHL NITROGEN <sup>b</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	15.5	≤ 35	1.5
FAT, OIL AND GREASE <sup>c</sup>	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	ND	≤ 20	3



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			EFFLUENT T23AR592-0001		
MICROBIOLOGY					
COLIFORM BACTERIA <sup>b</sup>	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221B)	2.0	-	1.8
<b>SAMPLE CONDITION</b>					
WATER'S COLOUR/TURBID			YELLOW/TURBID		
SEDIMENT			BROWN		

<sup>a</sup> : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

<sup>b</sup> : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

<sup>c</sup> : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

IN-HOUSE : BASED ON STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE  
MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 122,  
PART 125 D, DATED DECEMBER 29, 2005.

500\* : PERMITTED EXCESS VALUE TO TOTAL DISSOLVED SOLIDS OF ACTUAL TAP WATER USED.

<sup>A</sup> : MEASURED BY CUSTOMER.

ND : NON-DETECTABLE.

*Piyapat S.*

(MRS PIYAPAT SUTTAMANUTWONG)  
LABORATORY SUPERVISOR

SEPTEMBER 19, 2023

ISO 9001:2015 CERTIFIED  
ISO 14001:2015 CERTIFIED  
BY BSI GROUP (THAILAND) CO., LTD.

• PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.  
• THIS ANALYSIS REPORT APPROVES ONLY FOR SUBMITTED SAMPLES.

2/2

2023-U077672

- End of Analysis Report -

## ANALYSIS REPORT

**CUSTOMER NAME** : KASEMKIJ COMPANY LIMITED (KANTARY BANCHANG HOTEL)  
**ADDRESS** : 91, 91/1 MOO 3 PHLA BANCHANG RAYONG 21130  
**CONTACT INFORMATION** : TEL : 0 2233 8989-98 e-mail : kj-qc@kasemkij.com  
**SAMPLING SOURCE** : KANTARY HOTEL BANCHANG  
**SAMPLE TYPE** : EFFLUENT  
**SAMPLING DATE** : OCTOBER 4, 2023  
**SAMPLING TIME** : -  
**SAMPLING METHOD** : -  
**SAMPLING BY** : CUSTOMER  
**ANALYZED BY** : MISS NAPAPORN KHUNNOKKHUM

**RECEIVED DATE** : OCTOBER 5, 2023  
**ANALYTICAL DATE** : OCTOBER 5-12, 2023  
**REPORT NO.** : 2023-U094326  
**WORK NO.** : 2023-007354  
**ANALYSIS NO.** : T23AT835-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			EFFLUENT T23AT835-0001		
pH <sup>A</sup>	-	ELECTROMETRIC METHOD (SM: PART 4500-H <sup>+</sup> B)	7.1 (25°C)	5-9	-
BIOCHEMICAL OXYGEN DEMAND <sup>C</sup>	mg/L	AZIDE MODIFICATION METHOD (SM: PART 5210 B AND PART 4500-O C)	2.9	≤ 30	2.0
SUSPENDED SOLIDS <sup>A</sup>	mg/L	SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: PART 2540 D)	14.6	≤ 40	5.0
TOTAL DISSOLVED SOLIDS <sup>B</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAO.007 (TOTAL DISSOLVED SOLIDS DRIED AT 103-105 °C); SM: PART 2540 C	472	500*	25
SETTLEABLE SOLIDS <sup>C</sup>	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	≤ 0.5	0.1
SULPHIDE <sup>B</sup>	mg/L	IODOMETRIC METHOD (SM: PART 4500 -S <sup>2-</sup> F)	< 0.50	≤ 1.0	0.50
TOTAL KJELDAHL NITROGEN <sup>B</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	7.3	≤ 35	1.5
FAT, OIL AND GREASE <sup>C</sup>	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	ND	≤ 20	3



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			EFFLUENT T23AT835-0001		
MICROBIOLOGY					
COLIFORM BACTERIA <sup>b</sup>	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221B)	< 1.8	-	1.8
SAMPLE CONDITION					
WATER'S COLOUR/TURBID			YELLOW/CLEAR		
SEDIMENT			BROWN		

<sup>a</sup> : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

<sup>b</sup> : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

<sup>c</sup> : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

IN-HOUSE : BASED ON STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE  
MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 122,  
PART 125 D, DATED DECEMBER 29, 2005.

500\* : PERMITTED EXCESS VALUE TO TOTAL DISSOLVED SOLIDS OF ACTUAL TAP WATER USED.

ND : NON-DETECTABLE.

<sup>^</sup> : SAMPLING ON OCTOBER 26, 2023, ANALYSIS NO. T23AV396-0001 (ANALYTICAL DATE : OCTOBER 27-30, 2023).

THE REASON FOR ISSUING THE NEW REPORT IS SUBSTITUTE RESULT.

SUBSTITUTED REPORT FOR REPORT NO. 2023-U087721, DATED OCTOBER 17, 2023.

*Piyapat S.*

(MRS PIYAPAT SUTTAMANUTWONG)  
LABORATORY SUPERVISOR

NOVEMBER 6, 2023



## ANALYSIS REPORT

**CUSTOMER NAME** : KASEMKIJ COMPANY LIMITED (KANTARY BANCHANG HOTEL)  
**ADDRESS** : 91, 91/1 MOO 3 PHLA BANCHANG RAYONG 21130  
**CONTACT INFORMATION** : TEL : 0 2233 8989-98 e-mail : kj-qc@kasemkij.com  
**SAMPLING SOURCE** : KANTARY HOTEL BANCHANG  
**SAMPLE TYPE** : EFFLUENT  
**SAMPLING DATE** : NOVEMBER 1, 2023  
**SAMPLING TIME** : -  
**SAMPLING METHOD** : -  
**SAMPLING BY** : CUSTOMER  
**ANALYZED BY** : MISS NAPAPORN KHUNNOKKHUM

**RECEIVED DATE** : NOVEMBER 2, 2023  
**ANALYTICAL DATE** : NOVEMBER 2-10, 2023  
**REPORT NO.** : 2023-U096660  
**WORK NO.** : 2023-008245  
**ANALYSIS NO.** : T23AV831-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			EFFLUENT T23AV831-0001		
pH <sup>a</sup>	-	ELECTROMETRIC METHOD (SM: PART 4500-H <sup>+</sup> B)	7.2 (25°C)	5-9	-
BIOCHEMICAL OXYGEN DEMAND <sup>c</sup>	mg/L	AZIDE MODIFICATION METHOD (SM: PART 5210 B AND PART 4500-O C)	ND	≤ 30	2.0
SUSPENDED SOLIDS <sup>c</sup>	mg/L	SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: PART 2540 D)	ND	≤ 40	5.0
TOTAL DISSOLVED SOLIDS <sup>b</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAO.007 (TOTAL DISSOLVED SOLIDS DRIED AT 103-105 °C); SM: PART 2540 C	304	500*	25
SETTLABLE SOLIDS <sup>c</sup>	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	≤ 0.5	0.1
SULPHIDE <sup>b</sup>	mg/L	IODOMETRIC METHOD (SM: PART 4500 -S <sup>2-</sup> F)	< 0.50	≤ 1.0	0.50
TOTAL KJELDAHL NITROGEN <sup>b</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	11.5	≤ 35	1.5
FAT, OIL AND GREASE <sup>c</sup>	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	ND	≤ 20	3



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			EFFLUENT T23AV831-0001		
MICROBIOLOGY					
COLIFORM BACTERIA <sup>b</sup>	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221B)	< 1.8	-	1.8
SAMPLE CONDITION					
WATER'S COLOUR/TURBID			YELLOW/CLEAR		
SEDIMENT			BROWN		

<sup>a</sup> : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

<sup>b</sup> : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

<sup>c</sup> : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

IN-HOUSE : BASED ON STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE  
MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 122,  
PART 125 D, DATED DECEMBER 29, 2005.


500\* : PERMITTED EXCESS VALUE TO TOTAL DISSOLVED SOLIDS OF ACTUAL TAP WATER USED.

ND : NON-DETECTABLE.

*Piyapat S.*

(MRS PIYAPAT SUTTAMANUTWONG)  
LABORATORY SUPERVISOR

NOVEMBER 13, 2023



- PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
- THIS ANALYSIS REPORT APPROVES ONLY FOR SUBMITTED SAMPLES.

2/2

2023-U096660

- End of Analysis Report -

## ANALYSIS REPORT

**CUSTOMER NAME** : KASEMKIJ COMPANY LIMITED (KANTARY BANCHANG HOTEL)  
**ADDRESS** : 91, 91/1 MOO 3 PHLA BANCHANG RAYONG 21130  
**CONTACT INFORMATION** : TEL : 0 2233 8989-98 e-mail : kj-qc@kasemkij.com  
**SAMPLING SOURCE** : KANTARY HOTEL BANCHANG  
**SAMPLE TYPE** : EFFLUENT  
**SAMPLING DATE** : DECEMBER 6, 2023  
**SAMPLING TIME** : -  
**SAMPLING METHOD** : -  
**SAMPLING BY** : CUSTOMER  
**ANALYZED BY** : MISS NAPAPORN KHUNNOKKHUM

**RECEIVED DATE** : DECEMBER 7, 2023  
**ANALYTICAL DATE** : DECEMBER 7-14, 2023  
**REPORT NO.** : 2023-U108084  
**WORK NO.** : 2023-008969  
**ANALYSIS NO.** : T23AY423-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			EFFLUENT T23AY423-0001		
pH <sup>a</sup>	-	ELECTROMETRIC METHOD (SM: PART 4500-H <sup>+</sup> B)	6.3 (25°C)	5-9	-
BIOCHEMICAL OXYGEN DEMAND <sup>c</sup>	mg/L	AZIDE MODIFICATION METHOD (SM: PART 5210 B AND PART 4500-O C)	2.3	≤ 30	2.0
SUSPENDED SOLIDS <sup>a</sup>	mg/L	SUSPENDED SOLIDS DRIED AT 103-105 °C (SM: PART 2540 D)	6.0	≤ 40	5.0
TOTAL DISSOLVED SOLIDS <sup>b</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAO.007 (TOTAL DISSOLVED SOLIDS DRIED AT 103-105 °C); SM: PART 2540 C	398	500*	25
SETTLEABLE SOLIDS <sup>c</sup>	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	≤ 0.5	0.1
SULPHIDE <sup>b</sup>	mg/L	IODOMETRIC METHOD (SM: PART 4500 -S <sup>2-</sup> F)	< 0.50	≤ 1.0	0.50
TOTAL KJELDAHL NITROGEN <sup>b</sup>	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	17.6	≤ 35	1.5
FAT, OIL AND GREASE <sup>c</sup>	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	ND	≤ 20	3



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			EFFLUENT T23AY423-0001		
MICROBIOLOGY					
COLIFORM BACTERIA <sup>b</sup>	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221B)	< 1.8	-	1.8
SAMPLE CONDITION					
WATER'S COLOUR/TURBID			YELLOW/CLEAR		
SEDIMENT			BROWN		

<sup>a</sup> : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

<sup>b</sup> : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

<sup>c</sup> : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT STILL NOT ACCREDITED

IN-HOUSE : BASED ON STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 23<sup>rd</sup> EDITION, 2017.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE  
MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL. 122,  
PART 125 D, DATED DECEMBER 29, 2005.

500\* : PERMITTED EXCESS VALUE TO TOTAL DISSOLVED SOLIDS OF ACTUAL TAP WATER USED.

BIOCHEMICAL OXYGEN DEMAND (T23AY423-0001) : ADDITION OF NITRIFICATION INHIBITION (TCMP) FOLLOW TO THE SM: 5210B.5(e).

ND : NON-DETECTABLE.

*Piyapat S.*

(MRS PIYAPAT SUTTAMANUTWONG)  
LABORATORY SUPERVISOR

DECEMBER 18, 2023

ISO 9001:2015 CERTIFIED  
ISO 14001:2015 CERTIFIED  
BY BSI GROUP (THAILAND) CO., LTD.

• PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.  
• THIS ANALYSIS REPORT APPROVES ONLY FOR SUBMITTED SAMPLES.

2/2

2023-U108084

- End of Analysis Report -