

ภาคผนวกที่ 7

เอกสารรายงานการตรวจสอบคุณภาพสระว่ายน้ำ
ประจำเดือน กรกฎาคม 2566 ถึง ธันวาคม 2566

เอกสารตรวจสอบคุณภาพสระว่ายน้ำประจำเดือน

My Story Ladprao 71		INFINITE				
Check Chlorine Swimming Pool						
เดือน กรกฎาคม 2566					อาคาร A	
Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	6.8	1.5	6.8	SW	
2	1.5	6.8	1.5	6.8	SW	
3	1.5	6.8	1.5	6.8	SW	
4	3.0	7.2	3.0	7.2	SW	
5	3.0	7.2	3.0	7.2	SW	
6	3.0	7.2	3.0	7.2	SW	
7	3.0	7.6	3.0	7.6	SW	
8	3.0	7.6	3.0	7.6	SW	
9	3.0	7.6	3.0	7.6	SW	
10	3.0	7.6	3.0	7.6	SW	
11	1.5	7.2	1.5	7.2	SW	
12	1.5	7.2	1.5	7.2	SW	
13	1.5	7.2	1.5	7.2	SW	
14	1.5	7.2	1.5	7.2	SW	
15	1.5	7.2	1.5	7.2	SW	
16	1.5	7.2	1.5	7.2	SW	
17	1.0	6.8	1.0	6.8	SW	
18	1.0	6.8	1.0	6.8	SW	
19	3.0	6.8	3.0	6.8	SW	
20	3.0	6.8	3.0	6.8	SW	
21	3.0	6.8	3.0	6.8	SW	
22	3.0	7.2	3.0	7.2	SW	
23	3.0	7.2	3.0	7.2	SW	
24	3.0	7.2	3.0	7.2	SW	
25	3.0	7.2	3.0	7.2	SW	
26	1.5	6.8	1.5	6.8	SW	
27	1.5	6.8	1.5	6.8	SW	
28	1.5	6.8	1.5	6.8	SW	
29	1.5	6.8	1.5	6.8	SW	
30	1.5	6.8	1.5	6.8	SW	
31	3.0	7.2	3.0	7.2	SW	

Remark : Spa and Swimming Pool Water Quality
 The pool water quality should have the following range of values:
 a. pH of 7.2 to 7.5
 b. Total alkalinity of 90 to 110ppm
 c. Calcium hardness of 200 to 275ppm
 d. Free residue chlorine of 1.0 to 1.5ppm
 e. Free of Bacteria.
 f. For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

Month : 17/10/2560

อาคาร C

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	7.2	1.5	7.2		
2	1.5	7.2	1.5	7.2		
3	1.5	7.2	1.5	7.2		
4	1.5	7.2	1.5	7.2		
5	1.5	7.2	1.5	7.2		
6	3.0	6.8	3.0	6.8		
7	3.0	6.8	3.0	6.8		
8	3.0	6.8	3.0	6.8		
9	3.0	6.8	3.0	6.8		
10	3.0	6.8	3.0	6.8		
11	3.0	6.8	3.0	6.8		
12	1.5	6.4	1.5	6.8		
13	1.5	6.8	1.5	6.8		
14	1.5	7.2	1.5	7.2		
15	1.5	7.2	1.5	7.2		
16	1.5	7.2	1.5	7.2		
17	1.5	7.2	1.5	7.2		
18	3.0	7.2	3.0	7.2		
19	3.0	7.2	3.0	7.2		
20	3.0	7.2	3.0	7.2		
21	3.0	6.8	3.0	6.8		
22	3.0	6.8	3.0	6.8		
23	3.0	6.8	3.0	6.8		
24	3.0	6.8	3.0	6.8		
25	1.5	6.8	1.5	6.8		
26	1.5	6.8	1.5	6.8		
27	1.5	7.2	1.5	7.2		
28	1.5	7.2	1.5	7.2		
29	1.5	7.2	1.5	7.2		
30	1.5	7.2	1.5	7.2		
31	1.5	7.2	1.5	7.2		

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 28°C



My Story Ladprao 71



Check Chlorine Swimming Pool

เดือน สิงหาคม 2566

อาคาร A

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	3.0	7.6	3.0	7.6	จว	
2	3.0	7.6	3.0	7.6	จว	
3	3.0	7.6	3.0	7.6	จว	
4	1.5	7.2	1.5	7.2	จว	
5	1.5	7.2	1.5	7.2	จว	
6	1.5	7.2	1.5	7.2	จว	
7	1.5	6.8	1.5	6.8	จว	
8	1.0	6.8	1.0	6.8	จว	
9	1.0	6.8	1.0	6.8	จว	
10	3.0	7.2	3.0	7.2	จว	
11	3.0	7.2	3.0	7.2	จว	
12	3.0	7.0	3.0	7.2	จว	
13	3.0	7.0	3.0	7.2	จว	
14	3.0	7.2	3.0	7.2	จว	
15	3.0	7.2	3.0	7.2	จว	
16	1.5	6.8	1.5	6.8	จว	
17	1.5	6.8	1.5	6.8	จว	
18	1.5	6.8	1.5	6.8	จว	
19	1.5	6.8	1.5	6.8	จว	
20	1.5	6.8	1.5	6.8	จว	
21	1.0	6.8	1.0	6.8	จว	
22	1.0	6.8	1.0	6.8	จว	
23	3.0	7.6	3.0	7.6	จว	
24	3.0	7.6	3.0	7.6	จว	
25	3.0	7.6	3.0	7.6	จว	
26	3.0	7.6	3.0	7.6	จว	
27	3.0	7.2	3.0	7.6	จว	
28	3.0	7.2	3.0	7.2	จว	
29	1.5	7.2	1.5	7.2	จว	
30	1.5	7.2	1.5	7.2	จว	
31	1.5	7.2	1.5	7.2	จว	

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

เดือน สิงหาคม 2566

อาคาร C

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	7.5	6.8	1.5	7.2	อ.ก.	
2	1.5	6.8	1.5	6.8	อ.ก.	
3	1.5	6.8	1.5	6.8	อ.ก.	
4	1.5	6.8	1.5	6.8	อ.ก.	
5	1.5	6.8	1.5	6.8	อ.ก.	
6	1.5	6.8	1.5	6.8	อ.ก.	
7	1.5	7.2	1.5	7.2	อ.ก.	
8	3.0	7.2	3.0	7.2	อ.ก.	
9	3.0	7.2	3.0	7.2	อ.ก.	
10	3.0	7.2	3.0	7.2	อ.ก.	
11	3.0	7.2	3.0	7.2	อ.ก.	
12	3.0	7.2	3.0	7.2	อ.ก.	
13	3.0	6.8	3.0	6.8	อ.ก.	
14	3.0	6.8	3.0	6.8	อ.ก.	
15	1.5	6.8	1.5	6.8	อ.ก.	
16	1.5	6.8	1.5	6.8	อ.ก.	
17	1.5	6.8	1.5	6.8	อ.ก.	
18	1.5	6.8	1.5	6.8	อ.ก.	
19	1.5	6.8	1.5	6.8	อ.ก.	
20	1.5	7.2	1.5	7.2	อ.ก.	
21	1.5	7.2	1.5	7.2	อ.ก.	
22	3.0	7.2	1.5	7.2	อ.ก.	
23	3.0	7.2	3.0	7.2	อ.ก.	
24	3.0	7.2	3.0	7.2	อ.ก.	
25	3.0	7.2	3.0	7.2	อ.ก.	
26	3.0	7.2	3.0	7.2	อ.ก.	
27	3.0	6.8	3.0	6.8	อ.ก.	
28	3.0	6.8	3.0	6.8	อ.ก.	
29	1.5	6.8	3.0	6.8	อ.ก.	
30	1.5	6.8	3.0	6.8	อ.ก.	
31	1.5	6.8	3.0	6.8	อ.ก.	

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values;

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

เดือน กันยายน 2566

อาคาร A

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	7.2	1.5	7.2	จว	
2	1.5	7.2	1.5	7.2	จว	
3	1.5	7.2	1.5	7.2	จว	
4	1.5	7.2	1.5	7.2	จว	
5	3.0	7.6	3.0	7.6	จว	
6	3.0	7.6	3.0	7.6	จว	
7	3.0	7.6	3.0	7.6	จว	
8	3.0	7.6	3.0	7.6	จว	
9	3.0	7.6	3.0	7.6	จว	
10	1.5	7.2	1.5	7.2	จว	
11	1.5	7.2	1.5	7.2	จว	
12	1.5	7.2	1.5	7.2	จว	
13	1.5	6.8	1.5	6.8	จว	
14	1.0	6.8	1.0	6.8	จว	
15	1.0	6.8	1.0	6.8	จว	
16	3.0	6.8	3.0	6.8	จว	
17	3.0	7.6	3.0	7.6	จว	
18	3.0	7.6	3.0	7.6	จว	
19	3.0	7.6	3.0	7.6	จว	
20	3.0	7.6	3.0	7.6	จว	
21	1.5	7.2	1.5	7.2	จว	
22	1.5	7.2	1.5	7.2	จว	
23	1.5	7.2	1.5	7.2	จว	
24	1.5	7.2	1.5	7.2	จว	
25	1.5	7.2	1.5	7.2	จว	
26	3.0	7.6	3.0	7.6	จว	
27	3.0	7.6	3.0	7.6	จว	
28	3.0	7.6	3.0	7.6	จว	
29	3.0	7.6	3.0	7.6	จว	
30	3.0	7.6	3.0	7.6	จว	
31						

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

เดือน กันยายน 2566

อาคาร C

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	3.0	7.2	3.0	7.0	ดี	
2	3.0	7.2	3.0	7.2	ดี	
3	3.0	7.2	3.0	7.2	ดี	
4	3.0	7.2	3.0	7.2	ดี	
5	3.0	6.8	3.0	6.8	ดี	
6	3.0	6.8	3.0	6.8	ดี	
7	3.0	6.8	3.0	6.8	ดี	
8	3.0	6.8	3.0	6.8	ดี	
9	1.5	6.4	1.5	6.8	ดี	
10	1.5	6.8	1.5	6.8	ดี	
11	1.5	7.2	1.5	7.2	ดี	
12	1.5	7.2	1.5	7.2	ดี	
13	1.5	7.2	1.5	7.2	ดี	
14	1.5	7.2	1.5	7.2	ดี	
15	1.5	7.2	1.5	7.2	ดี	
16	1.5	7.2	1.5	7.2	ดี	
17	1.5	7.2	1.5	7.2	ดี	
18	3.0	7.2	3.0	7.2	ดี	
19	3.0	7.2	3.0	7.2	ดี	
20	3.0	7.2	3.0	7.2	ดี	
21	3.0	6.8	3.0	6.8	ดี	
22	3.0	6.8	3.0	6.8	ดี	
23	1.5	6.8	1.5	6.8	ดี	
24	1.5	6.8	1.5	6.8	ดี	
25	1.5	6.8	1.5	6.8	ดี	
26	1.5	6.8	1.5	6.8	ดี	
27	1.5	6.8	1.5	6.8	ดี	
28	1.5	7.2	1.5	7.2	ดี	
29	1.5	7.2	1.5	7.2	ดี	
30	3.0	7.2	3.0	7.2	ดี	
31						

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

เดือน ตุลาคม 2566

อาคาร A

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	3.0	7.6	3.0	7.6	SN	
2	3.0	7.6	3.0	7.6	SN	
3	3.0	7.6	3.0	7.6	SN	
4	3.0	7.6	3.0	7.6	SN	
5	1.5	7.2	1.5	7.2	SN	
6	1.5	7.2	1.5	7.2	SN	
7	1.5	7.2	1.5	7.2	SN	
8	1.5	7.2	1.5	7.2	SN	
9	1.0	6.8	1.0	6.8	SN	
10	1.0	6.8	1.0	6.8	SN	
11	1.0	6.8	1.0	6.8	SN	
12	3.0	7.6	3.0	7.6	SN	
13	3.0	7.6	3.0	7.6	SN	
14	3.0	7.6	3.0	7.6	SN	
15	3.0	7.6	3.0	7.6	SN	
16	3.0	7.2	3.0	7.2	SN	
17	3.0	7.2	3.0	7.2	SN	
18	3.0	7.2	3.0	7.2	SN	
19	1.5	6.8	1.5	6.8	SN	
20	1.5	6.8	1.5	6.8	SN	
21	1.5	6.8	1.5	6.8	SN	
22	1.5	6.8	1.5	6.8	SN	
23	1.5	6.8	1.5	6.8	SN	
24	1.0	6.8	1.0	6.8	SN	
25	1.0	6.8	1.0	6.8	SN	
26	3.0	7.2	3.0	7.2	SN	
27	3.0	7.2	3.0	7.2	SN	
28	3.0	7.2	3.0	7.2	SN	
29	3.0	7.2	3.0	7.2	SN	
30	3.0	7.2	3.0	7.2	SN	
31	1.5	7.2	1.5	7.2	SN	

Remark : Spa and Swimming Pool Water Quality
 The pool water quality should have the following range of values:
 a. pH of 7.2 to 7.5
 b. Total alkalinity of 90 to 110ppm
 c. Calcium hardness of 200 to 275ppm
 d. Free residue chlorine of 1.0 to 1.5ppm
 e. Free of Bacteria.
 f. For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

เดือน ตุลาคม 2566

อาคาร C

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	6.8	1.5	6.8		
2	1.5	6.8	1.5	6.8		
3	1.5	6.8	1.5	6.8		
4	1.5	6.8	1.5	6.8		
5	1.5	6.8	1.5	6.8		
6	1.5	6.8	1.5	6.8		
7	1.5	7.2	1.5	7.2		
8	1.5	7.2	1.5	7.2		
9	3.0	7.2	3.0	7.2		
10	3.0	7.2	3.0	7.2		
11	3.0	7.2	3.0	7.2		
12	3.0	7.2	3.0	7.2		
13	3.0	7.2	3.0	7.2		
14	3.0	6.8	3.0	6.8		
15	3.0	6.8	3.0	6.8		
16	3.0	6.8	3.0	6.8		
17	3.0	6.8	3.0	6.8		
18	1.5	6.8	1.5	6.8		
19	1.5	7.2	1.5	7.2		
20	1.5	7.2	1.5	7.2		
21	1.5	7.2	1.5	7.2		
22	1.5	7.2	1.5	7.2		
23	1.5	7.2	1.5	7.2		
24	1.5	7.2	1.5	7.2		
25	1.5	7.2	1.5	7.2		
26	3.0	6.8	3.0	6.8		
27	3.0	6.8	3.0	6.8		
28	3.0	6.8	3.0	6.8		
29	3.0	6.8	3.0	6.8		
30	3.0	6.8	3.0	6.8		
31	3.0	6.8	3.0	6.8		

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

เดือน พฤศจิกายน 2566

อาคาร A

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	7.2	1.5	7.2	SN	
2	1.5	7.2	1.5	7.2	SN	
3	1.5	7.2	1.5	7.2	SN	
4	1.5	6.8	1.5	6.8	SN	
5	1.0	6.8	1.0	6.8	SN	
6	1.0	6.8	1.0	6.8	SN	
7	1.0	6.8	1.0	6.8	SN	
8	3.0	7.6	3.0	7.6	SN	
9	3.0	7.6	3.0	7.6	SN	
10	3.0	7.6	3.0	7.6	SN	
11	3.0	7.6	3.0	7.6	SN	
12	3.0	7.6	3.0	7.6	SN	
13	3.0	7.6	3.0	7.6	SN	
14	1.5	7.2	1.5	7.2	SN	
15	1.5	7.2	1.5	7.2	SN	
16	1.5	7.2	1.5	7.2	SN	
17	1.5	7.2	1.5	7.2	SN	
18	1.5	6.8	1.5	6.8	SN	
19	1.5	6.8	1.5	6.8	SN	
20	1.5	6.8	1.5	6.8	SN	
21	1.0	6.8	1.0	6.8	SN	
22	3.0	7.2	3.0	7.2	SN	
23	3.0	7.2	3.0	7.2	SN	
24	3.0	7.2	3.0	7.2	SN	
25	3.0	7.2	3.0	7.2	SN	
26	1.5	7.2	1.5	7.2	SN	
27	1.5	7.2	1.5	7.2	SN	
28	1.5	6.8	1.5	6.8	SN	
29	1.5	6.8	1.5	6.8	SN	
30	1.5	6.8	1.5	6.8	SN	
31						

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

เดือน พฤศจิกายน 2566

อาคาร C

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	6.8	1.5	6.8	อ.พ.	
2	1.5	6.8	1.5	6.8	อ.พ.	
3	1.5	6.8	1.5	6.8	อ.พ.	
4	1.5	6.8	1.5	6.8	อ.พ.	
5	1.5	6.8	1.5	6.8	อ.พ.	
6	1.5	6.8	1.5	6.8	อ.พ.	
7	1.5	6.8	1.5	6.8	อ.พ.	
8	1.5	6.8	1.5	6.8	อ.พ.	
9	3.0	6.8	3.0	6.8	อ.พ.	
10	3.0	7.2	3.0	7.2	อ.พ.	
11	3.0	7.2	3.0	7.2	อ.พ.	
12	3.0	7.2	3.0	7.2	อ.พ.	
13	3.0	7.2	3.0	7.2	อ.พ.	
14	3.0	7.2	3.0	7.2	อ.พ.	
15	3.0	7.2	3.0	7.2	อ.พ.	
16	3.0	7.2	3.0	7.2	อ.พ.	
17	1.5	7.2	1.5	7.2	อ.พ.	
18	1.5	7.2	1.5	7.2	อ.พ.	
19	1.5	6.8	1.5	6.8	อ.พ.	
20	1.5	6.8	1.5	6.8	อ.พ.	
21	1.5	6.8	1.5	6.8	อ.พ.	
22	1.5	6.8	1.5	6.8	อ.พ.	
23	1.5	6.8	1.5	6.8	อ.พ.	
24	3.0	6.8	3.0	6.8	อ.พ.	
25	3.0	6.8	3.0	6.8	อ.พ.	
26	3.0	6.8	3.0	6.8	อ.พ.	
27	3.0	7.2	3.0	7.2	อ.พ.	
28	3.0	7.2	3.0	7.2	อ.พ.	
29	3.0	7.2	3.0	7.2	อ.พ.	
30	3.0	7.2	3.0	7.2	อ.พ.	
31						

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

เดือน ธันวาคม 2566

อาคาร A

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	3.0	7.6	3.0	7.6	จน	
2	3.0	7.6	3.0	7.6	จน	
3	3.0	7.6	3.0	7.6	จน	
4	3.0	7.6	3.0	7.6	จน	
5	3.0	7.2	3.0	7.2	จน	
6	3.0	7.2	3.0	7.2	จน	
7	1.5	6.8	1.5	6.8	จน	
8	1.5	6.8	1.5	6.8	จน	
9	1.5	6.8	1.5	6.8	จน	
10	1.5	6.8	1.5	6.8	จน	
11	1.5	6.8	1.5	6.8	จน	
12	3.0	7.2	3.0	7.2	จน	
13	3.0	7.2	3.0	7.2	จน	
14	3.0	7.2	3.0	7.2	จน	
15	3.0	7.2	3.0	7.2	จน	
16	3.0	7.2	3.0	7.2	จน	
17	1.5	7.2	1.5	7.2	จน	
18	1.5	7.2	1.5	7.2	จน	
19	1.5	6.8	1.5	6.8	จน	
20	1.0	6.8	1.0	6.8	จน	
21	1.0	6.8	1.0	6.8	จน	
22	1.0	6.8	1.0	6.8	จน	
23	3.0	6.8	3.0	6.8	จน	
24	3.0	6.8	3.0	6.8	จน	
25	3.0	7.6	3.0	7.6	จน	
26	3.0	7.6	3.0	7.6	จน	
27	3.0	7.6	3.0	7.6	จน	
28	1.5	7.6	1.5	7.6	จน	
29	1.5	7.6	1.5	7.6	จน	
30	1.5	7.2	1.5	7.2	จน	
31	1.5	7.2	1.5	7.2	จน	

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C



My Story Ladprao 71



Check Chlorine Swimming Pool

เดือน ธันวาคม 2566

อาคาร C

Date	7.00		17.00		Checked by	หมายเหตุ Remark
	Chlorine Level	P.H. Level	Chlorine Level	P.H. Level		
1	1.5	6.8	1.5	6.8	จก	
2	1.5	6.8	1.5	6.8	จก	
3	1.5	7.2	1.5	6.8	จก	
4	1.5	7.2	1.5	6.8	จก	
5	3.0	7.2	1.5	6.8	จก	
6	3.0	7.2	1.5	6.8	จก	
7	3.0	7.2	1.5	7.2	จก	
8	3.0	7.2	1.5	7.2	จก	
9	3.0	7.2	1.5	7.2	จก	
10	3.0	7.2	1.5	7.2	จก	
11	3.0	7.2	1.5	6.8	จก	
12	3.0	7.2	1.5	6.8	จก	
13	1.5	7.2	1.5	6.8	จก	
14	7.5	7.2	3.0	6.8	จก	
15	1.5	7.2	3.0	6.8	จก	
16	1.5	7.2	3.0	7.2	จก	
17	1.5	6.8	3.0	7.2	จก	
18	1.5	6.8	3.0	7.2	จก	
19	1.5	6.8	3.0	7.2	จก	
20	1.5	6.8	3.0	7.2	จก	
21	3.0	6.8	1.5	7.2	จก	
22	3.0	6.8	1.5	6.8	จก	
23	3.0	6.8	1.5	6.8	จก	
24	3.0	6.8	1.5	6.8	จก	
25	3.0	6.8	1.5	6.8	จก	
26	3.0	6.8	3.0	6.8	จก	
27	3.0	6.8	3.0	6.8	จก	
28	3.0	6.8	3.0	6.8	จก	
29	3.0	7.2	3.0	6.8	จก	
30	3.0	7.2	3.0	6.8	จก	
31	3.0	7.2	2.5	6.8	จก	

Remark : Spa and Swimming Pool Water Quality

The pool water quality should have the following range of values:

- pH of 7.2 to 7.5
- Total alkalinity of 90 to 110ppm
- Calcium hardness of 200 to 275ppm
- Free residue chlorine of 1.0 to 1.5ppm
- Free of Bacteria.
- For indoor pool the water temperature shall be 29°C