

ภาคผนวก ข-7

รายการอุปกรณ์สำรองระบบบำบัดมลพิษทางอากาศ

[illegible]

Plant	Old material number	Material	Material Description
2451	250A12585903	21008862	SET OF NUTS 1/4" X 3/8" 30303
2451	250A12585904	21008863	WASHER 3/8" 30303
2451	250A12585903	21008865	SHAFT 1/2" X 3/8" 30303
2451	250A12585903	21008866	SHAFT 1/2" X 3/8" 30303
2451	250A12585904	21008866	SHAFT 1/2" X 3/8" 30303
2451	250A12585905	21008867	SHAFT 1/2" X 3/8" 30303
2451	250A12585907	21008868	SHIM PN 183718801
2451	250A12585908	21008869	SHIM PN 183718801
2451	250A12586003	21008870	SOLENOID VALVE 20"DN PN004542
2452	250A12586009	21008871	SOL VALVE PN004990021
2451	250A12586103	21008872	SOL VALVE PN004990021
2451	250A12586122	21008873	SOL VALVE PN004990021
2451	250A12586123	21008873	SPARK PLUG PN00403503
2451	250A12586133	21008874	SPARK PLUG PN00403503
2451	250A12586135	21008875	SPRING PN00403503
2451	250A12586145	21008876	SPRING PN00403503
2451	250A12586173	21008877	SPRING PN00403503
2451	250A12586173	21008878	SPRING PN00403503
2451	250A12586193	21008879	SPRING PN00403503
2451	250A12586203	21008880	SPRING PN00403503
2451	250A12586213	21008882	SPRING PN00403503
2451	250A12586223	21008882	SPRING PN00403503
2451	250A12586233	21008883	SPRING PN00403503
2451	250A12586243	21008884	SPRING PN00403503
2451	250A12586253	21008885	SPRING PN00403503
2451	250A12586263	21008886	SPRING PN00403503
2451	250A12586273	21008887	ST ROD 1/2" X 3/8" 30303
2451	250A12586283	21008888	STEM PN00403503
2451	250A12586293	21008889	STEM PN00403503
2451	250A12586303	21008890	TC TYPE PN 00403503
2451	250A12586303	21008891	TEMP. ELEMENT PN00403503
2451	250A12586303	21008892	TEMP. ELEMENT PN00403503
2451	250A12586303	21008893	TEMP. ELEMENT PN00403503
2451	250A12586303	21008894	TEMP. ELEMENT PN00403503
2451	250A12586303	21008895	TRANSFER VALVE PN00403503
2451	250A12586303	21008896	TRANSFER VALVE PN00403503
2451	250A12586303	21008897	TRANSFER VALVE PN00403503
2451	250A12586303	21008898	TRANSFER VALVE PN00403503
2451	250A12586303	21008899	TRANSFER VALVE PN00403503
2451	250A12586303	21008900	TRANSFER VALVE PN00403503
2451	250A12586303	21008901	TRANSFER VALVE PN00403503
2451	250A12586303	21008902	TRANSFER VALVE PN00403503
2451	250A12586303	21008903	TRANSFER VALVE PN00403503
2451	250A12586303	21008904	TRANSFER VALVE PN00403503
2451	250A12586303	21008905	TRANSFER VALVE PN00403503
2451	250A12586303	21008906	TRANSFER VALVE PN00403503
2451	250A12586303	21008907	TRANSFER VALVE PN00403503
2451	250A12586303	21008908	TRANSFER VALVE PN00403503
2451	250A12586303	21008909	TRANSFER VALVE PN00403503
2451	250A12586303	21008910	TRANSFER VALVE PN00403503
2451	250A12586303	21008911	TRANSFER VALVE PN00403503
2451	250A12586303	21008912	TRANSFER VALVE PN00403503
2451	250A12586303	21008913	TRANSFER VALVE PN00403503
2451	250A12586303	21008914	TRANSFER VALVE PN00403503
2451	250A12586303	21008915	TRANSFER VALVE PN00403503
2451	250A12586303	21008916	TRANSFER VALVE PN00403503
2451	250A12586303	21008917	TRANSFER VALVE PN00403503
2451	250A12586303	21008918	TRANSFER VALVE PN00403503
2451	250A12586303	21008919	TRANSFER VALVE PN00403503
2451	250A12586303	21008920	TRANSFER VALVE PN00403503
2451	250A12586303	21008921	TRANSFER VALVE PN00403503
2451	250A12586303	21008922	TRANSFER VALVE PN00403503
2451	250A12586303	21008923	TRANSFER VALVE PN00403503
2451	250A12586303	21008924	TRANSFER VALVE PN00403503
2451	250A12586303	21008925	TRANSFER VALVE PN00403503
2451	250A12586303	21008926	TRANSFER VALVE PN00403503
2451	250A12586303	21008927	TRANSFER VALVE PN00403503
2451	250A12586303	21008928	TRANSFER VALVE PN00403503
2451	250A12586303	21008929	TRANSFER VALVE PN00403503
2451	250A12586303	21008930	TRANSFER VALVE PN00403503
2451	250A12586303	21008931	TRANSFER VALVE PN00403503
2451	250A12586303	21008932	TRANSFER VALVE PN00403503
2451	250A12586303	21008933	TRANSFER VALVE PN00403503
2451	250A12586303	21008934	TRANSFER VALVE PN00403503
2451	250A12586303	21008935	TRANSFER VALVE PN00403503
2451	250A12586303	21008936	TRANSFER VALVE PN00403503
2451	250A12586303	21008937	TRANSFER VALVE PN00403503
2451	250A12586303	21008938	TRANSFER VALVE PN00403503
2451	250A12586303	21008939	TRANSFER VALVE PN00403503
2451	250A12586303	21008940	TRANSFER VALVE PN00403503
2451	250A12586303	21008941	TRANSFER VALVE PN00403503
2451	250A12586303	21008942	TRANSFER VALVE PN00403503
2451	250A12586303	21008943	TRANSFER VALVE PN00403503
2451	250A12586303	21008944	TRANSFER VALVE PN00403503
2451	250A12586303	21008945	TRANSFER VALVE PN00403503
2451	250A12586303	21008946	TRANSFER VALVE PN00403503
2451	250A12586303	21008947	TRANSFER VALVE PN00403503
2451	250A12586303	21008948	TRANSFER VALVE PN00403503
2451	250A12586303	21008949	TRANSFER VALVE PN00403503
2451	250A12586303	21008950	TRANSFER VALVE PN00403503
2451	250A12586303	21008951	TRANSFER VALVE PN00403503
2451	250A12586303	21008952	TRANSFER VALVE PN00403503
2451	250A12586303	21008953	TRANSFER VALVE PN00403503
2451	250A12586303	21008954	TRANSFER VALVE PN00403503
2451	250A12586303	21008955	TRANSFER VALVE PN00403503
2451	250A12586303	21008956	TRANSFER VALVE PN00403503
2451	250A12586303	21008957	TRANSFER VALVE PN00403503
2451	250A12586303	21008958	TRANSFER VALVE PN00403503
2451	250A12586303	21008959	TRANSFER VALVE PN00403503
2451	250A12586303	21008960	TRANSFER VALVE PN00403503
2451	250A12586303	21008961	TRANSFER VALVE PN00403503
2451	250A12586303	21008962	TRANSFER VALVE PN00403503
2451	250A12586303	21008963	TRANSFER VALVE PN00403503
2451	250A12586303	21008964	TRANSFER VALVE PN00403503
2451	250A12586303	21008965	TRANSFER VALVE PN00403503
2451	250A12586303	21008966	TRANSFER VALVE PN00403503
2451	250A12586303	21008967	TRANSFER VALVE PN00403503
2451	250A12586303	21008968	TRANSFER VALVE PN00403503
2451	250A12586303	21008969	TRANSFER VALVE PN00403503
2451	250A12586303	21008970	TRANSFER VALVE PN00403503
2451	250A12586303	21008971	TRANSFER VALVE PN00403503
2451	250A12586303	21008972	TRANSFER VALVE PN00403503
2451	250A12586303	21008973	TRANSFER VALVE PN00403503
2451	250A12586303	21008974	TRANSFER VALVE PN00403503
2451	250A12586303	21008975	TRANSFER VALVE PN00403503
2451	250A12586303	21008976	TRANSFER VALVE PN00403503
2451	250A12586303	21008977	TRANSFER VALVE PN00403503
2451	250A12586303	21008978	TRANSFER VALVE PN00403503
2451	250A12586303	21008979	TRANSFER VALVE PN00403503
2451	250A12586303	21008980	TRANSFER VALVE PN00403503
2451	250A12586303	21008981	TRANSFER VALVE PN00403503
2451	250A12586303	21008982	TRANSFER VALVE PN00403503
2451	250A12586303	21008983	TRANSFER VALVE PN00403503
2451	250A12586303	21008984	TRANSFER VALVE PN00403503
2451	250A12586303	21008985	TRANSFER VALVE PN00403503
2451	250A12586303	21008986	TRANSFER VALVE PN00403503
2451	250A12586303	21008987	TRANSFER VALVE PN00403503
2451	250A12586303	21008988	TRANSFER VALVE PN00403503
2451	250A12586303	21008989	TRANSFER VALVE PN00403503
2451	250A12586303	21008990	TRANSFER VALVE PN00403503
2451	250A12586303	21008991	TRANSFER VALVE PN00403503
2451	250A12586303	21008992	TRANSFER VALVE PN00403503
2451	250A12586303	21008993	TRANSFER VALVE PN00403503
2451	250A12586303	21008994	TRANSFER VALVE PN00403503
2451	250A12586303	21008995	TRANSFER VALVE PN00403503
2451	250A12586303	21008996	TRANSFER VALVE PN00403503
2451	250A12586303	21008997	TRANSFER VALVE PN00403503
2451	250A12586303	21008998	TRANSFER VALVE PN00403503
2451	250A12586303	21008999	TRANSFER VALVE PN00403503
2451	250A12586303	21009000	TRANSFER VALVE PN00403503
2451	250A12586303	21009001	TRANSFER VALVE PN00403503
2451	250A12586303	21009002	TRANSFER VALVE PN00403503
2451	250A12586303	21009003	TRANSFER VALVE PN00403503
2451	250A12586303	21009004	TRANSFER VALVE PN00403503
2451	250A12586303	21009005	TRANSFER VALVE PN00403503
2451	250A12586303	21009006	TRANSFER VALVE PN00403503
2451	250A12586303	21009007	TRANSFER VALVE PN00403503
2451	250A12586303	21009008	TRANSFER VALVE PN00403503
2451	250A12586303	21009009	TRANSFER VALVE PN00403503
2451	250A12586303	21009010	TRANSFER VALVE PN00403503
2451	250A12586303	21009011	TRANSFER VALVE PN00403503
2451	250A12586303	21009012	TRANSFER VALVE PN00403503
2451	250A12586303	21009013	TRANSFER VALVE PN00403503
2451	250A12586303	21009014	TRANSFER VALVE PN00403503
2451	250A12586303	21009015	TRANSFER VALVE PN00403503
2451	250A12586303	21009016	TRANSFER VALVE PN00403503
2451	250A12586303	21009017	TRANSFER VALVE PN00403503
2451	250A12586303	21009018	TRANSFER VALVE PN00403503
2451	250A12586303	21009019	TRANSFER VALVE PN00403503
2451	250A12586303	21009020	TRANSFER VALVE PN00403503
2451	250A12586303	21009021	TRANSFER VALVE PN00403503
2451	250A12586303	21009022	TRANSFER VALVE PN00403503
2451	250A12586303	21009023	TRANSFER VALVE PN00403503
2451	250A12586303	21009024	TRANSFER VALVE PN00403503
2451	250A12586303	21009025	TRANSFER VALVE PN00403503
2451	250A12586303	21009026	TRANSFER VALVE PN00403503
2451	250A12586303	21009027	TRANSFER VALVE PN00403503
2451	250A12586303	21009028	TRANSFER VALVE PN00403503
2451	250A12586303	21009029	TRANSFER VALVE PN00403503
2451	250A12586303	21009030	TRANSFER VALVE PN00403503
2451	250A12586303	21009031	TRANSFER VALVE PN00403503
2451	250A12586303	21009032	TRANSFER VALVE PN00403503
2451	250A12586303	21009033	TRANSFER VALVE PN00403503
2451	250A12586303	21009034	TRANSFER VALVE PN00403503
2451	250A12586303	21009035	TRANSFER VALVE PN00403503
2451	250A12586303	21009036	TRANSFER VALVE PN00403503
2451	250A12586303	21009037	TRANSFER VALVE PN00403503
2451	250A12586303	21009038	TRANSFER VALVE PN00403503
2451	250A12586303	21009039	TRANSFER VALVE PN00403503
2451	250A12586303	21009040	TRANSFER VALVE PN00403503
2451	250A12586303	21009041	TRANSFER VALVE PN00403503
2451	250A12586303	21009042	TRANSFER VALVE PN00403503
2451	250A12586303	21009043	TRANSFER VALVE PN00403503
2451	250A12586303	21009044	TRANSFER VALVE PN00403503
2451	250A12586303	21009045	TRANSFER VALVE PN00403503
2451	250A12586303	21009046	TRANSFER VALVE PN00403503
2451	250A12586303	21009047	TRANSFER VALVE PN00403503
2451	250A12586303	21009048	TRANSFER VALVE PN00403503
2451	250A12586303	21009049	TRANSFER VALVE PN00403503
2451	250A12586303	21009050	TRANSFER VALVE PN00403503
2451	250A12586303	21009051	TRANSFER VALVE PN00403503
2451	250A12586303	21009052	TRANSFER VALVE PN00403503
2451	250A12586303	21009053	TRANSFER VALVE PN00403503
2451	250A12586303	21009054	TRANSFER VALVE PN00403503
2451	250A12586303	21009055	TRANSFER VALVE PN00403503
2451	250A12586303	21009056	TRANSFER VALVE PN00403503
2451	250A12586303	21009057	TRANSFER VALVE PN00403503
2451	250A12586303	21009058	TRANSFER VALVE PN00403503
2451	250A12586303	21009059	TRANSFER VALVE PN00403503
2451	250A12586303	21009060	TRANSFER VALVE PN00403503
2451	250A12586303	21009061	TRANSFER VALVE PN00403503
2451	250A12586303	21009062	TRANSFER VALVE PN00403503
2451	250A12586303	21009063	TRANSFER VALVE PN00403503
2451	250A12586303	21009064	TRANSFER VALVE PN00403503
2451	250A12586303	21009065	TRANSFER VALVE PN00403503
2451			

Part	Old material number	Material	Material Description	Stock Quantity on Hand	Base Unit of Measure	Stock Value on Hand	Current	Variation Type	Value
2451	200A000256513	21000973	SWITCH-1/4" BOLT #12-153	1	EA	27.446	1	SURPLUS	27.446
2451	200A000256223	21000975	BOLT LH LOCK COUPL. BOLT #12-28343-10516	8	EA	111.762	8	NORMAL	111.762
2451	200A000256233	21000975	BOLT LH LOCK COUPL. LOCKWASH PIN #28350-7	1	EA	2.446	1	NORMAL	2.446
2451	200A000256243	21000975	BOLT LH LOCK COUPL. FT BOLT #12-28343-10516	12	EA	1,440.214	12	NORMAL	1,440.214
2451	200A000256253	21000975	BOLT LH LOCK COUPL. HEADWASH PIN #10922	1	EA	82.846	1	NORMAL	82.846
2451	200A000256263	21000975	BOLT LH LOCK COUPL. TIE PIN #14517809-1	1	EA	54,500.61	1	NORMAL	54,500.61
2451	200A000256273	21000975	COUPLER COUPLER VARIABLE, 1/2" 3/4" 7/8"	1	EA	271.181	1	NORMAL	271.181
2451	200A000256283	21000982	GEOLINEAD KOT BOTTLES PIN #B23206419	1	EA	92,426.67	1	NORMAL	92,426.67
2451	200A000256303	21000982	GEOLINEAD KOT COMPLETE SET	1	SET	1,277.596	1	NORMAL	1,277.596
2451	200A000256313	21000984	ASBY DEGREE OF PROTECTION PIN #2428	1	EA	5,506.00	1	NORMAL	5,506.00
2451	200A000256323	21000984	BEARING SHELLE PIN #2.2-28-35-10	1	EA	1,093.92	1	NORMAL	1,093.92
2451	200A000256333	21000986	BEARING SHELLE PIN #2.2-28-35-10	1	EA	377.770	1	NORMAL	377.770
2451	200A000256343	21000986	HYDROSTATIC COMPLETE MODEL #2424-25	1	EA	26,120.00	1	NORMAL	26,120.00
2451	200A000256353	21000986	HYDROSTATIC COMPLETE MODEL #2424-25	1	EA	24,486.00	1	NORMAL	24,486.00
2451	200A000256363	21000986	MACHPIN COMPLETE ADJ PIN #2424-25	1	EA	1,000.00	1	NORMAL	1,000.00
2451	200A000256373	21000991	MACHPIN COMPLETE ADJ PIN #2424-25	1	EA	4,000.00	1	NORMAL	4,000.00
2451	200A000256383	21000992	NDE OL RING COMPLETE PIN #2.2-28-35-10	1	EA	40,800.00	1	NORMAL	40,800.00
2451	200A000256393	21000992	OL RING COMPLETE ADJ PIN #2.2-28-35-10	1	EA	37,100.00	1	NORMAL	37,100.00
2451	200A000256403	21000994	RING RING COMPLETE ADJ PIN #2.2-28-35-10	1	EA	166,243.00	1	NORMAL	166,243.00
2451	200A000256413	21000994	FLATWASH PIN #1055-18-58-58-58	1	EA	271.183	1	NORMAL	271.183
2451	200A000256423	21000995	GABINET COMPOSITE CHAMBER #7232-10004	40	EA	1,680.00	40	NORMAL	1,680.00
2451	200A000256433	21000998	EXTENSION PIN #1055-18-58-58-58	1	EA	24,487.12	1	NORMAL	24,487.12
2451	200A000256443	21000998	BEAR HOOK MACH PIN #18100474-13	26	EA	36,879.62	26	NORMAL	36,879.62
2451	200A000256453	21000998	FLATWASH PIN #1055-18-58-58-58	1	EA	666.169	1	NORMAL	666.169
2451	200A000256463	21001001	HEXAGON HEAD SCREW M2X55 PIN #1665-542	5	EA	5,617.74	5	NORMAL	5,617.74
2451	200A000256473	21001001	HEXAGON HEAD SCREW M2X55 PIN #1665-542	5	EA	3,981.18	5	NORMAL	3,981.18
2451	200A000256483	21001003	HEXAGON HEAD SCREW PIN #1665-542	5	EA	1,075.53	5	NORMAL	1,075.53
2451	200A000256493	21001003	HEXAGON HEAD SCREW PIN #1665-542	5	EA	3,981.18	5	NORMAL	3,981.18
2451	200A000256503	21001006	HEXAGON HEAD SCREW PIN #1665-532	5	EA	640.00	5	NORMAL	640.00
2451	200A000256513	21001007	HEXAGON HEAD SCREW M2X30 PIN #1665-532	50	EA	1,145.41	50	NORMAL	1,145.41
2451	200A000256523	21001007	HEXAGON HEAD SCREW M2X30 PIN #1665-538	50	EA	2,400.74	50	NORMAL	2,400.74
2451	200A000256533	21001009	HEXAGON HEAD SCREW M2X30 PIN #1665-542	10	EA	3,136.97	10	NORMAL	3,136.97
2451	200A000256543	21001009	HEXAGON HEAD SCREW M2X40 PIN #1665-532	10	EA	2,917.89	10	NORMAL	2,917.89
2451	200A000256553	21001							

Plant	Old material number	Material	Material Description	Stock Quantity on Hand	Base Unit of Measure	Stock Value on Hand	Currency	Valuation Type
2451	ZKSA72765103	21001009	SET OF DRUMS FOR P-1302 AIR	1	EA	0.00	THB	SURPLUS
2451	ZKSA72765113	21001002	BRKAR BACKUP RING FOR P-1302 AIR	1	SET	0.00	THB	SURPLUS
2451	ZKSA72765120	21001001	4100A-10000-002 PART KIT MSA	1	EA	39,615.00	THB	NORMAL
2451	ZKSA72765123	21001002	4100C1-10A00000-CHEMICAL PUMP C7	1	EA	68,400.00	THB	NORMAL
2451	ZKSA72765127	21001002	4100C2-10A00000-CHEMICAL PUMP M8	1	EA	1,544.00	THB	NORMAL
2451	ZKSA72765134	21001004	4100N100A-101002-CHEMICAL PUMP LAM	1	EA	15,600.00	THB	NORMAL
2451	ZKSA72765137	21001004	4600C2N1P-10000000000000000000	1	EA	1,775.00	THB	NORMAL
2454	ZKSA72765283	21001008	4100N2P-101-100 TACNA PUMP PVM	1	EA	9,000.00	THB	NORMAL
2454	ZKSA72765287	21001008	4600C2N1P-100 TACNA PUMP PVM	1	EA	1,225.00	THB	NORMAL
2454	ZKSA296600123	21001008	HYDRAULIC CYLINDER FOR RAM FEEDER	1	EA	466,381.00	THB	NORMAL
2454	ZKSA296600133	21001008	HYDRAULIC CYLINDER STROKE 500MM	1	EA	185,017.00	THB	NORMAL
2454	ZKSA296600143	21001110	PACKING FOR CYLINDER, HORIZNLI	1	SET	146,288.85	THB	NORMAL
2454	ZKSA296600153	21001110	PACKING FOR CYLINDER, HORIZNLI	1	SET	146,288.85	THB	NORMAL
2454	ZKSA296600203	21001116	ORING SEAL PACKING, HATCHIJOI NODDA	5	SET	331,639.92	THB	NORMAL
2454	ZKSA296600213	21001116	NOO P-1302 FEEDER PUMP	1	EA	2,111.00	THB	NORMAL
2454	ZKSA30761013	21001211	MECHANICAL SEAL, MODEL: IM90B0E	2	EA	27,000.00	THB	NORMAL
2454	ZKSA30761021	21001222	SPACER LEVER, MODEL: IM90B0E	2	EA	14,000.00	THB	NORMAL
2454	ZKSA30761033	21001222	CASING WEARING RING, MODEL: IM90B0E	1	EA	14,000.00	THB	NORMAL
2454	ZKSA30761043	21001224	BALANCING DISC SEAT, MODEL: IM90B0E	1	EA	35,000.00	THB	NORMAL
2454	ZKSA30761053	21001224	BALANCING DISC SEAT, MODEL: IM90B0E	1	EA	35,000.00	THB	NORMAL
2454	ZKSA30761063	21001226	BALL BEARING, MODEL: IM90B0E	1	EA	6,000.00	THB	NORMAL
2454	ZKSA30761073	21001227	IMPELLER, MODEL: IM90B0E	2	EA	1,000.00	THB	NORMAL
2454	ZKSA30761083	21001228	CASING WEARING RING, COMA6000S00BA	2	EA	324,800.00	THB	NORMAL
2454	ZKSA30761093	21001228	PACKING BALL BEARING, COMA6000S00BA	2	EA	1,000.00	THB	NORMAL
2454	ZKSA307610113	21001230	IMPELLER WEARING RING, COMA6000S00BA	1	EA	2,290.00	THB	NORMAL
2454	ZKSA307610123	21001230	BALL BEARING, MODEL: COMA6000S00BA	1	EA	21,700.00	THB	NORMAL
2454	ZKSA307610133	21001232	BALL BEARING, MODEL: COMA6000S00BA	1	EA	21,700.00	THB	NORMAL
2454	ZKSA307610143	21001232	ROLLER BEARING, MODEL: COMA6000S00BA	1	EA	3,900.00	THB	NORMAL
2454	ZKSA307610153	21001234	MECHANICAL SEAL, MODEL: COMA6000S00BA	1	EA	100,500.00	THB	NORMAL
2454	ZKSA307610163	21001235	SEAL, SLERVE, MODEL: COMA6000S00BA	1	EA	45,000.00	THB	NORMAL
2454	ZKSA307610173	21001235	CASING WEARING RING, MODEL: COMA6000S00BA	1	EA	4,800.00	THB	NORMAL
2454	ZKSA307610183	21001237	CASING WEARING RING, MODEL: COMA6000S00BA	1	EA	4,800.00	THB	NORMAL
2454	ZKSA307610193	21001238	BALL BEARING, MODEL: COMA6000S00BA	1	EA	1,000.00	THB	NORMAL
2454	ZKSA307610203	21001239	BALL BEARING, MODEL: COMA6000S00BA	1	EA	1,000.00	THB	NORMAL
2454	ZKSA307610213	21001239	BALL BEARING, MODEL: COMA6000S00BA	1	EA	87,500.00	THB	NORMAL
2454	ZKSA307610223	21001241	SEAL, SLERVE, MODEL: COMA6000S00BA	1	EA	19,000.00	THB	NORMAL
2454	ZKSA307610233	21001241	CASING WEARING RING, COMA6000S00BA	1	EA	1,000.00	THB	NORMAL
2454	ZKSA307610243	21001243	CASING WEARING RING, COMA6000S00BA	1	EA	19,000.00	THB	NORMAL
2454	ZKSA307610253	21001243	CASING WEARING RING, COMA6000S00BA					

Part	Old material number	Material	Material Description	Stock Quantity	Base Unit of Measure	Stock Value	Currency	Valuation Type
				Period End	Measure	Period End		
2461	203A13700023	21000121	IMPELLER (BUCTION) TASK KSB PN. 230.01	2	EA	599.100	USD	NORMAL
2461	203A13700033	21000142	IMPELLER CASING TASK KSB PN. 230.02	2	EA	111.218.00	USD	NORMAL
2461	203A13700043	21000147	ANGULAR CONTACT BALL BEARING KSB PN. 320	2	EA	7.660.000	USD	NORMAL
2461	203A13700053	21000144	CYLINDRICAL ROLLER BEARING KSB PN. 322	3	EA	3.270.000	USD	NORMAL
2461	203A13700063	21000145	SET OF GASKET KSB PN. 411	1	EA	4.750.000	USD	NORMAL
2461	203A13700073	21000146	SET OF O-RING KSB PN. 412	1	EA	8.848.000	USD	NORMAL
2461	203A13700083	21000148	LAYBIRTHN SEAL KSB PN. 423.01	1	EA	1.748.000	USD	NORMAL
2461	203A13700093	21000148	MECHANICAL SEAL KSB PN. 423	1	EA	505.176.00	USD	NORMAL
2461	203A13700103	21000149	CASING WEARING KSB PN. 500.01	2	EA	80.000.00	USD	NORMAL
2461	203A13700113	21000150	CASING WEARING KSB PN. 500.02	5	EA	88.750.00	USD	NORMAL
2461	203A13700123	21000150	SPACER RING KSB PN. 504.01	2	EA	134.400.00	USD	NORMAL
2461	203A13700133	21000152	SPACER RING KSB PN. 502.02	2	EA	39.240.00	USD	NORMAL
2461	203A13700143	21000153	THROWER KSB PN. 507.01	3	EA	114.460.00	USD	NORMAL
2461	203A13700153	21000153	THROWING SLEEVE KSB PN. 520.01	3	EA	51.471.00	USD	NORMAL
2461	203A13700163	21000155	SHAFT SLEEVE KSB PN. 523.01	2	EA	113.296.00	USD	NORMAL
2461	203A13700173	21000157	SPACER SLEEVE KSB PN. 525.02	2	EA	5.587.000	USD	NORMAL
2461	203A13700183	21000157	BEARING SLEEVE KSB PN. 529.02	1	EA	4.650.000	USD	NORMAL
2461	203A13700193	21000157	BALANCE DISK KSB PN. 531.01	1	EA	114.740.00	USD	NORMAL
2461	203A13700203	21000159	BALANCE DISK BEAT KSB PN. 532.01	1	EA	294.100.00	USD	NORMAL
2461	203A13700213	21000161	LOCATOR KSB PN. 533.00	1	EA	87.000.00	USD	NORMAL
2461	203A13700223	21000161	CIRCUIT KSB PN. 533.04	1	EA	97.000.00	USD	NORMAL
2461	203A13700233	21000163	SPRING KSB PN. 550	4	EA	1.164.000	USD	NORMAL
2461	203A13700243	21000163	IMPELLER CASING TASK KSB PN. 230.01	1	EA	599.100.00	USD	NORMAL
2461	203A13700253	21000165	IMPELLER CASING TASK KSB PN. 230.02	2	EA	106.338.00	USD	NORMAL
2461	203A13700263	21000166	ANGULAR CONTACT BALL BEARING KSB PN. 320	2	EA	7.800.000	USD	NORMAL
2461	203A13700273	21000166	CYLINDRICAL ROLLER BEARING KSB PN. 322	1	EA	3.270.000	USD	NORMAL
2461	203A13700283	21000166	SET OF GASKET KSB PN. 411	1	EA	4.750.000	USD	NORMAL
2461	203A13700293	21000166	SET OF O-RING KSB PN. 412	1	EA	8.848.000	USD	NORMAL
2461	203A13700303	21000170	LAYBIRTHN SEAL KSB PN. 423.01	1	EA	1.748.000	USD	NORMAL
2461	203A13700313	21000170	MECHANICAL SEAL KSB PN. 423	1	EA	505.176.00	USD	NORMAL
2461	203A13700323	21000172	CASING WEARING KSB PN. 502.01	2	EA	88.858.00	USD	NORMAL
2461	203A13700333	21000172	CASING WEARING KSB PN. 502.02	5	EA	88.858.00	USD	NORMAL
2461	203A13700343	21000174	SPACER RING KSB PN. 504.01	1	EA	134.400.00	USD	NORMAL
2461	203A13700353	21000174	SPACER RING KSB PN. 502.02	1	EA	39.240.00	USD	NORMAL
2461	203A13700363	21000176	LOOSE COLLAR KSB PN. 505.01	1	EA	54.020.00	USD	NORMAL
2461	203A13700373	21000177	THROWER KSB PN. 507.01	3	EA	114.460.00	USD	NORMAL
2461	203A13700383	21000178	THROWING SLEEVE KSB PN. 520.01	3	EA	51.471.00	USD	NORMAL
2461	203A13700393	21000179	SHAFT SLEEVE KSB PN. 523.01	2	EA	113.296.00	USD	NORMAL
2461	203A13700403	21000181	SPACER SLEEVE KSB PN. 525.02	2				

Part	Old material number	Material	Material Description	Stock Quantity on Hand	Base Unit of Measure	Stock Value on Hand	Currency	Valuation Type
2451	ZKSA15730403	21001369	SET OF GASKET KSB PN 90.9	1	EA	1,450.00	USD	NORMAL
2451	ZKSA15730413	21001370	SHAFT SEAL HUBER KSB PN 421 01	1	EA	1,450.00	USD	NORMAL
2451	ZKSA15730422	21001371	SHAFT SEAL HUBER KSB PN 421 02	1	EA	1,450.00	USD	NORMAL
2451	ZKSA15730434	21001373	THROWER KSB PN 507 01	1	EA	1,067.00	USD	NORMAL
2451	ZKSA15730435	21001374	ANGULAR CONTACT BALL BEARINGSKN320 02	1	EA	1,450.00	USD	NORMAL
2451	ZKSA15730436	21001375	CYLINDRICAL ROLLER BEARING KSB 320 01	1	EA	1,790.00	USD	NORMAL
2451	ZKSA15730437	21001376	SHAFT SEAL HUBER KSB PN 421 03	1	EA	1,790.00	USD	NORMAL
2451	ZKSA15730438	21001377	SHAFT SEAL HUBER KSB PN 421 01	1	EA	1,552.00	USD	NORMAL
2451	ZKSA15730439	21001378	SHAFT SEAL HUBER KSB PN 421 02	1	EA	1,552.00	USD	NORMAL
2451	ZKSA15730440	21001379	MECHANICAL SEAL KSB PN 433	1	EA	21,900.00	USD	NORMAL
2451	ZKSA15730441	21001380	THROWER KSB PN 507	1	EA	1,368.00	USD	NORMAL
2451	ZKSA15730423	21001381	SHAFT PROTECTION SLEEVE KSB PN 524 01	1	EA	53,162.00	USD	NORMAL
2451	ZKSA15730443	21001382	SET OF GASKET KSB PN 400	1	EA	970.00	USD	NORMAL
2451	ZKSA15730444	21001383	SHAFT PROTECTION SLEEVE KSB PN 524	1	EA	1,432.00	USD	NORMAL
2451	ZKSA15730445	21001384	CASING WEAVER KSB PN 502 01	1	EA	7,091.00	USD	NORMAL
2451	ZKSA15730446	21001385	CONSTANT LEVEL, OIL KSB PN 538	1	EA	1,788.00	USD	NORMAL
2451	ZKSA15730447	21001386	GLAND PACKING KSB PN 451	1	EA	1,184.00	USD	NORMAL
2451	ZKSA15730448	21001387	PROTECTOR KSB PN 505	1	EA	1,744.00	USD	NORMAL
2451	ZKSA15730449	21001388	LANDER ROLLER KSB PN 468	1	EA	1,067.00	USD	NORMAL
2451	ZKSA15730463	21001389	GROOVED BALL BEARING KSB PN 321	1	EA	1,450.00	USD	NORMAL
2451	ZKSA15730411	21001390	1-ARMED KSB PN 412	1	EA	291.00	USD	NORMAL
2451	ZKSA15730421	21001391	ROTATING SHAFT 1" OF SEAL	1	EA	388.00	USD	NORMAL
2451	ZKSA15730433	21001392	MECHANICAL SEAL KSB PN 433	2	EA	60,116.00	USD	NORMAL
2451	ZKSA15730434	21001393	CASING 75X114 KSB PN 502	1	EA	1,450.00	USD	NORMAL
2451	ZKSA15730465	21001394	SPACER RING KSB PN 501	1	EA	18,324.00	USD	NORMAL
2451	ZKSA15730466	21001395	SPACER RING KSB PN 504	1	EA	38,472.00	USD	NORMAL
2451	ZKSA15730473	21001396	SPACER SLEEVE KSB PN 525 02	1	EA	16,387.00	USD	NORMAL
2451	ZKSA15730488	21001397	BEARING SLEEVE KSB PN 503 02	1	EA	1,790.00	USD	NORMAL
2451	ZKSA18800011	21001398	GASKET #400 01 PFPE 41024041	1	EA	1,450.00	USD	NORMAL
2452	ZKSA18800033	21001400	SHAFT SLEEVE FOR P-2310ABR	1	EA	8,800.00	USD	SURPLUS
2452	ZKSA18800055	21001401	WEAR RING #001 PFPE 41024041	1	EA	1,450.00	USD	NORMAL
2452	ZKSA18801013	21001402	GASKET #400 01 PFPE 21024041	3	EA	2,222.00	USD	NORMAL
2452	ZKSA18801033	21001403	WEAR RING #002 PFPE 21024041	1	EA	1,722.00	USD	NORMAL
2452	ZKSA18801043	21001404	SHAFT WITH KEVLAIR TITANIUM #184042	1	EA	69,844.00	USD	NORMAL
2452	ZKSA18801052	21001405	SHAFT WITH KEVLAIR TITANIUM #184042	1	EA	69,844.00	USD	NORMAL
2452	ZKSA18801073	21001407	BALANCE GRINDER 067 00 P-23601 ABR	1	EA	199,062.67	USD	NORMAL
2452	ZKSA18801088	21001408	REPAIR KIT FOR P-23601 ABR	2	SET	108,102.00	USD	NORMAL
2452	ZKSA18801093	21001409	REPAIR KIT FOR P-23602 ABR	2	SET	115,110.00	USD	NORMAL
2452	ZKSA18801103	21001410	GASKET FOR P-23601ABR	1	SET	0.00	USD	NORMAL
2452	ZKSA18801029	21001411	REPAIR KIT FOR P-23602 ABR	1	EA	18,742.00	USD	NORMAL
2452	ZKSA18802033	21001412	SHAFT SLEEVE FOR P-23601ABR	1</				

Plant	Old material number	Material	Material Description	Stock Quantity on Hand	Stock Qty on Order	Base Unit of Measure	Stock Value on Hand	Currency	Valuation Type	Plant	Old material number	Material	Material Description	Stock Quantity on Hand	Stock Qty on Order	Base Unit of Measure	Stock Value on Hand	Currency	Valuation Type							
2451	20A432621003	210001650	GASKET CASING FOR P-185SAR	4	EA	5.422 14	THB	NORMAL	2451	20A43272003	210001650	MODULE PN INR-24BR	1	EA	114.553 59	THB	NORMAL	2451	20A43272003	210001650	MODULE PN INR-24BR	1	EA	114.553 59	THB	NORMAL
2451	20A432621004	210001651	110 SUPPLY VALVE 1/2" NPT	1	EA	114.553 59	THB	NORMAL	2451	20A43272004	210001651	110 SUPPLY CENTER VALVE	1	EA	114.553 59	THB	NORMAL	2451	20A43272004	210001651	110 SUPPLY CENTER VALVE	1	EA	114.553 59	THB	NORMAL
2451	20A432621005	210001652	MECH SEAL SPARE KIT PN 360274	8	EA	13.183 50	THB	NORMAL	2451	20A43272005	210001652	PACKING PUMP OUTER SET	1	EA	114.553 59	THB	NORMAL	2451	20A43272005	210001652	PACKING PUMP OUTER SET	1	EA	114.553 59	THB	NORMAL
2451	20A432621006	210001653	MECH SEAL SPARE KIT PN 360275	4	EA	24.215	THB	NORMAL	2451	20A43272006	210001653	ITEM BUSH FOR 360275	1	EA	31.275 38	THB	NORMAL	2451	20A43272006	210001653	ITEM BUSH FOR 360275	1	EA	31.275 38	THB	NORMAL
2451	20A432621007	210001654	MECH SEAL SPARE KIT PN 68838	6	EA	15.045 00	THB	NORMAL	2451	20A43272007	210001654	PLUG PN INR-360275	1	EA	73.028 79	THB	NORMAL	2451	20A43272007	210001654	PLUG PN INR-360275	1	EA	73.028 79	THB	NORMAL
2451	20A432621008	210001655	MECH SEAL SPARE KIT PN 4R0434	6	EA	2.225 00	THB	NORMAL	2451	20A43272008	210001655	PRING SEAL 360275 (IN 11)	1	EA	27.776 19	THB	NORMAL	2451	20A43272008	210001655	PRING SEAL 360275 (IN 11)	1	EA	27.776 19	THB	NORMAL
2451	20A432621009	210001656	MECH SEAL SPARE KIT PN 360275	3	EA	6.395 00	THB	NORMAL	2451	20A43272009	210001656	REPAIR KIT PN 768-100	1	SET	268.186 78	THB	NORMAL	2451	20A43272009	210001656	REPAIR KIT PN 768-100	1	SET	268.186 78	THB	NORMAL
2451	20A432621010	210001657	COMPLETE VALVE MODEL 3A125-45-C	1	EA	8.995 00	THB	NORMAL	2451	20A43272010	210001657	STEERING ASSEMBLY PN 14431	1	EA	85.125 38	THB	NORMAL	2451	20A43272010	210001657	STEERING ASSEMBLY PN 14431	1	EA	85.125 38	THB	NORMAL
2451	20A432621011	210001658	COMPLETE VALVE MODEL 39A-45-3-E	1	EA	701.100 00	THB	NORMAL	2451	20A43272011	210001658	STEERING WASHER PN 14431	1	EA	24.815 83	THB	NORMAL	2451	20A43272011	210001658	STEERING WASHER PN 14431	1	EA	24.815 83	THB	NORMAL
2451	20A432621012	210001659	CRIMPER SET GASKET 353160	1	EA	17.880 27	THB	NORMAL	2451	20A43272012	210001659	STEM ASSEMBLY PN 10747-02	1	EA	96.481 27	THB	NORMAL	2451	20A43272012	210001659	STEM ASSEMBLY PN 10747-02	1	EA	96.481 27	THB	NORMAL
2451	20A432621013	210001660	DRIVE SHAFT COUPLING FOR COUPLING TOWLE	1	EA	230.000 00	THB	NORMAL	2451	20A43272013	210001660	ITEM BUSH FOR 360275	1	EA	31.275 38	THB	NORMAL	2451	20A43272013	210001660	ITEM BUSH FOR 360275	1	EA	31.275 38	THB	NORMAL
2451	20A432621014	210001661	DRIVE SHAFT COUPLING FOR COUPLING TOWLE	1	EA	230.000 00	THB	NORMAL	2451	20A43272014	210001661	ITEM BUSH FOR 360275	1	EA	31.275 38	THB	NORMAL	2451	20A43272014	210001661	ITEM BUSH FOR 360275	1	EA	31.275 38	THB	NORMAL
2451	20A432621015	210001662	SET OF CUTTERS CPL, ITAG	1	SET	29.017 08	THB	NORMAL	2451	20A43272015	210001662	GASKET SET CASING LINE 68071	1	EA	76.908 05	THB	NORMAL	2451	20A43272015	210001662	GASKET SET CASING LINE 68071	1	EA	76.908 05	THB	NORMAL
2451	20A432621016	210001663	360275 PUMP SET	1	SET	35.011 07	THB	NORMAL	2451	20A43272016	210001663	PLATES 360275 PUMP SET 360275	1	SET	60.805 00	THB	NORMAL	2451	20A43272016	210001663	PLATES 360275 PUMP SET 360275	1	SET	60.805 00	THB	NORMAL
2451	20A432621017	210001664	RAKE RIGHT, ITAG	1	SET	33.511 02	THB	NORMAL	2451	20A43272017	210001664	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272017	210001664	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621018	210001665	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272018	210001665	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272018	210001665	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621019	210001666	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272019	210001666	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272019	210001666	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621020	210001667	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272020	210001667	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272020	210001667	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621021	210001668	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272021	210001668	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272021	210001668	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621022	210001669	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272022	210001669	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272022	210001669	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621023	210001670	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272023	210001670	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272023	210001670	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621024	210001671	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272024	210001671	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272024	210001671	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621025	210001672	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272025	210001672	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272025	210001672	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621026	210001673	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272026	210001673	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272026	210001673	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621027	210001674	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272027	210001674	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272027	210001674	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621028	210001675	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272028	210001675	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272028	210001675	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621029	210001676	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272029	210001676	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272029	210001676	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621030	210001677	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272030	210001677	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272030	210001677	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621031	210001678	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272031	210001678	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272031	210001678	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621032	210001679	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272032	210001679	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272032	210001679	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621033	210001680	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272033	210001680	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272033	210001680	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621034	210001681	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272034	210001681	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272034	210001681	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621035	210001682	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272035	210001682	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272035	210001682	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621036	210001683	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272036	210001683	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272036	210001683	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621037	210001684	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272037	210001684	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272037	210001684	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621038	210001685	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272038	210001685	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272038	210001685	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621039	210001686	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272039	210001686	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272039	210001686	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621040	210001687	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272040	210001687	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272040	210001687	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621041	210001688	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272041	210001688	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272041	210001688	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621042	210001689	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272042	210001689	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272042	210001689	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621043	210001690	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272043	210001690	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL	2451	20A43272043	210001690	10% OF SPRAY NOZZLE 68071	1	EA	5.500 00	THB	NORMAL
2451	20A432621044	210001691	WEARING PLATE, KOTO KOUKI	1	SET	1.372 205 84	THB	NORMAL	2451	20A43272044																

Plant	Old material number	Material	Material Description
2452	ZSA-059530003	21000200	PLUG/STEM RING IN, 50.16 IN, PLUG 4016
2452	ZSA-059530043	21000201	PLUG/STEM RING IN, 50.16 IN, PLUG 4016
2452	ZSA-059530054	21000202	PLUG/STEM RING IN, 50.16 IN, PLUG 4016
2452	ZSA-059530065	21000203	SEAT KEY, 6 P.N. KEY-00001-61
2452	ZSA-059530076	21000204	SEAT KEY, 6 P.N. KEY-00001-61
2452	ZSA-059530087	21000205	STEM PACKING, 100 IN, 1001-0001-00
2452	ZSA-059530098	21000206	STEM PACKING, 100 IN, 1001-0001-00
2452	ZSA-059530109	21000207	STEM PACKING, 100 IN, 1001-0001-00
2452	ZSA-059530120	21000208	STEM PACKING, 100 IN, 1001-0001-00
2452	ZSA-059530131	21000209	STEM PACKING, 100 IN, 1001-0001-00
2452	ZSA-059530142	21000210	ACTUATOR BOP CONTROL, 2000T, 500T-1
2452	ZSA-059530153	21000211	ACTUATOR BOP CONTROL, 2000T, 500T-1
2452	ZSA-059530164	21000212	GASKET VORTICE, 16.08 IN, 35K-6K
2452	ZSA-059530175	21000213	GASKET VORTICE, 16.08 IN, 35K-6K
2452	ZSA-059530186	21000214	GASKET VORTICE, 16.08 IN, 35K-6K
2452	ZSA-059530197	21000215	GASKET VORTICE, 16.08 IN, 35K-6K
2452	ZSA-059530208	21000216	GASKET VORTICE, 16.08 IN, 35K-6K
2452	ZSA-059530219	21000217	LIFTING TIE, 16.08 IN, 35K-6K
2452	ZSA-059530230	21000218	LIFTING TIE, 16.08 IN, 35K-6K
2452	ZSA-059530241	21000219	BOOY SEAT FOR CONTROL VALVE
2452	ZSA-059530252	21000220	ACTUATOR BOP CONTROL, 2000T, 500T-1
2452	ZSA-059530263	21000223	CAGE GASKET, 21.41 X 50.8 IN, 59-63
2452	ZSA-059530274	21000224	CAGE GASKET, 21.41 X 50.8 IN, 59-63
2452	ZSA-059530285	21000225	CAGE GASKET, 21.41 X 50.8 IN, 59-63
2452	ZSA-059530296	21000226	CAGE GASKET, 21.41 X 50.8 IN, 59-63
2452	ZSA-059530307	21000227	DIAPHRAGM, 10.08 IN, 50.03-53 DVO3
2452	ZSA-059530318	21000228	DIAPHRAGM, 10.08 IN, 50.03-53 DVO3
2452	ZSA-059530329	21000229	DIAPHRAGM, 10.08 IN, 50.03-53 DVO3
2452	ZSA-059530340	21000230	DIAPHRAGM, 10.08 IN, 50.03-53 DVO3
2452	ZSA-059530351	21000231	DIAPHRAGM, 10.08 IN, 50.03-53 DVO3
2452	ZSA-059530362	21000232	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530373	21000233	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530384	21000234	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530395	21000235	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530406	21000236	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530417	21000237	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530428	21000238	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530439	21000239	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530450	21000240	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530461	21000241	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530472	21000242	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530483	21000243	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530494	21000244	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530505	21000245	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530516	21000246	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530527	21000247	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530538	21000248	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530549	21000249	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530560	21000250	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530571	21000251	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530582	21000252	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530593	21000253	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530604	21000254	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530615	21000255	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530626	21000256	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530637	21000257	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530648	21000258	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530659	21000259	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530670	21000260	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530681	21000261	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530692	21000262	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530703	21000263	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530714	21000264	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530725	21000265	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530736	21000266	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530747	21000267	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530758	21000268	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530769	21000269	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530780	21000270	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530791	21000271	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530802	21000272	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530813	21000273	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530824	21000274	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530835	21000275	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530846	21000276	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530857	21000277	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530868	21000278	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530879	21000279	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530890	21000280	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530901	21000281	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530912	21000282	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530923	21000283	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530934	21000284	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530945	21000285	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530956	21000286	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530967	21000287	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530978	21000288	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059530989	21000289	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531000	21000290	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531011	21000291	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531022	21000292	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531033	21000293	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531044	21000294	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531055	21000295	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531066	21000296	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531077	21000297	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531088	21000298	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531099	21000299	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531110	21000300	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531121	21000301	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531132	21000302	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531143	21000303	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531154	21000304	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531165	21000305	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531176	21000306	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531187	21000307	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531198	21000308	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531209	21000309	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531220	21000310	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531231	21000311	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531242	21000312	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531253	21000313	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531264	21000314	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531275	21000315	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531286	21000316	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531297	21000317	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531308	21000318	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531319	21000319	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531330	21000320	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531341	21000321	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531352	21000322	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531363	21000323	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531374	21000324	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531385	21000325	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531396	21000326	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531407	21000327	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531418	21000328	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531429	21000329	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531440	21000330	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531451	21000331	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531462	21000332	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531473	21000333	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531484	21000334	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531495	21000335	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531506	21000336	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531517	21000337	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531528	21000338	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531539	21000339	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531550	21000340	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531561	21000341	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531572	21000342	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531583	21000343	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531594	21000344	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531605	21000345	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531616	21000346	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531627	21000347	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531638	21000348	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531649	21000349	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531660	21000350	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531671	21000351	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531682	21000352	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531693	21000353	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531704	21000354	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531715	21000355	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531726	21000356	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531737	21000357	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531748	21000358	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531759	21000359	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531770	21000360	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531781	21000361	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531792	21000362	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531803	21000363	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531814	21000364	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531825	21000365	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531836	21000366	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531847	21000367	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531858	21000368	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531869	21000369	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531880	21000370	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531891	21000371	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531902	21000372	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531913	21000373	GASKET BODY, 40.00 X 47.75 IN, 60-68
2452	ZSA-059531924	21000374	GASKET BODY, 4

[illegible]

Plant	Old material number	Material	Material Description	Stock Quantity on Period End	Base Unit of Measure	Stock Value on Period End	Currency	Valuation Type
2451	ZDA54828283	21000713	PLUG ITEM PN 20052638-1630000	1	EA	41,800.00	THB	NORMAL
2451	ZDA54828284	21000714	PLUG ITEM PN 20701241-1630000	1	EA	1,900.00	THB	NORMAL
2451	ZDA54828285	21000715	PLUG ITEM PN 17142013-1630000	1	EA	1,800.00	THB	NORMAL
2451	ZDA54828286	21000716	BODY GASKET PN 16300000-1630000	1	EA	1,710.00	THB	NORMAL
2451	ZDA54828287	21000717	CRIMP PIN PN 17886112-4800000-PV.31	1	EA	2,140.00	THB	NORMAL
2451	ZDA54828288	21000718	CRIMP PIN PN 17886112-4800000-PV.31	1	EA	2,140.00	THB	NORMAL
2451	ZDA54828289	21000719	DIAPHRAGM PN 01086003-779-8130-LV.2326	1	EA	8,750.00	THB	NORMAL
2451	ZDA54828290	21000720	SEAL WASHER PN1703801-4880000-PV.31	1	EA	1,370.00	THB	NORMAL
2451	ZDA54828291	21000721	STEM WIPER PN1703101-789-8130-LV.2326	1	EA	1,730.00	THB	NORMAL
2451	ZDA54828292	21000722	SEAL RING PN 21000325-1630000	1	EA	16,500.00	THB	NORMAL
2451	ZDA54828293	21000723	PLUG PN 20052638-1630000-PV.31	1	EA	1,900.00	THB	NORMAL
2451	ZDA54828294	21000724	PLUG ITEM PN 20701241-1630000-PV.31	1	EA	1,900.00	THB	NORMAL
2451	ZDA54828295	21000725	PLUG ITEM PN 17142013-1630000-PV.31	1	EA	1,800.00	THB	NORMAL
2451	ZDA54828296	21000726	PLUG ITEM PN 17142013-1630000-PV.31	1	EA	1,800.00	THB	NORMAL
2451	ZDA54828297	21000727	BOY GASKET PN40116956-826-000-LV.2326	1	EA	9,150.00	THB	NORMAL
2451	ZDA54828298	21000728	CRIMP PIN PN17886112-488-000-LV.2326	1	EA	2,140.00	THB	NORMAL
2451	ZDA54828299	21000729	CRIMP PIN PN17886112-488-000-LV.2326	1	EA	2,140.00	THB	NORMAL
2451	ZDA54828300	21000730	CRIMP PIN PN17886112-488-000-LV.2326	1	EA	2,140.00	THB	NORMAL
2451	ZDA54828301	21000731	DIAPHRAGM PN 01086003-779-8130-LV.2326	1	EA	29,240.00	THB	NORMAL
2451	ZDA54828302	21000732	BEARING RING PN20052638-1630000-PV.31	1	EA	8,500.00	THB	NORMAL
2451	ZDA54828303	21000733	CAGE GASKET PN40116956-826-000-LV.2326	1	EA	8,000.00	THB	NORMAL
2451	ZDA54828304	21000734	SEAL WASHER PN1703801-488-000-LV.2326	1	EA	1,370.00	THB	NORMAL
2451	ZDA54828305	21000735	STEM WIPER PN1703101-789-8130-LV.2326	1	EA	1,730.00	THB	NORMAL
2451	ZDA54828306	21000736	PACKING BOTTOM R. PN.20050026-1630000	1	EA	16,500.00	THB	NORMAL
2451	ZDA54828307	21000737	PACKING GLAND PN.20050026-1630000	1	EA	16,500.00	THB	NORMAL
2451	ZDA54828308	21000738	SEAL RING PN40116956-826-000-LV.2326	1	EA	418,810.15	THB	NORMAL
2451	ZDA54828309	21000739	CAGE PIN PN 21000325-1630000	1	EA	418,810.15	THB	NORMAL
2451	ZDA54828310	21000740	PLUG PN 21000325-1630000-LV.2326	1	EA	1,930.00	THB	NORMAL
2451	ZDA54828311	21000741	PLUG ITEM PN17142013-1630000-LV.2326	1	EA	1,810.00	THB	NORMAL
2451	ZDA54828312	21000742	PLUG ITEM PN17142013-1630000-LV.2326	1	EA	1,810.00	THB	NORMAL
2451	ZDA54828313	21000743	BOY GASKET PN40116956-826-000-LV.2326	1	EA	9,150.00	THB	NORMAL
2451	ZDA54828314	21000744	CRIMP PIN PN17886112-488-000-LV.2326	1	EA	2,140.00	THB	NORMAL
2451	ZDA54828315	21000745	CRIMP PIN PN17886112-488-000-LV.2326	1	EA	2,140.00	THB	NORMAL
2451	ZDA54828316	21000746	CRIMP PIN PN17886112-488-000-LV.2326	1	EA	2,140.00	THB	NORMAL
2451	ZDA54828317	21000747	DIAPHRAGM PN01086003-779-8130-LV.2326	1	EA	29,240.00	THB	NORMAL
2451	ZDA54828318	21000748	TEC SEAL RING PN4008810-946-000-LV.2326	1	EA	44,500.00	THB	NORMAL
2451	ZDA54828319	21000749	BOY GASKET PN40116956-826-000-LV.2326	1	EA	9,150.00	THB	NORMAL
2451	ZDA54828320	21000750	SEAL WASHER PN1703801-488-000-LV.2326	1	EA	1,370.00	THB	NORMAL
2451	ZDA54828321	21000751	STEM WIPER PN1703101-789-8130-LV.2326	1	EA	1,730.00	THB	NORMAL
2451	ZDA54828322	21000752	PACKING BOTTOM R. PN.20050026-1630000	1	EA	16,500.00	THB	NORMAL
2451	ZDA54828323	21000753	PACKING GLAND PN.20050026-1630000	1	EA	16,500.00	THB	NORMAL
2451	ZDA54828324	21000754	SEAL RING PN40116956-826-000-LV.2326	1	EA	418,810.15	THB	NORMAL
2451	ZDA54828325	21000755	CAGE PIN PN 21000325-1630000	1	EA	418,810.15	THB	NORMAL
2451	ZDA54828326	21000756	PLUG PN 21000325-1630000-LV.2326	1	EA	1,930.00	THB	NORMAL
2451	ZDA54828327	21000757	PLUG ITEM PN17142013-1630000-LV.2326	1	EA	1,810.00	THB	NORMAL
2451	ZDA54828328	21000758	PLUG ITEM PN17142013-1630000-LV.2326	1	EA	1,810.00	THB	NORMAL
2451	ZDA54828329	21000759	BOY GASKET PN40116956-826-000-LV.2326	1	EA	9,150.00	THB	NORMAL
2451	ZDA54828330	21000760	CRIMP PIN PN17886112-488-000-LV.2326	1	EA	2,140.00	THB	NORMAL
2451	ZDA54828331	21000761	CRIMP PIN PN17886112-488-000-LV.2326	1	EA	2,140.00	THB	NORMAL
2451	ZDA54828332	21000762	CRIMP PIN PN17886112-488-000-LV.2326	1	EA	2,140.00	THB	NORMAL
2451	ZDA54828333	21000763	DIAPHRAGM PN 01086003-779-8130-LV.2326	1	EA	2,900.00	THB	NORMAL
2451	ZDA54828334	21000764	TEC SEAL RING PN4008810-946-000-LV.2326	1	EA	44,500.00	THB	NORMAL
2451	ZDA54828335	21000765	CAGE GASKET PN40116956-826-000-LV.2326	1	EA	8,000.00	THB	NORMAL
2451	ZDA54828336	21000766	SEAL WASHER PN1703801-488-000-LV.2326	1	EA	1,370.00	THB	NORMAL
2451	ZDA54828337	21000767	STEM WIPER PN1703101-789-8130-LV.2326	1	EA	1,730.00	THB	NORMAL
2451	ZDA54828338	21000768	PACKING BOTTOM R. PN.20050026-1630000	1	EA	16,500.00	THB	NORMAL
2451	ZDA54828339	21000769	PACKING GLAND PN.20050026-1630000	1	EA	16,500.00	THB	NORMAL
2451	ZDA54828340	21000770	SEAL RING PN40116956-826-000-LV.2326	1	EA	418,810.15	THB	NORMAL
2451	ZDA54828341	21000771	CAGE PIN PN 21000325-1630000	1	EA	418,810.15	THB	NORMAL
2451	ZDA54828342	21000772	PLUG PN 21000325-1630000-LV.2326	1	EA	1,930.00	THB	NORMAL
2451	ZDA54828343	21000773	PLUG ITEM PN17142013-1630000-LV.2326	1	EA	1,810.00	THB	NORMAL
2451	ZDA54828344	21000774	PLUG ITEM PN17142013-1630000-LV.2326	1	EA	1,810.00	THB	NORMAL
2451	ZDA54828345	21000775	BOY GASKET PN40116956-826-000-LV.2326	1	EA	9,150.00	THB	NORMAL
2451	ZDA54828346	21000776	CRIMP PIN PN17886112-488-000-LV.2326	1	EA	2,140.00	THB	NORMAL
2451	ZDA54828347	21000777	CRIMP PIN PN17886112-488-000-LV.2326	1	EA	2,140.00	THB	NORMAL
2451	ZDA54828348	21000778	CRIMP PIN PN17886112-488-000-LV.2326	1	EA	2,140.00	THB	NORMAL
2451	ZDA54828349	21000779	DIAPHRAGM PN 01086003-779-8130-LV.2326	1	EA	2,900.00	THB	NORMAL
2451	ZDA54828350	21000780	TEC SEAL RING PN4008810-946-000-LV.2326	1	EA	44,500.00	THB	NORMAL
2451	ZDA54828351	21000781	CAGE GASKET PN40116956-826-000-LV.2326	1	EA	8,000.00	THB	NORMAL
2451	ZDA54828352	21000782	PACKING BOTTOM R. PN.20050026-1630000	1	EA	16,500.00	THB	NORMAL
2451	ZDA54828353	21000783	PACKING GLAND PN.20050026-1630000	1	EA	16,500.00	THB	NORMAL
2451	ZDA54828354	21000784	SEAL RING PN40116956-826-000-LV.2326	1	EA	418,810.15	THB	NORMAL
2451	ZDA54828355	21000785	CAGE PIN PN 21000325-1630000	1	EA	418,810.15	THB	NORMAL
2451	ZDA54828356	21000786	PLUG PN 21000325-1630000-LV.2326	1	EA	1,930.00	THB	NORMAL
2451	ZDA54828357	21000787	PLUG ITEM PN17142013-1630000-LV.2326	1	EA	1,810.00	THB	NORMAL
2451	ZDA54828358	21000788	PLUG ITEM PN17142013-1630000-LV.2326	1	EA	1,810.00	THB	NORMAL
2451	ZDA54828359	21000789	BOY GASKET PN40116956-826-000-LV.2326	1	EA	9,150.00	THB	NORMAL
2451	ZDA54828360	21000790	CRIMP PIN PN17886112-488-000-LV.2326	1	EA	2,140.00	THB	NORMAL
2451	ZDA54828361	21000791	CRIMP PIN PN17886112-488-000-LV.2326	1	EA	2,140.00	THB	NORMAL
2451	ZDA54828362	21000792	CRIMP PIN PN17886112-488-000-LV.2326	1	EA	2,140.00	THB	NORMAL
2451	ZDA54828363	21000793	DIAPHRAGM PN 01086003-779-8130-LV.2326	1	EA	2,900.00	THB	NORMAL
2451	ZDA54828364	21000794	TEC SEAL RING PN4008810-946-000-LV.2326	1	EA	44,500.00	THB	NORMAL
2451	ZDA54828365	21000795	CAGE GASKET PN40116956-826-000-LV.2326	1	EA	8,000.00	THB	NORMAL
2451	ZDA54828366	21000796	SEAL WASHER PN1703801-488-000-LV.2326	1	EA	1,370.00	THB	NORMAL
2451	ZDA54828367	21000797	STEM WIPER PN1703101-789-8130-LV.2326	1	EA	1,730.00	THB	NORMAL
2451	ZDA54828368	21000798	PACKING BOTTOM R. PN.20050026-1630000	1	EA	16,500.00	THB	NORMAL
2451	ZDA54828369	21000799	PACKING GLAND PN.20050026-1630000	1	EA	16,500.00	THB	NORMAL
2451	ZDA54828370	21000800	SEAL RING PN40116956-826-000-LV.2326	1	EA	418,810.15	THB	NORMAL
2451	ZDA54828371	21000801	CAGE PIN PN 21000325-1630000	1	EA	418,810.15	THB	NORMAL
2451	ZDA54828372	21000802	PACKING PN.20050026-1630000-PV.31	1	EA	9,150.00	THB	NORMAL
2451	ZDA54828373	21000803	CAGE PIN PN 21000325-1630000	1	EA	9,150.00	THB	NORMAL
2451	ZDA54828374	21000804	PLUG PN 21000325-1630000-LV.2326	1	EA	1,930.00	THB	NORMAL
2451	ZDA54828375	21000805	PLUG ITEM PN17142013-1630000-LV.2326	1	EA	1,810.00	THB	NORMAL
2451	ZDA54828376	21000806	PLUG ITEM PN17142013-1630000-LV.2326	1	EA	1,810.00	THB	NORMAL
2451	ZDA54828377	21000807	BOY GASKET PN40116956-826-000-LV.2326	1	EA	9,150.00	THB	NORMAL
2451	ZDA54828378	21000808	CRIMP PIN PN17886112-488-000-LV.2326	1	EA	2,140.00	THB	NORMAL
2451	ZDA54828379	21000809	CRIMP PIN PN17886112-488-000-LV.2326	1	EA	2,140.00	THB	NORMAL
2451	ZDA54828380	21000810	CRIMP PIN PN17886112-488-000-LV.2326	1	EA	2,140.00	THB	NORMAL
2451	ZDA54828381	21000811	DIAPHRAGM PN 01086003-779-8130-LV.2326	1	EA	2,900.00	THB	NORMAL
2451	ZDA54828382	21000812	PACKING PN.20050026-1630000-PV.31	1	EA	9,150.00	THB	NORMAL
2451	ZDA54828383	21000813	TEC SEAL RING PN4008810-946-000-LV.2326	1	EA	44,500.00	THB	NORMAL
2451	ZDA54828384	21000814	CAGE GASKET PN40116956-826-000-LV.2326	1	EA	8,000.00	THB	NORMAL
2451	ZDA54828385	21000815	PACKING BOTTOM R. PN.20050026-1630000	1	EA	16,500.00	THB	NORMAL
2451	ZDA54828386	21000816	PACKING GLAND PN.20050026-1630000	1	EA	16,500.00	THB	NORMAL
2451	ZDA54828387	21000817	SEAL RING PN40116956-826-000-LV.2326	1	EA	418,810.15	THB	NORMAL
2451	ZDA54828388	21000818	CAGE PIN PN 21000325-1630000	1	EA	418,810.15	THB	NORMAL
2451	ZDA54828389	21000819	PLUG PN 21000325-1630000-LV.2326	1	EA	1,930.00	THB	NORMAL
2451	ZDA54828390	21000820	PLUG ITEM PN17142013-1630000-LV.2326	1	EA	1,810.00	THB	NORMAL
2451	ZDA54828391	21000821	PLUG ITEM PN17142013-1630000-LV.2326	1	EA	1,810.00	THB	NORMAL
2451	ZDA54828392	21000822	BOY GASKET PN40116956-826-000-LV.2326	1	EA	9,150.00	THB	NORMAL
2451	ZDA54828393	21000823	CRIMP PIN PN17886112-488-000-LV.2326	1	EA	2,140.00	THB</	

[illegible]

Part	Old material number	Material	Description	Stock Quantity on Hand	Period End	Measure	Unit Price	Stock Value on Hand	Period End	Currency	Valuation Type
2451	2040012009	20400119	S-VALVE MANU.OLIVIERI PN 1/35S-558	1	11	EA	170.00	170.00	11	THB	NORMAL
2451	20400100000	20400040	TYCO MODEL RM2 JPN 62-306-2-01	7	EA	EA	141.8814	993.07	THB	NORMAL	
2451	20400000000	20400000	BEARING BALL BEARING BALL 25X40X8	2	EA	EA	379.25	758.50	THB	NORMAL	
2451	20400000000	20400022	BEARING BALL BEARING BALL 25X30X5	2	EA	EA	690.00	1,380.00	THB	NORMAL	
2451	20400000000	20400004	BEARING BALL BEARING BALL 25X30X5	2	EA	EA	770.991	1,541.98	THB	NORMAL	
2451	20400000000	20400004	BEARING BALL BEARING BALL 25X30X5	2	EA	EA	872.362	1,744.72	THB	NORMAL	
2451	20400000000	20400028	EXTERIOR SHUNT SEAL BEARING BALL 25X30X5	1	EA	EA	169.0000	169.00	THB	NORMAL	
2451	20400000000	20400028	HEATER IN MOTOR PUMP 30MM 800	1	EA	EA	1,037.50	1,037.50	THB	NORMAL	
2451	20400000000	20400028	MOTOR AND PUMP PUMP KIT 21X1016-EP	1	EA	EA	548.0000	548.00	THB	NORMAL	
2451	20400000000	20400028	SHUNT FUSE IN MOTOR 30MM 800	1	EA	EA	1,037.50	1,037.50	THB	NORMAL	
2451	20400000000	20400030	WATER LEAKAGE DET. KYT 21X1016-EP	1	EA	EA	1,960.0000	1,960.00	THB	NORMAL	
2451	20400000000	20400030	SHUNT FUSE IN MOTOR 30MM 800	1	EA	EA	1,037.50	1,037.50	THB	NORMAL	
2451	20400000000	20400034	BEARING SHELL NUT 30MM 800	1	EA	EA	498.0000	498.00	THB	NORMAL	
2451	20400000000	20400034	BEARING SHELL NUT 30MM 800	1	EA	EA	498.0000	498.00	THB	NORMAL	
2451	20400000000	20400036	BEARING SHELL NUT 30MM 800	1	EA	EA	624.0000	624.00	THB	NORMAL	
2451	20400000000	20400036	BUSHING BALL BEARING BALL 25X30X5	1	EA	EA	0.00	0.00	THB	NORMAL	
2451	20400000000	20400039	BUSHING BALL BEARING BALL 25X30X5	1	EA	EA	0.00	0.00	THB	SUPPLIES	
2451	20400000000	20400039	BUSHING BALL BEARING BALL 25X30X5	1	EA	EA	0.00	0.00	THB	NORMAL	
2451	20400000000	20400041	GASKET O-RING DIA 10MM	1	EA	EA	5.9968	5.9968	THB	NORMAL	
2451	20400000000	20400041	BUSHING BALL BEARING BALL 25X30X5	1	EA	EA	0.00	0.00	THB	NORMAL	
2451	20400000000	20400046	INDICATING THERMISTOR TYPE 304S15-015	1	EA	EA	22.884	22.884	THB	NORMAL	
2451	20400000000	20400047	COMPLETE SET GASKET FOR LAMP TRANSFORMER	1	EA	EA	40.0000	40.00	THB	NORMAL	
2451	20400000000	20400047	COILING AIR FAN OF BURRO 250V 250W	1	EA	EA	129.0000	129.00	THB	NORMAL	
2451	20400000000	20400047	GASKET FOR AIR TRANSFORMER 2000 KVA	1	EA	EA	13.7300	13.73	THB	NORMAL	
2451	20400000000	20400049	BUSHING BALL BEARING BALL 25X30X5	1	EA	EA	19.814	19.814	THB	NORMAL	
2451	20400000000	20400049	BUSHING BALL BEARING BALL 25X30X5	1	EA	EA	18.4000	18.40	THB	NORMAL	
2451	20400000000	20400051	INDICATING THERMISTOR TYPE 304S15-015	1	EA	EA	22.884	22.884	THB	NORMAL	
2451	20400000000	20400053	VFD ALLEN BRADLEY PN 20A02003A-VNANO	1	EA	EA	140.0000	140.00	THB	NORMAL	
2451	20400000000	20400053	VFD ALLEN BRADLEY PN 20A02003A-VNANO	1	EA	EA	140.0000	140.00	THB	NORMAL	
2451	20400000000	20400055	SHUT OFF VALVE FOR BUCHHEIM 2000-2000	2	EA	EA	15.0000	30.00	THB	NORMAL	
2451	20400000000	20400055	SHUT OFF VALVE FOR BUCHHEIM 2000-2000	2	EA	EA	15.0000	30.00	THB	NORMAL	
2451	20400000000	20400055	SHUT OFF VALVE FOR BUCHHEIM 2000-2000	2	EA	EA	15.0000	30.00	THB	NORMAL	
2451	20400000000	20400057	OL THERMISTOR RESISTOR MODEL ST-01608K	2	EA	EA	104.0000	208.00	THB	NORMAL	
2451	20400000000	20400059	MOTOR MOTOR 30MM 800	1	EA	EA	22.0000	22	THB	NORMAL	
2451	20400000000	20400059	MOTOR MOTOR 30MM 800	1	EA	EA	22.0000	22	THB	NORMAL	
2451	20400000000	20400060	MOTOR MOTOR 30MM 800	1	EA	EA	77.0000	77	THB	NORMAL	
2451	20400000000	20400061	SEAL RING FOR MOTOR 30MM 800	4	EA	EA	1.75	7	THB	NORMAL	
2451	20400000000	20400062	SEAL RING FOR MOTOR 30MM 800	5	EA	EA	7.6200	38.1	THB	NORMAL	
2451	20400000000	20400064	ALIAS COPICO FAN RADIATOR 100MM	1	EA	EA	1.75	1.75	THB	NORMAL	
2451	20400000000	20400066	VCE ABN VOA 3150A FOR MOTOR 30MM 800	1	EA	EA	1,069.5000	1,069.50	THB	NORMAL	
2451	20400000000	20400066	MC ACNENI 200-2000	1	EA	EA	1,069.5000	1,069.50	THB	NORMAL	
2451	20400000000	20400068	MC ACNENI 200-2000	1	EA	EA	1,000.0000	1,000.00	THB	NORMAL	
2451	20400000000	20400068	MC ACNENI 200-2000	1	EA	EA	1,000.0000	1,000.00	THB	NORMAL	
2451	20400000000	20400070	VACUUM CIRCUIT BREAKER 2.5KV 50A 63KA	1	EA	EA	386.0000	386.00	THB	NORMAL	
2451	20400000000	20400074	MOV CH 25KV 50A 63KA	1	EA	EA	1.00	1.00	THB	NORMAL	
2451	20400000000	20400074	MOV ACTUATOR 1.25KV 10A	1	EA	EA	668.0000	668.00	THB	NORMAL	
2451	20400000000	20400074	MOV ACTUATOR 1.25KV 10A	1	EA	EA	768.0000	768.00	THB	NORMAL	
2451	20400000000	20400076	DOO STARTER 100V 100W	1	EA	EA	300.0000	300.00	THB	NORMAL	
2451	20400000000	20400076	DOO STARTER 100V 100W	1	EA	EA	300.0000	300.00	THB	NORMAL	
2451	20400000000	20400077	DOO STARTER 100V 100W	1	EA	EA	300.0000	300.00	THB	NORMAL	
2451	20400000000	20400077	DOO STARTER 100V 100W	1	EA	EA	300.0000	300.00	THB	NORMAL	
2451	20400000000	20400079	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL 1.25KV 10A	3	EA	EA	389.0200	1,167.06	THB	NORMAL	
2451	20400000000	20400081	THRUST BEARING ASSEMBLY MODEL								

Part	Old material number	Material	Material Description	Stock Quantity on Hand	Unit of Measure	Base Unit of Measure	Stock Value on Hand	Currency	Valuation Type
2451	ZXA763932049	21000566	UNION CROCS TUBE 3/8" PN SS-BE004	2	EA	EA	15.262 \$	THB	NORMAL
2451	ZXA7639340219	21000567	MALE ELBOW TUBE 1/4"x1/4" PN SS-BE024	15	EA	EA	1.468 \$	THB	NORMAL
2451	ZXA7639340519	21000568	MALE ELBOW TUBE 1/4"x1/4" PN SS-BE024	15	EA	EA	8.768 \$	THB	NORMAL
2451	ZXA7639340519	21000569	MALE ELBOW TUBE 1/4"x1/4" PN SS-BE024	2	EA	EA	2.176 \$	THB	NORMAL
2451	ZXA7639340519	21000569	MALE ELBOW TUBE 1/4"x1/4" PN SS-BE024	4	EA	EA	2.632 \$	THB	NORMAL
2451	ZXA7639340519	21000569	MALE ELBOW TUBE 1/4"x1/4" PN SS-BE024	13	EA	EA	10.208 \$	THB	NORMAL
2451	ZXA7639340529	21000571	MALE ELBOW TUBE 3/8"x1/4" PN SS-BE024	5	EA	EA	2.288 \$	THB	NORMAL
2451	ZXA7639340529	21000571	MALE ELBOW TUBE 3/8"x1/4" PN SS-BE024	5	EA	EA	3.442 \$	THB	NORMAL
2451	ZXA7639340529	21000571	MALE ELBOW TUBE 3/8"x1/4" PN SS-BE024	3	EA	EA	2.082 \$	THB	NORMAL
2451	ZXA7639340519	21000574	MALE ELBOW TUBE 1/2"x1/2" PN SS-BE024	3	EA	EA	2.812 \$	THB	NORMAL
2451	ZXA7639340519	21000574	MALE ELBOW TUBE 1/2"x1/2" PN SS-BE024	3	EA	EA	3.016 \$	THB	NORMAL
2451	ZXA763949039	21000582	FERRULE SET SUS316 L/1/2" SS-200-BET	10	EA	EA	482 \$	THB	NORMAL
2451	ZXA763949039	21000582	FERRULE SET SUS316 L/1/2" SS-200-BET	10	EA	EA	53.812 \$	THB	NORMAL
2451	ZXA763949039	21000582	FERRULE SET SUS316 L/1/2" SS-200-BET	9	EA	EA	1.042 \$	THB	NORMAL
2451	ZXA763949039	21000582	FERRULE SET SUS316 L/1/2" SS-200-BET	9	EA	EA	2.308 \$	THB	NORMAL
2451	ZXA763967589	21000582	PLUG TUBE MALE 1/4" PN SS-BE-2	5	EA	EA	93.09 \$	THB	NORMAL
2451	ZXA763967589	21000582	PLUG TUBE MALE 1/4" PN SS-BE-2	5	EA	EA	1.296 \$	THB	NORMAL
2451	ZXA763967589	21000584	PLUG TUBE MALE 1/8" PN SS-2-P	5	EA	EA	766.09 \$	THB	NORMAL
2451	ZXA763967589	21000584	PLUG TUBE MALE 1/8" PN SS-2-P	5	EA	EA	1.266 \$	THB	NORMAL
2451	ZXA763967589	21000586	PLUG TUBE MALE 1/8" PN SS-B-P	5	EA	EA	1.667 \$	THB	NORMAL
2451	ZXA763967589	21000587	PLUG TUBE MALE 1/2" PN SS-BE0-3	5	EA	EA	1.570 \$	THB	NORMAL
2451	ZXA763967589	21000587	PLUG TUBE MALE 1/2" PN SS-BE0-3	5	EA	EA	1.527 \$	THB	NORMAL
2451	ZXA763969031	21000589	UNION TUBE 1/8" PN SS-BE004	4	EA	EA	3.956 \$	THB	NORMAL
2451	ZXA763969031	21000589	UNION TUBE 1/8" PN SS-BE004	4	EA	EA	1.608 \$	THB	NORMAL
2451	ZXA763969101	21000592	UNION TUBE 3/8" PN SS-BE004	4	EA	EA	2.109 \$	THB	NORMAL
2451	ZXA763969101	21000592	UNION TUBE 3/8" PN SS-BE004	4	EA	EA	4.292 \$	THB	NORMAL
2452	ZXA764002579	21000593	UNION TUBE 1/2" PN SS-BE004	2	EA	EA	1.716 \$	THB	NORMAL
2452	ZXA764002579	21000593	UNION TUBE 1/2" PN SS-BE004	2	EA	EA	2.172 \$	THB	NORMAL
2451	ZXA764002619	21000596	CONN. TUBE MALE 1/2"x1" PN SS-BE010	5	EA	EA	1.291 \$	THB	NORMAL
2451	ZXA764002619	21000596	CONN. TUBE MALE 1/2"x1" PN SS-BE010	5	EA	EA	2.220 \$	THB	NORMAL
2451	ZXA764003009	21000599	UNION CROCS TUBE 1/2" PN SS-BE010	8	EA	EA	1.076 \$	THB	NORMAL
2451	ZXA764003029	21000600	UNION CROCS TUBE 1/2" PN SS-BE010	7	EA	EA	1.625 \$	THB	NORMAL
2451	ZXA764003029	21000600	UNION CROCS TUBE 1/2"x1" PN SS-BE024	7	EA	EA	2.345 \$	THB	NORMAL
2451	ZXA764003049	21000602	FLANGE PIPE W/IN 1/8" SS-600-83-4"	21	EA	EA	15.920 \$	THB	NORMAL
2451	ZXA764003049	21000602	FLANGE PIPE W/IN 1/8" SS-600-83-4"	20	EA	EA	27.600 \$	THB	NORMAL
2451	ZXA764003049	21000604	FLANGE PIPE W/IN 1/8" SS-600-83-4"	17	EA	EA	6.133 \$	THB	NORMAL
2452	ZXA764003049	21000604	FLANGE PIPE W/IN 1/8" SS-600-83-4"	1	EA	EA	6.133 \$	THB	NORMAL
2451	ZXA764003049	21000605	FLANGE PIPE W/IN 1/8" SS-600-83-4"	2	EA	EA	694.40 \$	THB	NORMAL
2451	ZXA764003049	21000605	FLANGE PIPE W/IN 1/8" SS-600-83-4"	2	EA	EA	694.40 \$	THB	NORMAL
2451	ZXA764003049	21000605	FLANGE PIPE W/IN 1/8" SS-600-83-4"	22	EA	EA	18.600 \$	THB	NORMAL
2451	ZXA764003049	21000605	FLANGE PIPE W/IN 1/8" SS-600-83-4"	19	EA	EA	34.540 \$	THB	NORMAL
2451	ZXA764003049	21000608	FLANGE PIPE W/IN 1/2"x1/2" PN SS-BE024	13	EA	EA	32.743 \$	THB	NORMAL
2451	ZXA764003049	21000608	FLANGE PIPE W/IN 1/2"x1/2" PN SS-BE024	13	EA	EA	10.760 \$	THB	NORMAL
2451	ZXA764003049	21000610	FLANGE PIPE W/IN 1/2"x1/2" PN SS-BE024	4	EA	EA	8.360 \$	THB	NORMAL
2451	ZXA764003049	21000610	FLANGE PIPE W/IN 1/2"x1/2" PN SS-BE024	2	EA	EA	1.04 \$	THB	NORMAL
2452	ZXA764003029	21000612	PACKING RING CLASS 300X134	2	SET	SET	2.253 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	21000612	PACKING RING CLASS 300X134	4	EA	EA	0.00 \$	THB	SUPPLIS
2451	ZXA764003029	2							

Plant	Old material number	Material	Material Description	Stock Quantity on Part Used	Base Unit of Measure	Stock Value in Millions	Currency	Valuation Type
2450	72471453019	200003744	CHECK VALV 1/2" 800W SW F11 KVC-B58R	1	EA	1,230.00	THB	NORMAL
2450	72471453019	200003744	CHECK VALV 1/2" 800W SW F11 KVC-B58R	1	EA	1,230.00	THB	NORMAL
2450	72471460079	200003762	VALVE CHECK BALL 1/2" FN 125 040-OWP	1	EA	14,400.00	THB	NORMAL
2450	72471460741	200003762	VALVE CHECK BUTTERFLY VALV 1/2" 800W SW F11	1	EA	4,200.00	THB	NORMAL
2450	72472013519	200003566	GATE VALV 1/2" 150W RF WCB KVC-D11F-8	1	EA	1,040.00	THB	NORMAL
2450	72472013589	200003566	GATE VALV 1/2" 150W RF WCB KVC-D11F-8	1	EA	1,040.00	THB	NORMAL
2450	72472013589	200003566	GATE VALV 1/2" 300W RF WCB KVC-D11F-5	1	EA	12,570.00	THB	NORMAL
2450	72472103089	200003762	GATE VALV 1/2" 800W RF WCB KVC-B8T-16	6	EA	9,700.00	THB	NORMAL
2450	72472103089	200003762	GATE VALV 1/2" 800W RF WCB KVC-B8T-16	6	EA	14,400.00	THB	NORMAL
2450	72472103089	200003764	GATE VALV 1/2" 800W RF WCB KVC-D11F-8	1	EA	24,800.00	THB	NORMAL
2450	72472103089	200003764	GATE VALV 1/2" 800W RF WCB KVC-D11F-8	1	EA	1,080.00	THB	NORMAL
2450	72472103029	200003766	GATE VALV 3/4" 800W RF WCB KVC-MO3-763	3	EA	70,400.00	THB	NORMAL
2450	72472103049	200003766	GATE VALV 1/2" 800W RF WCB KVC-D11F-8	1	EA	1,080.00	THB	NORMAL
2450	72472103069	200003768	GATE VALV SW 1/4" 800W RF KVC-D11F-8	22	EA	39,600.00	THB	NORMAL
2450	72472103069	200003768	GATE VALV SW 1/4" 800W RF KVC-D11F-8	22	EA	1,001.00	THB	NORMAL
2450	72472103079	200003769	GATE VALV SW 1/4" 800W RF KVC-D11F-8	1	EA	3,985.66	THB	NORMAL
2450	72472103079	200003769	GATE VALV SW 1/4" 800W RF KVC-D11F-8	1	EA	25,200.00	THB	NORMAL
2450	72472103099	200003770	GATE VALV SW 1/4" 800W RF KVC-D11F-8	3	EA	0.00	THB	SURPLUS
2450	72472103099	200003770	GATE VALV SW 1/4" 800W RF KVC-D11F-8	3	EA	25,200.00	THB	NORMAL
2450	72472112629	200003774	GATE VALV 1/2" 800W RF 21WCB KVC-MO3-766	1	EA	46,800.00	THB	NORMAL
2450	72472202189	200003776	GATE VALV SW 1/4" 800W RF KVC-D11F-8	1	EA	148,387.77	THB	NORMAL
2450	72472204109	200003776	GATE VALV 1/2" 800W RF WCB KVC-D11F-8	1	EA	15,800.00	THB	NORMAL
2450	72472206189	200003778	GATE VALV NPT 3/4" 800W RF KVC-D11F-8	2	EA	74,192.88	THB	NORMAL
2450	72472210389	200003778	GATE VALV NPT 3/4" 800W RF KVC-D11F-8	1	EA	1,150.00	THB	NORMAL
2450	72472302319	200003780	GATE VALV 1/2" 150W RF KVC-D11F-8	1	EA	5,220.00	THB	NORMAL
2450	72472302349	200003780	GATE VALV 1/2" 150W RF KVC-D11F-8	1	EA	2,220.00	THB	NORMAL
2450	72472302389	200003782	GATE VALV 1/2" 150W RF KVC-D11F-8	1	EA	2,800.00	THB	NORMAL
2450	72472302389	200003782	GATE VALV 1/2" 150W RF KVC-D11F-8	1	EA	2,800.00	THB	NORMAL
2450	72472400549	200003784	GATE VALV SW 1/4" 800W RF KVC-D11F-8	16	EA	61,886.65	THB	NORMAL
2450	72472400549	200003784	GATE VALV SW 1/4" 800W RF KVC-D11F-8	16	EA	1,868.00	THB	NORMAL
2450	72472400589	200003785	GATE VALV SW 1/4" 800W RF KVC-D11F-8	1	EA	148,387.77	THB	NORMAL
2450	72473002489	200003789	GLOBE VALV 1/2" 150W RF WCB KVC-D11F-8	1	EA	15,800.00	THB	NORMAL
2450	72473002489	200003789	GLOBE VALV 1/2" 150W RF WCB KVC-D11F-8	1	EA	15,800.00	THB	NORMAL
2450	72473123329	200003792	GLOBE VALV 2" 800W RF 21WCB KVC-MO3-766	1	EA	66,895.00	THB	NORMAL
2450	72473123339	200003792	GLOBE VALV 1" 150W RF 21WCB KVC-MO3-766	1	EA	1,150.00	THB	NORMAL
2450	72473201029	200003794	GLOBE VALV 1/2" 800W RF KVC-D11F-8	3	EA	3,240.00	THB	NORMAL

Plant	Old material number	Material	Measure	Material Description	Stock Quantity on Hand	Stock Qty on Order	Base Unit of Measure	Stock Value on Hand	Currency	Valuation Type
2452	24A0230291893	21000655		CIRCUIT BREAKER 3P 400V PN.RI008705	1	EA	1,398.30	THB	NORMAL	
2452	24A0230291903	21000656		CIRCUIT BREAKER 3P 400V PN.RI008706	1	EA	1,476.30	THB	NORMAL	
2452	24A0230291913	21000657		CIRCUIT BREAKER 3P 400V PN.RI008709	1	EA	4,770.11	THB	NORMAL	
2452	24A0230291923	21000658		CIRCUIT BREAKER 3P 400V PN.RI008710	1	EA	1,398.30	THB	NORMAL	
2452	24A0230291933	21000659		CIRCUIT BREAKER 3P 750V PN.RI008720	1	EA	2,801.38	THB	NORMAL	
2452	24A0230291943	21000660		CIRCUIT BREAKER 3P 750V PN.RI008721	1	EA	1,313.13	THB	NORMAL	
2452	24A0230291953	21000661		CIRCUIT BREAKER 3P 750V PN.RI008723	1	EA	15,086.73	THB	NORMAL	
2452	24A0230291963	21000662		CIRCUIT BREAKER 3P 750V PN.RI008724	1	EA	13,942.15	THB	NORMAL	
2452	24A0230291973	21000663		CIRCUIT BREAKER 3P 750V PN.RI008725	1	EA	1,072.38	THB	NORMAL	
2452	24A0230291983	21000664		CIRCUIT BREAKER 3P 750V PN.RI008726	1	EA	3,194.55	THB	NORMAL	
2452	24A0230291993	21000665		CIRCUIT BREAKER 3P 750V PN.RI008727	1	EA	1,000.00	THB	NORMAL	
2452	24A0230292003	21000666		CIRCUIT BREAKER 3P 750V PN.RI008728	1	EA	17,581.52	THB	NORMAL	
2452	24A0230292013	21000667		CIRCUIT BREAKER 3P 750V PN.RI008729	1	EA	1,251.70	THB	NORMAL	
2452	24A0230292023	21000668		CIRCUIT BREAKER 3P 750V PN.RI008730	1	EA	11,933.55	THB	NORMAL	
2452	24A0230292033	21000669		CIRCUIT BREAKER 3P 750V PN.RI008731	1	EA	1,244.46	THB	NORMAL	
2452	24A0230292043	21000670		COM VME 8TA-0101 PN.RI008736P01	6	EA	82,723.37	THB	NORMAL	
2452	24A0230292053	21000671		CONTACT PLATE 100V PN.RI008737	1	EA	1,270.30	THB	NORMAL	
2452	24A0230292063	21000672		CONTACTS IN RELAYS OUT PN.RI008740	2	EA	14,874.84	THB	NORMAL	
2452	24A0230292073	21000673		CT 50/5VTA 30/300V PN.RI008742	1	EA	65,701.31	THB	NORMAL	
2452	24A0230292083	21000674		CT OUT BUT SWITCH PN.RI008743	1	EA	18,120.12	THB	NORMAL	
2452	24A0230292093	21000675		DC CURRENT TRANSFORMER PN.RI008744	1	EA	152,843.90	THB	NORMAL	
2452	24A0230292103	21000676		DDCC CONVTOR 100V PN.RI008745	1	EA	186,856.05	THB	NORMAL	
2452	24A0230292113	21000677		DDCC CONVTOR 110V PN.RI008746	1	EA	1,733.73	THB	NORMAL	
2452	24A0230292123	21000678		DDCC CONVTOR 110V PN.RI008747	2	EA	25,935.00	THB	NORMAL	
2452	24A0230292133	21000679		DETECT PN.RI008748	1	EA	4,658.31	THB	NORMAL	
2452	24A0230292143	21000680		DIAPHRAGM PN.RI008749	1	EA	12,609.98	THB	NORMAL	
2452	24A0230292153	21000681		DIODE PRESSURE PN.RI008750	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292163	21000682		RECTIFIER DIODE PN.RI008751	4	EA	26,690.23	THB	NORMAL	
2452	24A0230292173	21000683		DIODE PRESSURE PN.RI008752	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292183	21000684		DIODE PRESSURE PN.RI008753	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292193	21000685		DIODE PRESSURE PN.RI008754	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292203	21000686		DIODE PRESSURE PN.RI008755	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292213	21000687		DIODE PRESSURE PN.RI008756	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292223	21000688		DIODE PRESSURE PN.RI008757	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292233	21000689		DIODE PRESSURE PN.RI008758	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292243	21000690		DIODE PRESSURE PN.RI008759	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292253	21000691		DIODE PRESSURE PN.RI008760	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292263	21000692		DIODE PRESSURE PN.RI008761	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292273	21000693		DIODE PRESSURE PN.RI008762	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292283	21000694		DIODE PRESSURE PN.RI008763	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292293	21000695		DIODE PRESSURE PN.RI008764	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292303	21000696		DIODE PRESSURE PN.RI008765	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292313	21000697		DIODE PRESSURE PN.RI008766	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292323	21000698		DIODE PRESSURE PN.RI008767	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292333	21000699		DIODE PRESSURE PN.RI008768	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292343	21000700		DIODE PRESSURE PN.RI008769	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292353	21000701		DIODE PRESSURE PN.RI008770	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292363	21000702		DIODE PRESSURE PN.RI008771	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292373	21000703		DIODE PRESSURE PN.RI008772	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292383	21000704		DIODE PRESSURE PN.RI008773	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292393	21000705		DIODE PRESSURE PN.RI008774	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292403	21000706		DIODE PRESSURE PN.RI008775	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292413	21000707		DIODE PRESSURE PN.RI008776	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292423	21000708		DIODE PRESSURE PN.RI008777	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292433	21000709		DIODE PRESSURE PN.RI008778	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292443	21000710		DIODE PRESSURE PN.RI008779	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292453	21000711		DIODE PRESSURE PN.RI008780	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292463	21000712		DIODE PRESSURE PN.RI008781	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292473	21000713		DIODE PRESSURE PN.RI008782	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292483	21000714		DIODE PRESSURE PN.RI008783	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292493	21000715		DIODE PRESSURE PN.RI008784	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292503	21000716		DIODE PRESSURE PN.RI008785	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292513	21000717		DIODE PRESSURE PN.RI008786	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292523	21000718		DIODE PRESSURE PN.RI008787	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292533	21000719		DIODE PRESSURE PN.RI008788	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292543	21000720		DIODE PRESSURE PN.RI008789	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292553	21000721		DIODE PRESSURE PN.RI008790	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292563	21000722		DIODE PRESSURE PN.RI008791	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292573	21000723		DIODE PRESSURE PN.RI008792	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292583	21000724		DIODE PRESSURE PN.RI008793	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292593	21000725		DIODE PRESSURE PN.RI008794	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292603	21000726		DIODE PRESSURE PN.RI008795	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292613	21000727		DIODE PRESSURE PN.RI008796	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292623	21000728		DIODE PRESSURE PN.RI008797	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292633	21000729		DIODE PRESSURE PN.RI008798	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292643	21000730		DIODE PRESSURE PN.RI008799	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292653	21000731		DIODE PRESSURE PN.RI008800	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292663	21000732		DIODE PRESSURE PN.RI008801	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292673	21000733		DIODE PRESSURE PN.RI008802	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292683	21000734		DIODE PRESSURE PN.RI008803	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292693	21000735		DIODE PRESSURE PN.RI008804	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292703	21000736		DIODE PRESSURE PN.RI008805	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292713	21000737		DIODE PRESSURE PN.RI008806	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292723	21000738		DIODE PRESSURE PN.RI008807	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292733	21000739		DIODE PRESSURE PN.RI008808	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292743	21000740		DIODE PRESSURE PN.RI008809	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292753	21000741		DIODE PRESSURE PN.RI008810	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292763	21000742		DIODE PRESSURE PN.RI008811	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292773	21000743		DIODE PRESSURE PN.RI008812	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292783	21000744		DIODE PRESSURE PN.RI008813	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292793	21000745		DIODE PRESSURE PN.RI008814	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292803	21000746		DIODE PRESSURE PN.RI008815	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292813	21000747		DIODE PRESSURE PN.RI008816	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292823	21000748		DIODE PRESSURE PN.RI008817	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292833	21000749		DIODE PRESSURE PN.RI008818	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292843	21000750		DIODE PRESSURE PN.RI008819	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292853	21000751		DIODE PRESSURE PN.RI008820	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292863	21000752		DIODE PRESSURE PN.RI008821	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292873	21000753		DIODE PRESSURE PN.RI008822	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292883	21000754		DIODE PRESSURE PN.RI008823	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292893	21000755		DIODE PRESSURE PN.RI008824	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292903	21000756		DIODE PRESSURE PN.RI008825	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292913	21000757		DIODE PRESSURE PN.RI008826	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292923	21000758		DIODE PRESSURE PN.RI008827	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292933	21000759		DIODE PRESSURE PN.RI008828	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292943	21000760		DIODE PRESSURE PN.RI008829	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292953	21000761		DIODE PRESSURE PN.RI008830	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292963	21000762		DIODE PRESSURE PN.RI008831	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292973	21000763		DIODE PRESSURE PN.RI008832	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292983	21000764		DIODE PRESSURE PN.RI008833	1	EA	1,696.40	THB	NORMAL	
2452	24A0230292993	21000765		DIODE PRESSURE PN.RI008834	1	EA	1,696.40	THB	NORMAL	
2452	24A0230293003	21000766		DIODE PRESSURE PN.RI008835	1	EA	1,696.40	THB	NORMAL	
2452	24A0230293013	21000767		DIODE PRESSURE PN.RI008836	1	EA	1,696.40	THB	NORMAL	
2452	24A0230293023	21000768		DIODE PRESSURE PN.RI008837	1	EA	1,696.40	TH		

Part	Old material number	Material	Description	Stock Quantity	Period End	Base Unit of Measure	Stock Value on Period End	Currency	Valuation Type
2462	ZSA42250422	21008919	VALVE ASDY 10V1 IN PN#10001-400	1	EA	28.000	100	USD	NORMAL
2462	ZSA42250448	21008921	CYLINDER PISTON 10.5 MM DIA PN#10001-374	2	EA	28.000	100	USD	NORMAL
2462	ZSA42250450	21008922	GASKET 1/2" X 1/2" X 1/8" PN#10001-375	2	EA	2.800	100	USD	NORMAL
2462	ZSA42250509	21008923	M 6 X 1.00 L 8 SCREW 4318 PN#10004-574	8	EA	1.200	100	USD	NORMAL
2462	ZSA42250510	21008924	60603 1/8" O.D. CHROME PLATE 1/2" X 1/2" X 1/8" PN#10004-575	2	EA	1.200	100	USD	NORMAL
2462	ZSA42250529	21008925	CAM VALVE IN PN#10003-015	4	EA	1.000	100	USD	NORMAL
2462	ZSA42250539	21008926	BEAT SPRING SUPPORT HUB PN#10030-011	2	EA	3.200	100	USD	NORMAL
2462	ZSA42250540	21008927	BEAT SPRING HUB PN#10030-012	2	EA	3.200	100	USD	NORMAL
2462	ZSA42250559	21008928	POCKET SPRING SUPPORT HUB PN#10030-011	2	EA	3.200	100	USD	NORMAL
2462	ZSA42250560	21008929	BOOY 1/2" X 1/2" X 1/8" PN#10001-376	2	EA	8.000	100	USD	NORMAL
2462	ZSA42250579	21008930	SPRING CAMPSHIEV HUB LOW GRN PN#10007-000	4	EA	2.500	100	USD	NORMAL
2462	ZSA42250589	21008931	WASHER 1/2" X 1/2" X 1/8" PN#10001-377	2	EA	1.000	100	USD	NORMAL
2462	ZSA42250599	21008932	BEAT HUB 1 X 1/2 IN PN#10001-400	8	EA	1.600	100	USD	NORMAL
2462	ZSA42250609	21008933	M 6 X 1.00 SCREW 4318 PN#10004-574	8	EA	1.200	100	USD	NORMAL
2462	ZSA42250619	21008934	M 8 X 1.25 UNF 1/2" X 1/2" X 1/8" PN#10004-576	8	EA	1.600	100	USD	NORMAL
2462	ZSA42250629	21008935	M 4 X 1.00 L 1/2" X 1/2" X 1/8" PN#10004-577	8	EA	1.600	100	USD	NORMAL
2462	ZSA42250639	21008936	HEAD REAR 1/2" X 1/2" X 1/8" PN#10001-378	4	EA	78.000	100	USD	NORMAL
2462	ZSA42250649	21008937	M 10 X 1.50 UNF 1/2" X 1/2" X 1/8" PN#10004-578	24	EA	1.200	100	USD	NORMAL
2462	ZSA42250659	21008938	M 10 F 1/2" NARROW 125 A2JPN#10013-116	4	EA	1.200	100	USD	NORMAL
2462	ZSA42250669	21008939	SCAPTS 1/2" X 1/2" X 1/8" PN#10001-379	8	EA	3.200	100	USD	NORMAL
2462	ZSA42250679	21008940	CAM VALVE 25 WPT 1 PN#10003-016	8	EA	36.000	100	USD	NORMAL
2462	ZSA42250689	21008941	TIEBAR 12 3/16" X 1/2" X 1/8" PN#10001-310	4	EA	25.200	100	USD	NORMAL
2462	ZSA42250699	21008942	M 6 W/SHR 1/2" ON 125 A2J PN#10013-118	4	EA	1.600	100	USD	NORMAL
2462	ZSA42250709	21008943	M 12 X 1.75 UNF 1/2" X 1/2" X 1/8" PN#10004-579	16	EA	1.600	100	USD	NORMAL
2462	ZSA42250719	21008944	STUD 1/2" X 1/2" X 1/8" PN#10001-380	1	EA	1.400	100	USD	NORMAL
2462	ZSA42250729	21008945	GEAR WORM 3 X 1/2 IN PN#10001-030	1	EA	13.000	100	USD	NORMAL
2462	ZSA42250739	21008946	WORM 3 X 1/2 IN PN#10001-030	1	EA	8.800	100	USD	NORMAL
2465	ZSA43091003	21008948	THRAW COOLER PN#1047003	4	EA	841.643	100	USD	NORMAL
2465	ZSA43091004	21008949	STUD FITTING PN#10004-012	2	EA	714.84	100	USD	NORMAL
2465	ZSA43091005	21008952	ODDLE VALVE PN#1001474	2	EA	2.875	100	USD	NORMAL
2465	ZSA43091006	21008953	RE SEALER PN#10004-012	2	EA	3.845	100	USD	NORMAL
2465	ZSA43091008	21008955	PRESSURE RELIEF VALVE PN#10004-012	2	EA	20.84	100	USD	NORMAL
2465	ZSA43091009	21008956	STUD FITTING PN#10004-012	2	EA	5.565	100	USD	NORMAL
2465	ZSA43091010	21008957	STUD FITTING PN#10004-012	2	EA	1.228	100	USD	NORMAL
2465	ZSA43091011	21008958	VALVE PN#10004-012	2	EA	2.437	100	USD	NORMAL
2465	ZSA43091013	21008960	C						

Plant	Old material number	Material description	Material description	Stock quantity on hand	Base unit of measure	Stock value on hand	Currency	Valuation type
2442	ZSAR001100003	21000093	BEARING AS&B UC210, PN. 30105010	12	SET	8,400.00	USD	NORMAL
2443	ZSAR001100004	21000094	BEARING AS&B UC208, PN. 30051010	12	SET	7,200.00	USD	NORMAL
2442	ZSAR001070059	21000039	BEARING BALL, SKF 6205, ZCMA 520M SZAM	6	EA	620.00	USD	NORMAL
2443	ZSAR001080010	21000040	BEARING BALL, SKF 6206, ZCMA 530M SZAM	12	EA	107,408.00	USD	NORMAL
2443	ZSAR001080023	21000091	BEARING HOUSING DRIVE END, 328020	2	EA	189,600.00	USD	NORMAL
2443	ZSAR001080024	21000092	BEARING HOUSING, 320010	2	EA	26,200.00	USD	NORMAL
2443	ZSAR001080004	21000093	BEARING HOUSING, 230422 A10500104	2	EA	1,444.00	USD	NORMAL
2443	ZSAR001080003	21000094	BEARING ROLLER, TALL 1230422 A10500107	3	EA	12,561.00	USD	NORMAL
2443	ZSAR001080004	21000095	BEARING HOUSING, 210092 A10500106	3	EA	7,217.00	USD	NORMAL
2443	ZSAR001080007	21000096	BEARING ROLLER, DROVER, 230442	3	EA	68,800.00	USD	NORMAL
2443	ZSAR001080008	21000097	BEARING ROLLER, 301066 A10500107	9	EA	17,500.00	USD	NORMAL
2443	ZSAR001080011	21000040	BEARING HOUSING, 210102 A10500110	1	EA	3,730.00	USD	NORMAL
2443	ZSAR001080012	21000041	BEARING ROLLER (TALL), 230442	3	EA	10,440.00	USD	NORMAL
2443	ZSAR001080013	21000042	BEARING ROLLER, 230650 A10500111	1	EA	1,976.01	USD	NORMAL
2443	ZSAR001080014	21000094	BEARING HOUSING, DRIVE, 210102	4	EA	54,508.00	USD	NORMAL
2443	ZSAR001080015	21000043	BEARING ROLLER, 230472	4	EA	79,042.44	USD	NORMAL
2443	ZSAR001080016	21000044	BEARING ROLLER, 230472	4	EA	1,884.00	USD	NORMAL
2443	ZSAR001080017	21000040	BEARING BALL, 230630 A10500110	48	EA	23,320.00	USD	NORMAL
2443	ZSAR001080018	21000043	BEARING ROLLER (TALL), 230442	3	EA	12,444.00	USD	NORMAL
2443	ZSAR001080019	21000040	BEARING BALL, 300350 A10500110	10	EA	11,641.65	USD	NORMAL
2443	ZSAR001080020	21000043	NUT LOCK BKT MTR, ZCMA 00414	4	EA	6,697.00	USD	NORMAL
2443	ZSAR001080021	21000044	NUT LOCK MTR MTR, ZCMA 00414	2	EA	12,640.00	USD	NORMAL
2443	ZSAR001080022	21000041	V-BELT DRIVE IMPERIAL, 3-28	2	EA	420.00	USD	NORMAL
2443	ZSAR001080023	21000045	V-BELT DRIVE IMPERIAL, 3-36	2	EA	500.00	USD	NORMAL
2443	ZSAR001080024	21000048	V-BELT ATTU/SHCN 3/4 IN 24MM C&B#550	4	EA	3,353.00	USD	NORMAL
2443	ZSAR001080025	21000049	V-BELT DRIVE IMPERIAL, 3-48	2	EA	720.00	USD	NORMAL
2442	ZSAR001080030	21000049	V-BELT DRIVE IMPERIAL, 3-115	1	EA	570.00	USD	NORMAL
2443	ZSAR001080031	21000049	V-BELT DRIVE IMPERIAL, 3-142	1	EA	31,360.00	USD	NORMAL
2443	ZSAR001080032	21000042	V-BELT DRIVE IMPERIAL, 3P-38	10	EA	580.00	USD	NORMAL
2443	ZSAR001080033	21000046	SUPPORT FRAME, D80, 3014	1	SET	31,891.56	USD	NORMAL
2443	ZSAR001080034	21000047	BELLOWS FABRIC D700, 30086	1	SET	27,448.00	USD	NORMAL
2443	ZSAR001080035	21000048	SUPPORT FRAME, D84, 3014	1	SET	30,448.00	USD	NORMAL
2443	ZSAR001080036	21000048	TAIL PULLEY, TENSION PULLEY, 3/4 IN 1628	1	EA	109,468.05	USD	NORMAL
2443	ZSAR001080037	21000049	VIBRATION FEEDER, 3014, 1055001074	1	EA	1,444.00	USD	NORMAL
2443	ZSAR001080038	21000054	WEAR LINER, SET 343004	1	EA	456,458.58	USD	NORMAL
2443	ZSAR001080039	21000055	BAR WEDGE, SET, L-32, 420102	1	EA	1,952.02	USD	NORMAL
2443	ZSAR001080040	21000047	WHEEL, 18150, A10500113 SHREDDER 900X	1	EA	21,135.55	USD	NORMAL
2443	ZSAR001080041	21000047	WHEEL, 18151, A10500113 SHREDDER 900X	3	EA	15,565.28	USD	NORMAL
2443	ZSAR001080042	21000048	SCRAPER, 344043, A10500111 SHREDDER 900X					

Part	Old material number	Material	Material Description	Stock Quantity	Stock Unit	Base Unit of Measure	Stock Price	Current	Valuation Type
						Measure	Per 0.01		
2451	22A000025281	210010932	MODBUS MASTER/SLAVE COM-MV56-ACM	3	EA	EA	204.000.000	3	NORMAL
2451	22A000025289	210010933	PROFIB-DP MASTER PN 5120M4-ACM-BMS 3	3	EA	EA	204.000.000	3	NORMAL
2451	22A000031033	210010934	PROFIB-DP MASTER PN 5120M4-ACM-BMS 3	3	EA	EA	204.000.000	3	NORMAL
2451	22A000031043	210010935	PRESSURE SWITCH OPT 1/4" 5-BAR# 316M	11	SET	SET	25.489.000	11	NORMAL
2451	22A000031103	210010936	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	7.768.000	1	NORMAL
2451	22A00003113	210010937	FLOW COMPUTER CMN 1/2" 16-280-1	1	SET	SET	11.128.000	1	NORMAL
2451	22A000031313	210010938	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010939	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010940	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010941	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010942	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010943	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010944	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010945	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010946	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010947	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010948	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010949	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010950	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010951	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010952	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010953	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010954	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010955	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010956	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010957	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010958	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010959	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010960	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010961	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010962	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010963	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010964	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010965	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010966	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010967	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010968	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010969	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010970	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010971	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010972	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010973	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010974	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010975	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010976	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010977	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010978	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010979	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010980	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010981	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010982	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010983	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010984	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010985	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010986	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010987	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010988	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010989	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010990	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010991	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010992	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010993	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010994	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010995	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010996	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010997	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010998	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210010999	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011000	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011001	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011002	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011003	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011004	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011005	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011006	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011007	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011008	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011009	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011010	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011011	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011012	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011013	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011014	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011015	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011016	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011017	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011018	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011019	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011020	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011021	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011022	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011023	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011024	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011025	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011026	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011027	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011028	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011029	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011030	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011031	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011032	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011033	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011034	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011035	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011036	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011037	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011038	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011039	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011040	FLOW COMPUTER CMN 1/2" 16-280-1	1	EA	EA	11.128.000	1	NORMAL
2451	22A000031313	210011041</							

[illegible]

Part	Old material number	Material	Designation
2454	24D00901073	245511	GASKET STAINLESS STEEL/SEMI T330-10
2454	24D00901073	245512	GASKET GRAPHITE (H100) PN40 T331-32
2454	24D00901073	245513	SEAL RING 1/2" X 1/2" X 1/2" 304
2454	24D00901073	245514	HEADGUT M16 M4 SIEMENS PN780-730
2454	24D00901073	245515	HEADGUT M16 M4 SIEMENS PN780-730
2454	24D00901073	245516	HEADGUT END SCREW M6X7.5/10 T238-51
2454	24D00901073	245517	HEADGUT M12 M27 SIEMENS PN780-730
2454	24D0090182	245518	BEARING 6002-2RS (6002) 1/2" X 1 1/2"
2454	24D0090183	245519	BEARING FLUIDER (E18100474) (800)
2454	24D0090184	245520	OL ROLLER 1/2" X 1/2" X 1/2" (100)
2454	24D0090187	245521	SESS COT. 48" Flange (C31174) (800)
2454	24D0486005	245522	FLANGE 1/2" X 1/2" X 1/2" (100)
2454	24D07276328	245530	CHEMICAL PUMP 4X4 MCMPC-DS-2500-1
2454	24D0900222	245531	NOCK 1/2" X 1/2" X 1/2" (100)
2454	24D0900222	245532	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245533	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245534	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245535	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245536	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245537	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245538	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245539	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245540	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245541	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245542	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245543	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245544	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245545	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245546	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245547	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245548	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245549	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245550	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245551	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245552	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245553	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245554	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245555	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245556	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245557	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245558	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245559	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245560	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245561	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245562	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245563	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245564	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245565	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245566	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245567	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245568	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245569	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245570	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245571	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245572	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245573	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245574	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245575	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245576	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245577	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245578	BEARING FLUIDER (E18100474) (800)
2454	24D0900222	245579	BEARING FLUIDER (E181

Plant	Old material number	Material	Material Description
	DAU04309	201056072	SIEMENS SIGNALSSE ELECTRONIC SWITCH
	DAU04310	201056073	SIEMENS SIGNALSSE
	DAU04311	201056074	SIEMENS DS-MODULE
	DAU04312	201056075	SIEMENS DS-MODULE
	DAU04313	201056076	TURBOFROHER FREQUENCY-CONVERTER
	DAU04314	201056077	SIEMENS SHARED RESERVE MODULE
	DAU04315	201056078	SIEMENS SHARED RESERVE MODULE
	DAU04316	201056079	DUNLOP FLUX HYDRAULIC HOSE 1.6MM
	DAU04317	201056080	DUNLOP FLUX HYDRAULIC HOSE 1.6MM
	DAU04318	201056081	SIEMENS ACCESSORY RAYONTEK INFRANIR 2700-32MM
	DAU04319	201056082	ACCESSORY RAYONTEK INFRANIR 2700-32MM
	DAU04320	201056083	SIEMENS ACCESSORY BRACKET FOR SCALANCE
	DAU04321	201056084	SIEMENS ACCESSORY BRACKET FOR SCALANCE
	DAU04322	201056085	SIEMENS TERMINAL BLOCK
	DAU04323	201056086	SIEMENS COAXIAL CABLE 2 MM
	DAU04324	201056087	SIEMENS COAXIAL CABLE 2 MM
	DAU04325	201056088	SIEMENS COAXIAL CABLE 2 MM
	DAU04326	201056089	SIEMENS COAXIAL CABLE 2 MM
	DAU04327	201056090	SIEMENS COAXIAL CABLE 2 MM
	DAU04328	201056091	SIEMENS COAXIAL CABLE 2 MM
	DAU04329	201056092	SIEMENS COAXIAL CABLE 2 MM
	DAU04330	201056093	SIEMENS COAXIAL CABLE 2 MM
	DAU04331	201056094	SIEMENS COAXIAL CABLE 2 MM
	DAU04332	201056095	SIEMENS COAXIAL CABLE 2 MM
	DAU04333	201056096	SIEMENS COAXIAL CABLE 2 MM
	DAU04334	201056097	SIEMENS COAXIAL CABLE 2 MM
	DAU04335	201056098	SIEMENS COAXIAL CABLE 2 MM
	DAU04336	201056099	SIEMENS COAXIAL CABLE 2 MM
	DAU04337	201056100	SIEMENS COAXIAL CABLE 2 MM
	DAU04338	201056101	SIEMENS COAXIAL CABLE 2 MM
	DAU04339	201056102	SIEMENS COAXIAL CABLE 2 MM
	DAU04340	201056103	SIEMENS COAXIAL CABLE 2 MM
	DAU04341	201056104	SIEMENS COAXIAL CABLE 2 MM
	DAU04342	201056105	SIEMENS COAXIAL CABLE 2 MM
	DAU04343	201056106	SIEMENS COAXIAL CABLE 2 MM
	DAU04344	201056107	SIEMENS COAXIAL CABLE 2 MM
	DAU04345	201056108	SIEMENS COAXIAL CABLE 2 MM
	DAU04346	201056109	SIEMENS COAXIAL CABLE 2 MM
	DAU04347	201056110	SIEMENS COAXIAL CABLE 2 MM
	DAU04348	201056111	SIEMENS COAXIAL CABLE 2 MM
	DAU04349	201056112	SIEMENS COAXIAL CABLE 2 MM
	DAU04350	201056113	SIEMENS COAXIAL CABLE 2 MM
	DAU04351	201056114	SIEMENS COAXIAL CABLE 2 MM
	DAU04352	201056115	SIEMENS COAXIAL CABLE 2 MM
	DAU04353	201056116	SIEMENS COAXIAL CABLE 2 MM
	DAU04354	201056117	SIEMENS COAXIAL CABLE 2 MM
	DAU04355	201056118	SIEMENS COAXIAL CABLE 2 MM
	DAU04356	201056119	SIEMENS COAXIAL CABLE 2 MM
	DAU04357	201056120	SIEMENS COAXIAL CABLE 2 MM
	DAU04358	201056121	SIEMENS COAXIAL CABLE 2 MM
	DAU04359	201056122	SIEMENS COAXIAL CABLE 2 MM
	DAU04360	201056123	SIEMENS COAXIAL CABLE 2 MM
	DAU04361	201056124	SIEMENS COAXIAL CABLE 2 MM
	DAU04362	201056125	SIEMENS COAXIAL CABLE 2 MM
	DAU04363	201056126	SIEMENS COAXIAL CABLE 2 MM
	DAU04364	201056127	SIEMENS COAXIAL CABLE 2 MM
	DAU04365	201056128	LCF-25 SPARE FLUX FR1425, 500V, 1.6A
	DAU04366	201056129	LCF-25 SPARE FLUX FR1425, 500V, 2A
	DAU04367	201056130	LCF-25 SPARE FLUX FR1425/500V, 20A
	DAU04368	201056131	LCF-25 SPARE FLUX FR1425/500V, 20A
	DAU04369	201056132	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04370	201056133	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04371	201056134	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04372	201056135	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04373	201056136	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04374	201056137	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04375	201056138	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04376	201056139	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04377	201056140	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04378	201056141	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04379	201056142	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04380	201056143	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04381	201056144	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04382	201056145	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04383	201056146	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04384	201056147	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04385	201056148	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04386	201056149	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04387	201056150	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04388	201056151	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04389	201056152	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04390	201056153	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04391	201056154	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04392	201056155	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04393	201056156	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04394	201056157	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04395	201056158	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04396	201056159	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04397	201056160	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04398	201056161	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04399	201056162	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04400	201056163	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04401	201056164	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04402	201056165	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04403	201056166	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04404	201056167	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04405	201056168	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04406	201056169	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04407	201056170	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04408	201056171	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04409	201056172	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04410	201056173	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04411	201056174	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04412	201056175	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04413	201056176	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04414	201056177	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04415	201056178	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04416	201056179	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04417	201056180	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04418	201056181	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04419	201056182	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04420	201056183	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04421	201056184	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04422	201056185	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04423	201056186	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04424	201056187	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04425	201056188	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04426	201056189	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04427	201056190	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04428	201056191	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04429	201056192	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04430	201056193	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04431	201056194	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04432	201056195	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04433	201056196	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04434	201056197	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04435	201056198	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04436	201056199	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04437	201056200	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04438	201056201	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04439	201056202	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04440	201056203	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04441	201056204	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04442	201056205	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04443	201056206	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04444	201056207	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04445	201056208	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04446	201056209	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04447	201056210	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04448	201056211	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04449	201056212	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04450	201056213	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04451	201056214	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04452	201056215	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04453	201056216	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04454	201056217	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04455	201056218	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04456	201056219	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04457	201056220	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04458	201056221	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04459	201056222	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04460	201056223	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04461	201056224	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04462	201056225	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04463	201056226	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04464	201056227	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04465	201056228	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04466	201056229	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04467	201056230	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04468	201056231	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04469	201056232	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04470	201056233	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04471	201056234	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04472	201056235	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04473	201056236	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04474	201056237	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04475	201056238	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04476	201056239	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04477	201056240	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04478	201056241	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04479	201056242	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04480	201056243	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04481	201056244	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04482	201056245	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04483	201056246	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04484	201056247	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04485	201056248	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04486	201056249	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04487	201056250	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04488	201056251	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04489	201056252	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04490	201056253	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04491	201056254	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04492	201056255	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04493	201056256	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04494	201056257	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04495	201056258	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04496	201056259	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04497	201056260	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04498	201056261	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04499	201056262	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04500	201056263	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04501	201056264	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04502	201056265	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04503	201056266	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04504	201056267	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04505	201056268	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04506	201056269	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04507	201056270	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04508	201056271	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04509	201056272	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04510	201056273	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04511	201056274	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04512	201056275	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04513	201056276	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04514	201056277	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04515	201056278	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04516	201056279	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04517	201056280	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04518	201056281	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04519	201056282	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04520	201056283	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04521	201056284	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04522	201056285	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04523	201056286	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04524	201056287	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04525	201056288	INDICATOR LAMP RED 230VDC VVW-20ZMAR
	DAU04526	20105628	

ภาคผนวก ข-8

ผลการตรวจวัด NO_x จากระบบ CEMs
และผลการตรวจวัดคุณภาพน้ำทิ้ง (ก.ค.-ธ.ค. 66)

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
01/07/2023 00:00	26.59	14.3	415	12.7	164.7	11.3
01/07/2023 01:00	27.42	14.3	414.6	13.1	164.3	11.6
01/07/2023 02:00	26.49	14.2	410.1	12.8	162.7	11.2
01/07/2023 03:00	<Samp	<Samp	<Samp	<Samp	163.8	<Samp
01/07/2023 04:00	<Samp	<Samp	<Samp	<Samp	164.2	<Samp
01/07/2023 05:00	24.65	14.2	404.4	11.9	164.3	10.5
01/07/2023 06:00	23.96	14.2	404.6	11.6	164.5	10.2
01/07/2023 07:00	24.29	14.2	407.5	11.7	164.2	10.3
01/07/2023 08:00	24.46	14.3	410.1	11.7	165	10.4
01/07/2023 09:00	25.69	14.3	417.1	12.7	166	10.9
01/07/2023 10:00	26.56	14.3	417.7	12.6	166.1	11.3
01/07/2023 11:00	26.7	14.3	416.7	12.7	166.1	11.3
01/07/2023 12:00	25.94	14.3	414.8	12.3	165.4	11
01/07/2023 13:00	26.3	14.3	415.1	12.5	165.3	11.2
01/07/2023 14:00	27.21	14.3	415.5	12.9	165.4	11.5
01/07/2023 15:00	26.36	14.3	415.7	12.5	165.3	11.2
01/07/2023 16:00	25.82	14.3	415.7	12.2	165.1	11
01/07/2023 17:00	26.45	14.3	415.1	12.5	164.9	11.2
01/07/2023 18:00	26.57	14.3	415.3	12.6	165	11.3
01/07/2023 19:00	25.85	14.3	416.1	12.3	165.2	11
01/07/2023 20:00	25.25	14.3	417	12	165.6	10.7
01/07/2023 21:00	25.25	14.3	417	12	165.9	10.7
01/07/2023 22:00	24.88	14.3	412.9	11.9	165.4	10.6
01/07/2023 23:00	24.75	14.3	414.3	11.8	165.1	10.5
02/07/2023 00:00	24.57	14.3	413.6	11.7	165.1	10.4
02/07/2023 01:00	24.88	14.3	412.8	11.9	165.3	10.6
02/07/2023 02:00	26.83	14.3	418.8	12.7	166.2	11.4
02/07/2023 03:00	27.08	14.3	417.9	12.9	165.6	11.5
02/07/2023 04:00	27.02	14.3	417.5	12.8	165.5	11.5
02/07/2023 05:00	27.36	14.3	417.4	13	165.5	11.6
02/07/2023 06:00	27.06	14.3	417.3	12.9	165.4	11.5
02/07/2023 07:00	26.61	14.3	417.6	12.7	165.8	11.3
02/07/2023 08:00	26.58	14.3	416.6	12.6	165.5	11.3
02/07/2023 09:00	26.54	14.3	414.9	12.6	165.4	11.3
02/07/2023 10:00	25.59	14.3	414.1	12.1	165.4	10.9
02/07/2023 11:00	24.87	14.3	412.1	11.8	165.3	10.6
02/07/2023 12:00	25.12	14.3	411.3	11.9	164.9	10.7
02/07/2023 13:00	24.29	14.3	411.1	11.5	164.6	10.6
02/07/2023 14:00	24.17	14.3	411.2	11.4	164.5	10.3
02/07/2023 15:00	24.65	14.3	412.3	11.7	164.5	10.5
02/07/2023 16:00	24.79	14.3	413.7	11.8	164.7	10.5
02/07/2023 17:00	25.98	14.3	416.3	12.3	165.7	11.3
02/07/2023 18:00	27.1	14.3	417.4	12.9	164.7	11.5
02/07/2023 19:00	27.73	14.3	417.2	13.2	164.6	11.8
02/07/2023 20:00	25.3	14.3	417.2	12.1	164.8	10.7
02/07/2023 21:00	25.65	14.3	413.3	12.3	164.4	10.9
02/07/2023 22:00	24.56	14.2	411.2	11.8	164.2	10.4
02/07/2023 23:00	25.11	14.2	412.7	12	164.5	10.7
03/07/2023 00:00	26.25	14.3	414.4	12.5	164.5	11.1
03/07/2023 01:00	26.43	14.3	416.1	12.6	164.7	11.3
03/07/2023 02:00	26.43	14.3	415.8	12.6	164.8	11.2
03/07/2023 03:00	26.68	14.3	416.4	12.7	164.8	11.3
03/07/2023 04:00	26.31	14.3	417	12.5	165	11.2
03/07/2023 05:00	26.28	14.3	416.6	12.5	164.8	11.2
03/07/2023 06:00	25.78	14.3	416.4	12.3	164.8	10.9
03/07/2023 07:00	26.7	14.3	416.8	12.7	164.8	11.3
03/07/2023 08:00	26.28	14.3	417.2	12.5	164.8	11.2
03/07/2023 09:00	26.86	14.3	416.1	12.6	164.9	11.3
03/07/2023 10:00	27.1	14.3	416.3	12.8	164.7	11.5
03/07/2023 11:00	27.23	14.3	416.4	12.9	164.7	11.6
03/07/2023 12:00	27.44	14.3	415.1	13	164.8	11.6
03/07/2023 13:00	27.25	14.3	414.4	12.9	164.4	11.6
03/07/2023 14:00	29.08	14.3	415.2	13.8	164.2	12.3
03/07/2023 15:00	28.51	14.3	416.6	13.5	164.3	12.1
03/07/2023 16:00	27.95	14.3	416.4	13.3	164.6	11.9
03/07/2023 17:00	27.58	14.3	416.5	13.1	164.7	11.7

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
03/07/2023 18:00	27.92	14.3	415.4	13.3	164.6	11.9
03/07/2023 19:00	27.14	14.2	411.7	13	164.3	11.7
03/07/2023 20:00	25.91	14.2	415.9	12.4	164.9	11
03/07/2023 21:00	23.62	14.2	416	11.4	165.5	10
03/07/2023 22:00	22.95	14.2	414.5	11.1	165.3	9.7
03/07/2023 23:00	24.03	14.2	409.8	11.6	164.6	10.2
04/07/2023 00:00	24.22	14.2	408.4	11.7	164.3	10.3
04/07/2023 01:00	23.73	14.2	408.2	11.5	164.3	10.1
04/07/2023 02:00	23.78	14.2	408.3	11.5	164.3	10.1
04/07/2023 03:00	24.11	14.2	410.1	11.6	164.2	10.2
04/07/2023 04:00	24.76	14.2	410.4	11.9	164.5	10.5
04/07/2023 05:00	24.93	14.2	411.3	12	164.5	10.6
04/07/2023 06:00	24.45	14.2	409.7	11.8	164.7	10.4
04/07/2023 07:00	24.4	14.2	411.9	11.8	164.8	10.4
04/07/2023 08:00	27.24	14.3	417.1	13	164.9	11.6
04/07/2023 09:00	26.91	14.3	415	12.8	164.8	11.4
04/07/2023 10:00	27.7	14.3	414.2	12.9	164.7	11.5
04/07/2023 11:00	27.85	14.3	414.3	13.2	164.9	11.8
04/07/2023 12:00	28.99	14.3	412.6	13.7	164.5	12.3
04/07/2023 13:00	29.45	14.3	412.5	13.9	164.3	12.5
04/07/2023 14:00	29.89	14.3	413.6	14.1	164.5	12.7
04/07/2023 15:00	26.12	14.3	415.5	12.4	164.9	11.1
04/07/2023 16:00	24.7	14.3	415.3	11.7	164.7	10.5
04/07/2023 17:00	24.54	14.3	415.5	11.6	164.8	10.4
04/07/2023 18:00	24.36	14.3	416.1	11.6	164.8	10.3
04/07/2023 19:00	25.38	14.2	415.9	12.1	164.9	10.8
04/07/2023 20:00	25.06	14.3	417.1	11.9	164.9	10.6
04/07/2023 21:00	24.47	14.3	416.5	11.7	165.4	10.4
04/07/2023 22:00	24.32	14.2	412.2	11.7	165	10.3
04/07/2023 23:00	23.76	14.2	410.6	11.5	164.7	10.1
05/07/2023 00:00	23.47	14.2	410	11.3	164.5	10
05/07/2023 01:00	23.96	14.2	414	11.5	164.6	10.2
05/07/2023 02:00	24.16	14.2	413.5	11.6	164.7	10.3
05/07/2023 03:00	23.43	14.2	410.2	11.3	164.6	9.9
05/07/2023 04:00	23.47	14.2	409.4	11.4	164.5	10
05/07/2023 05:00	23.76	14.2	409	11.5	164.4	10.1
05/07/2023 06:00	23.67	14.1	408.1	11.5	164.2	10
05/07/2023 07:00	23.64	14.2	410	11.4	164.1	10
05/07/2023 08:00	25.93	14.3	415.3	12.4	164.5	11
05/07/2023 09:00	27.07	14.3	414.6	12.9	164.8	11.5
05/07/2023 10:00	27.65	14.3	412.4	13.1	164.4	11.7
05/07/2023 11:00	27.78	14.3	412.8	13.1	164.5	11.8
05/07/2023 12:00	28.32	14.3	408.2	13.4	164.4	11.2
05/07/2023 13:00	28.82	14.3	409	13.6	163.7	12.2
05/07/2023 14:00	27.28	14.3	410.1	12.9	163.9	11.6
05/07/2023 15:00	25.79	14.3	409.7	12.2	164.1	10.9
05/07/2023 16:00	26.85	14.3	412.1	12.7	164.4	11.4
05/07/2023 17:00	27.96	14.3	415.2	13.3	164.4	11.9
05/07/2023 18:00	27.32	14.3	416.4	13	164.6	11.6
05/07/2023 19:00	26.76	14.2	415.6	12.5	164.4	10.9
05/07/2023 20:00	25.3	14.2	418.3	12.1	164.8	10.7
05/07/2023 21:00	25.18	14.2	418.7	12.1	165.5	10.7
05/07/2023 22:00	24.69	14.2	416.4	11.9	165.3	10.5
05/07/2023 23:00	24.94	14.2	415.3	12	165.4	10.6
06/07/2023 00:00	25.57	14.2	414.8	12.3	165	10.9
06/07/2023 01:00	25.28	14.2	414.7	12.2	164.7	10.7
06/07/2023 02:00	25.24	14.2	413.8	12.2	164.7	10.7
06/07/2023 03:00	25.98	14.2	415.6	12.5	164.5	10.8
06/07/2023 04:00	26.09	14.2	414.1	12.6	164.8	11.1
06/07/2023 05:00	26.42	14.2	413.3	12.8	164.5	11.2
06/07/2023 06:00	26.97	14.2	414.5	13	164.9	11.4
06/07/2023 07:00	27.03	14.2	417.3	13	165	11.5
06/07/2023 08:00	26.24	14.3	418.4	12.5	165.1	11.1
06/07/2023 09:00	27.45	14.3	415.9	13	164.9	11.7
06/07/2023 10:00	29.27	14.3	414	13.8	164.3	12.4
06/07/2023 11:00	29.58	14.3	412.1	14	164.7	12.6

Site Report - GPSC CUP2 HRS01						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
06/07/2023 12:00	24.38	14.3	410.3	11.5	164.5	10.3
06/07/2023 13:00	23.17	14.3	410.2	11	163.9	9.8
06/07/2023 14:00	23.99	14.3	409.7	11.3	163.9	10
06/07/2023 15:00	23.74	14.3	409.9	11.2	163.9	10.1
06/07/2023 16:00	23.48	14.3	411.2	11.1	163.9	10
06/07/2023 17:00	22.95	14	412	11.4	157.3	9.7
06/07/2023 18:00	23.69	14.2	414.9	11.5	158.6	10.1
06/07/2023 19:00	23.85	14.3	417.6	11.4	164.7	10.1
06/07/2023 20:00	24.68	14.3	418.3	11.8	164.5	10.5
06/07/2023 21:00	26.01	14.3	419.2	12.4	164.9	11
06/07/2023 22:00	24.39	14.3	419	11.7	164.9	10.4
06/07/2023 23:00	23.95	14.3	420.1	11.5	165.3	10.2
07/07/2023 00:00	25.91	14.3	420.3	12.4	165.3	11
07/07/2023 01:00	27.19	14.3	420.6	13	165.5	11.5
07/07/2023 02:00	27.41	14.2	421.2	13.1	165.6	11.6
07/07/2023 03:00	28.02	14.2	420.6	13.4	165.5	11.9
07/07/2023 04:00	27.91	14.2	419.3	13.4	165.4	11.8
07/07/2023 05:00	28.33	14.2	419.3	13.6	165.6	12
07/07/2023 06:00	28.62	14.2	419.7	13.7	165.7	12.1
07/07/2023 07:00	27.52	14.3	418.8	13.2	165.7	11.7
07/07/2023 08:00	26.92	14.3	417	12.9	165.3	11.4
07/07/2023 09:00	26.83	14.3	415.3	12.8	165.2	11.4
07/07/2023 10:00	27.04	14.3	413.2	12.9	164.6	11.5
07/07/2023 11:00	26.28	14.3	410.8	12.5	164.5	11.2
07/07/2023 12:00	25.64	14.3	412.9	12.2	164	10.9
07/07/2023 13:00	27.03	14.2	415	13	163.8	11.5
07/07/2023 14:00	26.63	14.2	416.9	12.6	164.5	11.6
07/07/2023 15:00	27.3	14.2	417.1	13.1	164.9	11.6
07/07/2023 16:00	27.12	14.2	418.7	13	165.6	11.6
07/07/2023 17:00	27.24	14.3	414.5	13	164.4	11.5
07/07/2023 18:00	27.87	14.3	415	13.3	164.1	11.8
07/07/2023 19:00	28.26	14.3	416.1	13.5	164.3	12
07/07/2023 20:00	29.05	14.3	416.2	13.9	164.4	12.3
07/07/2023 21:00	29.11	14.3	416.9	13.9	164.6	12.4
07/07/2023 22:00	29.01	14.3	417.4	13.9	164.3	12.3
07/07/2023 23:00	28.93	14.3	417.7	13.8	164.6	12.3
08/07/2023 00:00	29.1	14.3	418.1	13.9	164.8	12.4
08/07/2023 01:00	29.69	14.3	418.4	14.2	164.9	12.6
08/07/2023 02:00	29.79	14.3	418.9	14.3	165.3	12.6
08/07/2023 03:00	29.17	14.2	419.6	14	165.7	12.4
08/07/2023 04:00	28.77	14.2	418.9	13.8	165.7	12.2
08/07/2023 05:00	24.74	14.1	409.9	12.1	161.7	10.5
08/07/2023 06:00	23.19	14.2	403	11.2	162.8	9.8
08/07/2023 07:00	27.88	14.2	418.4	11	165	9.7
08/07/2023 08:00	22.88	14.2	418.7	11	166	9.7
08/07/2023 09:01	23.01	14.2	418.8	11	166.1	9.8
08/07/2023 10:00	23.62	14.2	419.9	11.3	166	10
08/07/2023 11:00	23.4	14.3	417.9	11.2	165.4	9.9
08/07/2023 12:00	25	14.1	417.6	12.2	162.1	10.6
08/07/2023 13:00	25.34	13.8	414.4	13	151.8	10.8
08/07/2023 14:00	25.97	13.9	415.5	13	155.9	11
08/07/2023 15:00	25.81	13.9	416	13	156.3	11
08/07/2023 16:00	25.1	14.2	419.1	12.2	161.4	10.7
08/07/2023 17:00	23.97	14.2	418.5	11.5	165.5	10.2
08/07/2023 18:00	23.78	14.3	418.4	11.4	165.1	10.1
08/07/2023 19:00	23.95	14.3	418.7	11.4	164.7	10.2
08/07/2023 20:00	24.64	14.3	419.9	11.8	165.1	10.5
08/07/2023 21:00	25.08	14.3	419	12	164.9	10.6
08/07/2023 22:00	25.51	14.3	419.1	12.2	164.8	10.8
08/07/2023 23:00	25.48	14.3	420.5	12.2	165.2	10.8
09/07/2023 00:00	24.67	14.3	420.2	11.8	165.4	10.5
09/07/2023 01:00	24.26	14.2	421.6	11.6	165.8	10.4
09/07/2023 02:00	23.04	14.2	419.2	11.1	165.7	9.8
09/07/2023 03:00	22.77	14.2	416.7	11	165.1	9.7
09/07/2023 04:00	22.93	14.2	416.6	11.1	165	9.7
09/07/2023 05:00	23.09	14.2	415.4	11.1	165	9.8

Site Report - GPSC CUP2 HRSG1							
Date&Time	NOx@7%O2		O2		Flow		NOx@15%O2
	ppm	%Vol	km3/h	ppm	ppm	Deg C	
12/07/2023 00:00	24.28	14.2	410.7	11.7	164.9	10.3	
12/07/2023 01:00	23.36	14.2	412.2	11.3	164.6	9.9	
12/07/2023 02:00	23.8	14.2	411.7	11.5	164.3	10.1	
12/07/2023 03:00	24.44	14.2	411.5	11.8	164.3	10.4	
12/07/2023 04:00	25	14.2	411.4	12	164.2	10.6	
12/07/2023 05:00	26.01	14.2	410.8	12.5	164.6	11	
12/07/2023 06:00	26.57	14.2	411.5	12.8	164.7	11.3	
12/07/2023 07:00	26.73	14.2	413.7	12.8	164.8	11.3	
12/07/2023 08:00	23.01	13.7	414.5	11.8	156.5	9.8	
12/07/2023 09:00	21.46	12.1	419.7	13.6	139.9	10	
12/07/2023 10:00	23.46	12.6	416.9	14	136.5	10	
12/07/2023 11:00	25	12.7	415.7	14.7	138.4	10.6	
12/07/2023 12:00	26.46	12.7	413.9	15.6	138.8	11.2	
12/07/2023 13:00	25.99	12.7	414.3	15.3	138.1	11	
12/07/2023 14:00	26.18	12.7	413.6	15.5	137.5	11.1	
12/07/2023 15:00	26.47	12.7	412.9	15.6	138	11.2	
12/07/2023 16:00	27.49	12.7	414.9	16.2	138	11.7	
12/07/2023 17:00	26.06	12.7	416.4	15.4	138.3	11.1	
12/07/2023 18:00	25.61	12.8	418.6	15	139.3	10.9	
12/07/2023 19:00	26.12	12.8	420.7	15.2	139.9	11.1	
12/07/2023 20:00	26.25	12.8	422	15.3	140	11.1	
12/07/2023 21:00	26.3	12.8	422.3	15.3	140	11.2	
12/07/2023 22:00	26.16	12.8	421.6	15.3	139.7	11.1	
12/07/2023 23:00	26.26	12.8	422.3	15.3	139.7	11.1	
13/07/2023 00:00	24.81	13	410.6	14.1	142.1	10.5	
13/07/2023 01:00	23.45	13.3	409.5	12.8	145.3	10	
13/07/2023 02:00	22.57	13.3	409.4	12.4	145.4	9.6	
13/07/2023 03:00	22.49	13.2	408.2	12.4	145.1	9.5	
13/07/2023 04:00	22.45	13.2	406.8	12.4	145.2	9.5	
13/07/2023 05:00	22.63	13.2	406.3	12.6	144.6	9.6	
13/07/2023 06:00	23.39	13.2	406.6	13	144.5	9.9	
13/07/2023 07:00	24.89	13.3	409.8	13.7	144.6	10.8	
13/07/2023 08:00	25.39	13.3	413.8	13.9	144.9	10.8	
13/07/2023 09:00	27.36	13.4	416.6	14.9	145.7	11.6	
13/07/2023 10:00	28.15	13.4	416.2	15.3	145.2	11.9	
13/07/2023 11:00	28.04	13.4	415	15.2	145.4	11.9	
13/07/2023 12:00	29.7	13.4	412.6	16.1	145.4	12.6	
13/07/2023 13:00	29.24	13.4	413.3	15.3	144.7	12	
13/07/2023 14:00	24.32	13.3	413.7	13.2	144.8	10.3	
13/07/2023 15:00	26.47	13.3	414.7	14.4	143.9	11.2	
13/07/2023 16:00	18.5	13.6	375.7	9.8	146.2	7.9	
13/07/2023 17:00	20.73	13.6	380.3	10.8	149.1	9.1	
13/07/2023 18:00	23.32	13.9	349.8	11.8	149	9.9	
13/07/2023 19:00	25.66	13.9	349.9	12.9	151	10.9	
13/07/2023 20:00	26.58	13.9	349.7	13.4	151.1	11.3	
13/07/2023 21:00	26.26	13.9	349.4	13.2	150.6	11.1	
13/07/2023 22:00	26	13.9	349.6	13.1	150.8	11	
13/07/2023 23:00	26.19	13.9	348.8	13.2	151.3	11.1	
14/07/2023 00:00	25.89	13.9	348.6	13.1	151.5	11	
14/07/2023 01:00	26.88	13.9	348.7	13.5	151.3	11.3	
14/07/2023 02:00	27.85	13.9	348.5	14.1	151.3	11.3	
14/07/2023 03:00	28.89	13.9	348.2	14.5	151.1	12.2	
14/07/2023 04:00	29.03	13.9	348.7	14.6	151.7	12.3	
14/07/2023 05:00	25.01	13.9	348	12.6	152	10.6	
14/07/2023 06:00	24.2	13.9	347.8	12.2	151.2	10.3	
14/07/2023 07:00	24.05	13.9	348.7	12.1	150.8	10.2	
14/07/2023 08:00	23.99	13.9	350.4	12	150.6	10.2	
14/07/2023 09:00	23.77	13.9	351.1	12.3	151.5	10.5	
14/07/2023 10:00	24.8	14	351.5	12.3	151.5	10.5	
14/07/2023 11:00	24.9	14	351.6	12.4	151.7	10.6	
14/07/2023 12:00	25.04	14	352.4	12.4	151.6	10.6	
14/07/2023 13:00	24.99	14	392.5	12.4	150.9	10.6	
14/07/2023 14:00	24.93	14	365.9	12.4	150.5	10.6	
14/07/2023 15:00	25.45	14	375.6	12.7	151.2	10.8	
14/07/2023 16:00	23.52	13.9	379.8	11.9	150	10	
14/07/2023 17:00	22.77	13.8	369.7	11.5	149.3	9.7	

Site Report - GPSC CUP2 HRSG1							
Date&Time	NOx@7%O2		O2		Flow		NOx@15%O2
	ppm	%Vol	km3/h	ppm	ppm	Deg C	
14/07/2023 18:00	22.09	13.8	369.5	11.2	150.5	9.4	
14/07/2023 19:00	21.27	13.7	372.3	11.3	149.9	9.6	
14/07/2023 20:00	22.69	13.8	372.6	11.6	149	9.6	
14/07/2023 21:00	22.83	13.6	375	11.9	147.8	9.7	
14/07/2023 22:00	23.14	13.6	386.7	12.1	147.4	9.8	
14/07/2023 23:00	26.16	13.7	415.2	13.6	147.7	11.1	
15/07/2023 00:00	27.31	13.7	374.7	14.2	147.4	11.6	
15/07/2023 01:00	26.77	13.7	390.2	13.9	147.5	11.4	
15/07/2023 02:00	28.84	13.7	407.6	14	147.8	11.4	
15/07/2023 03:00	26.64	13.7	397.7	13.9	147.6	11.3	
15/07/2023 04:00	26.4	13.7	375.9	13.8	147.6	11.2	
15/07/2023 05:00	27.02	13.6	382.9	14.2	147.4	11.5	
15/07/2023 06:00	26.22	13.6	384.5	13.7	147.7	11.1	
15/07/2023 07:00	25.7	13.7	373.1	13.2	148.4	10.9	
15/07/2023 08:00	25.42	13.8	360.9	13	149.1	10.8	
15/07/2023 09:00	25.89	13.8	356.9	13.2	148.7	11	
15/07/2023 10:00	25.99	13.9	351.1	13.2	149.3	11	
15/07/2023 11:00	24.51	13.9	351.2	12.4	148.2	10.4	
15/07/2023 12:00	23.55	13.9	351.1	11.9	149	10	
15/07/2023 13:00	22.77	13.9	351.4	11.5	149.4	9.7	
15/07/2023 14:00	22.32	13.9	352	11.2	150.6	9.5	
15/07/2023 15:00	22.56	13.9	352.8	11.4	148.4	9.6	
15/07/2023 16:00	22.63	13.4	353	12.3	144.7	9.6	
15/07/2023 17:00	25.67	12.9	352.9	14.8	137.3	10.9	
15/07/2023 18:00	26.79	12.8	351.9	15.6	136.7	11.4	
15/07/2023 19:00	25.9	12.8	351.6	15.1	136.6	11	
15/07/2023 20:00	25.01	12.8	351.7	14.6	136.6	10.6	
15/07/2023 21:00	24.61	12.8	351.3	14.4	136.7	10.4	
15/07/2023 22:00	24.49	12.7	350.2	14.4	136.7	10.4	
15/07/2023 23:00	25.74	12.7	350	15.2	135.9	10.9	
16/07/2023 00:00	28.72	12.9	350.6	16.6	136.9	12.2	
16/07/2023 01:00	29.13	12.9	350.1	16.7	138.1	12.4	
16/07/2023 02:00	29.08	13	349.9	16.6	138.5	12.3	
16/07/2023 03:00	28.49	12.8	356.6	15.5	137.1	11.2	
16/07/2023 04:00	20.4	12.4	368.6	12.4	134.4	8.4	
16/07/2023 05:00	19.58	12.3	353.9	12.1	131.8	8.3	
16/07/2023 06:00	16.32	13.9	341.2	8.7	141	6.9	
16/07/2023 07:00	23.07	16.5	323.9	7.2	175.1	9.8	
16/07/2023 08:00	<Samp	<Samp	<Samp	<Samp	177.1	<Samp	
16/07/2023 09:00	Maintain	Maintain	Alarm	Maintain	182	Maintain	
16/07/2023 10:00	Maintain	Maintain	Alarm	Maintain	178.3	Maintain	
16/07/2023 11:00	Maintain	Maintain	Alarm	Maintain	178.5	Maintain	
16/07/2023 12:00	Maintain	Maintain	Alarm	Maintain	190.8	Maintain	
16/07/2023 13:00	Maintain	Maintain	Alarm	Maintain	180.8	Maintain	
16/07/2023 14:00	Maintain	Maintain	Alarm	Maintain	176.9	Maintain	
16/07/2023 15:00	Maintain	Maintain	Alarm	Maintain	175.9	Maintain	
16/07/2023 16:00	Maintain	Maintain	Alarm	Maintain	178.9	Maintain	
16/07/2023 17:00	Maintain	Maintain	Alarm	Maintain	181.4	Maintain	
16/07/2023 18:00	Maintain	Maintain	Alarm	Maintain	182.2	Maintain	
16/07/2023 19:00	Maintain	Maintain	Alarm	Maintain	182.9	Maintain	
16/07/2023 20:00	Maintain	Maintain	Alarm	Maintain	181.8	Maintain	
16/07/2023 21:00	Maintain	Maintain	Alarm	Maintain	181.9	Maintain	
16/07/2023 22:00	Maintain	Maintain	Alarm	Maintain	182.3	Maintain	
16/07/2023 23:00	Maintain	Maintain	Alarm	Maintain	182	Maintain	
17/07/2023 00:00	Maintain	Maintain	Alarm	Maintain	182.3	Maintain	
17/07/2023 01:00	Maintain	Maintain	Alarm	Maintain	183	Maintain	
17/07/2023 02:00	Maintain	Maintain	Alarm	Maintain	183.2	Maintain	
17/07/2023 03:00	Maintain	Maintain	Alarm	Maintain	182.9	Maintain	
17/07/2023 04:00	Maintain	Maintain	Alarm	Maintain	183	Maintain	
17/07/2023 05:00	Maintain	Maintain	Alarm	Maintain	183.3	Maintain	
17/07/2023 06:00	Maintain	Maintain	Alarm	Maintain	183	Maintain	
17/07/2023 07:00	Maintain	Maintain	Alarm	Maintain	183.5	Maintain	
17/07/2023 08:00	Maintain	Maintain	Alarm	Maintain	182.9	Maintain	
17/07/2023 09:00	Maintain	Maintain	Alarm	Maintain	181.9	Maintain	
17/07/2023 10:00	Maintain	Maintain	Alarm	Maintain	182	Maintain	
17/07/2023 11:00	Maintain	Maintain	Alarm	Maintain	178.7	Maintain	

Site Report - GPSC CUP2 HRSG1							
Date&Time	NOx@7%O2		O2		Flow		NOx@15%O2
	ppm	%Vol	km3/h	ppm	ppm	Deg C	
17/07/2023 12:00	Maintain	Maintain	Alarm	Maintain	178.8		
17/07/2023 13:00	Maintain	Maintain	Alarm	Maintain	184.5		
17/07/2023 14:00	Maintain	Maintain	Alarm	Maintain	185.4		
17/07/2023 15:00	Maintain	Maintain	Alarm	Maintain	185.4		
17/07/2023 16:00	Maintain	Maintain	Alarm	Maintain	186.2		
17/07/2023 17:00	Maintain	Maintain	Alarm	Maintain	188.4		
17/07/2023 18:00	Maintain	Maintain	Alarm	Maintain	189.2		
17/07/2023 19:00	Maintain	Maintain	Alarm	Maintain	189.5		
17/07/2023 20:00	Maintain	Maintain	Alarm	Maintain	189.9		</

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
01/08/2023 00:00	Maintain	Maintain	Alarm	Maintain	31.5	Maintain
01/08/2023 01:00	Maintain	Maintain	Alarm	Maintain	29.3	Maintain
01/08/2023 02:00	Maintain	Maintain	Alarm	Maintain	29.2	Maintain
01/08/2023 03:00	Maintain	Maintain	Alarm	Maintain	29.1	Maintain
01/08/2023 04:00	Maintain	Maintain	Alarm	Maintain	29	Maintain
01/08/2023 05:00	Maintain	Maintain	Alarm	Maintain	28.9	Maintain
01/08/2023 06:00	Maintain	Maintain	Alarm	Maintain	28.9	Maintain
01/08/2023 07:00	Maintain	Maintain	Alarm	Maintain	29.6	Maintain
01/08/2023 08:00	Maintain	Maintain	Alarm	Maintain	30.6	Maintain
01/08/2023 09:00	Maintain	Maintain	Alarm	Maintain	31.6	Maintain
01/08/2023 10:00	Maintain	Maintain	Alarm	Maintain	32.1	Maintain
01/08/2023 11:00	Maintain	Maintain	Alarm	Maintain	32.4	Maintain
01/08/2023 12:00	Maintain	Maintain	Alarm	Maintain	33.1	Maintain
01/08/2023 13:00	Maintain	Maintain	Alarm	Maintain	34.4	Maintain
01/08/2023 14:00	Maintain	Maintain	Alarm	Maintain	34.5	Maintain
01/08/2023 15:00	Maintain	Maintain	Alarm	Maintain	34.6	Maintain
01/08/2023 16:00	Maintain	Maintain	Alarm	Maintain	33.2	Maintain
01/08/2023 17:00	Maintain	Maintain	Alarm	Maintain	31.8	Maintain
01/08/2023 18:00	0	21.1	0.1	0.2	30.8	0
01/08/2023 19:00	0	21.1	0.1	0.1	31.1	0
01/08/2023 20:00	0	21.1	0.1	0	31.4	0
01/08/2023 21:00	0	21.1	0.1	0	31.5	0
01/08/2023 22:00	0	21.1	0.1	0.1	32.1	0
01/08/2023 23:00	0	21.1	0.1	0.3	33.1	0
02/08/2023 00:00	90.59	18.8	282.1	15.7	109	38.5
02/08/2023 01:00	135.45	17.3	330.3	35.3	200.6	57.5
02/08/2023 02:00	141.12	17.1	329	38.5	205	59.9
02/08/2023 03:00	138.09	17.1	328.8	37.7	202.3	58.6
02/08/2023 04:00	137.51	17.1	328.4	37.6	199.5	58.4
02/08/2023 05:00	159.74	15.8	330	58.1	185.7	67.8
02/08/2023 06:00	67.3	15.9	336.4	20.6	186.7	24.3
02/08/2023 07:00	56.93	15.9	336.3	20.5	187.3	24.2
02/08/2023 08:00	65.63	15.9	335.1	23.6	187.1	27.9
02/08/2023 09:00	71.25	15.7	358.5	26.6	183.7	30.2
02/08/2023 10:00	74.84	15.6	395.1	28.3	181	31.8
02/08/2023 11:00	64.47	15.9	353.2	23.3	185.1	27.4
02/08/2023 12:00	66.18	15.8	314.4	24.2	185.2	28.1
02/08/2023 13:00	71.94	15.9	317.9	26	185.7	30.5
02/08/2023 14:00	78.21	14.6	369	35.8	165.3	33.2
02/08/2023 15:00	82.75	13.2	453.7	46.1	123.8	35.1
02/08/2023 16:00	<Samp	<Samp	<Samp	<Samp	109.4	<Samp
02/08/2023 17:00	Maintain	Maintain	Alarm	Maintain	123.4	Maintain
02/08/2023 18:00	Maintain	Maintain	Alarm	Maintain	124.4	Maintain
02/08/2023 19:00	Maintain	Maintain	Alarm	Maintain	148.2	Maintain
02/08/2023 20:00	Maintain	Maintain	Alarm	Maintain	149	Maintain
02/08/2023 21:00	Maintain	Maintain	Alarm	Maintain	147.5	Maintain
02/08/2023 22:00	Maintain	Maintain	Alarm	Maintain	147.3	Maintain
02/08/2023 23:00	Maintain	Maintain	Alarm	Maintain	147.2	Maintain
03/08/2023 00:00	Maintain	Maintain	Alarm	Maintain	142.9	Maintain
03/08/2023 01:00	Maintain	Maintain	Alarm	Maintain	142.1	Maintain
03/08/2023 02:00	Maintain	Maintain	Alarm	Maintain	141.7	Maintain
03/08/2023 03:00	Maintain	Maintain	Alarm	Maintain	141.3	Maintain
03/08/2023 04:00	Maintain	Maintain	Alarm	Maintain	141.9	Maintain
03/08/2023 05:00	Maintain	Maintain	Alarm	Maintain	141.9	Maintain
03/08/2023 06:00	Maintain	Maintain	Alarm	Maintain	142.6	Maintain
03/08/2023 07:00	Maintain	Maintain	Alarm	Maintain	141.9	Maintain
03/08/2023 08:00	Maintain	Maintain	Alarm	Maintain	141.5	Maintain
03/08/2023 09:00	Maintain	Maintain	Alarm	Maintain	141.7	Maintain
03/08/2023 10:00	Maintain	Maintain	Alarm	Maintain	143.8	Maintain

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
03/08/2023 11:00	Maintain	Maintain	Alarm	Maintain	143.8	Maintain
03/08/2023 12:00	Maintain	Maintain	Alarm	Maintain	143.1	Maintain
03/08/2023 13:00	Maintain	Maintain	Alarm	Maintain	142.7	Maintain
03/08/2023 14:00	Maintain	Maintain	Alarm	Maintain	142.9	Maintain
03/08/2023 15:00	Maintain	Maintain	Alarm	Maintain	142.6	Maintain
03/08/2023 16:00	Maintain	Maintain	Alarm	Maintain	142.8	Maintain
03/08/2023 17:00	Maintain	Maintain	Alarm	Maintain	143.1	Maintain
03/08/2023 18:00	Maintain	Maintain	Alarm	Maintain	143.5	Maintain
03/08/2023 19:00	Maintain	Maintain	Alarm	Maintain	143.1	Maintain
03/08/2023 20:00	Maintain	Maintain	Alarm	Maintain	143.3	Maintain
03/08/2023 21:00	Maintain	Maintain	Alarm	Maintain	143.3	Maintain
03/08/2023 22:00	Maintain	Maintain	Alarm	Maintain	143.7	Maintain
03/08/2023 23:00	Maintain	Maintain	Alarm	Maintain	143	Maintain
04/08/2023 00:00	Maintain	Maintain	Alarm	Maintain	143.3	Maintain
04/08/2023 01:00	Maintain	Maintain	Alarm	Maintain	143.1	Maintain
04/08/2023 02:00	Maintain	Maintain	Alarm	Maintain	143.1	Maintain
04/08/2023 03:00	Maintain	Maintain	Alarm	Maintain	143.2	Maintain
04/08/2023 04:00	Maintain	Maintain	Alarm	Maintain	143.4	Maintain
04/08/2023 05:00	Maintain	Maintain	Alarm	Maintain	143.4	Maintain
04/08/2023 06:00	Maintain	Maintain	Alarm	Maintain	143.5	Maintain
04/08/2023 07:00	<Samp	<Samp	<Samp	<Samp	143.3	<Samp
04/08/2023 08:00	22.38	13.4	371.9	12.1	143.4	9.5
04/08/2023 09:00	21.94	13.4	372.3	11.9	143.9	9.3
04/08/2023 10:00	22.15	13.4	373.1	11.9	143.9	9.4
04/08/2023 11:00	22.55	13.4	373.6	12.1	144.3	9.6
04/08/2023 12:00	24.01	13.4	374.5	12.9	144	10.2
04/08/2023 13:00	24.62	13.4	398	13.2	143.1	10.5
04/08/2023 14:00	<Samp	<Samp	<Samp	<Samp	143.6	<Samp
04/08/2023 15:00	Maintain	Maintain	Alarm	Maintain	144.5	Maintain
04/08/2023 16:00	Maintain	Maintain	Alarm	Maintain	143.1	Maintain
04/08/2023 17:00	<Samp	<Samp	<Samp	<Samp	143.2	<Samp
04/08/2023 18:00	18.77	13.4	391.4	10.1	143.5	8
04/08/2023 19:00	18.57	13.4	392.5	10.1	143.7	7.9
04/08/2023 20:00	18.84	13.4	389.5	10.2	143.1	8
04/08/2023 21:00	19.23	13.4	389.3	10.4	143.5	8.2
04/08/2023 22:00	19.91	13.4	391.1	10.8	143.4	8.5
04/08/2023 23:00	22.95	12.5	414.8	13.9	136.2	9.7
05/08/2023 00:00	25.03	12.5	445.8	15	137.1	10.6
05/08/2023 01:00	24.69	12.5	445.3	14.8	136.9	10.5
05/08/2023 02:00	25.77	12.5	458.9	15.5	136.3	10.9
05/08/2023 03:00	25.3	12.5	459.6	15.3	136.3	10.7
05/08/2023 04:00	25.5	12.5	448.6	15.5	135.9	10.8
05/08/2023 05:00	25.59	12.3	458.3	15.9	134.7	10.9
05/08/2023 06:00	25.08	12.3	462.4	15.6	135.1	10.6
05/08/2023 07:00	25.07	12.3	460.8	15.5	135.3	10.6
05/08/2023 08:00	23.3	12.2	455.3	14.5	134.2	9.9
05/08/2023 09:00	24.03	12.3	451.6	14.9	134.3	10.2
05/08/2023 10:00	24.41	12.3	429.1	15.1	134	10.4
05/08/2023 11:00	24.89	12.3	433.1	15.4	134.4	10.6
05/08/2023 12:00	24.01	12.2	411.1	15.1	132.7	10.2
05/08/2023 13:00	23.4	12.1	407	14.8	132.3	9.9
05/08/2023 14:00	20.74	12	406.2	13.3	131.6	8.8
05/08/2023 15:00	23.71	12	407.2	15.2	131.5	10.1
05/08/2023 16:00	13.94	14	390.2	7.4	144.9	5.9
05/08/2023 17:00	7.95	15.4	357.4	3.2	165.2	3.4
05/08/2023 18:00	8.24	15.5	356.5	3.2	167.3	3.5
05/08/2023 19:00	10.2	15.5	366.1	4	167.6	4.3
05/08/2023 20:00	16.89	14.1	386.9	8.4	154.5	7.2
05/08/2023 21:00	20.09	13.7	406.6	10.5	145.5	8.5

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
05/08/2023 22:00	21.06	13.7	396.3	11	145.3	8.9
05/08/2023 23:00	14.45	15.2	376.5	6	163.6	6.1
06/08/2023 00:00	16.92	15.1	366.5	7.1	170.3	7.2
06/08/2023 01:00	17.38	15.1	387.3	7.3	169.5	7.4
06/08/2023 02:00	18.88	15	376.5	8.1	168.3	8
06/08/2023 03:00	20.39	14.9	377.6	8.8	167	8.7
06/08/2023 04:00	20.63	14.9	374.9	8.9	167.1	8.8
06/08/2023 05:00	20.39	14.9	381.5	8.8	167	8.7
06/08/2023 06:00	20.62	14.9	353.3	8.9	166.9	8.8
06/08/2023 07:00	20.12	14.9	369.1	8.7	167.2	8.5
06/08/2023 08:00	19.3	15	363.5	8.2	166.8	8.2
06/08/2023 09:00	16.03	15.3	361.6	6.5	168.2	6.8
06/08/2023 10:00	14.46	15.4	355.8	5.7	170.4	6.1
06/08/2023 11:00	14.06	15.4	349.9	5.6	170.1	6
06/08/2023 12:00	16.86	14.9	361.2	7.3	164.5	7.2
06/08/2023 13:00	17.75	14.8	368.6	7.7	162.7	7.5
06/08/2023 14:00	16.4	15	359.7	6.9	163.7	7
06/08/2023 15:00	14.69	15.3	340.5	5.9	166.3	6.2
06/08/2023 16:00	16.1	15.3	348.5	6.5	167.4	6.8
06/08/2023 17:00	16.8	15.3	345.8	6.8	167.8	7.1
06/08/2023 18:00	18.32	14.9	380.5	7.9	161	7.8
06/08/2023 19:00	19.13	15.1	378.3	8	161.5	8.1
06/08/2023 20:00	22.02	15.1	350	9.2	169.6	9.3
06/08/2023 21:00	23.24	15.1	354.9	9.7	170	9.9
06/08/2023 22:00	23.62	15.1	364.1	9.9	170.3	10
06/08/2023 23:00	25.04	15	375.3	10.7	167.2	10.6
07/08/2023 00:00	24.9	15.1	386.5	10.4	169.5	10.6
07/08/2023 01:00	24.3	15.1	394.7	10.2	170	10.3
07/08/2023 02:00	24.5	15.1	388.3	10.3	169.6	10.4
07/08/2023 03:00	24.53	15.1	368.5	10.3	169.5	10.4
07/08/2023 04:00	24.42	15.1	380.4	10.2	169.6	10.4
07/08/2023 05:00	24.41	15.1	401.6	10.2	169.4	10.4
07/08/2023 06:00	24.66	15.1	378.5	10.3	169.5	10.5
07/08/2023 07:00	24.6	15.1	378.1	10.3	169.4	10.4
07/08/2023 08:00	24.12	15.1	373.3	10.1	169	10.2
07/08/2023 09:00	23.71	15	362.6	10	168.6	10.1
07/08/2023 10:00	23.45	15	351.3	9.9	168	10
07/08/2023 11:00	23.08	15	371.7	9.7	167.7	9.8
07/08/2023 12:00	22.88	15	373.8	9.7	167.4	9.7
07/08/2023 13:00	23.16	15	355.3	9.8	167.4	9.8
07/08/2023 14:00	22.11	15	333.4	9.3	167.8	9.4
07/08/2023 15:00	17.51	15	354.5	7.4	167.9	7.4
07/08/2023 16:00	18.07	15	365.3	7.6	168	7.7
07/08/2023 17:00	18.49	15	357.3	7.8	168.3	7.8
07/08/2023 18:00	20.27	14.6	372.6	9.2	161.9	8.6
07/08/2023 19:00	23.32	14.1	398.1	11.4	146.2	9.9
07/08/2023 20:00	22.96	14.1	385.9	11.3	145.1	9.7
07/08/2023 21:00	21.4	14.4	388.3	10	150.1	9.1
07/08/2023 22:00	21.42	14.5	385.3	9.9	152.2	9.1
07/08/2023 23:00	21.06	14.6	376	9.6	153.6	8.9
08/08/2023 00:00	20.03	14.7	377.8	8.9	156.2	8.5
08/08/2023 01:00	21.8	14.7	374.3	9.7	156.2	9.3
08/08/2023 02:00	24.35	14.7	377.3	10.8	156.5	10.3
08/08/2023 03:00	25.05	14.7	384.9	11.2	156.6	10.6
08/08/2023 04:00	25.65	14.7	378.2	11.4	156.6	10.9
08/08/2023 05:00	25.85	14.7	378.4	11.5	156.5	11
08/08/2023 06:00	26.76	14.6	376.7	12.1	155.4	11.4
08/08/2023 07:00	25.9	14.6	374.1	11.8	155	11
08/08/2023 08:00	23.81	14.6	366	10.9	154.9	10.1

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
10/08/2023 20:00	26.39	14.5	352.9	12.1	166.6	11.2
10/08/2023 21:00	27.2	14.5	352.8	12.4	166.6	11.5
10/08/2023 22:00	27.69	14.6	352.3	12.6	166.4	11.8
10/08/2023 23:00	27.92	14.5	352	12.8	166.6	11.9
11/08/2023 00:00	28	14.5	351.6	12.8	166.5	11.9
11/08/2023 01:00	28.85	14.5	351.6	13.2	166.3	12.2
11/08/2023 02:00	28.89	14.5	350.8	13.2	166.5	12.3
11/08/2023 03:00	24.85	14.5	350.9	11.4	166.4	10.5
11/08/2023 04:00	24.81	14.5	350.6	11.4	166.3	10.5
11/08/2023 05:00	24.51	14.5	350.6	11.2	166.2	10.4
11/08/2023 06:00	24.56	14.5	350.9	11.3	166.4	10.4
11/08/2023 07:00	24.35	14.5	351.3	11.2	166.6	10.3
11/08/2023 08:00	23.47	14.5	352.3	10.7	166.7	10
11/08/2023 09:00	23.33	14.6	352.9	10.6	166.9	9.9
11/08/2023 10:00	23.08	14.6	354.1	10.5	166.9	9.8
11/08/2023 11:00	22.85	14.6	353.4	10.4	167	9.7
11/08/2023 12:00	22.7	14.6	354.3	10.3	167.1	9.6
11/08/2023 13:00	22.68	14.6	354.9	10.3	167.1	9.6
11/08/2023 14:00	22.41	14.6	354.9	10.2	167.2	9.5
11/08/2023 15:00	22.22	14.6	354.6	10.1	167	9.4
11/08/2023 16:00	23.59	14.6	361	10.7	167.5	10
11/08/2023 17:00	26.94	14.6	376	12.2	169.2	11.4
11/08/2023 18:00	22.32	14.5	395	10.4	167.7	9.5
11/08/2023 19:00	22.58	14.3	397.8	10.7	163.2	9.6
11/08/2023 20:00	19.84	14.3	390.1	9.5	161.6	8.4
11/08/2023 21:00	18	14.2	375	8.6	159.8	7.6
11/08/2023 22:00	20.41	14.2	380	9.8	160.7	8.7
11/08/2023 23:00	21.21	14.2	381.8	10.2	160.7	9
12/08/2023 00:00	24.57	14.3	389.3	11.7	161.6	10.4
12/08/2023 01:00	27.31	14.3	390.6	13	161.7	11.6
12/08/2023 02:00	26.56	14.3	389.9	12.7	161.7	11.3
12/08/2023 03:00	24.98	14.3	389	11.9	161.8	10.6
12/08/2023 04:00	25.34	14.2	388.4	12.1	161.7	10.8
12/08/2023 05:00	26.86	14.3	390.1	12.8	161.7	11.4
12/08/2023 06:00	25.08	14.3	389.8	12	161.7	10.6
12/08/2023 07:00	24.56	14.3	390.6	11.7	161.9	10.4
12/08/2023 08:00	26.27	14.3	392.2	12.5	161.8	11.2
12/08/2023 09:00	24.42	14.2	393.1	11.7	160.4	10.4
12/08/2023 10:00	23.85	14.2	394.6	11.5	159.3	10.1
12/08/2023 11:00	23.6	14.2	395.2	11.4	159.1	10
12/08/2023 12:00	24.93	14.2	409.5	12.1	157.9	10.6
12/08/2023 13:00	24.93	13.7	418.2	12.9	150.3	10.6
12/08/2023 14:00	25.1	13.8	418.9	12.9	149.6	10.7
12/08/2023 15:00	24.99	13.9	419.5	12.6	151.8	10.6
12/08/2023 16:00	25.18	13.9	419.9	12.7	151.5	10.7
12/08/2023 17:00	25.03	14	417.9	12.4	154.8	10.6
12/08/2023 18:00	25.08	14.2	414.9	12.1	160.4	10.6
12/08/2023 19:00	26.88	14.2	412.5	13	159.9	11.4
12/08/2023 20:00	26.94	14.2	411	13.1	159.7	11.4
12/08/2023 21:00	26.17	14	410.4	13.1	156.4	11.1
12/08/2023 22:00	25.73	13.7	410.4	13.3	149.9	10.9
12/08/2023 23:00	26.79	13.5	411.4	14.3	146.6	11.4
13/08/2023 00:00	28.24	13.6	412.9	14.9	147	12
13/08/2023 01:00	26.74	13.6	412.9	14.1	147.5	11.4
13/08/2023 02:00	26.14	13.8	411.9	13.4	150	11.1
13/08/2023 03:00	26.2	13.7	410.3	13.5	149.4	11.1
13/08/2023 04:00	26.52	13.7	410.2	13.8	148.7	11.3
13/08/2023 05:00	27.43	13.7	410.5	14.3	148.6	11.6
13/08/2023 06:00	27.46	13.7	411.3	14.3	148.5	11.7

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
13/08/2023 07:00	25.94	13.7	414.2	13.5	148.8	11
13/08/2023 08:00	25.57	13.7	416.5	13.2	149.6	10.9
13/08/2023 09:00	25.3	13.8	420.1	13	150	10.7
13/08/2023 10:00	24.27	13.8	419	12.4	150.6	10.3
13/08/2023 11:00	23.82	13.8	417.7	12.2	150.2	10.1
13/08/2023 12:00	24.02	13.8	416.7	12.2	149.8	10.2
13/08/2023 13:00	23.83	13.8	415.3	12.2	149.9	10.1
13/08/2023 14:00	24.39	13.8	415.7	12.4	150	10.4
13/08/2023 15:00	24.63	13.8	418.6	12.6	150.4	10.5
13/08/2023 16:00	24.9	13.8	419.5	12.7	150	10.6
13/08/2023 17:00	25.56	13.7	420.3	13.3	148.9	10.8
13/08/2023 18:00	24.23	13.7	417.6	12.5	149.4	10.3
13/08/2023 19:00	26.76	13.8	419.9	13.6	151	11.4
13/08/2023 20:00	27.45	13.8	419.3	14	150.4	11.7
13/08/2023 21:00	26.56	13.7	415.9	13.7	149.4	11.3
13/08/2023 22:00	26.48	13.7	416.6	13.8	149.3	11.2
13/08/2023 23:00	26.94	13.7	415.9	14	149.1	11.4
14/08/2023 00:00	27.38	13.6	413.9	14.4	147.8	11.6
14/08/2023 01:00	27.56	13.5	412.5	14.6	147.4	11.7
14/08/2023 02:00	27.29	13.6	412.8	14.4	148.1	11.6
14/08/2023 03:00	26.67	13.3	412.1	14.5	145.3	11.3
14/08/2023 04:00	25.94	13.4	411.3	14	146	11
14/08/2023 05:00	26.03	13.4	411.3	14	145.8	11
14/08/2023 06:00	25.11	13.4	411.8	13.6	145.9	10.7
14/08/2023 07:00	25.49	13.4	412.6	13.7	146	10.8
14/08/2023 08:00	25.85	13.4	414.5	13.9	145.9	11
14/08/2023 09:00	26.97	13.5	420.4	14.4	146.8	11.4
14/08/2023 10:00	27.42	13.6	419.2	14.5	146.6	11.6
14/08/2023 11:00	26.06	13.7	417.4	13.6	147.8	11.1
14/08/2023 12:00	24.13	13.8	416.7	12.3	150	10.2
14/08/2023 13:00	25.14	13.8	415.3	12.8	149.7	10.7
14/08/2023 14:00	25.44	14.2	416	12.2	158.1	10.8
14/08/2023 15:00	25.14	14.3	415.3	11.9	162.1	10.7
14/08/2023 16:00	25.71	14.1	419.3	12.5	158	10.9
14/08/2023 17:00	27.45	14.1	420.8	13.5	154.7	11.6
14/08/2023 18:00	26.61	14	421	13.1	154.3	11.3
14/08/2023 19:00	26.91	14	420.2	13.3	154.6	11.4
14/08/2023 20:00	27.45	13.9	419.8	13.8	151.6	11.6
14/08/2023 21:00	27.02	13.9	418.5	13.7	151.4	11.5
14/08/2023 22:00	27.44	13.7	416.2	14.3	149.8	11.6
14/08/2023 23:00	27.48	13.5	414.3	14.6	147.1	11.7
15/08/2023 00:00	28.89	13.5	413.7	15.3	146.6	12.3
15/08/2023 01:00	27.83	13.5	413.7	14.8	147.1	11.8
15/08/2023 02:00	27.96	13.5	414	14.9	146.8	11.9
15/08/2023 03:00	26.53	13.5	413.2	14.2	146.2	11.3
15/08/2023 04:00	27.11	13.4	433.9	14.6	145.7	11.5
15/08/2023 05:00	27.99	13.4	468.4	15.1	145.2	11.9
15/08/2023 06:00	26.51	13.8	433.8	13.6	150.6	11.3
15/08/2023 07:00	26.86	13.8	428.2	13.6	151.6	11.4
15/08/2023 08:00	27.76	13.9	457.5	14	151.4	11.8
15/08/2023 09:00	26.31	13.9	463.9	13.2	152.2	11.2
15/08/2023 10:00	24.98	13.9	443	12.5	151.9	10.6
15/08/2023 11:00	25	13.9	443.4	12.5	151.6	10.6
15/08/2023 12:00	25.11	13.9	469.6	12.6	151.4	10.7
15/08/2023 13:00	24.92	13.9	466.5	12.5	151.3	10.6
15/08/2023 14:00	25.97	13.9	465.2	13	151.7	11
15/08/2023 15:00	27.14	13.9	452.3	13.6	152	11.5
15/08/2023 16:00	27.36	14	446.6	13.6	153.5	11.6
15/08/2023 17:00	27.83	14	459.2	13.8	153.3	11.8

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
15/08/2023 18:00	27.72	14	458.2	13.8	153.3	11.8
15/08/2023 19:00	27.89	14	457.6	13.9	153.1	11.8
15/08/2023 20:00	27.87	13.9	455.1	14	152.9	11.8
15/08/2023 21:00	28.98	14	461.1	14.4	154.1	12.3
15/08/2023 22:00	29.86	14	448	14.8	153.8	12.7
15/08/2023 23:00	28.5	14	433.7	14.1	153.7	12.1
16/08/2023 00:00	26.91	14	438.2	13.3	154.1	11.4
16/08/2023 01:00	25.18	14.1	445	12.4	156	10.7
16/08/2023 02:00	25.38	14	446.3	12.5	155.8	10.8
16/08/2023 03:00	26.1	14.1	448.4	12.9	155.8	11.1
16/08/2023 04:00	26.69	14	438.6	13.2	155.5	11.3
16/08/2023 05:00	27.55	14	442.2	13.6	155.8	11.7
16/08/2023 06:00	27.71	14.1	446.2	13.6	156	11.8
16/08/2023 07:00	27.01	14.1	433.6	13.2	157.1	11.5
16/08/2023 08:00	26.6	14.2	469.9	12.9	158.8	11.3
16/08/2023 09:00	26.31	14.2	449.4	12.6	159.6	11.2
16/08/2023 10:00	26.15	14.2	454	12.5	159.8	11.1
16/08/2023 11:00	25.27	14.2	461.9	12.1	160	10.7
16/08/2023 12:00	26.04	14.2	446.5	12.5	159.8	11.1
16/08/2023 13:00	26.22	14.2	445.6	12.6	159.7	11.1
16/08/2023 14:00	26.19	14.2	449.8	12.5	159.6	11.1
16/08/2023 15:00	26.29	14.2	451.7	12.6	159.1	11.2
16/08/2023 16:00	27.04	14.2	451.8	13	159.1	11.5
16/08/2023 17:00	26.03	14	472.2	12.8	155.2	11
16/08/2023 18:00	25.93	14	463.6	12.9	152.6	11
16/08/2023 19:00	26.49	14.2	453.9	12.8	157.3	11.2
16/08/2023 20:00	26.03	14.2	455.3	12.5	161	11
16/08/2023 21:00	26.3	14.2	468.6	12.6	160.9	11.2
16/08/2023 22:00	26.15	14.2	447.5	12.6	160.4	11.1
16/08/2023 23:00	25.97	14.2	413.6	12.5	161.6	11
17/08/2023 00:00	27.89	14.2	411.5	13.3	161.5	11.8
17/08/2023 01:00	28.67	14.2	411	13.7	161.9	12.2
17/08/2023 02:00	29.11	14.2	411.1	13.9	161.7	12.4
17/08/2023 03:00	29.24	14.2	410.3	14	161.7	12.4
17/08/2023 04:00	29.48	14.2	410.4	14.1	161.4	12.5
17/08/2023 05:00	29.19	14.2	409.5	14.1	160.9	12.4
17/08/2023 06:00	28.93	14.1	409.6	14.1	158.4	12.3
17/08/2023 07:00	28.46	14.1	412.1	13.8	158.4	12.1
17/08/2023 08:00	26.95	14.1	410.8	13.2	156.1	11.4
17/08/2023 09:00	26.86	14.2	418.4	12.9	158.4	11.4
17/08/2023 10:00	Maintain	Maintain	Alarm	Maintain	153.8	Maintain
17/08/2023 11:00	Maintain	Maintain	Alarm	Maintain	153.3	Maintain
17/08/2023 12:00	Maintain	Maintain	Alarm	Maintain	152.8	Maintain
17/08/2023 13:00	<Samp	<Samp	<Samp	<Samp	153	<Samp
17/08/2023 14:00	25.23	13.9	416.7	12.8	152.9	11
17/08/2023 15:00	25.06	13.9	416	12.7	152.8	10.6
17/08/2023 16:00	25.29	13.8	418.5	12.8	153	10.7
17/08/2023 17:00	25.88	13.8	421.1	13.2	153.4	11
17/08/2023 18:00	25.48	13.8	418	13	153	10.8
17/08/2023 19:00	25.94	13.8	415.4	13.3	152.5	11
17/08/2023 20:00	26.01	13.8	414.1	13.3	152.4	11
17/08/2023 21:00	24.43	13.8	412.9	12.6	152.5	10.4
17/08/2023 22:00	25.24	14	423.1	12.6	157.6	10.7
17/08/2023 23:00	25.66	14.1	425.9	12.5	163.4	10.9
18/08/2023 00:00	26	14.1	425.1	12.7	163.5	11
18/08/2023 01:00	26.15	14.1	424.7	12.8	163.5	11.1
18/08/2023 02:00	25.6	14.1	422.1	12.6	163.1	10.9
18/08/2023 03:00	25.7	14.1	421.1	12.6	163.1	10.9
18/08/2023 04:00	26.02	14.1	421.5	12.8	163.1	11

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
20/08/2023 16:00	24.24	14.1	420.1	11.9	180	10.3
20/08/2023 17:00	25.05	14.1	420.2	12.3	159.9	10.6
20/08/2023 18:00	25.89	14.1	420.2	12.7	160.2	11
20/08/2023 19:00	25.43	14.1	420.6	12.5	159.9	10.8
20/08/2023 20:00	25.61	13.3	421.5	14	148.3	10.9
20/08/2023 21:00	25.31	13.3	421.7	13.8	146.4	10.7
20/08/2023 22:00	25.7	14.1	422	12.6	160.9	10.9
20/08/2023 23:00	25.92	14.1	423.2	12.6	163.5	11
21/08/2023 00:00	24.52	14	426.2	12.1	160.9	10.4
21/08/2023 01:00	24.68	14	424.6	12.2	161	10.5
21/08/2023 02:00	25.95	14.1	421.3	12.8	162.3	11
21/08/2023 03:00	26.55	14.1	418.9	13.1	163	11.3
21/08/2023 04:00	26.42	14	418.4	13.1	161	11.2
21/08/2023 05:00	26.32	14.1	418.5	13	162.7	11.2
21/08/2023 06:00	25.88	14	417.8	12.8	162.8	11
21/08/2023 07:00	25.78	14	418.6	12.7	162.4	10.9
21/08/2023 08:00	26.94	14.1	423.5	13.2	163.2	11.4
21/08/2023 09:00	27.44	14.1	420.3	13.5	162.7	11.6
21/08/2023 10:00	26.72	14	423.8	13.3	162	11.3
21/08/2023 11:00	23.99	13.6	420.4	12.6	150.3	10.2
21/08/2023 12:00	25.24	13.5	420.1	13.4	148.6	10.7
21/08/2023 13:00	25.0	13.4	419.1	13.9	147.6	11
21/08/2023 14:00	24.4	13.5	420.3	13	147.8	10.4
21/08/2023 15:00	25.62	13.5	419.9	13.6	147.4	10.9
21/08/2023 16:00	22.35	13.5	421.7	11.9	147.8	9.5
21/08/2023 17:00	28.72	13.7	422.4	14.9	150.1	12.2
21/08/2023 18:00	28.89	13.7	422.6	15	150.7	12.3
21/08/2023 19:00	28.42	13.7	423.6	14.7	151.3	12.1
21/08/2023 20:00	28.36	13.7	423.3	14.7	151.3	12
21/08/2023 21:00	26.71	13.6	419.9	14	150.5	11.3
21/08/2023 22:00	26.13	13.9	419.9	13.2	155.4	11.1
21/08/2023 23:00	25.04	14	420.1	12.4	161.8	10.6
22/08/2023 00:00	24.28	14	419.4	12	161.9	10.3
22/08/2023 01:00	23.97	14	418.8	11.9	161.8	10.2
22/08/2023 02:00	23.58	14	419	11.7	161.7	10
22/08/2023 03:00	23.37	14	419.1	11.6	162	9.9
22/08/2023 04:00	22.52	14	419.4	11.2	161.9	9.6
22/08/2023 05:00	22.3	14	419.5	11.1	162.1	9.5
22/08/2023 06:00	22	14	419	10.9	161.7	9.3
22/08/2023 07:00	22.16	14	422.3	10.9	162.3	9.4
22/08/2023 08:00	25.47	14	423.4	12.6	160.9	10.8
22/08/2023 09:00	27.15	13.8	420.1	13.8	153.8	11.5
22/08/2023 10:00	28.97	13.8	422.8	14.7	153.7	12.3
22/08/2023 11:00	27.74	13.8	420.2	14.2	152.2	11.8
22/08/2023 12:00	27.11	13.7	417.6	14	152	11.5
22/08/2023 13:00	27.88	13.6	418.4	14.7	149.6	11.8
22/08/2023 14:00	29.45	13.5	419.8	15.7	148.4	12.5
22/08/2023 15:00	26.23	13.2	418.6	14.5	143.7	11.1
22/08/2023 16:00	24.99	13.2	420.9	13.9	144.4	10.6
22/08/2023 17:00	26.16	13.1	423.3	14.6	143.9	11.1
22/08/2023 18:00	26.78	13.1	423.3	15	144.1	11.4
22/08/2023 19:00	26.64	13.1	423	16.1	142.9	12.2
22/08/2023 20:00	26.63	13.1	424.8	16.1	143.6	12.2
22/08/2023 21:00	25.93	13.1	425.3	14.6	143.4	11
22/08/2023 22:00	24.57	13.5	427.1	13.1	147.7	10.4
22/08/2023 23:00	26.83	13.8	426.5	13.8	153.4	11.4
23/08/2023 00:00	26.68	13.8	426.7	14.6	153.5	12.2
23/08/2023 01:00	29.37	14	427	14.6	157.6	12.5
23/08/2023 02:00	28.66	14.1	427	13.9	163.5	12.2

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
23/08/2023 03:00	28.7	14.1	425.4	14	163.6	12.2
23/08/2023 04:00	28.53	14.1	425.7	13.9	163.5	12.1
23/08/2023 05:00	28.28	14.1	424	13.8	163.2	12
23/08/2023 06:00	28.25	14.1	422.7	13.8	163	12
23/08/2023 07:00	28.65	14.1	425	13.9	163.1	12.2
23/08/2023 08:00	28.97	14.2	423.2	14.1	162.8	12.3
23/08/2023 09:00	28.74	14.2	420.9	13.9	162.7	12.2
23/08/2023 10:00	28.44	13.8	419.3	14.6	155.4	12.1
23/08/2023 11:00	28.65	13.3	418.7	15.7	145.1	12.2
23/08/2023 12:00	28.27	13.3	418.8	15.5	145.1	12
23/08/2023 13:00	28.58	13.3	418.5	15.7	144.8	12.1
23/08/2023 14:00	28.34	13.3	418.7	15.6	144.6	12
23/08/2023 15:00	30.06	13.3	422.4	16.5	146	12.8
23/08/2023 16:00	26.78	13.3	423	14.6	145.7	11.4
23/08/2023 17:00	25.28	13.3	423.8	14.2	145.7	10.9
23/08/2023 18:00	28.19	13	424.7	16	142.6	12
23/08/2023 19:00	29.07	13	426.4	16.4	142.6	12
23/08/2023 20:00	29.64	13.1	427.6	16.7	143.4	12.6
23/08/2023 21:00	27.1	13.1	425.6	15.3	143.2	11.5
23/08/2023 22:00	25.32	13.6	424.9	13.3	148.9	10.7
23/08/2023 23:00	28.52	13.8	425.9	14.5	153.7	12.1
24/08/2023 00:00	29.1	13.9	426.6	14.8	154.6	12.4
24/08/2023 01:00	29.44	13.9	426.9	14.9	154.7	12.5
24/08/2023 02:00	30.09	13.8	427.2	15.4	153	12.8
24/08/2023 03:00	30.25	13.8	426.9	15.5	152.6	12.8
24/08/2023 04:00	30.22	13.8	426.7	15.5	152.6	12.8
24/08/2023 05:00	30.46	13.7	427.1	15.8	151.6	12.9
24/08/2023 06:00	29.6	13.7	423.5	15.4	151.3	12.6
24/08/2023 07:00	28.28	13.7	425	14.6	152.8	12
24/08/2023 08:00	26.32	13.8	425.5	13.4	153.9	11.2
24/08/2023 09:00	26.34	13.8	424.9	13.4	154.1	11.2
24/08/2023 10:00	27.16	13.4	421.9	14.6	148.5	11.5
24/08/2023 11:00	28.57	13.1	420.5	16.1	142.7	12.1
24/08/2023 12:00	29.62	13.1	419.4	16.7	142.6	12.6
24/08/2023 13:00	29.21	13.1	420	16.5	142.3	12.4
24/08/2023 14:00	29.06	13.1	420.4	16.4	142.8	12.3
24/08/2023 15:00	29.72	13.1	419.4	16.7	142.2	12.6
24/08/2023 16:00	29.53	13.1	420.6	16.7	142.4	12.5
24/08/2023 17:00	29.05	13.1	422.4	16.4	142.4	12.3
24/08/2023 18:00	27.14	13	423.7	15.3	142.5	11.5
24/08/2023 19:00	27.49	13	424.5	15.6	142.5	11.7
24/08/2023 20:00	27.7	13	426	15.8	142.1	11.8
24/08/2023 21:00	27.93	13	427.8	15.9	142.2	11.9
24/08/2023 22:00	25.78	13.7	426.7	13.3	152.5	10.9
24/08/2023 23:00	24.86	14.2	421.6	12	166.2	10.6
25/08/2023 00:00	26.03	14.2	420.3	12.5	166.6	11.1
25/08/2023 01:00	25.93	14.2	419.6	12.5	166.6	11
25/08/2023 02:00	26.14	14.2	420.8	12.6	166.9	11.1
25/08/2023 03:00	26.72	14.2	423.3	12.8	166.9	11.3
25/08/2023 04:00	26.43	14.2	420.6	12.7	166.5	11.2
25/08/2023 05:00	27.81	14.2	422.3	13.4	166.7	11.8
25/08/2023 06:00	28.25	14.2	421.7	13.6	166.8	12
25/08/2023 07:00	28.24	14.3	424.6	13.5	167.2	12
25/08/2023 08:00	27.17	14.3	422.8	12.9	166.6	11.5
25/08/2023 09:00	25.79	14.3	420.8	12.3	166.4	10.9
25/08/2023 10:00	25.04	13.8	418.9	12.9	156.9	10.6
25/08/2023 11:00	24.42	13.3	419.2	13.3	146.2	10.4
25/08/2023 12:00	25.94	13.2	418	14.4	144.5	11
25/08/2023 13:00	25.84	13.1	416.9	14.4	143.3	11

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
25/08/2023 14:00	26.25	13.1	416.3	14.7	142.7	11.1
25/08/2023 15:00	25.57	13.1	417.4	14.4	142.6	10.9
25/08/2023 16:00	24.72	13.1	421	13.9	143.1	10.5
25/08/2023 17:00	25.99	13.2	423.7	14.3	144.5	11
25/08/2023 18:00	26.43	13.3	424.8	14.5	145	11.2
25/08/2023 19:00	23.82	13.4	424.6	12.8	147.5	10.1
25/08/2023 20:00	23.76	13.4	425.7	12.8	147.6	10.1
25/08/2023 21:00	24.3	13.5	424.5	13	148.7	10.3
25/08/2023 22:00	23.37	14.1	421	11.4	161	9.9
25/08/2023 23:00	23.28	14.2	419.7	11.2	166.1	9.9
26/08/2023 00:00	23.11	14.2	420.5	11.1	166.6	9.8
26/08/2023 01:00	22.73	14.2	419.8	11	166.7	9.6
26/08/2023 02:00	23.02	14.2	422.2	11.1	166.9	9.8
26/08/2023 03:00	23.16	14.2	422.7	11.1	166.8	9.8
26/08/2023 04:00	23.23	14.2	423.5	11.1	167	9.9
26/08/2023 05:00	23.26	14.2	422.8	11.2	167	9.9
26/08/2023 06:00	23.13	14.2	421.3	11.1	166.6	9.8
26/08/2023 07:00	23.27	14.3	423.9	11.1	167	9.9
26/08/2023 08:00	23.34	14.3	422.3	11.1	166.6	9.9
26/08/2023 09:00	22.98	14.3	420.4	10.9	166.6	9.8
26/08/2023 10:00	23.59	13.8	419.1	12	159	10
26/08/2023 11:00	27.11	13.1	419.5	15.3	142.4	11.5
26/08/2023 12:00	27.05	13.1	418.3	15.3	142.7	11.5
26/08/2023 13:00	28.4	13.1	416.9	16	141.9	12.1
26/08/2023 14:00	29.13	13.1	417	16.4	141.7	12.4
26/08/2023 15:00	29.03	13.1	417.1	16.3	141.7	12.3
26/08/2023 16:00	26.76	13.1	418.4	15.1	141.8	11.4
26/08/2023 17:00	25.71	13	420.5	14.5	141.8	10.9
26/08/2023 18:00	25.52	13	425.9	14.4	142.1	10.8
26/08/2023 19:00	26.68	13.2	428.6	14.8	144.3	11.3
26/08/2023 20:00	26.47	13.2	427.3	14.7	144.9	11.2
26/08/2023 21:00	26.98	13.2	426.7	15	145	11.5
26/08/2023 22:00	24.59	14.1	426.3	12.1	159.4	10.4
26/08/2023 23:00	22.57	14.3	424.7	10.8	166.8	9.6
27/08/2023 00:00	21.56	14.3	424	10.3	167.1	9.2
27/08/2023 01:00	22.24	14.3	424.5	10.6	167.2	9.4
27/08/2023 02:00	22.84	14.3	424.3	10.9	167.1	9.7
27/08/2023 03:00	23.05	14.3	424.4	11	167.2	9.8
27/08/2023 04:00	22.84	14.3	424.3	10.9	167.4	9.7
27/08/2023 05:00	23.76	14.3	424.5	11.4	167.3	10.1
27/08/2023 06:00	23.9	14.2	423.9	11.5	167.3	10.1
27/08/2023 07:00	23.61	14.3	423.9	11.3	167.3	10
27/08/2023 08:00	23.74	14.3	421.9	11.3	166.8	10.1
27/08/2023 09:00	26.02	14.3	421.4	12.4	166.5	11
27/08/2023 10:00	26.2	14.3	421.1	12.5	166.5	11.1
27/08/2023 11:00	26.67	14.3	418	12.6	166.2	11.3
27/08/2023 12:00	26.84	14.3	417.5	12.7	166.1	11.4
27/08/2023 13:00	25.75	14.3	416.3	12.2	165.8	10.9
27/08/2023 14:00	25.68	14.3	415.8	12.2	165.9	10.9
27/08/2023 15:00	26.92	14.3	416	12.7	165.6	11.4
27/08/2023 16:00	27.9	14.3	417.9	13.2	165.8	11.8
27/08/2023 17:00	29.5	14.3	418.8	14	166	12.5
27/08/2023 18:00	28.7	14.3	419.8	13.6	166.1	12.2
27/08/2023 19:00	25.72	14.2	421	12.4	165.9	10.9
27/08/2023 20:00	24.32	13	422.4	13.8	143.6	10.3
27/08/2023 21:00	25.25	13.1	423.3	14.1	143.1	10.7
27/08/2023 22:00	25.09	14.3	421.1	12	163.7	10.7
27/08/2023 23:00	25.98	14.3	421	12.4	166.1	11
28/08/2023 00:00	25.67	14.2	422.4	12.3	166.7	10.9

Site Report - GPSC CUP2 HRS G1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
30/08/2023 12:00	27.39	13	416.1	15.5	141.7	11.6
30/08/2023 13:00	27.19	13	415.8	15.4	141.1	11.5
30/08/2023 14:00	26.87	13	416.9	15.2	141.1	11.4
30/08/2023 15:00	27.02	13	417.6	15.3	141	11.5
30/08/2023 16:00	28.11	13	420.1	15.9	140.9	11.9
30/08/2023 17:00	26.22	13.1	422.5	14.6	142.7	11.1
30/08/2023 18:00	27.05	13.2	423	14.9	144.2	11.5
30/08/2023 19:00	27.19	13.2	424.1	15	144.5	11.5
30/08/2023 20:00	26.82	13.2	423.2	14.8	144.4	11.4
30/08/2023 21:00	26.44	13.2	423.4	14.6	144.4	11.2
30/08/2023 22:00	25.42	14.1	423.2	12.4	159	10.8
30/08/2023 23:00	25.38	14.3	422.1	12.1	166.1	10.8
31/08/2023 00:00	25.95	14.3	422.7	12.3	166.5	11
31/08/2023 01:00	25.52	14.3	423.1	12.2	166.6	10.8
31/08/2023 02:00	26.16	14.3	423.1	12.5	166.5	11.1
31/08/2023 03:00	27.05	14.3	423.4	12.9	166.6	11.5
31/08/2023 04:00	27.85	14.3	423.3	13.2	166.5	11.8
31/08/2023 05:00	27.96	14.3	423.3	13.3	166.5	11.9
31/08/2023 06:00	27.98	14.3	424	13.3	166.7	11.9
31/08/2023 07:00	27.74	14.3	422.8	13.2	166.7	11.8
31/08/2023 08:00	27.45	14.3	421.8	13.1	166.5	11.7
31/08/2023 09:00	27.32	14.3	420.6	13	166.3	11.6
31/08/2023 10:00	27.74	13.7	419.6	14.5	155.4	11.8
31/08/2023 11:00	24.55	13.1	418.3	13.8	142.8	10.4
31/08/2023 12:00	25.48	13	415.8	14.4	141.3	10.8
31/08/2023 13:00	28.32	13	420.5	16	141	12
31/08/2023 14:00	28.65	13	422.1	16.2	141.6	12.2
31/08/2023 15:00	28.41	13	420.3	16	141.7	12.1
31/08/2023 16:00	27.68	13	420.6	15.6	141.1	11.8
31/08/2023 17:00	25.63	13	421.4	14.5	141.6	10.9
31/08/2023 18:00	25.43	13	422.6	14.4	141.7	10.8
31/08/2023 19:00	24.6	13	421.8	14	141.4	10.4
31/08/2023 20:00	29.07	13	423.5	16.4	141.8	12.3
31/08/2023 21:00	27.88	13.2	424.7	15.5	143.3	11.8
31/08/2023 22:00	25.29	14.1	424.7	12.5	157.7	10.7
31/08/2023 23:00	24	14.3	425.8	11.5	165.7	10.2
Minimum	0	12	0.1	0	28.9	0
MinDate	01/08/2023 18:00	05/08/2023 14:00	01/08/2023 18:00	01/08/2023 20:00	01/08/2023 05:00	01/08/2023 18:00
Maximum	159.74	21.1	472.2	58.1	205	67.8
MaxDate	02/08/2023 05:00	01/08/2023 18:00	16/08/2023 17:00	02/08/2023 05:00	02/08/2023 02:00	02/08/2023 05:00
Avg	26.5	14.1	403.6	12.9	151.9	11.2
Num	678	678	678	678	744	678
Data[%]	91		91	91	99.9	91
STD	12.3	1	48.5	4.2	24.8	5.2

Site Report - GPSC CUP2 HRS G1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
01/09/2023 00:00	25.45	14.2	420.8	12.2	165.7	10.8
01/09/2023 01:00	24.86	14.2	419	12	165.9	10.6
01/09/2023 02:00	24.56	14.2	418.3	11.8	165.5	10.4
01/09/2023 03:00	24.55	14.2	418	11.8	165.5	10.4
01/09/2023 04:00	24.64	14.2	418.2	11.9	165.4	10.5
01/09/2023 05:00	24.41	14.2	418.4	11.8	166.1	10.4
01/09/2023 06:00	24.25	14.2	418.6	11.7	166	10.3
01/09/2023 07:00	26	14.2	420.4	12.5	166.3	11
01/09/2023 08:00	25.05	14.3	424	12	167.3	10.6
01/09/2023 09:00	25.56	14.3	422.8	12.2	166.7	10.9
01/09/2023 10:00	24.87	13.7	421.8	13	156.2	10.6
01/09/2023 11:00	26.87	12.9	421.7	15.5	140.6	11.4
01/09/2023 12:00	26.59	12.7	421.3	15.6	138.4	11.3
01/09/2023 13:00	26.96	12.7	419.5	15.8	137.7	11.4
01/09/2023 14:00	26.37	12.7	418.4	15.5	137.2	11.2
01/09/2023 15:00	26.28	12.7	418.1	15.5	137.6	11.2
01/09/2023 16:00	27.36	12.7	420.4	16.1	137.8	11.6
01/09/2023 17:00	27.76	12.7	421.3	16.4	137.9	11.8
01/09/2023 18:00	28.61	12.7	422.6	16.9	138	12.1
01/09/2023 19:00	27.74	12.7	423.8	16.4	138.3	11.8
01/09/2023 20:00	27.39	12.7	424.3	16.1	138.2	11.6
01/09/2023 21:00	27.94	12.7	423.9	16.4	138.7	11.9
01/09/2023 22:00	27.68	13.8	423.7	14.2	151.9	11.7
01/09/2023 23:00	24.23	14.3	423	11.5	165.5	10.3
02/09/2023 00:00	25.97	14.3	422.9	12.4	166.1	11
02/09/2023 01:00	26.35	14.3	423.3	12.5	166.3	11.2
02/09/2023 02:00	26.03	14.3	423.7	12.4	166.2	11
02/09/2023 03:00	27.13	14.3	424	12.9	166.3	11.5
02/09/2023 04:00	27.91	14.3	424.1	13.3	166.7	11.8
02/09/2023 05:00	28.34	14.3	424.7	13.5	166.4	12
02/09/2023 06:00	28.34	14.3	424.9	13.5	166.9	12
02/09/2023 07:00	27.98	14.3	424.2	13.3	167.1	11.9
02/09/2023 08:00	26.98	14.3	422.4	12.8	166.7	11.5
02/09/2023 09:00	26.86	14.3	420.4	12.8	166.2	11.4
02/09/2023 10:00	25.69	13.8	419.8	13.2	156.6	10.9
02/09/2023 11:00	26.3	12.9	418.6	15.2	139.6	11.2
02/09/2023 12:00	27.2	12.8	418.1	15.8	138.3	11.5
02/09/2023 13:00	27.51	12.8	416.5	16	128.5	11.7
02/09/2023 14:00	26.75	12.8	417.4	15.5	129.9	11.4
02/09/2023 15:00	26.28	12.8	417.3	15.4	136.5	11.2
02/09/2023 16:00	25.69	12.8	417.9	15	138	10.9
02/09/2023 17:00	25.69	12.8	418.8	15	138	10.9
02/09/2023 18:00	25.11	12.8	420.6	14.6	138.3	10.7
02/09/2023 19:00	24.89	12.8	421.5	14.5	139.3	10.6
02/09/2023 20:00	25.78	12.8	423	15	138.8	10.9
02/09/2023 21:00	27.01	12.8	424.8	15.7	138.6	11.5
02/09/2023 22:00	22.25	14	424.5	11.1	156.7	9.4
02/09/2023 23:00	21.13	14.3	423.4	10	166.6	9
03/09/2023 00:00	22.29	14.3	424	10.6	166.9	9.5
03/09/2023 01:00	22.98	14.3	424.8	10.9	166.7	9.8
03/09/2023 02:00	22.66	14.3	424.6	10.8	166.6	9.6
03/09/2023 03:00	22.38	14.3	424.8	10.7	166.9	9.5
03/09/2023 04:00	22.52	14.3	425	10.7	167.2	9.6
03/09/2023 05:00	22.01	14.3	424.7	10.5	167.5	9.3
03/09/2023 06:00	21.68	14.3	424	10.4	167	9.2
03/09/2023 07:00	21.63	14.3	421.6	10.3	166.6	9.2
03/09/2023 08:00	23.78	14.3	420.1	11.3	166.2	10.1
03/09/2023 09:00	23.55	14.3	418.3	11.2	165.9	10
03/09/2023 10:00	24.1	14.3	415.8	11.4	165.6	10.2

Site Report - GPSC CUP2 HRS G1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
03/09/2023 11:00	25.45	14.3	414.5	12.1	165.7	10.8
03/09/2023 12:00	25.68	14.3	413.2	12.2	166.1	10.9
03/09/2023 13:00	25.85	14.3	413	12.2	165.1	11
03/09/2023 14:00	25.81	14.3	413.7	12.2	165.1	11
03/09/2023 15:00	25.81	14.3	414.5	12.2	165.3	11
03/09/2023 16:00	25.89	14.3	416	12.3	165.5	11
03/09/2023 17:00	26.25	14.3	416.7	12.5	165.7	11.1
03/09/2023 18:00	25.67	14.3	418.4	12.2	165.9	10.9
03/09/2023 19:00	25.46	14.1	419	12.3	165	10.8
03/09/2023 20:00	25.83	12.9	421.4	14.9	141	11
03/09/2023 21:00	25.54	13.3	423	14	144.6	10.8
03/09/2023 22:00	23.57	14.3	421.9	11.2	165	10
03/09/2023 23:00	23.79	14.3	422.4	11.3	166.1	10.1
04/09/2023 00:00	24.78	14.3	422.4	11.8	166.4	10.5
04/09/2023 01:00	25.74	14.3	423.4	12.2	166.2	10.9
04/09/2023 02:00	25.4	14.3	423.6	12.1	166.7	10.8
04/09/2023 03:00	24.93	14.3	423.8	11.9	166.7	10.6
04/09/2023 04:00	25.28	14.3	424.6	12	166.8	10.7
04/09/2023 05:00	25.55	14.3	424.4	12.2	167	10.8
04/09/2023 06:00	25.84	14.3	423.9	12.3	166.8	11
04/09/2023 07:00	25.43	14.3	422	12.1	166.5	10.8
04/09/2023 08:00	<Samp	<Samp	<Samp	<Samp	<Samp	<Samp
04/09/2023 09:00	---	---	---	---	---	---
04/09/2023 10:00	---	---	---	---	---	---
04/09/2023 11:00	---	---	---	---	---	---
04/09/2023 12:00	---	---	---	---	---	---
04/09/2023 13:00	---	---	---	---	---	---
04/09/2023 14:00	---	---	---	---	---	---
04/09/2023 15:00	---	---	---	---	---	---
04/09/2023 16:00	---	---	---	---	---	---
04/09/2023 17:00	---	---	---	---	---	---
04/09/2023 18:00	---	---	---	---	---	---
04/09/2023 19:00	---	---	---	---	---	---
04/09/2023 20:00	---	---	---	---	---	---
04/09/2023 21:00	---	---	---	---	---	---
04/09/2023 22:00	---	---	---	---	---	---
04/09/2023 23:00	---	---	---	---	---	---
05/09/2023 00:00	---	---	---	---	---	---
05/09/2023 01:00	---	---	---	---	---	---
05/09/2023 02:00	---	---	---	---	---	---
05/09/2023 03:00	---	---	---	---	---	---
05/09/2023 04:00	---	---	---	---	---	---
05/09/2023 05:00	---	---	---	---	---	---
05/09/2023 06:00	---	---	---	---	---	---
05/09/2023 07:00	---	---	---	---	---	---
05/09/2023 08:00	---	---	---	---	---	---
05/09/2023 09:00	---	---	---	---	---	---
05/09/2023 10:00	---	---	---	---	---	---
05/09/2023 11:00	---	---	---	---	---	---
05/09/2023 12:00	---	---	---	---	---	---
05/09/2023 13:00	---	---	---	---	---	---
05/09/2023 14:00	---	---	---	---	---	---
05/09/2023 15:00	---	---	---	---	---	---
05/09/2023 16:00	---	---	---	---	---	---
05/09/2023 17:00	---	---	---	---	---	---
05/09/2023 18:00	---	---	---	---	---	---
05/09/2023 19:00	---	---	---	---	---	---
05/09/2023 20:00	---	---	---	---	---	---
05/09/2023 21:00	---	---	---	---	---	---

Site Report - GPSC CUP2 HRS G1						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
08/09/2023 09:00	---	---	---	---	---	---
08/09/2023 10:00	---	---	---	---	---	---
08/09/2023 11:00	---	---	---	---	---	---
08/09/2023 12:00	---	---	---	---	---	---
08/09/2023 13:00	---	---	---	---	---	---
08/09/2023 14:00	---	---	---	---	---	---
08/09/2023 15:00	---	---	---	---	---	---
08/09/2023 16:00	---	---	---	---	---	---
08/09/2023 17:00	---	---	---	---	---	---
08/09/2023 18:00	---	---	---	---	---	---
08/09/2023 19:00	---	---	---	---	---	---
08/09/2023 20:00	---	---	---	---	---	---
08/09/2023 21:00	---	---	---	---	---	---
08/09/2023 22:00	---	---	---	---	---	---
08/09/2023 23:00	---	---	---	---	---	---
09/09/2023 00:00	---	---	---	---	---	---
09/09/2023 01:00	---	---	---	---	---	---
09/09/2023 02:00	---	---	---	---	---	---
09/09/2023 03:00	---	---	---	---	---	---
09/09/2023 04:00	---	---	---	---	---	---
09/09/2023 05:00	---	---	---	---	---	---
09/09/2023 06:00	---	---	---	---	---	---
09/09/2023 07:00	---	---	---	---	---	---
09/09/2023 08:00	---	---	---	---	---	---
09/09/2023 09:00	---	---	---	---	---	---
09/09/2023 10:00	---	---	---	---	---	---
09/09/2023 11:00	---	---	---	---	---	---
09/09/2023 12:00	---	---	---	---	---	---
09/09/2023 13:00	---	---	---	---	---	---
09/09/2023 14:00	---	---	---	---	---	---
09/09/2023 15:00	---	---	---	---	---	---
09/09/2023 16:00	---	---	---	---	---	---
09/09/2023 17:00	---	---	---	---	---	---
09/09/2023 18:00	---	---	---	---	---	---
09/09/2023 19:00	---	---	---	---	---	---
09/09/2023 20:00	---	---	---	---	---	---
09/09/2023 21:00	---	---	---	---	---	---
09/09/2023 22:00	---	---	---	---	---	---
09/09/2023 23:00	---	---	---	---	---	---
10/09/2023 00:00	---	---	---	---	---	---
10/09/2023 01:00	---	---	---	---	---	---
10/09/2023 02:00	---	---	---	---	---	---
10/09/2023 03:00	---	---	---	---	---	---
10/09/2023 04:00	---	---	---	---	---	---
10/09/2023 05:00	---	---	---	---	---	---
10/09/2023 06:00	---	---	---	---	---	---
10/09/2023 07:00	---	---	---	---	---	---
10/09/2023 08:00	---	---	---	---	---	---
10/09/2023 09:00	---	---	---	---	---	---
10/09/2023 10:00	---	---	---	---	---	---
10/09/2023 11:00	---	---	---	---	---	---
10/09/2023 12:00	---	---	---	---	---	---
10/09/2023 13:00	---	---	---	---	---	---
10/09/2023 14:00	---	---	---	---	---	---
10/09/2023 15:00	---	---	---	---	---	---
10/09/2023 16:00	---	---	---	---	---	---
10/09/2023 17:00	---	---	---	---	---	---
10/09/2023 18:00	---	---	---	---	---	---
10/09/2023 19:00	---	---	---	---	---	---

Site Report - GPSC CUP2 HRS G1						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
10/09/2023 20:00	---	---	---	---	---	---
10/09/2023 21:00	---	---	---	---	---	---
10/09/2023 22:00	---	---	---	---	---	---
10/09/2023 23:00	---	---	---	---	---	---
11/09/2023 00:00	---	---	---	---	---	---
11/09/2023 01:00	---	---	---	---	---	---
11/09/2023 02:00	---	---	---	---	---	---
11/09/2023 03:00	---	---	---	---	---	---
11/09/2023 04:00	---	---	---	---	---	---
11/09/2023 05:00	---	---	---	---	---	---
11/09/2023 06:00	---	---	---	---	---	---
11/09/2023 07:00	---	---	---	---	---	---
11/09/2023 08:00	---	---	---	---	---	---
11/09/2023 09:00	---	---	---	---	---	---
11/09/2023 10:00	---	---	---	---	---	---
11/09/2023 11:00	---	---	---	---	---	---
11/09/2023 12:00	---	---	---	---	---	---
11/09/2023 13:00	---	---	---	---	---	---
11/09/2023 14:00	---	---	---	---	---	---
11/09/2023 15:00	---	---	---	---	---	---
11/09/2023 16:00	---	---	---	---	---	---
11/09/2023 17:00	---	---	---	---	---	---
11/09/2023 18:00	---	---	---	---	---	---
11/09/2023 19:00	---	---	---	---	---	---
11/09/2023 20:00	---	---	---	---	---	---
11/09/2023 21:00	---	---	---	---	---	---
11/09/2023 22:00	---	---	---	---	---	---
11/09/2023 23:00	---	---	---	---	---	---
12/09/2023 00:00	---	---	---	---	---	---
12/09/2023 01:00	---	---	---	---	---	---
12/09/2023 02:00	---	---	---	---	---	---
12/09/2023 03:00	---	---	---	---	---	---
12/09/2023 04:00	---	---	---	---	---	---
12/09/2023 05:00	---	---	---	---	---	---
12/09/2023 06:00	---	---	---	---	---	---
12/09/2023 07:00	---	---	---	---	---	---
12/09/2023 08:00	---	---	---	---	---	---
12/09/2023 09:00	---	---	---	---	---	---
12/09/2023 10:00	---	---	---	---	---	---
12/09/2023 11:00	---	---	---	---	---	---
12/09/2023 12:00	---	---	---	---	---	---
12/09/2023 13:00	---	---	---	---	---	---
12/09/2023 14:00	---	---	---	---	---	---
12/09/2023 15:00	---	---	---	---	---	---
12/09/2023 16:00	---	---	---	---	---	---
12/09/2023 17:00	---	---	---	---	---	---
12/09/2023 18:00	---	---	---	---	---	---
12/09/2023 19:00	---	---	---	---	---	---
12/09/2023 20:00	---	---	---	---	---	---
12/09/2023 21:00	---	---	---	---	---	---
12/09/2023 22:00	---	---	---	---	---	---
12/09/2023 23:00	---	---	---	---	---	---
13/09/2023 00:00	---	---	---	---	---	---
13/09/2023 01:00	---	---	---	---	---	---
13/09/2023 02:00	---	---	---	---	---	---
13/09/2023 03:00	---	---	---	---	---	---
13/09/2023 04:00	---	---	---	---	---	---
13/09/2023 05:00	---	---	---	---	---	---
13/09/2023 06:00	---	---	---	---	---	---

Site Report - GPSC CUP2 HRS G1						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
13/09/2023 07:00	---	---	---	---	---	---
13/09/2023 08:00	---	---	---	---	---	---
13/09/2023 09:00	---	---	---	---	---	---
13/09/2023 10:00	---	---	---	---	---	---
13/09/2023 11:00	---	---	---	---	---	---
13/09/2023 12:00	---	---	---	---	---	---
13/09/2023 13:00	---	---	---	---	---	---
13/09/2023 14:00	---	---	---	---	---	---
13/09/2023 15:00	---	---	---	---	---	---
13/09/2023 16:00	27.03	13.2	421.2	15	142.5	11.5
13/09/2023 17:00	26.7	13.2	423.2	14.8	141.9	11.3
13/09/2023 18:00	26.24	13.2	423.6	14.6	142.6	11.1
13/09/2023 19:00	27.24	13.2	424.6	15.2	143.1	11.6
13/09/2023 20:00	26.21	13.2	425.1	14.6	143.2	11.1
13/09/2023 21:00	25.32	13.2	426.4	14.1	143.2	10.7
13/09/2023 22:00	23.89	14.1	426.6	11.6	157.7	10.1
13/09/2023 23:00	23.71	14.3	425.5	11.2	166.6	10.1
14/09/2023 00:00	24.32	14.3	425.5	11.5	166.8	10.3
14/09/2023 01:00	24.94	14.3	423.8	11.8	166.8	10.6
14/09/2023 02:00	25.02	14.3	423.9	11.9	166.6	10.6
14/09/2023 03:00	25.72	14.3	424.4	12.2	166.6	10.9
14/09/2023 04:00	25.57	14.3	422.5	12.2	166.2	10.9
14/09/2023 05:00	25.6	14.3	422.3	12.2	165.9	10.9
14/09/2023 06:00	25.34	14.3	422	12.1	166.2	10.8
14/09/2023 07:00	26.03	14.3	425.2	12.3	166.3	11
14/09/2023 08:00	26.95	14.3	424.4	12.7	166.4	11.4
14/09/2023 09:00	27.31	14.4	421.9	12.8	166.3	11.6
14/09/2023 10:00	26.45	13.8	420.1	13.6	156	11.2
14/09/2023 11:00	27.18	13.2	418.9	15.1	143.7	11.5
14/09/2023 12:00	27.11	13.2	417.7	15	143.1	11.5
14/09/2023 13:00	<Samp	<Samp	<Samp	<Samp	142.4	<Samp
14/09/2023 14:00	<Samp	<Samp	<Samp	<Samp	142.1	<Samp
14/09/2023 15:00	26.34	13.2	422.3	14.7	143	11.2
14/09/2023 16:00	26.99	13.2	422.9	15	143.1	11.5
14/09/2023 17:00	26.1	13.2	427.9	14.5	142.7	11.1
14/09/2023 18:00	25.65	13.2	428	14.1	144.7	10.9
14/09/2023 19:00	25.7	13.3	428.8	14.1	145.3	10.9
14/09/2023 20:00	27.3	13.3	422.9	15	144.8	11.6
14/09/2023 21:00	26.78	14.3	420.4	14.6	145.8	11.4
14/09/2023 22:00	24.55	14	417.9	12.3	157.2	10.6
14/09/2023 23:00	24.93	14.3	417.1	11.9	165.7	10.6
15/09/2023 00:00	24.76	14.3	415.9	11.8	165.8	10.5
15/09/2023 01:00	24.65	14.3	420.2	11.8	166	10.5
15/09/2023 02:00	24.77	14.3	420.8	11.8	165.7	10.5
15/09/2023 03:00	25.55	14.3	422.1	12.2	165.8	10.8
15/09/2023 04:00	25.59	14.3	421.9	12.2	165.9	10.9
15/09/2023 05:00	24.03	14.3	421.7	11.5	166	10.2
15/09/2023 06:00	22.46	14.3	422	10.7	168	9.5
15/09/2023 07:00	23.36	14.3	425.5	11.1	166.3	9.9
15/09/2023 08:00	24.58	14.3	424.9	11.6	166.3	10.4
15/09/2023 09:00	25.07	14.3	424.3	11.8	166.2	10.6
15/09/2023 10:00	25.87	14	423.4	13	159.6	11
15/09/2023 11:00	26.91	13.3	423.4	14.7	145.8	11.4
15/09/2023 12:00	27.69	13.3	422.4	15.2	144.9	11.8
15/09/2023 13:00	26.2	13.3	421.3	14.4	144.5	11.1
15/09/2023 14:00	26.32	13.2	420.4	14.5	144.2	11.2
15/09/2023 15:00	26.48	13.3	421.1	14.6	144	11.2
15/09/2023 16:00	25.66	14.1	421.7	12.5	156.4	10.9
15/09/2023 17:00	26.63	14.3	422.9	12.6	165.1	11.3

Site Report - GPSC CUP2 HRS G1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
15/09/2023 18:00	27.68	14.3	425.1	13.1	165.5	11.7
15/09/2023 19:00	27.58	14.3	425.7	13	165.7	11.7
15/09/2023 20:00	27.61	14.3	425.9	13.1	166	11.7
15/09/2023 21:00	27.61	14.3	426	13	166.2	11.7
15/09/2023 22:00	28.36	14.3	426.6	13.4	166.2	12
15/09/2023 23:00	28.14	14.4	426.9	13.3	166.5	11.9
16/09/2023 00:00	27.6	14.3	426	13	166.7	11.7
16/09/2023 01:00	26.26	14.3	425.6	12.4	166.6	11.1
16/09/2023 02:00	26.1	14.3	425.9	12.3	166.6	11.1
16/09/2023 03:00	25.31	14.3	424	12	166.4	10.7
16/09/2023 04:00	24.91	14.3	424.3	11.8	166.4	10.6
16/09/2023 05:00	23.84	14.3	422.4	11.3	166.3	10.1
16/09/2023 06:00	24.41	14.3	423.4	11.6	166.3	10.4
16/09/2023 07:00	25.11	14.3	424.5	11.9	166.6	10.7
16/09/2023 08:00	25.09	14.4	422.7	11.8	166.4	10.6
16/09/2023 09:00	25.07	14.4	421.7	11.8	166.3	10.6
16/09/2023 10:00	<Samp	<Samp	<Samp	<Samp	171.2	<Samp
16/09/2023 11:00	23.11	14.4	418.8	10.9	165.5	9.8
16/09/2023 12:00	24.49	14.4	418.9	11.5	165.1	10.4
16/09/2023 13:00	24.2	14.3	418.9	11.4	165.1	10.3
16/09/2023 14:00	25.07	14.4	418.7	11.8	165	10.6
16/09/2023 15:00	26.09	14.4	420.3	12.2	165.9	11.1
16/09/2023 16:00	26.09	14.4	419.6	12.2	165.7	11.1
16/09/2023 17:00	26.78	14.4	420.8	12.6	165.7	11.4
16/09/2023 18:00	25.49	14.3	418.1	12	165.5	10.8
16/09/2023 19:00	24.68	14.3	416.3	11.7	165.2	10.5
16/09/2023 20:00	25.26	14.3	417.1	12	164.9	10.7
16/09/2023 21:00	25.4	14.3	415.7	12	164.2	10.8
16/09/2023 22:00	24.6	14.3	413.8	11.7	163.8	10.4
16/09/2023 23:00	24.75	14.3	414.1	11.8	163.9	10.5
17/09/2023 00:00	24.81	14.3	413.8	11.8	163.9	10.5
17/09/2023 01:00	26.25	14.3	412.7	12.5	163.7	11.1
17/09/2023 02:00	25.16	14.3	412.2	12	163.8	10.7
17/09/2023 03:00	24.37	14.3	412.2	11.6	163.8	10.3
17/09/2023 04:00	24.07	14.3	411.5	11.5	164.7	10.2
17/09/2023 05:00	24.25	14.3	411.4	11.6	164.2	10.3
17/09/2023 06:00	24.59	14.3	411.3	11.7	163.6	10.4
17/09/2023 07:00	24.13	14.3	412.3	11.5	163.8	10.2
17/09/2023 08:00	23.73	14.3	413.6	11.3	164.2	10.1
17/09/2023 09:00	11.91	15	336.2	5.1	165.9	5.1
17/09/2023 10:00	12.3	15.3	333.1	4.9	172.6	5.2
17/09/2023 11:00	15.29	14.8	333.3	6.7	164.3	6.5
17/09/2023 12:00	12.87	15.8	332.3	4.7	183.5	5.5
17/09/2023 13:00	12.95	15.8	331.9	4.7	184.8	5.5
17/09/2023 14:00	12.71	15.8	332.2	4.6	185.3	5.4
17/09/2023 15:00	13.48	15.8	332.3	4.9	185.5	5.7
17/09/2023 16:00	13.79	15.8	332.7	5	186.6	5.9
17/09/2023 17:00	13.9	15.8	332.6	5.1	186.1	5.9
17/09/2023 18:00	14.19	15.8	333	5.2	185.9	6
17/09/2023 19:00	14.21	15.8	333.4	5.2	186	6
17/09/2023 20:00	14.53	15.8	333.6	5.3	186.3	6.2
17/09/2023 21:00	14.73	15.8	333.4	5.4	186	6.3
17/09/2023 22:00	14.73	15.8	333.4	5.4	186.6	6.3
17/09/2023 23:00	16.46	15.6	334.1	6.2	183.9	7
18/09/2023 00:00	18.72	15.3	338	7.6	180.4	7.9
18/09/2023 01:00	25.11	14.5	383.7	11.5	169.3	10.7
18/09/2023 02:00	23.24	14.3	419.3	11.1	167.3	9.9
18/09/2023 03:00	24.4	14.3	418.9	11.7	165.8	10.4
18/09/2023 04:00	24.75	14.3	455.4	11.8	165.9	10.5

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
18/09/2023 05:00	24.25	14.2	465.4	11.6	165.3	10.3
18/09/2023 06:00	25.19	14.3	446.6	12	165.3	10.7
18/09/2023 07:00	25.19	14.3	464.1	12	165.7	10.7
18/09/2023 08:00	25.69	14.3	472.7	12.2	166.2	10.9
18/09/2023 09:00	25.94	14.3	466.8	12.3	166.6	11
18/09/2023 10:00	26.86	14.4	467.6	12.6	166	11.4
18/09/2023 11:00	27.21	14.4	465	12.8	165.6	11.5
18/09/2023 12:00	27.72	14.4	463.7	13	165.4	11.8
18/09/2023 13:00	28.23	14.4	468.9	13.3	165.6	12
18/09/2023 14:00	28.38	14.4	460.6	13.3	165.5	12
18/09/2023 15:00	25.28	14.4	454.4	11.9	166.2	10.7
19/09/2023 16:00	25.53	14.4	478.2	12	166	10.8
19/09/2023 17:00	26.36	14.4	482.9	12.4	165.7	11.2
18/09/2023 18:00	26.38	14.4	485.9	12.4	166.4	11.2
18/09/2023 19:00	26.83	14.3	468.6	12.6	166.9	11.4
18/09/2023 20:00	25.83	14.3	449.9	12.2	166.0	11
18/09/2023 21:00	26.51	14.3	473.5	12.5	166.5	11.3
18/09/2023 22:00	27.56	14.3	456.3	13	167.3	11.7
18/09/2023 23:00	26.82	14.3	438.9	12.7	167.6	11.4
19/09/2023 00:00	26.8	14.3	426.2	12.7	167.6	11.4
19/09/2023 01:00	25.53	14.3	423.5	12.1	167.5	10.8
19/09/2023 02:00	25.16	14.3	421.7	12	167	10.7
19/09/2023 03:00	25.47	14.3	423.7	12.1	167.2	10.8
19/09/2023 04:00	24.85	14.3	421.7	11.8	167	10.5
19/09/2023 05:00	24.92	14.3	420.7	11.9	166.9	10.6
19/09/2023 06:00	24.76	14.3	420.5	11.8	166.7	10.5
19/09/2023 07:00	24.78	14.3	423.2	11.8	167	10.5
19/09/2023 08:00	25.75	14.3	424.1	12.2	167.2	10.9
19/09/2023 09:00	26.71	14.4	421.5	12.6	166.7	11.3
19/09/2023 10:00	28.03	14.4	419.8	13.1	166.5	11.9
19/09/2023 11:00	25.84	14.4	419.1	12.1	166.5	11
19/09/2023 12:00	24.65	14.3	421	11.7	166.6	10.5
19/09/2023 13:00	24.49	14.3	422.5	11.6	166.3	10.4
19/09/2023 14:00	25.05	14.3	419.7	11.8	166.4	10.6
19/09/2023 15:00	<Samp	<Samp	<Samp	<Samp	<Samp	<Samp
19/09/2023 16:00	---	---	---	---	---	---
19/09/2023 17:00	---	---	---	---	---	---
19/09/2023 18:00	---	---	---	---	---	---
19/09/2023 19:00	---	---	---	---	---	---
19/09/2023 20:00	---	---	---	---	---	---
19/09/2023 21:00	---	---	---	---	---	---
19/09/2023 22:00	---	---	---	---	---	---
19/09/2023 23:00	---	---	---	---	---	---
20/09/2023 00:00	---	---	---	---	---	---
20/09/2023 01:00	---	---	---	---	---	---
20/09/2023 02:00	---	---	---	---	---	---
20/09/2023 03:00	---	---	---	---	---	---
20/09/2023 04:00	---	---	---	---	---	---
20/09/2023 05:00	---	---	---	---	---	---
20/09/2023 06:00	---	---	---	---	---	---
20/09/2023 07:00	---	---	---	---	---	---
20/09/2023 08:00	---	---	---	---	---	---
20/09/2023 09:00	---	---	---	---	---	---
20/09/2023 10:00	---	---	---	---	---	---
20/09/2023 11:00	---	---	---	---	---	---
20/09/2023 12:00	---	---	---	---	---	---
20/09/2023 13:00	---	---	---	---	---	---
20/09/2023 14:00	29.15	14.3	424.3	13.8	165.1	12.4
20/09/2023 15:00	27.65	14.3	418.9	13.2	163.8	11.7

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
20/09/2023 16:00	25.52	14.3	418.5	12.2	164.8	10.8
20/09/2023 17:00	25.37	14.3	419.2	12.1	165.6	10.8
20/09/2023 18:00	25.29	14.3	419.2	12.1	165.8	10.7
20/09/2023 19:00	25.26	14.3	419.7	12.1	165.9	10.7
20/09/2023 20:00	25.03	14.3	419.4	11.9	165.6	10.6
20/09/2023 21:00	22.18	14.3	419.8	10.6	165.3	9.4
20/09/2023 22:00	21.7	14.3	419.9	10.4	165.8	9.2
20/09/2023 23:00	21.72	14.3	420.2	10.4	166	9.2
21/09/2023 00:00	25.83	14.3	422.1	12.3	166.5	11
21/09/2023 01:00	25.34	14.3	420.4	12.1	166.2	10.8
21/09/2023 02:00	25.02	14.3	419.4	11.9	166.1	10.6
21/09/2023 03:00	25.07	14.3	419.9	12	166.2	10.6
21/09/2023 04:00	24.43	14.3	421.2	11.7	166.1	10.4
21/09/2023 05:00	24.45	14.3	421.3	11.7	165.9	10.4
21/09/2023 06:00	24.78	14.3	420.7	11.8	166.2	10.5
21/09/2023 07:00	24.85	14.3	421	11.8	166.3	10.5
21/09/2023 08:00	25.27	14.3	425.3	12	166.5	10.7
21/09/2023 09:00	25.16	14.3	424.3	11.9	166.7	10.7
21/09/2023 10:00	25.31	14.4	422.4	11.9	166.2	10.7
21/09/2023 11:00	25.51	14.4	418.6	12	165.8	10.8
21/09/2023 12:00	25.72	14.4	417.7	12.1	166	10.9
21/09/2023 13:00	24.35	14.4	415.7	11.4	165.7	10.3
21/09/2023 14:00	25.28	14.4	420.2	11.9	165.2	10.7
21/09/2023 15:00	26.7	14.3	422.3	12.6	165.1	11.3
21/09/2023 16:00	25.96	14.3	419.9	12.4	164	11
21/09/2023 17:00	22.51	14.3	420	10.7	164.9	9.6
21/09/2023 18:00	21.34	14.3	419.9	10.2	165.3	9.1
21/09/2023 19:00	23.39	14.3	418.2	11.1	165.2	9.9
21/09/2023 20:00	23.65	14.3	417.7	11.3	165.2	10
21/09/2023 21:00	24.59	14.3	418	11.7	165.6	10.4
21/09/2023 22:00	25	14.3	418	11.9	165.2	10.6
21/09/2023 23:00	24.21	14.3	418.8	11.6	165.6	10.3
22/09/2023 00:00	25.36	14.3	419.7	12.1	165.8	10.8
22/09/2023 01:00	24.8	14.3	419.6	11.8	165.9	10.5
22/09/2023 02:00	24.29	14.3	418.5	11.6	166.2	10.3
22/09/2023 03:00	23.92	14.3	418.3	11.4	166.2	10.2
22/09/2023 04:00	24.03	14.3	418.7	11.5	166	10.2
22/09/2023 05:00	23.35	14.2	418.6	11.2	166.1	9.9
22/09/2023 06:00	23.3	14.2	418	11.2	166	9.9
22/09/2023 07:00	23.32	14.3	419.1	11.1	166.1	9.9
22/09/2023 08:00	23.57	14.3	421.2	11.2	166.2	10
22/09/2023 09:00	24.11	14.3	426.1	11.4	167.2	10.2
22/09/2023 10:00	25.13	14.4	424.6	11.8	167.2	10.7
22/09/2023 11:00	24.98	14.4	421.7	11.7	166.8	10.6
22/09/2023 12:00	25.81	14.4	420	12.1	166.8	11
22/09/2023 13:00	23.7	14.4	419.3	11.2	166.6	10.1
22/09/2023 14:00	24.48	14.4	419.4	11.5	166.1	10.4
22/09/2023 15:00	24.78	14.4	419.6	11.7	166.1	10.5
22/09/2023 16:00	24.57	14.4	420.6	11.6	166.3	10.4
22/09/2023 17:00	26.04	14.4	422.6	12.3	166.5	11.1
22/09/2023 18:00	26.1	14.3	423.5	12.3	166.8	11.1
22/09/2023 19:00	26.98	14.3	425.4	12.7	167.1	11.5
22/09/2023 20:00	26.55	14.1	427.4	12.9	162.1	11.3
22/09/2023 21:00	26.82	14	428.5	13.2	158.5	11.4
22/09/2023 22:00	26.44	14.1	426.8	13	158.8	11.2
22/09/2023 23:00	25.97	14.2	424.1	12.6	163.5	11
23/09/2023 00:00	25.56	14.2	423.3	12.4	163.4	10.8
23/09/2023 01:00	25.47	14.2	423.2	12.3	163.4	10.8
23/09/2023 02:00	25.56	14.2	423.8	12.4	163.4	10.8

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
23/09/2023 03:00	25.83	14.2	423.1	12.5	163.4	11
23/09/2023 04:00	25.88	14.2	422.1	12.5	163.2	11
23/09/2023 05:00	26.06	14.2	421.9	12.6	163.2	11.1
23/09/2023 06:00	25.91	14.2	421.6	12.6	163.1	11
23/09/2023 07:00	25.54	14.2	423	12.4	163.2	10.8
23/09/2023 08:00	25.83	14.2	422.2	12.4	163.8	11
23/09/2023 09:00	25.87	14.2	424.1	12.4	163.9	11
23/09/2023 10:00	25.97	14.3	419.9	12.4	163.4	11
23/09/2023 11:00	25.95	14.3	420.2	12.4	163	11
23/09/2023 12:00	26.93	14.3	416.6	12.8	162.5	11.4
23/09/2023 13:00	27.52	14.3	415.8	13.1	162	11.7
23/09/2023 14:00	27.38	14.3	417.7	13.1	161.9	11.6
23/09/2023 15:00	27.93	14.3	420.8	13.3	162.4	11.9
23/09/2023 16:00	27.94	14.3	419.5	13.3	162.4	11.9
23/09/2023 17:00	29.19	14.3	420.1	14	162.3	12.4
23/09/2023 18:00	28.38	14.2	421.4	13.6	162.2	12
23/09/2023 19:00	27.81	14.2	426.2	13.4	162.9	11.8
23/09/2023 20:00	27.75	14.2	426.4	13.3	163.1	11.8
23/09/2023 21:00	28.32	14.2	427.2	13.6	163.7	12
23/09/2023 22:00	28.29	14.2	426.9	13.6	163.9	12
23/09/2023 23:00	27.86	14.2	425.3	13.4	163.8	11.8
24/09/2023 00:00	27.28	14.2	425.2	13.2	163.6	11.6
24/09/2023 01:00	26.67	14.2	425.2	12.9	163.8	11.3
24/09/2023 02:00	27.43	14.2	426.2	13.2	163.8	11.6
24/09/2023 03:00	27.3	14.2	425.2	13.2	163.7	11.6
24/09/2023 04:00	26.97	14.2	424.3	13	163.5	11.4
24/09/2023 05:00	26.66	14.2	422.8	12.9	163.5	11.3
24/09/2023 06:00	26.04	14.2	421.7	12.6	163.2	11.1
24/09/2023 07:00	25.6	14.2	425.5	12.4	163.6	10.9
24/09/2023 08:00	25.41	14.2	425.4	12.3	163.7	10.8
24/09/2023 09:00	26.73	14.2	423.3	12.9	161.8	11.3
24/09/2023 10:00	26.74	14.2	423.6	12.9	162.4	11.4
24/09/2023 11:00	26.48	14.2	422.4	12.7	162.3	11.2
24/09/2023 12:00	26.85	14.2	423.6	12.9	163.2	11.4
24/09/2023 13:00	28.13	14.2	425.3	13.5	163.3	11.9
24/09/2023 14:00	28.21	14.2	426.5	13.6	163.6	12
24/09/2023 15:00	27.97	14.2	425.7	13.5	163.7	11.9
24/09/2023 16:00	27.67	14.2	425.6	13.3	163.6	11.7
24/09/2023 17:00	28.01	14.2	426.5	13.5	163.7	11.9
24/09/2023 18:00	28.45	14.2	427.1	13.7	163.7	12.1
24/09/2023 19:00	28.43	14.2	426.7	13.7	163.7	12.1
24/09/2023 20:00	29.13	14.2	426.5	14.1	163.8	12.4
24/09/2023 21:00	29.46	14.2	425.1	14.2	163.7	12.5
24/09/2023 22:00	29.41	14.2	426	14.2	163.5	12.5
24/09/2023 23:00	29.45	14.2	426.2	14.2	163.9	12.5
25/09/2023 00:00	29.78	14.2	426.1	14.4	163.8	12.6
25/09/2023 01:00	30.06	14.2	425.6	14.5	163.6	12.8
25/09/2023 02:00	30.23	14.3	423.8	14.4	166.9	12.8
25/09/2023 03:00	27.41	14.3	424.3	13	166.7	11.6
25/09/2023 04:00	26.5	14.3	424.4	12.6	166.5	11.2
25/09/2023 05:00	26.13	14.3	422.1	12.5	166.8	11.1
25/09/2023 06:00	26.11	14.3	421.1	12.5	166.4	11.1
25/09/2023 07:00	25.87	14.2	424	12.5	164.6	11
25/09/2023 08:00	26.3	14.2	424	12.7	163.9	11.2
25/09/2023 09:00	27.62	14.2	422.2	13.3	163.7	11.7
25/09/2023 10:00	28.72	14.2	419.9	13.7	163.1	12.2
25/09/2023 11:00	28.08	14.2	417.8	13.4	162.5	11.9
25/09/2023 12:00	28.3	14.2	423.6	13.6	162.1	12
25/09/2023 13:00	26.28	14.2	420.3	12.7	161.7	11.2

Site Report - GPSC CUP2 HRS G1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
28/09/2023 01:00	27.9	14.3	425.7	13.3	163.3	11.8
28/09/2023 02:00	27.88	14.3	424.9	13.3	163.4	11.8
28/09/2023 03:00	27.98	14.3	425.5	13.4	163.1	11.9
28/09/2023 04:00	28.14	14.3	424.8	13.4	163	11.9
28/09/2023 05:00	28.12	14.3	424.1	13.4	162.7	11.9
28/09/2023 06:00	28.13	14.3	425.3	13.4	163.3	11.9
28/09/2023 07:00	28.01	14.3	423.5	13.4	163.3	11.9
28/09/2023 08:00	27.86	14.3	422.6	13.3	163.3	11.8
28/09/2023 09:00	28.04	14.3	421.7	13.4	163.1	11.9
28/09/2023 10:00	27.83	14.3	421.5	13.3	162.6	11.8
28/09/2023 11:00	27.56	14.3	421.3	13.1	162.7	11.7
28/09/2023 12:00	27.54	14.3	420.5	13.1	162.8	11.7
28/09/2023 13:00	26.7	14.3	417.9	12.7	161.8	11.3
28/09/2023 14:00	27.62	14.3	419.4	13.1	161.8	11.7
28/09/2023 15:00	28.73	14.3	420.6	13.7	161.6	12.2
28/09/2023 16:00	28.57	14.3	421.5	13.6	162	12.1
28/09/2023 17:00	28.6	14.3	421.7	13.6	162.1	12.1
28/09/2023 18:00	29.22	14.3	422.7	13.9	162.1	12.4
28/09/2023 19:00	29.25	14.3	422.6	14	162.1	12.4
28/09/2023 20:00	26.54	14.2	419.1	12.8	161.7	11.3
28/09/2023 21:00	25.79	14.2	418.8	12.5	162.2	10.9
28/09/2023 22:00	25.68	14.2	419.3	12.4	162.8	10.9
28/09/2023 23:00	25.75	14.2	418.4	12.5	162.9	10.9
29/09/2023 00:00	25.25	14.2	419.3	12.2	162.7	10.7
29/09/2023 01:00	25.2	14.2	418.5	12.2	163	10.7
29/09/2023 02:00	24.9	14.2	418.6	12.1	163	10.6
29/09/2023 03:00	24.68	14.2	418.9	12	163.2	10.5
29/09/2023 04:00	25	14.2	419.6	12.1	163	10.6
29/09/2023 05:00	25.02	14.2	419.5	12.1	162.9	10.6
29/09/2023 06:00	25.11	14.2	419.2	12.2	163.3	10.7
29/09/2023 07:00	24.69	14.2	422.2	11.9	163.5	10.5
29/09/2023 08:00	25.34	14.3	422.4	12.1	163.6	10.8
29/09/2023 09:00	25.54	14.3	421.5	12.2	163.5	10.8
29/09/2023 10:00	25.23	14.3	420.4	12	162.9	10.7
29/09/2023 11:00	25.08	14.3	419	11.9	162.6	10.6
29/09/2023 12:00	24.77	14.3	420.3	11.8	162.5	10.5
29/09/2023 13:00	24.06	14.3	420.8	11.5	162.9	10.2
29/09/2023 14:00	24.44	14.3	421.9	11.7	162.6	10.4
29/09/2023 15:00	25.04	14.3	419.7	11.9	162.6	10.6
29/09/2023 16:00	25.81	14.3	421.5	12.3	162.9	11
29/09/2023 17:00	26.98	14.3	422.9	12.9	162.9	11.5
29/09/2023 18:00	27.83	14.2	423	13.4	162.4	11.8
29/09/2023 19:00	28	14.2	420.4	13.5	162.2	11.9
29/09/2023 20:00	27.63	14.2	420.3	13.4	162.6	11.7
29/09/2023 21:00	27.12	14.2	419.8	13.1	163.1	11.5
29/09/2023 22:00	27.39	14.2	419.8	13.2	163.1	11.6
29/09/2023 23:00	27.14	14.2	418.9	13.1	163.3	11.5
30/09/2023 00:00	26.74	14.2	418.5	13	162.8	11.4
30/09/2023 01:00	25.84	14.2	418.7	12.5	162.6	11
30/09/2023 02:00	25.43	14.2	418.7	12.3	162.6	10.8
30/09/2023 03:00	26.02	14.2	418.7	12.6	162.7	11
30/09/2023 04:00	26.52	14.2	418.6	12.9	163.2	11.3
30/09/2023 05:00	27.05	14.2	418.9	13.1	163.2	11.5
30/09/2023 06:00	26.11	14.2	417.8	12.7	162.8	11.1
30/09/2023 07:00	25.13	14.2	421.5	12.1	163.5	10.7
30/09/2023 08:00	26.14	14.3	424.8	12.5	163.6	11.1
30/09/2023 09:00	26.13	14.3	423.9	12.5	163.6	11.1
30/09/2023 10:00	25.77	14.3	422.1	12.3	163.6	10.9
30/09/2023 11:00	25.83	14.3	422.7	12.3	163.2	11

Site Report - GPSC CUP2 HRS G1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
30/09/2023 12:00	25.89	14.3	419.8	12.3	163	11
30/09/2023 13:00	25.6	14.3	418.6	12.2	162.8	10.9
30/09/2023 14:00	25.46	14.3	419.3	12.1	162.7	10.8
30/09/2023 15:00	25.49	14.3	419.7	12.1	163.1	10.8
30/09/2023 16:00	25.82	14.3	421.4	12.3	162.5	11
30/09/2023 17:00	26.66	14.3	423.4	12.7	162.8	11.3
30/09/2023 18:00	27.29	14.3	425.6	12.9	165.1	11.6
30/09/2023 19:00	27.88	14.4	426.2	13.1	167.3	11.8
30/09/2023 20:00	28.46	14.4	426.6	13.4	167.3	12.1
30/09/2023 21:00	28.93	14.4	427	13.6	167.2	12.3
30/09/2023 22:00	29.09	14.4	426	13.7	167.1	12.3
30/09/2023 23:00	28.53	14.3	424.4	13.4	167.2	12.1
Minimum	11.91	12.7	331.9	4.6	128.5	5.1
MinDate	17/09/2023 09:00	01/09/2023 12:00	17/09/2023 13:00	02/09/2023 14:00	02/09/2023 13:00	17/09/2023 09:00
Maximum	30.23	15.8	485.9	16.9	186.6	12.8
MaxDate	25/09/2023 02:00	17/09/2023 12:00	18/09/2023 18:00	01/09/2023 18:00	17/09/2023 22:00	25/09/2023 01:00
Avg	25.67	14.2	420.4	12.4	162.9	10.9
Num	470	470	470	470	473	470
Data[%]	65.2	65.2	65.2	65.2	65.4	65.2
STD	2.7	0.5	19	1.7	8.6	1.1

Site Report - GPSC CUP2 HRS G1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
01/10/2023 00:00	26.74	14.3	423.5	12.6	167.3	11.3
01/10/2023 01:00	26.29	14.3	423.8	12.4	166.9	11.2
01/10/2023 02:00	25.16	14.3	422.5	11.9	166.4	10.7
01/10/2023 03:00	25.16	14.1	421.8	12.2	162	10.7
01/10/2023 04:00	25.57	14.1	421.7	12.5	160	10.9
01/10/2023 05:00	25.35	14.1	420.9	12.4	159.5	10.8
01/10/2023 06:00	25.73	14.1	420.4	12.6	159.7	10.9
01/10/2023 07:00	25.73	14.1	422.9	12.6	160	10.9
01/10/2023 08:00	26.5	14.2	425.9	12.7	163.1	11.2
01/10/2023 09:00	26.76	14.3	422.5	12.7	163.9	11.4
01/10/2023 10:00	27.33	14.3	421.4	13	163.5	11.6
01/10/2023 11:00	25.83	14.3	419.3	12.3	163.5	11
01/10/2023 12:00	24.47	14.3	416.5	11.7	162.8	10.4
01/10/2023 13:00	24.03	14.3	416.1	11.4	162.4	10.2
01/10/2023 14:00	24.73	14.3	419.8	11.8	162.5	10.5
01/10/2023 15:00	25.36	14.3	423.5	12.1	162.8	10.8
01/10/2023 16:00	26.13	14.2	424.5	12.5	163.3	11.1
01/10/2023 17:00	27.82	14.3	424.2	13.3	163.2	11.8
01/10/2023 18:00	28.23	14.3	425.3	13.5	163.2	12
01/10/2023 19:00	28.12	14.2	426.1	13.5	163.5	11.9
01/10/2023 20:00	28.04	14.2	425.5	13.5	163.6	11.9
01/10/2023 21:00	28.37	14.2	424.2	13.6	163.3	12
01/10/2023 22:00	28.76	14.2	424.5	13.8	163.5	12.2
01/10/2023 23:00	28.99	14.2	425.7	13.9	163.2	12.3
02/10/2023 00:00	26.97	14.2	425.7	12.9	163.1	11.4
02/10/2023 01:00	25.72	14.2	424.9	12.4	163.4	10.9
02/10/2023 02:00	25.89	14.2	421.3	12.5	162.4	11
02/10/2023 03:00	27.76	14	415.8	13.8	155.1	11.8
02/10/2023 04:00	28.6	14	417.7	14.3	155.4	12.1
02/10/2023 05:00	28.2	14	418.1	14.1	155.3	12
02/10/2023 06:00	27.59	14.1	417.8	13.6	157.9	11.7
02/10/2023 07:00	27.72	14.1	418.9	13.6	158.9	11.8
02/10/2023 08:00	27.45	14.1	421.7	13.3	160.8	11.7
02/10/2023 09:00	27.2	14.3	423.6	13	164.3	11.5
02/10/2023 10:00	27.44	14.2	424.6	13.1	163.8	11.6
02/10/2023 11:00	26.62	14.3	423.1	13.7	163.1	12.1
02/10/2023 12:00	27	14.3	421.5	12.9	162.7	11.5
02/10/2023 13:00	26.42	14.3	420.7	12.6	162.2	11.2
02/10/2023 14:00	26.08	14.3	415.5	12.5	161.6	11.1
02/10/2023 15:00	26.86	14.3	420.1	12.8	161.6	11.7
02/10/2023 16:00	27.73	14.3	420.9	13.2	161.8	11.8
02/10/2023 17:00	27.87	14.3	421.7	13.3	162	11.8
02/10/2023 18:00	27.81	14.2	424	13.3	162.4	11.8
02/10/2023 19:00	28.56	14.2	425	13.7	162.7	12.1
02/10/2023 20:00	28.67	14.2	426.1	13.7	162.8	12.2
02/10/2023 21:00	24.8	14.2	426.4	11.9	162.7	10.5
02/10/2023 22:00	25.27	14.2	427.1	12.1	162.7	10.7
02/10/2023 23:00	25.72	14.2	426.5	12.3	162.8	10.9
03/10/2023 00:00	25.27	14.2	425.5	12.2	162.6	10.7
03/10/2023 01:00	24.71	14.2	426.1	11.9	162.6	10.5
03/10/2023 02:00	24.9	14.2	424.8	12	162.6	10.6
03/10/2023 03:00	25.19	14.2	423.9	12.1	162.4	10.7
03/10/2023 04:00	24.9	14.2	421.9	12.1	162.4	10.6
03/10/2023 05:00	24.11	14.2	421.2	11.7	162.9	10.2
03/10/2023 06:00	24.47	14.2	421.4	11.9	162.5	10.4
03/10/2023 07:00	24.14	14.2	423	11.7	162.7	10.2
03/10/2023 08:00	25.7	14.2	425.5	12.4	163.1	10.9
03/10/2023 09:00	26.74	14.2	423.5	12.8	163.3	11.3
03/10/2023 10:00	26.54	14.2	422.8	12.7	162.3	11.3

Site Report - GPSC CUP2 HRS G1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
03/10/2023 11:00	27.71	14.2	424.7	13.4	161	11.8
03/10/2023 12:00	26.44	14.2	421.3	12.8	160.3	11.2
03/10/2023 13:00	25.82	13.9	424.3	12.9	153.8	11
03/10/2023 14:00	24.63	13.9	421.7	12.3	152.4	10.5
03/10/2023 15:00	24.81	14	422.7	12.3	147	10.5
03/10/2023 16:00	24.82	14.1	425.5	12.2	158.1	10.5
03/10/2023 17:00	25.88	14.2	425.6	12.4	163.3	11
03/10/2023 18:00	26.39	14.2	424.2	12.7	163.3	11.2
03/10/2023 19:00	25.81	14.2	423.2	12.4	163.4	11
03/10/2023 20:00	25.75	14.2	421.9	12.4	163	10.9
03/10/2023 21:00	26.24	14.2	420.7	12.7	162.3	11.1
03/10/2023 22:00	26.96	14.2	420	13	162.6	11.4
03/10/2023 23:00	27	14.2	420.1	13	162.5	11.5
04/10/2023 00:00	27.05	14.2	419.5	13	162	11.5
04/10/2023 01:00	27.03	14.2	419.2	13	161.8	11.5
04/10/2023 02:00	26.37	14.2	419	12.7	162	11.2
04/10/2023 03:00	25.41	14.2	418.6	12.3	161.9	10.8
04/10/2023 04:00	25.14	14.2	418.6	12.1	161.8	10.7
04/10/2023 05:00	24.52	14.2	418.8	11.8	162	10.4
04/10/2023 06:00	24.14	14.2	418.8	11.6	162.3	10.2
04/10/2023 07:00	23.79	14.2	419.6	11.5	162.5	10.1
04/10/2023 08:00	23.5	14.2	421.1	11.3	163	10
04/10/2023 09:00	23.45	14.3	425.9	11.2	163.6	10
04/10/2023 10:00	24.3	14.3	425.3	11.6	163.6	10.3
04/10/2023 11:00	24.44	14.3	425.5	11.7	163.5	10.4
04/10/2023 12:00	24.79	14.3	427	11.8	163.4	10.5
04/10/2023 13:00	24.08	14.3	425.8	11.5	163.4	10.2
04/10/2023 14:00	24.45	14.3	424.3	11.6	163	10.4
04/10/2023 15:00	24.28	14.3	423.4	11.6	162.7	10.3
04/10/2023 16:00	23.91	14.3	425.7	11.4	162.8	10.1
04/10/2023 17:00	24.82	14.2	426.9	11.9	162.8	10.5
04/10/2023 18:00	25.66	14.2	426.6	12.3	163.1	10.9
04/10/2023 19:00	25.07	14.2	426.7	12	163.1	10.6
04/10/2023 20:00	24.65	14.2	424.4	11.8	163.2	10.5
04/10/2023 21:00	24.58	14.2	423.4	11.8	163.3	10.4
04/10/2023 22:00	24.34	14.2	422.1	11.7	163	10.3
04/10/2023 23:00	24.1	14.2	421.5	11.6	162.9	10.2
05/10/2023 00:00	24.11	14.2	421.1	11.6	163.2	10.2
05/10/2023 01:00	23.94	14.2	470.4	11.6	163.2	10.2
05/10/2023 02:00	24.16	14.2	423.5	11.7	162.8	10.3
05/10/2023 03:00	24.27	14.2	431.6	11.7	162.6	10.3
05/10/2023 04:00	24.31	14.2	432.8	11.8	162.5	10.3
05/10/2023 05:00	24.5	14.2	439.1	11.9	162.2	10.4
05/10/2023 06:00	24.5	14.2	474.3	11.8	162.5	10.4
05/10/2023 07:00	24.4	14.2	448.1	11.8	162.8	10.4
05/10/2023 08:00	24.77	14.2	439.5	11.9	163.6	10.5
05/10/2023 09:00	25.09	14.2	449.8	12	163.8	10.7
05/10/2023 10:00	25.34	14.2	455.6	12.1	163.7	10.8
05/10/2023 11:00	26.2	14.3	452.7	12.5	163.9	11.1
05/10/2023 12:00	26.91	14.3	442.4	12.9	163.9	11.4
05/10/2023 13:00	27.21	14.2	449.7	13.1	163.4	11.5
05/10/2023 14:00	27.02	14.2	442.8	13	163.2	11.5
05/10/2023 15:00	26.11	14.2	425.8	12.5	163.4	11.1
05/10/2023 16:00	25.81	14.2	423.6	12.4	163.2	11
05/10/2023 17:00	25.82	14.2	423.2	12.4	163.1	11
05/10/2023 18:00	26.35	14.2	424.3	12.6	163.3	11.2
05/10/2023 19:00	26.71	14.3	424.8	12.8	163.5	11.3
05/10/2023 20:00	26.77	14.3	423.3	12.8	163.1	11.4
05/10/2023 21:00	27.24	14.3	423.3	13	162.8	11.6

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
05/10/2023 22:00	26.21	14.3	423	12.5	162.1	11.1
05/10/2023 23:00	26.1	14.2	426.3	12.5	162.1	11.1
06/10/2023 00:00	26.12	14.2	425.3	12.5	163.1	11.1
06/10/2023 01:00	27.2	14.2	426.1	13	163.4	11.5
06/10/2023 02:00	27.5	14.3	426.2	13.2	163.6	11.7
06/10/2023 03:00	27.28	14.2	426	13.1	163.3	11.6
06/10/2023 04:00	26.73	14.3	425.7	12.8	163.1	11.3
06/10/2023 05:00	26.74	14.3	426.1	12.8	163.2	11.4
06/10/2023 06:00	26.8	14.2	427.1	12.8	163.7	11.4
06/10/2023 07:00	26.43	14.2	426.1	12.7	163.8	11.2
06/10/2023 08:00	26.85	14.3	424.5	12.8	163.5	11.4
06/10/2023 09:00	26.76	14.3	421.9	12.8	163.4	11.4
06/10/2023 10:00	25.85	14.3	418.7	12.3	163.1	11
06/10/2023 11:00	23.52	14.3	418.7	11.2	163	10
06/10/2023 12:00	24.17	14.3	418.8	11.5	162.7	10.3
06/10/2023 13:00	25.34	14.2	421.2	12.2	159.9	10.8
06/10/2023 14:00	26.17	14.2	423.1	12.7	159.9	11.1
06/10/2023 15:00	26.88	14.2	424	13	159.9	11.4
06/10/2023 16:00	27.17	14.2	423.8	13.1	160.1	11.5
06/10/2023 17:00	26.87	14.2	425.1	13	160	11.4
06/10/2023 18:00	27.29	14.2	425.6	13.2	160.2	11.6
06/10/2023 19:00	27.74	14.3	425.4	13.2	164.2	11.8
06/10/2023 20:00	27.82	14.3	425.5	13.2	164.7	11.8
06/10/2023 21:00	27.59	14.3	426.1	13.1	164.9	11.7
06/10/2023 22:00	27.37	14.3	428.9	13	165.2	11.6
06/10/2023 23:00	27.73	14.3	426	13.2	165.1	11.8
07/10/2023 00:00	26.99	14.3	425.2	12.9	164.9	11.5
07/10/2023 01:00	27.31	14.3	425.8	13	164.8	11.6
07/10/2023 02:00	27.45	14.3	424.9	13.1	164.8	11.7
07/10/2023 03:00	27.89	14.3	425	13.3	164.7	11.8
07/10/2023 04:00	26.76	14.3	423.9	12.8	164.6	11.4
07/10/2023 05:00	26.33	14.3	422.7	12.6	164.6	11.2
07/10/2023 06:00	26.49	14.3	422.1	12.7	164.7	11.2
07/10/2023 07:00	25.86	14.3	424.5	12.3	165	11
07/10/2023 08:00	25.8	14.3	425	12.2	164.9	10.9
07/10/2023 09:00	25.74	14.3	423.9	12.2	165	10.9
07/10/2023 10:00	25.68	14.3	421.6	12.2	164.7	10.9
07/10/2023 11:00	25.82	14.2	421.2	12.4	162.2	11
07/10/2023 12:00	26.73	14.2	427.4	12.8	162.2	11.3
07/10/2023 13:00	26.11	14.2	422.8	12.5	161.6	11.1
07/10/2023 14:00	26.91	14.2	423.7	12.9	161.4	11.4
07/10/2023 15:00	27.06	14.2	423.1	13	161.7	11.5
07/10/2023 16:00	27.04	14.2	423.5	13	161.9	11.5
07/10/2023 17:00	27.53	14.2	424.7	13.2	161.5	11.7
07/10/2023 18:00	27.99	14.2	425.9	13.5	161.5	11.9
07/10/2023 19:00	29.11	14.2	440.4	14	161.6	12.4
07/10/2023 20:00	27.86	14.3	452	13.3	164.1	11.8
07/10/2023 21:00	27.43	14.3	446.2	13.1	164.6	11.6
07/10/2023 22:00	27.61	14.3	463.3	13.1	164.8	11.7
07/10/2023 23:00	27.16	14.3	449.1	13	164.8	11.5
08/10/2023 00:00	26.41	14.2	450.3	12.7	164.1	11.2
08/10/2023 01:00	26.11	14.2	451.1	12.5	163.7	11.1
08/10/2023 02:00	25.65	14.2	446.5	12.4	163.5	10.9
08/10/2023 03:00	25.85	14.2	448.6	12.5	163.4	11
08/10/2023 04:00	26.64	14.2	445.8	12.8	163.3	11.3
08/10/2023 05:00	26.74	14.2	429.7	12.9	163.4	11.3
08/10/2023 06:00	26.72	14.2	430.6	12.9	163.5	11.3
08/10/2023 07:00	26.33	14.2	423.1	12.7	163.7	11.2
08/10/2023 08:00	26.52	14.3	424.3	12.7	163.9	11.3

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
08/10/2023 09:00	26.53	14.3	422.2	12.6	163.6	11.3
08/10/2023 10:00	25.55	14.3	420.7	12.2	163.6	10.8
08/10/2023 11:00	24.49	14.3	420.1	11.6	163.5	10.4
08/10/2023 12:00	27.02	14.3	423	12.8	163.6	11.5
08/10/2023 13:00	26.58	14.2	422.5	12.7	161.9	11.3
08/10/2023 14:00	26.1	14.3	423.3	12.4	163.5	11.1
08/10/2023 15:00	26.76	14.3	424.6	12.8	163.7	11.4
08/10/2023 16:00	28.4	14.3	425.2	13.5	163.8	12.1
08/10/2023 17:00	28.54	14.3	425.2	13.6	163.6	12.1
08/10/2023 18:00	28.58	14.3	426.2	13.6	163.8	12.1
08/10/2023 19:00	28.92	14.3	426.8	13.8	164	12.3
08/10/2023 20:00	30.03	14.3	427.3	14.3	164.3	12.7
08/10/2023 21:00	30.29	14.3	427.3	14.5	164.3	12.9
08/10/2023 22:00	28.92	14.3	426.5	13.8	164.1	12.3
08/10/2023 23:00	28.16	14.2	426	13.5	163.9	12
09/10/2023 00:00	28.52	14.2	425.4	13.7	164	12.1
09/10/2023 01:00	27.69	14.2	423	13.3	163.4	11.8
09/10/2023 02:00	26.73	14.2	423	12.8	163.5	11.3
09/10/2023 03:00	26.39	14.2	422.6	12.6	163.4	11.2
09/10/2023 04:00	25.34	14.2	420.8	12.2	163.4	10.8
09/10/2023 05:00	25.03	14.2	420.3	12.1	163.5	10.6
09/10/2023 06:00	24.69	14.2	419.5	11.9	163.3	10.5
09/10/2023 07:00	25.53	14.2	373.9	12.3	163.5	10.8
09/10/2023 08:00	26.61	14.2	363.4	12.8	163.4	11.3
09/10/2023 09:00	27.35	14.2	416.4	13.1	164.5	11.6
09/10/2023 10:00	28.52	14.3	425.4	13.6	164.3	12.1
09/10/2023 11:00	27.97	14.3	424.7	13.3	164.7	11.9
09/10/2023 12:00	27.66	14.2	423	13.3	162.6	11.7
09/10/2023 13:00	28.58	14.2	422.4	13.8	160.2	12.1
09/10/2023 14:00	28.39	14.2	421	13.7	159.8	12.1
09/10/2023 15:00	27.2	14.1	419.8	13.2	158	11.5
09/10/2023 16:00	26.92	14.1	398.5	13.1	157.5	11.4
09/10/2023 17:00	27.28	14.1	390	13.3	157.8	11.6
09/10/2023 18:00	28	14.1	410.6	13.6	159.1	11.9
09/10/2023 19:00	27.79	14.2	408.5	13.3	162.4	11.8
09/10/2023 20:00	27.75	14.2	427.6	13.3	162.2	11.8
09/10/2023 21:00	26.28	14.2	428.9	12.7	162.6	11.2
09/10/2023 22:00	25.91	14.2	424.1	12.6	162	11
09/10/2023 23:00	26.05	14.2	423	12.6	162	11.1
10/10/2023 00:00	26.57	14.2	422.7	12.9	161.6	11.3
10/10/2023 01:00	26.5	14.1	421.9	12.9	161.1	11.3
10/10/2023 02:00	27.38	14.2	421.9	13.3	161.2	11.6
10/10/2023 03:00	27.58	14.2	421.5	13.4	160.9	11.7
10/10/2023 04:00	27.29	14.1	421.6	13.3	160.8	11.6
10/10/2023 05:00	27.11	14.1	419.7	13.2	160.7	11.5
10/10/2023 06:00	27.34	14.1	419.6	13.3	161	11.6
10/10/2023 07:00	26.6	14.1	419.8	13	160.9	11.3
10/10/2023 08:00	25.68	14.2	420.7	12.5	162	10.9
10/10/2023 09:00	26	14.2	426.8	12.5	162.3	11
10/10/2023 10:00	26.28	14.2	425.6	12.6	162.1	11.2
10/10/2023 11:00	25.44	14.2	424.4	12.2	162.1	10.8
10/10/2023 12:00	25.63	14.2	426.4	12.3	161.8	10.9
10/10/2023 13:00	25.94	14.2	425.3	12.5	162	11
10/10/2023 14:00	26.81	14.2	424.7	12.9	161.3	11.4
10/10/2023 15:00	26.92	14.2	427.7	13	161.2	11.4
10/10/2023 16:00	25.98	14.2	426.8	12.6	161	11
10/10/2023 17:00	26.43	14.2	427.6	12.8	161.5	11.2
10/10/2023 18:00	27.6	14.2	425.1	13.4	161.9	11.7
10/10/2023 19:00	28.39	14.1	421.5	13.8	161.3	12.1

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
10/10/2023 20:00	28.32	14.1	421	13.8	161.2	12
10/10/2023 21:00	28.47	14.1	420.7	13.9	161.1	12.1
10/10/2023 22:00	28.34	14.1	420.6	13.8	160.5	12
10/10/2023 23:00	27.95	14.2	420.8	13.5	161	11.9
11/10/2023 00:00	27.5	14.1	421.5	13.4	161	11.7
11/10/2023 01:00	26.49	14.2	420.9	12.8	161.9	11.2
11/10/2023 02:00	26.19	14.2	420.1	12.7	162.2	11.1
11/10/2023 03:00	26.37	14.2	419.8	12.8	161.7	11.2
11/10/2023 04:00	26.39	14.2	420.9	12.8	161.9	11.2
11/10/2023 05:00	25.93	14.2	420.7	12.6	161.8	11
11/10/2023 06:00	25.94	14.2	420.4	12.6	162.2	11
11/10/2023 07:00	25.89	14.2	421.2	12.5	162.6	11
11/10/2023 08:00	25.45	14.2	423.7	12.3	162.8	10.8
11/10/2023 09:00	25.18	14.2	425.9	12.1	163.7	10.7
11/10/2023 10:00	25.08	14.2	423.6	12.1	162.5	10.6
11/10/2023 11:00	25.71	14.2	423.5	12.4	161.3	10.9
11/10/2023 12:00	26.03	14.2	420.6	12.5	160.9	11
11/10/2023 13:00	25.82	14.2	420.1	12.4	160.3	11
11/10/2023 14:00	25.96	14.2	422.6	12.5	161	11
11/10/2023 15:00	27.27	14.2	428	13.2	160.8	11.6
11/10/2023 16:00	27.38	14.1	424.5	13.3	160.1	11.6
11/10/2023 17:00	27.55	14.1	427	13.4	160.8	11.7
11/10/2023 18:00	27.72	14.2	425.1	13.4	161.7	11.8
11/10/2023 19:00	27.86	14.1	423.6	13.5	161.4	11.8
11/10/2023 20:00	27.82	14.1	422.5	13.5	161.7	11.8
11/10/2023 21:00	27.83	14.1	421.6	13.5	161.8	11.8
11/10/2023 22:00	27.77	14.1	421.6	13.6	160.1	11.8
11/10/2023 23:00	28.2	14.1	421.7	13.8	159.8	12
12/10/2023 00:00	28	14	421.2	13.9	158.1	11.9
12/10/2023 01:00	27.66	14	421.1	13.8	157.7	11.7
12/10/2023 02:00	27.67	14	421.9	13.7	158.3	11.7
12/10/2023 03:00	28.7	14	421.4	14.2	158.4	12.2
12/10/2023 04:00	28.86	14	420.9	14.2	158.8	12.2
12/10/2023 05:00	28.89	14	421.8	14.3	157.4	12.3
12/10/2023 06:00	27.81	14	418.7	13.8	155	11.8
12/10/2023 07:00	27.67	14	419	13.8	155.2	11.7
12/10/2023 08:00	26.59	14	422	13.2	156.6	11.3
12/10/2023 09:00	25.91	14.1	427	12.8	158	11
12/10/2023 10:00	25.77	14.1	427.3	12.7	157.7	10.9
12/10/2023 11:00	25.85	14.1	427.5	12.7	158.8	11
12/10/2023 12:00	24.94	14.1	423.9	12.2	158.5	10.6
12/10/2023 13:00	<Samp	<Samp	<Samp	<Samp	158.5	<Samp
12/10/2023 14:00	<Samp	<Samp	<Samp	<Samp	158.8	<Samp
12/10/2023 15:00	<Samp	<Samp	<Samp	<Samp	161.4	<Samp
12/10/2023 16:00	<Samp	<Samp	<Samp	<Samp	157.3	<Samp
12/10/2023 17:00	25.09	14.1	422.7	12.3	157.6	10.6
12/10/2023 18:00	23.98	14	422.5	11.9	158.6	10.2
12/10/2023 19:00	25.99	13.9	422.1	13	154.8	11
12/10/2023 20:00	25.84	13.9	421.1	13	154.7	11
12/10/2023 21:00	25.54	14	421.1	12.7	156.8	10.8
12/10/2023 22:00	25.3	14.1	420.9	12.4	159.1	10.7
12/10/2023 23:00	25.3	14.2	420.5	12.2	162.5	10.7
13/10/2023 00:00	25.4	14.2	419.6	12.3	162.3	10.8
13/10/2023 01:00	24.87	14.2	419.5	12	162.9	10.6
13/10/2023 02:00	25.07	14.2	419.4	12.1	162.8	10.6
13/10/2023 03:00	25	14.2	419.3	12.1	162.6	10.6
13/10/2023 04:00	25.03	14.2	419.5	12.1	162.8	10.6
13/10/2023 05:00	23.65	14.2	418.8	11.5	162.6	10
13/10/2023 06:00	22.28	14.2	418.7	10.8	162.4	9.5

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
15/10/2023 18:00	27.18	14.4	424.8	12.8	165.3	11.5
15/10/2023 19:00	26.68	14.3	421.7	12.6	166	11.3
15/10/2023 20:00	26.92	14.3	421.3	12.7	166.4	11.4
15/10/2023 21:00	26.33	14.3	422.2	12.4	166.6	11.2
15/10/2023 22:00	26.83	14.4	424.6	12.6	166.6	11.4
15/10/2023 23:00	27.04	14.4	423.2	12.7	166.9	11.5
16/10/2023 00:00	24.22	14.3	420.6	11.5	166.5	10.3
16/10/2023 01:00	23.1	14.3	419.9	11	166.4	9.8
16/10/2023 02:00	22.16	14.3	419.8	10.5	166.3	9.4
16/10/2023 03:00	22.01	14.3	419.8	10.4	166.1	9.3
16/10/2023 04:00	22.35	14.3	419.1	10.6	166.4	9.5
16/10/2023 05:00	22.69	14.3	419.6	10.8	165.9	9.6
16/10/2023 06:00	22.73	14.3	419.1	10.8	165.8	9.6
16/10/2023 07:00	22.28	14.3	419.8	10.6	166.3	9.5
16/10/2023 08:00	23.95	14.3	423.6	11.3	166.8	10.2
16/10/2023 09:00	27.07	14.5	425.5	12.4	169	11.5
16/10/2023 10:00	27.48	14.7	422.3	12.2	174.5	11.7
16/10/2023 11:00	27.24	14.7	420.8	12.1	174.9	11.6
16/10/2023 12:00	27.27	14.7	419.9	12.1	175.1	11.6
16/10/2023 13:00	26.36	14.7	419.7	11.7	174.1	11.2
16/10/2023 14:00	25.76	14.4	418.4	12	168.2	10.9
16/10/2023 15:00	28.37	14.3	418.5	13.5	162.5	12
16/10/2023 16:00	28.62	14.1	423.9	13.9	158.9	12.1
16/10/2023 17:00	28.18	14.1	423.6	13.7	158	12
16/10/2023 18:00	27.11	14.2	424.1	13.1	161.5	11.5
16/10/2023 19:00	26.49	14.1	424.7	12.9	159.9	11.2
16/10/2023 20:00	28.99	14.1	427.8	14.1	160.1	12.3
16/10/2023 21:00	28.75	14.1	428.3	14	160.1	12.2
16/10/2023 22:00	26.95	14.1	424.3	13.1	159.9	11.4
16/10/2023 23:00	26.94	14.2	425.5	13	161.4	11.4
17/10/2023 00:00	26.91	14.2	424.7	13	161	11.4
17/10/2023 01:00	27.33	14.2	425.8	13.2	161.2	11.6
17/10/2023 02:00	27.29	14.2	426.2	13.2	161.3	11.6
17/10/2023 03:00	27.15	14.2	425	13.2	161.1	11.5
17/10/2023 04:00	27.4	14.2	423.8	13.3	160.8	11.6
17/10/2023 05:00	27.88	14.2	423.9	13.5	160.7	11.8
17/10/2023 06:00	27.51	14.2	423.2	13.3	160.9	11.7
17/10/2023 07:00	28.34	14.2	426.1	13.7	161.5	12
17/10/2023 08:00	28.21	14.2	427.2	13.5	161.6	12
17/10/2023 09:00	27.93	14.2	427.3	13.4	161.6	11.9
17/10/2023 10:00	<Samp	<Samp	<Samp	162.3	<Samp	<Samp
17/10/2023 11:00	26.67	14.3	422.5	12.7	162.5	11.3
17/10/2023 12:00	27.11	14.3	421.8	12.9	162.3	11.5
17/10/2023 13:00	28.11	14.2	421.2	13.5	160.6	11.9
17/10/2023 14:00	27.17	14.2	420.9	13	160.4	11.5
17/10/2023 15:00	24.66	14.2	420.7	11.9	160.1	10.5
17/10/2023 16:00	25.77	14.2	420.7	12.4	159.9	10.9
17/10/2023 17:00	27.57	14.2	421.3	13.3	159.7	11.7
17/10/2023 18:00	27.25	14.2	424.8	13.2	159.8	11.6
17/10/2023 19:00	28.01	14.2	425.7	13.6	159.9	11.9
17/10/2023 20:00	29.4	14.2	427.8	14.2	160.4	12.5
17/10/2023 21:00	29.47	14.2	428.8	14.2	160.6	12.5
17/10/2023 22:00	26.58	14.2	427.9	12.8	160.6	11.3
17/10/2023 23:00	25.96	14.2	427.8	12.6	160.6	11
18/10/2023 00:00	27.2	14.2	427.8	13.2	160.8	11.5
18/10/2023 01:00	27.21	14.2	427.2	13.2	160.8	11.5
18/10/2023 02:00	26.35	14.1	424.4	12.8	160.2	11.2
18/10/2023 03:00	26.33	14.1	423.8	12.8	160.2	11.2
18/10/2023 04:00	26.31	14.1	422.5	12.8	160	11.2

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
18/10/2023 05:00	26.46	14.1	422.1	12.9	160	11.2
18/10/2023 06:00	26.2	14.1	421.6	12.8	159.9	11.1
18/10/2023 07:00	26.32	14.1	425.7	12.8	160.5	11.2
18/10/2023 08:00	26.31	14.1	426.3	12.8	160.7	11.2
18/10/2023 09:00	25.63	14.2	424.2	12.3	162.1	10.9
18/10/2023 10:00	26.72	14.3	421.7	12.7	163.7	11.3
18/10/2023 11:00	25.42	14.3	423.2	12.1	163.3	10.8
18/10/2023 12:00	25.59	14.2	423.1	12.3	161.7	10.9
18/10/2023 13:00	25.97	14.2	419.6	12.5	162	11
18/10/2023 14:00	25.63	14.2	421.6	12.3	162.5	10.9
18/10/2023 15:00	26.39	14.2	423.3	12.7	163.1	11.2
18/10/2023 16:00	27.04	14.2	424.7	13	163.5	11.5
18/10/2023 17:00	27.87	14.2	422	13.4	163.3	11.8
18/10/2023 18:00	26.28	14.2	421.2	13.6	163	12
18/10/2023 19:00	28.37	14.2	422	13.8	161.6	12
18/10/2023 20:00	28.58	14.1	422	13.9	159.7	12.1
18/10/2023 21:00	28.6	14.1	422	14	159.6	12.1
18/10/2023 22:00	28.58	14.1	420.9	14	159.5	12.1
18/10/2023 23:00	28.49	14.1	420.9	14	159.5	12.1
19/10/2023 00:00	28.35	14.1	420.6	13.9	159.6	12
19/10/2023 01:00	27.88	14.1	420.9	13.7	159.6	11.8
19/10/2023 02:00	28.04	14.1	421.4	13.7	159.4	11.9
19/10/2023 03:00	28.32	14.1	420.7	13.9	159.3	12
19/10/2023 04:00	28.65	14.1	420.8	14	159.1	12.2
19/10/2023 05:00	28.23	14.1	420.6	13.8	158.9	12
19/10/2023 06:00	28.17	14.1	420.7	13.8	158.8	12
19/10/2023 07:00	28.09	14.1	421.9	13.7	159	11.9
19/10/2023 08:00	28.26	14.1	426.4	13.7	159.7	12
19/10/2023 09:00	27.99	14.2	449.9	13.5	160	11.9
19/10/2023 10:00	27.13	14.2	443	13.1	159.9	11.5
19/10/2023 11:00	26	14.1	462.7	12.6	157.9	11
19/10/2023 12:00	22.55	14.2	435.7	10.9	159.8	9.6
19/10/2023 13:00	22.79	14.2	430.3	11	161.5	9.7
19/10/2023 14:00	22.71	14.2	427.1	10.9	162.1	9.6
19/10/2023 15:00	21.85	14.2	424.1	10.5	161.6	9.3
19/10/2023 16:00	21.67	14.2	424	10.4	161.4	9.2
19/10/2023 17:00	22.31	14.2	424.5	10.8	161.4	9.5
19/10/2023 18:00	22.72	14.2	426.3	11	160.6	9.6
19/10/2023 19:00	23.34	14.2	428	11.3	160.6	9.9
19/10/2023 20:00	24.01	14.1	428.1	11.7	160.4	10.2
19/10/2023 21:00	24.68	14.1	424.5	12	160.2	10.5
19/10/2023 22:00	25.01	14.1	422.7	12.2	159.8	10.6
19/10/2023 23:00	25.43	14.1	422.4	12.4	159.9	10.8
20/10/2023 00:00	25.45	14.1	422.2	12.4	159.7	10.8
20/10/2023 01:00	25.1	14.1	421.6	12.3	159.8	10.7
20/10/2023 02:00	25.19	14.1	421.7	12.3	159.7	10.7
20/10/2023 03:00	25.6	14.1	422.2	12.5	159.6	10.9
20/10/2023 04:00	25.72	14.1	421.6	12.6	159.7	10.9
20/10/2023 05:00	25.15	14.1	421.2	12.3	159.5	10.7
20/10/2023 06:00	25.29	14.1	421	12.4	159.5	10.7
20/10/2023 07:00	25.63	14.1	424	12.5	159.7	10.9
20/10/2023 08:00	25.78	14.2	426.4	12.5	160.5	10.9
20/10/2023 09:00	26.61	14.2	423.4	12.8	160.2	11.3
20/10/2023 10:00	26.87	14.2	421.8	12.9	159.8	11.4
20/10/2023 11:00	27.28	14.2	419.7	13.1	160.1	11.6
20/10/2023 12:00	28.67	14.2	419.4	13.7	159.8	12.2
20/10/2023 13:00	26.35	14.2	420.5	12.7	159.5	11.2
20/10/2023 14:00	27.39	14.2	423	13.2	159.4	11.6
20/10/2023 15:00	24.07	14.2	421.9	11.6	159.6	10.2

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
20/10/2023 16:00	25.02	14.2	427.1	12.1	159.7	10.6
20/10/2023 17:00	27.08	14.2	422.7	13.1	159.3	11.5
20/10/2023 18:00	26.28	14.2	422.4	12.7	161.1	11.2
20/10/2023 19:00	25.99	14.2	422.2	12.6	161.2	11
20/10/2023 20:00	25.76	14.2	422.7	12.5	161.3	10.9
20/10/2023 21:00	25.55	14.2	421.8	12.4	161.1	10.8
20/10/2023 22:00	25.93	14.2	421.4	12.6	161.2	11
20/10/2023 23:00	26.57	14.2	421.2	12.9	161.2	11.3
21/10/2023 00:00	26.58	14.2	420.7	12.9	160.9	11.3
21/10/2023 01:00	26.43	14.2	421.3	12.8	161	11.2
21/10/2023 02:00	26.23	14.2	421.7	12.7	160.8	11.1
21/10/2023 03:00	25.8	14.2	422.2	12.5	161	11
21/10/2023 04:00	26.35	14.2	421.2	12.8	160.3	11.2
21/10/2023 05:00	26.81	14.2	420.8	13	160	11.4
21/10/2023 06:00	27.32	14.1	419.8	13.3	160	11.6
21/10/2023 07:00	27.51	14.2	420.1	13.4	160	11.7
21/10/2023 08:00	27.34	14.2	423.9	13.1	161.2	11.6
21/10/2023 09:00	27.22	14.3	425.9	13	162.4	11.6
21/10/2023 10:00	26.77	14.3	423.6	12.8	162.6	11.4
21/10/2023 11:00	26.39	14.3	421.9	12.6	161.7	11.2
21/10/2023 12:00	26.33	14.2	420.3	12.6	161	11.2
21/10/2023 13:00	25.49	14.2	418.3	12.2	159.7	10.8
21/10/2023 14:00	25.3	14.2	418.6	12.1	159	10.7
21/10/2023 15:00	26.84	14.2	420.2	12.8	159.3	11.4
21/10/2023 16:00	27.22	14.2	421.3	13	159.3	11.6
21/10/2023 17:00	26.65	14.2	422.6	12.8	159.6	11.3
21/10/2023 18:00	25.47	14.2	426.1	12.3	160.5	10.8
21/10/2023 19:00	25.92	14.2	424.2	12.5	160.5	11
21/10/2023 20:00	26.31	14.2	421.6	12.7	160.3	11.2
21/10/2023 21:00	27.33	14.1	420.8	13.3	160.3	11.6
21/10/2023 22:00	27.3	14.1	420.3	13.3	160.4	11.6
21/10/2023 23:00	27.3	14.1	420.1	13.3	160.3	11.6
22/10/2023 00:00	27.27	14.1	434.9	13.3	160.4	11.6
22/10/2023 01:00	27.2	14.1	472.4	13.2	160.3	11.5
22/10/2023 02:00	27.15	14.1	467.4	13.2	160.5	11.5
22/10/2023 03:00	27.14	14.1	462.2	13.2	160.4	11.5
22/10/2023 04:00	27.61	14.1	460.5	13.4	160.2	11.7
22/10/2023 05:00	28.98	14.1	458.9	14.1	160.1	12.3
22/10/2023 06:00	28.67	14.1	427.8	14	159.9	12.2
22/10/2023 07:00	27.52	14.1	421.5	13.4	160.5	11.7
22/10/2023 08:00	26.71	14.2	423.9	12.9	160.9	11.3
22/10/2023 09:00	26.52	14.2	426.8	12.8	161.3	11.3
22/10/2023 10:00	25.64	14.2	424.8	12.3	161.6	10.9
22/10/2023 11:00	24.87	14.2	422.3	12	161.2	10.6
22/10/2023 12:00	25.16	14.1	421.2	12.3	158	10.7
22/10/2023 13:00	24.53	14.2	421.2	11.9	158.4	10.4
22/10/2023 14:00	24.63	14.2	425.6	11.9	159.2	10.5
22/10/2023 15:00	26.18	14.1	427.7	12.7	159.3	11.1
22/10/2023 16:00	26.36	14.1	426.9	12.8	159.5	11.2
22/10/2023 17:00	25.59	14.1	425.7	12.4	159.9	10.9
22/10/2023 18:00	28.01	14.1	421.3	13.7	158.3	11.9
22/10/2023 19:00	28.08	14.1	419.5	13.7	158.1	11.9
22/10/2023 20:00	24.57	14.1	419.9	12.1	157.9	10.4
22/10/2023 21:00	23.77	14.1	420.3	11.7	158.9	10.1
22/10/2023 22:00	22.8	14.1	419.9	11.2	159	9.7
22/10/2023 23:00	23.53	14.1	419.5	11.5	159.1	10
23/10/2023 00:00	23.86	14.1	419.6	11.6	160.3	10.1
23/10/2023 01:00	23.09	14.1	418.7	11.3	160.3	9.8
23/10/2023 02:00	23.71	14.1	419.2	11.6	160.4	10.1

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
25/10/2023 14:00	28.27	14.3	422.7	13.5	162.2	12
25/10/2023 15:00	28.5	14.3	422.8	13.6	162.5	12.1
25/10/2023 16:00	28.44	14.3	423	13.5	162.3	12.1
25/10/2023 17:00	28.54	14.3	423.6	13.6	162.5	12.1
25/10/2023 18:00	29.29	14.3	425.4	14	162.3	12.4
25/10/2023 19:00	28.83	14.3	426.3	13.8	162.5	12.2
25/10/2023 20:00	27.43	14.2	427.8	13.1	162.8	11.6
25/10/2023 21:00	27	14.2	428.3	13	162.7	11.5
25/10/2023 22:00	26.87	14.2	428.7	12.9	162.5	11.4
25/10/2023 23:00	27.57	14.2	427	13.3	162.5	11.7
26/10/2023 00:00	27.65	14.2	425.4	13.3	162.4	11.7
26/10/2023 01:00	27	14.2	422.6	13.1	162	11.5
26/10/2023 02:00	26.98	14.2	422.3	13.1	161.8	11.5
26/10/2023 03:00	27.44	14.2	421.8	13.3	161.7	11.6
26/10/2023 04:00	27.6	14.2	422.1	13.4	161.6	11.7
26/10/2023 05:00	27.73	14.2	420.6	13.5	161.9	11.8
26/10/2023 06:00	27.88	14.2	421.2	13.5	161.6	11.8
26/10/2023 07:00	26.62	14.2	423.7	12.9	161.9	11.3
26/10/2023 08:00	<Samp	<Samp	<Samp	<Samp	<Samp	<Samp
26/10/2023 09:00	---	---	---	---	---	---
26/10/2023 10:00	---	---	---	---	---	---
26/10/2023 11:00	---	---	---	---	---	---
26/10/2023 12:00	---	---	---	---	---	---
26/10/2023 13:00	---	---	---	---	---	---
26/10/2023 14:00	---	---	---	---	---	---
26/10/2023 15:00	---	---	---	---	---	---
26/10/2023 16:00	---	---	---	---	---	---
26/10/2023 17:00	---	---	---	---	---	---
26/10/2023 18:00	---	---	---	---	---	---
26/10/2023 19:00	---	---	---	---	---	---
26/10/2023 20:00	---	---	---	---	---	---
26/10/2023 21:00	---	---	---	---	---	---
26/10/2023 22:00	---	---	---	---	---	---
26/10/2023 23:00	---	---	---	---	---	---
27/10/2023 00:00	---	---	---	---	---	---
27/10/2023 01:00	---	---	---	---	---	---
27/10/2023 02:00	---	---	---	---	---	---
27/10/2023 03:00	---	---	---	---	---	---
27/10/2023 04:00	---	---	---	---	---	---
27/10/2023 05:00	---	---	---	---	---	---
27/10/2023 06:00	---	---	---	---	---	---
27/10/2023 07:00	---	---	---	---	---	---
27/10/2023 08:00	---	---	---	---	---	---
27/10/2023 09:00	---	---	---	---	---	---
27/10/2023 10:00	---	---	---	---	---	---
27/10/2023 11:00	---	---	---	---	---	---
27/10/2023 12:00	---	---	---	---	---	---
27/10/2023 13:00	---	---	---	---	---	---
27/10/2023 14:00	26.13	14.3	418.8	12.4	160.6	11.1
27/10/2023 15:00	25.72	14.3	419.2	12.3	161	10.9
27/10/2023 16:00	25.89	14.3	421.1	12.3	161.5	11
27/10/2023 17:00	26.02	14.3	422	12.4	161.6	11
27/10/2023 18:00	26.23	14.2	424.4	12.5	162.1	11.1
27/10/2023 19:00	26.46	14.2	426.9	12.7	162.4	11.2
27/10/2023 20:00	26.82	14.2	428.6	12.9	163	11.4
27/10/2023 21:00	27.94	14.2	428.7	13.4	163	11.9
27/10/2023 22:00	28.42	14.2	428.9	13.6	163	12.1
27/10/2023 23:00	28.28	14.2	424.2	13.6	162.6	12
28/10/2023 00:00	28.41	14.2	422.5	13.7	162.4	12.1

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
28/10/2023 01:00	28.39	14.2	422.6	13.7	162.2	12
28/10/2023 02:00	28.57	14.2	422.8	13.8	162.3	12.1
28/10/2023 03:00	29.03	14.2	422.6	14	162.5	12.3
28/10/2023 04:00	28.78	14.2	422.2	13.9	162.2	12.2
28/10/2023 05:00	28.96	14.2	422.2	14	162.3	12.3
28/10/2023 06:00	29.17	14.2	421.5	14.1	162.3	12.4
28/10/2023 07:00	28.67	14.2	425.3	13.8	162.8	12.2
28/10/2023 08:00	27.54	14.3	425.3	13.2	163.3	11.7
28/10/2023 09:00	28.17	14.3	425.2	13.4	162.7	12
28/10/2023 10:00	28.92	14.3	424.1	13.8	162.9	12.3
28/10/2023 11:00	29	14.3	422.4	13.8	162.6	12.3
28/10/2023 12:00	29.5	14.3	421.7	14	162.4	12.5
28/10/2023 13:00	27.63	14.3	419	13.3	162.2	11.9
28/10/2023 14:00	27.94	14.3	417.4	13.3	162.1	11.9
28/10/2023 15:00	26.34	14.3	423.5	12.6	162.4	11.2
28/10/2023 16:00	26.25	14.3	423.2	12.5	162.3	11.1
28/10/2023 17:00	27.73	14.3	423.0	13.2	162.4	11.8
28/10/2023 18:00	29.3	14.3	428.1	14	162.8	12.4
28/10/2023 19:00	30.1	14.3	428.6	14.4	163	12.8
28/10/2023 20:00	29.78	14.2	429.2	14.3	163.3	12.6
28/10/2023 21:00	28.56	14.2	428.4	13.7	162.8	12.1
28/10/2023 22:00	29.72	14.2	427.7	14.2	163	12.6
28/10/2023 23:00	25.23	14.2	426	12.1	162.6	10.7
29/10/2023 00:00	26.22	14.2	423.5	12.6	162.6	11.1
29/10/2023 01:00	25.55	14.2	421.4	12.3	162.3	10.8
29/10/2023 02:00	25.96	14.2	421.3	12.5	162.2	11
29/10/2023 03:00	26.7	14.2	420.9	12.9	162.1	11.3
29/10/2023 04:00	26.2	14.2	420.3	12.7	161.7	11.1
29/10/2023 05:00	26.28	14.2	419.9	12.7	161.4	11.2
29/10/2023 06:00	26.73	14.2	425.8	12.9	161.9	11.3
29/10/2023 07:00	26.16	14.2	421.2	12.7	161.9	11.1
29/10/2023 08:00	26.26	14.2	422.4	12.7	162.3	11.1
29/10/2023 09:00	25.65	14.2	425.4	12.4	162.4	10.9
29/10/2023 10:00	25.57	14.2	427.6	12.3	163.1	10.9
29/10/2023 11:00	25	14.3	425.5	12	162.8	10.6
29/10/2023 12:00	25.1	14.3	423.6	12	162.7	10.7
29/10/2023 13:00	25.26	14.3	423.6	12.1	162	10.7
29/10/2023 14:00	26.53	14.2	421.3	12.8	161.1	11.3
29/10/2023 15:00	26.79	14.2	426.9	12.8	162.4	11.4
29/10/2023 16:00	26.47	14.2	425.4	12.7	162.2	11.2
29/10/2023 17:00	26.66	14.2	426.3	12.8	162.5	11.3
29/10/2023 18:00	26.42	14.2	424.6	12.7	162.4	11.2
29/10/2023 19:00	26.78	14.2	423	12.9	162.4	11.4
29/10/2023 20:00	24.89	14.2	421.1	12	162	10.6
29/10/2023 21:00	26.65	14.2	421.2	12.9	161.4	11.3
29/10/2023 22:00	27.27	14.2	422.3	13.2	161.6	11.6
29/10/2023 23:00	27.65	14.2	421.7	13.4	161.7	11.7
30/10/2023 00:00	27.78	14.2	422.1	13.4	161.9	11.8
30/10/2023 01:00	26.88	14.2	421.9	13	162	11.4
30/10/2023 02:00	26.99	14.2	421.2	13.1	162	11.5
30/10/2023 03:00	27.03	14.2	420.8	13.1	161.8	11.5
30/10/2023 04:00	27.28	14.2	421.2	13.2	161.7	11.6
30/10/2023 05:00	27.26	14.2	420.3	13.2	161.7	11.6
30/10/2023 06:00	27.32	14.2	420.3	13.2	161.7	11.6
30/10/2023 07:00	27.06	14.2	422.4	13.1	162.1	11.5
30/10/2023 08:00	27.54	14.2	426.9	13.2	162.4	11.7
30/10/2023 09:00	28.24	14.3	424.8	13.5	162.7	12
30/10/2023 10:00	28.77	14.3	423.4	13.7	162.9	12.2
30/10/2023 11:00	26.75	14.3	422.3	12.7	162.9	11.4

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
30/10/2023 12:00	25.95	14.3	419	12.3	162.7	11
30/10/2023 13:00	24.46	14.3	415.6	11.6	162	10.4
30/10/2023 14:00	24.66	14.3	416.4	11.7	161.8	10.5
30/10/2023 15:00	25.52	14.3	424.4	12.2	161.3	10.8
30/10/2023 16:00	25.33	14.2	421.9	12.2	160.8	10.8
30/10/2023 17:00	25.58	14.2	422.8	12.3	161	10.9
30/10/2023 18:00	25.92	14.2	421.4	12.5	161.5	11
30/10/2023 19:00	26.24	14.2	421.3	12.7	161.7	11.1
30/10/2023 20:00	26.34	14.2	421.1	12.7	161.8	11.2
30/10/2023 21:00	27.3	14.2	421.5	13.2	161.7	11.6
30/10/2023 22:00	27.18	14.2	422.1	13.1	161.8	11.5
30/10/2023 23:00	27.24	14.2	422.3	13.2	161.8	11.6
31/10/2023 00:00	27.2	14.2	423.1	13.1	161.7	11.5
31/10/2023 01:00	26.34	14.2	422.4	12.7	161.6	11.2
31/10/2023 02:00	26.85	14.2	420.9	13	161.3	11.4
31/10/2023 03:00	27.83	14.2	421.5	13.5	161.4	11.8
31/10/2023 04:00	28.65	14.2	421.4	13.8	161.4	12.2
31/10/2023 05:00	28.48	14.2	421.3	13.8	161.3	12.1
31/10/2023 06:00	27.23	14.2	420.9	13.2	161.4	11.6
31/10/2023 07:00	27.23	14.2	422.1	13.1	161.5	11.6
31/10/2023 08:00	27.02	14.2	424.9	13	161.9	11.5
31/10/2023 09:00	27.62	14.3	426.8	13.2	162.6	11.7
31/10/2023 10:00	27.18	14.3	426	12.9	162.4	11.5
31/10/2023 11:00	26.64	14.3	424.9	12.7	162.1	11.3
31/10/2023 12:00	26.46	14.3	437.7	12.6	162	11.2
31/10/2023 13:00	26.18	14.3	444.5	12.4	161.9	11.1
31/10/2023 14:00	25.13	14.3	452.7	11.9	161.9	10.7
31/10/2023 15:00	26.09	14.3	450.8	12.4	161.9	11.1
31/10/2023 16:00	25.9	14.3	449	12.4	162.1	11
31/10/2023 17:00	26	14.2	452.8	12.4	162.5	11
31/10/2023 18:00	26.31	14.2	440.5	12.6	162.8	11.2
31/10/2023 19:00	27.13	14.2	440	13	163	11.5
31/10/2023 20:00	27.96	14.2	446.7	13.4	163.2	11.9
31/10/2023 21:00	29.09	14.2	446.4	13.9	163.5	12.3
31/10/2023 22:00	29.54	14.3	429.6	14.1	163.8	12.5
31/10/2023 23:00	26.17	14.2	442.1	12.5	164.1	11.1
Minimum	21.67	13.9	363.4	10.4	147	9.2
MinDate	19/10/2023 16:00	03/10/2023 13:00	09/10/2023 08:00	16/10/2023 03:00	03/10/2023 15:00	19/10/2023 16:00
Maximum	31.39	14.7	474.3	15	175.1	13.3
MaxDate	15/10/2023 09:00	16/10/2023 10:00	05/10/2023 06:00	15/10/2023 09:00	16/10/2023 12:00	15/10/2023 09:00
Avg	26.54	14.2	424.4	12.8	161.8	11.3
Num	686	686	686	686	691	686
Data[%]	92.1	92.1	92.1	92.1	92.8	92.1
STD	1.5	0.1	8.3	0.7	2.2	0.6

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
03/11/2023 11:00	29.07	14.8	419.5	12.8	175.4	12.3
03/11/2023 12:00	29.1	14.8	418.2	12.8	175.6	12.4
03/11/2023 13:00	26.68	14.8	418.1	12.6	175.3	12.2
03/11/2023 14:00	27.57	14.8	417.6	12.2	175	11.7
03/11/2023 15:00	27.34	14.8	417.4	12.1	174.8	11.6
03/11/2023 16:00	27.28	14.8	419.2	12.1	174.7	11.6
03/11/2023 17:00	28.45	14.7	421.1	12.6	174.8	12.1
03/11/2023 18:00	29.13	14.7	423.4	12.9	175.1	12.4
03/11/2023 19:00	29.66	14.7	424.9	13.2	175.4	12.6
03/11/2023 20:00	24.67	14.2	421.7	12	162	10.5
03/11/2023 21:00	25.4	14.2	422.8	12.3	159.4	10.8
03/11/2023 22:00	25.87	14.6	421.3	11.7	172.8	11
03/11/2023 23:00	26.84	14.6	420.9	12.1	175	11.4
04/11/2023 00:00	26.59	14.6	420.1	12.9	175.1	12.1
04/11/2023 01:00	26.12	14.6	420.6	11.8	174.9	11.1
04/11/2023 02:00	25.22	14.6	419.7	11.4	174.8	10.7
04/11/2023 03:00	25.17	14.6	419.8	11.4	174.8	10.7
04/11/2023 04:00	24.85	14.6	419.9	11.2	174.8	10.5
04/11/2023 05:00	24.53	14.6	420.2	11.1	174.8	10.4
04/11/2023 06:00	25.48	14.6	420.5	11.5	174.8	10.8
04/11/2023 07:00	27.68	14.6	422.4	12.5	175	11.7
04/11/2023 08:00	27.55	14.7	425.2	12.3	175.4	11.7
04/11/2023 09:00	27.43	14.7	420	12.2	175.2	11.6
04/11/2023 10:00	27.61	14.7	420	12.2	175.1	11.7
04/11/2023 11:00	27.71	14.8	419.2	12.2	175.2	11.8
04/11/2023 12:00	26.35	14.7	422.2	11.7	174	11.2
04/11/2023 13:00	28.94	14.7	421.4	13	173.2	12.3
04/11/2023 14:00	29.77	14.7	420.7	13.4	173.6	12.6
04/11/2023 15:00	29.25	14.7	420.4	13.1	174.5	12.4
04/11/2023 16:00	28.93	14.7	421	13	174.5	12.3
04/11/2023 17:00	29.29	14.6	420	13.2	174.2	12.4
04/11/2023 18:00	29.94	14.6	420.5	13.5	174.4	12.7
04/11/2023 19:00	29.91	14.7	420.4	13.4	174.2	12.7
04/11/2023 20:00	29.84	14.7	420.7	13.4	174.4	12.7
04/11/2023 21:00	28.82	14.7	420.5	12.9	174.3	12.2
04/11/2023 22:00	28.42	14.7	420.6	12.8	174.2	12.1
04/11/2023 23:00	27.32	14.6	420.7	12.3	174	11.6
05/11/2023 00:00	26.76	14.6	420.4	12.1	174	11.4
05/11/2023 01:00	25.87	14.6	420.6	11.7	174.1	11
05/11/2023 02:00	25.55	14.6	419.8	11.5	174.2	10.8
05/11/2023 03:00	25.56	14.6	419.5	11.5	174.2	10.9
05/11/2023 04:00	25.16	14.6	419.9	11.4	174	10.7
05/11/2023 05:00	24.66	14.6	419.8	11.1	174	10.5
05/11/2023 06:00	24.57	14.6	419.6	11.1	174	10.4
05/11/2023 07:00	24.81	14.6	420.7	11.2	174.2	10.5
05/11/2023 08:00	25.05	14.7	423.7	11.2	174.7	10.6
05/11/2023 09:00	24.52	14.7	425.9	10.9	175.2	10.4
05/11/2023 10:00	24.87	14.7	423.4	11	175.4	10.6
05/11/2023 11:00	24.36	14.8	421.2	10.8	175.5	10.3
05/11/2023 12:00	24.88	14.8	419.8	11	175.5	10.6
05/11/2023 13:00	23.13	14.7	416.8	10.2	174.7	9.8
05/11/2023 14:00	22.92	14.8	416.1	10.1	174.5	9.7
05/11/2023 15:00	24.48	14.8	418.4	10.8	174.5	10.4
05/11/2023 16:00	25.78	14.7	426.1	11.5	174.7	10.9
05/11/2023 17:00	25.51	14.7	422.3	11.4	174.3	10.8
05/11/2023 18:00	25.8	14.7	421.9	11.6	174.3	11
05/11/2023 19:00	26.18	14.7	438.2	11.7	174.4	11.1
05/11/2023 20:00	26.45	14.7	445.6	11.9	174.3	11.2
05/11/2023 21:00	26.79	14.7	453.5	12	174.5	11.4

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
05/11/2023 22:00	27.18	14.7	430.5	12.2	174.9	11.5
05/11/2023 23:00	27.86	14.7	421.7	12.5	174.9	11.8
06/11/2023 00:00	27.95	14.7	421.5	12.5	174.9	11.9
06/11/2023 01:00	27.45	14.7	420.9	12.3	174.7	11.7
06/11/2023 02:00	27.4	14.6	420.1	12.3	174.8	11.6
06/11/2023 03:00	27.58	14.6	419.8	12.4	174.7	11.7
06/11/2023 04:00	27.55	14.6	420.2	12.4	174.6	11.7
06/11/2023 05:00	27.22	14.6	419.6	12.3	174.5	11.6
06/11/2023 06:00	27.58	14.6	419.9	12.4	174.7	11.7
06/11/2023 07:00	27.29	14.7	423.6	12.2	175.2	11.6
06/11/2023 08:00	28.26	14.7	425.3	12.5	175.7	12
06/11/2023 09:00	27.77	14.8	422.3	12.3	175.5	11.8
06/11/2023 10:00	28.2	14.8	420	12.4	175.4	12
06/11/2023 11:00	26.02	14.8	419.5	12.3	175.6	11.9
06/11/2023 12:00	27.48	14.8	418.6	12.1	175.5	11.7
06/11/2023 13:00	25.75	14.7	418	11.4	174.7	10.9
06/11/2023 14:00	26.12	14.7	418.9	11.6	174.6	11.1
06/11/2023 15:00	28.1	14.7	425.5	12.4	175.2	11.9
06/11/2023 16:00	28.57	14.7	424.9	12.7	175.5	12.1
06/11/2023 17:00	28.6	14.7	424.8	12.7	175.8	12.1
06/11/2023 18:00	27.42	14.7	426.6	12.2	175.9	11.6
06/11/2023 19:00	25.93	14.7	427.9	11.6	176	11
06/11/2023 20:00	26.12	14.7	428.2	11.7	176.2	11.1
06/11/2023 21:00	26.16	14.7	422.4	11.7	176.1	11.1
06/11/2023 22:00	25.75	14.7	427.8	11.6	175.7	10.9
06/11/2023 23:00	26	14.7	422.6	11.7	175.4	11
07/11/2023 00:00	26.44	14.7	422.9	11.9	175.2	11.2
07/11/2023 01:00	26.62	14.7	422.7	11.9	175.1	11.3
07/11/2023 02:00	26.71	14.7	421.8	12	175.1	11.3
07/11/2023 03:00	26.96	14.6	421.2	12.1	175.1	11.4
07/11/2023 04:00	27.51	14.6	421.1	12.4	174.9	11.7
07/11/2023 05:00	27.87	14.6	420.9	12.5	175	11.8
07/11/2023 06:00	27.92	14.7	421.4	12.6	175	11.9
07/11/2023 07:00	27.32	14.7	423.2	12.3	175.2	11.6
07/11/2023 08:00	27.56	14.7	426.7	12.3	175.8	11.7
07/11/2023 09:00	26.92	14.7	424.2	12	175.7	11.4
07/11/2023 10:00	27.05	14.7	421.3	12	175.5	11.5
07/11/2023 11:00	<Samp	<Samp	<Samp	<Samp	175.7	<Samp
07/11/2023 12:00	25.9	14.7	420.6	11.5	175.4	11
07/11/2023 13:00	26.45	14.7	426.6	11.8	175.3	11.2
07/11/2023 14:00	27.37	14.7	427.9	12.2	175.7	11.6
07/11/2023 15:00	27.26	14.7	422.9	12.2	175.8	11.6
07/11/2023 16:00	27.02	14.7	422.5	12.1	174.8	11.5
07/11/2023 17:00	27.04	14.7	423.1	12.1	175	11.5
07/11/2023 18:00	27.2	14.7	422.3	12.2	175.1	11.5
07/11/2023 19:00	27.05	14.7	422.1	12.1	175.1	11.5
07/11/2023 20:00	27.33	14.7	422.2	12.3	175.1	11.6
07/11/2023 21:00	27.3	14.7	421.5	12.3	175	11.6
07/11/2023 22:00	27.36	14.7	421	12.3	175	11.6
07/11/2023 23:00	27.49	14.6	420.1	12.4	175	11.7
08/11/2023 00:00	27.52	14.6	419.5	12.4	174.8	11.7
08/11/2023 01:00	28.18	14.6	419.5	12.7	174.8	12
08/11/2023 02:00	28.52	14.6	418.8	12.8	174.7	12.1
08/11/2023 03:00	28.68	14.6	419.5	12.9	174.7	12.2
08/11/2023 04:00	28.51	14.6	418.8	12.9	174.6	12.1
08/11/2023 05:00	28.52	14.6	418.6	12.9	174.5	12.1
08/11/2023 06:00	28.66	14.6	419.6	12.9	174.7	12.2
08/11/2023 07:00	28.31	14.7	422.3	12.7	175.1	12
08/11/2023 08:00	28.92	14.7	426.2	12.9	175.8	12.3

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
08/11/2023 09:00	28.52	14.7	423.4	12.6	175.7	12.1
08/11/2023 10:00	28.42	14.8	421.6	12.6	175.4	12.1
08/11/2023 11:00	28.24	14.8	420.3	12.5	175.5	12
08/11/2023 12:00	26.89	14.8	419.2	11.8	175.3	11.4
08/11/2023 13:00	27.35	14.8	418.2	12	175.2	11.6
08/11/2023 14:00	25.51	14.8	416.1	11.2	174.4	10.8
08/11/2023 15:00	24.46	14.5	423.6	11.2	170.5	10.4
08/11/2023 16:00	25.92	14.5	422.4	12	166.6	11
08/11/2023 17:00	26.88	14.7	422.3	12.1	173.9	11.4
08/11/2023 18:00	26.55	14.7	421.6	11.9	174.5	11.3
08/11/2023 19:00	26.74	14.7	421.9	12	175	11.4
08/11/2023 20:00	26.8	14.7	421.9	12	175.2	11.4
08/11/2023 21:00	27	14.7	422.3	12.1	175.3	11.5
08/11/2023 22:00	27.03	14.7	422.2	12.2	175.3	11.5
08/11/2023 23:00	27.1	14.6	421.9	12.2	175.4	11.5
09/11/2023 00:00	27.47	14.6	421.4	12.4	175.2	11.7
09/11/2023 01:00	27.34	14.6	420.8	12.3	175.3	11.6
09/11/2023 02:00	27.56	14.6	420.6	12.4	175	11.7
09/11/2023 03:00	27.89	14.6	420.2	12.6	174.7	11.8
09/11/2023 04:00	27.93	14.6	421.3	12.6	174.9	11.9
09/11/2023 05:00	27.59	14.6	421.3	12.4	174.7	11.7
09/11/2023 06:00	27.86	14.6	421.5	12.6	174.9	11.8
09/11/2023 07:00	28	14.6	422.1	12.6	175	11.9
09/11/2023 08:00	29.1	14.7	426.6	13	175.7	12.4
09/11/2023 09:00	28.53	14.7	423.9	12.7	175.5	12.1
09/11/2023 10:00	28.88	14.7	422	12.8	175.1	12.3
09/11/2023 11:00	28.79	14.7	422.5	12.8	175	12.2
09/11/2023 12:00	29.41	14.8	423.1	13	174.9	12.5
09/11/2023 13:00	27.54	14.7	425.3	12.2	175.2	11.7
09/11/2023 14:00	27.37	14.7	425.2	12.2	175.1	11.6
09/11/2023 15:00	28.45	14.7	425.4	12.6	175.2	12.1
09/11/2023 16:00	28.76	14.7	425.9	12.8	175.4	12.2
09/11/2023 17:00	28.56	14.7	426.3	12.7	175.4	12.1
09/11/2023 18:00	28.86	14.7	427.1	12.9	175.4	12.2
09/11/2023 19:00	27.27	14.7	427.4	12.2	175.7	11.6
09/11/2023 20:00	26.54	14.7	424.5	11.9	175.5	11.3
09/11/2023 21:00	27.22	14.7	426.3	12.2	175.5	11.6
09/11/2023 22:00	26.81	14.7	423.2	12	175.1	11.4
09/11/2023 23:00	26.55	14.7	421.7	11.9	175	11.3
10/11/2023 00:00	26.96	14.7	422.1	12.1	174.9	11.4
10/11/2023 01:00	26.71	14.7	421.3	12	175	11.3
10/11/2023 02:00	26.66	14.6	421.4	12	174.5	11.3
10/11/2023 03:00	26.94	14.6	421.3	12.1	174.7	11.4
10/11/2023 04:00	26.93	14.6	420.7	12.1	174.4	11.4
10/11/2023 05:00	26.84	14.6	421.3	12.1	174.7	11.4
10/11/2023 06:00	27.34	14.6	421.1	12.3	174.7	11.6
10/11/2023 07:00	27.74	14.7	423.9	12.4	175.3	11.8
10/11/2023 08:00	27.89	14.7	424.7	12.4	175.7	11.8
10/11/2023 09:00	23.29	14.4	422.4	10.8	167.1	9.9
10/11/2023 10:00	Maintain	Maintain	Alarm	Maintain	173.5	Maintain
10/11/2023 11:00	Maintain	Maintain	Alarm	Maintain	175.4	Maintain
10/11/2023 12:00	Maintain	Maintain	Alarm	Maintain	175	Maintain
10/11/2023 13:00	Maintain	Maintain	Alarm	Maintain	174.7	Maintain
10/11/2023 14:00	<Samp	<Samp	<Samp	<Samp	166.1	<Samp
10/11/2023 15:00	25.92	14.1	427.2	12.6	163.1	11
10/11/2023 16:00	28.63	14.2	427.2	13.8	165.2	12.2
10/11/2023 17:00	25.91	14.5	427.4	11.9	173.5	11
10/11/2023 18:00	25.5	14.5	427.8	11.7	175.7	10.8
10/11/2023 19:00	25.59	14.5	426.3	11.8	175.8	10.9

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
13/11/2023 07:00	28.46	14.5	423.3	13.1	175.2	12.1
13/11/2023 08:00	26.96	14.5	426.4	12.4	175.4	11.4
13/11/2023 09:00	26.58	14.6	422.8	12.1	175.5	11.3
13/11/2023 10:00	26.53	14.6	424.3	12	175.4	11.3
13/11/2023 11:00	26.38	14.6	420.6	11.9	175.5	11.2
13/11/2023 12:00	26.02	14.6	419.4	11.8	175.5	11
13/11/2023 13:00	26.66	14.6	419.5	12	175.3	11.3
13/11/2023 14:00	26.59	14.6	417.8	12	175.5	11.3
13/11/2023 15:00	26.96	14.6	419.7	12.2	175.1	11.4
13/11/2023 16:00	26.58	14.6	419.5	12	175.1	11.3
13/11/2023 17:00	25.25	14.6	421.4	11.5	175.2	10.7
13/11/2023 18:00	25.75	14.6	423.3	11.7	175.2	10.9
13/11/2023 19:00	25.87	14.5	425.9	11.8	175.7	11
13/11/2023 20:00	26.46	14.5	427.6	12.1	175.9	11.2
13/11/2023 21:00	27.47	14.5	428.2	12.6	176	11.7
13/11/2023 22:00	27.72	14.5	426.5	12.7	175.6	11.8
13/11/2023 23:00	28.03	14.5	427.2	12.8	175.6	11.9
14/11/2023 00:00	28.05	14.5	427	12.8	175.7	11.9
14/11/2023 01:00	28.8	14.5	426.3	13.2	175.3	12.2
14/11/2023 02:00	29.29	14.5	424.6	13.4	174.5	12.4
14/11/2023 03:00	29.76	14.5	423.2	13.7	174.4	12.6
14/11/2023 04:00	29.16	14.5	422.4	13.4	174.9	12.4
14/11/2023 05:00	27.16	14.5	422.3	12.5	175	11.5
14/11/2023 06:00	27.4	14.5	422	12.6	174.7	11.6
14/11/2023 07:00	27.25	14.5	422.8	12.5	175.1	11.6
14/11/2023 08:00	27.89	14.6	427.3	12.7	175.4	11.8
14/11/2023 09:00	27.31	14.6	425.4	12.4	175.4	11.6
14/11/2023 10:00	27.03	14.6	423.5	12.3	175.2	11.5
14/11/2023 11:00	27.23	14.6	421.9	12.3	175.2	11.6
14/11/2023 12:00	27.48	14.6	420.5	12.4	175.4	11.7
14/11/2023 13:00	27.62	14.6	419.3	12.5	175.1	11.7
14/11/2023 14:00	28.4	14.6	419.6	12.8	175.1	12.1
14/11/2023 15:00	28.72	14.6	419.7	13	175.1	12.2
14/11/2023 16:00	29.2	14.6	420.7	13.2	175.1	12.4
14/11/2023 17:00	29.11	14.6	421.1	13.2	175.1	12.4
14/11/2023 18:00	29.03	14.6	423.9	13.2	175.3	12.3
14/11/2023 19:00	28.88	14.6	425.3	13.1	175.5	12.3
14/11/2023 20:00	28.45	14.6	426.4	13	175.5	12.1
14/11/2023 21:00	29.24	14.6	427.8	13.3	175.6	12.4
14/11/2023 22:00	29.54	14.6	428.1	13.5	175.7	12.5
14/11/2023 23:00	29.47	14.6	427	13.5	175.3	12.5
15/11/2023 00:00	30.14	14.6	427	13.8	174.9	12.8
15/11/2023 01:00	30.04	14.5	426.2	13.7	174.6	12.8
15/11/2023 02:00	29.87	14.5	424	13.7	174.9	12.7
15/11/2023 03:00	29.96	14.5	422.1	13.8	174.7	12.7
15/11/2023 04:00	29.53	14.5	422.3	13.6	174.4	12.5
15/11/2023 05:00	26.99	14.5	421.7	12.4	174.7	11.5
15/11/2023 06:00	27.6	14.5	421.9	12.7	174.7	11.7
15/11/2023 07:00	27.54	14.5	422.9	12.6	175	11.7
15/11/2023 08:00	28.15	14.5	425.3	12.9	175.2	11.9
15/11/2023 09:00	20.4	13.9	426.8	10.3	157.5	8.7
15/11/2023 10:00	21.88	13.9	425.4	11	154.3	9.3
15/11/2023 11:00	22.35	14.1	422.5	10.9	156.5	9.5
15/11/2023 12:00	27.88	14.6	420.8	12.6	174.9	11.8
15/11/2023 13:00	27.47	14.6	419.6	12.4	175.8	11.7
15/11/2023 14:00	27.69	14.6	418.9	12.5	175.5	11.8
15/11/2023 15:00	26.86	14.6	417.7	12.2	175.2	11.4
15/11/2023 16:00	27.17	14.6	419.2	12.3	174.9	11.5
15/11/2023 17:00	27.88	14.6	424.7	12.7	175.4	11.8

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
15/11/2023 18:00	28.42	14.5	428.5	13	175.7	12.1
15/11/2023 19:00	27.88	14.5	425.8	12.8	175.6	11.8
15/11/2023 20:00	29.56	14.5	428.2	13.5	175.7	12.5
15/11/2023 21:00	29.64	14.6	428.9	13.5	175.5	12.6
15/11/2023 22:00	28.55	14.5	425.8	13.1	175.5	12.1
15/11/2023 23:00	27.87	14.5	425.6	12.7	175.1	11.8
16/11/2023 00:00	28.06	14.5	426.2	12.8	175.2	11.9
16/11/2023 01:00	28.13	14.5	424	12.9	174.9	11.9
16/11/2023 02:00	28.26	14.5	423.9	12.9	174.5	12
16/11/2023 03:00	28.56	14.5	424	13.1	174.7	12.1
16/11/2023 04:00	28.06	14.5	423.8	12.9	174.7	11.9
16/11/2023 05:00	27.24	14.5	422.6	12.5	174.7	11.6
16/11/2023 06:00	27.48	14.5	422.4	12.6	174.5	11.7
16/11/2023 07:00	27.61	14.5	423.4	12.7	174.3	11.7
16/11/2023 08:00	27.63	14.6	426.9	12.6	175	11.7
16/11/2023 09:00	27.12	14.6	424.6	12.3	175.1	11.5
16/11/2023 10:00	26.76	14.6	422.6	12.1	175	11.4
16/11/2023 11:00	27.85	14.6	421.3	12.6	175.2	11.8
16/11/2023 12:00	27.57	14.6	419.9	12.4	175.2	11.7
16/11/2023 13:00	27.8	14.6	420.4	12.5	175.2	11.8
16/11/2023 14:00	28.12	14.6	419.4	12.7	175.1	11.9
16/11/2023 15:00	28.08	14.6	423	12.7	175	11.9
16/11/2023 16:00	28.36	14.6	424.4	12.9	175.3	12
16/11/2023 17:00	26.49	14.5	424.9	12.1	175.4	11.2
16/11/2023 18:00	27.67	14.5	425.1	12.6	175.7	11.7
16/11/2023 19:00	29.66	14.6	426.4	13.5	175.5	12.6
16/11/2023 20:00	29.82	14.6	426.9	13.6	175.5	12.7
16/11/2023 21:00	29.47	14.6	427.8	13.4	175.4	12.5
16/11/2023 22:00	30.49	14.6	428.9	13.9	175.1	12.9
16/11/2023 23:00	28.29	14.6	426.9	12.9	175.4	12
17/11/2023 00:00	27.62	14.6	425.9	12.6	175.3	11.7
17/11/2023 01:00	28.5	14.6	426.2	13	175	12.1
17/11/2023 02:00	29.72	14.6	424.7	13.6	174.4	12.6
17/11/2023 03:00	30.35	14.6	423.7	13.9	174.3	12.9
17/11/2023 04:00	31.02	14.6	422.6	14.2	174.2	13.2
17/11/2023 05:00	31.61	14.5	421.3	14.4	173.5	13.4
17/11/2023 06:00	32.42	14.5	420.7	14.8	173.6	13.8
17/11/2023 07:00	31.93	14.6	420.6	14.6	173.6	13.6
17/11/2023 08:00	28.45	14.6	421.8	13	173.9	12.1
17/11/2023 09:00	28.23	14.6	424.1	12.8	174.4	12
17/11/2023 10:00	<Samp	<Samp	<Samp	<Samp	174.7	<Samp
17/11/2023 11:00	28.38	14.6	427.7	12.8	175.4	12
17/11/2023 12:00	28.52	14.6	428.4	12.9	175.5	12.1
17/11/2023 13:00	28.61	14.6	428.2	12.9	175	12.1
17/11/2023 14:00	28.3	14.6	426.4	12.7	174.8	12
17/11/2023 15:00	28.56	14.6	426.5	12.9	175.3	12.1
17/11/2023 16:00	28.99	14.6	426.5	13.1	175.4	12.3
17/11/2023 17:00	29.44	14.6	427.7	13.3	175.2	12.5
17/11/2023 18:00	30.11	14.6	428.5	13.6	175.2	12.8
17/11/2023 19:00	28.5	14.6	422.7	13	173.8	12.1
17/11/2023 20:00	29.69	14.6	423.1	13.5	174.4	12.6
17/11/2023 21:00	30.14	14.6	421.9	13.7	174.3	12.8
17/11/2023 22:00	30.39	14.6	420.9	13.8	173.9	12.9
17/11/2023 23:00	29.97	14.6	420.4	13.7	174	12.7
18/11/2023 00:00	29.01	14.6	419.4	13.3	173.7	12.3
18/11/2023 01:00	28.84	14.5	418.7	13.2	173.8	12.2
18/11/2023 02:00	28.81	14.5	418.1	13.2	173.8	12.2
18/11/2023 03:00	29.33	14.5	417.7	13.4	173.4	12.4
18/11/2023 04:00	30.81	14.5	417	14.1	173.4	13.1

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
18/11/2023 05:00	30.88	14.5	416.6	14.2	173.1	13.1
18/11/2023 06:00	30.96	14.5	416.9	14.2	173.1	13.1
18/11/2023 07:00	30.15	14.5	416.8	13.8	173.1	12.8
18/11/2023 08:00	29.16	14.5	417.8	13.3	173.1	12.4
18/11/2023 09:00	28.7	14.6	420.1	13.1	173.8	12.2
18/11/2023 10:00	29.71	14.6	438.5	13.5	174.2	12.6
18/11/2023 11:00	29.54	14.6	451.2	13.4	174.1	12.5
18/11/2023 12:00	30.01	14.6	444.9	13.5	174.7	12.7
18/11/2023 13:00	29.65	14.6	430.6	13.3	175.1	12.6
18/11/2023 14:00	29.21	14.6	426.6	13.1	175.5	12.4
18/11/2023 15:00	29.3	14.6	426.3	13.2	175.5	12.4
18/11/2023 16:00	29.86	14.6	427.7	13.4	175.4	12.7
18/11/2023 17:00	29.86	14.6	428.7	13.5	175.3	12.7
18/11/2023 18:00	29.23	14.6	424	13.3	174.8	12.4
18/11/2023 19:00	28.97	14.6	421.2	13.2	174.7	12.3
18/11/2023 20:00	28.73	14.5	420	13.1	174.5	12.2
18/11/2023 21:00	29.11	14.5	419.2	13.3	174.3	12.4
18/11/2023 22:00	29.57	14.5	418.1	13.6	174.2	12.6
18/11/2023 23:00	29.95	14.5	417.9	13.7	174.1	12.7
19/11/2023 00:00	29.78	14.5	417.5	13.7	174	12.6
19/11/2023 01:00	29.44	14.5	417.1	13.5	173.6	12.5
19/11/2023 02:00	29.5	14.5	416.7	13.6	173.6	12.5
19/11/2023 03:00	29.86	14.5	416.5	13.7	173.7	12.7
19/11/2023 04:00	30.37	14.5	415.8	14	173.5	12.9
19/11/2023 05:00	31.34	14.5	415.9	14.4	173.4	13.3
19/11/2023 06:00	30.75	14.5	415.2	14.1	173.2	13.1
19/11/2023 07:00	30	14.5	415.8	13.8	173.3	12.7
19/11/2023 08:00	29.78	14.5	416.9	13.7	173.5	12.6
19/11/2023 09:00	28.94	14.6	419.8	13.2	173.8	12.3
19/11/2023 10:00	28.22	14.6	422.1	12.8	173.7	12
19/11/2023 11:00	28.02	14.6	425.7	12.7	174.3	11.9
19/11/2023 12:00	27.71	14.6	427.9	12.5	175.4	11.8
19/11/2023 13:00	27.21	14.6	426.9	12.3	175.4	11.5
19/11/2023 14:00	27.1	14.6	426	12.2	175.3	11.5
19/11/2023 15:00	27.41	14.6	425.6	12.3	175.4	11.6
19/11/2023 16:00	27.17	14.6	426.7	12.2	175.3	11.5
19/11/2023 17:00	27.64	14.6	428.4	12.5	175.3	11.7
19/11/2023 18:00	27.93	14.6	423.3	12.7	174.9	11.9
19/11/2023 19:00	27.99	14.6	420.6	12.8	174.6	11.9
19/11/2023 20:00	27.55	14.5	418.2	12.7	174.6	11.7
19/11/2023 21:00	28.24	14.5	417.4	13	174	12
19/11/2023 22:00	28.89	14.5	417.2	13.3	174.1	12.3
19/11/2023 23:00	28.83	14.5	416.4	13.3	173.8	12.2
20/11/2023 00:00	29.42	14.5	416.1	13.6	173.6	12.5
20/11/2023 01:00	29.5	14.5	415.7	13.6	173.6	12.5
20/11/2023 02:00	29.11	14.5	415.2	13.4	173.5	12.4
20/11/2023 03:00	29.41	14.5	414.7	13.6	173.2	12.5
20/11/2023 04:00	29.77	14.5	414.3	13.8	173.2	12.6
20/11/2023 05:00	27.54	14.5	414.5	12.7	173.3	11.7
20/11/2023 06:00	28.74	14.5	414.4	13.3	173.3	12.2
20/11/2023 07:00	28.59	14.5	415.8	13.2	173.2	12.1
20/11/2023 08:00	28.4	14.5	417.6	13	173.6	12.1
20/11/2023 09:00	28.56	14.6	420.8	13	174	12.1
20/11/2023 10:00	28.81	14.6	425.9	13	174.7	12.2
20/11/2023 11:00	29.14	14.6	426.6	13.1	175.4	12.4
20/11/2023 12:00	29.49	14.7	426.8	13.3	175.3	12.5
20/11/2023 13:00	28.93	14.7	424.8	13	175.6	12.3
20/11/2023 14:00	28.95	14.7	424.2	13	175.7	12.3
20/11/2023 15:00	28.83	14.7	424	13	175.9	12.2

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
23/11/2023 03:00	30.18	14.5	418.4	13.9	173.3	12.8
23/11/2023 04:00	29.58	14.5	418.6	13.6	173.3	12.6
23/11/2023 05:00	28.49	14.5	419	13.1	173.4	12.1
23/11/2023 06:00	28.5	14.5	418.2	13.1	173.3	12.1
23/11/2023 07:00	27.76	14.5	419.7	12.8	173.5	11.8
23/11/2023 08:00	27.21	14.6	424.7	12.4	174.2	11.6
23/11/2023 09:00	<Samp	<Samp	<Samp	<Samp	174.3	<Samp
23/11/2023 10:00	Maintain	Maintain	Alarm	Maintain	174	Maintain
23/11/2023 11:00	<Samp	<Samp	<Samp	<Samp	174.5	<Samp
23/11/2023 12:00	29.24	14.7	421.4	13.1	174.7	12.4
23/11/2023 13:00	28.92	14.7	420.5	13	174.9	12.3
23/11/2023 14:00	29.38	14.7	420.2	13.2	174.8	12.5
23/11/2023 15:00	29.37	14.6	420.2	13.2	175	12.5
23/11/2023 16:00	29.56	14.6	421	13.3	174.9	12.5
23/11/2023 17:00	29.34	14.6	422.1	13.2	174.9	12.5
23/11/2023 18:00	28.56	14.6	425	12.9	175.1	12.1
23/11/2023 19:00	27.97	14.6	428.1	12.7	175.5	11.9
23/11/2023 20:00	27.31	14.6	427.3	12.4	175.4	11.6
23/11/2023 21:00	26.08	14.5	422.6	11.9	175.1	11.1
23/11/2023 22:00	25.37	14.5	420.7	11.6	174.9	10.8
23/11/2023 23:00	25.83	14.5	420.2	11.9	174.7	11
24/11/2023 00:00	27.08	14.5	420.2	12.4	174.5	11.5
24/11/2023 01:00	27.42	14.5	420.1	12.6	174.5	11.6
24/11/2023 02:00	27.51	14.5	420.3	12.6	174.4	11.7
24/11/2023 03:00	28.32	14.5	420.3	13	174.3	12
24/11/2023 04:00	28.6	14.5	420.2	13.1	174.2	12.1
24/11/2023 05:00	29	14.5	419.9	13.3	173.9	12.3
24/11/2023 06:00	28.9	14.5	418.9	13.3	173.9	12.3
24/11/2023 07:00	27.95	14.5	420.4	12.8	174.3	11.9
24/11/2023 08:00	28.13	14.6	425.6	12.8	175	11.9
24/11/2023 09:00	28.63	14.6	426.7	13	174.8	12.2
24/11/2023 10:00	28.08	14.6	424.1	12.7	174.8	11.9
24/11/2023 11:00	27.96	14.6	422.8	12.6	174.8	11.9
24/11/2023 12:00	27.78	14.6	421.1	12.5	175.2	11.8
24/11/2023 13:00	28.76	14.6	420.7	13	175.1	12.2
24/11/2023 14:00	29.73	14.6	420.4	13.4	175	12.6
24/11/2023 15:00	29.25	14.6	420.9	13.2	175	12.4
24/11/2023 16:00	28	14.6	421.3	12.7	175.2	11.9
24/11/2023 17:00	26.79	14.6	422.7	12.2	175.4	11.4
24/11/2023 18:00	27.2	14.6	424.9	12.4	175.7	11.5
24/11/2023 19:00	29.7	14.6	426.8	13.5	175.7	12.6
24/11/2023 20:00	28.55	14.5	423.7	13	175.4	12.1
24/11/2023 21:00	28.1	14.5	420.2	12.9	174.9	11.9
24/11/2023 22:00	28.53	14.5	420.1	13.1	174.8	12.1
24/11/2023 23:00	29.77	14.5	421.3	13.7	174.5	12.6
25/11/2023 00:00	27.1	14.5	420.7	12.4	174.4	11.5
25/11/2023 01:00	27.8	14.5	419.3	12.8	174.2	11.8
25/11/2023 02:00	28.66	14.5	419.1	13.2	173.6	12.2
25/11/2023 03:00	28.09	14.5	418.6	12.9	174.1	11.9
25/11/2023 04:00	28.6	14.5	418	13.2	174.1	12.1
25/11/2023 05:00	28.84	14.5	417.5	13.3	173.8	12.2
25/11/2023 06:00	28.97	14.5	417.9	13.3	173.7	12.3
25/11/2023 07:00	28.58	14.5	419	13.1	173.5	12.1
25/11/2023 08:00	28.62	14.5	420.7	13.1	173.6	12.1
25/11/2023 09:00	29.34	14.6	425.7	13.3	174.5	12.5
25/11/2023 10:00	29.69	14.6	426.5	13.4	174.7	12.6
25/11/2023 11:00	28.84	14.6	424.8	13	174.6	12.2
25/11/2023 12:00	28.02	14.6	423.3	12.6	174.9	11.9
25/11/2023 13:00	27.01	14.6	422.1	12.2	174.8	11.5

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
25/11/2023 14:00	26.87	14.6	422.3	12.1	174.8	11.4
25/11/2023 15:00	27.56	14.6	423.4	12.4	174.9	11.7
25/11/2023 16:00	28.62	14.6	424.9	12.9	175	12.1
25/11/2023 17:00	28.85	14.6	426.6	13.1	175.3	12.2
25/11/2023 18:00	29.78	14.6	427.3	13.5	175.5	12.6
25/11/2023 19:00	29.85	14.6	428.4	13.5	175.6	12.7
25/11/2023 20:00	28.97	14.6	425.7	13.2	175.4	12.3
25/11/2023 21:00	29.26	14.6	423.7	13.3	175.2	12.4
25/11/2023 22:00	29.27	14.6	423.4	13.3	174.8	12.4
25/11/2023 23:00	28.04	14.6	422.5	12.8	174.8	11.9
26/11/2023 00:00	27.72	14.6	421.8	12.7	174.7	11.8
26/11/2023 01:00	27.4	14.5	421.3	12.5	174.5	11.6
26/11/2023 02:00	28.24	14.5	421.3	12.9	174.4	12
26/11/2023 03:00	28.93	14.5	420.4	13.2	174.2	12.3
26/11/2023 04:00	27.99	14.5	421	12.8	174	11.9
26/11/2023 05:00	27.7	14.5	420.6	12.7	174.2	11.8
26/11/2023 06:00	27.65	14.5	420.7	12.7	174.2	11.7
26/11/2023 07:00	27.16	14.5	421.5	12.4	174.5	11.5
26/11/2023 08:00	26.41	14.6	425	12	174.8	11.2
26/11/2023 09:00	24.93	14.6	426.8	11.3	174.8	10.6
26/11/2023 10:00	23.8	14.6	425.8	10.8	174.8	10.1
26/11/2023 11:00	23.09	14.6	424.1	10.5	174.9	9.8
26/11/2023 12:00	22.47	14.6	422.5	10.2	175	9.5
26/11/2023 13:00	23.37	14.6	421.2	10.6	174.8	9.9
26/11/2023 14:00	26.72	14.6	419.8	12.1	175	11.3
26/11/2023 15:00	27.9	14.6	420.4	12.6	174.9	11.8
26/11/2023 16:00	29.29	14.6	422.2	13.2	174.8	12.4
26/11/2023 17:00	29.59	14.6	424.1	13.4	175	12.6
26/11/2023 18:00	29.75	14.6	425.6	13.5	175.2	12.6
26/11/2023 19:00	30.16	14.6	425.2	13.7	175.5	12.8
26/11/2023 20:00	29.9	14.6	425.6	13.6	175.7	12.7
26/11/2023 21:00	28.38	14.6	426.6	12.9	175.8	12
26/11/2023 22:00	28.29	14.6	427.2	12.9	175.8	12
26/11/2023 23:00	28.55	14.6	427.4	13	175.5	12.1
27/11/2023 00:00	28.13	14.5	422.3	12.9	174.7	11.9
27/11/2023 01:00	28.75	14.5	421.4	13.2	174.6	12.2
27/11/2023 02:00	28.85	14.5	421.2	13.3	174.5	12.2
27/11/2023 03:00	29.21	14.5	420	13.5	174.2	12.4
27/11/2023 04:00	29.28	14.5	419.8	13.5	174	12.4
27/11/2023 05:00	29.66	14.5	419.6	13.7	174	12.6
27/11/2023 06:00	30.29	14.5	419	14	174	12.9
27/11/2023 07:00	29.94	14.5	421	13.8	174.3	12.7
27/11/2023 08:00	28.05	14.5	425.2	12.8	174.6	11.9
27/11/2023 09:00	28.54	14.6	427.5	13	175	12.1
27/11/2023 10:00	29.34	14.6	427.9	13.3	175	12.5
27/11/2023 11:00	28.45	14.6	425.7	12.9	174.9	12.1
27/11/2023 12:00	29.32	14.6	424.6	13.3	175	12.4
27/11/2023 13:00	28.87	14.6	422.8	13.1	175	12.3
27/11/2023 14:00	28.62	14.6	422.6	13	175	12.1
27/11/2023 15:00	29.67	14.6	423.1	13.5	174.9	12.6
27/11/2023 16:00	29.02	14.6	424	13.2	174.9	12.3
27/11/2023 17:00	29.99	14.6	425.2	13.6	175.2	12.7
27/11/2023 18:00	28.32	14.6	426.9	12.9	175.7	12
27/11/2023 19:00	26.87	14.5	422.9	12.3	175.2	11.4
27/11/2023 20:00	27.42	14.5	421.3	12.6	174.9	11.6
27/11/2023 21:00	28.78	14.5	421.7	13.2	174.8	12.2
27/11/2023 22:00	29.33	14.5	420.2	13.5	174.7	12.5
27/11/2023 23:00	29.86	14.5	419.8	13.7	174.5	12.7
28/11/2023 00:00	30.19	14.5	419	13.9	173.8	12.8

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
28/11/2023 01:00	29.99	14.5	418.9	13.8	173.4	12.7
28/11/2023 02:00	30.86	14.5	418.7	14.2	173.7	13.1
28/11/2023 03:00	30.86	14.5	418.5	14.2	173.9	13.1
28/11/2023 04:00	31.89	14.5	417.8	14.7	174.1	13.5
28/11/2023 05:00	32.55	14.5	417.8	15	173.7	13.8
28/11/2023 06:00	31.79	14.5	417.3	14.6	173.7	13.5
28/11/2023 07:00	31.56	14.5	417.9	14.5	173.7	13.4
28/11/2023 08:00	28.47	14.5	419.7	13	173.8	12.1
28/11/2023 09:00	28.57	14.6	422.3	13	174.5	12.1
28/11/2023 10:00	29.16	14.6	427.5	13.2	174.8	12.4
28/11/2023 11:00	29.52	14.6	427.1	13.3	174.9	12.5
28/11/2023 12:00	28.55	14.6	425.1	12.9	174.6	12.1
28/11/2023 13:00	28.23	14.6	423.9	12.7	175.2	12
28/11/2023 14:00	28.53	14.6	423.5	12.9	175.3	12.1
28/11/2023 15:00	29.22	14.6	424.7	13.2	174.6	12.4
28/11/2023 16:00	29.73	14.6	426.2	13.4	175.1	12.6
28/11/2023 17:00	30.14	14.6	426.6	13.6	175.4	12.8
28/11/2023 18:00	28.41	14.6	428.5	12.9	175.2	12.1
28/11/2023 19:00	29.7	14.6	423.5	13.6	175.3	12.6
28/11/2023 20:00	29.83	14.5	420.2	13.7	174.3	12.7
28/11/2023 21:00	30.25	14.5	419.6	13.9	174.2	12.8
28/11/2023 22:00	30.15	14.5	420.3	13.8	173.6	12.8
28/11/2023 23:00	30.46	14.5	419.3	14	173.7	12.9
29/11/2023 00:00	30.95	14.5	418.4	14.2	174	13.1
29/11/2023 01:00	30.33	14.5	418.5	13.9	173.2	12.9
29/11/2023 02:00	31.18	14.5	418.7	14.3	173.7	13.2
29/11/2023 03:00	31.36	14.5	418.2	14.4	173.1	13.3
29/11/2023 04:00	31.4	14.5	418.2	14.5	173.6	13.3
29/11/2023 05:00	31.16	14.5	417.1	14.4	173.5	13.2
29/11/2023 06:00	31.35	14.5	417	14.5	173.3	13.3
29/11/2023 07:00	30.7	14.5	417.5	14.1	173.7	13
29/11/2023 08:00	28.4	14.5	419.8	13	173.6	12.1
29/11/2023 09:00	28.15	14.6	422.7	12.8	174.5	11.9
29/11/2023 10:00	28.49	14.6	427.2	12.9	174.9	12.1
29/11/2023 11:00	26.84	14.6	425.5	12.1	174.7	11.4
29/11/2023 12:00	26.16	14.6	422.1	11.8	175.3	11.1
29/11/2023 13:00	27.33	14.6	421.6	12.3	174.5	11.6
29/11/2023 14:00	26.97	14.6	421.4	12.1	175.2	11.4
29/11/2023 15:00	26.75	14.6	421	12.1	174.7	11.4
29/11/2023 16:00	26.72	14.6	422	12.1	175	11.3
29/11/2023 17:00	26.01	14.6	423.1	11.8	175.2	11
29/11/2023 18:00	26.75	14.6	425.2	12.1	175.1	11.4
29/11/2023 19:00	26.74	14.6	426.3	12.2	175.9	11.3
29/11/2023 20:00	27.81	14.6	427.7	12.7	175.4	11.8
29/11/2023 21:00	27.95	14.5	425.7	12.8	175.5	11.9
29/11/2023 22:00	28.88	14.5	422.1	13.2	174.5	12.3
29/11/2023 23:00	30.01	14.5	421.4	13.8	174.4	12.7
30/11/2023 00:00	29.08	14.5	421.4	13.3	174.7	12.3
30/11/2023 01:00	28.92	14.5	420.7	13.3	173.9	12.3
30/11/2023 02:00	29.26	14.5	420.2	13.4	174	12.4
30/11/2023 03:00	29.41	14.5	419.9	13.5	174	12.5
30/11/2023 04:00	30.01	14.5	419.8	13.8	173.7	12.7
30/11/2023 05:00	30.23	14.5	418.8	13.9	174	12.8
30/11/2023 06:00	30.82	14.5	418.6	14.2	173.6	13.1
30/11/2023 07:00	30.22	14.5	420.2	13.9	174.3	12.8
30/11/2023 08:00	29.19	14.6	435.3	13.3	174.8	12.4
30/11/2023 09:00	30.24	14.6	428.6	13.7	175	12.8
30/11/2023 10:00	29.7	14.6	422	13.4	174.9	12.6
30/11/2023 11:00	30.29	14.6	421.3	13.6	174.7	12.9

Site Report - GPSC CUP2 HRSG1							
Date&Time	NOx@7%O2		O2		Flow		NOx
	ppm	%Vol	ppm	%Vol	km3/h	Deg C	
01/12/2023 00:00	28.79	14.5	422.8	13.2	174.3	174.3	12.2
01/12/2023 01:00	29.55	14.5	422.5	13.6	174	174	12.5
01/12/2023 02:00	29.85	14.5	422.4	13.7	174	174	12.7
01/12/2023 03:00	30.09	14.5	422.4	13.8	174.5	174.5	12.8
01/12/2023 04:00	29.98	14.5	422.9	13.8	174.5	174.5	12.7
01/12/2023 05:00	28.8	14.5	424.7	13.2	174.4	174.4	12.2
01/12/2023 06:00	28.11	14.5	423.9	12.9	174.5	174.5	11.9
01/12/2023 07:00	28.35	14.5	422.5	13	174.3	174.3	12
01/12/2023 08:00	28.84	14.6	426.5	13.2	175	175	12.2
01/12/2023 09:00	28.33	14.6	424.6	12.9	174.9	174.9	12
01/12/2023 10:00	28.08	14.6	422.7	12.8	174.4	174.4	11.9
01/12/2023 11:00	28.3	14.6	420.9	11.9	174.5	174.5	11.2
01/12/2023 12:00	28.73	14.6	421.1	12.1	174.3	174.3	11.3
01/12/2023 13:00	28.78	14.6	419.2	12.1	174.5	174.5	11.4
01/12/2023 14:00	28.73	14.6	420.3	12.2	174	174	11.3
01/12/2023 15:00	28.08	14.5	427.3	12	174.1	174.1	11.1
01/12/2023 16:00	28.69	14.5	425.4	12.2	174.5	174.5	11.3
01/12/2023 17:00	28.61	14.5	424.9	12.2	174.6	174.6	11.3
01/12/2023 18:00	26.12	14.5	426.5	12	175.3	175.3	11.1
01/12/2023 19:00	26.41	14.5	426.9	12.2	175.8	175.8	11.2
01/12/2023 20:00	26.6	14.5	422.7	12.3	175	175	11.3
01/12/2023 21:00	27.78	14.5	423.7	12.8	175.1	175.1	11.8
01/12/2023 22:00	29.69	14.5	422.5	13.7	174.8	174.8	12.6
01/12/2023 23:00	29.43	14.5	423.1	13.5	174.9	174.9	12.5
02/12/2023 00:00	29.37	14.5	424.5	13.5	174.9	174.9	12.5
02/12/2023 01:00	28.93	14.5	422.6	13.3	174.4	174.4	12.3
02/12/2023 02:00	28.96	14.5	421	13.4	174.5	174.5	12.3
02/12/2023 03:00	29.14	14.5	420.3	13.4	174	174	12.4
02/12/2023 04:00	29.47	14.5	419.9	13.6	174.1	174.1	12.5
02/12/2023 05:00	30.84	14.5	420.2	14.2	174.3	174.3	13.1
02/12/2023 06:00	30.87	14.5	419.1	14.3	174.1	174.1	13.1
02/12/2023 07:00	29.54	14.5	421.4	13.6	174.5	174.5	12.5
02/12/2023 08:00	28.37	14.5	424.5	13	174.4	174.4	12
02/12/2023 09:00	28.35	14.6	425.5	12.9	175	175	12
02/12/2023 10:00	28.37	14.6	423	12.9	174.8	174.8	12
02/12/2023 11:00	29.34	14.6	422.3	13.3	174.7	174.7	12.5
02/12/2023 12:00	30.32	14.6	421	13.7	175	175	12.9
02/12/2023 13:00	29.14	14.6	420.3	13.1	174.6	174.6	12.4
02/12/2023 14:00	28.79	14.6	419.7	13	175.1	175.1	12.2
02/12/2023 15:00	29.28	14.6	419	13.2	175	175	12.4
02/12/2023 16:00	29.37	14.6	419.2	13.3	174.9	174.9	12.5
02/12/2023 17:00	29.68	14.6	420	13.4	174.8	174.8	12.6
02/12/2023 18:00	29.77	14.6	421.5	13.5	174.8	174.8	12.6
02/12/2023 19:00	29.51	14.6	423.4	13.4	175.3	175.3	12.5
02/12/2023 20:00	29.19	14.6	425.5	13.3	175.4	175.4	12.4
02/12/2023 21:00	29.36	14.6	427.4	13.4	175.4	175.4	12.5
02/12/2023 22:00	29.52	14.6	426.6	13.5	175.5	175.5	12.5
02/12/2023 23:00	29.67	14.6	426.7	13.5	175	175	12.6
03/12/2023 00:00	28.81	14.5	426	13.2	175.2	175.2	12.2
03/12/2023 01:00	28.81	14.5	426.8	13.2	174.9	174.9	12.2
03/12/2023 02:00	28.81	14.5	424.9	13.2	174.6	174.6	12.2
03/12/2023 03:00	28.44	14.5	424.4	13	174.8	174.8	12.1
03/12/2023 04:00	28.72	14.5	425.3	13.1	174.4	174.4	12.2
03/12/2023 05:00	28.82	14.5	424.3	13.2	174.6	174.6	12.2
03/12/2023 06:00	28.62	14.5	422.9	13.1	174.2	174.2	12.1
03/12/2023 07:00	29	14.5	424.2	13.3	174.4	174.4	12.3
03/12/2023 08:00	29.76	14.6	426.8	13.6	174.7	174.7	12.6
03/12/2023 09:00	28.82	14.6	424.8	13.1	174.4	174.4	12.2
03/12/2023 10:00	28.18	14.6	422.4	12.8	174.5	174.5	12

Site Report - GPSC CUP2 HRSG1							
Date&Time	NOx@7%O2		O2		Flow		NOx
	ppm	%Vol	ppm	%Vol	km3/h	Deg C	
03/12/2023 11:00	27.45	14.6	421.8	12.4	174.4	174.4	11.7
03/12/2023 12:00	27.18	14.6	420.9	12.3	174.5	174.5	11.5
03/12/2023 13:00	26.8	14.6	419.9	12.1	174.5	174.5	11.4
03/12/2023 14:00	26.6	14.6	422.3	12.1	174.2	174.2	11.3
03/12/2023 15:00	26.3	14.6	422.7	12	175	175	11.2
03/12/2023 16:00	27.94	14.6	422.4	12.7	174.5	174.5	11.9
03/12/2023 17:00	29.14	14.6	423.1	13.3	174.8	174.8	12.4
03/12/2023 18:00	29.55	14.6	425.8	13.5	175.1	175.1	12.5
03/12/2023 19:00	28.36	14.6	427.5	12.9	175.1	175.1	12
03/12/2023 20:00	28.25	14.5	425.7	12	175.3	175.3	11.1
03/12/2023 21:00	25.77	14.5	425.2	11.8	175.3	175.3	10.9
03/12/2023 22:00	26.57	14.5	424.2	12.2	175.3	175.3	11.3
03/12/2023 23:00	26.61	14.5	424.1	12.2	175.4	175.4	11.3
04/12/2023 00:00	26.75	14.5	424	12.3	175.3	175.3	11.4
04/12/2023 01:00	27.69	14.5	424.6	12.7	175.5	175.5	11.8
04/12/2023 02:00	27.45	14.5	424.1	12.6	175.3	175.3	11.7
04/12/2023 03:00	27.98	14.5	424.4	12.9	175	175	11.9
04/12/2023 04:00	28.19	14.5	424.7	13	175.2	175.2	12
04/12/2023 05:00	27.57	14.5	421.6	12.7	174.7	174.7	11.7
04/12/2023 06:00	28.12	14.5	420.8	13	174.7	174.7	11.9
04/12/2023 07:00	29.05	14.5	420.8	13.4	174.6	174.6	12.3
04/12/2023 08:00	29.67	14.5	425.8	13.6	175.1	175.1	12.6
04/12/2023 09:00	30.09	14.6	426.4	13.7	175.3	175.3	12.8
04/12/2023 10:00	29.59	14.6	425.9	13.5	174.9	174.9	12.6
04/12/2023 11:00	29.38	14.6	425	13.3	174.8	174.8	12.5
04/12/2023 12:00	28.64	14.6	422.6	13	175.2	175.2	12.2
04/12/2023 13:00	28.22	14.6	420.1	12.8	175.2	175.2	12
04/12/2023 14:00	28.64	14.6	420.1	13	175.1	175.1	12.2
04/12/2023 15:00	28.87	14.6	418.9	13.1	174.7	174.7	12.3
04/12/2023 16:00	28.17	14.6	422	12.8	174.2	174.2	12
04/12/2023 17:00	29.13	14.5	425.5	13.3	174.9	174.9	12.4
04/12/2023 18:00	29.11	14.5	421.9	13.4	174.5	174.5	12.4
04/12/2023 19:00	28.62	14.5	421.8	13.2	174.8	174.8	12.1
04/12/2023 20:00	28.43	14.5	420.7	13.1	174.8	174.8	12.1
04/12/2023 21:00	26.93	14.5	420	12.5	174.5	174.5	11.4
04/12/2023 22:00	27.67	14.5	420.2	12.8	174.6	174.6	11.7
04/12/2023 23:00	27.8	14.5	420.5	12.8	174.6	174.6	11.8
05/12/2023 00:00	28.38	14.5	420.9	13.1	174.4	174.4	12
05/12/2023 01:00	27.75	14.5	420.8	12.8	174.2	174.2	11.8
05/12/2023 02:00	28.26	14.5	420.6	13	174.4	174.4	12
05/12/2023 03:00	28.49	14.5	420.7	13.2	174.7	174.7	12.1
05/12/2023 04:00	29.2	14.5	424.9	13.4	174.9	174.9	12.4
05/12/2023 05:00	27.93	14.5	421.6	12.9	174.8	174.8	11.9
05/12/2023 06:00	26.58	14.5	419.3	12.3	174.5	174.5	11.3
05/12/2023 07:00	26.13	14.5	420	12.1	174.4	174.4	11.1
05/12/2023 08:00	25.93	14.5	424.3	11.9	174.9	174.9	11
05/12/2023 09:00	27.79	14.6	424.6	12.7	175.1	175.1	11.8
05/12/2023 10:00	27.47	14.6	422.9	12.5	174.9	174.9	11.7
05/12/2023 11:00	27.44	14.6	421.8	12.4	174.8	174.8	11.6
05/12/2023 12:00	26.83	14.6	419.8	12.1	174.9	174.9	11.4
05/12/2023 13:00	26.65	14.6	419	12.1	174.9	174.9	11.3
05/12/2023 14:00	25.31	14.6	419.5	11.5	174.5	174.5	10.7
05/12/2023 15:00	25.93	14.6	425.9	11.8	174.7	174.7	11
05/12/2023 16:00	27.02	14.6	427	12.3	175.1	175.1	11.5
05/12/2023 17:00	27.6	14.6	427.2	12.6	175.2	175.2	11.7
05/12/2023 18:00	27.29	14.5	424.8	12.5	175.2	175.2	11.6
05/12/2023 19:00	27.08	14.5	422.7	12.5	175	175	11.5
05/12/2023 20:00	27	14.5	421.6	12.4	175.1	175.1	11.5
05/12/2023 21:00	27.5	14.5	421.5	12.7	175.1	175.1	11.7

Site Report - GPSC CUP2 HRSG1							
Date&Time	NOx@7%O2		O2		Flow		NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm	
05/12/2023 22:00	27.42	14.5	421.8	12.6	175.1	11.6	
05/12/2023 23:00	27.24	14.5	420.9	12.6	175	11.6	
06/12/2023 00:00	26.97	14.5	420.4	12.5	174.8	11.4	
06/12/2023 01:00	27.46	14.5	419.7	12.7	174.8	11.7	
06/12/2023 02:00	28.15	14.5	418.9	13	174.6	11.9	
06/12/2023 03:00	28.67	14.5	418.3	13.3	174.4	12.2	
06/12/2023 04:00	29.28	14.5	418.7	13.6	174.6	12.4	
06/12/2023 05:00	29.11	14.5	417.7	13.5	174.5	12.4	
06/12/2023 06:00	29.79	14.5	418.1	13.8	174.4	12.6	
06/12/2023 07:00	28.68	14.5	420.2	13.3	174.8	12.2	
06/12/2023 08:00	28.8	14.5	425.3	13.2	175.3	12.2	
06/12/2023 09:00	28.79	14.6	423.4	13.1	175.2	12.2	
06/12/2023 10:00	28.87	14.6	421.5	13.1	175.2	12.3	
06/12/2023 11:00	27.91	14.6	420	12.6	175	11.8	
06/12/2023 12:00	28.33	14.6	418.2	12.8	175.1	12	
06/12/2023 13:00	26.1	14.6	417.9	11.9	174.7	11.1	
06/12/2023 14:00	27.26	14.6	417.4	12.4	174.7	11.6	
06/12/2023 15:00	28.42	14.6	418.3	12.9	174.7	12.1	
06/12/2023 16:00	28.71	14.6	419.7	13	174.7	12.2	
06/12/2023 17:00	28.58	14.6	420.6	13	174.4	12.1	
06/12/2023 18:00	27.66	14.6	423.1	12.6	174.3	11.7	
06/12/2023 19:00	26.92	14.6	424.9	12.3	174.6	11.4	
06/12/2023 20:00	26.85	14.5	426.1	12.3	174.9	11.4	
06/12/2023 21:00	27.94	14.5	427	12.8	175.3	11.9	
06/12/2023 22:00	26.52	14.5	423.6	12.2	174.9	11.3	
06/12/2023 23:00	26.67	14.5	422	12.3	175.3	11.3	
07/12/2023 00:00	27.07	14.5	421.7	12.5	175.2	11.5	
07/12/2023 01:00	27.06	14.5	419.9	12.5	174.6	11.5	
07/12/2023 02:00	29.5	14.5	420	13.6	174.7	12.5	
07/12/2023 03:00	35.2	14.5	420.4	16.2	174.7	14.9	
07/12/2023 04:00	Maintain	Maintain	Alarm	Maintain	174.8	Maintain	
07/12/2023 05:00	Maintain	Maintain	Alarm	Maintain	174.8	Maintain	
07/12/2023 06:00	Maintain	Maintain	Alarm	Maintain	174.2	Maintain	
07/12/2023 07:00	Maintain	Maintain	Alarm	Maintain	174.8	Maintain	
07/12/2023 08:00	Maintain	Maintain	Alarm	Maintain	175.1	Maintain	
07/12/2023 09:00	Maintain	Maintain	Alarm	Maintain	175.2	Maintain	
07/12/2023 10:00	Maintain	Maintain	Alarm	Maintain	175.2	Maintain	
07/12/2023 11:00	Maintain	Maintain	Alarm	Maintain	175	Maintain	
07/12/2023 12:00	Maintain	Maintain	Alarm	Maintain	175.5	Maintain	
07/12/2023 13:00	Maintain	Maintain	Alarm	Maintain	175.1	Maintain	
07/12/2023 14:00	Maintain	Maintain	Alarm	Maintain	174.6	Maintain	
07/12/2023 15:00	<Samp	<Samp	<Samp	<Samp	174.2	<Samp	
07/12/2023 16:00	22.65	14.6	419.2	10.3	174.4	9.6	
07/12/2023 17:00	23.8	14.6	419.9	10.8	174.2	10.1	
07/12/2023 18:00	25.08	14.6	423.6	11.4	174.3	10.6	
07/12/2023 19:00	21.89	14.2	420.6	10.5	168.4	9.3	
07/12/2023 20:00	22.67	14.2	420.1	11	165.5	9.6	
07/12/2023 21:00	23.79	14.2	421.2	11.4	166.1	10.1	
07/12/2023 22:00	27.4	14.5	419.9	12.7	173.7	11.6	
07/12/2023 23:00	27.89	14.5	419.3	12.9	174.2	11.8	
08/12/2023 00:00	28.46	14.5	418.9	13.2	174	12.1	
08/12/2023 01:00	28.59	14.5	418.6	13.2	173.9	12.1	
08/12/2023 02:00	29.09	14.5	418.4	13.5	174.1	12.3	
08/12/2023 03:00	29.52	14.5	418.4	13.7	173.7	12.5	
08/12/2023 04:00	29.64	14.5	418.1	13.7	173.9	12.6	
08/12/2023 05:00	29.59	14.5	418	13.7	173.8	12.6	
08/12/2023 06:00	29.54	14.5	418.6	13.7	174.2	12.5	
08/12/2023 07:00	28.67	14.5	421.2	13.2	174.3	12.2	
08/12/2023 08:00	29.4	14.6	425.4	13.4	175.1	12.5	

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
10/12/2023 20:00	25.29	14.5	426.5	11.6	175.1	10.7
10/12/2023 21:00	25.03	14.5	424.4	11.5	175.4	10.6
10/12/2023 22:00	25.16	14.5	422.1	11.6	175.2	10.7
10/12/2023 23:00	24.8	14.5	421.3	11.5	175.1	10.5
11/12/2023 00:00	23.5	14.5	420.6	10.9	175	10
11/12/2023 01:00	23.56	14.5	419.2	10.9	174.7	10
11/12/2023 02:00	23.78	14.5	419.2	11	174.6	10.1
11/12/2023 03:00	24.02	14.4	418.3	11.1	174.7	10.2
11/12/2023 04:00	24.18	14.4	419	11.2	174.4	10.3
11/12/2023 05:00	24.89	14.5	418.4	11.5	174.5	10.6
11/12/2023 06:00	24.95	14.4	418.9	11.6	174.5	10.6
11/12/2023 07:00	24.42	14.5	420.4	11.3	174.7	10.4
11/12/2023 08:00	24.12	14.5	424.4	11.1	175.4	10.2
11/12/2023 09:00	24.49	14.5	422.7	11.2	175.4	10.4
11/12/2023 10:00	24.48	14.6	421.2	11.1	175.3	10.4
11/12/2023 11:00	24.46	14.6	419	11.1	174.8	10.4
11/12/2023 12:00	23.04	14.6	417.3	10.5	174.6	9.8
11/12/2023 13:00	22.98	14.6	415.8	10.4	174.2	9.8
11/12/2023 14:00	24.73	14.6	415.7	11.2	173.9	10.5
11/12/2023 15:00	25.53	14.6	417	11.5	174.3	10.8
11/12/2023 16:00	25.73	14.6	419.9	11.7	174.4	10.9
11/12/2023 17:00	26.47	14.6	421.1	12	174.6	11.2
11/12/2023 18:00	25.39	14.6	423.4	11.8	174.9	10.8
11/12/2023 19:00	25.74	14.5	425.3	11.8	175.2	10.9
11/12/2023 20:00	26.14	14.5	426.8	12	175.1	11.1
11/12/2023 21:00	22.54	13.8	426.1	11.5	159.8	9.6
11/12/2023 22:00	19.63	12.8	379.3	11.3	141.1	8.3
11/12/2023 23:00	17.1	12.5	351.6	10.3	135.4	7.3
12/12/2023 00:00	17.26	12.5	351.8	10.4	134.9	7.3
12/12/2023 01:00	16.71	12.8	351.7	9.7	138	7.1
12/12/2023 02:00	16.71	13	350.9	9.5	140.4	7.1
12/12/2023 03:00	17.01	13	350.9	9.6	140.5	7.2
12/12/2023 04:00	16.99	13	350.9	9.6	140.4	7.2
12/12/2023 05:00	17.17	13	351.1	9.7	140.5	7.3
12/12/2023 06:00	16.53	13.2	350.9	9.2	141.7	7
12/12/2023 07:00	15.12	13.3	351	8.3	143.1	6.4
12/12/2023 08:00	14.14	13.4	351.6	7.6	145.2	6
12/12/2023 09:00	14.7	13.5	352.7	7.9	145.3	6.2
12/12/2023 10:00	19.23	13.4	379.6	10.4	145	8.2
12/12/2023 11:00	17.61	13.1	390.1	9.8	141.5	7.5
12/12/2023 12:00	18.47	13.1	394.1	10.4	141.4	7.8
12/12/2023 13:00	17.73	13.1	388.8	10	140.4	7.5
12/12/2023 14:00	18.4	13.1	393.9	10.4	140.3	7.8
12/12/2023 15:00	16.49	13.2	387.3	9.1	142.6	7
12/12/2023 16:00	16.17	13.3	385.2	8.9	143.4	6.9
12/12/2023 17:00	15.86	13.4	384.1	8.6	144.6	6.7
12/12/2023 18:00	17.09	13.3	382.4	9.3	144.3	7.3
12/12/2023 19:00	15.84	13.3	378.4	8.7	144.8	6.7
12/12/2023 20:00	15.35	13.2	361.5	8.5	143.2	6.5
12/12/2023 21:00	16.29	13.1	360.9	9.1	142.3	6.9
12/12/2023 22:00	16.8	13.1	360.5	9.4	142.3	7.1
12/12/2023 23:00	16.85	13.1	360.1	9.4	142.2	7.2
13/12/2023 00:00	16.7	13.1	360	9.4	142	7.1
13/12/2023 01:00	17.09	13.1	359.7	9.6	141.5	7.3
13/12/2023 02:00	17.61	13	359.7	10	140.7	7.5
13/12/2023 03:00	17.79	13	359.6	10.1	140.7	7.5
13/12/2023 04:00	18.04	12.9	360.2	10.3	140.2	7.7
13/12/2023 05:00	18.26	12.9	360.5	10.5	139.9	7.7
13/12/2023 06:00	18.29	12.9	360	10.5	139.8	7.8

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
13/12/2023 07:00	18.01	12.9	360.2	10.3	140.2	7.6
13/12/2023 08:00	17.43	13	360.9	10	140	7.4
13/12/2023 09:00	17.44	13	361.4	9.9	139.8	7.4
13/12/2023 10:00	18.03	13	363.3	10.2	139.4	7.7
13/12/2023 11:00	18.55	13	364.3	10.5	139.5	7.9
13/12/2023 12:00	19.28	13.1	365.2	10.9	138.9	8.2
13/12/2023 13:00	19.34	13.1	366.1	10.8	139.8	8.2
13/12/2023 14:00	18.5	13.1	365.2	10.4	139.9	7.9
13/12/2023 15:00	17.57	13.1	365.7	9.9	140	7.5
13/12/2023 16:00	17.4	13.1	364.8	9.8	139.4	7.4
13/12/2023 17:00	17.81	13	364.3	10.1	139.2	7.6
13/12/2023 18:00	17.44	13	363.2	9.9	139.4	7.4
13/12/2023 19:00	17.39	13	362.2	9.9	139.5	7.4
13/12/2023 20:00	17.5	13	361	10	139.4	7.4
13/12/2023 21:00	17.91	13	361.3	10.2	139.4	7.6
13/12/2023 22:00	18.35	13	360.6	10.5	139.3	7.8
13/12/2023 23:00	19.63	13	360.3	11.2	139.4	8.3
14/12/2023 00:00	20.85	13	360.7	11.8	139.4	8.8
14/12/2023 01:00	21	13	360.3	11.9	139.3	8.9
14/12/2023 02:00	21.42	13	360.6	12.2	139.5	9.1
14/12/2023 03:00	21.7	12.9	360.6	12.5	138.2	9.2
14/12/2023 04:00	22.19	12.8	360.5	12.9	136.8	9.4
14/12/2023 05:00	21.95	13	360.5	12.5	139.2	9.3
14/12/2023 06:00	21.86	13	360	12.4	139	9.3
14/12/2023 07:00	21.14	13.2	360.4	11.8	141.1	9
14/12/2023 08:00	20.4	13.2	361	11.3	141.8	8.7
14/12/2023 09:00	20.54	13.3	362.5	11.3	142.3	8.7
14/12/2023 10:00	21.18	13.3	368.6	11.5	142.4	9
14/12/2023 11:00	21.26	13.4	374.2	11.5	143.1	9
14/12/2023 12:00	21.33	13.4	375.6	11.5	143.7	9.1
14/12/2023 13:00	21.37	13.4	374.9	11.5	143.5	9.1
14/12/2023 14:00	19.9	13.4	376.1	10.8	143.4	8.4
14/12/2023 15:00	19.2	13.4	375.9	10.4	143.3	8.1
14/12/2023 16:00	19.62	13.3	375.1	10.7	143.3	8.3
14/12/2023 17:00	20.08	13.4	374.2	10.9	143.1	8.5
14/12/2023 18:00	20.07	13.4	373.1	10.9	143.3	8.5
14/12/2023 19:00	19.57	13.4	371.4	10.5	144.5	8.3
14/12/2023 20:00	19.42	13.4	370.8	10.4	144.7	8.2
14/12/2023 21:00	19.28	13.4	370.3	10.4	145.1	8.2
14/12/2023 22:00	19.3	13.4	369.7	10.4	144.6	8.2
14/12/2023 23:00	19.22	13.7	378.3	9.9	149.8	8.2
15/12/2023 00:00	19.51	13.8	378.3	10	152.1	8.3
15/12/2023 01:00	19.7	13.6	377.8	10.3	149.6	8.4
15/12/2023 02:00	20.24	13.6	378	10.6	148.9	8.6
15/12/2023 03:00	21.07	13.7	378.4	11	148.9	8.9
15/12/2023 04:00	21.27	13.7	378	11	150.3	9
15/12/2023 05:00	22.9	13.7	384.1	11.8	150.8	9.7
15/12/2023 06:00	23.84	13.9	387.9	12.1	154.3	10.1
15/12/2023 07:00	24.9	14	391.2	12.4	156.9	10.6
15/12/2023 08:00	27.02	14.1	401.7	13.3	159.7	11.5
15/12/2023 09:00	25.65	14.1	404.2	12.5	160.6	10.9
15/12/2023 10:00	26.52	14.2	408.1	12.8	161.4	11.3
15/12/2023 11:00	27.19	14.2	410.3	13.1	162	11.5
15/12/2023 12:00	27.27	14.2	411.8	13.1	162.7	11.6
15/12/2023 13:00	26.97	14.2	415	12.9	162.9	11.4
15/12/2023 14:00	25.22	14.2	414.3	12.1	162.1	10.7
15/12/2023 15:00	25.95	14.2	416	12.5	162.3	11
15/12/2023 16:00	25.85	14.2	416.9	12.4	162.5	11
15/12/2023 17:00	26.51	14.2	420.1	12.8	163	11.3

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
15/12/2023 18:00	26.57	14.2	422.2	12.8	163	11.3
15/12/2023 19:00	26.04	14.2	424.3	12.6	163.6	11.1
15/12/2023 20:00	25.54	14.2	426.6	12.4	163.6	10.8
15/12/2023 21:00	25.65	14.1	427.7	12.5	164.1	10.9
15/12/2023 22:00	25.43	14.1	426.8	12.4	163.6	10.8
15/12/2023 23:00	24.72	14.1	424.1	12.1	163.2	10.5
16/12/2023 00:00	24.77	14.1	422	12.2	163	10.5
16/12/2023 01:00	25.01	14.1	420.3	12.3	162.4	10.6
16/12/2023 02:00	25.08	14.1	420.1	12.3	162.3	10.6
16/12/2023 03:00	25.29	14.1	419.2	12.5	162.5	10.7
16/12/2023 04:00	25.56	14.1	419.8	12.6	162.5	10.8
16/12/2023 05:00	25.55	14.1	419.9	12.6	162	10.8
16/12/2023 06:00	25.33	14.1	419.9	12.5	162.2	10.8
16/12/2023 07:00	24.88	14.1	422.2	12.2	162.8	10.6
16/12/2023 08:00	25.04	14.1	425.5	12.2	163.5	10.6
16/12/2023 09:00	25.12	14.2	423	12.2	162.9	10.7
16/12/2023 10:00	25.78	14.2	420.6	12.4	163.2	10.9
16/12/2023 11:00	25.88	14.2	419	12.4	162.7	11
16/12/2023 12:00	26.85	14.2	418.4	12.9	162.6	11.4
16/12/2023 13:00	24.87	14.2	415	12	162.5	10.6
16/12/2023 14:00	25.01	14.2	414.9	12	161.5	10.6
16/12/2023 15:00	25.1	14.2	416.1	12.1	161.7	10.7
16/12/2023 16:00	24.62	14.2	419.6	11.9	161.9	10.4
16/12/2023 17:00	25.37	14.2	420.6	12.2	162.4	10.8
16/12/2023 18:00	25.85	14.2	422.5	12.5	162.8	11
16/12/2023 19:00	25.29	14.2	426.5	12.2	163.5	10.7
16/12/2023 20:00	25.35	14.2	427.1	12.2	166	10.8
16/12/2023 21:00	24.87	14.2	427.4	12	166.1	10.6</

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
20/12/2023 16:00	18.49	14.6	418	8.4	174.4	7.8
20/12/2023 17:00	18.77	14.6	419.7	8.5	174.2	8
20/12/2023 18:00	19.42	14.6	421.7	8.8	174.5	8.2
20/12/2023 19:00	21.81	14.6	424.4	9.9	175.3	9.3
20/12/2023 20:00	22	14.6	425.9	10	175.4	9.3
20/12/2023 21:00	22.63	14.5	427.3	10.4	175.4	9.6
20/12/2023 22:00	23.37	14.5	423.8	10.7	174.6	9.9
20/12/2023 23:00	24.9	14.5	422.9	11.4	174	10.6
21/12/2023 00:00	26.01	14.5	422.2	11.9	173.8	11
21/12/2023 01:00	25.99	14.5	421.7	11.9	173.7	11
21/12/2023 02:00	26.51	14.5	421.4	12.2	173.7	11.3
21/12/2023 03:00	27.08	14.5	420.5	12.4	173.4	11.5
21/12/2023 04:00	27.5	14.5	419.8	12.6	173.1	11.7
21/12/2023 05:00	27.71	14.5	419.9	12.7	173.7	11.8
21/12/2023 06:00	27.67	14.5	419.1	12.7	173.3	11.7
21/12/2023 07:00	27.69	14.5	419.2	12.7	173.1	11.8
21/12/2023 08:00	27.77	14.5	422.2	12.7	173.8	11.8
21/12/2023 09:00	28.23	14.6	427.1	12.8	174.5	12
21/12/2023 10:00	26.65	14.6	426.5	12	174.8	11.3
21/12/2023 11:00	25.86	14.6	423.9	11.6	174.6	11
21/12/2023 12:00	25.57	14.6	421.9	11.5	174.8	10.9
21/12/2023 13:00	25.2	14.7	420.6	11.3	174.7	10.7
21/12/2023 14:00	25.28	14.7	420.2	11.4	174.4	10.7
21/12/2023 15:00	26.12	14.7	420.8	11.7	174.7	11.1
21/12/2023 16:00	27.08	14.7	422.2	12.2	174.8	11.5
21/12/2023 17:00	27.46	14.7	423.9	12.3	174.7	11.7
21/12/2023 18:00	27.7	14.6	426	12.5	174.8	11.8
21/12/2023 19:00	28.05	14.6	428.9	12.7	174.9	11.9
21/12/2023 20:00	28.21	14.6	427.9	12.8	175	12
21/12/2023 21:00	27.88	14.6	423.3	12.7	174.8	11.8
21/12/2023 22:00	27.53	14.6	421.4	12.6	174	11.7
21/12/2023 23:00	28.65	14.5	420	13.1	173.8	12.2
22/12/2023 00:00	29.74	14.6	420	13.6	173.6	12.6
22/12/2023 01:00	29.98	14.6	419.8	13.7	173.5	12.7
22/12/2023 02:00	30.13	14.5	418.9	13.8	173.3	12.8
22/12/2023 03:00	30.18	14.5	418.1	13.8	172.9	12.8
22/12/2023 04:00	29.4	14.5	416.6	13.5	172.6	12.5
22/12/2023 05:00	29.1	14.5	415.8	13.4	172.5	12.4
22/12/2023 06:00	29.14	14.5	415.7	13.4	172.5	12.4
22/12/2023 07:00	27.97	14.5	415.9	12.9	172.6	11.9
22/12/2023 08:00	26.05	14.5	416.6	12	172.4	11.1
22/12/2023 09:00	25.81	14.5	417.9	11.8	172.7	11
22/12/2023 10:00	25.41	14.6	420.3	11.6	173.2	10.8
22/12/2023 11:00	20.48	14.6	422	9.3	173.7	8.7
22/12/2023 12:00	25.72	14.6	425	11.6	174.1	10.9
22/12/2023 13:00	26.54	14.6	429.4	11.9	174.4	11.3
22/12/2023 14:00	27.68	14.7	428.8	12.4	174.6	11.7
22/12/2023 15:00	28.79	14.7	428.6	12.9	174.6	12.2
22/12/2023 16:00	29.91	14.7	429.7	13.4	174.5	12.7
22/12/2023 17:00	28.16	14.6	428.8	12.7	174.4	12
22/12/2023 18:00	26.77	14.6	422.8	12.1	174.4	11.4
22/12/2023 19:00	26.34	14.6	421.8	12	174.2	11.2
22/12/2023 20:00	26.85	14.6	420.3	12.2	173.9	11.4
22/12/2023 21:00	27.36	14.6	418.9	12.5	173.6	11.6
22/12/2023 22:00	28	14.6	418.5	12.8	174	11.9
22/12/2023 23:00	29.01	14.5	418	13.3	173.6	12.3
23/12/2023 00:00	28.85	14.5	416.1	13.2	173.5	12.2
23/12/2023 01:00	29.43	14.5	415.9	13.5	172.6	12.5
23/12/2023 02:00	24.37	14.4	416	11.3	169.9	10.3

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
23/12/2023 03:00	23.34	14.5	415.3	10.7	172	9.9
23/12/2023 04:00	23.54	14.5	414.3	10.8	172.2	10
23/12/2023 05:00	24.81	14.5	413.9	11.4	172.2	10.5
23/12/2023 06:00	24.91	14.5	413.5	11.5	172.1	10.6
23/12/2023 07:00	26.83	14.5	413.3	12.4	172.1	11.4
23/12/2023 08:00	26.16	14.5	414.5	12.1	172.2	11.1
23/12/2023 09:00	25.65	14.5	416.1	11.8	173	10.9
23/12/2023 10:00	25.28	14.6	418.1	11.5	172.4	10.7
23/12/2023 11:00	25.05	14.6	420.5	11.4	173.5	10.6
23/12/2023 12:00	25.7	14.6	422.6	11.6	173.7	10.9
23/12/2023 13:00	25.68	14.6	425.1	11.6	174.1	10.9
23/12/2023 14:00	25.97	14.7	427.7	11.7	174.3	11
23/12/2023 15:00	26.45	14.7	427.7	11.9	174.3	11.2
23/12/2023 16:00	26.72	14.7	427.3	12	174.4	11.3
23/12/2023 17:00	26.97	14.6	426.6	12.2	174	11.4
23/12/2023 18:00	27.42	14.6	422.8	12.4	173.8	11.6
23/12/2023 19:00	27.39	14.6	420.3	12.5	174	11.6
23/12/2023 20:00	26.91	14.6	419	12.3	173.6	11.4
23/12/2023 21:00	27.45	14.6	419.1	12.5	173.2	11.7
23/12/2023 22:00	28.12	14.6	419.3	12.8	173.1	11.9
23/12/2023 23:00	28.57	14.6	418.3	13	173	12.1
24/12/2023 00:00	28.35	14.5	417.5	13	172.8	12
24/12/2023 01:00	27.11	14.5	417.6	12.4	172.8	11.5
24/12/2023 02:00	27.76	14.5	417	12.7	172.7	11.8
24/12/2023 03:00	28.03	14.5	416.6	12.8	172.7	11.9
24/12/2023 04:00	28.26	14.5	416.3	12.9	172.5	12
24/12/2023 05:00	28.16	14.5	416.1	12.9	172.4	12
24/12/2023 06:00	27.91	14.5	415.2	12.8	172.2	11.8
24/12/2023 07:00	27.7	14.5	415.2	12.7	172.2	11.8
24/12/2023 08:00	27.01	14.5	416	12.4	172.5	11.5
24/12/2023 09:00	26.15	14.5	415.9	12	172.5	11.1
24/12/2023 10:00	26.04	14.5	417	11.9	172.5	11.1
24/12/2023 11:00	26.02	14.5	418.6	11.9	172.7	11
24/12/2023 12:00	25.87	14.6	419.2	11.8	172.8	11
24/12/2023 13:00	25.48	14.6	420.8	11.6	172.9	10.8
24/12/2023 14:00	25.58	14.6	420.4	11.7	172.9	10.9
24/12/2023 15:00	25.69	14.6	420.5	11.7	173	10.9
24/12/2023 16:00	26.16	14.6	420	11.9	172.9	11.1
24/12/2023 17:00	26.14	14.5	418.5	12	172.8	11.1
24/12/2023 18:00	26.32	14.5	418.2	12	172.8	11.2
24/12/2023 19:00	26.47	14.5	418.8	12.1	172.9	11.2
24/12/2023 20:00	26.35	14.5	418.6	12.1	173	11.2
24/12/2023 21:00	26.8	14.5	418	12.3	172.8	11.4
24/12/2023 22:00	27.18	14.5	418.1	12.4	172.9	11.5
24/12/2023 23:00	26.8	14.5	417.4	12.3	173.2	11.4
25/12/2023 00:00	26.76	14.5	417.6	12.3	173.3	11.4
25/12/2023 01:00	26.43	14.5	417.2	12.1	173.3	11.2
25/12/2023 02:00	26.34	14.5	416.7	12.1	173	11.2
25/12/2023 03:00	26.95	14.5	417	12.4	173	11.4
25/12/2023 04:00	27	14.5	416.5	12.4	172.9	11.5
25/12/2023 05:00	28.05	14.5	416.7	12.9	172.9	11.9
25/12/2023 06:00	27.78	14.5	415.5	12.8	172.7	11.8
25/12/2023 07:00	27.15	14.5	415.5	12.5	172.8	11.5
25/12/2023 08:00	26.49	14.5	415.7	12.2	173	11.2
25/12/2023 09:00	26.5	14.5	416.7	12.1	173.3	11.2
25/12/2023 10:00	25.85	14.6	418.1	11.8	173.5	11
25/12/2023 11:00	25.66	14.6	420.5	11.7	173.6	10.9
25/12/2023 12:00	25.58	14.6	421.5	11.6	173.8	10.9
25/12/2023 13:00	26.28	14.6	423.9	11.9	174.3	11.2

Site Report - GPSC CUP2 HRSG1						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
25/12/2023 14:00	27.05	14.6	427.9	12.2	174.6	11.5
25/12/2023 15:00	27.52	14.7	429.4	12.4	174.7	11.7
25/12/2023 16:00	27.36	14.7	428.8	12.3	174.8	11.6
25/12/2023 17:00	27.32	14.6	427.9	12.3	174.7	11.6
25/12/2023 18:00	28.48	14.6	423.3	12.9	174.6	12.1
25/12/2023 19:00	28.62	14.6	421.1	13	173.9	12.1
25/12/2023 20:00	29.96	14.6	419.7	13.6	173.6	12.7
25/12/2023 21:00	27.03	14.6	420.2	12.3	173.7	11.5
25/12/2023 22:00	25.27	14.6	419.3	11.5	173.5	10.7
25/12/2023 23:00	25.41	14.6	419.1	11.6	173.6	10.8
26/12/2023 00:00	25.22	14.6	417.9	11.5	173.6	10.7
26/12/2023 01:00	25.18	14.5	417.7	11.5	173.6	10.7
26/12/2023 02:00	25.71	14.5	417.3	11.8	173.4	10.9
26/12/2023 03:00	25.48	14.5	416.4	11.7	173.4	10.8
26/12/2023 04:00	25.5	14.5	415.7	11.7	173.1	10.8
26/12/2023 05:00	25.75	14.5	415.5	11.8	173.4	10.9
26/12/2023 06:00	26.36	14.5	415.4	12.1	173	11.2
26/12/2023 07:00	26.29	14.5	415.6	12.1	172.7	11.2
26/12/2023 08:00	26.06	14.5	416.7	11.9	173	11.1
26/12/2023 09:00	25.91	14.6	418.3	11.8	173.3	11
26/12/2023 10:00	25.82	14.6	421.4	11.7	173.6	11
26/12/2023 11:00	25.43	14.6	423.3	11.5	174.1	10.8
26/12/2023 12:00	25.54	14.6	429	11.5	174.8	10.8
26/12/2023 13:00	25.22	14.7	427.2	11.3	174.8	10.7
26/12/2023 14:00	25.15	14.7	426.8	11.3	174.7	10.7
26/12/2023 15:00	25.22	14.7	426	11.3	174.6	10.7
26/12/2023 16:00	26.02	14.7	426.8	11.7	174.6	1

Site Report - GPSC CUP2 HRS G1						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
30/12/2023 12:00	25.95	14.7	416.2	11.6	173.8	11
30/12/2023 13:00	25.12	14.7	414.8	11.2	173.9	10.7
30/12/2023 14:00	24.35	14.7	413.5	10.9	173.2	10.3
30/12/2023 15:00	24.62	14.7	414.6	11	173.3	10.4
30/12/2023 16:00	24.09	14.6	415.6	10.8	173.4	10.2
30/12/2023 17:00	25.38	14.6	419.1	11.4	173.7	10.8
30/12/2023 18:00	26.5	14.6	421.6	12	174.2	11.2
30/12/2023 19:00	27.22	14.6	424.2	12.3	174.5	11.6
30/12/2023 20:00	27.73	14.6	426.8	12.6	175.1	11.8
30/12/2023 21:00	27.49	14.6	426.9	12.5	175.1	11.7
30/12/2023 22:00	27.58	14.6	424.7	12.6	174.9	11.7
30/12/2023 23:00	29.04	14.6	427.4	13.2	175	12.3
31/12/2023 00:00	29.57	14.6	426.2	13.5	174.8	12.6
31/12/2023 01:00	27.83	14.6	425.2	12.7	174.6	11.8
31/12/2023 02:00	28.01	14.6	426.3	12.7	174.7	11.9
31/12/2023 03:00	28.47	14.6	426.4	12.9	174.8	12.1
31/12/2023 04:00	28.94	14.6	423.5	13.2	174.1	12.3
31/12/2023 05:00	29.17	14.6	423.9	13.3	174.2	12.4
31/12/2023 06:00	29.96	14.6	423.5	13.7	174.1	12.7
31/12/2023 07:00	29.73	14.6	425.1	13.5	174.3	12.6
31/12/2023 08:00	27.31	14.6	426.1	12.4	174.7	11.6
31/12/2023 09:00	26.26	14.6	422.8	11.8	174.4	11.1
31/12/2023 10:00	24.73	14.7	420	11.1	174.1	10.5
31/12/2023 11:00	24.15	14.7	417.7	10.8	173.7	10.3
31/12/2023 12:00	22.48	14.7	417	10.1	174.3	9.5
31/12/2023 13:00	22.33	14.7	416	10	173.9	9.5
31/12/2023 14:00	19.55	14.6	414.6	8.8	173.6	8.3
31/12/2023 15:00	20.09	14.6	415.9	9.1	173.4	8.5
31/12/2023 16:00	21.77	14.6	417.2	9.8	173.5	9.2
31/12/2023 17:00	23.52	14.7	418.2	10.6	173.9	10
31/12/2023 18:00	25.98	14.7	422.2	11.7	174.2	11
31/12/2023 19:00	25.49	14.6	425	11.5	175	10.8
31/12/2023 20:00	25.01	14.6	428.6	11.3	175.2	10.6
31/12/2023 21:00	24.21	14.6	427.4	11	175.4	10.3
31/12/2023 22:00	25.52	14.6	425	11.6	175	10.8
31/12/2023 23:00	26.41	14.6	423.3	12.1	174.8	11.2
Minimum	8.69	12.5	331.2	3.3	134.9	3.7
MinDate	17/12/2023 10:00	11/12/2023 23:00	17/12/2023 15:00	17/12/2023 10:00	12/12/2023 00:00	17/12/2023 10:00
Maximum	35.2	15.6	429.7	16.2	184.9	14.9
MaxDate	07/12/2023 03:00	17/12/2023 05:00	22/12/2023 16:00	07/12/2023 03:00	17/12/2023 06:00	07/12/2023 03:00
Avg	24.83	14.4	413.5	11.6	169.8	10.5
Num	731	731	731	731	744	731
Data[%]	98.3	98.3	98.3	98.3	100	98.3
STD	3.9	0.5	21	1.6	10.7	1.7

Site Report - GPSC CUP2 HRSQ2							
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2	
	ppm	%Vol	km3/h	ppm	Deg C	ppm	ppm
01/07/2023 00:00	21.56	14.2	430.9	10.4	164.7	9.1	
01/07/2023 01:00	21.36	14.2	429.8	10.3	164.5	9.1	
01/07/2023 02:00	20.32	14.2	423.6	9.9	164.4	8.6	
01/07/2023 03:00	21.86	14.2	421.9	10.6	165.5	9.3	
01/07/2023 04:00	21.52	14.1	419.6	10.5	166.3	9.1	
01/07/2023 05:00	21.67	14.1	418.7	10.5	166.5	9.2	
01/07/2023 06:00	21.39	14.1	419.5	10.4	166.8	9.1	
01/07/2023 07:00	22.3	14.2	425.5	10.8	165.9	9.5	
01/07/2023 08:00	23.51	14.2	431	11.3	166.5	10	
01/07/2023 09:00	23.11	14.2	429.6	11.1	166.5	9.8	
01/07/2023 10:00	23.25	14.2	429.8	11.2	166.4	9.9	
01/07/2023 11:00	23.82	14.2	430.9	11.4	166.6	10.1	
01/07/2023 12:00	23.11	14.2	430.1	11.1	165.6	9.8	
01/07/2023 13:00	22.91	14.2	430.5	11	165.3	9.7	
01/07/2023 14:00	23.62	14.2	430.6	11.4	165.4	10	
01/07/2023 15:00	23.72	14.2	431.1	11.4	165.4	10.1	
01/07/2023 16:00	23.58	14.2	431.4	11.3	165.3	10	
01/07/2023 17:00	24.03	14.2	431.1	11.5	165.1	10.2	
01/07/2023 18:00	24.29	14.2	430.8	11.7	165.2	10.3	
01/07/2023 19:00	23.92	14.2	430.7	11.5	165.3	10.2	
01/07/2023 20:00	23.48	14.2	429.5	11.3	165.4	10	
01/07/2023 21:00	23.95	14.2	429.7	11.5	165.7	10.2	
01/07/2023 22:00	24.18	14.2	429.7	11.8	165.7	10.3	
01/07/2023 23:00	23.58	14.2	430.2	11.3	165.6	10	
02/07/2023 00:00	22.69	14.2	430.2	10.9	165.6	9.6	
02/07/2023 01:00	23.29	14.2	427.1	11.2	165.7	9.9	
02/07/2023 02:00	23.7	14.2	427	11.4	165.6	10.1	
02/07/2023 03:00	23.71	14.2	426.1	11.4	165	10.1	
02/07/2023 04:00	24.16	14.2	426.4	11.6	165.2	10.3	
02/07/2023 05:00	24.32	14.2	426.2	11.7	165.2	10.3	
02/07/2023 06:00	24.19	14.2	426.5	11.7	165.3	10.3	
02/07/2023 07:00	24.21	14.2	427.2	11.6	165.6	10.3	
02/07/2023 08:00	24.74	14.2	430.1	11.9	165.6	10.5	
02/07/2023 09:00	24.94	14.2	430.6	11.9	165.4	10.6	
02/07/2023 10:00	23.7	14.2	429.4	11.4	165	10.1	
02/07/2023 11:00	22.95	14.2	428.5	11	164.2	9.7	
02/07/2023 12:00	22.87	14.2	427.3	11	163.4	9.7	
02/07/2023 13:00	22.25	14.2	426.8	10.7	163.4	9.4	
02/07/2023 14:00	22.16	14.2	426.7	10.7	163	9.4	
02/07/2023 15:00	22.49	14.2	427.9	10.8	163.1	9.5	
02/07/2023 16:00	22.4	14.2	429.6	10.8	163.9	9.5	
02/07/2023 17:00	23.43	14.2	431.4	11.3	164.3	9.9	
02/07/2023 18:00	23.99	14.2	431.3	11.5	164.7	10.2	
02/07/2023 19:00	23.37	14.2	429.2	11.2	164.8	9.9	
02/07/2023 20:00	24.86	14.2	432.3	11.9	165.4	10.6	
02/07/2023 21:00	26.83	14.3	436	12.8	166.5	11.4	
02/07/2023 22:00	24.17	14.2	431.5	11.6	166.5	10.3	
02/07/2023 23:00	25.1	14.3	434.7	12	166.9	10.7	
03/07/2023 00:00	25.34	14.3	432	12.1	166.1	10.8	
03/07/2023 01:00	23.92	14.2	426.4	11.5	164.8	10.2	
03/07/2023 02:00	24.6	14.2	427.6	11.8	164.8	10.4	
03/07/2023 03:00	24.87	14.2	428.6	11.9	165.1	10.6	
03/07/2023 04:00	24.51	14.2	427.8	11.8	165	10.4	
03/07/2023 05:00	24.22	14.2	427.8	11.6	164.9	10.3	
03/07/2023 06:00	23.68	14.2	428.9	11.4	164.7	10	
03/07/2023 07:00	24.53	14.2	428.1	11.8	165	10.5	
03/07/2023 08:00	25	14.3	431.6	12	165.4	10.6	
03/07/2023 09:00	24.85	14.3	431	11.9	164.7	10.5	
03/07/2023 10:00	25.45	14.3	432.1	12.2	164.7	10.8	
03/07/2023 11:00	25.64	14.3	431.6	12.3	164.8	10.9	
03/07/2023 12:00	25.78	14.2	430.8	12.3	164.8	10.9	
03/07/2023 13:00	25.92	14.3	430.5	12.4	164.5	11	
03/07/2023 14:00	27.14	14.2	434.4	13	165.4	11.4	
03/07/2023 15:00	27.17	14.2	432.8	13	165	11.5	
03/07/2023 16:00	26.94	14.2	431.8	12.9	165.4	11.4	
03/07/2023 17:00	26.87	14.2	432.6	12.9	165.5	11.4	
03/07/2023 18:00	26.53	14.2	428.6	12.7	165	11.3	

Site Report - GPSC CUP2 HRSQ2							
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2	
	ppm	%Vol	km3/h	ppm	Deg C	ppm	ppm
03/07/2023 19:00	24.67	14.2	421.2	11.9	165.3	10.5	
03/07/2023 20:00	26.64	14.3	437.1	12.7	167.8	11.3	
03/07/2023 21:00	26.65	14.3	439.7	12.7	169.2	11.3	
03/07/2023 22:00	25.21	14.2	434.6	12.1	168.6	10.7	
03/07/2023 23:00	22.64	14.2	421	11	166.8	9.6	
04/07/2023 00:00	21.61	14.1	419.6	10.5	166.4	9.2	
04/07/2023 01:00	21.1	14.1	418.1	10.3	166.3	9	
04/07/2023 02:00	21.42	14.1	420	10.4	166.1	9.1	
04/07/2023 03:00	21.3	14.1	420.8	10.4	166	9	
04/07/2023 04:00	21.6	14.1	421.4	10.5	165.8	9.2	
04/07/2023 05:00	22.1	14.2	424.4	10.7	165.8	9.4	
04/07/2023 06:00	21.44	14.1	422.2	10.4	165.7	9.1	
04/07/2023 07:00	21.87	14.2	424.6	10.6	165.9	9.3	
04/07/2023 08:00	25.64	14.2	431.5	12.3	165.9	10.9	
04/07/2023 09:00	26.42	14.2	430.1	12.6	165.1	11.2	
04/07/2023 10:00	26.49	14.2	429.5	12.7	164.9	11.2	
04/07/2023 11:00	27.05	14.3	429.6	12.9	164.6	11.5	
04/07/2023 12:00	27.36	14.3	428.3	13.1	164	11.6	
04/07/2023 13:00	27.74	14.3	427.9	13.3	163.7	11.8	
04/07/2023 14:00	28.03	14.3	428.7	13.4	164	11.9	
04/07/2023 15:00	26.84	14.2	430.1	12.8	164.7	11.4	
04/07/2023 16:00	26.06	14.2	429.3	12.5	164.4	11.1	
04/07/2023 17:00	26.19	14.2	429.7	12.5	164.7	11.1	
04/07/2023 18:00	25.2	14.2	431.1	12.5	165.1	11.2	
04/07/2023 19:00	25.96	14.2	431.5	12.4	165.5	11	
04/07/2023 20:00	25.18	14.2	431.9	12.1	165.8	10.7	
04/07/2023 21:00	24.42	14.2	428.9	11.7	166	10.4	
04/07/2023 22:00	23.1	14.2	422.1	11.2	165.8	9.8	
05/07/2023 00:00	22.53	14.1	420.9	10.9	165.9	9.6	
05/07/2023 01:00	22.05	14.1	421.1	10.7	165.9	9.4	
05/07/2023 02:00	23.21	14.2	428.4	11.2	165.1	10.9	
05/07/2023 03:00	23.09	14.2	425.9	11.2	165.6	9.8	
05/07/2023 04:00	21.82	14.1	421	10.8	165.7	9.3	
05/07/2023 05:00	21.65	14.1	419.7	10.6	165.6	9.2	
05/07/2023 06:00	21.84	14.1	419.7	10.6	165.9	9.3	
05/07/2023 07:00	21.86	14.1	418	10.7	166.1	9.3	
05/07/2023 08:00	22.34	14.1	420.6	10.9	166.2	9.5	
05/07/2023 09:00	25.09	14.2	430.3	12.1	166.1	10.6	
05/07/2023 10:00	26.64	14.2	430.5	12.7	166	11.3	
05/07/2023 11:00	26.47	14.2	428.4	12.7	164.8	11.2	
05/07/2023 12:00	26.18	14.2	425.2	12.6	163.4	11.1	
05/07/2023 13:00	25.62	14.2	423.7	12.3	162.8	10.9	
05/07/2023 14:00	26.93	14.2	424.1	12.9	162.7	11.4	
05/07/2023 15:00	27.14	14.2	425	13	162.7	11.5	
05/07/2023 16:00	26.5	14.2	425	12.7	162.8	11.3	
05/07/2023 17:00	27.17	14.2	426.9	13	163.3	11.5	
05/07/2023 18:00	27.8	14.2	428.4	13.3	164.1	11.8	
05/07/2023 19:00	28.05	14.2	430.3	13.4	164.6	11.9	
05/07/2023 20:00	26.18	14.2	427.4	12.6	164.6	11.1	
05/07/2023 21:00	26.9	14.2	435.5	12.9	166.5	11.4	
05/07/2023 22:00	27.51	14.3	439.2	13.1	166.3	11.7	
05/07/2023 23:00	27.23	14.3	438.3	13	168.4	11.6	
06/07/2023 00:00	27.49	14.3	438.8	13.1	168.8	11.7	
06/07/2023 01:00	27.17	14.2	437	13	168.7	11.5	
06/07/2023 02:00	26.88	14.2	437.6	12.8	168.6	11.4	
06/07/2023 03:00	26.84	14.2	438	12.9	168.6	11.4	
06/07/2023 04:00	27.46	14.3	439.7	13.1	168.7	11.7	
06/07/2023 05:00	27.37	14.2	435.7	13.1	168.8	11.6	
06/07/2023 06:00	27.38	14.2	436.1	13.1	168.6	11.6	
06/07/2023 07:00	28.1	14.3	437.2	13.4	168.8	11.9	
06/07/2023 08:00	28.06	14.3	438.8	13.4	168.8	11.9	
06/07/2023 09:00	24.81	14.3	435.6	11.8	168	10.5	
06/07/2023 10:00	24.81	14.3	434.2	11.8	167.1	10.5	
06/07/2023 11:00	25.18	14.3	431	12	166	10.7	
06/07/2023 12:00	24.68	14.3	429	11.8	165.3	10.5	
06/07/2023 13:00	22.74	14.2	425.9	10.9	163.9	9.7	
06/07/2023 14:00	21.26	14.2	424.7	10.2	163.1	9	

Site Report - GPSC CUP2 HRSQ2							
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2	
	ppm	%Vol	km3/h	ppm	Deg C	ppm	
06/07/2023 14:00	21.19	14.2	424	10.2	162.8	9	
06/07/2023 15:00	21.29	14.2	424.6	10.3	162.9	9	
06/07/2023 16:00	20.56	14.2	425.3	9.9	162.9	8.7	
06/07/2023 17:00	18.81	14.1	425.5	9.2	160.9	8	
06/07/2023 18:00	20.99	14.2	428.3	10.2	162.3	8.9	
06/07/2023 19:00	22.64	14.2	433.1	10.9	166.8	9.6	
06/07/2023 20:00	23.01	14.2	432.3	11	165.4	9.8	
06/07/2023 21:00	22.93	14.2	432.2	11	165.8	9.7	
06/07/2023 22:00	21.93	14.2	432.5	10.5	166	9.3	
06/07/2023 23:00	21.72	14.2	434.3	10.4	166.5	9.2	
07/07/2023 00:00	24.05	14.2	435.3	11.5	166.9	10.2	
07/07/2023 01:00	25.15	14.2	437.2	12	167.7	10.7	
07/07/2023 02:00	25.62	14.2	437.5	12.3	168.4	10.9	
07/07/2023 03:00	26.97	14.3	438.5	12.4	168.4	11.1	
07/07/2023 04:00	26.07	14.3	438.8	12.5	168.5	11.1	
07/07/2023 05:00	26.54	14.3	439.2	12.7	168.5	11.3	
07/07/2023 06:00	26.49	14.3	437.9	12.7	168.7	11.2	
07/07/2023 07:00	25.41	14.2	434.9	12.2	167.9	10.8	
07/07/2023 08:00	25.09	14.3	433.7	12	167.6	10.7	
07/07/2023 09:00	24.81	14.3	432.3	11.9	167.3	10.5	
07/07/2023 10:00	24.37	14.2	428.6	11.7	165.9	10.3	
07/07/2023 11:00	23.86	14.2	428.5	11.4	164.4	9.7	
07/07/2023 12:00	21.97	14.2	427.7	10.6	164	9.3	
07/07/2023 13:00	25.19	14.2	433.3	12.1	166	10.7	
07/07/2023 14:00	22.81	14.2	430.9	11	165.7	9.7	
07/07/2023 15:00	23.06	14.2	431.4	11.1	165.8	9.8	
07/07/2023 16:00	23.28	14.2	434.2	11.2	167.4	9.9	
07/07/2023 17:00	22.7	14.2	430.2	10.9	165.4	9.6	
07/07/2023 18:00	23.16	14.2	430.4	11.2	165.1	9.8	
07/07/2023 19:00	23.52	14.2	431.6	11.3	165.3	10	
07/07/2023 20:00	24.02	14.2	431.5	11.5	166.5	10.1	
07/07/2023 21:00	23.91	14.2	432.8	11.5	165.7	10.2	
07/07/2023 22:00	24.39	14.2	432.9	11.7	165.9	10.4	
07/07/2023 23:00	24.29	14.2	433.6	11.7	166	10.3	
08/07/2023 00:00	24.29	14.2	433.9	11.7	166.3	10.3	
08/07/2023 01:00	24.6	14.2	433.8	11.8	166.3	10.4	
08/07/2023 02:00	24.73	14.2	434	11.9	166.5	10.5	
08/07/2023 03:00	24.93	14.2	437.5	12	168	10.6	
08/07/2023 04:00	25.09	14.2	437.5	12.2	168.3	10.8	
08/07/2023 05:00	19.11	14.4	424.8	9.4	161.9	8.1	
08/07/2023 06:00	14.54	13.9	414.4	7.3	158	6.2	
08/07/2023 07:00	22.94	14.2	436.6	11	167.9	9.7	
08/07/2023 08:00	23.33	14.3	439.3	11.1	169.7	9.9	
08/07/2023 09:00	22.87	14.3	439.4	10.9	169.8	9.7	
08/07/2023 10:00	22.55	14.3	438	10.8	169.3	9.6	
08/07/2023 11:00	21.74	14.2	433.8	10.4	167.5	9.2	
08/07/2023 12:00	21.61	14.1	432.5	10.5	167.4	9.1	
08/07/2023 13:00	17.29	13.9	426.9	8.6	158.7	7.3	
08/07/2023 14:00	20.95	13.7	432.1	10.9	157.3	8.9	
08/07/2023 15:00	21.38	13.7	438.1	11	153.2	9.1	
08/07/2023 16:00	22.41	14.2	435	10.7	167.5	9.5	
08/07/2023 17:00	21.93	14.2	433.6	10.1	166.7	9	
08/07/2023 18:00	21.05	14.2	433.6	10.1	166.6	8.9	
08/07/2023 19:00	21.74	14.2	434.9	10.5	166.4	9.2	
08/07/2023 20:00	22.36	14.2	434.9	10.7	166.7	9.5	
08/07/2023 21:00	22.62	14.2	435.3	10.9	166.8	9.6	
08/07/2023 22:00	22.74	14.2	434.9	10.9	166.5	9.7	
08/07/2023 23:00	23.07	14.2	435.2	11.1	166.6	9.8	
09/07/2023 00:00	22.8	14.2	435	10.9	166.9	9.7	
09/07/2023 01:00	22.69	14.2	436.4	10.9	167.4	9.6	
09/07/2023 02:00	23.01	14.2	439.1	11	168.8	9.8	
09/07/2023 03:00	23.22	14.3	440.8	11.1	169.3	9.9	
09/07/2023 04:00	23.21	14.2	439.7	11.1	169.1	9.8	
09/07/2023 05:00	23.21	14.2	438.4	11.1	168.9	9.8	
09/07/2023 06:00	23.72	14.2	438.9	11.4	169.2	10.1	
09/07/2023 07:00	23.8	14.3	439.7	11.4	169.2	10.1	
09/07/2023 08:00	22.69	14.2	438.5	10.9	168.9	9.6	

Site Report - GPSC CUP2 HRSG2							
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2	
	ppm	%Vol	km3/h	ppm	Deg C	ppm	
12/07/2023 04:00	23.27	14.2	427.1	11.3	167	9.9	
12/07/2023 05:00	23.9	14.2	427.1	11.5	167.5	10.1	
12/07/2023 06:00	24.24	14.2	428.6	11.7	167.4	10.3	
12/07/2023 07:00	25.14	14.2	432.4	12.1	167.6	10.7	
12/07/2023 08:00	<Samp	<Samp	<Samp	<Samp	167.1	<Samp	
12/07/2023 09:00	Maintain	Maintain	Alarm	Maintain	184.2	Maintain	
12/07/2023 10:00	Maintain	Maintain	Alarm	Maintain	108.5	Maintain	
12/07/2023 11:00	Maintain	Maintain	Alarm	Maintain	80.4	Maintain	
12/07/2023 12:00	Maintain	Maintain	Alarm	Maintain	69	Maintain	
12/07/2023 13:00	Maintain	Maintain	Alarm	Maintain	67	Maintain	
12/07/2023 14:00	Maintain	Maintain	Alarm	Maintain	65.2	Maintain	
12/07/2023 15:00	Maintain	Maintain	Alarm	Maintain	62.3	Maintain	
12/07/2023 16:00	Maintain	Maintain	Alarm	Maintain	58.9	Maintain	
12/07/2023 17:00	<Samp	<Samp	<Samp	<Samp	56.4	<Samp	
12/07/2023 18:00	102.15	20.8	0	0.5	53.6	43.4	
12/07/2023 19:00	108.89	20.8	0	0.5	50	46.2	
12/07/2023 20:00	114.01	20.8	0	0.6	50.1	48.4	
12/07/2023 21:00	115.87	20.8	0	0.6	50.2	49.2	
12/07/2023 22:00	114.91	20.8	0	0.5	49.1	48.8	
12/07/2023 23:00	117.1	20.8	0	0.5	48.2	49.7	
13/07/2023 00:00	114.64	20.8	0	0.5	48.2	48.7	
13/07/2023 01:00	105.69	20.8	0	0.5	44.4	45.3	
13/07/2023 02:00	105.67	20.8	0	0.5	44.2	44.9	
13/07/2023 03:00	102.89	20.8	0	0.5	44.6	43.8	
13/07/2023 04:00	103.84	20.8	0	0.5	44.1	44.1	
13/07/2023 05:00	110.19	20.8	0	0.5	43.7	46.8	
13/07/2023 06:00	109.19	20.8	0	0.5	43.1	46.3	
13/07/2023 07:00	107.76	20.8	0	0.5	43.4	45.7	
13/07/2023 08:00	114.86	20.8	0	0.5	43.9	48.8	
13/07/2023 09:00	127.56	20.8	0	0.6	45.9	54.1	
13/07/2023 10:00	114.09	20.8	0	0.5	48.8	48.4	
13/07/2023 11:00	112.12	20.8	0	0.5	46.6	47.6	
13/07/2023 12:00	108.38	20.8	0	0.5	44.2	46	
13/07/2023 13:00	119.17	20.8	0	0.5	42	50.6	
13/07/2023 14:00	110.98	20.8	0	0.5	40.4	47.1	
13/07/2023 15:00	116.94	20.8	0	0.5	39.1	49.6	
13/07/2023 16:00	105.85	20.8	0	0.5	37.9	44.9	
13/07/2023 17:00	109.21	20.8	0	0.5	36.8	46.4	
13/07/2023 18:00	116.87	20.8	0	0.5	35.9	49.6	
13/07/2023 19:00	120.3	20.8	0	0.5	35	51.1	
13/07/2023 20:00	120.06	20.8	0	0.5	34.2	51	
13/07/2023 21:00	119.1	20.8	0	0.5	33.7	50.6	
13/07/2023 22:00	117.94	20.8	0	0.5	33.4	50.1	
13/07/2023 23:00	122.12	20.8	0	0.5	33	51.8	
14/07/2023 00:00	118.41	20.8	0	0.5	32.7	50.3	
14/07/2023 01:00	115.2	20.8	0	0.5	32.4	48.9	
14/07/2023 02:00	107.18	20.8	0	0.5	32.1	45.5	
14/07/2023 03:00	101.27	20.8	0	0.4	31.4	43	
14/07/2023 04:00	98.7	20.8	0	0.4	31.1	41.9	
14/07/2023 05:00	104.77	20.8	0	0.5	30.8	44.5	
14/07/2023 06:00	107.63	20.8	0	0.5	30.6	45.7	
14/07/2023 07:00	102.75	20.8	0	0.5	30.7	43.6	
14/07/2023 08:00	112.67	20.8	0	0.5	31.7	47.8	
14/07/2023 09:00	129.71	20.8	0	0.5	32.4	55.1	
14/07/2023 10:00	136.43	20.8	0	0.6	32.1	58.8	
14/07/2023 11:00	124.56	20.8	0	0.6	33.4	52.9	
14/07/2023 12:00	114.99	20.8	0	0.5	33.1	48.8	
14/07/2023 13:00	126.08	20.8	0	0.5	32.9	53.5	
14/07/2023 14:00	126.52	20.8	0	0.6	15.4	54.6	
14/07/2023 15:00	<Samp	<Samp	<Samp	<Samp	0	<Samp	
14/07/2023 16:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
14/07/2023 17:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
14/07/2023 18:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
14/07/2023 19:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
14/07/2023 20:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
14/07/2023 21:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
14/07/2023 22:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	

Site Report - GPSC CUP2 HRSG2							
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2	
	ppm	%Vol	km3/h	ppm	Deg C	ppm	
14/07/2023 23:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
15/07/2023 00:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
15/07/2023 01:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
15/07/2023 02:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
15/07/2023 03:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
15/07/2023 04:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
15/07/2023 05:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
15/07/2023 06:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
15/07/2023 07:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
15/07/2023 08:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
15/07/2023 09:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
15/07/2023 10:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
15/07/2023 11:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
15/07/2023 12:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
15/07/2023 13:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
15/07/2023 14:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
15/07/2023 15:00	Shutdown	Shutdown	Alarm	Shutdown	0	Shutdown	
15/07/2023 16:00	Shutdown	Shutdown	Alarm	Shutdown	20.3	Shutdown	
15/07/2023 17:00	Shutdown	Shutdown	Alarm	Shutdown	33.4	Shutdown	
15/07/2023 18:00	Shutdown	Shutdown	Alarm	Shutdown	33.2	Shutdown	
15/07/2023 19:00	Shutdown	Shutdown	Alarm	Shutdown	32.8	Shutdown	
15/07/2023 20:00	Shutdown	Shutdown	Alarm	Shutdown	32.6	Shutdown	
15/07/2023 21:00	Shutdown	Shutdown	Alarm	Shutdown	32.4	Shutdown	
15/07/2023 22:00	Shutdown	Shutdown	Alarm	Shutdown	32.1	Shutdown	
15/07/2023 23:00	Shutdown	Shutdown	Alarm	Shutdown	32.1	Shutdown	
16/07/2023 00:00	Shutdown	Shutdown	Alarm	Shutdown	31.6	Shutdown	
16/07/2023 01:00	Shutdown	Shutdown	Alarm	Shutdown	31.1	Shutdown	
16/07/2023 02:00	Shutdown	Shutdown	Alarm	Shutdown	30.7	Shutdown	
16/07/2023 03:00	Shutdown	Shutdown	Alarm	Shutdown	30.2	Shutdown	
16/07/2023 04:00	Shutdown	Shutdown	Alarm	Shutdown	29.9	Shutdown	
16/07/2023 05:00	Shutdown	Shutdown	Alarm	Shutdown	29.7	Shutdown	
16/07/2023 06:00	Shutdown	Shutdown	Alarm	Shutdown	29.6	Shutdown	
16/07/2023 07:00	Shutdown	Shutdown	Alarm	Shutdown	29.7	Shutdown	
16/07/2023 08:00	Shutdown	Shutdown	Alarm	Shutdown	30.5	Shutdown	
16/07/2023 09:00	Shutdown	Shutdown	Alarm	Shutdown	31.3	Shutdown	
16/07/2023 10:00	Shutdown	Shutdown	Alarm	Shutdown	31.6	Shutdown	
16/07/2023 11:00	Shutdown	Shutdown	Alarm	Shutdown	32.1	Shutdown	
16/07/2023 12:00	Shutdown	Shutdown	Alarm	Shutdown	32.4	Shutdown	
16/07/2023 13:00	Shutdown	Shutdown	Alarm	Shutdown	32.5	Shutdown	
16/07/2023 14:00	Shutdown	Shutdown	Alarm	Shutdown	32.7	Shutdown	
16/07/2023 15:00	Shutdown	Shutdown	Alarm	Shutdown	32.8	Shutdown	
16/07/2023 16:00	Shutdown	Shutdown	Alarm	Shutdown	33.1	Shutdown	
16/07/2023 17:00	Shutdown	Shutdown	Alarm	Shutdown	33.2	Shutdown	
16/07/2023 18:00	Shutdown	Shutdown	Alarm	Shutdown	32.9	Shutdown	
16/07/2023 19:00	Shutdown	Shutdown	Alarm	Shutdown	32.6	Shutdown	
16/07/2023 20:00	Shutdown	Shutdown	Alarm	Shutdown	32.4	Shutdown	
16/07/2023 21:00	Shutdown	Shutdown	Alarm	Shutdown	31.5	Shutdown	
16/07/2023 22:00	Shutdown	Shutdown	Alarm	Shutdown	31.5	Shutdown	
16/07/2023 23:00	Shutdown	Shutdown	Alarm	Shutdown	31.2	Shutdown	
17/07/2023 00:00	Shutdown	Shutdown	Alarm	Shutdown	30.8	Shutdown	
17/07/2023 01:00	Shutdown	Shutdown	Alarm	Shutdown	30.3	Shutdown	
17/07/2023 02:00	Shutdown	Shutdown	Alarm	Shutdown	30	Shutdown	
17/07/2023 03:00	Shutdown	Shutdown	Alarm	Shutdown	29.8	Shutdown	
17/07/2023 04:00	Shutdown	Shutdown	Alarm	Shutdown	29.6	Shutdown	
17/07/2023 05:00	Shutdown	Shutdown	Alarm	Shutdown	29.3	Shutdown	
17/07/2023 06:00	Shutdown	Shutdown	Alarm	Shutdown	29.3	Shutdown	
17/07/2023 07:00	Shutdown	Shutdown	Alarm	Shutdown	29.6	Shutdown	
17/07/2023 08:00	Shutdown	Shutdown	Alarm	Shutdown	29.6	Shutdown	
17/07/2023 09:00	Shutdown	Shutdown	Alarm	Shutdown	30	Shutdown	
17/07/2023 10:00	Shutdown	Shutdown	Alarm	Shutdown	30.2	Shutdown	
17/07/2023 11:00	Shutdown	Shutdown	Alarm	Shutdown	30.6	Shutdown	
17/07/2023 12:00	Shutdown	Shutdown	Alarm	Shutdown	31.2	Shutdown	
17/07/2023 13:00	Shutdown	Shutdown	Alarm	Shutdown	31.5	Shutdown	
17/07/2023 14:00	Shutdown	Shutdown	Alarm	Shutdown	31.9	Shutdown	
17/07/2023 15:00	Shutdown	Shutdown	Alarm	Shutdown	34.7	Shutdown	
17/07/2023 16:00	Shutdown	Shutdown	Alarm	Shutdown	32.8	Shutdown	
17/07/2023 17:00	Shutdown	Shutdown	Alarm	Shutdown	32.7	Shutdown	

Site Report - GPSC CUP2 HRSG2							
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2	
	ppm	%Vol	km3/h	ppm	Deg C	ppm	
17/07/2023 18:00	Shutdown	Shutdown	Alarm	Shutdown	32.4	Shutdown	
17/07/2023 19:00	Shutdown	Shutdown	Alarm	Shutdown	32	Shutdown	
17/07/2023 20:00	Shutdown	Shutdown	Alarm	Shutdown	31.8	Shutdown	
17/07/2023 21:00	Shutdown	Shutdown	Alarm	Shutdown	31.5	Shutdown	
17/07/2023 22:00	Shutdown	Shutdown	Alarm	Shutdown	31.2	Shutdown	
17/07/2023 23:00	Shutdown	Shutdown	Alarm	Shutdown	30.9	Shutdown	
18/07/2023 00:00	Shutdown	Shutdown	<Samp	Shutdown	30.8	Shutdown	
18/07/2023 01:00	725.57	20.8	0	0.5	30.4	53.3	
18/07/2023 02:00	114.61	20.8	0	0.5	30.2	48.6	
18/07/2023 03:00	113.96	20.8	0	0.5	30	48.4	
18/07/2023 04:00	110.05	20.8	0	0.5	29.7	46.7	
18/07/2023 05:00	118.62	20.8	0	0.5	29.5	50.4	
18/07/2023 06:00	115.22	20.8	0	0.5	29.2	48.9	
18/07/2023 07:00	114.21	20.8	0	0.5	29.5	48.5	
18/07/2023 08:00	116.73	20.8	0	0.5	30.1	49.5	
18/07/2023 09:00	131.16	20.8	0	0.6	31	55.7	
18/07/2023 10:00	Shutdown	Shutdown	<Samp	Shutdown	31.8	Shutdown	
18/07/2023 11:00	Shutdown	Shutdown	Alarm	Shutdown	31.6	Shutdown	
18/07/2023 12:00	Shutdown	Shutdown	Alarm	Shutdown	31.4	Shutdown	
18/07/2023 13:00	Shutdown	Shutdown	Alarm	Shutdown	31.7	Shutdown	
18/07/2023 14:00	Shutdown	Shutdown	Alarm	Shutdown	31.7	Shutdown	
18/07/2023 15:00	Shutdown	Shutdown	Alarm	Shutdown	31.8	Shutdown	
18/07/2023 16:00	Shutdown	Shutdown	Alarm	Shutdown	31.8	Shutdown	
18/07/2023 17:00	Shutdown	Shutdown	Alarm	Shutdown	31.6	Shutdown	
18/07/2023 18:00	Shutdown	Shutdown	Alarm	Shutdown	31.3	Shutdown	
18/07/2023 19:00	Shutdown	Shutdown	Alarm	Shutdown	31	Shutdown	
18/07/2023 20:00	Shutdown	Shutdown	Alarm	Shutdown	30.8	Shutdown	
18/07/2023 21:00	Shutdown	Shutdown	Alarm	Shutdown	30.7	Shutdown	
18/07/2023 22:00	Shutdown	Shutdown	Alarm	Shutdown	30.6	Shutdown	
18/07/2023 23:00	Shutdown	Shutdown	Alarm	Shutdown	30.5	Shutdown	
19/07/2023 00:00	Shutdown	Shutdown	Alarm	Shutdown	30.2	Shutdown	
19/07/2023 01:00	Shutdown	Shutdown	Alarm	Shutdown	30	Shutdown	
19/07/2023 02:00	Shutdown	Shutdown	Alarm	Shutdown	29.9	Shutdown	
19/07/2023 03:00	Shutdown	Shutdown	Alarm	Shutdown	29.6	Shutdown	
19/07/2023 04:00	Shutdown	Shutdown	Alarm	Shutdown	29.5	Shutdown	
19/07/2023 05:00	Shutdown	Shutdown	Alarm	Shutdown	29.4	Shutdown	
19/07/2023 06:00	Shutdown	Shutdown	Alarm	Shutdown	29.4	Shutdown	
19/07/2023 07:00	Shutdown	Shutdown	Alarm	Shutdown	29.3	Shutdown	
19/07/2023 08:00	Shutdown	Shutdown	Alarm	Shutdown	29.3	Shutdown	
19/07/2023 09:00	Shutdown	Shutdown	Alarm	Shutdown	29.4	Shutdown	
19/07/2023 10:00	Shutdown	Shutdown	Alarm	Shutdown	29.4	Shutdown	
19/07/2023 11:00	Shutdown	Shutdown	Alarm	Shutdown	28.6	Shutdown	
19/07/2023 12:00	Shutdown	Shutdown	Alarm	Shutdown	29.8	Shutdown	
19/07/2023 13:00	Shutdown	Shutdown	Alarm	Shutdown	30.2	Shutdown	
19/07/2023 14:00	Shutdown	Shutdown	Alarm	Shutdown	30.3	Shutdown	
19/07/2023 15:00	Shutdown	Shutdown	Alarm	Shutdown	30.3	Shutdown	
19/07/2023 16:00	Shutdown	Shutdown	Alarm	Shutdown	30.9	Shutdown	
19/07/2023 17:00	Shutdown	Shutdown	Alarm	Shutdown	30.6	Shutdown	
19/07/2023 18:00	Shutdown	Shutdown	Alarm	Shutdown	30	Shutdown	
19/07/2023 19:00	Shutdown	Shutdown	Alarm	Shutdown	29.8	Shutdown	
19/07/2023 20:00	Shutdown	Shutdown	Alarm	Shutdown	29.7	Shutdown	
19/07/2023 21:00	Shutdown	Shutdown	Alarm	Shutdown	29.6	Shutdown	
19/07/2023 22:00	Shutdown	Shutdown	Alarm	Shutdown	29.6	Shutdown	
19/07/2023 23:00	Shutdown	Shutdown	Alarm	Shutdown	29.6	Shutdown	
20/07/2023 00:00	Shutdown	Shutdown	Alarm	Shutdown	29.6	Shutdown	
20/07/2023 01:00	Shutdown	Shutdown	Alarm	Shutdown	29.6	Shutdown	
20/07/2023 02:00	Shutdown	Shutdown	Alarm	Shutdown	29.5	Shutdown	
20/07/2023 03:00	Shutdown	Shutdown	Alarm	Shutdown	29.5	Shutdown	
20/07/2023 04:00	Shutdown	Shutdown	Alarm	Shutdown	29.5	Shutdown	
20/07/2023 05:00	Shutdown	Shutdown	Alarm	Shutdown	29.4	Shutdown	
20/07/2023 06:00	Shutdown	Shutdown	Alarm	Shutdown	29.3	Shutdown	
20/07/2023 07:00	Shutdown	Shutdown	Alarm	Shutdown	29.4	Shutdown	
20/07/2023 08:00	Shutdown	Shutdown	Alarm	Shutdown	29.9	Shutdown	
20/07/2023 09:00	Shutdown	Shutdown	Alarm	Shutdown	30.6	Shutdown	
20/07/2023 10:00	Shutdown	Shutdown	Alarm	Shutdown	31.2	Shutdown	
20/07/2023 11:00	Shutdown	Shutdown	Alarm	Shutdown	31.7	Shutdown	
20/07/2023 12:00	Shutdown	Shutdown	Alarm	Shutdown	31.4	Shutdown	

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
01/08/2023 00:00	Shutdown	Shutdown	Alarm	Shutdown	28.8	Shutdown
01/08/2023 01:00	Shutdown	Shutdown	Alarm	Shutdown	28.7	Shutdown
01/08/2023 02:00	Shutdown	Shutdown	Alarm	Shutdown	28.6	Shutdown
01/08/2023 03:00	Shutdown	Shutdown	Alarm	Shutdown	28.5	Shutdown
01/08/2023 04:00	Shutdown	Shutdown	Alarm	Shutdown	28.4	Shutdown
01/08/2023 05:00	Shutdown	Shutdown	Alarm	Shutdown	28.3	Shutdown
01/08/2023 06:00	Shutdown	Shutdown	Alarm	Shutdown	28.2	Shutdown
01/08/2023 07:00	Shutdown	Shutdown	Alarm	Shutdown	28.8	Shutdown
01/08/2023 08:00	Shutdown	Shutdown	Alarm	Shutdown	29.7	Shutdown
01/08/2023 09:00	Shutdown	Shutdown	Alarm	Shutdown	30.6	Shutdown
01/08/2023 10:00	Shutdown	Shutdown	Alarm	Shutdown	31	Shutdown
01/08/2023 11:00	Shutdown	Shutdown	Alarm	Shutdown	31.2	Shutdown
01/08/2023 12:00	Shutdown	Shutdown	Alarm	Shutdown	32.5	Shutdown
01/08/2023 13:00	Shutdown	Shutdown	Alarm	Shutdown	33.6	Shutdown
01/08/2023 14:00	Shutdown	Shutdown	Alarm	Shutdown	33.1	Shutdown
01/08/2023 15:00	Shutdown	Shutdown	Alarm	Shutdown	32.6	Shutdown
01/08/2023 16:00	Shutdown	Shutdown	Alarm	Shutdown	31.5	Shutdown
01/08/2023 17:00	Shutdown	Shutdown	Alarm	Shutdown	30.5	Shutdown
01/08/2023 18:00	Shutdown	Shutdown	Alarm	Shutdown	29.5	Shutdown
01/08/2023 19:00	Shutdown	Shutdown	Alarm	Shutdown	29.2	Shutdown
01/08/2023 20:00	Shutdown	Shutdown	Alarm	Shutdown	29	Shutdown
01/08/2023 21:00	Shutdown	Shutdown	Alarm	Shutdown	29	Shutdown
01/08/2023 22:00	Shutdown	Shutdown	Alarm	Shutdown	29	Shutdown
01/08/2023 23:00	Shutdown	Shutdown	Alarm	Shutdown	29.5	Shutdown
02/08/2023 00:00	Shutdown	Shutdown	Alarm	Shutdown	29.5	Shutdown
02/08/2023 01:00	Shutdown	Shutdown	Alarm	Shutdown	31.3	Shutdown
02/08/2023 02:00	Shutdown	Shutdown	Alarm	Shutdown	29	Shutdown
02/08/2023 03:00	Shutdown	Shutdown	Alarm	Shutdown	28.4	Shutdown
02/08/2023 04:00	Shutdown	Shutdown	Alarm	Shutdown	28.3	Shutdown
02/08/2023 05:00	Shutdown	Shutdown	Alarm	Shutdown	28.3	Shutdown
02/08/2023 06:00	Shutdown	Shutdown	Alarm	Shutdown	28.4	Shutdown
02/08/2023 07:00	Shutdown	Shutdown	Alarm	Shutdown	28.6	Shutdown
02/08/2023 08:00	Shutdown	Shutdown	Alarm	Shutdown	29.6	Shutdown
02/08/2023 09:00	Shutdown	Shutdown	Alarm	Shutdown	31.3	Shutdown
02/08/2023 10:00	Shutdown	Shutdown	Alarm	Shutdown	31.8	Shutdown
02/08/2023 11:00	Shutdown	Shutdown	Alarm	Shutdown	31.6	Shutdown
02/08/2023 12:00	Shutdown	Shutdown	Alarm	Shutdown	31.8	Shutdown
02/08/2023 13:00	Shutdown	Shutdown	Alarm	Shutdown	31.3	Shutdown
02/08/2023 14:00	Shutdown	Shutdown	Alarm	Shutdown	31.1	Shutdown
02/08/2023 15:00	Shutdown	Shutdown	Alarm	Shutdown	30.7	Shutdown
02/08/2023 16:00	Shutdown	Shutdown	Alarm	Shutdown	30.1	Shutdown
02/08/2023 17:00	Maintain	Maintain	Alarm	Maintain	29.4	Maintain
02/08/2023 18:00	Maintain	Maintain	Alarm	Maintain	29.1	Maintain
02/08/2023 19:00	Maintain	Maintain	Alarm	Maintain	29	Maintain
02/08/2023 20:00	Maintain	Maintain	Alarm	Maintain	29	Maintain
02/08/2023 21:00	Maintain	Maintain	Alarm	Maintain	29	Maintain
02/08/2023 22:00	Maintain	Maintain	Alarm	Maintain	29.3	Maintain
02/08/2023 23:00	Maintain	Maintain	Alarm	Maintain	34.1	Maintain
03/08/2023 00:00	Maintain	Maintain	Alarm	Maintain	34	Maintain
03/08/2023 01:00	Maintain	Maintain	Alarm	Maintain	33.8	Maintain
03/08/2023 02:00	Maintain	Maintain	Alarm	Maintain	34	Maintain
03/08/2023 03:00	Maintain	Maintain	Alarm	Maintain	34.2	Maintain
03/08/2023 04:00	Maintain	Maintain	Alarm	Maintain	40.5	Maintain
03/08/2023 05:00	Maintain	Maintain	Alarm	Maintain	34.4	Maintain
03/08/2023 06:00	Maintain	Maintain	Alarm	Maintain	33.9	Maintain
03/08/2023 07:00	Maintain	Maintain	Alarm	Maintain	33.5	Maintain
03/08/2023 08:00	Maintain	Maintain	Alarm	Maintain	36.3	Maintain
03/08/2023 09:00	Maintain	Maintain	Alarm	Maintain	51.9	Maintain
03/08/2023 10:00	Maintain	Maintain	Alarm	Maintain	87.2	Maintain

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
03/08/2023 11:00	Maintain	Maintain	Alarm	Maintain	131.9	Maintain
03/08/2023 12:00	Maintain	Maintain	Alarm	Maintain	218.1	Maintain
03/08/2023 13:00	Maintain	Maintain	Alarm	Maintain	228.1	Maintain
03/08/2023 14:00	Maintain	Maintain	Alarm	Maintain	226.5	Maintain
03/08/2023 15:00	Maintain	Maintain	Alarm	Maintain	207.4	Maintain
03/08/2023 16:00	Maintain	Maintain	Alarm	Maintain	176	Maintain
03/08/2023 17:00	<Samp	<Samp	<Samp	<Samp	213.6	<Samp
03/08/2023 18:00	119.24	16.9	124.5	12	179.4	50.6
03/08/2023 19:00	149.76	20.8	0	1.1	99.1	63.6
03/08/2023 20:00	154.46	20.8	0	1	91.2	65.6
03/08/2023 21:00	157.99	20.8	0	1	84.8	67.1
03/08/2023 22:00	158.75	20.8	0	0.9	78.1	67.4
03/08/2023 23:00	158.75	20.8	0	0.9	76.8	67.4
04/08/2023 00:00	151.71	20.8	0	0.9	73.5	64.4
04/08/2023 01:00	154.66	20.8	0	0.9	67.2	65.6
04/08/2023 02:00	157.34	20.8	0	0.9	66.1	65.8
04/08/2023 03:00	154.98	20.8	0	0.9	66.4	66.8
04/08/2023 04:00	155.2	20.8	0	0.9	80.7	65.9
04/08/2023 05:00	156.87	20.8	0	0.9	114.4	66.6
04/08/2023 06:00	157.54	20.8	0	0.9	101.3	66.9
04/08/2023 07:00	157.49	20.8	0	0.9	80	66.8
04/08/2023 08:00	159.6	20.8	0	0.9	83.3	67.7
04/08/2023 09:00	146.31	20.5	23.1	1.3	74.4	62.1
04/08/2023 10:00	134.51	20.5	24.7	1.6	78.9	57.1
04/08/2023 11:00	Shutdown	Shutdown	<Samp	Shutdown	60.9	Shutdown
04/08/2023 12:00	Shutdown	Shutdown	Alarm	Shutdown	80.9	Shutdown
04/08/2023 13:00	Shutdown	Shutdown	Alarm	Shutdown	107.2	Shutdown
04/08/2023 14:00	Shutdown	Shutdown	Alarm	Shutdown	77.6	Shutdown
04/08/2023 15:00	Shutdown	Shutdown	Alarm	Shutdown	62	Shutdown
04/08/2023 16:00	Shutdown	Shutdown	Alarm	Shutdown	60.2	Shutdown
04/08/2023 17:00	Shutdown	Shutdown	Alarm	Shutdown	57	Shutdown
04/08/2023 18:00	Shutdown	Shutdown	Alarm	Shutdown	59.1	Shutdown
04/08/2023 19:00	Shutdown	Shutdown	Alarm	Shutdown	61	Shutdown
04/08/2023 20:00	Shutdown	Shutdown	Alarm	Shutdown	59.8	Shutdown
04/08/2023 21:00	Shutdown	Shutdown	Alarm	Shutdown	56.7	Shutdown
04/08/2023 22:00	Shutdown	Shutdown	Alarm	Shutdown	53.4	Shutdown
04/08/2023 23:00	Shutdown	Shutdown	Alarm	Shutdown	55	Shutdown
05/08/2023 00:00	Shutdown	Shutdown	Alarm	Shutdown	54.7	Shutdown
05/08/2023 01:00	Shutdown	Shutdown	Alarm	Shutdown	54.3	Shutdown
05/08/2023 02:00	Shutdown	Shutdown	Alarm	Shutdown	52.4	Shutdown
05/08/2023 03:00	Shutdown	Shutdown	Alarm	Shutdown	50.3	Shutdown
05/08/2023 04:00	Shutdown	Shutdown	Alarm	Shutdown	48.6	Shutdown
05/08/2023 05:00	Shutdown	Shutdown	Alarm	Shutdown	48.8	Shutdown
05/08/2023 06:00	Shutdown	Shutdown	Alarm	Shutdown	47.2	Shutdown
05/08/2023 07:00	Shutdown	Shutdown	Alarm	Shutdown	45.6	Shutdown
05/08/2023 08:00	Shutdown	Shutdown	Alarm	Shutdown	42	Shutdown
05/08/2023 09:00	Shutdown	Shutdown	Alarm	Shutdown	42.3	Shutdown
05/08/2023 10:00	Shutdown	Shutdown	Alarm	Shutdown	43.1	Shutdown
05/08/2023 11:00	Shutdown	Shutdown	Alarm	Shutdown	41.9	Shutdown
05/08/2023 12:00	Shutdown	Shutdown	Alarm	Shutdown	44.8	Shutdown
05/08/2023 13:00	Shutdown	Shutdown	Alarm	Shutdown	47.1	Shutdown
05/08/2023 14:00	Shutdown	Shutdown	Alarm	Shutdown	176.4	Shutdown
05/08/2023 15:00	Shutdown	Shutdown	Alarm	Shutdown	212.3	Shutdown
05/08/2023 16:00	Shutdown	Shutdown	Alarm	Shutdown	213.9	Shutdown
05/08/2023 17:00	Shutdown	Shutdown	Alarm	Shutdown	218.9	Shutdown
05/08/2023 18:00	Shutdown	Shutdown	Alarm	Shutdown	219.1	Shutdown
05/08/2023 19:00	Shutdown	Shutdown	Alarm	Shutdown	219.2	Shutdown
05/08/2023 20:00	Shutdown	Shutdown	Alarm	Shutdown	214.1	Shutdown
05/08/2023 21:00	Shutdown	Shutdown	Alarm	Shutdown	211.5	Shutdown

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
05/08/2023 22:00	Shutdown	Shutdown	Alarm	Shutdown	212.1	Shutdown
05/08/2023 23:00	Shutdown	Shutdown	Alarm	Shutdown	217.4	Shutdown
06/08/2023 00:00	Shutdown	Shutdown	Alarm	Shutdown	216.6	Shutdown
06/08/2023 01:00	Shutdown	Shutdown	Alarm	Shutdown	216.1	Shutdown
06/08/2023 02:00	Shutdown	Shutdown	Alarm	Shutdown	216.2	Shutdown
06/08/2023 03:00	Shutdown	Shutdown	Alarm	Shutdown	216.1	Shutdown
06/08/2023 04:00	Shutdown	Shutdown	Alarm	Shutdown	216.2	Shutdown
06/08/2023 05:00	Shutdown	Shutdown	Alarm	Shutdown	216	Shutdown
06/08/2023 06:00	Shutdown	Shutdown	Alarm	Shutdown	216	Shutdown
06/08/2023 07:00	Shutdown	Shutdown	Alarm	Shutdown	216.2	Shutdown
06/08/2023 08:00	Shutdown	Shutdown	Alarm	Shutdown	216.5	Shutdown
06/08/2023 09:00	Shutdown	Shutdown	Alarm	Shutdown	217.7	Shutdown
06/08/2023 10:00	Shutdown	Shutdown	Alarm	Shutdown	218.3	Shutdown
06/08/2023 11:00	Shutdown	Shutdown	Alarm	Shutdown	217.9	Shutdown
06/08/2023 12:00	Shutdown	Shutdown	Alarm	Shutdown	215.1	Shutdown
06/08/2023 13:00	Shutdown	Shutdown	Alarm	Shutdown	214.8	Shutdown
06/08/2023 14:00	Shutdown	Shutdown	Alarm	Shutdown	215.2	Shutdown
06/08/2023 15:00	Shutdown	Shutdown	Alarm	Shutdown	213.7	Shutdown
06/08/2023 16:00	Shutdown	Shutdown	Alarm	Shutdown	213.8	Shutdown
06/08/2023 17:00	Shutdown	Shutdown	Alarm	Shutdown	214	Shutdown
06/08/2023 18:00	Shutdown	Shutdown	Alarm	Shutdown	213.1	Shutdown
06/08/2023 19:00	Shutdown	Shutdown	Alarm	Shutdown	212.9	Shutdown
06/08/2023 20:00	Shutdown	Shutdown	Alarm	Shutdown	216	Shutdown
06/08/2023 21:00	Shutdown	Shutdown	Alarm	Shutdown	217.8	Shutdown
06/08/2023 22:00	Shutdown	Shutdown	Alarm	Shutdown	217.7	Shutdown
06/08/2023 23:00	Shutdown	Shutdown	Alarm	Shutdown	217.5	Shutdown
07/08/2023 00:00	Shutdown	Shutdown	Alarm	Shutdown	217.3	Shutdown
07/08/2023 01:00	Shutdown	Shutdown	Alarm	Shutdown	217.5	Shutdown
07/08/2023 02:00	Shutdown	Shutdown	Alarm	Shutdown	217.4	Shutdown
07/08/2023 03:00	Shutdown	Shutdown	Alarm	Shutdown	217.2	Shutdown
07/08/2023 04:00	Shutdown	Shutdown	Alarm	Shutdown	217	Shutdown
07/08/2023 05:00	Shutdown	Shutdown	Alarm	Shutdown	216.8	Shutdown
07/08/2023 06:00	Shutdown	Shutdown	Alarm	Shutdown	216.7	Shutdown
07/08/2023 07:00	Shutdown	Shutdown	Alarm	Shutdown	217	Shutdown
07/08/2023 08:00	Shutdown	Shutdown	Alarm	Shutdown	217	Shutdown
07/08/2023 09:00	Shutdown	Shutdown	Alarm	Shutdown	217.2	Shutdown
07/08/2023 10:00	Shutdown	Shutdown	Alarm	Shutdown	217.2	Shutdown
07/08/2023 11:00	Shutdown	Shutdown	Alarm	Shutdown	217.3	Shutdown
07/08/2023 12:00	Shutdown	Shutdown	Alarm	Shutdown	217.3	Shutdown
07/08/2023 13:00	Shutdown	Shutdown	Alarm	Shutdown	217.2	Shutdown
07/08/2023 14:00	Shutdown	Shutdown	Alarm	Shutdown	217.2	Shutdown
07/08/2023 15:00	Shutdown	Shutdown	Alarm	Shutdown	217	Shutdown
07/08/2023 16:00	Shutdown	Shutdown	Alarm	Shutdown	216.7	Shutdown
07/08/2023 17:00	19.71	14.4	408.8	9.2	217.1	8.4
07/08/2023 18:00	17.49	14.4	408.8	8.2	217.2	7.4
07/08/2023 19:00	16.39	14.4	406.5	7.7	217	7
07/08/2023 20:00	16.39	14.3	387.3	7.7	215.6	7
07/08/2023 21:00	19.44	14.3	385.7	9.2	215.2	8.3
07/08/2023 22:00	17	14.3	385.7	8	215.4	7.2
07/08/2023 23:00	14.83	14.3	385	7	215.4	6.3
08/08/2023 00:00	17.23	14.3	384.9	8.1	215	7.3
08/08/2023 01:00	15.33	14.3	385	7.2	215.2	6.5
08/08/2023 02:00	16.9	14.3	384.9	8	215.2	7.2
08/08/2023 03:00	18.69	14.3	384.5	8.9	215.2	7.9
08/08/2023 04:00	16.21	14.3	384.6	7.7	215.2	6.9
08/08/2023 05:00	15.93	14.3	384	7.6	215	6.8
08/08/2023 06:00	17.01	14.3	384.4	8.1	215.1	7.2
08/08/2023 07:00	17.43	14.3	384.8	8.2	215.1	7.4
08/08/2023 08:00	19.34	14.3	385.6	9.1	215.3	8.2

Site Report - GPSC CUP2 HRSG2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
10/08/2023 20:00	4.39	14.3	350.5	2.1	210.6	1.9
10/08/2023 21:00	4.64	14.3	350.5	2.2	210.7	2
10/08/2023 22:00	5.82	14.4	351.4	2.7	210.9	2.5
10/08/2023 23:00	5.26	14.4	352.2	2.5	211.5	2.2
11/08/2023 00:00	4.61	14.4	352.3	2.2	211.6	2
11/08/2023 01:00	4.83	14.4	352.9	2.3	211.5	2
11/08/2023 02:00	4.5	14.4	352.8	2.1	211.7	1.9
11/08/2023 03:00	4.33	14.4	353.5	2	211.6	1.8
11/08/2023 04:00	4.28	14.4	353	2	211.6	1.8
11/08/2023 05:00	4.26	14.4	352.7	2	211.6	1.8
11/08/2023 06:00	4.2	14.4	353	2	211.6	1.8
11/08/2023 07:00	4.41	14.4	351.5	2.1	211.6	1.9
11/08/2023 08:00	5.02	14.4	350.6	2.4	211.2	2.1
11/08/2023 09:00	5.85	14.3	350.4	2.8	211.1	2.5
11/08/2023 10:00	4.88	14.3	349.4	2.3	210.9	2.1
11/08/2023 11:00	4.29	14.3	349.4	2	211.1	1.8
11/08/2023 12:00	4.19	14.3	348.1	2	211.2	1.8
11/08/2023 13:00	4.27	14.3	347.3	2	210.9	1.8
11/08/2023 14:00	4.4	14.3	346.8	2.1	210.3	1.9
11/08/2023 15:00	4.14	14.3	347.2	2	210.1	1.8
11/08/2023 16:00	4.38	14.1	350.2	2.2	210.1	1.9
11/08/2023 17:00	5.84	13.6	364.5	3.1	210.4	2.5
11/08/2023 18:00	6.12	14	368	3	211.7	2.6
11/08/2023 19:00	6.47	14	366.7	3.2	211.7	2.7
11/08/2023 20:00	6.15	14	366.8	3.1	211.8	2.6
11/08/2023 21:00	6.24	14	354.7	3.1	211.1	2.6
11/08/2023 22:00	6.23	14	357.4	3.1	211.3	2.6
11/08/2023 23:00	6.11	14	360	3.1	211.6	2.6
12/08/2023 00:00	6.72	14	366.4	3.4	212.3	2.9
12/08/2023 01:00	7.1	14	366.6	3.5	212.1	3
12/08/2023 02:00	7.38	14	377	3.7	213	3.1
12/08/2023 03:00	7.05	14	375.1	3.5	213.2	3
12/08/2023 04:00	7.06	14	374.9	3.5	213.2	3
12/08/2023 05:00	7.09	14	375.5	3.5	213	3
12/08/2023 06:00	7.12	14	375.8	3.5	213.1	3
12/08/2023 07:00	7.38	14	376.5	3.7	213.1	3.1
12/08/2023 08:00	7.5	14	377.7	3.7	213.2	3.2
12/08/2023 09:00	8.8	14	378.3	4.4	213.1	3.7
12/08/2023 10:00	6.99	14	379.4	3.4	213.2	3
12/08/2023 11:00	6.52	14	379	3.2	212.8	2.8
12/08/2023 12:00	7.26	14	385.1	3.6	213.7	3.1
12/08/2023 13:00	6.55	13.9	400.2	3.3	214	2.8
12/08/2023 14:00	6.35	13.9	400.6	3.2	214.1	2.7
12/08/2023 15:00	6.84	13.9	399.7	3.4	214.3	2.9
12/08/2023 16:00	7.07	13.9	398.9	3.5	214.2	3
12/08/2023 17:00	7.94	14	397.8	3.9	214.5	3.4
12/08/2023 18:00	7.98	14	397.4	3.9	214.7	3.4
12/08/2023 19:00	<Samp	<Samp	<Samp	<Samp	214.8	<Samp
12/08/2023 20:00	6.76	14	395.9	3.3	215	2.9
12/08/2023 21:00	6.14	13.8	396.2	3.1	214.8	2.6
12/08/2023 22:00	5.23	13.5	395.7	2.8	214.1	2.2
12/08/2023 23:00	6.19	13.4	396.8	3.3	213.8	2.6
13/08/2023 00:00	6.85	13.5	397.3	3.7	213.8	2.9
13/08/2023 01:00	6.53	13.5	397.8	3.5	213.9	2.8
13/08/2023 02:00	7.3	14	395.8	3.6	214.7	3.1
13/08/2023 03:00	7.47	14	394.1	3.7	214.8	3.2
13/08/2023 04:00	7.48	14	394.9	3.7	214.7	3.2
13/08/2023 05:00	7.98	14	395.9	4	214.5	3.4
13/08/2023 06:00	8.18	14	395.6	4.1	214.5	3.5

Site Report - GPSC CUP2 HRSG2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
13/08/2023 07:00	8.53	14	397.4	4.2	214.4	3.6
13/08/2023 08:00	9.74	14.1	398.1	4.8	214.6	4.1
13/08/2023 09:00	12.66	14.1	400	6.2	214.9	5.4
13/08/2023 10:00	13.21	14	400.9	6.6	214.9	5.6
13/08/2023 11:00	10.19	14	401.3	5.1	214.7	4.3
13/08/2023 12:00	10.35	14	407.9	5.1	215.8	4.4
13/08/2023 13:00	8.53	14	409.6	4.2	215.6	3.6
13/08/2023 14:00	8.68	14	409.3	4.3	215.1	3.7
13/08/2023 15:00	7.11	13.9	401.1	3.6	214.5	3
13/08/2023 16:00	6.96	13.9	400.2	3.5	214.3	3
13/08/2023 17:00	7.47	13.8	404.9	3.8	214.2	3.2
13/08/2023 18:00	7.48	13.7	398.8	3.9	213.5	3.2
13/08/2023 19:00	7.45	13.9	397.9	3.7	213.7	3.2
13/08/2023 20:00	7.66	13.9	398.1	3.8	213.5	3.3
13/08/2023 21:00	8.13	13.9	397	4.1	213.6	3.4
13/08/2023 22:00	9.17	13.9	397.7	4.6	214	3.9
13/08/2023 23:00	11	13.9	397.1	5.5	214	4.7
14/08/2023 00:00	9.83	13.9	396.7	4.9	214	4.2
14/08/2023 01:00	8.5	13.9	396.6	4.3	214.1	3.6
14/08/2023 02:00	13.18	14.1	417.1	6.5	215.9	5.6
14/08/2023 03:00	13.43	14	419.7	6.6	216.4	5.7
14/08/2023 04:00	14.71	14.1	417.6	7.2	216.6	6.2
14/08/2023 05:00	15.39	14.1	418.7	7.5	216.5	6.5
14/08/2023 06:00	15.28	14.1	418.8	7.5	216.6	6.5
14/08/2023 07:00	17.01	14.1	421.2	8.3	216.7	7.2
14/08/2023 08:00	18.15	14.1	417.3	8.9	216.2	7.7
14/08/2023 09:00	15.68	14.2	426.1	7.6	217.1	6.7
14/08/2023 10:00	16.54	14.3	431	7.9	217.6	7
14/08/2023 11:00	16.74	14.3	432.6	8	217.5	7.1
14/08/2023 12:00	16.09	14.3	432.5	7.7	217.4	6.8
14/08/2023 13:00	15.82	14.3	430.8	7.5	216.9	6.7
14/08/2023 14:00	11.5	14.1	403.1	5.6	214.6	4.9
14/08/2023 15:00	10.16	14	416.6	5	214.8	4.3
14/08/2023 16:00	10.8	14	430.4	5.4	216.2	4.6
14/08/2023 17:00	10.63	13.9	427.4	5.3	215.9	4.5
14/08/2023 18:00	9.69	13.9	426.7	4.9	215.8	4.1
14/08/2023 19:00	10.13	13.9	427.5	5.1	215.8	4.3
14/08/2023 20:00	16.3	14.3	436.7	7.8	217.3	6.9
14/08/2023 21:00	16.09	14.3	436.5	7.7	217.4	6.8
14/08/2023 22:00	13.92	14.1	437.8	6.8	217.4	5.9
14/08/2023 23:00	11.89	13.9	440.7	6	217.5	5
15/08/2023 00:00	13.25	13.9	442.9	6.7	217.8	5.6
15/08/2023 01:00	13.48	13.9	441.9	6.8	217.8	5.7
15/08/2023 02:00	13.84	13.9	440.8	7	217.3	5.9
15/08/2023 03:00	13.05	13.8	441.9	6.7	217.3	5.5
15/08/2023 04:00	13.41	13.8	442.9	6.9	217.5	5.7
15/08/2023 05:00	16.15	13.9	441.6	8.1	217.5	6.9
15/08/2023 06:00	18.21	14.2	439.1	8.7	218.4	7.7
15/08/2023 07:00	18.55	14.2	439.8	8.9	218.5	7.9
15/08/2023 08:00	19.65	14.3	439.1	9.4	218.2	8.3
15/08/2023 09:00	18.25	14.3	436.3	8.7	217.8	7.7
15/08/2023 10:00	Maintain	Maintain	Alarm	Maintain	217.4	Maintain
15/08/2023 11:00	Maintain	Maintain	Alarm	Maintain	217.3	Maintain
15/08/2023 12:00	Maintain	Maintain	Alarm	Maintain	217.3	Maintain
15/08/2023 13:00	Maintain	Maintain	Alarm	Maintain	216.5	Maintain
15/08/2023 14:00	Maintain	Maintain	Alarm	Maintain	216.4	Maintain
15/08/2023 15:00	Maintain	Maintain	Alarm	Maintain	216.7	Maintain
15/08/2023 16:00	Maintain	Maintain	Alarm	Maintain	217.2	Maintain
15/08/2023 17:00	<Samp	<Samp	<Samp	<Samp	217.2	<Samp

Site Report - GPSC CUP2 HRSG2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
15/08/2023 18:00	16.09	14.2	437.9	7.7	217.2	6.8
15/08/2023 19:00	16.67	14.3	438.9	8	217.4	7.1
15/08/2023 20:00	17.12	14.3	438.9	8.2	217.8	7.3
15/08/2023 21:00	18.66	14.3	441.3	8.9	218.3	7.9
15/08/2023 22:00	19.51	14.3	441	9.3	218.1	8.3
15/08/2023 23:00	20.27	14.3	442	9.6	218.1	8.6
16/08/2023 00:00	17.53	14.2	441.7	8.5	218.1	7.4
16/08/2023 01:00	15.36	14.1	441.4	7.5	217.8	6.5
16/08/2023 02:00	15.32	14.1	443.1	7.5	218.1	6.5
16/08/2023 03:00	15.2	14.1	438.6	7.5	218	6.5
16/08/2023 04:00	13.19	14	434	6.6	217.4	5.6
16/08/2023 05:00	13.91	14	434.9	6.9	217.6	5.9
16/08/2023 06:00	14.21	14	437.9	7.1	217.9	6
16/08/2023 07:00	17.6	14.2	441.7	8.5	218.4	7.5
16/08/2023 08:00	19.27	14.3	439.6	9.2	218.1	8.2
16/08/2023 09:00	<Samp	<Samp	<Samp	<Samp	218	<Samp
16/08/2023 10:00	Maintain	Maintain	Alarm	Maintain	217.7	Maintain
16/08/2023 11:00	Maintain	Maintain	Alarm	Maintain	217.8	Maintain
16/08/2023 12:00	Maintain	Maintain	Alarm	Maintain	218	Maintain
16/08/2023 13:00	Maintain	Maintain	Alarm	Maintain	217.7	Maintain
16/08/2023 14:00	Maintain	Maintain	Alarm	Maintain	217.1	Maintain
16/08/2023 15:00	<Samp	<Samp	<Samp	<Samp	216.8	<Samp
16/08/2023 16:00	16.37	14.3	434.5	7.8	216.9	6.9
16/08/2023 17:00	19.81	14.5	436.8	9.1	217.5	8.4
16/08/2023 18:00	17.97	14.4	438.5	8.4	217.6	7.6
16/08/2023 19:00	16.83	14.3	439.7	8	217.9	7.1
16/08/2023 20:00	16.6	14.3	439.7	7.9	218.2	7
16/08/2023 21:00	16.33	14.3	439.5	7.8	217.9	6.9
16/08/2023 22:00	15.89	14.3	440.5	7.6	218.4	6.7
16/08/2023 23:00	15.76	14.2	439.3	7.5	218.5	6.7
17/08/2023 00:00	16.93	14.2	436.6	8.1	218.1	7.2
17/08/2023 01:00	17.68	14.2	436.7	8.5	218.3	7.5
17/08/2023 02:00	17.88	14.2	435.9	8.6	218.1	7.6
17/08/2023 03:00	17.81	14.2	435.3	8.6	218.1	7.6
17/08/2023 04:00	17.92	14.2	435.3	8.6	218	7.6
17/08/2023 05:00	17.28	14.2	433.5	8.3	217.9	7.3
17/08/2023 06:00	16.27	14.1	433.6	7.9	217.9	6.9
17/08/2023 07:00	16.75	14.2	439.1	8.1	218.1	7.1
17/08/2023 08:00	17.42	14.2	441.5	8.4	218.2	7.4
17/08/2023 09:00	<Samp	<Samp	<Samp	<Samp	217.9	<Samp
17/08/2023 10:00	Maintain	Maintain	Alarm	Maintain	217.5	Maintain
17/08/2023 11:00	<Samp	<Samp	<Samp	<Samp	217.6	<Samp
17/08/2023 12:00	21.84	14.2	438.3	10.6	217.4	9.3
17/08/2023 13:00	23.31	14.2	436.9	11.3	217.4	9.9
17/08/2023 14:00	22.4	14.1	433.9	11	216.9	9.5
17/08/2023 15:00	18.73	14.1	433	9.2	216.7	8
17/08/2023 16:00	16.02	14.1	435.4	7.8	216.6	6.8
17/08/2023 17:00	15.99	14.1	437.9	7.8	216.8	6.8
17/08/2023 18:00	15.8	14.1	439.1	7.7	217.1	6.7
17/08/2023 19:00	16.5	14.1	440.7	8.1	217.4	7
17/08/2023 20:00	18.21	14.2	442.7	8.8	218.1	7.7
17/08/2023 21:00	19.73	14.3	442.8	9.4	218.7	8.4
17/08/2023 22:00	18.75	14.3	439.9	8.9	218.5	8
17/08/2023 23:00	19.36	14.3	442.9	9.2	218.9	8.2
18/08/2023 00:00	19.74	14.3	444	9.4	219	8.4
18/08/2023 01:00	19.77	14.3	445.7	9.4	219.1	8.4
18/08/2023 02:00	19.71	14.3	444.8	9.4	219.2	8.4
18/08/2023 03:00	19.44	14.3	442.9	9.3	219.1	8.3
18/08/2023 04:00	19.34	14.3	442.6	9.2	219	8.2

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
20/08/2023 16:00	21.08	14.3	446	10.1	176.9	8.9
20/08/2023 17:00	21.71	14.3	446.1	10.4	177.2	9.2
20/08/2023 18:00	22.41	14.3	446.6	10.7	177.2	9.5
20/08/2023 19:00	21.56	14.3	446.1	10.3	174.1	9.2
20/08/2023 20:00	21.25	14.3	446.2	10.2	174.1	9
20/08/2023 21:00	21.05	14.3	445.9	10.1	174	8.9
20/08/2023 22:00	21.96	14.3	445.8	10.5	172.4	9.3
20/08/2023 23:00	22.64	14.3	447.7	10.8	173.7	9.6
21/08/2023 00:00	21.42	14.2	449.9	10.3	173.7	9.1
21/08/2023 01:00	21.7	14.2	452.4	10.4	173.7	9.2
21/08/2023 02:00	22.96	14.2	451.4	11	173.8	9.7
21/08/2023 03:00	23.02	14.2	449.5	11.1	173.8	9.8
21/08/2023 04:00	24.47	14.3	455	11.7	174.9	10.4
21/08/2023 05:00	23.3	14.2	453	11.2	173.7	9.9
21/08/2023 06:00	23.54	14.2	456.4	11.3	174.6	10
21/08/2023 07:00	23.06	14.2	455	11	174.9	9.8
21/08/2023 08:00	23.03	14.3	452.3	11	173.8	9.8
21/08/2023 09:00	23.84	14.3	454.1	11.4	174.8	10.1
21/08/2023 10:00	23.14	14.3	449.8	11	174.5	9.8
21/08/2023 11:00	22.38	14.3	444.6	10.7	171.8	9.5
21/08/2023 12:00	23.36	14.3	445.1	11.1	172.8	9.9
21/08/2023 13:00	23.37	14.3	443.9	11.1	173.2	9.9
21/08/2023 14:00	23.04	14.3	444.8	11	172	9.8
21/08/2023 15:00	24.08	14.3	445	11.5	172.7	10.2
21/08/2023 16:00	21.88	14.3	446.9	10.4	172.2	9.3
21/08/2023 17:00	23.34	14.3	447.5	11.1	172.3	9.9
21/08/2023 18:00	23.25	14.3	447.9	11.1	173	9.9
21/08/2023 19:00	23.31	14.3	447.4	11.1	172	9.9
21/08/2023 20:00	23.83	14.3	453.2	11.4	172.7	10.1
21/08/2023 21:00	24.31	14.3	457.1	11.6	174.6	10.3
21/08/2023 22:00	23.87	14.3	456.2	11.4	174.3	10.1
21/08/2023 23:00	22.74	14.3	455.9	10.9	174.9	9.7
22/08/2023 00:00	21.82	14.3	456.3	10.4	174.8	9.3
22/08/2023 01:00	21.53	14.2	456	10.3	175	9.1
22/08/2023 02:00	21.43	14.3	456	10.2	175.6	9.1
22/08/2023 03:00	21.53	14.3	454.4	10.3	174.5	9.1
22/08/2023 04:00	20.69	14.2	454.8	9.9	174	8.8
22/08/2023 05:00	20.7	14.2	454.2	9.9	173.9	8.8
22/08/2023 06:00	20.44	14.3	456.1	9.8	174.1	8.7
22/08/2023 07:00	21.38	14.3	454.2	10.2	173.7	9.1
22/08/2023 08:00	25.64	14.3	449.6	12.2	174	10.9
22/08/2023 09:00	25.54	14.3	446.5	12.1	173.4	10.8
22/08/2023 10:00	25.71	14.3	446.6	12.2	172.7	10.9
22/08/2023 11:00	23.67	14.3	445.5	11.3	172.3	10
22/08/2023 12:00	23.4	14.3	442.6	11.1	171.8	9.9
22/08/2023 13:00	23.68	14.3	443.7	11.3	174	10.1
22/08/2023 14:00	24.02	14.3	444.6	11.4	174.1	10.2
22/08/2023 15:00	21.08	14.1	443.1	10.2	171.5	8.9
22/08/2023 16:00	18.52	13.9	444.7	9.3	168.9	7.9
22/08/2023 17:00	19.27	13.8	446.3	9.8	167.1	8.2
22/08/2023 18:00	20.11	13.8	446.9	10.3	166.4	8.5
22/08/2023 19:00	20.58	13.8	447.1	10.6	165.1	8.7
22/08/2023 20:00	20.52	13.8	447.3	10.5	165.7	8.7
22/08/2023 21:00	19.88	13.8	447.8	10.2	165.8	8.4
22/08/2023 22:00	18.75	14	451.6	9.3	169.9	8
22/08/2023 23:00	20.36	14.1	452.3	10	173.7	8.6
23/08/2023 00:00	22.14	14.1	451.6	10.8	172.5	9.4
23/08/2023 01:00	23.63	14.2	453.1	11.4	173.7	10
23/08/2023 02:00	25.66	14.3	453.8	12.2	175.7	10.9

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
23/08/2023 03:00	25.61	14.3	454.4	12.2	176.5	10.9
23/08/2023 04:00	25.59	14.3	453.8	12.2	176.8	10.9
23/08/2023 05:00	25.71	14.3	455.1	12.3	176.5	10.9
23/08/2023 06:00	25.86	14.3	455.3	12.3	177	11
23/08/2023 07:00	25.7	14.3	452.5	12.2	175.5	10.9
23/08/2023 08:00	26.17	14.3	450.2	12.4	175.7	11.1
23/08/2023 09:00	26.69	14.3	447.4	12.7	175.4	11.3
23/08/2023 10:00	24.64	13.9	445	12.3	170	10.5
23/08/2023 11:00	25.79	13.5	442	13.7	161.8	10.9
23/08/2023 12:00	25.22	13.5	441.9	13.4	161.1	10.7
23/08/2023 13:00	25.22	13.5	441	13.4	161.2	10.7
23/08/2023 14:00	25.07	13.5	442.5	13.3	161.1	10.6
23/08/2023 15:00	25.9	13.5	444.8	13.8	162	11
23/08/2023 16:00	24.94	13.5	444.7	13.2	161.5	10.6
23/08/2023 17:00	25.22	13.5	445.6	13.5	161.2	10.7
23/08/2023 18:00	27.71	13.3	446.1	15.1	159	11.8
23/08/2023 19:00	28.21	13.3	446.8	15.4	158.7	12
23/08/2023 20:00	28.59	13.3	449.3	15.6	160.2	12.1
23/08/2023 21:00	26.63	13.3	446	14.5	159.1	11.3
23/08/2023 22:00	21.66	13.7	446.4	11.3	163.4	9.2
23/08/2023 23:00	20.1	13.9	448.9	10	169	8.5
24/08/2023 00:00	21.53	14.1	450.4	10.5	172.1	9.1
24/08/2023 01:00	22.08	14.1	450.1	10.8	172.5	9.4
24/08/2023 02:00	21.11	14	450	10.5	170.7	9
24/08/2023 03:00	20.98	13.9	452.2	10.5	170.5	8.9
24/08/2023 04:00	20.93	13.9	450.5	10.5	169.4	8.9
24/08/2023 05:00	20.88	13.9	450.8	10.5	168.7	8.9
24/08/2023 06:00	20.14	13.9	454.5	10.1	170.5	8.5
24/08/2023 07:00	20.39	14	453.9	10.1	171.3	8.7
24/08/2023 08:00	20.48	14	450.8	10.1	172.2	8.7
24/08/2023 09:00	<Samp	<Samp	<Samp	<Samp	170.2	<Samp
24/08/2023 10:00	Maintain	Maintain	Alarm	Maintain	165.4	Maintain
24/08/2023 11:00	Maintain	Maintain	Alarm	Maintain	160	Maintain
24/08/2023 12:00	Maintain	Maintain	Alarm	Maintain	158.6	Maintain
24/08/2023 13:00	Maintain	Maintain	Alarm	Maintain	159.3	Maintain
24/08/2023 14:00	Maintain	Maintain	Alarm	Maintain	159.2	Maintain
24/08/2023 15:00	Maintain	Maintain	Alarm	Maintain	158.7	Maintain
24/08/2023 16:00	Maintain	Maintain	Alarm	Maintain	158.8	Maintain
24/08/2023 17:00	Maintain	Maintain	Alarm	Maintain	158.8	Maintain
24/08/2023 18:00	Maintain	Maintain	Alarm	Maintain	157.8	Maintain
24/08/2023 19:00	Maintain	Maintain	Alarm	Maintain	159.2	Maintain
24/08/2023 20:00	Maintain	Maintain	Alarm	Maintain	159.5	Maintain
24/08/2023 21:00	Maintain	Maintain	Alarm	Maintain	160.5	Maintain
24/08/2023 22:00	Maintain	Maintain	Alarm	Maintain	171.3	Maintain
24/08/2023 23:00	Maintain	Maintain	Alarm	Maintain	176.2	Maintain
25/08/2023 00:00	Maintain	Maintain	Alarm	Maintain	177.5	Maintain
25/08/2023 01:00	Maintain	Maintain	Alarm	Maintain	177.1	Maintain
25/08/2023 02:00	Maintain	Maintain	Alarm	Maintain	177.3	Maintain
25/08/2023 03:00	Maintain	Maintain	Alarm	Maintain	177.2	Maintain
25/08/2023 04:00	Maintain	Maintain	Alarm	Maintain	177.2	Maintain
25/08/2023 05:00	Maintain	Maintain	Alarm	Maintain	177.4	Maintain
25/08/2023 06:00	Maintain	Maintain	Alarm	Maintain	176.5	Maintain
25/08/2023 07:00	Maintain	Maintain	Alarm	Maintain	176.4	Maintain
25/08/2023 08:00	Maintain	Maintain	Alarm	Maintain	176.4	Maintain
25/08/2023 09:00	Maintain	Maintain	Alarm	Maintain	176.4	Maintain
25/08/2023 10:00	Maintain	Maintain	Alarm	Maintain	171.7	Maintain
25/08/2023 11:00	Maintain	Maintain	Alarm	Maintain	166.7	Maintain
25/08/2023 12:00	Maintain	Maintain	Alarm	Maintain	165.6	Maintain
25/08/2023 13:00	Maintain	Maintain	Alarm	Maintain	165.6	Maintain

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
25/08/2023 14:00	Maintain	Maintain	Alarm	Maintain	164.9	Maintain
25/08/2023 15:00	Maintain	Maintain	Alarm	Maintain	165.6	Maintain
25/08/2023 16:00	Maintain	Maintain	Alarm	Maintain	166.5	Maintain
25/08/2023 17:00	Maintain	Maintain	Alarm	Maintain	166.2	Maintain
25/08/2023 18:00	Maintain	Maintain	Alarm	Maintain	166.2	Maintain
25/08/2023 19:00	Maintain	Maintain	Alarm	Maintain	165.9	Maintain
25/08/2023 20:00	Maintain	Maintain	Alarm	Maintain	167.4	Maintain
25/08/2023 21:00	Maintain	Maintain	Alarm	Maintain	167.6	Maintain
25/08/2023 22:00	Maintain	Maintain	Alarm	Maintain	174.3	Maintain
25/08/2023 23:00	Maintain	Maintain	Alarm	Maintain	176.5	Maintain
26/08/2023 00:00	Maintain	Maintain	Alarm	Maintain	176	Maintain
26/08/2023 01:00	Maintain	Maintain	Alarm	Maintain	177.1	Maintain
26/08/2023 02:00	Maintain	Maintain	Alarm	Maintain	175.5	Maintain
26/08/2023 03:00	Maintain	Maintain	Alarm	Maintain	175.7	Maintain
26/08/2023 04:00	Maintain	Maintain	Alarm	Maintain	176.6	Maintain
26/08/2023 05:00	Maintain	Maintain	Alarm	Maintain	175.9	Maintain
26/08/2023 06:00	Maintain	Maintain	Alarm	Maintain	176	Maintain
26/08/2023 07:00	Maintain	Maintain	Alarm	Maintain	176.5	Maintain
26/08/2023 08:00	Maintain	Maintain	Alarm	Maintain	174.6	Maintain
26/08/2023 09:00	Maintain	Maintain	Alarm	Maintain	175.6	Maintain
26/08/2023 10:00	Maintain	Maintain	Alarm	Maintain	172.3	Maintain
26/08/2023 11:00	Maintain	Maintain	Alarm	Maintain	162.5	Maintain
26/08/2023 12:00	Maintain	Maintain	Alarm	Maintain	163	Maintain
26/08/2023 13:00	Maintain	Maintain	Alarm	Maintain	162.6	Maintain
26/08/2023 14:00	Maintain	Maintain	Alarm	Maintain	162.4	Maintain
26/08/2023 15:00	Maintain	Maintain	Alarm	Maintain	162	Maintain
26/08/2023 16:00	Maintain	Maintain	Alarm	Maintain	161.2	Maintain
26/08/2023 17:00	Maintain	Maintain	Alarm	Maintain	161.4	Maintain
26/08/2023 18:00	Maintain	Maintain	Alarm	Maintain	161.9	Maintain
26/08/2023 19:00	Maintain	Maintain	Alarm	Maintain	163.7	Maintain
26/08/2023 20:00	Maintain	Maintain	Alarm	Maintain	163.7	Maintain
26/08/2023 21:00	Maintain	Maintain	Alarm	Maintain	163.7	Maintain
26/08/2023 22:00	Maintain	Maintain	Alarm	Maintain	173.6	Maintain
26/08/2023 23:00	Maintain	Maintain	Alarm	Maintain	176.6	Maintain
27/08/2023 00:00	Maintain	Maintain	Alarm	Maintain	176.7	Maintain
27/08/2023 01:00	Maintain	Maintain	Alarm	Maintain	177	Maintain
27/08/2023 02:00	Maintain	Maintain	Alarm	Maintain	177.2	Maintain
27/08/2023 03:00	Maintain	Maintain	Alarm	Maintain	177.1	Maintain
27/08/2023 04:00	Maintain	Maintain	Alarm	Maintain	176.1	Maintain
27/08/2023 05:00	Maintain	Maintain	Alarm	Maintain	177.2	Maintain
27/08/2023 06:00	Maintain	Maintain	Alarm	Maintain	176.4	Maintain
27/08/2023 07:00	Maintain	Maintain	Alarm	Maintain	175	Maintain
27/08/2023 08:00	Maintain	Maintain	Alarm	Maintain	174.9	Maintain
27/08/2023 09:00	Maintain	Maintain	Alarm	Maintain	175.6	Maintain
27/08/2023 10:00	Maintain	Maintain	Alarm	Maintain	176.3	Maintain
27/08/2023 11:00	Maintain	Maintain	Alarm	Maintain	176.2	Maintain
27/08/2023 12:00	Maintain	Maintain	Alarm	Maintain	175.2	Maintain
27/08/2023 13:00	Maintain	Maintain	Alarm	Maintain	175.5	Maintain
27/08/2023 14:00	Maintain	Maintain	Alarm	Maintain	175.2	Maintain
27/08/2023 15:00	Maintain	Maintain	Alarm	Maintain	175.7	Maintain
27/08/2023 16:00	Maintain	Maintain	Alarm	Maintain	175.1	Maintain
27/08/2023 17:00	Maintain	Maintain	Alarm	Maintain	175.5	Maintain
27/08/2023 18:00	Maintain	Maintain	Alarm	Maintain	175.3	Maintain
27/08/2023 19:00	Maintain	Maintain	Alarm	Maintain	174.7	Maintain
27/08/2023 20:00	Maintain	Maintain	Alarm	Maintain	162.2	Maintain
27/08/2023 21:00	Maintain	Maintain	Alarm	Maintain	162.9	Maintain
27/08/2023 22:00	Maintain	Maintain	Alarm	Maintain	175.5	Maintain
27/08/2023 23:00	Maintain	Maintain	Alarm	Maintain	175.5	Maintain
28/08/2023 00:00	Maintain	Maintain	Alarm	Maintain	176.3	Maintain

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
30/08/2023 12:00	26.76	13.4	434.5	14.4	153.6	11.4
30/08/2023 13:00	27.33	13.4	434.4	14.7	153.3	11.6
30/08/2023 14:00	27.64	13.4	435.9	14.9	153.6	11.7
30/08/2023 15:00	28.31	13.4	436.4	15.2	153.6	12
30/08/2023 16:00	27.36	13.4	438.6	14.7	153.9	11.6
30/08/2023 17:00	24.04	13.5	440.5	12.8	155.6	10.2
30/08/2023 18:00	26.88	13.6	440.2	14.2	156	11.4
30/08/2023 19:00	26.88	13.5	441.2	14.2	156.5	11.4
30/08/2023 20:00	24.7	13.5	441.1	13.1	156.5	10.5
30/08/2023 21:00	22.85	13.6	440.9	12.1	156.3	9.7
30/08/2023 22:00	22.76	14.2	444.2	10.9	166.5	9.7
30/08/2023 23:00	22.64	14.3	445	10.8	170.9	9.6
31/08/2023 00:00	23.32	14.3	445.8	11.1	171.6	9.9
31/08/2023 01:00	23.32	14.3	445.1	11.1	172.1	9.9
31/08/2023 02:00	24.04	14.3	444.9	11.5	171.1	10.2
31/08/2023 03:00	24.82	14.3	445.9	11.8	171.3	10.5
31/08/2023 04:00	25.33	14.3	445.7	12.1	171.4	10.8
31/08/2023 05:00	25.25	14.3	445.7	12	171.4	10.7
31/08/2023 06:00	25.03	14.3	447.7	11.9	171.9	10.6
31/08/2023 07:00	24.78	14.3	448	11.8	171.8	10.5
31/08/2023 08:00	24.03	14.3	446.8	11.4	172.2	10.2
31/08/2023 09:00	23.64	14.3	445.6	11.2	171.8	10
31/08/2023 10:00	24.12	13.8	441.2	12.3	164.6	10.2
31/08/2023 11:00	23.85	13.5	437.8	12.7	157.1	10.1
31/08/2023 12:00	21.21	13.5	435.2	11.4	155.9	9
31/08/2023 13:00	23.92	13.5	440.3	12.8	157.3	10.2
31/08/2023 14:00	24.53	13.5	441.7	13.1	157.4	10.4
31/08/2023 15:00	24.67	13.5	439.5	13.2	156.8	10.5
31/08/2023 16:00	24.29	13.5	437.7	13	155.9	10.3
31/08/2023 17:00	22.44	13.5	438.5	12	156.5	9.5
31/08/2023 18:00	21.85	13.5	439.6	11.7	156.8	9.3
31/08/2023 19:00	20.67	13.5	439.4	11.1	156.7	8.8
31/08/2023 20:00	24.79	13.5	441.4	13.2	157.3	10.5
31/08/2023 21:00	28.66	13.5	442	15.2	158.1	12.2
31/08/2023 22:00	27.45	14.1	447.1	13.4	168.2	11.7
31/08/2023 23:00	26.55	14.3	449	12.7	172.3	11.3
Minimum	4.14	13.3	0	0.9	28.2	1.8
MinDate	11/08/2023 15:00	23/08/2023 18:00	03/08/2023 19:00	03/08/2023 22:00	01/08/2023 06:00	11/08/2023 03:00
Maximum	159.6	20.8	457.1	55.3	228.1	67.7
MaxDate	04/08/2023 08:00	03/08/2023 19:00	21/08/2023 21:00	09/08/2023 08:00	03/08/2023 13:00	04/08/2023 08:00
Avg	24.55	14.4	406.1	9.1	173.4	10.4
Num	430	430	430	430	744	430
Data[%]	57.7	57.7	57.7	57.7	99.9	57.7
STD	29.6	1.3	86.9	6.8	55.7	12.6

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
01/09/2023 00:00	28.1	14.3	451.5	13.4	171.2	11.9
01/09/2023 01:00	27.93	14.3	452.6	13.3	171.6	11.9
01/09/2023 02:00	27.62	14.3	453.5	13.2	172.5	11.7
01/09/2023 03:00	27.93	14.3	453.5	13.3	173	11.9
01/09/2023 04:00	27.83	14.2	452.8	13.3	171.6	11.8
01/09/2023 05:00	27.6	14.2	452.6	13.2	172	11.7
01/09/2023 06:00	27.68	14.3	452.9	13.2	173.7	11.7
01/09/2023 07:00	26.31	14.3	451.8	12.6	172.7	11.2
01/09/2023 08:00	24.87	14.3	448	11.9	172.3	10.6
01/09/2023 09:00	24.97	14.3	446.4	11.9	172.6	10.6
01/09/2023 10:00	25.28	13.8	442.7	12.9	164.5	10.7
01/09/2023 11:00	26.85	13.3	439.7	14.8	155.4	11.4
01/09/2023 12:00	25.15	13.2	439.4	14	152.9	10.7
01/09/2023 13:00	24.91	13.1	438.1	13.9	152.5	10.6
01/09/2023 14:00	24.79	13.1	437.7	13.8	151.9	10.5
01/09/2023 15:00	24.76	13.1	437.6	13.8	152.3	10.5
01/09/2023 16:00	26.27	13.1	439.2	14.7	152.3	11.2
01/09/2023 17:00	26.77	13.1	439.2	14.9	152.7	11.4
01/09/2023 18:00	27.79	13.1	440.7	15.5	152.3	11.8
01/09/2023 19:00	27.38	13.1	442.3	15.3	152.5	11.6
01/09/2023 20:00	27.06	13.1	442.4	15.1	151.9	11.5
01/09/2023 21:00	27.24	13.1	441.4	15.3	151.8	11.6
01/09/2023 22:00	26.35	13.8	443.4	13.4	161.7	11.2
01/09/2023 23:00	28.74	14.3	444.1	13.7	170.8	12.2
02/09/2023 00:00	29.26	14.3	444.7	13.9	171	12.4
02/09/2023 01:00	29.71	14.3	445.2	14.2	170.9	12.6
02/09/2023 02:00	29.31	14.3	445.8	14	171.5	12.4
02/09/2023 03:00	29.28	14.3	446.4	14	172.2	12.4
02/09/2023 04:00	29.09	14.3	446.5	13.9	171.7	12.3
02/09/2023 05:00	29.24	14.3	447.3	13.9	172	12.4
02/09/2023 06:00	29.34	14.3	448.6	14	172.4	12.5
02/09/2023 07:00	28.14	14.3	447.7	13.4	172.5	11.9
02/09/2023 08:00	22.87	14.3	446.9	10.9	172.1	9.7
02/09/2023 09:00	21.1	14.3	444.5	10	172.1	9
02/09/2023 10:00	23.9	13.9	442.7	12.1	165.8	10.1
02/09/2023 11:00	27.53	13.3	438.8	15.1	153.1	11.7
02/09/2023 12:00	26.96	13.3	437.1	14.7	151.3	11.4
02/09/2023 13:00	27.23	13.3	435.1	14.9	143.1	11.6
02/09/2023 14:00	26.61	13.3	436.1	14.6	143.8	11.3
02/09/2023 15:00	26.01	13.3	436.3	14.3	149.8	11
02/09/2023 16:00	25.42	13.3	435.8	14	151.1	10.8
02/09/2023 17:00	25.52	13.3	436.6	14	150.7	10.8
02/09/2023 18:00	25.15	13.3	437.8	13.8	151.5	10.7
02/09/2023 19:00	24.93	13.3	438.3	13.7	151.8	10.6
02/09/2023 20:00	25.76	13.3	440	14.1	151.7	10.9
02/09/2023 21:00	26.88	13.3	442.2	14.7	152.1	11.4
02/09/2023 22:00	25.14	14.1	446.7	12.3	164.3	10.7
02/09/2023 23:00	25.44	14.3	447.9	12.1	168.9	10.8
03/09/2023 00:00	26.01	14.3	447.9	12.4	168.8	11
03/09/2023 01:00	26.27	14.3	448.8	12.5	168.9	11.1
03/09/2023 02:00	26.66	14.3	448.4	12.7	168.8	11.3
03/09/2023 03:00	26.99	14.3	449.2	12.8	169.2	11.5
03/09/2023 04:00	27.56	14.3	449.4	13.1	169.3	11.7
03/09/2023 05:00	27.3	14.3	449.6	13	169.5	11.6
03/09/2023 06:00	26.9	14.3	450.6	12.8	169.4	11.4
03/09/2023 07:00	25.71	14.3	446.2	12.2	168.9	10.9
03/09/2023 08:00	24	14.3	444.3	11.4	170.2	10.2
03/09/2023 09:00	22.66	14.3	442	10.8	170.7	9.6
03/09/2023 10:00	21.35	14.3	438.3	10.2	171	9.1

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
03/09/2023 11:00	23.94	14.3	436.8	11.4	170.5	10.2
03/09/2023 12:00	24.48	14.3	436	11.6	170.5	10.4
03/09/2023 13:00	25.71	14.3	434.5	12.2	169.8	10.9
03/09/2023 14:00	26.17	14.3	435.3	12.4	169.8	11.1
03/09/2023 15:00	26.5	14.3	436.3	12.6	170.5	11.2
03/09/2023 16:00	26.81	14.3	437.7	12.8	171.1	11.4
03/09/2023 17:00	26.75	14.3	437.9	12.7	171	11.4
03/09/2023 18:00	26.15	14.3	440.1	12.5	171	11.1
03/09/2023 19:00	23.57	14.2	440.5	11.4	170.1	10
03/09/2023 20:00	27.1	13.4	439.6	14.7	156.6	11.5
03/09/2023 21:00	27.48	13.7	441.9	14.3	159.8	11.7
03/09/2023 22:00	27.15	14.3	443.1	13	171.6	11.5
03/09/2023 23:00	27.81	14.3	442.7	13.3	170.9	11.8
04/09/2023 00:00	29.45	14.3	443.7	14	171.7	12.5
04/09/2023 01:00	30.06	14.3	444.6	14.3	171.2	12.8
04/09/2023 02:00	28.63	14.3	444.6	13.6	171.4	12.2
04/09/2023 03:00	28.36	14.3	445	13.5	171.9	12
04/09/2023 04:00	29.06	14.3	446.7	13.9	172.3	12.3
04/09/2023 05:00	29.32	14.3	446.4	14	172.6	12.4
04/09/2023 06:00	29.55	14.3	447.5	14.1	172.6	12.5
04/09/2023 07:00	27.97	14.3	444.7	13.3	172.4	11.9
04/09/2023 08:00	26.59	14.3	441.5	12.7	171.5	11.3
04/09/2023 09:00	24.45	14.3	439.8	11.6	172	10.4
04/09/2023 10:00	23.94	13.9	437.2	12	166.4	10.2
04/09/2023 11:00	25.53	13.4	435.1	13.7	156.1	10.8
04/09/2023 12:00	26.34	13.4	434.3	14.1	156.3	11.2
04/09/2023 13:00	28.21	13.5	434	15.1	155.9	12
04/09/2023 14:00	27.61	13.4	434.3	14.8	155.4	11.7
04/09/2023 15:00	28.18	13.4	435.5	15.1	155.2	12
04/09/2023 16:00	28.83	13.4	437.5	15.5	155.3	12.2
04/09/2023 17:00	27.57	13.4	439.5	14.8	156.5	11.7
04/09/2023 18:00	26.3	13.5	441.1	14.1	156.8	11.2
04/09/2023 19:00	26.26	13.5	441.6	14.1	157.4	11.1
04/09/2023 20:00	23.73	13.5	442.2	12.7	157.1	10.1
04/09/2023 21:00	22.96	13.5	441.9	12.3	156.3	9.7
04/09/2023 22:00	22.44	14	443.9	11.1	166	9.5
04/09/2023 23:00	23.73	14.3	444.4	11.3	171.8	10.1
05/09/2023 00:00	25.8	14.3	444.9	12.3	171.9	10.9
05/09/2023 01:00	26.13	14.3	444.7	12.4	171	11.1
05/09/2023 02:00	26.58	14.3	447	12.7	171.7	11.3
05/09/2023 03:00	27.3	14.3	447.5	13	171.9	11.6
05/09/2023 04:00	27.67	14.3	446.9	13.2	172.3	11.7
05/09/2023 05:00	27.66	14.3	446.4	13.1	172.5	11.7
05/09/2023 06:00	27	14.3	444.8	12.8	171.2	11.5
05/09/2023 07:00	26.29	14.3	444	12.5	172	11.2
05/09/2023 08:00	26.01	14.3	444.2	12.3	171.8	11
05/09/2023 09:00	24.61	14.3	444.2	11.7	171.6	10.4
05/09/2023 10:00	25.4	13.9	443.3	12.8	166.1	10.8
05/09/2023 11:00	26.88	13.6	443	14.2	159.1	11.4
05/09/2023 12:00	26.68	13.6	441.7	14.1	158.3	11.3
05/09/2023 13:00	27.53	13.6	440.2	14.5	158.9	11.7
05/09/2023 14:00	29.48	13.6	439.9	15.5	158.3	12.5
05/09/2023 15:00	26.06	13.6	439	13.7	157.2	11.1
05/09/2023 16:00	25.79	13.6	439.4	13.6	157.1	10.9
05/09/2023 17:00	24.85	13.6	440.1	13.1	157.3	10.5
05/09/2023 18:00	23.82	13.6	441.4	12.6	158.7	10.1
05/09/2023 19:00	23.09	13.6	444.3	12.2	158.9	9.8
05/09/2023 20:00	22.25	13.5	446.5	11.8	160	9.4
05/09/2023 21:00	23.64	13.6	448.2	12.5	160	10

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
08/09/2023 09:00	25.29	14.3	448.3	12	172.2	10.7
08/09/2023 10:00	24.37	13.7	444.5	12.5	164.2	10.3
08/09/2023 11:00	25.82	13.4	442.5	13.9	157.8	11
08/09/2023 12:00	26.91	13.4	441.7	14.4	157.6	11.4
08/09/2023 13:00	28.51	13.5	439	15.3	157.1	12.1
08/09/2023 14:00	28.8	13.4	438	15.4	156.5	12.2
08/09/2023 15:00	29.09	13.5	437.6	15.6	156.9	12.3
08/09/2023 16:00	30.07	13.5	437.9	16.1	156.6	12.8
08/09/2023 17:00	26.03	13.5	439.8	13.9	156.9	11
08/09/2023 18:00	22.68	13.4	439.4	12.3	155.8	9.6
08/09/2023 19:00	21.62	13.4	442.3	11.7	156.3	9.2
08/09/2023 20:00	25.28	13.4	444.9	13.6	156.8	10.7
08/09/2023 21:00	27.85	13.4	447.7	15	157.8	11.8
08/09/2023 22:00	26.9	14.2	450.7	13	168.7	11.4
08/09/2023 23:00	28.26	14.3	451.8	13.5	173.5	12
09/09/2023 00:00	28.61	14.3	452.2	13.6	173.3	12.1
09/09/2023 01:00	29.41	14.3	452.4	14	173.5	12.5
09/09/2023 02:00	29.31	14.3	453.4	14	173.4	12.4
09/09/2023 03:00	29.48	14.3	453.3	14.1	173	12.5
09/09/2023 04:00	29.89	14.3	452.9	14.3	173.3	12.7
09/09/2023 05:00	29.7	14.3	451.7	14.2	173	12.6
09/09/2023 06:00	29.17	14.3	450.2	13.9	173.1	12.4
09/09/2023 07:00	27.15	14.3	449.6	12.9	173.1	11.5
09/09/2023 08:00	21.78	14.3	446.9	10.4	172.5	9.2
09/09/2023 09:00	21.09	14.3	444.9	10	172.7	9
09/09/2023 10:00	22.52	13.8	440.3	11.6	164.6	9.6
09/09/2023 11:00	24.98	13.4	437.1	13.5	155.8	10.6
09/09/2023 12:00	26.27	13.4	436.4	14.2	155.7	11.1
09/09/2023 13:00	26.88	13.4	435.1	14.6	155.1	11.4
09/09/2023 14:00	24.88	13.3	434.3	13.6	154	10.6
09/09/2023 15:00	24.61	13.3	433	13.4	154.1	10.4
09/09/2023 16:00	25.04	13.3	436.1	13.7	154.3	10.6
09/09/2023 17:00	25.59	13.3	439.4	14	154.8	10.9
09/09/2023 18:00	25.14	13.3	440.1	13.7	154.8	10.7
09/09/2023 19:00	25.13	13.3	440.5	13.7	155	10.7
09/09/2023 20:00	24.9	13.4	440.8	13.5	155.6	10.6
09/09/2023 21:00	26.39	13.4	442.2	14.3	156	11.2
09/09/2023 22:00	25.95	14.1	445.4	12.7	166.9	11
09/09/2023 23:00	26.72	14.3	446.7	12.7	171.6	11.3
10/09/2023 00:00	27.48	14.3	449	13.1	172.7	11.7
10/09/2023 01:00	27.75	14.3	448.7	13.2	172.5	11.8
10/09/2023 02:00	28.6	14.3	448.5	13.6	172.4	12.1
10/09/2023 03:00	29.05	14.3	448.2	13.8	172.3	12.3
10/09/2023 04:00	28.63	14.3	446.7	13.6	172.6	12.2
10/09/2023 05:00	28.38	14.3	446.7	13.5	172.2	12
10/09/2023 06:00	28.39	14.3	446.4	13.5	172.2	12
10/09/2023 07:00	26.84	14.3	445.9	12.8	171.4	11.4
10/09/2023 08:00	26.72	14.3	445.5	12.7	171.7	11.3
10/09/2023 09:00	23.86	14.3	445.2	11.3	171.4	10.1
10/09/2023 10:00	25.86	14.3	442.9	12.3	171.7	11
10/09/2023 11:00	27.13	14.3	442.3	12.9	171.7	11.5
10/09/2023 12:00	24.8	14.3	440.7	11.8	171.4	10.5
10/09/2023 13:00	24.55	14.3	440	11.7	170.7	10.4
10/09/2023 14:00	24.2	14.3	442	11.5	171	10.3
10/09/2023 15:00	24.14	14.3	444.7	11.5	170.9	10.2
10/09/2023 16:00	22.99	14.3	444.5	11	171.3	9.8
10/09/2023 17:00	24.85	14.3	444.6	11.8	171.5	10.5
10/09/2023 18:00	24.98	14.3	445.1	11.9	170.8	10.6
10/09/2023 19:00	25.11	14.2	445.2	12.1	169.9	10.7

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
10/09/2023 20:00	24.84	13.5	443.4	13.3	157.9	10.5
10/09/2023 21:00	23.39	13.7	445	12.2	160.1	9.9
10/09/2023 22:00	22.91	14.3	446.4	10.9	171.3	9.7
10/09/2023 23:00	24.12	14.3	447.6	11.5	172.2	10.2
11/09/2023 00:00	24.7	14.3	448.7	11.7	172.6	10.5
11/09/2023 01:00	26.78	14.3	450.6	12.7	172.8	11.4
11/09/2023 02:00	27.43	14.3	451	13	173.2	11.6
11/09/2023 03:00	27.85	14.3	451.8	13.2	173.4	11.8
11/09/2023 04:00	28.65	14.3	452.3	13.6	173.3	12.2
11/09/2023 05:00	28.8	14.3	451.7	13.7	173.5	12.2
11/09/2023 06:00	28.44	14.3	449	13.5	172.7	12.1
11/09/2023 07:00	27.95	14.3	447.4	13.2	172.4	11.9
11/09/2023 08:00	24.46	14.3	445.6	11.6	172.1	10.4
11/09/2023 09:00	24.08	14.3	444.3	11.4	171.1	10.2
11/09/2023 10:00	23.41	14	441.2	11.7	165.3	9.9
11/09/2023 11:00	23.42	13.4	436.5	12.6	155	9.9
11/09/2023 12:00	23.97	13.4	438.1	12.9	156.2	10.2
11/09/2023 13:00	25.11	13.4	437.3	13.6	156	10.7
11/09/2023 14:00	25.41	13.4	437.4	13.7	155.7	10.8
11/09/2023 15:00	26.3	13.4	438.3	14.2	155.8	11.2
11/09/2023 16:00	26.51	13.4	439.4	14.3	156	11.3
11/09/2023 17:00	26.49	13.4	441	14.3	155.6	11.2
11/09/2023 18:00	28.19	13.4	443.6	15.2	156.6	12
11/09/2023 19:00	27.95	13.4	444.1	15.1	156.6	11.9
11/09/2023 20:00	27.77	13.4	443.4	15	156.6	11.8
11/09/2023 21:00	27.71	13.4	444.4	14.9	157.2	11.8
11/09/2023 22:00	24.79	14.1	447.6	12.1	167.5	10.5
11/09/2023 23:00	24.72	14.3	447.4	11.7	171.2	10.5
12/09/2023 00:00	25.63	14.3	448.2	12.2	171.9	10.9
12/09/2023 01:00	25.71	14.3	448.5	12.2	172	10.9
12/09/2023 02:00	25.89	14.3	449.3	12.3	172.4	11
12/09/2023 03:00	26.31	14.3	449.1	12.5	172.4	11.2
12/09/2023 04:00	26.76	14.3	448.8	12.7	172	11.4
12/09/2023 05:00	26.99	14.3	448.2	12.8	172.1	11.5
12/09/2023 06:00	26.92	14.3	448.8	12.8	172.2	11.4
12/09/2023 07:00	26.5	14.3	447.5	12.6	172.3	11.2
12/09/2023 08:00	25.05	14.3	446.8	11.9	171.7	10.6
12/09/2023 09:00	24.67	14.1	444.8	12.2	168.2	10.5
12/09/2023 10:00	22.74	13.1	439.8	12.7	146.3	9.7
12/09/2023 11:00	25.13	13.5	439.4	13.4	149.7	10.7
12/09/2023 12:00	27.9	13.5	440.1	14.9	150.3	11.8
12/09/2023 13:00	26.37	13.5	443.5	14	170.9	11.2
12/09/2023 14:00	26.14	13.5	443.5	13.9	181.4	11.1
12/09/2023 15:00	26.78	13.5	439.2	14.3	151.4	11.4
12/09/2023 16:00	27.63	13.5	439.8	14.8	147.4	11.7
12/09/2023 17:00	28.03	13.5	440.6	15	147.5	11.9
12/09/2023 18:00	28.07	13.5	441	15	147.3	11.9
12/09/2023 19:00	28.96	13.5	442.3	15.5	147.8	12.3
12/09/2023 20:00	28.84	13.5	441.9	15.4	147.9	12.2
12/09/2023 21:00	<Samp	<Samp	<Samp	<Samp	149.4	<Samp
12/09/2023 22:00	Maintain	Maintain	Alarm	Maintain	192.7	Maintain
12/09/2023 23:00	Maintain	Maintain	Alarm	Maintain	109.7	Maintain
13/09/2023 00:00	Maintain	Maintain	Alarm	Maintain	144.5	Maintain
13/09/2023 01:00	<Samp	<Samp	<Samp	<Samp	191.6	<Samp
13/09/2023 02:00	24.55	14.3	446.5	11.7	169.1	10.4
13/09/2023 03:00	23.74	14.3	445.5	11.3	168.1	10.1
13/09/2023 04:00	24.48	14.3	446.4	11.6	168.5	10.4
13/09/2023 05:00	25.11	14.3	447.4	11.9	169.2	10.7
13/09/2023 06:00	25.28	14.3	448.8	12	169.6	10.7

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
13/09/2023 07:00	24.44	14.3	448.3	11.6	169.6	10.4
13/09/2023 08:00	24.37	14.3	443.8	11.5	168.5	10.3
13/09/2023 09:00	23.82	14.3	442.1	11.3	167.8	10.1
13/09/2023 10:00	23.87	13.9	438.9	12.1	159.2	10.1
13/09/2023 11:00	25.63	13.5	436.9	13.6	148.1	10.9
13/09/2023 12:00	26.34	13.5	436.1	14	148	11.2
13/09/2023 13:00	<Samp	<Samp	<Samp	<Samp	147.4	<Samp
13/09/2023 14:00	<Samp	<Samp	<Samp	<Samp	147	<Samp
13/09/2023 15:00	27.49	13.5	435.5	14.7	146.9	11.7
13/09/2023 16:00	27.28	13.5	437.5	14.6	147.3	11.6
13/09/2023 17:00	27.74	13.4	439.3	14.9	147.7	11.8
13/09/2023 18:00	27.88	13.4	439.6	15	147.8	11.8
13/09/2023 19:00	28.41	13.5	440.4	15.2	148	12.1
13/09/2023 20:00	28.08	13.5	440.3	15	148.2	11.9
13/09/2023 21:00	27.42	13.5	442.4	14.7	148.6	11.6
13/09/2023 22:00	24.33	14.2	449.1	11.7	165.4	10.3
13/09/2023 23:00	23.18	14.3	450.1	11.1	170	9.8
14/09/2023 00:00	23.81	14.2	451.6	11.4	170.2	10.1
14/09/2023 01:00	25.77	14.3	451.7	12.3	170.4	10.9
14/09/2023 02:00	26.23	14.3	449.4	12.5	170	11.1
14/09/2023 03:00	27.31	14.3	449.7	13	169.8	11.6
14/09/2023 04:00	27.44	14.3	452.1	13.1	170.2	11.6
14/09/2023 05:00	27.47	14.3	452.6	13.1	170.1	11.7
14/09/2023 06:00	27.15	14.3	453.7	13	170.6	11.5
14/09/2023 07:00	26.09	14.3	451.8	12.4	170.2	11.1
14/09/2023 08:00	25.45	14.3	448.1	12.1	169.5	10.8
14/09/2023 09:00	24.9	14.3	444.2	11.8	168.8	10.6
14/09/2023 10:00	23.56	13.9	440.5	11.9	160.3	10
14/09/2023 11:00	24.76	13.4	436	13.3	147.9	10.5
14/09/2023 12:00	25.09	13.4	434.9	13.5	147.5	10.6
14/09/2023 13:00	26.27	13.4	434.6	14.1	147.1	11.2
14/09/2023 14:00	25.55	13.4	436.5	13.8	147.3	10.8
14/09/2023 15:00	24.59	13.4	439	13.3	147.4	10.4
14/09/2023 16:00	25.33	13.4	440	13.7	147.5	10.8
14/09/2023 17:00	25	13.4	444.6	13.5	147.7	10.6
14/09/2023 18:00	24.99	13.5	447.4	13.3	149.5	10.6
14/09/2023 19:00	24.42	13.6	445.7	12.9	150.4	10.4
14/09/2023 20:00	26.18	13.6	451.4	13.7	152.2	11.1
14/09/2023 21:00	26.44	13.7	453.3	13.6	155.8	11.2
14/09/2023 22:00	27.09	14.2	456.7	13	167	11.5
14/09/2023 23:00	25.77	14.3	455.1	12.3	170.8	10.9
15/09/2023 00:00	25.34	14.3	454.6	12.1	170.9	10.8
15/09/2023 01:00	25.58	14.3	453.8	12.2	171	10.9
15/09/2023 02:00	26.33	14.3	453.9	12.6	170.5	11.2
15/09/2023 03:00	27.2	14.3	451.6	13	170	11.5
15/09/2023 04:00	27.26	14.3	452.4	13	170.1	11.6
15/09/2023 05:00	25.74	14.3	453.6	12.3	170.4	10.9
15/09/2023 06:00	23.83	14.3	453.2	11.4	170.5	10.1
15/09/2023 07:00	23.03	14.3	450.9	11	170	9.8
15/09/2023 08:00	22.51	14.3	448	10.7	169.5	9.6
15/09/2023 09:00	<Samp	<Samp	<Samp	<Samp	168.8	<Samp
15/09/2023 10:00	<Samp	<Samp	<Samp	<Samp	163.4	<Samp
15/09/2023 11:00	21.98	13.5	439.8	11.7	149.2	9.3
15/09/2023 12:00	26.05	13.5	438.9	13.9	148.9	11.1
15/09/2023 13:00	26.51	13.5	437.8	14.2	148.2	11.3
15/09/2023 14:00	26.95	13.4	437.2	14.5	148	11.4
15/09/2023 15:00	27.53	13.4	437.9	14.8	147.8	11.7
15/09/2023 16:00	25.94	14.1	443.6	12.8	159.4	11
15/09/2023 17:00	26.7	14.3	446.2	12.7	167.5	11.3

Site Report - GPSC CUP2 HRSBG2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
18/09/2023 05:00	25.11	14.6	457.6	11.5	178.4	10.7
18/09/2023 06:00	25.5	14.6	457.2	11.6	178.5	10.8
18/09/2023 07:00	24.83	14.6	456.3	11.3	178.5	10.5
18/09/2023 08:00	23.8	14.6	454.3	10.9	178.3	10.1
18/09/2023 09:00	23.23	14.6	451.5	10.6	178.1	9.9
18/09/2023 10:00	23.04	14.6	445	10.5	176.7	9.8
18/09/2023 11:00	23.05	14.6	444.1	10.5	176	9.8
18/09/2023 12:00	23.91	14.6	444.3	10.8	175.9	10.1
18/09/2023 13:00	24.98	14.6	445.3	11.3	176	10.6
18/09/2023 14:00	<Samp	<Samp	<Samp	<Samp	174.9	<Samp
18/09/2023 15:00	<Samp	<Samp	<Samp	<Samp	174.7	<Samp
18/09/2023 16:00	Maintain	Maintain	Alarm	Maintain	174.1	Maintain
18/09/2023 17:00	Maintain	Maintain	Alarm	Maintain	173.3	Maintain
18/09/2023 18:00	Maintain	Maintain	Alarm	Maintain	174.6	Maintain
18/09/2023 19:00	Maintain	Maintain	Alarm	Maintain	177.5	Maintain
18/09/2023 20:00	Maintain	Maintain	Alarm	Maintain	177.6	Maintain
18/09/2023 21:00	Maintain	Maintain	Alarm	Maintain	177.3	Maintain
18/09/2023 22:00	<Samp	<Samp	<Samp	<Samp	178	<Samp
18/09/2023 23:00	24.01	14.6	453.2	10.9	178.7	10.2
19/09/2023 00:00	25.11	14.6	453.4	11.4	178.8	10.7
19/09/2023 01:00	25.35	14.6	453.9	11.6	179	10.8
19/09/2023 02:00	25.39	14.6	455.2	11.6	179	10.8
19/09/2023 03:00	25.78	14.6	453.5	11.8	179.2	10.9
19/09/2023 04:00	25.8	14.6	454.1	11.8	179.3	11
19/09/2023 05:00	26	14.6	454.3	11.9	179.3	11
19/09/2023 06:00	26.05	14.6	454.1	11.9	179.2	11.1
19/09/2023 07:00	25.33	14.6	452.4	11.6	179	10.8
19/09/2023 08:00	25.3	14.6	449.6	11.5	178.7	10.7
19/09/2023 09:00	25.79	14.6	446.2	11.7	178.1	10.9
19/09/2023 10:00	26.88	14.6	444.5	12.1	177.8	11.4
19/09/2023 11:00	25.36	14.6	442.5	11.5	177.4	10.8
19/09/2023 12:00	25.31	14.6	445	11.5	177.6	10.7
19/09/2023 13:00	25.65	14.6	445.4	11.7	177.4	10.9
19/09/2023 14:00	26.05	14.6	442.7	11.9	177.1	11.1
19/09/2023 15:00	25.68	14.6	440.1	11.7	176.9	10.9
19/09/2023 16:00	26.1	14.6	440.5	11.9	176.8	11.1
19/09/2023 17:00	27.64	14.6	445.2	12.6	177.5	11.7
19/09/2023 18:00	27.51	14.6	448.9	12.6	177.7	11.7
19/09/2023 19:00	27.46	14.6	449.9	12.5	177.9	11.7
19/09/2023 20:00	27.97	14.6	451.1	12.8	178	11.9
19/09/2023 21:00	28.05	14.6	452	12.8	178.2	11.9
19/09/2023 22:00	28.05	14.6	452.5	12.8	178.2	11.9
19/09/2023 23:00	28.65	14.6	453.6	13.1	178.5	12.2
20/09/2023 00:00	26.55	14.6	453.7	12.1	178.6	11.3
20/09/2023 01:00	25.14	14.6	453.4	11.5	178.5	10.7
20/09/2023 02:00	25.29	14.6	453.7	11.5	178.5	10.7
20/09/2023 03:00	25.3	14.5	454.2	11.6	178.5	10.7
20/09/2023 04:00	25.47	14.5	453.5	11.6	178.5	10.8
20/09/2023 05:00	25.33	14.5	453.1	11.6	178.6	10.8
20/09/2023 06:00	25	14.6	453.4	11.4	178.7	10.6
20/09/2023 07:00	23.75	14.6	452.2	10.8	178.7	10.1
20/09/2023 08:00	21.53	14.6	448.3	9.8	178.4	9.1
20/09/2023 09:00	18.92	14.6	445.1	8.6	177.6	8
20/09/2023 10:00	20.06	14.6	442	9.1	177.2	8.5
20/09/2023 11:00	21.8	14.6	441.3	9.9	177.2	9.3
20/09/2023 12:00	22.36	14.6	440.1	10.1	177	9.5
20/09/2023 13:00	22.21	14.6	442.9	10.1	176.9	9.4
20/09/2023 14:00	25.73	14.6	454.2	11.7	177.7	10.9
20/09/2023 15:00	24.67	14.6	452.1	11.3	177	10.5

Site Report - GPSC CUP2 HRSBG2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
20/09/2023 16:00	21.16	14.5	450.3	9.7	177.9	9
20/09/2023 17:00	22.79	14.6	454.3	10.4	178.9	9.7
20/09/2023 18:00	22.57	14.6	455.2	10.3	179.1	9.6
20/09/2023 19:00	22.23	14.6	455.4	10.1	179.1	9.4
20/09/2023 20:00	23.79	14.6	455.8	10.8	178.9	10.1
20/09/2023 21:00	21.48	14.6	455.8	9.8	178.7	9.1
20/09/2023 22:00	20.91	14.6	455.7	9.5	178.9	8.9
20/09/2023 23:00	21.01	14.6	455.6	9.6	179.2	8.9
21/09/2023 00:00	23.79	14.6	453.1	10.8	178.8	10.1
21/09/2023 01:00	24.29	14.6	454.3	11.1	178.9	10.3
21/09/2023 02:00	24.57	14.6	455.1	11.2	179.2	10.4
21/09/2023 03:00	24.48	14.6	454.5	11.2	179.1	10.4
21/09/2023 04:00	23.73	14.6	453.9	10.8	178.8	10.1
21/09/2023 05:00	23.72	14.6	453.8	10.8	178.5	10.1
21/09/2023 06:00	24.13	14.6	454.8	11	178.8	10.2
21/09/2023 07:00	23.79	14.6	454	10.9	178.9	10.1
21/09/2023 08:00	23.32	14.6	452	10.6	178.5	9.9
21/09/2023 09:00	22.73	14.6	448.8	10.3	178.2	9.6
21/09/2023 10:00	22.7	14.6	445	10.3	177.5	9.6
21/09/2023 11:00	23.12	14.6	443	10.5	177.2	9.8
21/09/2023 12:00	23.89	14.6	442	10.8	177.2	10.1
21/09/2023 13:00	23.65	14.6	439.2	10.7	176.6	10
21/09/2023 14:00	25.29	14.6	444.9	11.5	176.5	10.7
21/09/2023 15:00	28.73	14.6	455.5	13.1	177.9	12.2
21/09/2023 16:00	28.43	14.6	456.4	12.9	177.6	12.1
21/09/2023 17:00	25.64	14.6	455.8	11.7	178.1	10.9
21/09/2023 18:00	24.04	14.6	456.6	10.9	178.4	10.2
21/09/2023 19:00	23.91	14.6	453.6	10.9	178.5	10.1
21/09/2023 20:00	21.42	14.5	448.9	9.8	177.9	9.1
21/09/2023 21:00	21.24	14.5	450.2	9.8	178.4	9
21/09/2023 22:00	21.8	14.5	451.5	10	178.1	9.3
21/09/2023 23:00	22.27	14.5	453.3	10.2	178.6	9.5
22/09/2023 00:00	24.62	14.6	456.1	11.2	179.2	10.5
22/09/2023 01:00	24.02	14.6	456.1	10.9	179.2	10.2
22/09/2023 02:00	24.34	14.6	456.3	11.1	179.5	10.3
22/09/2023 03:00	24.32	14.6	456.5	11.1	179.5	10.3
22/09/2023 04:00	24.14	14.6	456.5	11	179.2	10.2
22/09/2023 05:00	23.77	14.6	456.3	10.9	179.2	10.1
22/09/2023 06:00	22.71	14.5	454.1	10.4	179.1	9.6
22/09/2023 07:00	22.07	14.6	455.3	10.1	179.1	9.4
22/09/2023 08:00	21.12	14.6	453.7	9.6	179	9
22/09/2023 09:00	19.59	14.6	451.5	8.9	178.8	8.3
22/09/2023 10:00	19.46	14.6	448.8	8.8	178.4	8.3
22/09/2023 11:00	18.99	14.6	445.9	8.6	178	8.1
22/09/2023 12:00	19.19	14.6	444.2	8.7	177.7	8.1
22/09/2023 13:00	18.23	14.6	442.9	8.3	177.4	7.7
22/09/2023 14:00	18.81	14.6	441.5	8.6	176.8	8
22/09/2023 15:00	19.46	14.6	441.6	8.9	176.6	8.3
22/09/2023 16:00	19.95	14.6	442.7	9.1	176.8	8.5
22/09/2023 17:00	20.71	14.6	445.2	9.4	177.3	8.8
22/09/2023 18:00	22.94	14.6	445.9	10.4	177.4	9.7
22/09/2023 19:00	24.5	14.6	446.7	11.1	177.7	10.4
22/09/2023 20:00	24.44	14.6	470.2	11.1	178.2	10.4
22/09/2023 21:00	23.82	14.6	511.4	10.9	178.7	10.1
22/09/2023 22:00	23.47	14.6	529.6	10.7	178.8	10
22/09/2023 23:00	24.04	14.6	527.9	11	179.1	10.2
23/09/2023 00:00	24.35	14.6	517.3	11.1	179.1	10.3
23/09/2023 01:00	24.83	14.5	508.3	11.3	179	10.5
23/09/2023 02:00	25.13	14.5	502.2	11.5	179	10.7

Site Report - GPSC CUP2 HRSBG2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
23/09/2023 03:00	25.27	14.5	498.4	11.5	179	10.7
23/09/2023 04:00	25.67	14.5	488.8	11.7	179	10.9
23/09/2023 05:00	25.73	14.5	464.7	11.8	179	10.9
23/09/2023 06:00	25.23	14.5	453.9	11.5	179	10.7
23/09/2023 07:00	24.51	14.5	463.4	11.2	178.8	10.4
23/09/2023 08:00	23.76	14.6	449.9	10.8	178.6	10.1
23/09/2023 09:00	23.91	14.6	449.4	10.9	178.1	10.1
23/09/2023 10:00	23.95	14.6	444.7	10.9	177.6	10.2
23/09/2023 11:00	23.98	14.6	443	10.9	177.3	10.2
23/09/2023 12:00	25.14	14.6	439.1	11.4	176.3	10.7
23/09/2023 13:00	26.03	14.6	438.7	11.8	176	11
23/09/2023 14:00	26.48	14.6	440.2	12	176	11.2
23/09/2023 15:00	27.58	14.6	444.3	12.5	176.8	11.7
23/09/2023 16:00	27.33	14.6	442.2	12.4	176.7	11.6
23/09/2023 17:00	28.19	14.6	443.9	12.8	176.9	12
23/09/2023 18:00	27.54	14.6	444.6	12.5	176.6	11.7
23/09/2023 19:00	27.57	14.6	449.7	12.6	177.6	11.7
23/09/2023 20:00	27.57	14.6	450.4	12.6	177.9	11.7
23/09/2023 21:00	28.19	14.6	451.5	12.8	178.7	12
23/09/2023 22:00	28.23	14.6	451.8	12.9	178.9	12
23/09/2023 23:00	28.64	14.6	451.9	13.1	178.9	12.2
24/09/2023 00:00	28.48	14.6	452.1	13	178.9	12.1
24/09/2023 01:00	28.68	14.5	451.5	13.1	178.8	12.2
24/09/2023 02:00	29.88	14.6	451.5	13.6	178.8	12.7
24/09/2023 03:00	28.56	14.5	451.4	13	178.7	12.1
24/09/2023 04:00	27.65	14.5	452.1	12.7	178.7	11.7
24/09/2023 05:00	27.44	14.5	452.6	12.6	178.9	11.6
24/09/2023 06:00	26.87	14.5	452.9	12.3	178.9	11.4
24/09/2023 07:00	24.87	14.5	450.4	11.4	178.6	10.6

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
28/09/2023 01:00	27.49	14.6	447.8	12.5	176.9	11.7
28/09/2023 02:00	28.04	14.6	447.3	12.8	176.8	11.9
28/09/2023 03:00	28.39	14.6	447.8	12.9	176.8	12
28/09/2023 04:00	28.46	14.6	447.8	13	176.6	12.1
28/09/2023 05:00	28.27	14.6	447.4	12.9	176.4	12
28/09/2023 06:00	28.35	14.6	448.1	12.9	176.8	12
28/09/2023 07:00	27.8	14.6	447.4	12.7	176.7	11.8
28/09/2023 08:00	27.22	14.6	446.1	12.4	176.6	11.6
28/09/2023 09:00	27.12	14.6	445.9	12.3	176.4	11.5
28/09/2023 10:00	27.12	14.6	445.4	12.3	176.1	11.5
28/09/2023 11:00	27.16	14.6	445.3	12.4	176.1	11.5
28/09/2023 12:00	27.53	14.6	444.7	12.5	176.1	11.7
28/09/2023 13:00	27.07	14.6	441.8	12.3	175.3	11.5
28/09/2023 14:00	28.52	14.6	443.2	13	175.5	12.1
28/09/2023 15:00	28.79	14.6	444.3	13.1	175.7	12.2
28/09/2023 16:00	29.1	14.6	444.9	13.2	176.2	12.4
28/09/2023 17:00	29.49	14.6	445.6	13.4	176.3	12.5
28/09/2023 18:00	29.52	14.6	446.2	13.4	176.4	12.5
28/09/2023 19:00	26.55	14.6	447.8	12.1	176.4	11.3
28/09/2023 20:00	25.25	14.6	455.5	11.5	177.4	10.7
28/09/2023 21:00	24.36	14.6	455.7	11.1	178.3	10.3
28/09/2023 22:00	23.82	14.6	454.8	10.9	178.9	10.1
28/09/2023 23:00	23.94	14.6	455.5	10.9	179.2	10.2
29/09/2023 00:00	23.72	14.6	453.5	10.8	178.6	10.1
29/09/2023 01:00	24.12	14.6	455	11	179.3	10.2
29/09/2023 02:00	23.93	14.6	455.1	10.9	179.2	10.2
29/09/2023 03:00	23.62	14.5	453.9	10.8	179.3	10
29/09/2023 04:00	24.23	14.6	454.4	11.1	179.2	10.3
29/09/2023 05:00	24.23	14.5	455.2	11.1	179.2	10.3
29/09/2023 06:00	24.2	14.6	455.4	11.1	179.6	10.3
29/09/2023 07:00	23.32	14.6	451.8	10.6	179	9.9
29/09/2023 08:00	23.12	14.6	446.3	10.5	177.6	9.8
29/09/2023 09:00	22.65	14.6	445.4	10.3	177.2	9.6
29/09/2023 10:00	22.36	14.6	444.2	10.2	176.5	9.5
29/09/2023 11:00	22.55	14.6	442.9	10.2	176.3	9.6
29/09/2023 12:00	22.71	14.6	443.7	10.3	176.3	9.6
29/09/2023 13:00	22.19	14.6	443.7	10.1	176.6	9.4
29/09/2023 14:00	23.82	14.5	444.5	11	175.9	10.1
29/09/2023 15:00	25.28	14.5	443	11.6	174.9	10.7
29/09/2023 16:00	26.02	14.5	444.3	12	175.3	11
29/09/2023 17:00	26.9	14.5	444.9	12.4	175.2	11.4
29/09/2023 18:00	28.45	14.5	451.6	13.1	176.1	12.1
29/09/2023 19:00	28.36	14.5	453.4	13	177.1	12
29/09/2023 20:00	27.33	14.5	453.2	12.5	177.8	11.6
29/09/2023 21:00	27.02	14.5	454	12.4	178.2	11.5
29/09/2023 22:00	25.99	14.5	453.4	11.9	178.6	11
29/09/2023 23:00	26	14.5	453.7	11.9	178.5	11
30/09/2023 00:00	25.93	14.5	453.3	11.9	178.3	11
30/09/2023 01:00	26.03	14.5	452.8	12	178.4	11
30/09/2023 02:00	26.23	14.5	453	12.1	178.3	11.1
30/09/2023 03:00	26.72	14.5	452.5	12.3	178.4	11.3
30/09/2023 04:00	27.76	14.5	453.7	12.8	179	11.8
30/09/2023 05:00	28.25	14.5	453.2	13	179	12
30/09/2023 06:00	25.08	14.5	452.9	11.5	178.7	10.6
30/09/2023 07:00	24.1	14.5	452	11.1	178.3	10.2
30/09/2023 08:00	24.46	14.5	446.7	11.2	176.6	10.4
30/09/2023 09:00	24.37	14.5	445.6	11.2	176.1	10.3
30/09/2023 10:00	24.15	14.5	444.4	11.1	176	10.2
30/09/2023 11:00	24.55	14.5	445.2	11.3	175.8	10.4

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
30/09/2023 12:00	24.93	14.5	442.7	11.4	175.5	10.6
30/09/2023 13:00	25.3	14.5	441.7	11.6	175.2	10.7
30/09/2023 14:00	25.54	14.5	441.7	11.7	175	10.8
30/09/2023 15:00	26.03	14.5	441.6	11.9	175.3	11
30/09/2023 16:00	26.69	14.5	442.9	12.3	174.9	11.3
30/09/2023 17:00	27.51	14.5	444.7	12.6	175.4	11.7
30/09/2023 18:00	28.65	14.5	448.6	13.2	176.5	12.2
30/09/2023 19:00	28.67	14.5	451	13.2	177	12.2
30/09/2023 20:00	28.98	14.5	452.1	13.3	177.3	12.3
30/09/2023 21:00	29.16	14.5	451.9	13.4	177.1	12.4
30/09/2023 22:00	29.06	14.5	452.5	13.4	177.2	12.3
30/09/2023 23:00	28.96	14.5	452.9	13.4	177.4	12.3
Minimum	5.4	13.1	350.4	2.3	109.7	2.3
MinDate	17/09/2023 11:00	01/09/2023 13:00	17/09/2023 12:00	17/09/2023 11:00	12/09/2023 23:00	17/09/2023 11:00
Maximum	30.23	15.7	529.6	16.2	192.7	12.8
MaxDate	26/09/2023 03:00	17/09/2023 10:00	22/09/2023 22:00	06/09/2023 13:00	12/09/2023 22:00	04/09/2023 01:00
Avg	25.27	14.3	445.4	12.2	170.6	10.7
Num	701	701	701	701	720	701
Data[%]	97.2	97.2	97.2	97.2	99.9	97.2
STD	3.4	0.5	16.9	1.9	9.8	1.4

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
01/10/2023 00:00	27.17	14.5	452.8	12.5	177.7	11.5
01/10/2023 01:00	26.01	14.5	452.3	12	177.3	11
01/10/2023 02:00	25.97	14.5	453.1	12	177.1	11
01/10/2023 03:00	26.15	14.5	453.6	12.1	177.2	11.1
01/10/2023 04:00	26.43	14.5	453.4	12.2	177.4	11.2
01/10/2023 05:00	26.24	14.5	454.2	12.1	177.6	11.1
01/10/2023 06:00	25.84	14.5	454.4	11.9	178.3	11
01/10/2023 07:00	25.42	14.5	453.2	11.7	177.8	10.8
01/10/2023 08:00	25.23	14.5	450.3	11.6	177.5	10.7
01/10/2023 09:00	24.81	14.5	447.6	11.4	177.1	10.5
01/10/2023 10:00	25.04	14.5	446	11.5	176.7	10.6
01/10/2023 11:00	23.8	14.5	443.4	10.9	176.4	10.1
01/10/2023 12:00	22.87	14.5	440.4	10.5	175.3	9.7
01/10/2023 13:00	22.83	14.5	440.6	10.5	174.7	9.7
01/10/2023 14:00	24.87	14.5	442.9	11.5	174.9	10.6
01/10/2023 15:00	26.95	14.5	445	12.5	175.3	11.4
01/10/2023 16:00	27.48	14.5	447.9	12.7	176.3	11.7
01/10/2023 17:00	26.54	14.5	449.2	13.2	176.5	12.1
01/10/2023 18:00	26.44	14.5	450.3	13.1	176.7	12.1
01/10/2023 19:00	27.63	14.5	450.5	12.8	176.9	11.7
01/10/2023 20:00	27.44	14.5	451	12.7	177.1	11.6
01/10/2023 21:00	27.98	14.5	449.8	12.9	176.9	11.9
01/10/2023 22:00	28.01	14.5	450.5	12.9	177	11.9
01/10/2023 23:00	28.33	14.5	448.5	13.1	176.4	12
02/10/2023 00:00	25.36	14.5	448.9	11.7	176.2	10.8
02/10/2023 01:00	23.66	14.5	451.3	11	176.9	10
02/10/2023 02:00	24.6	14.5	453.3	11.3	177	10.4
02/10/2023 03:00	24.33	14.5	444.7	11.2	175.7	10.3
02/10/2023 04:00	26.58	14.5	451	12.2	177.3	11.3
02/10/2023 05:00	26.28	14.5	452	12.1	177.8	11.2
02/10/2023 06:00	25.17	14.5	451.6	11.6	178	10.7
02/10/2023 07:00	24.64	14.5	452.4	11.3	178.1	10.5
02/10/2023 08:00	25.04	14.5	453.4	11.5	177.7	10.6
02/10/2023 09:00	23.92	14.5	451.9	11	177.3	10.2
02/10/2023 10:00	23.2	14.5	448.7	10.7	176.9	9.8
02/10/2023 11:00	24.54	14.5	448.7	11.3	176.5	10.4
02/10/2023 12:00	25.56	14.5	447.2	11.8	176.2	10.8
02/10/2023 13:00	25.79	14.5	446.3	11.9	176	10.9
02/10/2023 14:00	25.77	14.5	445.9	11.9	175.9	10.9
02/10/2023 15:00	26.3	14.5	446	12.1	175.8	11.2
02/10/2023 16:00	27.97	14.5	446.2	12.8	175.9	11.9
02/10/2023 17:00	28.08	14.5	446.3	12.9	176	11.9
02/10/2023 18:00	27.63	14.5	448.7	12.7	176.4	11.7
02/10/2023 19:00	28.14	14.5	450	13	176.8	11.9
02/10/2023 20:00	28.24	14.5	451.1	13	176.8	12
02/10/2023 21:00	24.14	14.5	451.9	11.1	176.9	10.2
02/10/2023 22:00	23.42	14.5	451.8	10.8	176.8	9.9
02/10/2023 23:00	24.13	14.5	452.1	11.1	177	10.2
03/10/2023 00:00	24.38	14.5	452.2	11.3	176.9	10.3
03/10/2023 01:00	24.31	14.5	452	11.2	176.9	10.3
03/10/2023 02:00	24.62	14.5	451.8	11.4	176.9	10.5
03/10/2023 03:00	25.01	14.5	452.7	11.6	177	10.6
03/10/2023 04:00	24.82	14.5	453.4	11.5	177.6	10.5
03/10/2023 05:00	24.34	14.5	453.2	11.3	178	10.3
03/10/2023 06:00	24.41	14.5	453.5	11.3	177.8	10.4
03/10/2023 07:00	23.83	14.5	453.4	11	177.7	10.1
03/10/2023 08:00	24.64	14.5	450.3	11.4	177.2	10.5
03/10/2023 09:00	25.76	14.5	448.5	11.9	177	10.9
03/10/2023 10:00	25.9	14.5	446.9	11.9	176.1	11

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
03/10/2023 11:00	28.43	14.5	448.3	13.1	176	12.1
03/10/2023 12:00	25.65	14.5	452.5	11.8	175.8	10.9
03/10/2023 13:00	23.92	14.5	452	11.1	175.5	10.2
03/10/2023 14:00	21.72	14.5	451.9	10	175.3	9.2
03/10/2023 15:00	21.66	14.5	452.3	10	169.9	9.2
03/10/2023 16:00	23.6	14.5	451.2	10.9	177.4	10
03/10/2023 17:00	29.61	14.5	452.2	13.7	177.5	12.6
03/10/2023 18:00	30.08	14.5	452.7	13.9	177.6	12.8
03/10/2023 19:00	26.86	14.5	453.2	12.4	177.7	11.4
03/10/2023 20:00	26.01	14.5	453.9	12	177.9	11
03/10/2023 21:00	26.02	14.5	453.9	12	178	11
03/10/2023 22:00	26.32	14.5	453.6	12.1	178.6	11.2
03/10/2023 23:00	26.41	14.5	453.6	12.1	178.7	11.2
04/10/2023 00:00	27.04	14.5	453.1	12.4	178.2	11.5
04/10/2023 01:00	27.8	14.5	453.4	12.7	178	11.8
04/10/2023 02:00	27.81	14.5	453.7	12.8	178.1	11.8
04/10/2023 03:00	27.17	14.5	453	12.5	178	11.5
04/10/2023 04:00	27.05	14.5	452.2	12.4	177.7	11.5
04/10/2023 05:00	26.67	14.5	452.4	12.2	177.7	11.3
04/10/2023 06:00	25.84	14.5	452.8	11.9	178	11
04/10/2023 07:00	25.43	14.5	453.4	11.7	178.1	10.8
04/10/2023 08:00	25.02	14.5	454	11.5	177.9	10.6
04/10/2023 09:00	23.82	14.5	450.8	11	177.2	10.1
04/10/2023 10:00	24.16	14.5	449.6	11.1	176.9	10.3
04/10/2023 11:00	25.03	14.5	450.4	11.5	176.9	10.6
04/10/2023 12:00	25.88	14.5	451.3	11.9	176.7	11
04/10/2023 13:00	25.28	14.5	450.4	11.7	176.9	10.7
04/10/2023 14:00	25.76	14.5	449.6	11.9	176.4	10.9
04/10/2023 15:00	25.23	14.5	448.6	11.7	176.3	10.7
04/10/2023 16:00	26.75	14.5	448.8	12.4	176.8	11.4
04/10/2023 17:00	27.04	14.5	451.8	12.5	176.2	11.5
04/10/2023 18:00	25.69	14.5	452.6	11.9	176.8	10.9
04/10/2023 19:00	24.54	14.5	452.7	11.3	176.9	10.4
04/10/2023 20:00	24.09	14.5	452.9	11.1	177.1	10.2
04/10/2023 21:00	23.65	14.5	453	10.9	177.4	10
04/10/2023 22:00	23.65	14.5	452.8	10.9	177.3	10
04/10/2023 23:00	23.76	14.5	453.4	11	177.5	10.1
05/10/2023 00:00	23.97	14.5	453.6	11.1	177.9	10.2
05/10/2023 01:00	24.56	14.5	453.8	11.3	178.2	10.4
05/10/2023 02:00	25.02	14.5	454.2	11.5	178.1	10.6
05/10/2023 03:00	25.14	14.5	453.6	11.6	178.2	10.7
05/10/2023 04:00	25.44	14.5	453.9	11.7	178	10.8
05/10/2023 05:00	25.41	14.5	454	11.7	177.7	10.8
05/10/2023 06:00	25.29	14.5	454	11.7	177.5	10.7
05/10/2023 07:00	24.82	14.5	452.7	11.5	177.3	10.5
05/10/2023 08:00	24.19	14.5	450.8	11.2	177	10.3
05/10/2023 09:00	23.8	14.5	449.7	11	176.9	10.1
05/10/2023 10:00	23.59	14.5	447.9	10.9	176.6	10
05/10/2023 11:00	24.8	14.5	448.4	11.5	176.8	10.5
05/10/2023 12:00	25.86	14.5	450.8	12	177.1	11
05/10/2023 13:00	27.92	14.5	451.4	12.9	176.9	11.9
05/10/2023 14:00	26.13	14.5	451.9	13	176.8	11.9
05/10/2023 15:00	26.26	14.5	451.7	12.2	177.1	11.1
05/10/2023 16:00	25.67	14.5	447.1	11.9	176.4	10.9
05/10/2023 17:00	25.6	14.5	447	11.9	176.1	10.9
05/10/2023 18:00	26.1	14.5	447.5	12.1	176.2	11.1
05/10/2023 19:00	26.45	14.5	447.6	12.2	176.3	11.2
05/10/2023 20:00	26.46	14.5	448.1	12.2	176.3	11.2
05/10/2023 21:00	26.44	14.5	448	12.2	176.1	11.2

Site Report - GPSC CUP2 HRSg2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
05/10/2023 22:00	25.61	14.5	447.1	11.8	175.3	10.9
05/10/2023 23:00	25.74	14.5	449.1	11.9	175.2	10.9
06/10/2023 00:00	26.81	14.5	450	12.4	176.3	11.4
06/10/2023 01:00	27.54	14.5	448.6	12.7	176.2	11.7
06/10/2023 02:00	27.76	14.5	448.7	12.8	176.3	11.8
06/10/2023 03:00	27.67	14.5	448.3	12.8	176.1	11.7
06/10/2023 04:00	27.97	14.5	447.8	12.9	175.6	11.9
06/10/2023 05:00	27.91	14.5	448.1	12.9	175.7	11.8
06/10/2023 06:00	27.73	14.5	450.4	12.8	176.5	11.8
06/10/2023 07:00	26.3	14.5	451.2	12.2	177.1	11.2
06/10/2023 08:00	26.22	14.5	447.5	12.1	176.1	11.1
06/10/2023 09:00	25.33	14.5	445.1	11.7	175.7	10.8
06/10/2023 10:00	23.85	14.5	442.5	11	175.3	10.1
06/10/2023 11:00	21.35	14.5	442.2	9.8	175.2	9.1
06/10/2023 12:00	22.38	14.5	442.8	10.3	175	9.5
06/10/2023 13:00	23.86	14.5	444.1	11	175	10.1
06/10/2023 14:00	25	14.5	445.6	11.5	175.3	10.6
06/10/2023 15:00	25.55	14.5	445.7	11.8	175.5	10.8
06/10/2023 16:00	26.01	14.5	445.5	12	175.6	11
06/10/2023 17:00	25.77	14.5	446.3	11.9	175.8	10.9
06/10/2023 18:00	25.87	14.5	446.7	12	175.8	11
06/10/2023 19:00	25.94	14.5	447.1	12	175.9	11
06/10/2023 20:00	25.96	14.5	447.3	12	176.1	11
06/10/2023 21:00	26.08	14.5	449.1	12.1	176.6	11.1
06/10/2023 22:00	25.82	14.5	451.3	12	177.2	11
06/10/2023 23:00	26.42	14.5	452.2	12.2	177.5	11.2
07/10/2023 00:00	24.33	14.5	452.5	11.3	177.4	10.3
07/10/2023 01:00	23.86	14.5	452.1	11	177.3	10.1
07/10/2023 02:00	24.67	14.5	453.1	11.4	177.5	10.5
07/10/2023 03:00	25.36	14.5	452.3	11.7	177.3	10.8
07/10/2023 04:00	25.79	14.5	452.6	11.9	177.2	10.9
07/10/2023 05:00	25.42	14.5	453.9	11.7	177.9	10.8
07/10/2023 06:00	25.29	14.5	453.5	11.7	178	10.7
07/10/2023 07:00	24.07	14.5	451.9	11.1	177.7	10.2
07/10/2023 08:00	23.07	14.5	449.6	10.6	177.1	9.8
07/10/2023 09:00	22.78	14.5	447.1	10.5	176.7	9.7
07/10/2023 10:00	22.57	14.5	444.5	10.4	176.1	9.6
07/10/2023 11:00	22.42	14.5	444.9	10.3	175.8	9.5
07/10/2023 12:00	24.21	14.5	450.8	11.2	176.9	10.3
07/10/2023 13:00	23.59	14.5	446	10.9	175.9	10
07/10/2023 14:00	25.15	14.5	445.6	11.6	175.4	10.7
07/10/2023 15:00	25.37	14.5	445.3	11.7	175.6	10.8
07/10/2023 16:00	25.65	14.5	445.6	11.8	175.7	10.9
07/10/2023 17:00	26.31	14.5	446.8	12.2	175.8	11.2
07/10/2023 18:00	26.61	14.5	448	12.3	175.8	11.3
07/10/2023 19:00	27.52	14.5	450.4	12.7	176.1	11.7
07/10/2023 20:00	24.48	14.5	452.4	11.3	176.9	10.4
07/10/2023 21:00	24.26	14.5	452.1	11.2	177.2	10.3
07/10/2023 22:00	24.16	14.5	452	11.1	177.3	10.3
07/10/2023 23:00	24.18	14.5	453.4	11.2	177.7	10.3
08/10/2023 00:00	24.31	14.5	452.9	11.2	177.8	10.3
08/10/2023 01:00	24.43	14.5	453.3	11.3	177.8	10.4
08/10/2023 02:00	24.33	14.5	453.9	11.2	178.1	10.3
08/10/2023 03:00	24.69	14.5	454.6	11.4	178.3	10.5
08/10/2023 04:00	25.27	14.5	453.8	11.7	178.1	10.7
08/10/2023 05:00	24.85	14.5	454.2	11.5	178.3	10.5
08/10/2023 06:00	24.65	14.5	454.4	11.4	178.7	10.5
08/10/2023 07:00	23.8	14.5	452.6	11	178	10.1
08/10/2023 08:00	23.16	14.5	447.5	10.7	176.9	9.8

Site Report - GPSC CUP2 HRSg2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
08/10/2023 09:00	22.79	14.5	446.3	10.5	176.5	9.7
08/10/2023 10:00	21.83	14.5	445.1	10	176.4	9.3
08/10/2023 11:00	21.92	14.5	444.6	10.1	176.1	9.3
08/10/2023 12:00	25.01	14.5	447.7	11.5	176.5	10.6
08/10/2023 13:00	25.04	14.5	446.1	11.5	176.4	10.6
08/10/2023 14:00	24.97	14.5	445.9	11.5	176.1	10.6
08/10/2023 15:00	25.72	14.5	447.3	11.9	176.4	10.9
08/10/2023 16:00	26.92	14.5	447.6	12.4	176.4	11.4
08/10/2023 17:00	26.81	14.5	447.6	12.4	176.4	11.4
08/10/2023 18:00	26.47	14.5	447.4	12.2	176.4	11.2
08/10/2023 19:00	26.58	14.5	448.4	12.3	176.5	11.3
08/10/2023 20:00	27.26	14.5	449	12.6	176.8	11.6
08/10/2023 21:00	27.33	14.5	450.7	12.6	177.2	11.6
08/10/2023 22:00	28.25	14.5	451.6	13	177.2	12
08/10/2023 23:00	28.48	14.5	453.6	13.1	177.6	12.1
09/10/2023 00:00	28.95	14.5	453.8	13.3	177.9	12.3
09/10/2023 01:00	29.85	14.5	453.5	13.8	177.7	12.7
09/10/2023 02:00	25.65	14.5	453.5	11.8	177.7	10.9
09/10/2023 03:00	23.56	14.5	453.7	10.8	177.7	10
09/10/2023 04:00	23.09	14.5	453.6	10.6	178.1	9.8
09/10/2023 05:00	21.99	14.5	455.1	10.1	178.5	9.3
09/10/2023 06:00	21.15	14.5	454.4	9.7	178.6	9
09/10/2023 07:00	21.01	14.5	454.6	9.7	178.6	8.9
09/10/2023 08:00	21.65	14.5	453.6	10	177.8	9.2
09/10/2023 09:00	21.92	14.5	451.8	10.1	177.8	9.3
09/10/2023 10:00	22.7	14.5	448.5	10.4	177.2	9.6
09/10/2023 11:00	22.59	14.5	448.5	10.4	177.3	9.6
09/10/2023 12:00	24.69	14.5	444.9	11.4	176.6	10.5
09/10/2023 13:00	27.73	14.5	443.9	12.7	176	11.8
09/10/2023 14:00	27.63	14.5	442.5	12.7	175.7	11.7
09/10/2023 15:00	26.85	14.5	441.3	12.3	175.3	11.4
09/10/2023 16:00	27.44	14.5	443	12.6	175.3	11.6
09/10/2023 17:00	27.58	14.5	444.4	12.7	175.4	11.7
09/10/2023 18:00	28.63	14.5	447.4	13.2	176.1	12.2
09/10/2023 19:00	27.04	14.5	448.4	12.5	176.3	11.5
09/10/2023 20:00	25.5	14.5	448.8	11.8	176.5	10.8
09/10/2023 21:00	24.77	14.5	452.1	11.5	177.3	10.5
09/10/2023 22:00	25.2	14.5	452.8	11.7	177.5	10.7
09/10/2023 23:00	25.43	14.5	453.2	11.8	177.8	10.8
10/10/2023 00:00	25.83	14.5	454.3	11.9	177.8	11
10/10/2023 01:00	25.95	14.5	454.3	12	177.9	11
10/10/2023 02:00	27.52	14.5	454.9	12.7	178.1	11.7
10/10/2023 03:00	28.28	14.5	454.3	13	177.9	12
10/10/2023 04:00	28.07	14.5	454.3	12.9	178	11.9
10/10/2023 05:00	27.29	14.5	453.6	12.5	178.4	11.6
10/10/2023 06:00	26.36	14.5	453.2	12.1	178.6	11.2
10/10/2023 07:00	25.02	14.5	452.4	11.5	178.1	10.6
10/10/2023 08:00	24.28	14.5	454	11.2	178.2	10.3
10/10/2023 09:00	23.51	14.5	451.7	10.8	177.5	10
10/10/2023 10:00	22.94	14.5	449	10.6	176.7	9.7
10/10/2023 11:00	22.67	14.5	447.9	10.4	176.5	9.6
10/10/2023 12:00	24	14.5	450.4	11.1	176.7	10.2
10/10/2023 13:00	24.74	14.5	449.6	11.4	177	10.5
10/10/2023 14:00	25.85	14.5	447.8	11.9	176.5	11
10/10/2023 15:00	27.22	14.5	450.6	12.6	177	11.6
10/10/2023 16:00	25.22	14.5	455.1	11.7	176.7	10.7
10/10/2023 17:00	25.03	14.5	468.3	11.6	177.2	10.6
10/10/2023 18:00	27.61	14.5	455.5	12.8	177.3	11.7
10/10/2023 19:00	28.53	14.5	455.2	13.1	178.1	12.1

Site Report - GPSC CUP2 HRSg2						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
10/10/2023 20:00	27.01	14.5	454.8	12.4	178.6	11.5
10/10/2023 21:00	26.35	14.5	465.9	12.1	178.5	11.2
10/10/2023 22:00	26.33	14.5	480.1	12.1	177.9	11.2
10/10/2023 23:00	26.43	14.5	467.2	12.1	177.8	11.2
11/10/2023 00:00	25.87	14.5	454.5	11.9	177.7	11
11/10/2023 01:00	26.69	14.5	454.4	12.3	178.1	11.3
11/10/2023 02:00	27.21	14.5	454.3	12.5	178.1	11.6
11/10/2023 03:00	27.35	14.5	454	12.6	177.7	11.6
11/10/2023 04:00	27.81	14.5	454.4	12.8	178.2	11.8
11/10/2023 05:00	27.3	14.5	454	12.6	178	11.6
11/10/2023 06:00	27.39	14.5	454.2	12.6	178.2	11.6
11/10/2023 07:00	26.74	14.5	454	12.3	178.1	11.4
11/10/2023 08:00	26.03	14.5	452.4	12	177.3	11
11/10/2023 09:00	23.9	14.5	449.7	11	177	10.1
11/10/2023 10:00	23.1	14.5	446.3	10.7	176.3	9.8
11/10/2023 11:00	24.07	14.5	446	11.1	176.4	10.2
11/10/2023 12:00	24.44	14.5	442.5	11.3	175.8	10.4
11/10/2023 13:00	25.04	14.5	441.4	11.5	175.4	10.6
11/10/2023 14:00	25.69	14.5	446.2	11.8	176.1	10.9
11/10/2023 15:00	28.02	14.5	450	12.9	176.4	11.9
11/10/2023 16:00	29.13	14.5	452.9	13.5	176.9	12.4
11/10/2023 17:00	25.33	14.5	452.3	11.7	177.1	10.8
11/10/2023 18:00	24.86	14.5	452.9	11.5	177.5	10.6
11/10/2023 19:00	24.86	14.5	453.4	11.5	177.4	10.6
11/10/2023 20:00	24.56	14.5	453.9	11.4	177.7	10.4
11/10/2023 21:00	24.29	14.5	453.9	11.2	178.1	10.3
11/10/2023 22:00	24.25	14.5	454.2	11.2	177.8	10.3
11/10/2023 23:00	24.65	14.5	453.5	11.4	178.4	10.5
12/10/2023 00:00	24.82	14.5	454.4	11.4	178.4	10.5
12/10/2023 01:00	25.18	14.5	454.3	11.6	178.5	10.7
12/10/2023 02:00	25.58	14.5	453.1	11.8	177.9	10.9
12/10/2023 03:00	27.66	14.5	453.4	12.8	177.5	11.7
12/10/2023 04:00	26.42	14.5	454.3	12.2	178.6	11.2
12/10/2023 05:00	26.76	14.5	452.2	12.3	177.2	11.4
12/10/2023 06:00	25.68	14.5	446.8	11.8	176.5	10.9
12/10/2023 07:00	26	14.5	449.6	12	177.5	11
12/10/2023 08:00	25.63	14.5	453.9	11.8	178.2	10.9
12/10/2023 09:00	24.2	14.5	451.7	11.2	177.3	10.3
12/10/2023 10:00	<Samp	<Samp	<Samp	<Samp	176.4	<Samp
12/10/2023 11:00	Maintain	Maintain	Alarm	Maintain	177.1	Maintain
12/10/2023 12:00	Maintain	Maintain	Alarm	Maintain	176.5	Maintain
12/10/2023 13:00	<Samp	<Samp	<Samp	<Samp	176.1	<Samp
12/10/2023 14:00	26.14	14.5	441.6	12.1	175.5	11.1
12/10/2023 15:00	<Samp	<Samp	<Samp	<Samp	165.2	<Samp
12/10/2023 16:00	<Samp	<Samp	<Samp	<Samp	167.8	<Samp
12/10/2023 17:00	27.95	14.2	453.1	13.5	169.4	11.9
12/10/2023 18:00	26.6	14.3	453.6	12.6	172.2	11.3
12/10/2023 19:00	25.21	14.5	454.1	11.6	178.4	10.7
12/10/2023 20:00	24.45	14.5	452.9	11.3	178.3	10.4
12/10/2023 21:00	24.19	14.5	453.6	11.1	178.4	10.3
12/10/2023 22:00	24.16	14.5	453.5	11.1	178.3	10.3
12/10/2023 23:00	24.59	14.5	453.8	11.3	178.1	10.4
13/10/2023 00:00	24.54	14.5	452.8	11.3	178.1	10.4
13/10/2023 01:00	24.86	14.5	453.6	11.5	178.5	10.6
13/10/2023 02:00	25.12	14.5	453.2	11.6	178.5	10.7
13/10/2023 03:00	25.25	14.5	452.7	11.7	178.3	10.7
13/10/2023 04:00	25.27	14.5	453	11.7	178.5	10.7
13/10/2023 05:00	23.97	14.5	452.8	11.1	178.3	10.2
13/10/2023 06:00	22.03	14.5	452.7	10.2	178.1	9.4

Site Report - GPSC CUP2 HRSG2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
15/10/2023 18:00	25.11	14	450.1	12.4	163.6	10.7
15/10/2023 19:00	24.61	14.1	450.7	12.1	164.9	10.4
15/10/2023 20:00	24.39	14.1	450.6	12	165.6	10.4
15/10/2023 21:00	23.93	14.1	449.8	11.7	166.1	10.2
15/10/2023 22:00	24.97	14.1	450	12.2	167.3	10.6
15/10/2023 23:00	25.09	14.2	450.5	12.2	168.1	10.7
16/10/2023 00:00	23.23	14.2	451	11.2	169	9.9
16/10/2023 01:00	22.87	14.2	451.1	11.1	169.2	9.7
16/10/2023 02:00	22.73	14.2	450.7	11	169.1	9.6
16/10/2023 03:00	23.52	14.2	451.3	11.4	169.2	10
16/10/2023 04:00	24.59	14.2	451.7	11.9	169.8	10.4
16/10/2023 05:00	24.92	14.2	451.8	12	169.5	10.6
16/10/2023 06:00	24.35	14.2	451.1	11.8	169.4	10.3
16/10/2023 07:00	24.28	14.2	451.6	11.7	169.5	10.3
16/10/2023 08:00	30.15	14.1	448.9	14.6	168.2	12.8
16/10/2023 09:00	24.06	14.1	446.5	11.7	166.2	10.2
16/10/2023 10:00	23.77	14	443.3	11.7	162.7	10.1
16/10/2023 11:00	24.57	14	441.3	12.1	162.3	10.4
16/10/2023 12:00	25.89	14.1	440.5	12.7	163.6	11
16/10/2023 13:00	25.29	14	439.8	12.5	162.6	10.7
16/10/2023 14:00	<Samp	<Samp	<Samp	<Samp	<Samp	<Samp
16/10/2023 15:00	Maintain	Maintain	Alarm	Maintain	173.1	Maintain
16/10/2023 16:00	Maintain	Maintain	Alarm	Maintain	173	Maintain
16/10/2023 17:00	Maintain	Maintain	Alarm	Maintain	173.9	Maintain
16/10/2023 18:00	<Samp	<Samp	<Samp	<Samp	177	<Samp
16/10/2023 19:00	27.4	14.5	453.7	12.6	177.7	11.6
16/10/2023 20:00	27.64	14.5	453.2	12.7	177.6	11.7
16/10/2023 21:00	27.53	14.5	453	12.7	177.3	11.7
16/10/2023 22:00	27.31	14.5	454.2	12.5	177.4	11.6
16/10/2023 23:00	27.74	14.5	454.5	12.7	177.8	11.8
17/10/2023 00:00	27.95	14.5	454.6	12.8	177.7	11.9
17/10/2023 01:00	28.55	14.5	454.2	13.1	177.7	12.1
17/10/2023 02:00	29	14.5	454.5	13.3	177.6	12.3
17/10/2023 03:00	29.48	14.5	454.5	13.5	177.6	12.5
17/10/2023 04:00	30.08	14.5	455.1	13.8	177.8	12.8
17/10/2023 05:00	30.69	14.5	455	14	177.6	13
17/10/2023 06:00	30.16	14.5	455.2	13.8	177.9	12.8
17/10/2023 07:00	28.72	14.5	453.2	13.2	177.5	12.2
17/10/2023 08:00	27.39	14.5	451.4	12.5	176.9	11.6
17/10/2023 09:00	28.02	14.6	449.7	12.8	176.5	11.9
17/10/2023 10:00	27.97	14.6	448.4	12.8	176.5	11.9
17/10/2023 11:00	28.49	14.6	447.8	13	176.6	12.1
17/10/2023 12:00	29.43	14.6	445.4	13.4	176.3	12.5
17/10/2023 13:00	29.69	14.6	444.9	13.5	176.1	12.6
17/10/2023 14:00	28.44	14.6	443.6	13	176	12.1
17/10/2023 15:00	25.96	14.5	443.2	11.9	175.9	11
17/10/2023 16:00	26.08	14.5	442.4	11.9	175.9	11.1
17/10/2023 17:00	26.84	14.5	443.5	12.3	175.9	11.4
17/10/2023 18:00	26.85	14.5	448.3	12.3	176.5	11.4
17/10/2023 19:00	27.46	14.5	450.9	12.6	176.9	11.7
17/10/2023 20:00	28.25	14.5	452.9	12.9	177.4	12
17/10/2023 21:00	28.74	14.5	453.1	13.1	177.6	12.2
17/10/2023 22:00	25.97	14.5	453.6	11.9	177.6	11
17/10/2023 23:00	24.8	14.5	452.3	11.4	177.4	10.5
18/10/2023 00:00	26.79	14.5	451.1	12.3	177.4	11.4
18/10/2023 01:00	26.92	14.5	453.2	12.3	177.5	11.4
18/10/2023 02:00	26.83	14.5	454.4	12.3	177.7	11.4
18/10/2023 03:00	26.93	14.5	454.9	12.3	177.9	11.4
18/10/2023 04:00	27.65	14.6	455.8	12.6	178.4	11.7

Site Report - GPSC CUP2 HRSG2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
18/10/2023 05:00	27.56	14.6	456	12.6	178.5	11.7
18/10/2023 06:00	26.59	14.5	455.9	12.1	178.6	11.3
18/10/2023 07:00	26.76	14.5	454.2	12.3	178.1	11.4
18/10/2023 08:00	25.87	14.5	452.4	11.9	177.6	11
18/10/2023 09:00	24.85	14.5	449.5	11.4	177.1	10.5
18/10/2023 10:00	26.5	14.6	447.2	12.1	176.7	11.2
18/10/2023 11:00	26.25	14.5	447.7	12	176.3	11.1
18/10/2023 12:00	26.53	14.6	453.8	12.1	176	11.3
18/10/2023 13:00	26.63	14.6	452.6	12.2	177.5	11.3
18/10/2023 14:00	27.02	14.5	453.7	12.4	178.1	11.5
18/10/2023 15:00	27.7	14.5	453.6	12.7	177.7	11.8
18/10/2023 16:00	28.11	14.5	453.9	12.9	177.6	11.9
18/10/2023 17:00	29.06	14.5	455.2	13.3	177.9	12.3
18/10/2023 18:00	29.31	14.6	455.6	13.4	178	12.4
18/10/2023 19:00	29.07	14.6	456.1	13.3	178.5	12.3
18/10/2023 20:00	29.68	14.5	455	13.6	177.9	12.6
18/10/2023 21:00	28.25	14.6	455	12.9	178.6	12
18/10/2023 22:00	27.94	14.6	455.4	12.7	178.6	11.9
18/10/2023 23:00	27.82	14.6	455.7	12.7	178.8	11.8
19/10/2023 00:00	27.79	14.6	455.6	12.7	178.9	11.8
19/10/2023 01:00	28.19	14.5	455.6	12.9	178.5	12
19/10/2023 02:00	28.56	14.5	455.2	13.1	178.3	12.1
19/10/2023 03:00	28.85	14.5	455.1	13.2	178.4	12.2
19/10/2023 04:00	29.39	14.5	455.2	13.4	178	12.5
19/10/2023 05:00	28.99	14.5	455.2	13.2	178.1	12.3
19/10/2023 06:00	28.4	14.5	455	13	178	12.1
19/10/2023 07:00	28	14.5	455.5	12.8	177.8	11.9
19/10/2023 08:00	27.23	14.5	452.1	12.5	176.9	11.6
19/10/2023 09:00	26.48	14.5	450.8	12.1	176.7	11.2
19/10/2023 10:00	27.51	14.5	449.3	12.6	176.5	11.7
19/10/2023 11:00	22.59	14.5	450.9	10.4	175.1	9.6
19/10/2023 12:00	17.29	14.3	452.3	8.3	168.7	7.3
19/10/2023 13:00	19.99	14.2	450.7	9.6	168.5	8.5
19/10/2023 14:00	20.58	14.2	449.5	9.9	168.8	8.7
19/10/2023 15:00	25.66	14.5	449.3	11.8	175.8	10.9
19/10/2023 16:00	25.26	14.5	448.7	11.6	176.6	10.7
19/10/2023 17:00	25.33	14.5	449.8	11.6	176.9	10.8
19/10/2023 18:00	25.22	14.5	451.7	11.6	177.2	10.7
19/10/2023 19:00	25.42	14.5	453.3	11.7	177.3	10.8
19/10/2023 20:00	25.36	14.5	453.6	11.7	177.3	10.8
19/10/2023 21:00	25.65	14.5	455	11.8	177.8	10.9
19/10/2023 22:00	25.58	14.5	455.5	11.7	178.1	10.9
19/10/2023 23:00	25.71	14.5	456.3	11.8	178.4	10.9
20/10/2023 00:00	26.02	14.5	456.2	11.9	178.4	11
20/10/2023 01:00	26.66	14.5	455.5	12.2	178.3	11.3
20/10/2023 02:00	27.03	14.5	455	12.4	178.2	11.5
20/10/2023 03:00	27.72	14.5	455.3	12.7	178.2	11.8
20/10/2023 04:00	27.7	14.5	455.3	12.7	178.1	11.8
20/10/2023 05:00	27.36	14.5	455.4	12.5	178.1	11.6
20/10/2023 06:00	26.87	14.5	455.3	12.3	178.2	11.4
20/10/2023 07:00	26.89	14.5	454.6	12.4	177.7	11.4
20/10/2023 08:00	26.59	14.5	451.8	12.2	177.3	11.3
20/10/2023 09:00	27.4	14.5	448.9	12.5	176.8	11.6
20/10/2023 10:00	27.42	14.6	446.6	12.5	176.3	11.6
20/10/2023 11:00	28.23	14.6	444.6	12.9	176.2	12
20/10/2023 12:00	29.97	14.6	443.6	13.6	175.8	12.7
20/10/2023 13:00	27.27	14.5	444.9	12.5	175.7	11.6
20/10/2023 14:00	28.48	14.5	448.7	13	176.2	12.1
20/10/2023 15:00	29.09	14.6	447.5	13.3	176.1	12.3

Site Report - GPSC CUP2 HRSG2						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
20/10/2023 16:00	28.91	14.5	453.8	13.2	176.4	12.3
20/10/2023 17:00	27.96	14.6	453.3	12.7	177.7	11.9
20/10/2023 18:00	28.3	14.6	453.3	12.9	178.1	12
20/10/2023 19:00	28.13	14.6	455.6	12.8	178.3	11.9
20/10/2023 20:00	27.69	14.6	455.7	12.6	178.2	11.8
20/10/2023 21:00	26.72	14.6	455.4	12.2	178.4	11.3
20/10/2023 22:00	27.32	14.6	455.8	12.5	178.7	11.6
20/10/2023 23:00	27.62	14.6	456	12.6	178.8	11.7
21/10/2023 00:00	28.18	14.6	455.6	12.9	178.5	12
21/10/2023 01:00	28.38	14.6	454.9	13	178.4	12
21/10/2023 02:00	28.74	14.6	455.9	13.1	178.1	12.2
21/10/2023 03:00	28.31	14.5	455.8	12.9	178	12
21/10/2023 04:00	28.88	14.6	455.6	13.2	177.8	12.3
21/10/2023 05:00	28.96	14.6	455.4	13.2	177.8	12.3
21/10/2023 06:00	26.11	14.6	455	11.9	177.9	11.1
21/10/2023 07:00	25.24	14.6	454.4	11.5	177.7	10.7
21/10/2023 08:00	24.93	14.6	454.8	11.4	177.5	10.6
21/10/2023 09:00	23.48	14.5	450.9	10.7	176.6	10
21/10/2023 10:00	22.76	14.6	449.3	10.4	176.5	9.7
21/10/2023 11:00	22.22	14.6	447.3	10.1	176.1	9.4
21/10/2023 12:00	22.79	14.6	445.1	10.4	175.8	9.7
21/10/2023 13:00	22.66	14.6	442.3	10.3	175.2	9.6
21/10/2023 14:00	23.57	14.6	442.2	10.8	174.8	10
21/10/2023 15:00	26.11	14.6	444.4	11.9	174.9	11.1
21/10/2023 16:00	26.2	14.5	445.9	12	175.1	11.1
21/10/2023 17:00	25.82	14.5	446.7	11.8	175.5	11
21/10/2023 18:00	24.98	14.5	449.4	11.4	176.1	10.6
21/10/2023 19:00	25.29	14.6	456	11.5	177.4	10.7
21/10/2023 20:00	24.47	14.6	455.2	11.1	178	10.4
21/10/2023 21:00	24.35	14.6	454.7	11.1	178.1	10.3
21/10/2023 22:00	24.33	14.6	454.3	11.1	178.2	10.3
21/10/2023 23:00	24.93	14.6	455.4	11.4	178.3	10.6
22/10/2023 00:00	25.08	14.6	454.4	11.4	178.5	10.6
22/10/2023 01:00	25.51	14.6	454.8	11.6	178.3	10.8
22/10/2023 02:00	26.36	14.6	454.6	12	178.3	11.2
22/10/2023 03:00	26.43	14.6	454.7	12.1	178.2	11.2
22/10/2023 04:00	26.91	14.6	454.3	12.3	178	11.4
22/10/2023 05:00	27.3	14.6	454.2	12.5	178.1	11.6
22/10/2023 06:00	26.85	14.6	453.6	12.3	178	11.4
22/10/2023 07:00	26.13	14.6	455.7	11.9	178.3	11.1
22/10/2023 08:00	26.42	14.5	455.1	12.1	177.7	11.2
22/10/2023 09:00	25.82	14.5	452.5	11.8	177.1	11
22/10/2023 10:00	25.36	14.5	450	11.6	176.8	10.8
22/10/2023 11:00	25.8	14.6	447.5	11.8	176.4	11
22/10/2023 12:00	26.92	14.6	445.6	12.3	176.2	11.4
22/10/2023 13:00	26.58	14.5	445.1	12.2	175.6	11.3
22/10/2023 14:00	27.39	14.5	448.9	12.6	175.8	11.6
22/10/2023 15:00	28.84	14.5	450.7	13.3	175.8	12.2
22/10/2023 16:00	28.57	14.5	451.6	13.1	176.2	12.1
22/10/2023 17:00	27.49	14.5	450.3	12.7	176.8	11.7
22/10/2023 18:00	30	14.6	454.6	13.7	177.2	12.7
22/10/2023 19:00	27.77	14.6	455	12.7	177.9	11.8
22/10/2023 20:00	24.96	14.6	455.5	11.4	178	10.6
22/10/2023 21:00	24.64	14.6	455.6	11.2	178.6	10.5
22/10/2023 22:00	23.3	14.6	454.8	10.6	178.6	9.9
22/10/2023 23:00	23.92	14.6	454.4	10.9	178.5	10.2
23/10/2023 00:00	24.49	14.5	453.9	11.2	178.3	10.4
23/10/2023 01:00	24.05	14.5	453.2	11	178.1	10.2
23/10/2023 02:00	24.77	14.5	453.4	11.3	178.2	10.5

Site Report - GPSC CUP2 HRSg2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
25/10/2023 14:00	28.82	14.5	448.4	13.2	176	12.2
25/10/2023 15:00	28.99	14.5	448.7	13.3	176.2	12.3
25/10/2023 16:00	28.48	14.5	449.2	13.1	176.1	12.1
25/10/2023 17:00	27.51	14.5	449.7	12.6	176.3	11.7
25/10/2023 18:00	28.17	14.5	450.8	12.9	176.4	12
25/10/2023 19:00	27.19	14.5	452.1	12.5	176.6	11.5
25/10/2023 20:00	26.79	14.5	452.9	12.3	177	11.4
25/10/2023 21:00	26.87	14.5	454.1	12.4	177.2	11.4
25/10/2023 22:00	26.11	14.5	454.8	12	177.1	11.1
25/10/2023 23:00	26.36	14.5	454.8	12.1	177.2	11.2
26/10/2023 00:00	27.58	14.5	455.1	12.7	177.5	11.7
26/10/2023 01:00	27.36	14.5	450.7	12.5	178	11.6
26/10/2023 02:00	27.39	14.5	455.2	12.5	178.1	11.6
26/10/2023 03:00	28.09	14.5	455.9	12.9	178.2	11.9
26/10/2023 04:00	28.06	14.5	455.8	12.8	178.1	11.9
26/10/2023 05:00	27.58	14.5	455.6	12.6	178.2	11.7
26/10/2023 06:00	27.05	14.5	454.5	12.4	178.1	11.5
26/10/2023 07:00	27.07	14.5	455.6	12.4	177.9	11.5
26/10/2023 08:00	28.76	14.5	450.9	13.2	176.5	12.2
26/10/2023 09:00	28.47	14.5	445.5	13	175.8	12.1
26/10/2023 10:00	26.56	14.5	444.4	12.1	175.3	11.3
26/10/2023 11:00	26.59	14.5	443.2	12.1	175.1	11.3
26/10/2023 12:00	26.21	14.5	441	12	174.8	11.1
26/10/2023 13:00	25.37	14.5	441.6	11.6	174.3	10.8
26/10/2023 14:00	25.49	14.5	442.1	11.7	174.3	10.8
26/10/2023 15:00	25.76	14.5	443	11.8	174.3	10.9
26/10/2023 16:00	25.89	14.5	445.2	11.9	174.6	11
26/10/2023 17:00	25.91	14.5	445.8	11.9	174.9	11
26/10/2023 18:00	25.77	14.5	447.8	11.8	175.3	10.9
26/10/2023 19:00	25.4	14.5	448.5	11.6	175.6	10.8
26/10/2023 20:00	24.98	14.5	450.3	11.5	175.9	10.6
26/10/2023 21:00	24.76	14.5	449.7	11.4	176.2	10.5
26/10/2023 22:00	24.61	14.5	448.6	11.3	176	10.4
26/10/2023 23:00	24.73	14.5	452.3	11.4	176.7	10.5
27/10/2023 00:00	23.64	14.5	455.2	10.8	177.6	10
27/10/2023 01:00	22.15	14.5	454.8	10.1	178.3	9.4
27/10/2023 02:00	22.45	14.5	455.7	10.3	178.3	9.5
27/10/2023 03:00	22.63	14.5	455.3	10.4	178	9.6
27/10/2023 04:00	27.52	14.5	454.9	12.6	177.2	11.7
27/10/2023 05:00	28.2	14.5	455.4	12.9	177.7	12
27/10/2023 06:00	27.44	14.5	455.4	12.5	178	11.6
27/10/2023 07:00	26.43	14.5	455	12.1	178.1	11.2
27/10/2023 08:00	24.81	14.5	448.3	11.4	176.7	10.5
27/10/2023 09:00	25.95	14.5	444.2	11.9	175.6	11
27/10/2023 10:00	26.28	14.5	443.6	12	175.3	11.2
27/10/2023 11:00	26.71	14.5	442.7	12.2	175.2	11.3
27/10/2023 12:00	27.33	14.6	440.4	12.5	174.7	11.6
27/10/2023 13:00	27.04	14.5	440.4	12.4	174	11.5
27/10/2023 14:00	28.61	14.5	442.1	13.1	174.1	12.1
27/10/2023 15:00	28.23	14.5	443	12.9	174.6	12
27/10/2023 16:00	28.48	14.5	443.7	13.1	174.9	12.1
27/10/2023 17:00	28.49	14.5	444.9	13.1	175	12.1
27/10/2023 18:00	28.55	14.5	446.8	13.1	175.5	12.1
27/10/2023 19:00	28.8	14.5	449.4	13.2	175.9	12.2
27/10/2023 20:00	28.32	14.5	453	13	176.9	12
27/10/2023 21:00	28.94	14.5	453.3	13.3	176.9	12.3
27/10/2023 22:00	29.44	14.5	454.1	13.6	177	12.5
27/10/2023 23:00	29.87	14.5	454.5	13.7	177.3	12.7
28/10/2023 00:00	28.27	14.5	455.3	12.9	177.9	12

Site Report - GPSC CUP2 HRSg2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
28/10/2023 01:00	27.48	14.5	455.1	12.6	178	11.7
28/10/2023 02:00	27.72	14.5	455.7	12.7	177.8	11.8
28/10/2023 03:00	28.51	14.5	455.4	13.1	177.8	12.1
28/10/2023 04:00	28.25	14.5	454.9	12.9	177.8	12
28/10/2023 05:00	28.01	14.5	455.5	12.8	178	11.9
28/10/2023 06:00	27.95	14.5	455.5	12.8	178.2	11.9
28/10/2023 07:00	27.27	14.5	454	12.5	177.5	11.6
28/10/2023 08:00	26.39	14.5	451.3	12.1	177	11.2
28/10/2023 09:00	26.43	14.5	450.7	12.1	176.3	11.2
28/10/2023 10:00	27.32	14.5	449.4	12.5	176.4	11.6
28/10/2023 11:00	27.29	14.5	447.1	12.5	175.8	11.6
28/10/2023 12:00	27.92	14.5	446.2	12.8	175.7	11.9
28/10/2023 13:00	26.85	14.5	443.9	12.3	175.3	11.4
28/10/2023 14:00	28.6	14.5	442	13.1	174.8	12.1
28/10/2023 15:00	28.4	14.5	447.8	12.2	175.7	11.2
28/10/2023 16:00	26.05	14.5	447.4	12	175.7	11.1
28/10/2023 17:00	27.43	14.5	448	12.6	175.7	11.6
28/10/2023 18:00	29.08	14.5	451.8	13.4	176.2	12.3
28/10/2023 19:00	29.26	14.5	453.4	13.5	176.7	12.4
28/10/2023 20:00	28.5	14.5	454.1	13.1	176.9	12.1
28/10/2023 21:00	27.64	14.5	454.3	12.7	176.7	11.7
28/10/2023 22:00	28.96	14.5	454.9	13.3	176.9	12.3
28/10/2023 23:00	27.95	14.6	456	12.8	177.5	11.9
29/10/2023 00:00	28.57	14.6	456	13	177.8	12.1
29/10/2023 01:00	28.56	14.6	454.6	13	178.1	12.1
29/10/2023 02:00	29.42	14.6	455.5	13.4	178	12.5
29/10/2023 03:00	26.56	14.6	455.4	12.1	178.2	11.3
29/10/2023 04:00	27.75	14.5	455.1	12.7	177.8	11.8
29/10/2023 05:00	28.19	14.5	455.7	12.9	178	12
29/10/2023 06:00	28.31	14.6	455.3	12.9	178.2	12
29/10/2023 07:00	28.13	14.6	456	12.8	178.1	11.9
29/10/2023 08:00	28.52	14.5	455.9	13.1	177.9	12.1
29/10/2023 09:00	27.6	14.5	454.6	12.7	177.2	11.7
29/10/2023 10:00	27.69	14.5	451.8	12.7	176.7	11.8
29/10/2023 11:00	27.92	14.5	449.8	12.8	176.2	11.9
29/10/2023 12:00	29.01	14.5	447.7	13.3	176.1	12.3
29/10/2023 13:00	29.77	14.5	449.1	13.6	175.7	12.6
29/10/2023 14:00	27.44	14.6	454.9	12.5	177.5	11.6
29/10/2023 15:00	28.83	14.5	453.5	13.3	176.6	12.2
29/10/2023 16:00	28.89	14.5	454.4	13.3	176.6	12.3
29/10/2023 17:00	29.02	14.5	454	13.4	176.8	12.3
29/10/2023 18:00	28.43	14.5	454.2	13.1	177.1	12.1
29/10/2023 19:00	28.58	14.5	455.3	13.1	177.4	12.1
29/10/2023 20:00	25.77	14.5	455.8	11.8	177.8	10.9
29/10/2023 21:00	27.74	14.5	455.2	12.7	177.7	11.8
29/10/2023 22:00	28.78	14.5	455.8	13.2	177.7	12.2
29/10/2023 23:00	29.02	14.6	455.7	13.2	178	12.3
30/10/2023 00:00	29.15	14.6	455.8	13.3	178.1	12.4
30/10/2023 01:00	25.5	14.6	455.6	11.6	178.3	10.8
30/10/2023 02:00	26.93	14.5	454.8	12.3	178.3	11.4
30/10/2023 03:00	28.88	14.5	454.8	13.2	178.1	12.3
30/10/2023 04:00	29.52	14.5	455	13.5	177.9	12.5
30/10/2023 05:00	29.4	14.5	455.2	13.4	178	12.5
30/10/2023 06:00	27.59	14.5	454.9	12.6	178.1	11.7
30/10/2023 07:00	27.19	14.5	455.3	12.4	178	11.5
30/10/2023 08:00	27.15	14.5	452.4	12.5	176.6	11.5
30/10/2023 09:00	27.61	14.5	449.9	12.6	176.4	11.7
30/10/2023 10:00	28.92	14.6	447.1	13.2	176.1	12.3
30/10/2023 11:00	29.26	14.6	445.5	13.4	175.8	12.4

Site Report - GPSC CUP2 HRSg2						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
30/10/2023 12:00	29.14	14.6	441.9	13.3	175.4	12.4
30/10/2023 13:00	27.68	14.5	438.7	12.6	174.7	11.7
30/10/2023 14:00	29.31	14.6	439.7	13.4	174.4	12.4
30/10/2023 15:00	28.91	14.6	453.4	13.2	176.2	12.3
30/10/2023 16:00	27.78	14.5	454.9	12.7	177.3	11.8
30/10/2023 17:00	26.03	14.5	454.6	11.9	177.1	11
30/10/2023 18:00	24.72	14.6	455.3	11.3	178.1	10.5
30/10/2023 19:00	25.11	14.5	455.5	11.5	178.3	10.7
30/10/2023 20:00	25.65	14.5	455.3	11.7	178.3	10.9
30/10/2023 21:00	26.32	14.6	454.9	12	178.1	11.2
30/10/2023 22:00	26.79	14.6	456	12.2	178.1	11.4
30/10/2023 23:00	27.02	14.6	456	12.3	178	11.5
31/10/2023 00:00	27.43	14.5	456.1	12.5	177.8	11.6
31/10/2023 01:00	27.52	14.5	455.7	12.6	177.8	11.7
31/10/2023 02:00	28.33	14.6	455.6	12.9	177.7	12
31/10/2023 03:00	28.66	14.5	454.5	13.1	177.8	12.2
31/10/2023 04:00	29.36	14.6	455	13.4	177.9	12.5
31/10/2023 05:00	28.06	14.6	455	12.8	177.8	11.9
31/10/2023 06:00	26.92	14.6	455	12.3	177.9	11.4
31/10/2023 07:00	26.47	14.6	455.8	12	178.1	11.2
31/10/2023 08:00	26.38	14.6	455.4	12	177.6	11.2
31/10/2023 09:00	26.69	14.5	453.1	12.2	176.7	11.3
31/10/2023 10:00	26.55	14.5	450.6	12.1	176.3	11.3
31/10/2023 11:00	26.82	14.5	449	12.3	176	11.4
31/10/2023 12:00	27.4	14.6	447.7	12.5	175.8	11.6
31/10/2023 13:00	27.64	14.5	446.8	12.6	175.7	11.7
31/10/2023 14:00	27.16	14.5	446.4	12.4	175.7	11.5
31/10/2023 15:00	28.39	14.5	446.6	13	175.7	12.1
31/10/2023 16:00	28.77	14.5	447.6	13.1	176.2	12
31/10/2023 17:00	27.77	14.5	448.7	12.8	176.4	11.8
31/10/2023 18:00	26.81	14.5	450.9	12.4	176.7	11.4
31/10/2023 19:00	27.03	14.5	452.4	12.5	177	11.5
31/10/2023 20:00	27.48	14.5	453.4	12.7	177.1	11.7
31/10/2023 21:00	28.74	14.5	454.2	13.3	177.1	12.2
31/10/2023 22:00	29.35	14.5	454.4	13.6	177.1	12.5
31/10/2023 23:00	28.23	14.5	455.4	13.1	177.4	12
Minimum	17.29	14	438.7	8.3	162.3	7.3
MinDate	19/10/2023 12:00	15/10/2023 18:00	10/10/2023 14:00	19/10/2023 12:00	16/10/2023 11:00	19/10/2023 12:00
Maximum	30.69	14.6	480.1	14.6	178.9	13
MaxDate	17/10/2023 05:00	07/10/2023 09:00	10/10/2023 22:00	16/10/2023 08:00	19/10/2023 00:00	17/10/2023 05:00
Avg	26.44	14.5	451	12.2	176.6	11.2
Num	729	729	729	729	744	729
Data[%]	97.9	97.9	97.9	97.9	99.9	97.9
STD	1.9	0.1	4.5	0.9	2.2	0.8

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
03/11/2023 11:00	24.81	14.5	443.6	11.4	175.8	10.5
03/11/2023 12:00	25.27	14.5	442.5	11.6	175.8	10.7
03/11/2023 13:00	25.38	14.5	460.7	11.6	175.8	10.8
03/11/2023 14:00	24.55	14.5	486	11.3	175.6	10.4
03/11/2023 15:00	23.93	14.5	446.9	11	175	10.2
03/11/2023 16:00	23.88	14.5	457	11	175	10.1
03/11/2023 17:00	24.87	14.5	445.3	11.5	175.7	10.6
03/11/2023 18:00	25.67	14.5	447.9	11.9	176.3	10.9
03/11/2023 19:00	25.63	14.5	448.4	11.8	176.4	10.9
03/11/2023 20:00	27.35	14.5	455.5	12.5	177.6	11.6
03/11/2023 21:00	28.06	14.5	455.7	12.9	177.7	11.9
03/11/2023 22:00	27.7	14.5	455.5	12.7	178.6	11.8
03/11/2023 23:00	27.39	14.5	455.1	12.6	178.7	11.6
04/11/2023 00:00	27.63	14.5	455.4	12.7	178.9	11.7
04/11/2023 01:00	28.09	14.5	454.8	12.9	178.7	11.9
04/11/2023 02:00	27.77	14.5	455.1	12.8	178.9	11.8
04/11/2023 03:00	27.72	14.5	454.4	12.8	178.7	11.8
04/11/2023 04:00	27.72	14.5	454.1	12.8	178.7	11.8
04/11/2023 05:00	27.97	14.5	455.4	12.9	178.7	11.9
04/11/2023 06:00	28	14.5	455.7	12.9	178.7	11.9
04/11/2023 07:00	27.95	14.5	455.3	12.9	178.4	11.9
04/11/2023 08:00	26.68	14.5	450.5	12.4	177.1	11.3
04/11/2023 09:00	26.69	14.5	447.3	12.3	176.3	11.3
04/11/2023 10:00	27.41	14.5	451.9	12.6	176.1	11.6
04/11/2023 11:00	27.99	14.5	445	12.9	175.9	11.9
04/11/2023 12:00	26.66	14.5	448.3	12.3	175.5	11.3
04/11/2023 13:00	28.87	14.5	453.7	13.3	176.7	12.3
04/11/2023 14:00	26.51	14.5	454.4	12.2	177.4	11.3
04/11/2023 15:00	26.53	14.5	455.5	12.1	178.3	11.3
04/11/2023 16:00	25.65	14.5	455	11.8	178.2	10.9
04/11/2023 17:00	24.9	14.5	454.2	11.4	178	10.6
04/11/2023 18:00	25.19	14.5	454.9	11.6	178.2	10.7
04/11/2023 19:00	24.73	14.5	454.1	11.3	178	10.5
04/11/2023 20:00	24.58	14.5	454.4	11.3	178.1	10.4
04/11/2023 21:00	25.04	14.5	454.4	11.5	178	10.6
04/11/2023 22:00	26.08	14.5	453.9	12	177.9	11.1
04/11/2023 23:00	25.86	14.5	454.3	11.9	177.8	11
05/11/2023 00:00	26.69	14.5	454	12.3	177.7	11.3
05/11/2023 01:00	27.13	14.5	454.3	12.5	177.9	11.5
05/11/2023 02:00	26.91	14.5	454.2	12.4	178	11.4
05/11/2023 03:00	26.64	14.5	453.6	12.3	178.1	11.3
05/11/2023 04:00	26.3	14.5	454.1	12.1	177.8	11.2
05/11/2023 05:00	25.85	14.5	454.2	11.9	177.8	11
05/11/2023 06:00	25.75	14.5	454.4	11.8	177.8	10.9
05/11/2023 07:00	26.1	14.5	454.9	12	177.8	11.1
05/11/2023 08:00	26.5	14.5	454.1	12.2	177.2	11.2
05/11/2023 09:00	25.78	14.5	450.8	11.9	176.4	10.9
05/11/2023 10:00	26.39	14.5	448.4	12.2	176.3	11.2
05/11/2023 11:00	26.32	14.5	445.5	12.1	176.1	11.2
05/11/2023 12:00	27.95	14.5	444.1	12.8	175.9	11.9
05/11/2023 13:00	25.9	14.5	440.6	12	175	11
05/11/2023 14:00	26.13	14.5	440.2	12.1	174.6	11.1
05/11/2023 15:00	27.81	14.5	441.8	12.8	174.7	11.8
05/11/2023 16:00	30.12	14.5	479.8	13.8	176.4	12.8
05/11/2023 17:00	28.28	14.5	476.5	12.9	177.8	12
05/11/2023 18:00	27.39	14.5	455.9	12.5	177.8	11.6
05/11/2023 19:00	27.83	14.5	455.9	12.7	177.8	11.8
05/11/2023 20:00	27.69	14.5	455.8	12.7	177.7	11.8
05/11/2023 21:00	27.96	14.5	455.9	12.8	178.1	11.9

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
05/11/2023 22:00	28.42	14.5	455.8	13	178.6	12.1
05/11/2023 23:00	29.54	14.5	455.8	13.5	178.4	12.5
06/11/2023 00:00	28.5	14.5	456	13	178.5	12.1
06/11/2023 01:00	27.2	14.5	454.7	12.5	178.4	11.5
06/11/2023 02:00	27.4	14.5	454.4	12.6	178.5	11.6
06/11/2023 03:00	27.55	14.5	453.6	12.7	178.4	11.7
06/11/2023 04:00	27.93	14.5	454.9	12.8	178.4	11.9
06/11/2023 05:00	27.3	14.5	454	12.5	178.3	11.6
06/11/2023 06:00	27.64	14.5	453.3	12.7	178.5	11.7
06/11/2023 07:00	27.96	14.5	455	12.9	178.3	11.9
06/11/2023 08:00	27.24	14.5	450.6	12.6	177.1	11.6
06/11/2023 09:00	25.04	14.5	447.2	11.5	176.5	10.6
06/11/2023 10:00	25.31	14.5	445	11.6	176.2	10.7
06/11/2023 11:00	25.9	14.5	442.9	11.9	175.9	11
06/11/2023 12:00	24.79	14.5	442.5	11.4	175.7	10.5
06/11/2023 13:00	23.21	14.5	442.3	10.7	175.3	9.9
06/11/2023 14:00	23.93	14.5	443.7	11.1	175.5	10.2
06/11/2023 15:00	26.68	14.5	449.9	12.3	176.3	11.3
06/11/2023 16:00	26.89	14.5	450.3	12.4	176.8	11.4
06/11/2023 17:00	26.19	14.5	450.4	12.1	176.9	11.1
06/11/2023 18:00	25.85	14.5	452.4	12	177.1	11
06/11/2023 19:00	25.1	14.5	454	11.6	177.4	10.7
06/11/2023 20:00	25.02	14.5	453.9	11.6	177.6	10.6
06/11/2023 21:00	25.27	14.5	454.3	11.7	177.7	10.7
06/11/2023 22:00	24.82	14.5	456.1	11.4	178.4	10.5
06/11/2023 23:00	25.23	14.5	455.6	11.6	178.7	10.7
07/11/2023 00:00	25.78	14.5	456	11.8	178.4	10.9
07/11/2023 01:00	26.27	14.5	455.9	12.1	178.4	11.2
07/11/2023 02:00	26.73	14.5	455.7	12.3	178.6	11.3
07/11/2023 03:00	27.12	14.5	454.9	12.5	178.6	11.5
07/11/2023 04:00	27.54	14.5	455.4	12.6	178.6	11.7
07/11/2023 05:00	28.06	14.5	455.8	12.9	178.8	11.9
07/11/2023 06:00	27.56	14.5	455.3	12.6	178.5	11.7
07/11/2023 07:00	27.16	14.5	455.3	12.5	178.3	11.5
07/11/2023 08:00	27.11	14.5	452.4	12.5	177.3	11.5
07/11/2023 09:00	25.41	14.5	449.3	11.7	176.9	10.8
07/11/2023 10:00	<Samp	<Samp	<Samp	<Samp	176.5	<Samp
07/11/2023 11:00	Maintain	Maintain	Alarm	Maintain	176.6	Maintain
07/11/2023 12:00	23.02	14.5	445.2	10.6	176.2	9.8
07/11/2023 13:00	24.98	14.5	452	11.6	176.7	10.6
07/11/2023 14:00	24.25	14.5	453.5	11.2	177.2	10.3
07/11/2023 15:00	24.39	14.5	455.8	11.2	178	10.4
07/11/2023 16:00	24.08	14.5	456.1	11	178.1	10.2
07/11/2023 17:00	23.83	14.5	456.1	10.9	178.2	10.1
07/11/2023 18:00	23.57	14.5	455.8	10.8	178.4	10
07/11/2023 19:00	23.16	14.5	456.1	10.6	178.5	9.8
07/11/2023 20:00	23.35	14.5	456.3	10.7	178.6	9.9
07/11/2023 21:00	23.33	14.5	456.2	10.7	178.6	9.9
07/11/2023 22:00	23.33	14.5	455.5	10.7	178.6	9.9
07/11/2023 23:00	23.32	14.5	454.4	10.7	178.7	9.9
08/11/2023 00:00	23.79	14.5	454.6	10.9	178.7	10.1
08/11/2023 01:00	24.15	14.5	453.6	11.1	178.5	10.3
08/11/2023 02:00	24.59	14.5	453.1	11.3	178.4	10.4
08/11/2023 03:00	25.15	14.5	454.6	11.5	178.5	10.7
08/11/2023 04:00	24.81	14.5	453.8	11.4	178.5	10.5
08/11/2023 05:00	24.66	14.5	453.2	11.3	178.5	10.5
08/11/2023 06:00	24.5	14.5	453.9	11.3	178.4	10.4
08/11/2023 07:00	24.51	14.5	455.3	11.3	178.6	10.4
08/11/2023 08:00	24.55	14.5	454.3	11.3	177.3	10.4

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
08/11/2023 09:00	24.04	14.5	448.9	11.1	176.7	10.2
08/11/2023 10:00	<Samp	<Samp	<Samp	<Samp	176.2	<Samp
08/11/2023 11:00	<Samp	<Samp	<Samp	<Samp	176.1	<Samp
08/11/2023 12:00	26.35	14.5	444.2	12.1	175.9	11.2
08/11/2023 13:00	26.37	14.5	443.2	12.1	175.7	11.2
08/11/2023 14:00	24.86	14.5	440.1	11.5	174.9	10.6
08/11/2023 15:00	25.13	14.5	450.3	11.6	175.5	10.7
08/11/2023 16:00	26.4	14.5	454.7	12.1	177.2	11.2
08/11/2023 17:00	26.34	14.5	454.8	12.1	177.5	11.2
08/11/2023 18:00	25.76	14.5	455.2	11.8	177.9	10.9
08/11/2023 19:00	25.14	14.5	455.6	11.6	178.4	10.7
08/11/2023 20:00	24.74	14.5	455.1	11.4	178.7	10.5
08/11/2023 21:00	24.78	14.5	455.3	11.4	178.6	10.5
08/11/2023 22:00	24.98	14.5	455.9	11.5	178.7	10.6
08/11/2023 23:00	24.98	14.5	454.7	11.5	178.9	10.6
09/11/2023 00:00	25.72	14.5	454.9	11.8	178.7	10.9
09/11/2023 01:00	26.17	14.5	454.5	12	178.8	11.1
09/11/2023 02:00	26.68	14.5	454.8	12.3	178.7	11.3
09/11/2023 03:00	27.17	14.5	454.7	12.5	178.5	11.5
09/11/2023 04:00	27.28	14.5	455.2	12.6	178.5	11.6
09/11/2023 05:00	27.43	14.5	456	12.6	178.2	11.6
09/11/2023 06:00	27.31	14.5	455.7	12.6	178.4	11.6
09/11/2023 07:00	27.46	14.5	455	12.7	178.4	11.7
09/11/2023 08:00	27.41	14.5	451.8	12.7	177.2	11.6
09/11/2023 09:00	28.24	14.5	449.3	13.1	176.6	12
09/11/2023 10:00	Maintain	Maintain	Alarm	Maintain	176.2	Maintain
09/11/2023 11:00	Maintain	Maintain	Alarm	Maintain	176.1	Maintain
09/11/2023 12:00	Maintain	Maintain	Alarm	Maintain	176.1	Maintain
09/11/2023 13:00	Maintain	Maintain	Alarm	Maintain	176.4	Maintain
09/11/2023 14:00	Maintain	Maintain	Alarm	Maintain	176.1	Maintain
09/11/2023 15:00	<Samp	<Samp	<Samp	<Samp	176.3	<Samp
09/11/2023 16:00	30.92	14.5	451.5	14.2	176.7	13.1
09/11/2023 17:00	20.64	14.2	448.4	9.9	169.8	8.8
09/11/2023 18:00	21.32	14.5	452.8	9.8	176	9
09/11/2023 19:00	26.71	14.5	453.9	12.3	177.2	11.3
09/11/2023 20:00	27.87	14.5	455.3	12.8	177.8	11.8
09/11/2023 21:00	27.36	14.5	455.2	12.5	177.7	11.6
09/11/2023 22:00	26.54	14.6	455.7	12.1	178	11.3
09/11/2023 23:00	26.67	14.6	455.8	12.2	178.4	11.3
10/11/2023 00:00	27.41	14.6	455.6	12.5	178.4	11.6
10/11/2023 01:00	27.66	14.6	455.5	12.6	178.6	11.7
10/11/2023 02:00	27.55	14.6	455.3	12.5	178.4	11.7
10/11/2023 03:00	27.53	14.6	455.4	12.6	178.5	11.7
10/11/2023 04:00	27.31	14.6	455.6	12.5	178.2	11.6
10/11/2023 05:00	27.38	14.6	455.9	12.5	178.4	11.6
10/11/2023 06:00	27.47	14.6	455.8	12.5	178.4	11.7
10/11/2023 07:00	27.27	14.5	454.5	12.5	178.1	11.6
10/11/2023 08:00	25.31	14.5	450.4	11.6	177.1	10.7
10/11/2023 09:00	24.26	14.5	447.6	11.1	176.2	10.3
10/11/2023 10:00	25.07	14.6	444.6	11.4	175.7	10.6
10/11/2023 11:00	25.29	14.6	444.8	11.5	176.1	10.7
10/11/2023 12:00	24.9	14.5	442.4	11.4	175.5	10.6
10/11/2023 13:00	26.25	14.5	443.8	12	175.2	11.1
10/11/2023 14:00	27.06	14.5	451.2	12.4	176.4	11.5
10/11/2023 15:00	27.6	14.5	451.3	12.7	176.4	11.7
10/11/2023 16:00	26.69	14.5	453.1	12.2	177	11.3
10/11/2023 17:00	23.7	14.5	452.1	10.9	177.3	10.1
10/11/2023 18:00	23.25	14.5	453.6	10.7	177.4	9.9
10/11/2023 19:00	22.74	14.5	453.8	10.4	177.8	9.7

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
13/11/2023 07:00	29.3	14.6	455.7	13.4	178.2	12.4
13/11/2023 08:00	24.97	14.5	453.1	11.4	177.2	10.6
13/11/2023 09:00	22.94	14.5	450.5	10.5	176.9	9.7
13/11/2023 10:00	22.79	14.6	446.4	10.4	176.1	9.7
13/11/2023 11:00	23.01	14.6	444.3	10.5	175.8	9.8
13/11/2023 12:00	23.5	14.6	443.5	10.7	175.7	10
13/11/2023 13:00	24.62	14.6	442.5	11.2	175.2	10.4
13/11/2023 14:00	24.97	14.6	441.3	11.4	175.4	10.6
13/11/2023 15:00	25.48	14.6	443.2	11.6	175.4	10.8
13/11/2023 16:00	25.05	14.6	444.8	11.4	176.1	10.6
13/11/2023 17:00	23.63	14.5	448	10.8	176.6	10
13/11/2023 18:00	24.2	14.5	449.3	11.1	176.8	10.3
13/11/2023 19:00	24.39	14.5	451.7	11.2	177.1	10.4
13/11/2023 20:00	25.01	14.5	452.6	11.5	177.4	10.6
13/11/2023 21:00	25.72	14.5	469.8	11.8	177.4	10.9
13/11/2023 22:00	26.27	14.5	463.6	12	177.5	11.1
13/11/2023 23:00	27.13	14.5	454.1	12.4	177.4	11.5
14/11/2023 00:00	27.54	14.5	454.2	12.6	177.3	11.7
14/11/2023 01:00	28.76	14.6	454.5	13.1	177.3	12.2
14/11/2023 02:00	29.77	14.6	455.1	13.6	177.1	12.6
14/11/2023 03:00	27.36	14.6	455.6	12.4	177.5	11.6
14/11/2023 04:00	26.78	14.6	456.1	12.2	178.5	11.4
14/11/2023 05:00	26.38	14.6	456.2	12	178.5	11.2
14/11/2023 06:00	26.44	14.6	456.5	12	178.4	11.2
14/11/2023 07:00	25.74	14.6	455.7	11.7	178.6	10.9
14/11/2023 08:00	25.37	14.5	452.5	11.6	177.1	10.8
14/11/2023 09:00	23.7	14.6	450.2	10.8	176.7	10.1
14/11/2023 10:00	23	14.6	447.8	10.5	176.2	9.8
14/11/2023 11:00	23.37	14.6	445.8	10.6	175.8	9.9
14/11/2023 12:00	24.09	14.6	444.5	11	175.7	10.2
14/11/2023 13:00	24.75	14.6	443.9	11.3	175.4	10.5
14/11/2023 14:00	25.94	14.6	443.3	11.8	175.4	11
14/11/2023 15:00	26.47	14.6	443	12.1	175.3	11.2
14/11/2023 16:00	27.14	14.6	444.7	12.4	175.6	11.5
14/11/2023 17:00	27.28	14.6	446.5	12.4	176.1	11.6
14/11/2023 18:00	27.2	14.5	449.3	12.4	176.5	11.5
14/11/2023 19:00	27.49	14.5	450.8	12.6	176.8	11.7
14/11/2023 20:00	27.67	14.5	451.8	12.7	176.9	11.7
14/11/2023 21:00	28.87	14.5	452.5	13.2	177	12.3
14/11/2023 22:00	29.58	14.5	453.6	13.5	177.1	12.6
14/11/2023 23:00	30.11	14.5	453.6	13.8	176.9	12.8
15/11/2023 00:00	26.28	14.5	453.5	12	176.5	11.2
15/11/2023 01:00	25.76	14.6	454.2	11.8	176.6	10.9
15/11/2023 02:00	25.69	14.6	455.8	11.7	177.7	10.9
15/11/2023 03:00	25.57	14.6	456.1	11.6	178.2	10.9
15/11/2023 04:00	25.59	14.6	455.6	11.6	178	10.9
15/11/2023 05:00	25.79	14.6	456.5	11.7	178.3	10.9
15/11/2023 06:00	25.9	14.6	456.6	11.7	178.3	11
15/11/2023 07:00	25.54	14.6	455.9	11.6	178.4	10.8
15/11/2023 08:00	25.84	14.6	455.5	11.7	178	11
15/11/2023 09:00	25.67	14.6	453	11.7	177.1	10.9
15/11/2023 10:00	23.54	14.6	449.3	10.7	176.1	10
15/11/2023 11:00	22.18	14.6	446.9	10.1	175.6	9.4
15/11/2023 12:00	23.57	14.6	445.2	10.7	176.1	10
15/11/2023 13:00	23.82	14.6	443.4	10.8	176	10.1
15/11/2023 14:00	24.81	14.6	443.7	11.3	176	10.5
15/11/2023 15:00	24.75	14.6	442	11.3	175.7	10.5
15/11/2023 16:00	25.44	14.5	442.9	11.6	175.4	10.8
15/11/2023 17:00	26.09	14.5	449.9	11.9	176.5	11.1

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
15/11/2023 18:00	26.29	14.5	453.7	12.1	177.2	11.2
15/11/2023 19:00	25.39	14.5	454.8	11.6	178	10.8
15/11/2023 20:00	27.02	14.5	453.7	12.4	177.7	11.5
15/11/2023 21:00	28.3	14.5	453.9	12.9	177.2	12
15/11/2023 22:00	25.02	14.6	454.7	11.4	177.6	10.6
15/11/2023 23:00	24.3	14.6	455.2	11.1	177.6	10.3
16/11/2023 00:00	25.2	14.6	455.4	11.5	177.5	10.7
16/11/2023 01:00	25.91	14.6	455.9	11.8	177.7	11
16/11/2023 02:00	26.68	14.6	455.6	12.1	177.6	11.3
16/11/2023 03:00	27.43	14.6	455.8	12.5	177.7	11.6
16/11/2023 04:00	26.82	14.6	456.1	12.2	177.8	11.4
16/11/2023 05:00	25.93	14.6	455.9	11.8	178.3	11
16/11/2023 06:00	26.19	14.6	456.6	11.9	178.1	11.1
16/11/2023 07:00	26.03	14.6	455.9	11.8	177.7	11
16/11/2023 08:00	25.49	14.6	453.8	11.6	177	10.8
16/11/2023 09:00	24.8	14.6	450.1	11.3	176.3	10.5
16/11/2023 10:00	24.65	14.6	447.8	11.2	176.1	10.5
16/11/2023 11:00	25.26	14.6	445.5	11.5	176	10.7
16/11/2023 12:00	25.35	14.6	443.8	11.5	175.5	10.8
16/11/2023 13:00	26.08	14.6	444.7	11.9	175.7	11.1
16/11/2023 14:00	26.28	14.6	444.3	12	175.7	11.2
16/11/2023 15:00	25.83	14.6	448	11.8	176.2	11
16/11/2023 16:00	25.52	14.5	450.1	11.7	176.6	10.8
16/11/2023 17:00	23.36	14.5	450.6	10.7	176.9	9.9
16/11/2023 18:00	24.35	14.5	451.2	11.2	176.9	10.3
16/11/2023 19:00	26.01	14.5	451.9	11.9	176.8	11
16/11/2023 20:00	27.43	14.5	452.3	12.5	176.9	11.6
16/11/2023 21:00	28.65	14.6	452.7	13.1	176.9	12.2
16/11/2023 22:00	29.97	14.6	453.8	13.7	176.9	12.7
16/11/2023 23:00	26.36	14.6	455.1	12	177.8	11.2
17/11/2023 00:00	23.84	14.6	455.6	10.8	177.7	10.1
17/11/2023 01:00	24.35	14.6	455.4	11.1	177.5	10.3
17/11/2023 02:00	25.34	14.6	455.8	11.5	177.8	10.8
17/11/2023 03:00	26.27	14.6	456.8	11.8	178	11.1
17/11/2023 04:00	26.71	14.6	456.5	12	178.1	11.3
17/11/2023 05:00	26.92	14.6	454.7	12.1	177.8	11.4
17/11/2023 06:00	27.64	14.6	453.7	12.5	177.7	11.7
17/11/2023 07:00	27.58	14.6	453.7	12.4	177.6	11.7
17/11/2023 08:00	26	14.7	456	11.7	178	11
17/11/2023 09:00	25.35	14.7	454.8	11.4	177.9	10.8
17/11/2023 10:00	24.59	14.6	455.8	11.1	177	10.4
17/11/2023 11:00	25.28	14.6	453.3	11.4	176.9	10.7
17/11/2023 12:00	26.74	14.6	452.6	12.1	176.8	11.4
17/11/2023 13:00	27.48	14.6	452.3	12.4	176.3	11.7
17/11/2023 14:00	27.28	14.6	450.9	12.3	176	11.6
17/11/2023 15:00	27.97	14.6	451.6	12.7	176.6	11.9
17/11/2023 16:00	28.55	14.6	451.7	12.9	176.6	12.1
17/11/2023 17:00	28.95	14.6	452.8	13.1	176.7	12.3
17/11/2023 18:00	29.65	14.6	455	13.4	177	12.6
17/11/2023 19:00	29.03	14.6	457	13.1	177.3	12.3
17/11/2023 20:00	28.86	14.7	456.6	13	178.5	12.2
17/11/2023 21:00	28.74	14.7	456.8	12.9	178.5	12.2
17/11/2023 22:00	27.7	14.7	455.5	12.4	178.2	11.8
17/11/2023 23:00	24.27	14.7	454	10.9	178.1	10.3
18/11/2023 00:00	23.12	14.6	452.4	10.4	177.7	9.8
18/11/2023 01:00	22.58	14.6	450.8	10.2	177.6	9.6
18/11/2023 02:00	22.21	14.6	449.7	10.1	177.5	9.4
18/11/2023 03:00	23.72	14.6	449.2	10.7	177.2	10.1
18/11/2023 04:00	23.36	14.6	447.6	10.6	177.2	9.9

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
18/11/2023 05:00	23.17	14.6	447.5	10.5	176.8	9.8
18/11/2023 06:00	23.06	14.6	447.4	10.5	176.8	9.8
18/11/2023 07:00	23.27	14.6	448.2	10.6	176.9	9.9
18/11/2023 08:00	25.85	14.6	449.3	11.7	176.8	11
18/11/2023 09:00	26.75	14.7	453.3	12	177.9	11.4
18/11/2023 10:00	27.82	14.7	457.6	12.4	178.3	11.8
18/11/2023 11:00	28.43	14.7	456.7	12.8	177.6	12.1
18/11/2023 12:00	29.25	14.6	453.7	13.2	176.3	12.4
18/11/2023 13:00	29.41	14.6	453	13.3	176.5	12.5
18/11/2023 14:00	29.38	14.6	451.7	13.3	176.7	12.5
18/11/2023 15:00	29.68	14.6	451	13.4	176.5	12.6
18/11/2023 16:00	30.27	14.6	452.5	13.7	176.7	12.8
18/11/2023 17:00	29.23	14.6	454	13.2	177.1	12.4
18/11/2023 18:00	27.93	14.6	456.6	12.6	177.9	11.9
18/11/2023 19:00	26.59	14.7	456.4	11.9	178.8	11.3
18/11/2023 20:00	24.84	14.6	453.5	11.2	178.4	10.5
18/11/2023 21:00	24.63	14.6	451.3	11.1	178	10.5
18/11/2023 22:00	24.63	14.6	449.5	11.2	177.7	10.5
18/11/2023 23:00	26.21	14.6	449.7	11.9	177.6	11.1
19/11/2023 00:00	26.51	14.6	448.5	12	177.4	11.3
19/11/2023 01:00	27.11	14.6	447.7	12.3	177.1	11.5
19/11/2023 02:00	27.82	14.6	447.7	12.7	177	11.8
19/11/2023 03:00	28.52	14.6	447.5	13	177.1	12.1
19/11/2023 04:00	28.92	14.6	446.1	13.2	176.8	12.3
19/11/2023 05:00	29.62	14.6	445.7	13.5	176.6	12.6
19/11/2023 06:00	29.29	14.6	445.5	13.4	176.4	12.4
19/11/2023 07:00	28.84	14.6	446	13.1	176.6	12.2
19/11/2023 08:00	27.74	14.6	447.9	12.6	176.9	11.8
19/11/2023 09:00	27.51	14.7	454	12.4	177.8	11.7
19/11/2023 10:00	28.06	14.7	455.1	12.6	177.7	11.9
19/11/2023 11:00	29.83	14.6	456.5	13.4	176.9	12.7
19/11/2023 12:00	29.7	14.6	453.6	13.4	177.1	12.6
19/11/2023 13:00	29.5	14.6	451.6	13.3	176.7	12.5
19/11/2023 14:00	29.88	14.6	450.5	13.5	176.4	12.7
19/11/2023 15:00	30.38	14.6	450.6	13.7	176.5	12.9
19/11/2023 16:00	30.36	14.6	451.8	13.7	176.6	12.9
19/11/2023 17:00	31.47	14.6	453.8	14.3	177.1	13.4
19/11/2023 18:00	30.59	14.6	456	13.8	177.9	13
19/11/2023 19:00	27.45	14.6	454.8	12.4	178.6	11.7
19/11/2023 20:00	25.22	14.6	450.1	11.5	178.1	10.7
19/11/2023 21:00	25.23	14.6	448.4	11.5	177.5	10.7
19/11/2023 22:00	25.78	14.6	448.1	11.7	177.5	10.9
19/11/2023 23:00	26.32	14.6	446.7	12	177.1	11.2
20/11/2023 00:00	27.28	14.6	446.8	12.4	176.9	11.6
20/11/2023 01:00	27.94	14.6	445.9	12.8	176.9	11.9
20/11/2023 02:00	28.25	14.5	445.5	12.9	176.6	12
20/11/2023 03:00	28.48	14.5	444.9	13	176.4	12.1
20/11/2023 04:00	28.6	14.5	444.2	13.1	176.3	12.1
20/11/2023 05:00	29.08	14.5	443.6	13.3	176.2	12.3
20/11/2023 06:00	29.41	14.5	444	13.5	176.3	12.5
20/11/2023 07:00	29.66	14.6	445.7	13.5	176.4	12.6
20/11/2023 08:00	28.96	14.6	449.5	13.1	177.3	12.3
20/11/2023 09:00	29.07	14.7	455.7	13	178.1	12.3
20/11/2023 10:00	30.16	14.7	456.1	13.6	177.9	12.8
20/11/2023 11:00	30.15	14.6	453.6	13.6	177.1	12.8
20/11/2023 12:00	30.45	14.6	451.3	13.7	176.5	12.9
20/11/2023 13:00	30.07	14.6	449.8	13.6	176.5	12.8
20/11/2023 14:00	30.54	14.6	448.8	13.8	176.5	13
20/11/2023 15:00	30.47	14.6	448	13.8	176.6	12.9

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
23/11/2023 03:00	28.95	14.6	451	13.2	177.1	12.3
23/11/2023 04:00	29.1	14.6	451.5	13.2	177.1	12.4
23/11/2023 05:00	28.98	14.6	453.1	13.1	177.4	12.3
23/11/2023 06:00	27.97	14.6	451.1	12.7	177.1	11.9
23/11/2023 07:00	28.16	14.6	453.8	12.8	177.4	12
23/11/2023 08:00	29.11	14.6	454.1	13.2	177.1	12.4
23/11/2023 09:00	29.9	14.6	450.8	13.6	176	12.7
23/11/2023 10:00	28.99	14.6	448.3	13.1	175.4	12.3
23/11/2023 11:00	28.44	14.6	446.8	12.9	175.4	12.1
23/11/2023 12:00	28.9	14.6	446	13.1	175.4	12.3
23/11/2023 13:00	28.51	14.6	444.9	12.9	175.5	12.1
23/11/2023 14:00	27.49	14.6	445.2	12.5	175.7	11.7
23/11/2023 15:00	27.91	14.6	444.7	12.7	175.9	11.8
23/11/2023 16:00	27.76	14.6	446.1	12.6	176	11.8
23/11/2023 17:00	26.93	14.6	447.5	12.2	176.1	11.4
23/11/2023 18:00	25.8	14.6	450.5	11.7	176.6	11
23/11/2023 19:00	24.66	14.6	453.8	11.2	177	10.5
23/11/2023 20:00	23.46	14.6	455.2	10.7	177.6	10
23/11/2023 21:00	22.25	14.6	456.2	10.1	178.4	9.4
23/11/2023 22:00	21.2	14.6	455.1	9.6	178.6	9
23/11/2023 23:00	21.47	14.6	454.9	9.7	178.6	9.1
24/11/2023 00:00	22.99	14.6	454.5	10.4	178.4	9.8
24/11/2023 01:00	24.47	14.6	454.3	11.1	178.4	10.4
24/11/2023 02:00	24.88	14.6	453.9	11.3	178.3	10.6
24/11/2023 03:00	25.95	14.6	454.4	11.8	178.3	11
24/11/2023 04:00	26.03	14.6	454.4	11.8	178.3	11.1
24/11/2023 05:00	26.05	14.6	453.5	11.8	178	11.1
24/11/2023 06:00	25.64	14.6	452.6	11.6	177.7	10.9
24/11/2023 07:00	25.18	14.6	454.2	11.4	178.2	10.7
24/11/2023 08:00	26.15	14.6	454.3	11.9	177.5	11.1
24/11/2023 09:00	25.84	14.6	451.8	11.7	176.7	11
24/11/2023 10:00	25.62	14.6	449.2	11.6	176.2	10.9
24/11/2023 11:00	25.6	14.6	447.1	11.6	176.1	10.9
24/11/2023 12:00	25.74	14.6	445.4	11.7	176	10.9
24/11/2023 13:00	26.69	14.6	444.3	12.1	175.8	11.3
24/11/2023 14:00	27.67	14.6	444.3	12.6	175.6	11.7
24/11/2023 15:00	27.94	14.6	444.9	12.7	175.7	11.9
24/11/2023 16:00	26.68	14.6	445.7	12.2	176.1	11.3
24/11/2023 17:00	25.01	14.5	446.7	11.4	176.4	10.6
24/11/2023 18:00	25.83	14.5	450.1	11.8	176.9	11
24/11/2023 19:00	28.51	14.6	451.8	13	177	12.1
24/11/2023 20:00	28.04	14.6	455.6	12.8	177.8	11.9
24/11/2023 21:00	26.77	14.6	455.7	12.1	178.6	11.4
24/11/2023 22:00	26.77	14.6	456.1	12.1	178.9	11.4
24/11/2023 23:00	27.78	14.6	455.8	12.6	178.4	11.8
25/11/2023 00:00	24.11	14.6	456.2	10.9	178.4	10.2
25/11/2023 01:00	23.93	14.6	455.1	10.8	178.4	10.2
25/11/2023 02:00	25.06	14.6	453.9	11.3	177.6	10.6
25/11/2023 03:00	25.53	14.6	453.4	11.6	178	10.8
25/11/2023 04:00	25.23	14.6	451.7	11.5	177.9	10.7
25/11/2023 05:00	25.1	14.6	450.7	11.4	177.5	10.7
25/11/2023 06:00	25.3	14.6	451	11.5	177.6	10.7
25/11/2023 07:00	25.83	14.6	453.6	11.7	177.6	11
25/11/2023 08:00	26.29	14.6	456.2	11.8	177.7	11.2
25/11/2023 09:00	27.6	14.6	454.7	12.5	177.2	11.7
25/11/2023 10:00	28.14	14.6	451.3	12.7	176.4	11.9
25/11/2023 11:00	28.11	14.6	449.5	12.7	176.1	11.9
25/11/2023 12:00	28.21	14.6	448	12.8	176.1	12
25/11/2023 13:00	27.84	14.6	446.4	12.6	176	11.8

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
25/11/2023 14:00	28	14.6	447.3	12.7	176.1	11.9
25/11/2023 15:00	28.5	14.6	448.5	12.9	176.3	12.1
25/11/2023 16:00	29.18	14.6	450.2	13.3	176.5	12.4
25/11/2023 17:00	29.06	14.6	451.7	13.2	176.8	12.3
25/11/2023 18:00	29.5	14.6	452.8	13.4	176.9	12.5
25/11/2023 19:00	29.78	14.6	453.7	13.5	177.1	12.6
25/11/2023 20:00	28.83	14.6	455.1	13.1	177.3	12.2
25/11/2023 21:00	27.53	14.6	456.6	12.5	177.6	11.7
25/11/2023 22:00	27.83	14.6	456.1	12.6	177.7	11.8
25/11/2023 23:00	28.32	14.6	455.7	12.8	177.8	12
26/11/2023 00:00	28.6	14.6	456	12.9	177.8	12.1
26/11/2023 01:00	28.68	14.6	456.7	13	178.1	12.2
26/11/2023 02:00	29.4	14.6	456.4	13.3	178.2	12.5
26/11/2023 03:00	29.8	14.6	456.7	13.5	178.1	12.6
26/11/2023 04:00	29.07	14.6	456.3	13.1	178.1	12.3
26/11/2023 05:00	27.72	14.6	456.5	12.5	178.1	11.8
26/11/2023 06:00	27.05	14.6	456.2	12.2	178.3	11.5
26/11/2023 07:00	26.73	14.6	456.1	12.1	178.4	11.3
26/11/2023 08:00	26.04	14.6	454.1	11.8	177.3	11.1
26/11/2023 09:00	24.5	14.6	452.8	11.1	176.7	10.4
26/11/2023 10:00	23.74	14.6	450.5	10.8	176.4	10.1
26/11/2023 11:00	23.01	14.6	448.4	10.5	176.3	9.8
26/11/2023 12:00	22.69	14.6	446.8	10.3	176.2	9.6
26/11/2023 13:00	24.8	14.6	444.8	11.3	175.8	10.5
26/11/2023 14:00	29.17	14.6	443.1	13.3	175.5	12.4
26/11/2023 15:00	29.73	14.6	442.9	13.5	175.4	12.6
26/11/2023 16:00	29.77	14.6	444.8	13.6	175.6	12.6
26/11/2023 17:00	29.91	14.6	447	13.6	176.1	12.7
26/11/2023 18:00	27.76	14.6	448.8	12.7	176.4	11.8
26/11/2023 19:00	28.67	14.6	449.8	13.1	176.9	12.2
26/11/2023 20:00	28.89	14.6	450.4	13.2	177.1	12.3
26/11/2023 21:00	29.19	14.5	451.4	13.3	177.2	12.4
26/11/2023 22:00	29.24	14.5	452.6	13.4	177.3	12.4
26/11/2023 23:00	29.76	14.5	452.9	13.6	177.1	12.6
27/11/2023 00:00	30.08	14.6	454.6	13.7	177.5	12.8
27/11/2023 01:00	27.39	14.6	455.4	12.5	178.1	11.6
27/11/2023 02:00	26.43	14.6	455.7	12	178.2	11.2
27/11/2023 03:00	26.83	14.6	455.3	12.2	178.1	11.4
27/11/2023 04:00	26.77	14.6	455.2	12.2	178	11.4
27/11/2023 05:00	27.05	14.6	455.3	12.3	178	11.5
27/11/2023 06:00	27.24	14.6	454.7	12.4	178.2	11.6
27/11/2023 07:00	27.77	14.6	455.8	12.6	178.2	11.8
27/11/2023 08:00	27.57	14.6	454.6	12.6	177.1	11.7
27/11/2023 09:00	29.72	14.6	452.9	13.6	176.8	12.6
27/11/2023 10:00	27.79	14.6	452.5	12.7	176.9	11.8
27/11/2023 11:00	26.84	14.6	450.4	12.2	176.4	11.4
27/11/2023 12:00	29.24	14.6	448.7	13.3	176.3	12.4
27/11/2023 13:00	28.14	14.6	447	12.8	176.1	11.9
27/11/2023 14:00	28.3	14.6	446.6	12.9	176.1	12
27/11/2023 15:00	29.4	14.6	447.8	13.4	176.2	12.5
27/11/2023 16:00	29.2	14.6	448.8	13.3	176.3	12.4
27/11/2023 17:00	30.16	14.6	450	13.8	176.7	12.8
27/11/2023 18:00	28.31	14.6	452.1	12.9	177.2	12
27/11/2023 19:00	27.02	14.6	455	12.3	177.7	11.5
27/11/2023 20:00	26.94	14.6	455.8	12.2	178.4	11.4
27/11/2023 21:00	27.67	14.6	455.9	12.5	178.4	11.7
27/11/2023 22:00	27.85	14.6	455.5	12.6	178.5	11.8
27/11/2023 23:00	27.92	14.6	454.1	12.7	178.3	11.9
28/11/2023 00:00	28.55	14.6	454.2	13	177.8	12.1

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
28/11/2023 01:00	29.27	14.6	453.1	13.3	177.5	12.4
28/11/2023 02:00	28.83	14.6	453.9	13.1	177.8	12.2
28/11/2023 03:00	27.24	14.6	452.3	12.4	177.9	11.6
28/11/2023 04:00	27.9	14.6	451.9	12.7	178	11.8
28/11/2023 05:00	28.39	14.6	451.1	12.9	177.6	12.1
28/11/2023 06:00	28.58	14.6	450.2	13	177.6	12.1
28/11/2023 07:00	28.6	14.6	450.2	13	177.4	12.1
28/11/2023 08:00	28.97	14.6	454.5	13.1	177.9	12.3
28/11/2023 09:00	28.84	14.6	456.8	13	178.2	12.2
28/11/2023 10:00	28.83	14.6	453.8	13.1	176.9	12.2
28/11/2023 11:00	30.54	14.6	452	13.9	176.5	13
28/11/2023 12:00	30.24	14.6	449.1	13.7	175.7	12.8
28/11/2023 13:00	30.23	14.6	447.8	13.7	176.1	12.8
28/11/2023 14:00	30.71	14.6	446.9	13.9	176	13
28/11/2023 15:00	30.12	14.6	447.4	13.7	175.5	12.8
28/11/2023 16:00	29.9	14.6	450	13.6	176.5	12.7
28/11/2023 17:00	29.86	14.6	451.1	13.6	176.7	12.7
28/11/2023 18:00	28.12	14.6	453.2	12.8	176.8	11.9
28/11/2023 19:00	29.16	14.6	455.5	13.3	177.8	12.4
28/11/2023 20:00	27.44	14.6	454.5	12.4	178.2	11.6
28/11/2023 21:00	27.9	14.6	454.6	12.6	178.3	11.8
28/11/2023 22:00	29.35	14.6	455.7	13.3	177.7	12.5
28/11/2023 23:00	29.12	14.6	455.6	13.2	177.8	12.4
29/11/2023 00:00	29.2	14.6	454	13.2	178.1	12.4
29/11/2023 01:00	29.37	14.6	452.1	13.3	177.2	12.5
29/11/2023 02:00	29.35	14.6	452.6	13.3	177.8	12.5
29/11/2023 03:00	28.57	14.6	451.7	13	177.1	12.1
29/11/2023 04:00	28.2	14.6	451.2	12.8	177.4	12
29/11/2023 05:00	27.54	14.6	449.9	12.5	177.2	11.7
29/11/2023 06:00	26.81	14.6	448.5	12.2	176.9	11.4
29/11/2023 07:00	27.22	14.6	450.5	12.4	177.5	11.6
29/11/2023 08:00	27.54	14.6	454.9	12.4	177.6	11.7
29/11/2023 09:00	27.56	14.6	455.5	12.5	177.7	11.7
29/11/2023 10:00	26.74	14.6	451.9	12.1	176.7	11.3
29/11/2023 11:00	26.06	14.6	449	11.8	176.1	11.1
29/11/2023 12:00	25.91	14.6	447.1	11.7	176.2	11
29/11/2023 13:00	26.71	14.6	445.4	12.1	175.3	11.3
29/11/2023 14:00	26.99	14.6	445.9	12.2	176	11.5
29/11/2023 15:00	26.91	14.6	445.6	12.2	175.5	11.4
29/11/2023 16:00	26.7	14.6	446.8	12.1	176.2	11.3
29/11/2023 17:00	25.88	14.6	447.3	11.8	176.4	11
29/11/2023 18:00	26.26	14.6	449.8	12	176.5	11.1
29/11/2023 19:00	25.98	14.5	451.5	11.9	177.3	11
29/11/2023 20:00	26.38	14.5	452.9	12.1	176.9	11.2
29/11/2023 21:00	26.89	14.5	454.1	12.3	177.6	11.4
29/11/2023 22:00	28.47	14.6	455.2	12.9	177.6	12.1
29/11/2023 23:00	29.64	14.6	456	13.5	177.8	12.6
30/11/2023 00:00	28.02	14.6	456	12.7	178.3	11.9
30/11/2023 01:00	27.56	14.6	456.1	12.5	177.5	11.7
30/11/2023 02:00	27.44	14.6	455.6	12.4	178	11.6
30/11/2023 03:00	27.41	14.6	455.4	12.4	178	11.6
30/11/2023 04:00	28.19	14.6	455.6	12.8	177.9	12
30/11/2023 05:00	27.88	14.6	455	12.6	178.2	11.8
30/11/2023 06:00	27.62	14.6	454.3	12.5	177.7	11.7
30/11/2023 07:00	27.83	14.6	455.8	12.6	178.3	11.8
30/11/2023 08:00	26.16	14.6	453.7	11.9	177.2	11.1
30/11/2023 09:00	25.28	14.6	449.9	11.5	176.4	10.7
30/11/2023 10:00	26.68	14.6	446.1	12.1	176.1	11.3
30/11/2023 11:00	26.95	14.6	444.4	12.2	175.4	11.4

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
01/12/2023 00:00	28.73	14.6	455	13.1	177.6	12.2
01/12/2023 01:00	29.9	14.6	455.5	13.6	177.1	12.7
01/12/2023 02:00	29.16	14.6	455.2	13.3	176.9	12.4
01/12/2023 03:00	28.58	14.6	455.6	13	177.5	12.1
01/12/2023 04:00	28.9	14.6	455.1	13.2	177.2	12.3
01/12/2023 05:00	29.21	14.5	453.9	13.4	176.6	12.4
01/12/2023 06:00	29.02	14.5	454.1	13.3	177.1	12.3
01/12/2023 07:00	28.25	14.6	454	12.9	177.2	12
01/12/2023 08:00	26.97	14.5	452.6	12.3	176.8	11.4
01/12/2023 09:00	25.52	14.5	449.8	11.7	176.4	10.8
01/12/2023 10:00	23.99	14.5	448	11	175.9	10.2
01/12/2023 11:00	23.85	14.6	446	10.9	175.8	10.1
01/12/2023 12:00	25.89	14.5	445.5	11.8	175.6	11
01/12/2023 13:00	26.3	14.5	444	12	175.6	11.2
01/12/2023 14:00	26.99	14.5	444.8	12.4	175.3	11.5
01/12/2023 15:00	26.72	14.5	451.5	12.3	175.6	11.3
01/12/2023 16:00	26.86	14.5	449.6	12.4	176.1	11.4
01/12/2023 17:00	26	14.5	449.8	12	176.1	11
01/12/2023 18:00	25.91	14.5	452.1	12	176.8	11
01/12/2023 19:00	25.83	14.5	452.4	11.9	177.4	11
01/12/2023 20:00	26.61	14.5	461.9	12.3	177.1	11.3
01/12/2023 21:00	27.44	14.5	479.8	12.6	177.4	11.6
01/12/2023 22:00	28.19	14.5	480.9	12.9	177.8	12
01/12/2023 23:00	29.56	14.5	485.4	13.5	177.8	12.5
02/12/2023 00:00	28.76	14.5	482.2	13.2	177.2	12.2
02/12/2023 01:00	28.35	14.5	483.1	13	177.2	12
02/12/2023 02:00	28.56	14.6	480.1	13	178	12.1
02/12/2023 03:00	28.71	14.6	482.2	13.1	177.8	12.2
02/12/2023 04:00	28.9	14.6	475.8	13.2	178.1	12.3
02/12/2023 05:00	29.94	14.6	470.3	13.6	178.4	12.7
02/12/2023 06:00	29.44	14.6	456.2	13.4	178.2	12.5
02/12/2023 07:00	28.86	14.6	455.6	13.1	178.5	12.3
02/12/2023 08:00	25.79	14.5	452.8	11.8	177.1	10.9
02/12/2023 09:00	24.58	14.5	450.4	11.2	176.7	10.4
02/12/2023 10:00	24.61	14.6	448.3	11.2	176.2	10.4
02/12/2023 11:00	25.59	14.6	446	11.7	175.8	10.9
02/12/2023 12:00	26.94	14.6	444.6	12.3	175.7	11.4
02/12/2023 13:00	27.43	14.6	444	12.5	175.3	11.6
02/12/2023 14:00	27.31	14.6	443.5	12.4	175.7	11.6
02/12/2023 15:00	27.84	14.6	443.2	12.7	175.8	11.8
02/12/2023 16:00	28.19	14.6	444.6	12.8	176	12
02/12/2023 17:00	28.25	14.6	445.5	12.9	176	12
02/12/2023 18:00	29.26	14.6	447.7	13.3	176.1	12.4
02/12/2023 19:00	29.46	14.6	449.7	13.4	176.6	12.5
02/12/2023 20:00	28.98	14.5	451.4	13.2	176.9	12.3
02/12/2023 21:00	29.02	14.5	454.1	13.3	177.2	12.3
02/12/2023 22:00	29.02	14.5	453.9	13.3	177.4	12.3
02/12/2023 23:00	29.6	14.5	454.1	13.5	176.9	12.6
03/12/2023 00:00	26.16	14.5	461.2	12	177.3	11.1
03/12/2023 01:00	23.72	14.5	465.5	10.9	177	10.1
03/12/2023 02:00	23.87	14.5	454.3	10.9	177	10.1
03/12/2023 03:00	26.23	14.5	454.7	12	177.2	11.1
03/12/2023 04:00	28.7	14.6	454.3	13.1	177	12.2
03/12/2023 05:00	29.7	14.6	454.8	13.5	177.2	12.6
03/12/2023 06:00	27.95	14.6	455.4	12.7	177.5	11.9
03/12/2023 07:00	26.16	14.6	454.6	11.9	177.3	11.1
03/12/2023 08:00	27.76	14.6	453.2	12.7	176.9	11.8
03/12/2023 09:00	27.3	14.6	450.2	12.5	176.2	11.6
03/12/2023 10:00	26.46	14.6	447.2	12.1	176.1	11.2

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
03/12/2023 11:00	26.75	14.6	446.3	12.2	175.8	11.4
03/12/2023 12:00	27.43	14.6	444.6	12.5	175.4	11.6
03/12/2023 13:00	27.92	14.6	443.5	12.7	175.3	11.9
03/12/2023 14:00	28.26	14.6	444.8	12.9	175.1	12
03/12/2023 15:00	28.09	14.5	446.5	12.9	176.2	11.9
03/12/2023 16:00	28.98	14.5	446.4	13.2	175.9	12.3
03/12/2023 17:00	29.35	14.5	448.5	13.4	176.1	12.5
03/12/2023 18:00	29.67	14.5	451.3	13.6	176.7	12.6
03/12/2023 19:00	26	14.5	451.8	11.9	176.6	11
03/12/2023 20:00	24.46	14.5	453.2	11.2	177.3	10.4
03/12/2023 21:00	24.63	14.5	453.1	11.3	177.6	10.5
03/12/2023 22:00	24.96	14.5	454.2	11.4	177.6	10.6
03/12/2023 23:00	24.86	14.5	454.3	11.4	178	10.6
04/12/2023 00:00	25.06	14.5	453.9	11.5	177.8	10.6
04/12/2023 01:00	26.13	14.5	454	12	177.9	11.1
04/12/2023 02:00	26.5	14.5	453.2	12.2	177.5	11.2
04/12/2023 03:00	26.94	14.5	453.7	12.4	177.4	11.4
04/12/2023 04:00	27.8	14.5	453.4	12.8	177.4	11.8
04/12/2023 05:00	27.65	14.5	454.5	12.7	177.8	11.7
04/12/2023 06:00	27.59	14.6	455.4	12.6	178.3	11.7
04/12/2023 07:00	27.51	14.6	455.4	12.5	178.3	11.7
04/12/2023 08:00	28.34	14.5	452.8	13	177.2	12
04/12/2023 09:00	28.78	14.5	451.8	13.2	177	12.2
04/12/2023 10:00	27.28	14.5	449.4	12.6	175.6	11.6
04/12/2023 11:00	29.74	14.3	445.9	14.2	167.8	12.6
04/12/2023 12:00	30.25	14.3	443.8	14.4	167.8	12.8
04/12/2023 13:00	26.37	14.3	441.6	12.6	167.3	11.2
04/12/2023 14:00	25.71	14.3	441.6	12.3	167.3	10.9
04/12/2023 15:00	25.85	14.3	441.3	12.4	167.1	11
04/12/2023 16:00	25.17	14.2	444.8	12.1	166.5	10.7
04/12/2023 17:00	27.83	14.2	452.1	13.3	168.8	11.8
04/12/2023 18:00	26.84	14.3	453.4	12.8	169.5	11.4
04/12/2023 19:00	25.81	14.3	453.1	12.3	169.8	11
04/12/2023 20:00	25.23	14.3	453.2	12	170.1	10.7
04/12/2023 21:00	23.55	14.5	454.8	10.8	176.8	10
04/12/2023 22:00	24.6	14.6	455.5	11.2	178.5	10.4
04/12/2023 23:00	24.86	14.6	454.9	11.4	178.5	10.6
05/12/2023 00:00	25.56	14.6	455.4	11.7	178.3	10.9
05/12/2023 01:00	26.08	14.6	454.6	11.9	178.2	11.1
05/12/2023 02:00	26.76	14.6	455.1	12.2	178.3	11.4
05/12/2023 03:00	27.87	14.5	454.7	12.7	178.5	11.8
05/12/2023 04:00	28.06	14.5	452.3	12.9	177.5	11.9
05/12/2023 05:00	27.4	14.5	454	12.5	177.9	11.6
05/12/2023 06:00	25.04	14.6	454.1	11.4	178.8	10.6
05/12/2023 07:00	23.71	14.6	454.5	10.8	178.5	10.1
05/12/2023 08:00	22.89	14.5	452.5	10.5	177.6	9.7
05/12/2023 09:00	23.73	14.5	448.9	10.9	176.6	10.1
05/12/2023 10:00	23.81	14.6	446.9	10.9	176.3	10.1
05/12/2023 11:00	25.94	14.6	444.3	11.8	175.9	11
05/12/2023 12:00	26.88	14.6	443.6	12.3	175.8	11.4
05/12/2023 13:00	27.55	14.5	442.1	12.6	175.9	11.7
05/12/2023 14:00	25.99	14.5	443.2	11.9	175.7	11
05/12/2023 15:00	27.26	14.5	451.3	12.5	176.6	11.6
05/12/2023 16:00	28.37	14.5	452.2	13	176.9	12
05/12/2023 17:00	28.72	14.5	452.4	13.2	177	12.2
05/12/2023 18:00	28.34	14.5	453.8	13	177.4	12
05/12/2023 19:00	28.19	14.5	454.4	12.9	177.9	12
05/12/2023 20:00	27.69	14.5	455.9	12.7	178.3	11.8
05/12/2023 21:00	28.23	14.6	455.1	12.9	178.6	12

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
05/12/2023 22:00	28.14	14.5	454.9	12.9	178.5	11.9
05/12/2023 23:00	28.4	14.5	455.1	13	178.6	12.1
06/12/2023 00:00	28.23	14.5	454.7	12.9	178.7	12
06/12/2023 01:00	28.73	14.5	454.5	13.1	178.8	12.2
06/12/2023 02:00	29.53	14.5	454	13.5	178.7	12.5
06/12/2023 03:00	29.07	14.5	453.6	13.3	178.6	12.3
06/12/2023 04:00	24.51	14.6	469.6	11.2	178.9	10.4
06/12/2023 05:00	26.81	14.5	476.6	12.3	178.8	11.4
06/12/2023 06:00	27.13	14.5	461	12.4	178.7	11.5
06/12/2023 07:00	26.3	14.5	454.7	12	178.7	11.2
06/12/2023 08:00	26.24	14.5	450.9	12.1	177.3	11.1
06/12/2023 09:00	26.16	14.5	448.3	12	176.7	11.1
06/12/2023 10:00	26.61	14.6	445.5	12.2	176.2	11.3
06/12/2023 11:00	26.89	14.6	444.3	12.3	176.1	11.4
06/12/2023 12:00	27.63	14.6	442.8	12.6	176	11.7
06/12/2023 13:00	26.54	14.5	442.1	12.2	175.7	11.3
06/12/2023 14:00	27.16	14.5	440.8	12.4	175.2	11.5
06/12/2023 15:00	26.79	14.5	441.1	12.3	175.1	11.4
06/12/2023 16:00	26.6	14.5	443.4	12.2	175.6	11.3
06/12/2023 17:00	26.57	14.5	443.2	12.2	174.9	11.3
06/12/2023 18:00	25.16	14.5	446.3	11.6	175.2	10.7
06/12/2023 19:00	23.7	14.5	450.4	10.9	176.1	10.1
06/12/2023 20:00	22.98	14.5	451.1	10.6	176.5	9.8
06/12/2023 21:00	28.37	14.5	451	13.1	176.9	12
06/12/2023 22:00	28.58	14.5	453.5	13.1	177.3	12.1
06/12/2023 23:00	29.26	14.5	453.6	13.4	178.3	12.4
07/12/2023 00:00	29.88	14.5	454.2	13.7	178.5	12.7
07/12/2023 01:00	30.26	14.5	454.4	13.8	178.4	12.8
07/12/2023 02:00	26.82	14.5	454.7	12.3	178.5	11.4
07/12/2023 03:00	24.83	14.5	454.3	11.4	178.4	10.5
07/12/2023 04:00	24.56	14.5	454.1	11.2	178.3	10.4
07/12/2023 05:00	24.35	14.5	455	11.1	178.4	10.3
07/12/2023 06:00	24.55	14.6	455	11.2	178.1	10.4
07/12/2023 07:00	24.5	14.6	455.2	11.2	178.5	10.4
07/12/2023 08:00	25.15	14.5	452.3	11.5	177.2	10.7
07/12/2023 09:00	25.44	14.5	448.4	11.6	176.8	10.8
07/12/2023 10:00	25.47	14.6	447.7	11.6	176.6	10.8
07/12/2023 11:00	26.19	14.6	446.3	11.9	176.1	11.1
07/12/2023 12:00	27.02	14.6	444.1	12.3	176	11.5
07/12/2023 13:00	27.36	14.6	442.8	12.5	175.6	11.6
07/12/2023 14:00	25.03	14.5	442	11.4	175.5	10.6
07/12/2023 15:00	24.53	14.5	441.9	11.2	175	10.4
07/12/2023 16:00	23.84	14.5	443	10.9	175.3	10.1
07/12/2023 17:00	24.4	14.5	443.7	11.2	175.2	10.4
07/12/2023 18:00	25.66	14.5	448.5	11.8	175.4	10.9
07/12/2023 19:00	25.18	14.6	453.1	11.5	177.3	10.7
07/12/2023 20:00	25.71	14.6	453.3	11.7	177.9	10.9
07/12/2023 21:00	25.66	14.6	453.1	11.7	178	10.9
07/12/2023 22:00	26.05	14.6	453.9	11.9	178.2	11.1
07/12/2023 23:00	26.41	14.6	452.9	12	178.3	11.2
08/12/2023 00:00	26.71	14.6	451.2	12.2	177.9	11.3
08/12/2023 01:00	27.11	14.6	451.6	12.4	178	11.5
08/12/2023 02:00	28.05	14.6	451.3	12.8	178	11.9
08/12/2023 03:00	29.26	14.6	452.2	13.4	177.9	12.4
08/12/2023 04:00	29.2	14.5	450.7	13.3	177.9	12.4
08/12/2023 05:00	26.13	14.6	451.7	11.9	177.9	11.1
08/12/2023 06:00	25.05	14.6	451.2	11.4	178	10.6
08/12/2023 07:00	26.19	14.6	453.4	11.9	178.1	11.1
08/12/2023 08:00	26.88	14.6	452.6	12.2	177.6	11.4

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
10/12/2023 20:00	27.05	14.5	450.5	12.4	176.7	11.5
10/12/2023 21:00	27	14.5	452.6	12.4	177.6	11.5
10/12/2023 22:00	27.67	14.5	453.9	12.7	177.9	11.7
10/12/2023 23:00	27.14	14.5	454	12.4	178.3	11.5
11/12/2023 00:00	25.69	14.5	455	11.8	178.4	10.9
11/12/2023 01:00	25.7	14.6	454.4	11.7	178.7	10.9
11/12/2023 02:00	26.18	14.6	454.5	12	178.8	11.1
11/12/2023 03:00	26.4	14.5	453.3	12.1	178.8	11.2
11/12/2023 04:00	26.62	14.5	453.8	12.2	178.5	11.3
11/12/2023 05:00	27.03	14.6	453.8	12.3	178.7	11.5
11/12/2023 06:00	26.8	14.6	454.2	12.2	178.7	11.4
11/12/2023 07:00	26.06	14.5	453.6	11.9	178.4	11.1
11/12/2023 08:00	25.4	14.5	451	11.7	177.4	10.8
11/12/2023 09:00	24.74	14.5	448.4	11.3	176.9	10.5
11/12/2023 10:00	24.47	14.5	447.3	11.2	176.7	10.4
11/12/2023 11:00	25.1	14.6	445.3	11.5	176.2	10.7
11/12/2023 12:00	24.52	14.5	442.6	11.2	175.6	10.4
11/12/2023 13:00	24.92	14.5	440.3	11.4	175	10.6
11/12/2023 14:00	26.74	14.6	440.3	12.2	174.7	11.4
11/12/2023 15:00	27.26	14.6	440.6	12.4	175	11.6
11/12/2023 16:00	27.57	14.6	443.8	12.6	175.4	11.7
11/12/2023 17:00	28.6	14.5	445.9	13.1	175.7	12.1
11/12/2023 18:00	27.35	14.5	449.3	12.6	176.7	11.6
11/12/2023 19:00	27.82	14.5	450.8	12.8	176.9	11.8
11/12/2023 20:00	28.37	14.5	451.4	13.1	176.8	12
11/12/2023 21:00	25.36	13.7	449.1	13.1	159.9	10.8
11/12/2023 22:00	20.41	13.1	398	11.4	144.3	8.7
11/12/2023 23:00	17.72	13	366.7	10.1	140.2	7.5
12/12/2023 00:00	18.12	13	366.6	10.4	139.9	7.7
12/12/2023 01:00	16.38	13.2	366.6	9.1	142.6	7
12/12/2023 02:00	16.25	13.4	366.9	8.8	145	6.9
12/12/2023 03:00	16.86	13.4	366	9.1	144.7	7.2
12/12/2023 04:00	17.03	13.4	366.8	9.2	144.6	7.2
12/12/2023 05:00	17.09	13.4	366.6	9.2	145.2	7.3
12/12/2023 06:00	16.65	13.5	366.8	8.9	146.1	7.1
12/12/2023 07:00	15.2	13.5	366.9	8.1	147.1	6.5
12/12/2023 08:00	14.13	13.5	367.3	7.5	147.5	6
12/12/2023 09:00	13.91	13.6	367.9	7.3	147.3	5.9
12/12/2023 10:00	19.33	13.5	396.5	10.2	147.6	8.2
12/12/2023 11:00	23.83	13.3	413.8	13	145.4	10.1
12/12/2023 12:00	22.58	13.3	407.9	12.4	144.1	9.6
12/12/2023 13:00	23.1	13.2	405.4	12.7	143.7	9.8
12/12/2023 14:00	25.3	13.3	413.1	13.8	144	10.7
12/12/2023 15:00	21.16	13.5	404.4	11.3	146.3	9
12/12/2023 16:00	19.89	13.5	402.7	10.6	147.1	8.4
12/12/2023 17:00	20.12	13.5	401.2	10.7	146.5	8.5
12/12/2023 18:00	21.43	13.5	399	11.4	147	9.1
12/12/2023 19:00	19.93	13.4	395.3	10.7	147.2	8.5
12/12/2023 20:00	16.83	13.3	376.9	9.2	145.3	7.1
12/12/2023 21:00	17.72	13.3	376.2	9.7	144.5	7.5
12/12/2023 22:00	18.47	13.3	376.2	10.1	144.5	7.8
12/12/2023 23:00	18.68	13.3	376.2	10.3	144.4	7.9
13/12/2023 00:00	19.06	13.3	375.2	10.5	144.3	8.1
13/12/2023 01:00	19.85	13.3	375.6	10.9	144	8.4
13/12/2023 02:00	20.42	13.3	374.7	11.2	144.3	8.7
13/12/2023 03:00	20.8	13.3	374.8	11.4	144.4	8.8
13/12/2023 04:00	21.54	13.2	375.1	12	143.4	9.1
13/12/2023 05:00	21.67	13.2	375.1	12.1	143	9.2
13/12/2023 06:00	21.76	13.2	374.8	12.1	143.1	9.2

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
13/12/2023 07:00	20.7	13.2	375.4	11.5	143.4	8.8
13/12/2023 08:00	19.26	13.2	375.7	10.7	143.2	8.2
13/12/2023 09:00	19.21	13.2	377.3	10.6	143.3	8.2
13/12/2023 10:00	20.37	13.2	378.1	11.3	142.4	8.6
13/12/2023 11:00	21.51	13.2	379.2	11.9	142.6	9.1
13/12/2023 12:00	23.53	13.2	380	13	142.2	10
13/12/2023 13:00	24.72	13.3	380.4	13.6	142.3	10.5
13/12/2023 14:00	24	13.2	380.1	13.2	142.5	10.2
13/12/2023 15:00	23.35	13.2	379.8	12.9	142.3	9.9
13/12/2023 16:00	22.65	13.2	378.7	12.6	141.9	9.6
13/12/2023 17:00	22.93	13.2	379	12.7	141.7	9.7
13/12/2023 18:00	22.25	13.2	381.2	12.4	141.9	9.4
13/12/2023 19:00	21.59	13.1	422.4	12	142.1	9.2
13/12/2023 20:00	21.41	13.1	419.7	12	142.1	9.1
13/12/2023 21:00	22.1	13.1	415.3	12.4	142.1	9.4
13/12/2023 22:00	22.62	13.1	398.7	12.6	142	9.6
13/12/2023 23:00	24.52	13.2	412.8	13.7	142.2	10.4
14/12/2023 00:00	26.59	13.2	403.7	14.7	142.6	11.3
14/12/2023 01:00	27.25	13.2	411	15.1	142.4	11.6
14/12/2023 02:00	28.2	13.2	395.7	15.6	142.4	12
14/12/2023 03:00	28.58	13.1	410.1	16	141.5	12.1
14/12/2023 04:00	28.31	13	400.2	16	140.2	12
14/12/2023 05:00	24.15	13.1	402.7	13.5	141.7	10.2
14/12/2023 06:00	23.52	13.1	405.1	13.1	141.4	10
14/12/2023 07:00	21.68	13.3	391.1	11.9	143.5	9.2
14/12/2023 08:00	18.65	13.4	385.6	10.1	144.6	7.9
14/12/2023 09:00	16.92	13.4	377.6	9.1	145	7.2
14/12/2023 10:00	17.45	13.5	384.3	9.3	144.9	7.4
14/12/2023 11:00	19.04	13.5	390.1	10.1	145.2	8.1
14/12/2023 12:00	21.33	13.5	390.3	11.3	145.1	9.1
14/12/2023 13:00	22.22	13.5	390.1	11.8	145.1	9.4
14/12/2023 14:00	21.58	13.5	392.2	11.5	144.6	9.2
14/12/2023 15:00	20.37	13.5	391.6	10.9	144.2	8.6
14/12/2023 16:00	20.2	13.5	390.6	10.8	144.2	8.6
14/12/2023 17:00	19.95	13.4	389.6	10.7	144.7	8.5
14/12/2023 18:00	19.84	13.4	388.6	10.7	145.3	8.4
14/12/2023 19:00	18.71	13.5	388.4	9.9	146.8	7.9
14/12/2023 20:00	17.73	13.6	387.7	9.3	147.7	7.5
14/12/2023 21:00	16.73	13.7	387	8.7	151	7.1
14/12/2023 22:00	16.59	13.7	386.2	8.6	151	7
14/12/2023 23:00	18.85	13.9	395.9	9.5	156	8
15/12/2023 00:00	19.72	13.9	395.9	10	157.1	8.4
15/12/2023 01:00	20.36	13.8	395.4	10.4	155.1	8.6
15/12/2023 02:00	21.62	13.9	395.2	10.9	156.6	9.2
15/12/2023 03:00	22.64	13.9	395.4	11.4	157	9.6
15/12/2023 04:00	23.22	13.9	395.5	11.7	157.1	9.9
15/12/2023 05:00	25.96	13.9	401.9	13.1	156.6	11
15/12/2023 06:00	27.06	14	405.4	13.5	160.1	11.5
15/12/2023 07:00	27.01	14	408.2	13.5	159	11.5
15/12/2023 08:00	28.52	14	420.6	14.1	160.7	12.1
15/12/2023 09:00	28.89	14.1	425.5	14.2	161.4	12.3
15/12/2023 10:00	25.65	14.1	430	12.5	161.8	10.9
15/12/2023 11:00	26.36	14.2	433.3	12.8	162.1	11.2
15/12/2023 12:00	27.93	14.2	434	13.5	162.4	11.9
15/12/2023 13:00	29.03	14.1	433.8	14.1	161.8	12.3
15/12/2023 14:00	27.14	14.1	432.9	13.2	160.6	11.5
15/12/2023 15:00	27.98	14.2	433.6	13.6	162	11.9
15/12/2023 16:00	27.77	14.2	439.3	13.5	162.4	11.8
15/12/2023 17:00	29.49	14.2	441.7	14.3	164.2	12.5

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
15/12/2023 18:00	26.01	14.2	444.3	12.6	165	11
15/12/2023 19:00	24.88	14.2	445.6	12	166.1	10.6
15/12/2023 20:00	25.06	14.2	447.1	12.1	166.4	10.6
15/12/2023 21:00	25.17	14.2	448.7	12.1	167.3	10.7
15/12/2023 22:00	25.4	14.2	448.9	12.3	167.4	10.8
15/12/2023 23:00	25.7	14.2	450.5	12.4	167.8	10.9
16/12/2023 00:00	25.77	14.2	451.3	12.3	169.4	10.9
16/12/2023 01:00	26.01	14.2	469.5	12.4	169.3	11
16/12/2023 02:00	26.31	14.3	451	12.6	169.5	11.2
16/12/2023 03:00	26.84	14.3	450.5	12.8	169.6	11.4
16/12/2023 04:00	26.96	14.3	450.8	12.9	169.8	11.4
16/12/2023 05:00	27.34	14.3	475.3	13	169.3	11.6
16/12/2023 06:00	27.12	14.3	463	12.9	169.5	11.5
16/12/2023 07:00	25.81	14.2	451.1	12.4	169.4	11
16/12/2023 08:00	24	14.2	446.5	11.6	165.5	10.2
16/12/2023 09:00	22.74	14.2	458.5	11	166.2	9.7
16/12/2023 10:00	24.17	14.2	457.2	11.6	165.7	10.3
16/12/2023 11:00	24.82	14.2	448.6	11.9	164.5	10.5
16/12/2023 12:00	26.93	14.2	437.2	13	163.9	11.4
16/12/2023 13:00	24.66	14.2	433.4	12	162.5	10.5
16/12/2023 14:00	25.24	14.2	433.7	12.2	161.8	10.7
16/12/2023 15:00	25.38	14.2	434.4	12.3	162.1	10.8
16/12/2023 16:00	<Samp	<Samp	437.8	<Samp	162.9	<Samp
16/12/2023 17:00	26.3	14.2	438.5	12.8	163.4	11.2
16/12/2023 18:00	27.13	14.2	440.9	13.1	164.1	11.5
16/12/2023 19:00	26.48	14.2	446.5	12.8	165.9	11.2
16/12/2023 20:00	27.07	14.2	448.8	13	168.5	11.5
16/12/2023 21:00	26.03	14.3	450.7	12.4	169.1	11
16/12/2023 22:00	21.73	14.5	453	9.9	177.5	9.2
16/12/2023 23:00	21.51	14.6	453.1	9.8	178.6	9.1
17/12/2023 00:00	22.57	14.6	453.4	10.3	178.5	9.6
17/12/2023 01:00	23.06	14.6	452.5	10.5	178.9	9.8
17/12/2023 02:00	23.05	14.6	451.2	10.5	178.9	9.8
17/12/2023 03:00	20.7	14.6	430	9.4	177.4	8.8
17/12/2023 04:00	11.1	15.5	357.8	4.3	182.5	4.7
17/12/2023 05:00	12.13	15.6	357.4	4.6	186.5	5.1
17/12/2023 06:00	12.38	15.6	356.9	4.7	187	5.3
17/12/2023 07:00	13.09	15.6	356.8	5	187	5.6
17/12/2023 08:00	12.94	15.6	355.4	4.9	186.4	5.5
17/12/2023 09:00	13.86	15.6	354.2	5.3	185.6	5.9
17/12/2023 10:00	10.84	15.6	353.4	4.1	185.1	4.6
17/12/2023 11:00	11.9	15.6	352.5	4.5	184.9	5.1
17/12/2023 12:00	13.31	15.6	350.9	5.1	184.1	5.7
17/12/2023 13:00	13.77	15.6	350.6	5.3	183.9	5.8
17/12/2023 14:00	15.2	15.6	350.2	5.8	184.3	6.5
17/12/2023 15:00	15.21	15.6	349.1	5.8	183.7	6.5
17/12/2023 16:00	15.1	15.6	349.4	5.8	183.3	6.4
17/12/2023 17:00	15.23	15.5	351.1	5.9	183.5	6.5
17/12/2023 18:00	19.91	14.8	397.2	8.8	178.2	8.5
17/12/2023 19:00	24.44	14.6	445.8	11.1	176.7	10.4
17/12/2023 20:00	23.65	14.5	450.6	10.8	176.7	10
17/12/2023 21:00	24.05	14.5	453.8	11	176.9	10.2
17/12/2023 22:00	24.08	14.6	454.9	11	177.1	10.2
17/12/2023 23:00	23.61	14.6	456	10.8	177.6	10
17/12/2023 00:00	24.35	14.6	454.9	11.1	177.8	10.3
18/12/2023 01:00	24.35	14.6	455	11	178	10.3
18/12/2023 02:00	26.14	14.6	456.2	11.8	177.8	11.1
18/12/2023 03:00	25.92	14.6	454.6	11.8	177.7	11
18/12/2023 04:00	24.71	14.6	480.8	11.2	177.6	10.5

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
20/12/2023 16:00	25.67	14.5	440.9	11.7	174.7	10.9
20/12/2023 17:00	26.35	14.5	442.9	12.1	175	11.2
20/12/2023 18:00	26.2	14.5	445	12	175.2	11.1
20/12/2023 19:00	25.67	14.5	449.2	11.8	176.3	10.9
20/12/2023 20:00	25.95	14.5	450.5	11.9	176.7	11
20/12/2023 21:00	26.65	14.5	453.6	12.2	176.9	11.3
20/12/2023 22:00	27.32	14.6	454.5	12.5	177.2	11.6
20/12/2023 23:00	27.2	14.6	455.3	12.3	177.1	11.5
21/12/2023 00:00	28.64	14.6	455.4	13	177.2	12.2
21/12/2023 01:00	29.31	14.6	454.6	13.3	177.3	12.4
21/12/2023 02:00	28.4	14.6	454.8	12.9	177.4	12.1
21/12/2023 03:00	28.22	14.6	453.7	12.8	177.1	12
21/12/2023 04:00	28.32	14.6	452.8	12.8	177.1	12
21/12/2023 05:00	28.03	14.6	452.6	12.7	177.5	11.9
21/12/2023 06:00	26.92	14.6	450.7	12.2	177	11.4
21/12/2023 07:00	26.07	14.6	450.6	11.8	176.6	11.1
21/12/2023 08:00	25.31	14.6	455.3	11.4	177.7	10.7
21/12/2023 09:00	26.2	14.6	454.7	11.8	177.1	11.1
21/12/2023 10:00	25.79	14.6	451.5	11.7	176.3	10.9
21/12/2023 11:00	25.04	14.6	448.6	11.3	176	10.6
21/12/2023 12:00	25.18	14.6	446.6	11.4	175.8	10.7
21/12/2023 13:00	25.86	14.6	445.1	11.7	175.7	11
21/12/2023 14:00	26.11	14.6	444.3	11.8	175.3	11.1
21/12/2023 15:00	26.56	14.6	428.7	12	175.3	11.3
21/12/2023 16:00	27.56	14.6	367.4	12.5	175.5	11.7
21/12/2023 17:00	28.02	14.6	377.2	12.7	175.5	11.9
21/12/2023 18:00	28.25	14.6	387.9	12.8	176.1	12
21/12/2023 19:00	28.23	14.6	397.9	12.8	176.6	12
21/12/2023 20:00	28.88	14.6	401.2	13.1	176.9	12.3
21/12/2023 21:00	27.93	14.6	405.9	12.6	178.2	11.9
21/12/2023 22:00	27.47	14.6	408.1	12.4	178	11.7
21/12/2023 23:00	27.88	14.6	412.2	12.6	177.6	11.8
22/12/2023 00:00	29.08	14.6	428.4	13.1	177.4	12.3
22/12/2023 01:00	29.41	14.6	450.1	13.3	177.1	12.5
22/12/2023 02:00	29.41	14.6	449.1	13.3	176.9	12.5
22/12/2023 03:00	28.54	14.6	447.4	13	176.4	12.1
22/12/2023 04:00	26.65	14.6	445.3	12.2	175.8	11.3
22/12/2023 05:00	25.69	14.6	444.1	11.7	175.7	10.9
22/12/2023 06:00	24.76	14.5	443.8	11.3	175.8	10.5
22/12/2023 07:00	23.22	14.5	443.5	10.6	175.7	9.9
22/12/2023 08:00	21.23	14.6	444.1	9.7	175.6	9
22/12/2023 09:00	22.02	14.6	447.2	10	176	9.3
22/12/2023 10:00	23.71	14.6	452.3	10.7	177	10.1
22/12/2023 11:00	25.03	14.7	454.7	11.2	177.6	10.6
22/12/2023 12:00	29.11	14.7	455.6	13.1	177.3	12.4
22/12/2023 13:00	27.18	14.6	454.8	12.3	176.3	11.5
22/12/2023 14:00	28.27	14.6	453.2	12.8	176.1	12
22/12/2023 15:00	29.22	14.6	452.4	13.2	175.9	12.4
22/12/2023 16:00	29.43	14.6	453.4	13.3	176.1	12.5
22/12/2023 17:00	29.08	14.6	455.1	13.1	176.4	12.3
22/12/2023 18:00	27.28	14.7	456	12.2	178.1	11.6
22/12/2023 19:00	27.11	14.7	455.9	12.1	178.2	11.5
22/12/2023 20:00	25.84	14.6	452.2	11.6	177.7	11
22/12/2023 21:00	25.32	14.6	463.6	11.4	177.2	10.7
22/12/2023 22:00	26.28	14.6	448.1	11.9	177.4	11.2
22/12/2023 23:00	26.68	14.6	446.7	12.1	177	11.3
23/12/2023 00:00	26.03	14.6	444.5	11.9	176.5	11.1
23/12/2023 01:00	28.04	14.6	444.3	12.8	175.6	11.9
23/12/2023 02:00	28.43	14.5	443.3	13	175	12.1

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
23/12/2023 03:00	29.1	14.5	442.4	13.3	174.9	12.4
23/12/2023 04:00	28.96	14.5	441.4	13.3	174.9	12.3
23/12/2023 05:00	28.72	14.5	440.4	13.2	174.9	12.2
23/12/2023 06:00	28.23	14.5	439.9	13	174.7	12
23/12/2023 07:00	27.84	14.5	439.3	12.8	174.7	11.8
23/12/2023 08:00	26	14.5	440.4	11.9	174.8	11
23/12/2023 09:00	26.04	14.6	443.4	11.9	175.3	11.1
23/12/2023 10:00	25.89	14.6	448.4	11.7	176.4	11
23/12/2023 11:00	27.04	14.7	458.5	12.1	177.3	11.5
23/12/2023 12:00	28.8	14.7	469.2	12.9	177.5	12.2
23/12/2023 13:00	29.89	14.7	455.7	13.4	177.1	12.7
23/12/2023 14:00	30.13	14.6	453.8	13.6	176.1	12.8
23/12/2023 15:00	28.8	14.6	453.5	13	176.1	12.2
23/12/2023 16:00	28.72	14.6	453.4	13	176.1	12.2
23/12/2023 17:00	29.04	14.6	455.1	13.1	176.4	12.3
23/12/2023 18:00	28.33	14.7	456	12.7	177.5	12
23/12/2023 19:00	26.36	14.7	453.3	11.8	178	11.2
23/12/2023 20:00	25.08	14.6	450.8	11.3	177.2	10.6
23/12/2023 21:00	25.54	14.6	450.3	11.5	176.8	10.8
23/12/2023 22:00	25.97	14.6	450	11.7	176.8	11
23/12/2023 23:00	25.82	14.6	448.7	11.7	176.5	11
24/12/2023 00:00	25.68	14.6	447.4	11.6	176.1	10.9
24/12/2023 01:00	26.6	14.6	447.2	12	176	11.3
24/12/2023 02:00	27.84	14.6	446.8	12.6	175.9	11.8
24/12/2023 03:00	28.17	14.6	445.8	12.8	175.9	12
24/12/2023 04:00	28.07	14.6	445.4	12.8	175.6	11.9
24/12/2023 05:00	27.55	14.6	445.1	12.5	175.5	11.7
24/12/2023 06:00	26.61	14.6	443.9	12.1	175.4	11.3
24/12/2023 07:00	25.37	14.6	443.6	11.6	175.3	10.8
24/12/2023 08:00	24.18	14.6	443.5	11	175.4	10.3
24/12/2023 09:00	23.51	14.6	444.6	10.7	175.5	10
24/12/2023 10:00	24.02	14.6	447	10.9	175.8	10.2
24/12/2023 11:00	24.9	14.6	449.2	11.2	176.2	10.6
24/12/2023 12:00	25.75	14.6	449.8	11.6	176.4	10.9
24/12/2023 13:00	26.41	14.7	453.3	11.9	176.8	11.2
24/12/2023 14:00	27.25	14.6	452.3	12.3	176.8	11.6
24/12/2023 15:00	27.93	14.6	452.5	12.6	176.8	11.9
24/12/2023 16:00	27.62	14.6	451.8	12.4	176.7	11.7
24/12/2023 17:00	26.53	14.6	450	12	176.5	11.3
24/12/2023 18:00	25.33	14.6	449.2	11.5	176.3	10.8
24/12/2023 19:00	24.27	14.6	449.8	11	176.4	10.3
24/12/2023 20:00	24.34	14.6	448.4	11	176.3	10.3
24/12/2023 21:00	26.84	14.6	448.2	12.1	176.1	11.4
24/12/2023 22:00	27.5	14.6	448.3	12.4	176.2	11.7
24/12/2023 23:00	27.72	14.6	447.7	12.6	176.4	11.8
25/12/2023 00:00	27.68	14.6	448.3	12.5	176.6	11.7
25/12/2023 01:00	27.54	14.6	447.4	12.5	176.5	11.7
25/12/2023 02:00	27.98	14.6	447.1	12.7	176.3	11.9
25/12/2023 03:00	28.34	14.6	447	12.9	176.3	12
25/12/2023 04:00	28	14.6	446.7	12.7	176.2	11.9
25/12/2023 05:00	27.94	14.6	445	12.7	176	11.9
25/12/2023 06:00	27.57	14.6	444.3	12.6	175.9	11.7
25/12/2023 07:00	26.5	14.6	444.3	12.1	175.9	11.2
25/12/2023 08:00	24.95	14.6	444.2	11.4	176.1	10.6
25/12/2023 09:00	25.13	14.6	446.6	11.4	176.5	10.7
25/12/2023 10:00	24.88	14.6	449.3	11.2	176.8	10.6
25/12/2023 11:00	26.74	14.7	454.2	12	177.5	11.3
25/12/2023 12:00	28.61	14.7	456.3	12.8	177.9	12.1
25/12/2023 13:00	29.45	14.7	455.8	13.2	177.6	12.5

Site Report - GPSC CUP2 HRSQ2						
Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
25/12/2023 14:00	30.23	14.6	454.6	13.6	176.7	12.8
25/12/2023 15:00	29.68	14.6	453.9	13.4	176.3	12.6
25/12/2023 16:00	28.56	14.6	453.6	12.9	176.3	12.1
25/12/2023 17:00	28.7	14.6	454.8	12.9	176.6	12.2
25/12/2023 18:00	28.17	14.7	455.9	12.6	178	12
25/12/2023 19:00	27.18	14.7	454.7	12.2	177.9	11.5
25/12/2023 20:00	26.61	14.7	451.3	12	177.3	11.3
25/12/2023 21:00	27.41	14.6	451.3	12.3	177.2	11.6
25/12/2023 22:00	27.52	14.6	450.4	12.4	177.1	11.7
25/12/2023 23:00	27.73	14.6	449.2	12.5	177.1	11.8
26/12/2023 00:00	27.67	14.6	448.3	12.5	176.8	11.7
26/12/2023 01:00	28.25	14.6	447.5	12.8	176.8	12
26/12/2023 02:00	29.03	14.6	447.2	13.2	176.6	12.3
26/12/2023 03:00	28.49	14.6	445.5	13	176.4	12.1
26/12/2023 04:00	28.39	14.6	459.8	12.9	176.2	12
26/12/2023 05:00	28.02	14.6	456.8	12.8	176.2	11.9
26/12/2023 06:00	27.89	14.6	464.4	12.7	176	11.8
26/12/2023 07:00	27.31	14.6	457.5	12.5	175.7	11.6
26/12/2023 08:00	26.47	14.6	470.8	12	176	11.2
26/12/2023 09:00	26.42	14.6	467	12	176.5	11.2
26/12/2023 10:00	27.37	14.7	455.1	12.3	177.4	11.6
26/12/2023 11:00	27.84	14.7	455.9	12.5	177.8	11.8
26/12/2023 12:00	29.58	14.6	454.3	13.3	176.7	12.6
26/12/2023 13:00	29.89	14.6	451.9	13.5	176.3	12.7
26/12/2023 14:00	29.19	14.6	451.1	13.2	176.1	12.4
26/12/2023 15:00	27.76	14.6	450.7	12.5	176.2	11.8
26/12/2023 16:00	28.56	14.6	451.6	12.9	176.3	12.1
26/12/2023 17:00	28.9	14.6	452.8	13.1	176.5	12.3
26/12/2023 18:00	29.27	14.6	454.6	13.2	176.9	12.4
26/12/2023 19:00	27.65	14.7	456.2	12.4	177.7	11.7
26/12/2023 20:00	26.19	14.7	455.7	11.7	178.2	11.1
26/12/2023 21:00	25.41	14.7	453.8	11.4	177.9	10.8
26/12/2023 22:00	24.79	14.6	452.4	11.2	177.6	10.5
26/12/2023 23:00	25.89	14.6	453.3	11.7	177.5	11
27/12/2023 00:00	26.49	14.6	452.4	11.9	177.4	11.2
27/12/2023 01:00	26.99	14.6	451.8	12.2	177.4	11.5
27/12/2023 02:00	27.6	14.6	451.5	12.5	177.3	11.7
27/12/2023 03:00	28.19	14.6	450.5	12.7	177.1	12
27/12/2023 04:00	27.19	14.6	448.4	12.3	176.6	11.5
27/12/2023 05:00	25.84	14.6	447	11.8	176.4	11
27/12/2023 06:00	25.37	14.6	447.1	11.5	176.3	10.8
27/12/2023 07:00	24.25	14.6	447.6	11	176.3	10.3
27/12/2023 08:00	22.78	14.6	453.3	10.3	177.6	9.7
27/12/2023 09:00	22.84	14.7	454.8	10.3	177.9	9.7
27/12/2023 10:00	24	14.6	454.3	10.8	176.7	10.2
27/12/2023 11:00	26.97	14.6	452	12.2	176.2	11.4
27/12/2023 12:00	29.03	14.6	449	13.1	175.7	12.3
27/12/2023 13:00	30.48	14.6	446	13.8	175.6	12.9
27/12/2023 14:00	30.05	14.6	448.3	13.6	174.8	12.8
27/12/2023 15:00	30.17	14.6	443.7	13.6	175.1	12.8
27/12/2023 16:00	29.13	14.6	444.2	13.2	175.2	12.4
27/12/2023 17:00	30.16	14.6	447.6	13.7	175.6	12.8
27/12/2023 18:00	28.78	14.6	451.4	13.1	176.7	12.2
27/12/2023 19:00	27.21	14.6	454.6	12.3	177.7	11.5
27/12/2023 20:00	24.31	14.6	454.4	11	178.4	10.3
27/12/2023 21:00	23.41	14.6	453.4	10.6	178	9.9
27/12/2023 22:00	23.84	14.6	451.9	10.8	178	10.1
27/12/2023 23:00	24.66	14.6	452.3	11.2	177.5	10.5
28/12/2023 00:00	25.56	14.6	451.1	11.6	177.5	10.8

Site Report - GPSC CUP2 HRSG2

Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
30/12/2023 12:00	29.35	14.6	441.2	13.3	174.9	12.5
30/12/2023 13:00	28.23	14.6	439.5	12.8	174.8	12
30/12/2023 14:00	26.88	14.6	437.8	12.2	174	11.4
30/12/2023 15:00	27.01	14.6	439	12.3	174.2	11.5
30/12/2023 16:00	25.93	14.6	439.9	11.8	174.4	11
30/12/2023 17:00	27.25	14.6	443.2	12.4	175	11.6
30/12/2023 18:00	27.87	14.6	446.9	12.7	175.7	11.8
30/12/2023 19:00	28.15	14.5	449.5	12.9	176.1	12
30/12/2023 20:00	28.08	14.5	451.6	12.8	176.7	11.9
30/12/2023 21:00	27.82	14.5	452.9	12.7	176.9	11.8
30/12/2023 22:00	27.89	14.6	454.8	12.7	177.7	11.8
30/12/2023 23:00	29.12	14.6	454.6	13.3	177.4	12.4
31/12/2023 00:00	29.86	14.6	454.4	13.6	177.3	12.7
31/12/2023 01:00	26.33	14.6	454.9	12	177.5	11.2
31/12/2023 02:00	26.12	14.6	454.6	11.9	177.6	11.1
31/12/2023 03:00	27.17	14.6	454.8	12.3	177.5	11.5
31/12/2023 04:00	26.72	14.6	454.1	12.1	177.5	11.3
31/12/2023 05:00	27.51	14.6	454.5	12.5	177.7	11.7
31/12/2023 06:00	28.17	14.6	454.9	12.7	177.6	12
31/12/2023 07:00	28.42	14.6	454.5	12.9	177.5	12.1
31/12/2023 08:00	26.96	14.6	452.1	12.3	176.5	11.4
31/12/2023 09:00	26.65	14.6	448	12.1	175.9	11.3
31/12/2023 10:00	25.69	14.6	445	11.6	175.5	10.9
31/12/2023 11:00	25.66	14.6	442.2	11.6	175.1	10.9
31/12/2023 12:00	25.87	14.6	441.8	11.7	175.3	11
31/12/2023 13:00	26.26	14.6	440	11.9	174.9	11.1
31/12/2023 14:00	24.17	14.6	438.4	11	174.4	10.3
31/12/2023 15:00	24.79	14.6	439.1	11.3	174.2	10.5
31/12/2023 16:00	25.98	14.6	440.1	11.8	174.4	11
31/12/2023 17:00	26.98	14.6	441.4	12.3	174.5	11.5
31/12/2023 18:00	28.74	14.6	444.2	13.1	175.2	12.2
31/12/2023 19:00	28.43	14.6	448.8	13	176.2	12.1
31/12/2023 20:00	27.9	14.5	452.6	12.8	176.7	11.8
31/12/2023 21:00	28.38	14.5	453.5	13	177.1	12
31/12/2023 22:00	28.88	14.6	454.4	13.2	177.4	12.3
31/12/2023 23:00	29.2	14.6	454.4	13.3	178	12.4
Minimum	10.84	13	349.1	4.1	139.9	4.6
MinDate	17/12/2023 10:00	11/12/2023 23:00	17/12/2023 15:00	17/12/2023 10:00	12/12/2023 00:00	17/12/2023 10:00
Maximum	30.48	15.6	496.4	16	187	12.9
MaxDate	27/12/2023 13:00	17/12/2023 05:00	09/12/2023 21:00	14/12/2023 03:00	17/12/2023 06:00	27/12/2023 13:00
Avg	25.89	14.4	441.5	12	172.7	11
Num	736	736	737	736	744	736
Data[%]	98.9	98.9	99.1	98.9	100	98.9
STD	3.2	0.4	25.7	1.4	10.2	1.4

Site Report - GPSC CUP2 AB21							
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2	
	ppm	%Vol	km3/h	ppm	Deg C	ppm	
01/07/2023 00:00	27.86	4.7	0	32.4	127.9	11.8	
01/07/2023 01:00	27.62	4.7	0.3	32.2	127.7	11.7	
01/07/2023 02:00	26.85	4.7	0	31.4	124.3	11.4	
01/07/2023 03:00	27.48	4.7	0	32.1	127.7	11.7	
01/07/2023 04:00	27.47	4.7	0.7	32	129.4	11.7	
01/07/2023 05:00	27.98	4.8	1.2	32.4	130.2	11.9	
01/07/2023 06:00	27.69	4.8	0	32.1	130.5	11.8	
01/07/2023 07:00	28	4.8	0	32.4	128.5	11.9	
01/07/2023 08:00	28.12	4.8	0	32.5	129	11.9	
01/07/2023 09:00	28.36	4.8	0	32.8	129.3	12	
01/07/2023 10:00	28.41	4.8	0	33	129.4	12.1	
01/07/2023 11:00	28.05	4.7	1.6	32.7	129.9	11.9	
01/07/2023 12:00	28.19	4.8	11.2	32.7	129.9	12	
01/07/2023 13:00	28.52	4.8	0.2	32.9	129.1	12.1	
01/07/2023 14:00	28.51	4.8	0.2	33	129	12.1	
01/07/2023 15:00	28.41	4.7	1.4	33	128.9	12.1	
01/07/2023 16:00	28.35	4.7	0.2	33	128.5	12	
01/07/2023 17:00	28.48	4.7	0.2	33.2	128.3	12.1	
01/07/2023 18:00	28.41	4.7	0.2	33.1	128	12.1	
01/07/2023 19:00	28.17	4.7	0.2	32.8	127.9	12	
01/07/2023 20:00	27.88	4.7	8.3	32.2	127.8	11.8	
01/07/2023 21:00	27.77	4.7	0	32.3	128	11.8	
01/07/2023 22:00	28.11	4.7	1	32.7	129.2	11.9	
01/07/2023 23:00	28.18	4.8	0.2	32.7	128.8	12	
02/07/2023 00:00	28.2	4.8	0.2	32.7	128.5	12	
02/07/2023 01:00	28.31	4.9	0.2	32.7	128.7	12	
02/07/2023 02:00	28.81	4.9	0.2	33.2	128.6	12.2	
02/07/2023 03:00	29.16	4.9	0	33.6	128.1	12.4	
02/07/2023 04:00	29.1	4.9	16.8	33.5	128	12.4	
02/07/2023 05:00	28.88	4.9	20.2	33.3	128	12.3	
02/07/2023 06:00	28.89	4.9	0.7	33.2	128.4	12.3	
02/07/2023 07:00	29.1	4.9	7	33.5	128.7	12.4	
02/07/2023 08:00	29.34	4.9	16.3	33.8	128.5	12.5	
02/07/2023 09:00	29.58	4.8	2	34.2	128.5	12.6	
02/07/2023 10:00	29.54	4.9	0	34.1	128.4	12.5	
02/07/2023 11:00	29.5	4.9	6	33.9	128.6	12.5	
02/07/2023 12:00	29.87	4.9	0.4	34.3	128.8	12.7	
02/07/2023 13:00	29.67	5	0.6	34	128.9	12.6	
02/07/2023 14:00	29.71	5.1	0	33.9	128.9	12.6	
02/07/2023 15:00	29.5	5.1	0	33.6	129.3	12.5	
02/07/2023 16:00	29.25	5.1	0	33.3	128.8	12.4	
02/07/2023 17:00	29.33	5.1	10.5	33.4	128.6	12.4	
02/07/2023 18:00	29.3	5	0	33.3	128.3	12.4	
02/07/2023 19:00	28.45	4.9	0.2	32.7	127.9	12.1	
02/07/2023 20:00	28.75	4.9	0.2	33.1	128.4	12.2	
02/07/2023 21:00	29.27	5	0.2	33.6	128.2	12.4	
02/07/2023 22:00	28.84	4.9	0.2	33.2	129	12.2	
02/07/2023 23:00	29.09	4.9	0.2	33.4	129.2	12.3	
03/07/2023 00:00	29.61	4.9	0.2	34	128.2	12.6	
03/07/2023 01:00	29.7	5	0	34.5	128.3	12.6	
03/07/2023 02:00	29.86	5	0.2	34.1	128.5	12.7	
03/07/2023 03:00	29.6	5	0.2	33.8	128.3	12.6	
03/07/2023 04:00	29.45	5	0.2	33.6	128.4	12.5	
03/07/2023 05:00	29.61	5	0.2	33.8	128.2	12.6	
03/07/2023 06:00	29.65	5	0.2	33.9	128.2	12.6	
03/07/2023 07:00	29.79	5	0.2	34.1	128.3	12.6	
03/07/2023 08:00	29.65	4.9	2.2	34.1	128.7	12.6	
03/07/2023 09:00	30	4.9	0	34.5	128.1	12.7	
03/07/2023 10:00	30	4.9	0	34.4	127.7	12.7	
03/07/2023 11:00	29.9	4.9	2.4	34.4	128.5	12.7	
03/07/2023 12:00	30.23	4.9	0	34.7	129.3	12.8	
03/07/2023 13:00	30.76	4.9	6.4	35.4	129.1	13.1	
03/07/2023 14:00	30.88	4.9	3.4	35.6	128.3	13.1	
03/07/2023 15:00	31.25	4.8	0	36.1	128.1	13.3	
03/07/2023 16:00	30.63	4.8	0	35.4	128.8	13	
03/07/2023 17:00	31.2	4.9	0	35.9	129.2	13.2	
03/07/2023 18:00	30.97	4.9	4.3	35.6	128.5	13.1	
03/07/2023 19:00	30.18	4.9	0.2	34.7	129.1	12.8	
03/07/2023 20:00	30.43	4.9	0.2	35.1	130	12.9	

Site Report - GPSC CUP2 AB21							
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2	
	ppm	%Vol	km3/h	ppm	Deg C	ppm	
03/07/2023 21:00	30.35	4.9	0	34.8	130.7	12.9	
03/07/2023 22:00	29.8	5	0.2	34.2	130.8	12.6	
03/07/2023 23:00	29.54	5	0.2	33.8	131.1	12.5	
04/07/2023 00:00	29.3	5	0.2	33.8	130.9	12.4	
04/07/2023 01:00	29.36	5	0.2	33.5	131.4	12.5	
04/07/2023 02:00	29.3	5	0.2	33.6	130	12.4	
04/07/2023 03:00	29.11	5	0.2	33.4	130	12.4	
04/07/2023 04:00	29.2	4.9	0.2	33.6	130	12.4	
04/07/2023 05:00	28.76	4.9	0.2	33.1	130	12.2	
04/07/2023 06:00	28.93	4.9	0.2	33.3	130.3	12.3	
04/07/2023 07:00	28.93	4.9	0.2	33.3	130.7	12.3	
04/07/2023 08:00	30.09	4.9	1.9	34.7	129.2	12.8	
04/07/2023 09:00	30.55	4.8	0	34.1	129	13	
04/07/2023 10:00	30.61	4.8	0	35.4	128.8	13	
04/07/2023 11:00	30.97	4.9	0.5	35.7	129	13.1	
04/07/2023 12:00	31.09	4.9	2.9	35.8	129	13.2	
04/07/2023 13:00	31.73	4.9	0	36.6	128.8	13.5	
04/07/2023 14:00	31.88	4.9	0.3	36.6	128.9	13.5	
04/07/2023 15:00	32.08	4.9	0	36.9	129.3	13.6	
04/07/2023 16:00	31.44	4.9	8.2	36.2	129.3	13.3	
04/07/2023 17:00	31.03	4.9	2.2	35.7	129.5	13.2	
04/07/2023 18:00	31.02	4.9	0.7	35.7	129.5	13.2	
04/07/2023 19:00	30.56	4.9	0.2	35.2	129.5	13	
04/07/2023 20:00	29.9	4.9	0.2	34.5	129.5	12.7	
04/07/2023 21:00	29.55	4.9	0.2	34	129.8	12.5	
04/07/2023 22:00	29.32	4.8	0.2	33.9	130.7	12.4	
04/07/2023 23:00	29.34	4.9	0.2	33.5	130.8	12.3	
05/07/2023 00:00	28.98	4.9	0.2	33.3	130.7	12.3	
05/07/2023 01:00	28.97	4.9	0.2	33.2	130.3	12.3	
05/07/2023 02:00	28.88	4.9	0.2	33.2	130	12.3	
05/07/2023 03:00	28.88	4.9	0.2	33.2	130.8	12.3	
05/07/2023 04:00	28.46	4.9	0.2	32.8	130.9	12.1	
05/07/2023 05:00	28.65	4.9	0.2	32.9	131.1	12.2	
05/07/2023 06:00	28.78	4.9	0.2	33	131	12.2	
05/07/2023 07:00	28.76	4.9	0.8	33.1	131	12.2	
05/07/2023 08:00	29.66	4.8	1.9	34.3	130	12.6	
05/07/2023 09:00	30.62	4.9	0.7	35.3	130	13	
05/07/2023 10:00	31.06	4.9	0	35.8	130	13.2	
05/07/2023 11:00	30.78	4.9	0.6	35.5	129.4	13.1	
05/07/2023 12:00	31.06	4.9	1.8	35.8	128.8	13.2	
05/07/2023 13:00	31.58	4.9	0.2	36.4	128.5	13.5	
05/07/2023 14:00	31.75	4.9	0.2	36.6	128.8	13.5	
05/07/2023 15:00	31.75	4.9	0.2	36.7	129.1	13.4	
05/07/2023 16:00	31.38	4.8	0.2	36.3	128.8	13.3	
05/07/2023 17:00	30.88	4.8	0.2	35.8	128.2	13.1	
05/07/2023 18:00	30.68	4.8	0.2	35.5	128.4	13	
05/07/2023 19:00	29.97	4.9	0.2	34.4	127.9	12.7	
05/07/2023 20:00	29.89	5	0.2	34.3	128.6	12.7	
05/07/2023 21:00	30	5	0.2	34.4	130.4	12.7	
05/07/2023 22:00	29.85	5	0.2	34.7	129.3	12.8	
05/07/2023 23:00	29.62	5	0.2	33.9	131.1	12.6	
06/07/2023 00:00	29.52	4.9	0.2	33.9	131	12.5	
06/07/2023 01:00	29.64	5	0.2	33.9	130.4	12.6	
06/07/2023 02:00	29.57	5	0.2	33.8	130.6	12.6	
06/07/2023 03:00	29.67	5	0.2	33.9	130.5	12.6	
06/07/2023 04:00	29.83	5	0.2	34.1	130.3	12.7	
06/07/2023 05:00	30.15	5	0.2	34.6	130.6	12.8	
06/07/2023 06:00	30.22	4.9	0.2	34.5	130.7	12.8	
06/07/2023 07:00	30.02	4.9	0.2	34.4	130.6	12.7	
06/07/2023 08:00	30.81	4.9	0.5	35.5	130.9	13.1	
06/07/2023 09:00	31.73	4.8	4.6	36.7	130.5	13.5	
06/07/2023 10:00	32.74	4.9	2.7	37.8	130.4	13.9	
06/07/2023 11:00	32.16	4.9	0	37.1	130.4	13.7	
06/07/2023 12:00	31.27	4.8	0	36.1	129.9	13.3	
06/07/2023 13:00	31.07	4.7	0.2	35.7	129.3	13.1	
06/07/2023 14:00	31.32	4.7	0.2	36.5	129.2	13.3	
06/07/2023 15:00	31.12	4.7	0.2	36.2	129.3	13.2	
06/07/2023 16:00	30.08	4.7	0.2	35.1	129.1	12.8	
06/07/2023 17:00	<Samp	<Samp	<Samp	<Samp	101.2	<Samp	

Site Report - GPSC CUP2 AB21							
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2	
	ppm	%Vol	km3/h	ppm	Deg C	ppm	
06/07/2023 18:00	<Samp	<Samp	<Samp	<Samp	135.3	<Samp	
06/07/2023 19:00	27.58	3.8	0	33.9	126.7	11.7	
06/07/2023 20:00	27.53	3.8	0.2	33.8	126	11.7	
06/07/2023 21:00	27.43	3.9	0.2	33.6	126.3	11.6	
06/07/2023 22:00	26.95	3.9	0.2	33	126	11.4	

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
12/07/2023 12:00	24.3	4.2	0.2	29.2	126.5	10.3
12/07/2023 13:00	24.31	4.3	0.2	29.1	129.1	10.3
12/07/2023 14:00	24.47	4.2	0.2	29.4	129.2	10.4
12/07/2023 15:00	24.72	4.1	0.2	29.8	129.3	10.5
12/07/2023 16:00	24.88	4.2	0.2	30.1	129.9	10.6
12/07/2023 17:00	24.99	4.2	0.2	29.5	129.9	10.4
12/07/2023 18:00	24.1	4.2	0.2	28.9	129.4	10.2
12/07/2023 19:00	24.16	4.3	0.2	28.9	129.4	10.3
12/07/2023 20:00	24.15	4.3	0.2	28.9	129.4	10.2
12/07/2023 21:00	24.05	4.3	0.2	28.7	129.7	10.2
12/07/2023 22:00	23.95	4.3	0.2	28.6	129.5	10.2
12/07/2023 23:00	23.94	4.4	0.2	28.3	129.5	10.1
13/07/2023 00:00	23.76	4.5	0.2	28.1	130.3	10.1
13/07/2023 01:00	23.48	4.5	0.2	27.7	130.1	10
13/07/2023 02:00	23.27	4.5	0.2	27.4	130.1	9.9
13/07/2023 03:00	23.12	4.6	0.2	27.2	130.7	9.8
13/07/2023 04:00	23.13	4.6	0.2	27.1	131.1	9.8
13/07/2023 05:00	23.2	4.6	0.2	27.2	131.3	9.8
13/07/2023 06:00	23.5	4.6	0.2	27.5	131.4	10
13/07/2023 07:00	24.09	4.6	0.2	28.3	131.1	10.2
13/07/2023 08:00	24.57	4.6	0.2	28.9	130.4	10.4
13/07/2023 09:00	25.31	4.5	1.5	29.9	130.6	10.7
13/07/2023 10:00	25.28	4.5	3.4	29.8	130.1	10.7
13/07/2023 11:00	25.3	4.5	11.9	29.9	130.1	10.7
13/07/2023 12:00	25.87	4.5	4	30.5	129.9	11
13/07/2023 13:00	26.08	4.5	3.6	30.8	129.7	11.1
13/07/2023 14:00	25.17	4.5	0.2	29.8	129.5	10.7
13/07/2023 15:00	25.14	4.5	0.2	30.4	130	10.9
13/07/2023 16:00	24.84	4.4	0.2	29.5	129.7	10.5
13/07/2023 17:00	24.41	4.4	0.2	29	129.7	10.4
13/07/2023 18:00	24.15	4.4	0.2	28.7	129.8	10.3
13/07/2023 19:00	24.24	4.2	0.2	29.1	129.6	10.3
13/07/2023 20:00	24.31	4.2	0.2	29.2	129.7	10.3
13/07/2023 21:00	23.91	4.2	0.2	28.7	129.3	10.1
13/07/2023 22:00	23.63	4.3	0.2	28.3	129.3	10
13/07/2023 23:00	23.48	4.3	0.2	28.1	130	10
14/07/2023 00:00	23.34	4.3	0.2	27.8	130.3	9.9
14/07/2023 01:00	23.42	4.3	0.2	28	130.2	9.9
14/07/2023 02:00	23.78	4.3	0.2	28.3	129.8	10.1
14/07/2023 03:00	23.99	4.4	0.2	28.5	129.7	10.2
14/07/2023 04:00	24.1	4.4	0.2	28.6	130.2	10.2
14/07/2023 05:00	24.12	4.5	0.2	28.5	130.7	10.2
14/07/2023 06:00	24.03	4.5	0.2	28.3	130.4	10.2
14/07/2023 07:00	24.18	4.4	0.2	28.6	130.2	10.3
14/07/2023 08:00	24.68	4.4	0.2	29.4	129.5	10.5
14/07/2023 09:00	25.32	4.3	0.2	30.2	129.3	10.7
14/07/2023 10:00	25.81	4.3	0.2	30.7	129.4	11
14/07/2023 11:00	26.29	4.4	5.3	31.3	129.8	11.2
14/07/2023 12:00	26.3	4.4	11	31.3	129.6	11.2
14/07/2023 13:00	26.08	4.4	0.2	30.8	129.9	11.1
14/07/2023 14:00	25.81	4.3	0.2	30.8	129.9	11.1
14/07/2023 15:00	25.25	4.3	0.2	30.2	129.3	10.7
14/07/2023 16:00	24.83	4.3	0.2	29.7	129.5	10.5
14/07/2023 17:00	24.39	4.3	0.2	29.1	129.4	10.4
14/07/2023 18:00	24.1	4.3	0.2	28.8	129.2	10.2
14/07/2023 19:00	24.14	4.3	0.2	28.8	129.7	10.2
14/07/2023 20:00	24.36	4.3	0.2	29.1	129.2	10.3
14/07/2023 21:00	24.18	4.3	0.2	28.8	129.4	10.3
14/07/2023 22:00	24.2	4.4	0.2	28.8	129.4	10.3
14/07/2023 23:00	25.37	4.5	0.2	30	129.3	10.8
15/07/2023 00:00	25.65	4.5	0.2	30.2	129.6	10.9
15/07/2023 01:00	25.35	4.5	0.2	29.8	130	10.8
15/07/2023 02:00	25.13	4.5	0.2	29.6	130.1	10.7
15/07/2023 03:00	25.04	4.6	0.2	29.4	130.2	10.6
15/07/2023 04:00	25.06	4.6	0.2	29.4	130.6	10.6
15/07/2023 05:00	24.71	4.3	0.2	29.4	130.6	10.5
15/07/2023 06:00	24.43	4.3	0.2	29.2	129.6	10.4
15/07/2023 07:00	24.04	4.2	0.2	28.9	129.5	10.2
15/07/2023 08:00	24.09	4.2	0.2	29	129.4	10.2

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
15/07/2023 09:00	24.69	4.1	0.2	29.8	128.9	10.5
15/07/2023 10:00	25.19	4.1	0.2	30.5	128.7	10.7
15/07/2023 11:00	26.15	4.1	0.2	31.7	128.4	11.1
15/07/2023 12:00	25.97	4.1	1.6	31.5	128.5	11
15/07/2023 13:00	25.91	4.1	0.2	31.3	128.9	11
15/07/2023 14:00	25.97	4.1	2.6	31.2	128.9	11
15/07/2023 15:00	25.77	4	0.2	31.3	128.2	10.9
15/07/2023 16:00	24.63	4	0.2	30	127.6	10.5
15/07/2023 17:00	24.38	3.9	0.2	29.8	127.1	10.3
15/07/2023 18:00	24.41	3.9	0.2	29.8	127.2	10.4
15/07/2023 19:00	23.98	3.9	0.2	29.3	128	10.2
15/07/2023 20:00	23.58	3.9	0.2	28.8	128.3	10
15/07/2023 21:00	23.32	3.9	0.2	28.5	128.4	9.9
15/07/2023 22:00	23.07	3.9	0.2	28.2	129	9.8
15/07/2023 23:00	23.15	3.9	0.2	28.3	128.5	9.8
16/07/2023 00:00	24.15	4	0.2	29.4	128.2	10.3
16/07/2023 01:00	24.57	4.2	0.2	29.5	128.8	10.4
16/07/2023 02:00	24.5	4.3	0.2	29.3	129.2	10.4
16/07/2023 03:00	24.21	4.3	0.2	28.9	129.5	10.3
16/07/2023 04:00	24.12	4.2	0.2	28.9	129.5	10.2
16/07/2023 05:00	24.05	4	0.2	29.2	129	10.2
16/07/2023 06:00	25.38	3.7	0.2	31.5	129.4	10.8
16/07/2023 07:00	26.46	3.5	0.2	33.2	129.2	11.2
16/07/2023 08:00	26.41	3.5	0.2	33.1	129.3	11.2
16/07/2023 09:00	26.92	3.4	0.2	33.8	128.7	11.4
16/07/2023 10:00	27.16	3.4	0.2	34.1	128.1	11.5
16/07/2023 11:00	27.05	3.5	0.2	33.8	128.5	11.3
16/07/2023 12:00	27.16	3.5	0.2	33.9	128.1	11.5
16/07/2023 13:00	26.96	3.4	0.2	33.9	127.8	11.4
16/07/2023 14:00	27.22	3.5	0.2	34	127.9	11.6
16/07/2023 15:00	27	3.5	0.2	33.8	128	11.5
16/07/2023 16:00	27.03	3.5	0.2	33.9	127.9	11.5
16/07/2023 17:00	26.68	3.4	0.2	33.6	127.5	11.3
16/07/2023 18:00	26.37	3.4	0.2	33.2	127.6	11.2
16/07/2023 19:00	26.34	3.4	0.2	33.1	128.1	11.2
16/07/2023 20:00	26.6	3.4	0.2	33.5	128	11.3
16/07/2023 21:00	26.94	3.4	0.2	33.9	127.5	11.4
16/07/2023 22:00	26.82	3.4	0.2	33.8	127.5	11.4
16/07/2023 23:00	26.82	3.4	0.2	33.8	127.4	11.4
17/07/2023 00:00	26.86	3.4	0.2	33.8	127.5	11.4
17/07/2023 01:00	26.72	3.4	0.2	33.6	127.9	11.3
17/07/2023 02:00	26.5	3.4	0.2	33.3	128.2	11.2
17/07/2023 03:00	26.51	3.4	0.2	33.3	128.1	11.2
17/07/2023 04:00	26.6	3.5	0.2	33.4	127.9	11.3
17/07/2023 05:00	26.5	3.5	0.2	33.1	128.1	11.2
17/07/2023 06:00	26.55	3.6	0.2	33.1	128	11.3
17/07/2023 07:00	26.57	3.5	0.2	33.2	128.3	11.3
17/07/2023 08:00	26.57	3.5	0.2	33.3	127.7	11.3
17/07/2023 09:00	26.91	3.4	0.2	33.9	127.2	11.4
17/07/2023 10:00	26.92	3.3	0.2	33.9	127.4	11.4
17/07/2023 11:00	27.07	3.3	0.2	34.2	126.9	11.5
17/07/2023 12:00	27.36	3.3	0.2	34.7	127.1	11.6
17/07/2023 13:00	27.77	3.3	0.2	35.2	127.1	11.8
17/07/2023 14:00	27.62	3.2	0.2	35.1	126.8	11.7
17/07/2023 15:00	27.45	3.3	0.2	34.8	126.7	11.7
17/07/2023 16:00	27.42	3.2	0.2	34.9	127.4	11.6
17/07/2023 17:00	27.28	3.2	0.2	34.7	127.5	11.6
17/07/2023 18:00	26.87	3.2	0.2	34.2	127.7	11.4
17/07/2023 19:00	26.74	3.2	0.2	34	127.9	11.4
17/07/2023 20:00	27.06	3.3	0.2	34.3	127.9	11.5
17/07/2023 21:00	27.14	3.4	0.2	34.2	127.7	11.5
17/07/2023 22:00	26.98	3.4	0.2	33.9	128	11.5
17/07/2023 23:00	26.58	3.4	0.2	33.4	128.1	11.3
18/07/2023 00:00	26.34	3.4	0.2	33.1	128.2	11.2
18/07/2023 01:00	26.18	3.4	0.2	32.9	128.2	11.2
18/07/2023 02:00	26.41	3.5	0.2	33.2	128.2	11.2
18/07/2023 03:00	26.95	3.5	0.2	33.7	127.9	11.4
18/07/2023 04:00	26.59	3.5	0.2	33.3	127.9	11.3
18/07/2023 05:00	26.54	3.5	0.2	33.3	128.1	11.3

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
18/07/2023 06:00	26.28	3.5	0.2	32.8	128.9	11.2
18/07/2023 07:00	26.34	3.5	0.2	33	128.7	11.2
18/07/2023 08:00	24.91	4.1	0.2	30.2	127.5	10.6
18/07/2023 09:00	24.95	4.2	0.2	29.9	127.8	10.6
18/07/2023 10:00	25.39	4.3	0.2	30.4	128	10.8
18/07/2023 11:00	25.26	4.5	0.2	29.8	127.9	10.7
18/07/2023 12:00	24.62	4.5	0.2	29	127.4	10.5
18/07/2023 13:00	24.84	4.5	0.2	29.3	126.7	10.5
18/07/2023 14:00	25.24	4.7	0.2	29.5	126.6	10.7
18/07/2023 15:00	25.85	4.9	0.2	29.7	127.7	11
18/07/2023 16:00	25.93	4.9	0.2	29.8	127.8	11
18/07/2023 17:00	26.07	4.8	0.2	30.1	127.9	11.1
18/07/2023 18:00	25.78	4.8	0.2	29.9	127.8	10.9
18/07/2023 19:00	25.6	4.8	0.2	29.7	128	10.9
18/07/2023 20:00	24.87	4.8	0.2	28.8	128.6	10.6
18/07/2023 21:00	24.63	4.8	0.2	28.5	129.2	10.5
18/07/2023 22:00	24.42	4.6	0.2	28.7	129.2	10.4
18/07/2023 23:00	24.05	4.2	0.2	28.8	128.3	10.2
19/07/2023 00:00	23.9	4.2	0.2	28.7	127.8	10.1
19/07/2023 01:00	23.75	4.2	0.2	28.6	127.9	10.1
19/07/2023 02:00	23.79	3.9	0.2	29.2	127.2	10.1
19/07/2023 03:00	23.79	3.9	0.2	29.2	127.4	10.1
19/07/2023 04:00	23.76	3.9	0.2	29.1	127.5	10.1
19/07/2023 05:00	23.7	3.9	0.2	29	127.4	10.1
19/07/2023 06:00	23.53	3.9	0.2	28.8	127.5	10
19/07/2023 07:00	23.38	3.9	0.2	28.6	127.3	9.9
19/07/2023 08:00	23.81	4.1	0.2	28.9	125.9	10.1
19/07/2023 09:00	23.78	4.1	0.2	28.8	125.8	10.1
19/07/2023 10:00	23.12	3.9	0.2	28.3	128.4	9.8
19/07/2023 11:00	22.98	4	0.2	28	128.3	9.8
19/07/2023 12:00	23.72	4.1	0.2	28.6	128.1	10.1
19/07/2023 13:00	24.54	4.1	0.2	29.6	128.3	10.4
19/07/2023 14:00	25.3	4.3	0.2	30.3	127.6	10.7
19/07/2023 15:00	25.6	4.4	0.2	30.5	129.1	10.9
19/07/2023 16:00	25.31	4.3	0.2	30.2	129.5	10.7
19/07/2023 17:00	24.73	4.4	0.2	29.4	129.3	10.5
19/07/2023 18:00	24.93	4.4	0.2	29.7	129	10.6
19/07/2023 19:00	24.85	4.3	0.2	29.6	129.2	10.5
19/07/2023 20:00	24.56	4.3	0.2	29.3	129.5	10.4
19/07/2023 21:00	24.85	4.4	0.2	29.5	129.7	10.5
19/07/2023 22:00	24.79	4.4	0.2	29.5	129.6	10.5
19/07/2023 23:00	24.53	4.4	0.2	29.2	129.4	10.4
20/07/2023 00:00	24.47	4.4	0.2	29.1	129.4	10.4
20/07/2023 01:00	24.48	4.3	0.2	29.2	129.2	10.4
20/07/2023 02:00	24.3	4.4	0.2	28.9	129.4	10.3
20/07/2023 03:00	24.13	4.4	0.2	28.7	129.6	10.2
20/07/2023 04:00	24.25	4.4	0.2	28.8	129.5	10.3
20/07/2023 05:00	24.21	4.4	0.2	28.7	129.7	10.3
20/07/2023 06:00	24.19	4.4	0.2	28.7	129.8	10.3
20/07/2023 07:00	23.96	4.4	0.2	28.5	129.7	10.2
20/07/2023 08:00	24.1	4.4	0.2	28.8	129.1	10.2
20/07/2023 09:00	24.79	4.3	0.2	29.6	129.1	10.5
20/07/2023 10:00	25.13	4.4	0.2	29.9	129.1	10.7
20/07/2023 11:00	25	4.3	0.2	29.8	129.3	10.6
20/07/2023 12:00	24.44	4.2	0.2	29.4	129	10.4
20/07/2023 13:00	24.49	4.2	0.2	29.4	129	10.4
20/07/2023 14:00	25.12	4.3	0.2	30.1	129.2	10.7
20/07/2023 15:00	24.3	4.4	0.2	29.9	128.7	10.3
20/07/2023 16:00	24.17	4.1	0.2	29.2	127.7	10.3
20/07/2023 17:00	24.48	4	0.2	29.8	127.2	10.4
20/07/2023 18:00	24.95	4.1	0.2	30.1	126.5	10.6
20/07/2023 19:00	26.6	4.3	0.2	31.8	126.7	11.3
20/07/2023 20:00	26.54	4.4	0.2	31.6	127.5	11.3
20/07/2023 21:00	26.52	4.4	0.2	31.6	127.3	11.3
20/07/2023 22:00	26.96	4.4	0.2	32	125.3	11.4
20/07/2023 23:00	26.88	4.4	0.2	31.8	125.7	11.4
21/07/2023 00:00	26.75	4.4	0.2	31.7	126.5	11.4
21/07/2023 01:00	26.9	4.5	0.2	31.8	123.2	11.4
21/07/2023 02:00	27.03	4.5	0.2	31.9	128.1	11.5

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
03/08/2023 13:00	Maintain	Maintain	Maintain	Maintain	68.3	Maintain
03/08/2023 14:00	Maintain	Maintain	Maintain	Maintain	62.9	Maintain
03/08/2023 15:00	Maintain	Maintain	Maintain	Maintain	55.3	Maintain
03/08/2023 16:00	Maintain	Maintain	Maintain	Maintain	54.4	Maintain
03/08/2023 17:00	Maintain	Maintain	Maintain	Maintain	54.5	Maintain
03/08/2023 18:00	Maintain	Maintain	Maintain	Maintain	53.8	Maintain
03/08/2023 19:00	Maintain	Maintain	Maintain	Maintain	53.4	Maintain
03/08/2023 20:00	Maintain	Maintain	Maintain	Maintain	53.1	Maintain
03/08/2023 21:00	Maintain	Maintain	Maintain	Maintain	52.8	Maintain
03/08/2023 22:00	<Samp	<Samp	<Samp	<Samp	52.1	<Samp
03/08/2023 23:00	0	20.9	0.3	2.4	51.2	0
04/08/2023 00:00	0	20.9	0.3	2.4	50.8	0
04/08/2023 01:00	0	20.9	0.3	2.4	50.5	0
04/08/2023 02:00	0	20.9	0.3	2.4	49.4	0
04/08/2023 03:00	0	20.9	0.3	2.4	48.6	0
04/08/2023 04:00	0	20.9	0.3	2.4	47.7	0
04/08/2023 05:00	0	20.9	0.3	2.4	47	0
04/08/2023 06:00	0	20.9	0.3	2.4	47.2	0
04/08/2023 07:00	0	20.9	0.3	2.4	46.8	0
04/08/2023 08:00	0	20.9	0.3	2.4	47.5	0
04/08/2023 09:00	0	20.9	0.3	2.4	48.3	0
04/08/2023 10:00	0	20.9	0.3	2.3	48.5	0
04/08/2023 11:00	0	20.9	0.3	2.3	48.9	0
04/08/2023 12:00	0	20.9	0.3	2.2	48.8	0
04/08/2023 13:00	0	20.9	0.3	2.2	48.1	0
04/08/2023 14:00	0	20.9	0.3	2.3	48.1	0
04/08/2023 15:00	0	20.9	0.3	2.3	47.9	0
04/08/2023 16:00	0	20.9	0.3	2.3	47.4	0
04/08/2023 17:00	0	20.9	0.3	2.3	45.8	0
04/08/2023 18:00	0	20.9	0.3	2.3	43	0
04/08/2023 19:00	0	20.9	0.3	2.3	41.5	0
04/08/2023 20:00	0	20.9	0.3	2.3	40.7	0
04/08/2023 21:00	0	20.9	0.3	2.3	40.7	0
04/08/2023 22:00	0	20.9	0.3	2.3	40.5	0
04/08/2023 23:00	0	20.9	0.3	2.3	39.9	0
05/08/2023 00:00	0	20.9	0.3	2.3	39.4	0
05/08/2023 01:00	0	20.9	0.3	2.3	39.1	0
05/08/2023 02:00	0	20.9	0.3	2.3	38.9	0
05/08/2023 03:00	0	20.9	0.3	2.3	38.7	0
05/08/2023 04:00	0	20.9	0.3	2.3	38.3	0
05/08/2023 05:00	0	20.9	0.3	2.3	37.8	0
05/08/2023 06:00	0	20.9	0.3	2.3	37.5	0
05/08/2023 07:00	0	20.9	0.3	2.3	38	0
05/08/2023 08:00	0	20.9	0.3	2.3	40.1	0
05/08/2023 09:00	0	20.9	0.3	2.3	41.7	0
05/08/2023 10:00	0	20.9	0.3	2.3	42.7	0
05/08/2023 11:00	0	20.9	0.3	2.3	42.7	0
05/08/2023 12:00	0	20.9	0.3	2.3	42.7	0
05/08/2023 13:00	0	20.9	0.3	2.3	42.2	0
05/08/2023 14:00	0	20.9	0.3	2.3	41.6	0
05/08/2023 15:00	0	20.9	0.3	2.3	41.3	0
05/08/2023 16:00	0	20.9	0.3	2.2	40.1	0
05/08/2023 17:00	0	20.9	0.3	2.3	38.5	0
05/08/2023 18:00	0	20.9	0.3	2.3	37.7	0
05/08/2023 19:00	0	20.9	0.3	2.3	36.8	0
05/08/2023 20:00	0	20.9	0.3	2.3	36.5	0
05/08/2023 21:00	0	20.9	0.3	2.3	36.5	0
05/08/2023 22:00	0	20.9	0.3	2.3	36.4	0
05/08/2023 23:00	0	20.9	0.3	2.3	35.5	0
06/08/2023 00:00	0	20.9	0.3	2.3	35.2	0
06/08/2023 01:00	0	20.9	0.3	2.2	35.4	0

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
06/08/2023 02:00	0	20.9	0.3	2.3	34.9	0
06/08/2023 03:00	0	20.9	0.3	2.2	34.6	0
06/08/2023 04:00	0	20.9	0.3	2.3	34.4	0
06/08/2023 05:00	0	20.9	0.3	2.2	34.7	0
06/08/2023 06:00	0	20.9	0.3	2.2	34.6	0
06/08/2023 07:00	0	20.9	0.3	2.2	35.1	0
06/08/2023 08:00	0	20.9	0.3	2.2	36.6	0
06/08/2023 09:00	0	20.9	0.3	2.3	37.5	0
06/08/2023 10:00	0	20.9	0.3	2.3	38.6	0
06/08/2023 11:00	0	20.9	0.3	2.2	39.1	0
06/08/2023 12:00	0	20.9	0.3	2.2	39.6	0
06/08/2023 13:00	0	20.9	0.3	2.2	38.9	0
06/08/2023 14:00	0	20.9	0.3	2.2	38.6	0
06/08/2023 15:00	0	20.9	0.3	2.2	38.5	0
06/08/2023 16:00	0	20.9	0.3	2.2	37.7	0
06/08/2023 17:00	0	20.9	0.3	2.2	36.3	0
06/08/2023 18:00	0	20.9	0.3	2.2	35.3	0
06/08/2023 19:00	0	20.9	0.3	2.2	34	0
06/08/2023 20:00	0	20.9	0.3	2.2	33.3	0
06/08/2023 21:00	0	20.9	0.3	2.3	33.2	0
06/08/2023 22:00	0	20.9	0.3	2.3	33.2	0
06/08/2023 23:00	0	20.9	0.3	2.3	33.4	0
07/08/2023 00:00	0	20.9	0.3	2.2	33.3	0
07/08/2023 01:00	0	20.9	0.3	2.2	33	0
07/08/2023 02:00	0	20.9	0.3	2.2	32.8	0
07/08/2023 03:00	0	20.9	0.3	2.2	32.8	0
07/08/2023 04:00	0	20.9	0.3	2.2	33.1	0
07/08/2023 05:00	0	20.9	0.3	2.2	33.2	0
07/08/2023 06:00	0	20.9	0.3	2.2	33.3	0
07/08/2023 07:00	0	20.9	0.3	2.2	33.7	0
07/08/2023 08:00	0	20.9	0.3	2.2	35.2	0
07/08/2023 09:00	0	20.9	0.3	2.2	36.5	0
07/08/2023 10:00	0	20.9	0.3	2.2	37.4	0
07/08/2023 11:00	0	20.9	0.3	2.2	37.9	0
07/08/2023 12:00	0	20.9	0.3	2.2	38.7	0
07/08/2023 13:00	0	20.9	0.3	2.2	38	0
07/08/2023 14:00	0	20.9	0.3	2.2	37.7	0
07/08/2023 15:00	0	20.9	0.3	2.2	36.9	0
07/08/2023 16:00	0	20.9	0.3	2.2	35.5	0
07/08/2023 17:00	0	20.9	0.3	2.2	34.3	0
07/08/2023 18:00	0	20.9	0.3	2.2	33.8	0
07/08/2023 19:00	0	20.9	0.3	2.2	33.6	0
07/08/2023 20:00	0	20.9	0.3	2.2	33.1	0
07/08/2023 21:00	0	20.9	0.3	2.2	33	0
07/08/2023 22:00	0	20.9	0.3	2.2	32.7	0
07/08/2023 23:00	0	20.9	0.3	2.2	32.5	0
08/08/2023 00:00	0	20.9	0.3	2.2	32.5	0
08/08/2023 01:00	0	20.9	0.3	2.2	32.2	0
08/08/2023 02:00	0	20.9	0.3	2.2	32.2	0
08/08/2023 03:00	0	20.9	0.3	2.2	32	0
08/08/2023 04:00	0	20.9	0.3	2.2	31.9	0
08/08/2023 05:00	0	20.9	0.3	2.2	32	0
08/08/2023 06:00	0	20.9	0.3	2.2	32	0
08/08/2023 07:00	0	20.9	0.3	2.2	32.9	0
08/08/2023 08:00	0	20.9	0.3	2.3	34.7	0
08/08/2023 09:00	0	20.9	0.3	2.2	36.9	0
08/08/2023 10:00	0	20.9	0.3	2.2	37	0
08/08/2023 11:00	0	20.9	0.3	2.3	36.9	0
08/08/2023 12:00	0	20.9	0.3	2.2	37.8	0
08/08/2023 13:00	0	20.9	0.3	2.2	37.4	0
08/08/2023 14:00	0	20.9	0.3	2.2	37.3	0

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
08/08/2023 15:00	0	20.9	0.3	2.2	37	0
08/08/2023 16:00	0	20.9	0.3	2.2	36.4	0
08/08/2023 17:00	0	20.9	0.3	2.2	35.5	0
08/08/2023 18:00	0	20.9	0.3	2.2	33.9	0
08/08/2023 19:00	0	20.9	0.3	2.2	32.4	0
08/08/2023 20:00	0	20.9	0.3	2.2	31.8	0
08/08/2023 21:00	0	20.9	0.3	2.3	31.4	0
08/08/2023 22:00	0	20.9	0.3	2.3	31.6	0
08/08/2023 23:00	0	20.9	0.3	2.3	31.4	0
09/08/2023 00:00	0	20.9	0.3	2.3	31.1	0
09/08/2023 01:00	0	20.9	0.3	2.3	31.1	0
09/08/2023 02:00	0	20.9	0.3	2.3	30.9	0
09/08/2023 03:00	0	20.9	0.3	2.3	30.9	0
09/08/2023 04:00	0	20.9	0.3	2.3	31.2	0
09/08/2023 05:00	0	20.9	0.3	2.3	31.4	0
09/08/2023 06:00	0	20.9	0.3	2.3	31.3	0
09/08/2023 07:00	0	20.9	0.3	2.3	32.3	0
09/08/2023 08:00	0	20.9	0.3	2.3	33.9	0
09/08/2023 09:00	0	20.9	0.3	2.3	35.2	0
09/08/2023 10:00	0	20.9	0.3	2.3	36.2	0
09/08/2023 11:00	0	20.9	0.3	2.2	35.9	0
09/08/2023 12:00	0	20.9	0.3	2.1	39.1	0
09/08/2023 13:00	0	20.9	0.3	2	36.6	0
09/08/2023 14:00	0	20.9	0.3	1.4	37.4	0
09/08/2023 15:00	0	20.9	0.3	1.5	37.7	0
09/08/2023 16:00	0	20.9	0.3	1.8	37.6	0
09/08/2023 17:00	0	20.9	0.3	2	36.4	0
09/08/2023 18:00	0	20.9	0.3	2.1	34.2	0
09/08/2023 19:00	0	20.9	0.3	2.2	32.2	0
09/08/2023 20:00	0	20.9	0.3	2.3	31.6	0
09/08/2023 21:00	0	20.9	0.3	2.3	31.5	0
09/08/2023 22:00	0	20.9	0.3	2.3	31.5	0
09/08/2023 23:00	0	20.9	0.3	2.3	31.2	0
10/08/2023 00:00	0	20.9	0.3	2.3	31.1	0
10/08/2023 01:00	0	20.9	0.3	2.3	30.7	0
10/08/2023 02:00	0	20.9	0.3	2.3	30.7	0
10/08/2023 03:00	0	20.9	0.3	2.3	30.7	0
10/08/2023 04:00	0	20.9	0.3	2.3	30.7	0
10/08/2023 05:00	0	20.9	0.3	2.3	30.5	0
10/08/2023 06:00	0	20.9	0.3	2.3	30.7	0
10/08/2023 07:00	0	20.9	0.3	2.3	32.9	0
10/08/2023 08:00	0	20.9	0.3	2.2	34.9	0
10/08/2023 09:00	0	20.9	0.3	2.3	36	0
10/08/2023 10:00	0	20.9	0.3	2.3	36.5	0
10/08/2023 11:00	0	20.9	0.3	2.2	36.5	0
10/08/2023 12:00	0	20.9	0.3	2.2	39.2	0
10/08/2023 13:00	0	20.9	0.3	2.2	36.7	0
10/08/2023 14:00	0	20.9	0.3	2.2	36.4	0
10/08/2023 15:00	0	20.9	0.3	2.2	37.6	0
10/08/2023 16:00	0	20.9	0.3	2.3	37.2	0
10/08/2023 17:00	0	20.9	0.3	2.3	34.5	0
10/08/2023 18:00	0	20.9	0.3	2.3	33.9	0
10/08/2023 19:00	0	20.9	0.3	2.3	38.5	0
10/08/2023 20:00	0	20.9	0.3	2.3	37.5	0
10/08/2023 21:00	0	20.9	0.3	2.3	36.1	0
10/08/2023 22:00	0	20.9	0.3	2.3	35.1	0
10/08/2023 23:00	0	20.9	0.3	2.3	33.9	0
11/08/2023 00:00	0	20.9	0.3	2.3	33.4	0
11/08/2023 01:00	0	20.9	0.3	2.3	32.9	0
11/08/2023 02:00	0	20.9	0.3	2.3	32.1	0
11/08/2023 03:00	0	20.9	0.3	2.3	31.8	0

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2		O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol		km3/h	ppm	Deg C	ppm
13/08/2023 17:00	Maintain	Maintain		Maintain	Maintain	42.5	Maintain
13/08/2023 18:00	Maintain	Maintain		Maintain	Maintain	40.2	Maintain
13/08/2023 19:00	Maintain	Maintain		Maintain	Maintain	38.8	Maintain
13/08/2023 20:00	Maintain	Maintain		Maintain	Maintain	38.2	Maintain
13/08/2023 21:00	Maintain	Maintain		Maintain	Maintain	37.3	Maintain
13/08/2023 22:00	Maintain	Maintain		Maintain	Maintain	37	Maintain
13/08/2023 23:00	Maintain	Maintain		Maintain	Maintain	36.9	Maintain
14/08/2023 00:00	Maintain	Maintain		Maintain	Maintain	36.5	Maintain
14/08/2023 01:00	Maintain	Maintain		Maintain	Maintain	35.9	Maintain
14/08/2023 02:00	Maintain	Maintain		Maintain	Maintain	35.5	Maintain
14/08/2023 03:00	Maintain	Maintain		Maintain	Maintain	35	Maintain
14/08/2023 04:00	Maintain	Maintain		Maintain	Maintain	34.9	Maintain
14/08/2023 05:00	Maintain	Maintain		Maintain	Maintain	34.5	Maintain
14/08/2023 06:00	Maintain	Maintain		Maintain	Maintain	34.4	Maintain
14/08/2023 07:00	Maintain	Maintain		Maintain	Maintain	35	Maintain
14/08/2023 08:00	Maintain	Maintain		Maintain	Maintain	40.1	Maintain
14/08/2023 09:00	Maintain	Maintain		Maintain	Maintain	43.4	Maintain
14/08/2023 10:00	Maintain	Maintain		Maintain	Maintain	59.5	Maintain
14/08/2023 11:00	Maintain	Maintain		Maintain	Maintain	107.2	Maintain
14/08/2023 12:00	Maintain	Maintain		Maintain	Maintain	122.9	Maintain
14/08/2023 13:00	Maintain	Maintain		Maintain	Maintain	126.4	Maintain
14/08/2023 14:00	Maintain	Maintain		Maintain	Maintain	127.1	Maintain
14/08/2023 15:00	Maintain	Maintain		Maintain	Maintain	128.8	Maintain
14/08/2023 16:00	<Samp	<Samp	<Samp	<Samp	<Samp	128.3	<Samp
14/08/2023 17:00	28.38	4.6	0.2	33.3	128.1	12	
14/08/2023 18:00	27.51	4.6	0.2	32.2	127.9	11.7	
14/08/2023 19:00	27.42	4.6	0.2	32.2	127.7	11.6	
14/08/2023 20:00	27.13	4.5	0.2	32	127.7	11.5	
14/08/2023 21:00	26.82	4.5	0.2	31.6	127.7	11.4	
14/08/2023 22:00	27.02	4.5	0.2	31.8	127.8	11.5	
14/08/2023 23:00	27.42	4.5	0.2	32.3	128	11.6	
15/08/2023 00:00	28.2	4.6	0.2	33	128.3	12	
15/08/2023 01:00	28.03	4.6	0.2	32.9	128.6	11.9	
15/08/2023 02:00	28.07	4.7	0.2	32.8	128.2	11.9	
15/08/2023 03:00	27.56	4.7	0.2	32.2	127.6	11.7	
15/08/2023 04:00	27.74	4.7	0.2	32.4	127.9	11.8	
15/08/2023 05:00	27.88	4.7	0.2	32.6	127.8	11.8	
15/08/2023 06:00	27.84	4.6	0.2	32.6	128.2	11.8	
15/08/2023 07:00	27.94	4.6	0.2	32.8	128.4	11.9	
15/08/2023 08:00	28.58	4.6	0.2	33.6	127.9	12.1	
15/08/2023 09:00	28.56	4.5	0.2	33.6	127.6	12.1	
15/08/2023 10:00	28.15	4.5	0.2	33.2	127.6	11.9	
15/08/2023 11:00	27.62	4.5	0.2	32.8	127.5	11.7	
15/08/2023 12:00	27.76	4.5	0.2	32.8	127.9	11.8	
15/08/2023 13:00	27.82	4.5	0.2	32.8	126.7	11.8	
15/08/2023 14:00	27.95	4.5	0.2	32.9	126.6	11.9	
15/08/2023 15:00	27.59	4.5	0.2	32.5	126.5	11.7	
15/08/2023 16:00	27.19	4.5	0.2	32.1	126.4	11.5	
15/08/2023 17:00	27.52	4.5	0.2	32.5	126.4	11.7	
15/08/2023 18:00	27.49	4.5	0.2	32.5	126.7	11.7	
15/08/2023 19:00	27.6	4.5	0.2	32.6	126.6	11.7	
15/08/2023 20:00	27.51	4.4	0.2	32.6	127.2	11.7	
15/08/2023 21:00	28.34	4.5	0.2	33.4	127.3	12	
15/08/2023 22:00	28.89	4.6	0.2	33.9	127.1	12.3	
15/08/2023 23:00	29.03	4.5	0.2	34.2	127	12.3	
16/08/2023 00:00	28.62	4.6	0.2	33.7	126.4	12.1	
16/08/2023 01:00	28.43	4.7	0.2	33.2	127.4	12.1	
16/08/2023 02:00	28.33	4.7	0.2	33.1	127.7	12	
16/08/2023 03:00	28.73	4.7	0.2	33.5	128.1	12.2	
16/08/2023 04:00	28.77	4.6	0.2	33.6	128.5	12.2	
16/08/2023 05:00	28.99	4.6	0.2	33.9	128.8	12.3	

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2		O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol		km3/h	ppm	Deg C	ppm
16/08/2023 06:00	28.69	4.6	0.2	33.7	128.7	12.2	
16/08/2023 07:00	28.49	4.6	0.2	33.5	128.1	12.1	
16/08/2023 08:00	28.54	4.5	0.2	33.6	127.6	12.1	
16/08/2023 09:00	28.61	4.6	0.2	33.5	127.7	12.1	
16/08/2023 10:00	27.58	4.6	0.2	32.4	127.9	11.7	
16/08/2023 11:00	27.32	4.5	0.2	32.2	127.6	11.6	
16/08/2023 12:00	28.31	4.6	0.2	33.2	129.1	12	
16/08/2023 13:00	<Samp	<Samp	<Samp	<Samp	128.2	<Samp	
16/08/2023 14:00	Maintain	Maintain	Maintain	Maintain	127.8	Maintain	
16/08/2023 15:00	<Samp	<Samp	<Samp	<Samp	127.1	<Samp	
16/08/2023 16:00	27.66	4.6	0.2	32.4	127.2	11.7	
16/08/2023 17:00	27.84	4.6	0.2	32.5	126.8	11.8	
16/08/2023 18:00	27.98	4.6	0.2	32.8	126.5	11.9	
16/08/2023 19:00	28.25	4.5	0.2	33.4	126.9	12	
16/08/2023 20:00	28.05	4.6	0.2	32.9	128	11.9	
16/08/2023 21:00	27.62	4.5	0.2	32.5	127.9	11.7	
16/08/2023 22:00	27.18	4.4	0.2	32.2	127.9	11.5	
16/08/2023 23:00	27.39	4.5	0.2	32.4	129	11.6	
17/08/2023 00:00	28.43	4.6	0.2	33.4	128	12.1	
17/08/2023 01:00	28.59	4.5	0.2	33.7	127.5	12.1	
17/08/2023 02:00	28.82	4.5	0.2	33.9	127.6	12.2	
17/08/2023 03:00	28.91	4.6	0.2	33.8	128.2	12.3	
17/08/2023 04:00	28.89	4.6	0.2	33.8	128	12.3	
17/08/2023 05:00	29.05	4.7	0.2	33.9	128.5	12.3	
17/08/2023 06:00	28.96	4.7	0.2	33.7	128.9	12.3	
17/08/2023 07:00	28.73	4.6	0.2	33.6	128.5	12.2	
17/08/2023 08:00	29.35	4.8	0.2	34.1	127.9	12.5	
17/08/2023 09:00	29.68	4.7	0.2	34.5	127.5	12.6	
17/08/2023 10:00	29.97	4.6	0.2	35.1	127.2	12.7	
17/08/2023 11:00	30.3	4.7	0.2	35.4	127.4	12.9	
17/08/2023 12:00	30.69	4.6	0.2	35.9	127.5	13	
17/08/2023 13:00	31.48	4.6	0.2	36.8	127.9	13.4	
17/08/2023 14:00	29.61	4.7	0.2	34.6	127.7	12.6	
17/08/2023 15:00	29.49	4.5	0.2	34.7	127.6	12.5	
17/08/2023 16:00	29.31	4.7	0.2	34.1	127.4	12.4	
17/08/2023 17:00	28.52	4.5	0.2	33.7	126.6	12.1	
17/08/2023 18:00	28.2	4.6	0.2	33.1	126.5	12	
17/08/2023 19:00	28.14	4.5	0.2	33.2	126.8	11.9	
17/08/2023 20:00	28.67	4.5	0.2	33.8	127.3	12.2	
17/08/2023 21:00	28.51	4.5	0.2	33.7	128.4	12.1	
17/08/2023 22:00	28.33	4.5	0.2	33.5	128.7	12	
17/08/2023 23:00	28.2	4.4	0.2	33.4	128.8	12	
18/08/2023 00:00	28.52	4.6	0.2	33.5	129	12.1	
18/08/2023 01:00	28.45	4.6	0.2	33.4	129.3	12.1	
18/08/2023 02:00	28.1	4.5	0.2	33.2	129.2	11.9	
18/08/2023 03:00	28.04	4.5	0.2	33	129	11.9	
18/08/2023 04:00	28.2	4.5	0.2	33.2	129.1	12	
18/08/2023 05:00	28.4	4.6	0.2	33.3	128.8	12.1	
18/08/2023 06:00	28.39	4.5	0.2	33.4	128.3	12.1	
18/08/2023 07:00	28.29	4.5	0.2	33.4	128.1	12	
18/08/2023 08:00	28.55	4.5	0.2	33.6	127.6	12.1	
18/08/2023 09:00	29.8	4.8	0.2	34.6	128.1	12.6	
18/08/2023 10:00	31.09	4.8	0.2	35.9	128.4	13.2	
18/08/2023 11:00	31.41	4.8	0.2	36.3	128.5	13.3	
18/08/2023 12:00	31.03	4.6	0.2	36.4	129.6	13.2	
18/08/2023 13:00	31.68	4.6	0.2	37.1	128.4	13.4	
18/08/2023 14:00	31.27	4.7	0.2	36.5	128.7	13.3	
18/08/2023 15:00	31.32	4.5	0.2	36.8	128.6	13.3	
18/08/2023 16:00	30.76	4.6	0.2	36.1	128	13.1	
18/08/2023 17:00	28.93	4.4	0.2	34.3	126.8	12.3	
18/08/2023 18:00	28.51	4.4	0.2	33.8	126.3	12.1	

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2		O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol		km3/h	ppm	Deg C	ppm
18/08/2023 19:00	28.42	4.4	0.2	33.6	126.9	12.1	
18/08/2023 20:00	28.2	4.4	0.2	33.5	127	12	
18/08/2023 21:00	27.76	4.4	0.2	32.9	127.6	11.8	
18/08/2023 22:00	27.59	4.5	0.2	32.6	128	11.7	
18/08/2023 23:00	27.49	4.5	0.2	32.5	128.2	11.7	
19/08/2023 00:00	27.44	4.4	0.2	32.5	128.9	11.6	
19/08/2023 01:00	27.86	4.5	0.2	32.9	129	11.8	
19/08/2023 02:00	27.88	4.4	0.2	33	129.1	11.8	
19/08/2023 03:00	28.07	4.5	0.2	33.1	129	11.9	
19/08/2023 04:00	27.93	4.4	0.2	33.1	128.6	11.9	
19/08/2023 05:00	28.05	4.4	0.2	33.2	128.9	11.9	
19/08/2023 06:00	27.76	4.4	0.2	33	129	11.8	
19/08/2023 07:00	28.14	4.5	0.2	33.2	129.2	11.9	
19/08/2023 08:00	28.32	4.2	0.2	34.1	128.7	12	
19/08/2023 09:00	29.39	4.2	0.2	35.2	128.3	12.5	
19/08/2023 10:00	30.32	4.3	0.2	36.3	127.8	12.9	
19/08/2023 11:00	30.66	4.3	0.2	36.6	127.6	13	
19/08/2023 12:00	30.82	4.3	0.2	36.7	129	13.1	
19/08/2023 13:00	31.17	4.6	0.2	36.6	127.8	13.2	
19/08/2023 14:00	31.02	4.5	0.2	36.6	128.2	13.2	
19/08/2023 15:00	31.06	4.6	0.2	36.4	128.7	13.2	
19/08/2023 16:00	30.34	4.3	0.2	36.2	128.4	12.9	
19/08/2023 17:00	29.56	4.5	0.2	34.9	128	12.5	
19/08/2023 18:00	28.4	4.4	0.2	33.6	127.1	12.1	
19/08/2023 19:00	28.42	4.4	0.2	33.8	127.3	12.1	
19/08/2023 20:00	28.26	4.5	0.2	33.3	127.9	12	
19/08/2023 21:00	27.03	4.3	0.2	32.3	127.6	11.5	
19/08/2023 22:00	27.06	4.4	0.2	32.2	128.2	11.5	
19/08/2023 23:00	26.96	4.4	0.2	32	128.6	11.4	
20/08/2023 00:00	27.19	4.5	0.2	32.2	128.2	11.5	
20/08/2023 01:00	27.66	4.7	0.2	32.7	129.4	11.7	
20/08/2023 02:00	27.38	4.7	0.2	31.8	129.6	11.6	
20/08/2023 03:00	27.62	4.7	0.2	32.2	129.8	11.7	
20/08/2023 04:00	27.64	4.6	0.2	32.4	129.4	11.7	
20/08/2023 05:00	27.4	4.5	0.2	32.3	129.5	11.6	
20/08/2023 06:00	27.44	4.7	0.2	31.9	129.3	11.6	
20/08/2023 07:00	28.01	4.5	0.2	32.9	129.1	11.9	
20/08/2023 08:00	28.67	4.6	0.2	33.6	128.7	12.2	
20/08/2023 09:00	28.11	4.4	0.2	33.3	128.3	11.9	
20/08/2023 10:00	27.54	4.5	0.2	32.5	128.4	11.7	
20/08/2023 11:00	29.36	4.5	0.2	34.6	128.3	12.5	
20/08/2023 12:00	29.61	4.6	0.2	34.8	128.9	12.6	
20/08/2023 13:00	28.49	4.3	0.2	34.1	127.5	12.1	
20/08/2023 14:00	29.04	4.6	0.2	34	127.4	12.3	
20/08/2023 15:00	28.21	4.5	0.2	33.2	127.3	12	
20/08/2023 16:00	27.7	4.4	0.2	32.8	127.2	11.8	
20/08/2023 17:00	28.13	4.6	0.2	33	127.1	11.9	
20/08/2023 18:00	27.95	4.5	0.2	33	127.1	11.9	
20/08/2023 19:00	27.42	4.5	0.2	32.4	127.4	11.6	
20/08/2023 20:00	27.32	4.5	0.2	32.2	127.2	11.6	
20/08/2023 21:00	27.05	4.5	0.2	31.9	127.2	11.5	
20/08/2023 22:00	27.49	4.5	0.2	32.5	127.7	11.7	
20/08/2023 23:00	27.8	4.5	0.2	32.8	126.4	11.8	
21/08/2023 00:00	26.47	4.4	0.2	31.4	116.5	11.2	
21/08/2023 01:00	26.75	4.5	0.2	31.5	127.3	11.4	
21/08/2023 02:00	27.77	4.6	0.2	32.5	128.4	11.8	
21/08/2023 03:00	27.63	4.5	0.2	32.7	128	11.7	
21/08/2023 04:00	28.01	4.7	0.2	32.7	128.6	11.9	
21/08/2023 05:00	27.82	4.6	0.2	32.6	128.3	11.8	
21/08/2023 06:00	27.48	4.6	0.2	32.2	128.4	11.7	
21/08/2023 07:00	27.46	4.7	0.2	32.1	129.3	11.7	

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
23/08/2023 21:00	27.44	4.2	0.2	33	127.2	11.6
23/08/2023 22:00	27.6	4.4	0.2	32.8	126.8	11.7
23/08/2023 23:00	27.86	4.3	0.2	33.2	127.2	11.8
24/08/2023 00:00	27.72	4.3	0.2	33.1	127.7	11.8
24/08/2023 01:00	28.12	4.4	0.2	33.4	127.5	11.9
24/08/2023 02:00	28.28	4.3	0.2	33.8	127.2	12
24/08/2023 03:00	28.62	4.5	0.2	33.7	127.6	12.1
24/08/2023 04:00	28.67	4.5	0.2	33.9	127.7	12.2
24/08/2023 05:00	28.51	4.5	0.2	33.7	127.7	12.1
24/08/2023 06:00	27.81	4.4	0.2	33	127.2	11.8
24/08/2023 07:00	27.49	4.3	0.2	32.8	127.9	11.7
24/08/2023 08:00	27.95	4.5	0.2	33.1	127.7	11.9
24/08/2023 09:00	27.4	4.4	0.2	32.6	127.7	11.6
24/08/2023 10:00	25.02	4.1	0.2	30.3	126.5	10.6
24/08/2023 11:00	25.58	4	0.2	31	126.4	10.9
24/08/2023 12:00	27.64	4.3	0.2	32.9	126.8	11.7
24/08/2023 13:00	27.37	4.5	0.2	32.2	127	11.6
24/08/2023 14:00	25.87	4.5	0.2	30.6	127	11
24/08/2023 15:00	27.12	4.3	0.2	32.3	127.1	11.5
24/08/2023 16:00	27.47	4.3	0.2	32.7	126.6	11.7
24/08/2023 17:00	27.95	4.4	0.2	33.2	126	11.9
24/08/2023 18:00	27.89	4.3	0.2	33.2	126.1	11.8
24/08/2023 19:00	27.82	4.3	0.2	33.3	126.6	11.8
24/08/2023 20:00	27.84	4.2	0.2	33.3	127.3	11.8
24/08/2023 21:00	27.97	4.3	0.2	33.3	127.7	11.9
24/08/2023 22:00	27.96	4.3	0.2	33.4	128.4	11.9
24/08/2023 23:00	28.15	4.3	0.2	33.6	128.5	11.9
25/08/2023 00:00	28.26	4.4	0.2	33.6	128.6	12
25/08/2023 01:00	28.35	4.5	0.2	33.3	128.8	12
25/08/2023 02:00	27.77	4.3	0.2	33.2	128.9	11.8
25/08/2023 03:00	28.13	4.4	0.2	33.3	128.1	11.9
25/08/2023 04:00	28.02	4.4	0.2	33.3	128	11.9
25/08/2023 05:00	28.64	4.5	0.2	33.9	127.9	12.2
25/08/2023 06:00	29.04	4.5	0.2	34.2	128.2	12.3
25/08/2023 07:00	28.51	4.4	0.2	33.9	127.9	12.1
25/08/2023 08:00	28.72	4.3	0.2	34.4	127.1	12.2
25/08/2023 09:00	29.12	4.3	0.2	34.9	127	12.4
25/08/2023 10:00	26.88	4.3	0.2	32.2	127.3	11.4
25/08/2023 11:00	26.29	4.4	0.2	31.3	127.1	11.2
25/08/2023 12:00	27.04	4.5	0.2	31.9	128.1	11.5
25/08/2023 13:00	27.23	4.3	0.2	32.5	126.6	11.6
25/08/2023 14:00	25.87	4.2	0.2	31.1	126.3	11
25/08/2023 15:00	25.32	4.4	0.2	30.1	127.1	10.7
25/08/2023 16:00	25.21	4.5	0.2	29.8	126.6	10.7
25/08/2023 17:00	26.13	4.4	0.2	31.1	126.4	11.1
25/08/2023 18:00	27.11	4.2	0.2	32.5	125.7	11.5
25/08/2023 19:00	27.43	4.3	0.2	32.8	126.1	11.6
25/08/2023 20:00	27.64	4.3	0.2	33.1	126.4	11.7
25/08/2023 21:00	28.64	4.4	0.2	33.9	126.7	12.1
25/08/2023 22:00	28.48	4.4	0.2	33.9	127.4	12.2
25/08/2023 23:00	28.37	4.3	0.2	33.8	127.8	12
26/08/2023 00:00	28.23	4.4	0.2	33.6	128.4	12
26/08/2023 01:00	28.24	4.5	0.2	33.4	128.6	12
26/08/2023 02:00	27.94	4.4	0.2	33.2	128.3	11.9
26/08/2023 03:00	27.97	4.4	0.2	33.2	128.1	11.9
26/08/2023 04:00	28.15	4.5	0.2	33.2	128.4	11.9
26/08/2023 05:00	28.11	4.4	0.2	33.3	128.1	11.9
26/08/2023 06:00	28.33	4.5	0.2	33.5	128.1	12
26/08/2023 07:00	28.4	4.5	0.2	33.6	128	12.1
26/08/2023 08:00	28.4	4.3	0.2	33.9	127.4	12.1
26/08/2023 09:00	28.25	4.1	0.2	34.2	127.1	12

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
26/08/2023 10:00	28.73	4.1	0.2	34.8	127.4	12.2
26/08/2023 11:00	29.45	4.1	0.2	35.7	127.3	12.5
26/08/2023 12:00	29.39	4.1	0.2	35.5	128.1	12.5
26/08/2023 13:00	29.82	4.1	0.2	36.1	127.2	12.7
26/08/2023 14:00	30.68	4.3	0.2	36.5	127.3	13
26/08/2023 15:00	30.66	4.4	0.2	36.3	127.7	13
26/08/2023 16:00	30.09	4.4	0.2	35.7	127.4	12.8
26/08/2023 17:00	29.21	4.3	0.2	34.8	126.3	12.4
26/08/2023 18:00	28.46	4.3	0.2	34	125.3	12.1
26/08/2023 19:00	29.31	4.5	0.2	34.6	126.7	12.4
26/08/2023 20:00	28.88	4.4	0.2	34.3	127.1	12.3
26/08/2023 21:00	28.72	4.3	0.2	34.4	127.3	12.2
26/08/2023 22:00	29.17	4.6	0.2	34.2	127.9	12.4
26/08/2023 23:00	28.44	4.3	0.2	33.9	127.6	12.1
27/08/2023 00:00	28.1	4.3	0.2	33.6	127.2	11.9
27/08/2023 01:00	28.42	4.5	0.2	33.5	127.3	12.1
27/08/2023 02:00	28.94	4.7	0.2	33.7	127.6	12.3
27/08/2023 03:00	28.58	4.4	0.2	33.8	127.8	12.1
27/08/2023 04:00	28.37	4.4	0.2	33.6	128.2	12
27/08/2023 05:00	28.29	4.5	0.2	33.5	128	12
27/08/2023 06:00	28.76	4.8	0.2	33.4	128.6	12.2
27/08/2023 07:00	28.28	4.5	0.2	33.4	128.3	12
27/08/2023 08:00	28.72	4.6	0.2	33.7	127.4	12.2
27/08/2023 09:00	29.52	4.7	0.2	34.4	127.4	12.5
27/08/2023 10:00	28.91	4.3	0.2	34.5	127.2	12.3
27/08/2023 11:00	30.28	4.6	0.2	35.4	127.6	12.9
27/08/2023 12:00	30.54	4.7	0.2	35.5	128.2	13
27/08/2023 13:00	30.43	4.8	0.2	35.2	128.3	12.9
27/08/2023 14:00	30.45	4.7	0.2	35.5	128.5	12.9
27/08/2023 15:00	30.71	4.6	0.2	35.9	128.6	13
27/08/2023 16:00	30.35	4.6	0.2	35.6	127.7	12.9
27/08/2023 17:00	30.46	4.6	0.2	35.6	127.3	12.9
27/08/2023 18:00	29.54	4.5	0.2	34.8	127.7	12.5
27/08/2023 19:00	28.32	4.5	0.2	33.5	127.3	12
27/08/2023 20:00	28.13	4.5	0.2	33.1	127.3	11.9
27/08/2023 21:00	27.85	4.4	0.2	33	127.1	11.8
27/08/2023 22:00	27.3	4.2	0.2	32.8	127.4	11.6
27/08/2023 23:00	27.34	4.4	0.2	32.5	127.9	11.8
28/08/2023 00:00	27.05	4.3	0.2	32.3	128.1	11.5
28/08/2023 01:00	26.88	4.2	0.2	32.3	127.7	11.4
28/08/2023 02:00	28.06	4.7	0.2	32.8	128.4	11.9
28/08/2023 03:00	28.26	4.5	0.2	33.4	127.9	12
28/08/2023 04:00	28.69	4.6	0.2	33.6	128.3	12.2
28/08/2023 05:00	28.45	4.4	0.2	33.7	128.2	12.1
28/08/2023 06:00	28.82	4.6	0.2	33.7	128.3	12.2
28/08/2023 07:00	28.82	4.5	0.2	34	128	12.2
28/08/2023 08:00	28.15	4	0.2	34.3	126.6	11.9
28/08/2023 09:00	28.32	4.1	0.2	34.3	125.8	12
28/08/2023 10:00	29.13	4.3	0.2	34.8	126.2	12.4
28/08/2023 11:00	29.78	4.3	0.2	35.7	126.6	12.6
28/08/2023 12:00	30.01	4.2	0.2	36	127.7	12.7
28/08/2023 13:00	30.26	4.4	0.2	36	127.1	12.8
28/08/2023 14:00	29.73	4.3	0.2	35.5	127.4	12.6
28/08/2023 15:00	29.03	4.3	0.2	34.6	126.6	12.3
28/08/2023 16:00	28.65	4.2	0.2	34.4	126.4	12.2
28/08/2023 17:00	28.45	4.2	0.2	34.2	125.9	12.1
28/08/2023 18:00	28.01	4.2	0.2	33.6	126	11.9
28/08/2023 19:00	27.85	4.3	0.2	33.2	126.8	11.8
28/08/2023 20:00	27.42	4.1	0.2	33.1	126.9	11.6
28/08/2023 21:00	27.44	4.3	0.2	32.8	127	11.6
28/08/2023 22:00	27.07	4.2	0.2	32.5	127	11.5

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
28/08/2023 23:00	27.15	4.1	0.2	32.8	128	11.5
29/08/2023 00:00	27.06	4.2	0.2	32.5	127.9	11.5
29/08/2023 01:00	28.55	4.5	0.2	33.6	128	12.1
29/08/2023 02:00	28.05	4.2	0.2	33.7	127.6	11.9
29/08/2023 03:00	28.92	4.5	0.2	34	127.8	12.3
29/08/2023 04:00	29.07	4.4	0.2	34.5	127.2	12.3
29/08/2023 05:00	28.57	4.2	0.2	34.2	127	12.1
29/08/2023 06:00	28.55	4.3	0.2	34.1	127.1	12.1
29/08/2023 07:00	28.65	4.3	0.2	34.1	126.9	12.2
29/08/2023 08:00	28.94	4.3	0.2	34.5	126.6	12.3
29/08/2023 09:00	28.71	4.4	0.2	34.1	126.7	12.2
29/08/2023 10:00	27.29	4.4	0.2	32.4	126.8	11.6
29/08/2023 11:00	26.83	4.3	0.2	32	126.9	11.4
29/08/2023 12:00	26.97	4.2	0.2	32.4	127.1	11.4
29/08/2023 13:00	27.64	4.1	0.2	33.3	126.3	11.7
29/08/2023 14:00	28.24	4.3	0.2	33.7	126.7	12
29/08/2023 15:00	27.05	4.3	0.2	32.3	126.6	11.5
29/08/2023 16:00	27.16	4.4	0.2	32.3	126.2	11.5
29/08/2023 17:00	26.82	4.1	0.2	32.3	125.9	11.4
29/08/2023 18:00	27.16	4.2	0.2	32.5	126.6	11.5
29/08/2023 19:00	26.92	4.1	0.2	32.5	126.6	11.4
29/08/2023 20:00	28.22	4.3	0.2	33.6	127.2	12
29/08/2023 21:00	28.44	4.4	0.2	33.8	126.8	12.1
29/08/2023 22:00	28.1	4.3	0.2	33.6	126.7	11.9
29/08/2023 23:00	28.41	4.4	0.2	33.7	127	12.1
30/08/2023 00:00	28.51	4.3	0.2	34	127.1	12.1
30/08/2023 01:00	28.2	4.1	0.2	34	127	12
30/08/2023 02:00	28.89	4.4	0.2	34.2	127.1	12.3
30/08/2023 03:00	28.19	4.2	0.2	33.8	127.1	12
30/08/2023 04:00	27.88	4.2	0.2	33.5	126.9	11.8
30/08/2023 05:00	28.02	4.3	0.2	33.4	126.5	11.9
30/08/2023 06:00	28.52	4.5	0.2	33.7	127.2	12.1
30/08/2023 07:00	28.72	4.6	0.2	33.8	127.9	12.2
30/08/2023 08:00	28.84	4.5	0.2	33.9	127.5	12.2
30/08/2023 09:00	28.78	4.4	0.2	34.1	127.2	12.2
30/08/2023 10:00	29.09	4.4	0.2	34.6	126.9	12.3
30/08/2023 11:00	29.22	4.5	0.2	34.4	127	12.4
30/08/2023 12:00	29.24	4.5	0.2	34.4	127.5	12.4
30/08/2023 13:00	29.13	4.5	0.2	34.3	126.6	12.4
30/08/2023 14:00	28.74	4.4	0.2	34.1	126.1	12.2
30/08/2023 15:00	28.64	4.3	0.2	34.1	126	12.2
30/08/2023 16:00	28.75	4.3	0.2	34.2	125.9	12.2
30/08/2023 17:00	28.14	4.3	0.2	33.7	125.9	11.9
30/08/2023 18:00	27.85	4.2	0.2	33.5	126.3	11.8
30/08/2023 19:00	27.78	4.3	0.2	33.1	126.7	11.8
30/08/2023 20:00	27.7	4.3	0.2	33	126.6	11.8
30/08/2023 21:00	27.47	4.1	0.2	33.3	126.4	11.7
30/08/2023 22:00	27.66	4.1	0.2	33.4	126.2	11.7
30/08/2023 23:00	27.81	4.2	0.2	33.5	126.3	11.8
31/08/2023 00:00	27.68	4.1	0.2	33.5	126.2	11.7
31/08/2023 01:00	27.59	4.1	0.2	33.3	126.5	11.7
31/08/2023 02:00	27.74	4.2	0.2	33.4	126.6	11.8
31/08/2023 03:00	27.54	4	0.2	33.5	126.3	11.7
31/08/2023 04:00	28.08	4.2	0.2	33.8	126.4	11.9
31/08/2023 05:00	27.94	4.1	0.2	33.7	126.6	11.9
31/08/2023 06:00	27.94	4.2	0.2	33.6	126.6	11.9
31/08/2023 07:00	28.08	4.2	0.2	33.8	127.1	11.9
31/08/2023 08:00	28.18	4.2	0.2	33.8	127.1	12
31/08/2023 09:00	28.48	4.3	0.2	34.1	127.2	12.1
31/08/2023 10:00	28.64	4.3	0.2	34.2	127.8	12.2
31/08/2023 11:00	29.13	4.3	0.2	34.8	127.7	12.4

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
01/09/2023 00:00	28.43	4.4	0.2	33.8	127.3	12.1
01/09/2023 01:00	28.08	4.4	0.2	33.4	128	11.9
01/09/2023 02:00	28.17	4.4	0.2	33.4	127.8	12
01/09/2023 03:00	28.05	4.4	0.2	33.3	127.8	11.9
01/09/2023 04:00	28.05	4.4	0.2	33.3	127.9	11.9
01/09/2023 05:00	27.84	4.3	0.2	33.3	128.2	11.8
01/09/2023 06:00	28.12	4.4	0.2	33.4	128.3	11.9
01/09/2023 07:00	28.05	4.4	0.2	33.2	128.6	11.9
01/09/2023 08:00	27.92	4.4	0.2	33.2	128.7	11.9
01/09/2023 09:00	28.21	4.4	0.2	33.5	127.9	12
01/09/2023 10:00	28.31	4.3	0.2	33.8	127.2	12
01/09/2023 11:00	29.02	4.3	0.2	34.7	126.6	12.3
01/09/2023 12:00	28.69	4.2	0.2	34.4	126.7	12.2
01/09/2023 13:00	28.8	4.2	0.2	34.6	126.5	12.2
01/09/2023 14:00	28.59	4.2	0.2	34.3	126	12.1
01/09/2023 15:00	28.2	4.2	0.2	33.8	126.1	12
01/09/2023 16:00	28.67	4.3	0.2	34.2	125.8	12.2
01/09/2023 17:00	27.99	4	0.2	34.1	125.8	11.9
01/09/2023 18:00	28.69	4.3	0.2	34.3	126	12.2
01/09/2023 19:00	28.12	4.3	0.2	33.6	125.6	11.9
01/09/2023 20:00	27.55	4.1	0.2	33.4	125.2	11.7
01/09/2023 21:00	28.04	4.3	0.2	33.5	125.9	11.9
01/09/2023 22:00	28.33	4.3	0.2	33.9	126.4	12
01/09/2023 23:00	28.51	4.1	0.2	34.4	126	12.1
02/09/2023 00:00	28.65	4.3	0.2	34.2	126.1	12.2
02/09/2023 01:00	27.92	4	0.2	33.8	125.4	11.9
02/09/2023 02:00	28.19	4.4	0.2	33.5	125.7	12
02/09/2023 03:00	27.78	4.1	0.2	33.6	125.8	11.8
02/09/2023 04:00	28.27	4.2	0.2	34	126.1	12
02/09/2023 05:00	28.44	4.2	0.2	34.1	126.5	12.1
02/09/2023 06:00	28.66	4.3	0.2	34.2	127.6	12.2
02/09/2023 07:00	28.49	4.3	0.2	34.1	127.7	12.1
02/09/2023 08:00	28.54	4.2	0.2	34.2	127.3	12.1
02/09/2023 09:00	28.96	4.2	0.2	34.7	127.1	12.3
02/09/2023 10:00	29.24	4.3	0.2	34.9	127.2	12.4
02/09/2023 11:00	29.5	4.2	0.2	35.5	126.9	12.5
02/09/2023 12:00	29.68	4.1	0.2	35.8	126.2	12.6
02/09/2023 13:00	29.5	4.1	0.2	35.6	125.6	12.5
02/09/2023 14:00	29.03	4.2	0.2	34.9	125.8	12.3
02/09/2023 15:00	28.66	3.9	0.2	34.9	125.3	12.2
02/09/2023 16:00	28.74	4.1	0.2	34.8	125.5	12.2
02/09/2023 17:00	28.59	4.1	0.2	34.6	125.5	12.1
02/09/2023 18:00	27.95	4	0.2	34	125.9	11.9
02/09/2023 19:00	28	4.2	0.2	33.7	126.4	11.9
02/09/2023 20:00	27.83	3.9	0.2	33.9	125.6	11.8
02/09/2023 21:00	28.87	4.3	0.2	34.4	125.8	12.3
02/09/2023 22:00	28.78	4.1	0.2	34.7	126.8	12.2
02/09/2023 23:00	28.82	4.2	0.2	34.7	126.9	12.2
03/09/2023 00:00	28.99	4.3	0.2	34.5	127.2	12.3
03/09/2023 01:00	28.46	4.1	0.2	34.5	126.3	12.1
03/09/2023 02:00	29.11	4.4	0.2	34.5	126.3	12.4
03/09/2023 03:00	28.85	4.3	0.2	34.4	127.1	12.2
03/09/2023 04:00	29.06	4.4	0.2	34.4	127.7	12.3
03/09/2023 05:00	29.42	4.7	0.2	34.4	128.8	12.5
03/09/2023 06:00	28.71	4.4	0.2	34.2	128.2	12.2
03/09/2023 07:00	28.64	4.4	0.2	34.1	127.6	12.2
03/09/2023 08:00	28.65	4.4	0.2	34.1	126.8	12.2
03/09/2023 09:00	28.64	4.2	0.2	34.4	126.8	12.2
03/09/2023 10:00	28.76	4.2	0.2	34.5	126.8	12.2
03/09/2023 11:00	28.91	4.3	0.2	34.6	126.5	12.3
03/09/2023 12:00	29.2	4.3	0.2	34.8	127.3	12.4

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
03/09/2023 13:00	29.3	4.4	0.2	34.8	126.5	12.4
03/09/2023 14:00	29.04	4.3	0.2	34.7	126.3	12.3
03/09/2023 15:00	28.99	4.4	0.2	34.5	126.7	12.3
03/09/2023 16:00	28.96	4.5	0.2	34.2	126.5	12.3
03/09/2023 17:00	28.43	4.3	0.2	34	126.6	12.1
03/09/2023 18:00	27.99	4.5	0.2	33.1	126.6	11.9
03/09/2023 19:00	27.74	4.4	0.2	32.9	126.3	11.8
03/09/2023 20:00	27.34	4.2	0.2	32.9	125.7	11.6
03/09/2023 21:00	28.05	4.5	0.2	33.1	125.8	11.9
03/09/2023 22:00	27.56	4.2	0.2	33.1	125.7	11.7
03/09/2023 23:00	27.23	4	0.2	33.1	125.7	11.6
04/09/2023 00:00	28.14	4.2	0.2	33.8	126.1	11.9
04/09/2023 01:00	28.61	4.4	0.2	33.9	126.4	12.1
04/09/2023 02:00	28.43	4.4	0.2	33.8	127.1	12.1
04/09/2023 03:00	27.9	4.2	0.2	33.5	126.5	11.8
04/09/2023 04:00	28.56	4.5	0.2	33.6	127.3	12.1
04/09/2023 05:00	28.27	4.3	0.2	33.7	127.5	12
04/09/2023 06:00	28.26	4.3	0.2	33.7	128	12
04/09/2023 07:00	28.51	4.4	0.2	33.8	127.6	12.1
04/09/2023 08:00	28.77	4.5	0.2	34	127.6	12.2
04/09/2023 09:00	28.35	4.4	0.2	33.7	127.4	12
04/09/2023 10:00	27.8	4	0.2	33.8	126.5	11.8
04/09/2023 11:00	27.79	3.9	0.2	34	125.6	11.8
04/09/2023 12:00	28.08	3.9	0.2	34.2	125.8	11.9
04/09/2023 13:00	28.65	4.1	0.2	34.6	125.3	12.2
04/09/2023 14:00	28.66	4.3	0.2	34.3	125.6	12.2
04/09/2023 15:00	28.47	4.1	0.2	34.4	125.5	12.1
04/09/2023 16:00	28.62	4.2	0.2	34.3	125.5	12.1
04/09/2023 17:00	28.29	4.2	0.2	34.1	125.3	12
04/09/2023 18:00	28.34	4.2	0.2	34.1	125.3	12
04/09/2023 19:00	27.88	4	0.2	33.8	125.3	11.8
04/09/2023 20:00	28.45	4.2	0.2	34.2	125.8	12.1
04/09/2023 21:00	28.51	4.3	0.2	34.1	125.5	12.1
04/09/2023 22:00	27.8	4.2	0.2	33.5	125.8	11.8
04/09/2023 23:00	28.25	4.3	0.2	33.7	126.1	12
05/09/2023 00:00	28.31	4.2	0.2	34.1	126	12
05/09/2023 01:00	28.43	4.2	0.2	34.2	126.1	12.1
05/09/2023 02:00	28.87	4.4	0.2	34.2	127.2	12.3
05/09/2023 03:00	28.46	4.1	0.2	34.4	126.5	12.1
05/09/2023 04:00	28.93	4.3	0.2	34.5	127	12.3
05/09/2023 05:00	29.34	4.5	0.2	34.6	127.3	12.5
05/09/2023 06:00	28.49	4.1	0.2	34.5	126.8	12.1
05/09/2023 07:00	28.87	4.2	0.2	34.8	126.2	12.3
05/09/2023 08:00	29.12	4.2	0.2	35	125.7	12.4
05/09/2023 09:00	28.81	4.3	0.2	34.4	125.9	12.2
05/09/2023 10:00	29.45	4.3	0.2	35.1	125.9	12.5
05/09/2023 11:00	29.87	4.3	0.2	35.6	125.5	12.7
05/09/2023 12:00	29.58	4.2	0.2	35.5	125.2	12.6
05/09/2023 13:00	29.92	4.2	0.2	36	125.9	12.7
05/09/2023 14:00	30.67	4.4	0.2	36.5	126.2	13
05/09/2023 15:00	30.31	4	0.2	36.8	125.3	12.9
05/09/2023 16:00	29.57	4.2	0.2	35.5	125.4	12.6
05/09/2023 17:00	28.95	4.1	0.2	34.9	125.6	12.3
05/09/2023 18:00	28.51	4.1	0.2	34.4	125.9	12.1
05/09/2023 19:00	28.06	4.2	0.2	33.6	125.5	11.9
05/09/2023 20:00	27.42	4.2	0.2	33	126.2	11.6
05/09/2023 21:00	27.98	4.2	0.2	33.6	126.6	11.9
05/09/2023 22:00	28.09	4.2	0.2	33.7	127.2	11.9
05/09/2023 23:00	28.61	4.5	0.2	33.8	127.4	12.1
06/09/2023 00:00	27.95	4.1	0.2	33.9	127.3	11.9
06/09/2023 01:00	28.06	4.2	0.2	33.8	127	11.9

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
06/09/2023 02:00	28.7	4.4	0.2	34	127.5	12.2
06/09/2023 03:00	28.83	4.5	0.2	34	128.1	12.2
06/09/2023 04:00	28.35	4.2	0.2	34.1	127.9	12
06/09/2023 05:00	28.84	4.4	0.2	34.2	127.8	12.2
06/09/2023 06:00	28.33	4.3	0.2	33.8	127.4	12
06/09/2023 07:00	27.63	4	0.2	33.6	126.9	11.7
06/09/2023 08:00	27.94	4	0.2	34	126.5	11.9
06/09/2023 09:00	28.77	4.3	0.2	34.4	127.4	12.2
06/09/2023 10:00	28.67	4.3	0.2	34.1	127.2	12.2
06/09/2023 11:00	29.05	4.5	0.2	34.4	127	12.3
06/09/2023 12:00	29.71	4.5	0.2	35	127.6	12.6
06/09/2023 13:00	30.92	4.4	0.2	36.7	127.3	13.1
06/09/2023 14:00	30.62	4.4	0.2	36.4	126.8	13
06/09/2023 15:00	29	4.2	0.2	34.9	126.6	12.3
06/09/2023 16:00	29.09	4.3	0.2	34.8	126.6	12.3
06/09/2023 17:00	28.56	4.1	0.2	34.4	126.3	12.1
06/09/2023 18:00	28.53	4.3	0.2	34.1	126.1	12.1
06/09/2023 19:00	28.7	4.3	0.2	34.3	126.8	12.2
06/09/2023 20:00	28.02	4	0.2	34.1	126.6	11.9
06/09/2023 21:00	28.26	4.3	0.2	33.8	126.9	12
06/09/2023 22:00	28.59	4.5	0.2	33.7	127.3	12.1
06/09/2023 23:00	27.7	4.1	0.2	33.4	127.2	11.8
07/09/2023 00:00	28.07	4.4	0.2	33.3	127.5	11.9
07/09/2023 01:00	27.53	4.1	0.2	33.3	127.8	11.7
07/09/2023 02:00	27.87	4.2	0.2	33.4	127.8	11.8
07/09/2023 03:00	28.23	4.5	0.2	33.3	128	12
07/09/2023 04:00	28.11	4.4	0.2	33.4	128.6	11.9
07/09/2023 05:00	28.06	4.3	0.2	33.5	128.6	11.9

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
11/09/2023 04:00	29.65	4.4	0.2	35.2	127.8	12.6
11/09/2023 05:00	30.01	4.6	0.2	35.2	126.3	12.7
11/09/2023 06:00	30.21	4.8	0.2	35	126.8	12.8
11/09/2023 07:00	30.58	4.8	0.2	35.5	127.7	13
11/09/2023 08:00	29.91	4.7	0.2	34.8	127.1	12.7
11/09/2023 09:00	30.31	4.7	0.2	35.3	127.1	12.9
11/09/2023 10:00	30.27	4.5	0.2	35.7	126.5	12.8
11/09/2023 11:00	30.02	4.4	0.2	35.6	126.5	12.7
11/09/2023 12:00	29.66	4.5	0.2	35	126.4	12.6
11/09/2023 13:00	29.56	4.4	0.2	35.2	126.6	12.5
11/09/2023 14:00	29.34	4.3	0.2	35.1	126.4	12.5
11/09/2023 15:00	29.3	4.3	0.2	35	126.2	12.4
11/09/2023 16:00	28.96	4.3	0.2	34.6	125.9	12.3
11/09/2023 17:00	28.77	4.3	0.2	34.3	125.6	12.2
11/09/2023 18:00	28.95	4.2	0.2	34.7	125.2	12.3
11/09/2023 19:00	29.13	4.4	0.2	34.5	125.5	12.4
11/09/2023 20:00	28.75	4.3	0.2	34.4	125.5	12.2
11/09/2023 21:00	28.62	4.2	0.2	34.4	125.5	12.1
11/09/2023 22:00	29.06	4.4	0.2	34.5	125.7	12.3
11/09/2023 23:00	29.37	4.4	0.2	34.9	126.1	12.5
12/09/2023 00:00	29.33	4.4	0.2	34.9	125.6	12.5
12/09/2023 01:00	28.78	4.2	0.2	34.7	125.4	12.2
12/09/2023 02:00	29.02	4.4	0.2	34.5	126	12.3
12/09/2023 03:00	29.01	4.3	0.2	34.5	125.9	12.3
12/09/2023 04:00	28.95	4.3	0.2	34.5	125.9	12.3
12/09/2023 05:00	29.06	4.3	0.2	34.6	125.7	12.3
12/09/2023 06:00	29.03	4.3	0.2	34.6	125.7	12.3
12/09/2023 07:00	29.12	4.4	0.2	34.6	126.4	12.4
12/09/2023 08:00	28.69	4.1	0.2	34.7	125.8	12.2
12/09/2023 09:00	29.05	4.2	0.2	34.9	125.4	12.3
12/09/2023 10:00	29.32	4.2	0.2	35.2	125.5	12.4
12/09/2023 11:00	29.74	4.2	0.2	35.7	125.5	12.6
12/09/2023 12:00	30.29	4.2	0.2	36.4	125.3	12.9
12/09/2023 13:00	31.27	4.4	0.2	37.1	125	13.3
12/09/2023 14:00	30.74	4.3	0.2	36.6	125	13
12/09/2023 15:00	29.92	4.4	0.2	35.5	125.3	12.7
12/09/2023 16:00	29.38	4.3	0.2	35.1	125.4	12.5
12/09/2023 17:00	29.18	4.2	0.2	35	125.4	12.4
12/09/2023 18:00	28.9	4.2	0.2	34.6	125	12.3
12/09/2023 19:00	29.32	4.4	0.2	34.9	125.6	12.4
12/09/2023 20:00	28.82	4.1	0.2	34.8	125.8	12.2
12/09/2023 21:00	29	4.4	0.2	34.4	126.4	12.3
12/09/2023 22:00	25.7	3.4	0.2	32.3	126.9	10.9
12/09/2023 23:00	26.02	3.5	0.2	32.5	126	11
13/09/2023 00:00	25.73	3.5	0.2	32.2	126.1	10.9
13/09/2023 01:00	26.33	3.8	0.2	32.4	124.8	11.2
13/09/2023 02:00	28.85	4.3	0.2	34.5	126	12.2
13/09/2023 03:00	28.4	4.4	0.2	33.8	126.6	12.1
13/09/2023 04:00	28.37	4.2	0.2	34.1	126	12
13/09/2023 05:00	28.66	4.2	0.2	34.5	126.5	12.2
13/09/2023 06:00	29.09	4.4	0.2	34.4	127.3	12.3
13/09/2023 07:00	28.34	4	0.2	34.4	126.9	12
13/09/2023 08:00	28.82	3.9	0.2	35.2	125.8	12.2
13/09/2023 09:00	29.35	4.1	0.2	35.4	125.5	12.5
13/09/2023 10:00	29.15	4	0.2	35.5	125.3	12.4
13/09/2023 11:00	29.71	4.2	0.2	35.7	125.5	12.6
13/09/2023 12:00	29.81	4.1	0.2	36	125.6	12.7
13/09/2023 13:00	29.59	4.2	0.2	35.5	125.7	12.6
13/09/2023 14:00	<Samp	<Samp	<Samp	<Samp	126	<Samp
13/09/2023 15:00	<Samp	<Samp	<Samp	<Samp	125.8	<Samp
13/09/2023 16:00	27.32	4.5	0.2	32.3	126	11.6

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
13/09/2023 17:00	26.8	4.3	0.2	32.1	125.9	11.4
13/09/2023 18:00	26.82	4.4	0.2	31.8	126.2	11.4
13/09/2023 19:00	26.73	4.2	0.2	32.1	126.3	11.3
13/09/2023 20:00	27.08	4.3	0.2	32.4	126.6	11.5
13/09/2023 21:00	26.56	4.2	0.2	31.8	126.5	11.3
13/09/2023 22:00	26.29	4.2	0.2	31.5	126.9	11.2
13/09/2023 23:00	26.25	4.3	0.2	31.4	127.9	11.1
14/09/2023 00:00	25.89	4.3	0.2	31	127.9	11
14/09/2023 01:00	25.73	4.1	0.2	31.1	127.2	10.9
14/09/2023 02:00	25.4	4.1	0.2	30.7	127	10.8
14/09/2023 03:00	26.04	4.2	0.2	31.2	127.5	11.1
14/09/2023 04:00	26.21	4.2	0.2	31.4	127.3	11.1
14/09/2023 05:00	26.71	4.5	0.2	31.5	127.6	11.3
14/09/2023 06:00	26.21	4.2	0.2	31.4	127.7	11.1
14/09/2023 07:00	26.3	4.2	0.2	31.6	126.7	11.2
14/09/2023 08:00	27.13	4.3	0.2	32.3	126.8	11.5
14/09/2023 09:00	27.74	4.3	0.2	33.1	127.1	11.8
14/09/2023 10:00	27.81	4.1	0.2	33.4	126.7	11.7
14/09/2023 11:00	27.49	4	0.2	33.3	126.4	11.7
14/09/2023 12:00	27.57	4.1	0.2	33.4	126.2	11.7
14/09/2023 13:00	28.08	4.3	0.2	33.6	125.8	11.9
14/09/2023 14:00	28.07	4.4	0.2	33.3	126.5	11.9
14/09/2023 15:00	26.38	4.1	0.2	31.9	125.5	11.2
14/09/2023 16:00	26.62	4.1	0.2	32.1	125.4	11.3
14/09/2023 17:00	26.08	4.2	0.2	31.3	124.3	11.1
14/09/2023 18:00	25.98	4.3	0.2	31.1	125	11
14/09/2023 19:00	25.8	4.2	0.2	31.1	126	10.9
14/09/2023 20:00	26.57	4.2	0.2	31.9	125.5	11.3
14/09/2023 21:00	26.09	4.1	0.2	31.5	125.2	11.1
14/09/2023 22:00	26.57	4.4	0.2	31.5	128.4	11.3
14/09/2023 23:00	26.33	4.4	0.2	31.3	128.7	11.2
15/09/2023 00:00	26.11	4.3	0.2	31.2	128.4	11.1
15/09/2023 01:00	26.16	4.4	0.2	31.1	128	11.1
15/09/2023 02:00	25.94	4.4	0.2	31.2	127.2	11
15/09/2023 03:00	26.59	4.4	0.2	31.6	127.1	11.3
15/09/2023 04:00	26.81	4.6	0.2	31.5	127.5	11.4
15/09/2023 05:00	26.19	4.3	0.2	31.3	127.1	11.1
15/09/2023 06:00	26.44	4.5	0.2	31.3	127.4	11.2
15/09/2023 07:00	26.11	4.3	0.2	31.2	127.2	11.1
15/09/2023 08:00	26.15	4.1	0.2	31.6	126.5	11.1
15/09/2023 09:00	27.06	4.4	0.2	32.1	126.2	11.5
15/09/2023 10:00	27.45	4.5	0.2	32.4	126.5	11.6
15/09/2023 11:00	26.26	3.9	0.2	32	125.6	11.1
15/09/2023 12:00	26.19	3.9	0.2	32	125.1	11.1
15/09/2023 13:00	26.85	4.3	0.2	32	125.6	11.4
15/09/2023 14:00	26.24	4	0.2	31.9	125.7	11.1
15/09/2023 15:00	26.37	4.2	0.2	31.7	125.6	11.2
15/09/2023 16:00	26.34	4.3	0.2	31.4	125.2	11.2
15/09/2023 17:00	26.06	4.1	0.2	31.4	124.9	11.1
15/09/2023 18:00	26.32	4.1	0.2	31.7	125	11.2
15/09/2023 19:00	25.95	4	0.2	31.6	125.2	11
15/09/2023 20:00	26.49	4.3	0.2	31.7	126	11.2
15/09/2023 21:00	26.34	4.2	0.2	31.7	126.3	11.2
15/09/2023 22:00	27.35	4.3	0.2	32.6	126.2	11.6
15/09/2023 23:00	27.6	4.5	0.2	32.6	126.9	11.7
16/09/2023 00:00	27.09	4.2	0.2	32.5	127.3	11.5
16/09/2023 01:00	26.8	4.2	0.2	32.1	127.5	11.4
16/09/2023 02:00	26.95	4.4	0.2	32	127.5	11.4
16/09/2023 03:00	26.83	4.4	0.2	31.9	127.3	11.4
16/09/2023 04:00	26.57	4.3	0.2	31.7	127.8	11.3
16/09/2023 05:00	26.4	4.2	0.2	31.6	127.4	11.2

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
16/09/2023 06:00	26.65	4.3	0.2	31.7	127.7	11.3
16/09/2023 07:00	26.78	4.3	0.2	31.9	127.7	11.4
16/09/2023 08:00	26.97	4.3	0.2	32.3	127.3	11.4
16/09/2023 09:00	26.93	4.1	0.2	32.6	127.1	11.4
16/09/2023 10:00	26.94	4.1	0.2	32.6	123.9	11.4
16/09/2023 11:00	27.34	4.2	0.2	32.8	126.9	11.6
16/09/2023 12:00	27.56	4.3	0.2	32.9	126.9	11.7
16/09/2023 13:00	27.24	4.3	0.2	32.5	126.5	11.6
16/09/2023 14:00	27.48	4.2	0.2	32.9	126.2	11.7
16/09/2023 15:00	27.34	4.1	0.2	33.1	126.3	11.6
16/09/2023 16:00	27.77	4.4	0.2	33	127	11.8
16/09/2023 17:00	27.34	4.2	0.2	32.9	126.6	11.6
16/09/2023 18:00	26.95	4.2	0.2	32.4	126.6	11.4
16/09/2023 19:00	26.65	4.3	0.2	31.8	125.7	11.3
16/09/2023 20:00	26.47	4.1	0.2	31.9	125.2	11.2
16/09/2023 21:00	26.79	4.3	0.2	32	125.5	11.4
16/09/2023 22:00	26.74	4.3	0.2	31.8	125.6	11.3
16/09/2023 23:00	26.56	4.2	0.2	31.8	125.4	11.3
17/09/2023 00:00	26.64	4.2	0.2	31.9	125.4	11.3
17/09/2023 01:00	27.29	4.3	0.2	32.6	125.8	11.6
17/09/2023 02:00	27.15	4.4	0.2	32.3	126.4	11.5
17/09/2023 03:00	27.22	4.6	0.2	31.9	127	11.6
17/09/2023 04:00	26.91	4.5	0.2	31.8	127.2	11.4
17/09/2023 05:00	27.12	4.6	0.2	31.9	127	11.5
17/09/2023 06:00	26.75	4.2	0.2	32.1	126.1	11.4
17/09/2023 07:00	27.05	4.4	0.2	32	126.1	11.5
17/09/2023 08:00	27.31	4.5	0.2	32.2	126.7	11.6
17/09/2023 09:00	27.52	4.4	0.2	32.6	127	11.7
17/09/2023 10:00	28.09	4.6	0.2	32.9	127.3	11.9
17/09/2023 11:00	28.08	4.6	0.2	32.8	126.9	11.9
17/09/2023 12:00	28.36	4.7	0.2	33	126.3	12
17/09/2023 13:00	27.99	4.6	0.2	32.9	126.4	11.9
17/09/2023 14:00	27.23	4.5	0.2	32.1	126.7	11.6
17/09/2023 15:00	27.19	4.3	0.2	32.4	126.3	11.5
17/09/2023 16:00	26.92	4.3	0.2	32.2	127	11.4
17/09/2023 17:00	27.1	4.5	0.2	32	127.4	11.5
17/09/2023 18:00	26.78	4.3	0.2	32	127.1	11.4
17/09/2023 19:00	26.73	4.3	0.2	31.9	126.6	11.3
17/09/2023 20:00	26.75	4.4	0.2	31.8	127	11.4
17/09/2023 21:00	26.52	4.4	0.2	31.6	126.9	11.3
17/09/2023 22:00	26.09	4.1	0.2	31.5	127	11.1
17/09/2023 23:00	26.48	4.2	0.2	31.7	126.7	11.2
18/09/2023 00:00	26.7	4.5	0.2	31.4	127	11.3
18/09/2023 01:00	26.47	4.3	0.2	31.6	126.6	11.2
18/09/2023 02:00	26.9	4.4	0.2	31.9	127.5	11.4
18/09/2023 03:00	26.68	4.4	0.2	31.6	128.3	11.3
18/09/2023 04:00	26.54	4.4	0.2	31.5	128.4	11.3
18/09/2023 05:00	26.66	4.4	0.2	31.6	128	11.3
18/09/2023 06:00	27.06	4.6	0.2	31.7	128.7	11.5
18/09/2023 07:00	27.18	4.7	0.2	31.6	129.3	11.5
18/09/2023 08:00	26.9	4.2	0.2	31.6	128.6	11.2
18/09/2023 09:00	26.63	4.3	0.2	31.8	128.3	11.3
18/09/2023 10:00	26.75	4.1	0.2	32.4	127.6	11.4
18/09/2023 11:00	26.74	4	0.2	32.6	126.3	11.3
18/09/2023 12:00	27.38	4.2	0.2	32.8	126.2	11.6
18/09/2023 13:00	26.98	4.1	0.2	32.7	126	11.5
18/09/2023 14:00	27.81	4.4	0.2	33	126.5	11.8
18/09/2023 15:00	27.13	4.3	0.2	32.5	127.1	11.5
18/09/2023 16:00	26.74	4.2	0.2	32.2	126.9	11.4
18/09/2023 17:00	26.83	4.1	0.2	32.4	126.6	11.4
18/09/2023 18:00	26.78	4.1	0.2	32.3	126.5	11.4

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
21/09/2023 08:00	26.31	4.2	0.2	31.6	127.7	11.2
21/09/2023 09:00	26.52	4	0.2	32.2	127.4	11.3
21/09/2023 10:00	27.32	4.1	0.2	33	127.7	11.6
21/09/2023 11:00	27.33	3.9	0.2	33.4	127.6	11.6
21/09/2023 12:00	27.82	4.1	0.2	33.5	128.1	11.8
21/09/2023 13:00	27.04	4.2	0.2	32.5	128.5	11.5
21/09/2023 14:00	26.88	4.2	0.2	32.2	127.1	11.4
21/09/2023 15:00	27.78	4.3	0.2	33.2	126.3	11.8
21/09/2023 16:00	26.78	4.1	0.2	32.3	123.1	11.4
21/09/2023 17:00	26.79	4.1	0.2	32.3	124.1	11.4
21/09/2023 18:00	26.9	4.2	0.2	32.4	124.6	11.4
21/09/2023 19:00	27.24	4.2	0.2	32.8	124.4	11.6
21/09/2023 20:00	27.02	4.3	0.2	32.3	127	11.5
21/09/2023 21:00	27.24	4.4	0.2	32.4	127.8	11.6
21/09/2023 22:00	27.14	4.1	0.2	32.8	127.3	11.5
21/09/2023 23:00	27.04	4.1	0.2	32.7	127.4	11.5
22/09/2023 00:00	26.79	4.2	0.2	32.3	127.4	11.4
22/09/2023 01:00	26.78	4.2	0.2	32.2	127.4	11.4
22/09/2023 02:00	26.9	4.3	0.2	32.1	128	11.4
22/09/2023 03:00	26.91	4.4	0.2	31.9	128.5	11.4
22/09/2023 04:00	26.88	4.4	0.2	31.9	128.1	11.4
22/09/2023 05:00	26.93	4.6	0.2	31.6	127.9	11.4
22/09/2023 06:00	27.17	4.7	0.2	31.6	128.7	11.5
22/09/2023 07:00	27.12	4.7	0.2	31.7	129	11.5
22/09/2023 08:00	27.39	4.6	0.2	32.1	128.6	11.6
22/09/2023 09:00	27.21	4.3	0.2	32.4	128.1	11.6
22/09/2023 10:00	27.93	4.3	0.2	33.3	128.4	11.9
22/09/2023 11:00	28.35	4.5	0.2	33.4	128.9	12
22/09/2023 12:00	28.4	4.4	0.2	33.7	128.5	12.1
22/09/2023 13:00	26.82	4.3	0.2	32	127.9	11.4
22/09/2023 14:00	26.45	4.2	0.2	31.8	127.2	11.2
22/09/2023 15:00	26.52	4.2	0.2	31.9	126.9	11.3
22/09/2023 16:00	26.5	4.2	0.2	31.8	127.2	11.2
22/09/2023 17:00	26.44	4.1	0.2	32	127.1	11.4
22/09/2023 18:00	26.86	4.3	0.2	32.1	127.5	11.4
22/09/2023 19:00	27.02	4.3	0.2	32.2	127.7	11.5
22/09/2023 20:00	26.68	4.2	0.2	32.1	127.5	11.3
22/09/2023 21:00	26.76	4.3	0.2	31.9	128.5	11.4
22/09/2023 22:00	26.47	4.3	0.2	31.6	128.3	11.2
22/09/2023 23:00	26.23	4.2	0.2	31.4	128.5	11.1
23/09/2023 00:00	26.17	4.3	0.2	31.2	128.3	11.1
23/09/2023 01:00	26.19	4.4	0.2	31.1	128.4	11.1
23/09/2023 02:00	25.8	4.2	0.2	31.1	128.5	11
23/09/2023 03:00	26.16	4.4	0.2	31.1	128.5	11.1
23/09/2023 04:00	25.87	4.2	0.2	31.1	128.6	11
23/09/2023 05:00	26.11	4.3	0.2	31.2	128.2	11.1
23/09/2023 06:00	26.33	4.5	0.2	31	128.6	11.2
23/09/2023 07:00	25.73	4.2	0.2	30.8	128.2	10.9
23/09/2023 08:00	26.47	4.4	0.2	31.4	128.4	11.2
23/09/2023 09:00	27.37	4.5	0.2	32.3	128.8	11.6
23/09/2023 10:00	27.51	4.3	0.2	32.8	128.7	11.7
23/09/2023 11:00	27.38	4.4	0.2	32.5	128.3	11.6
23/09/2023 12:00	27.65	4.2	0.2	33.1	127.3	11.7
23/09/2023 13:00	27.91	4.3	0.2	33.4	127.4	11.8
23/09/2023 14:00	27.68	4.3	0.2	33	127.1	11.7
23/09/2023 15:00	27.57	4.3	0.2	33	127.5	11.7
23/09/2023 16:00	27.31	4.2	0.2	32.7	128	11.6
23/09/2023 17:00	27.39	4.3	0.2	32.8	127.8	11.6
23/09/2023 18:00	26.56	4.2	0.2	31.9	126.9	11.3
23/09/2023 19:00	26.14	4	0.2	31.8	127.2	11.1
23/09/2023 20:00	26.58	4.3	0.2	31.7	128.3	11.3

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
23/09/2023 21:00	26.05	4	0.2	31.7	127.8	11.1
23/09/2023 22:00	26.3	4.1	0.2	31.7	127.9	11.2
23/09/2023 23:00	26.57	4.4	0.2	31.5	128.5	11.3
24/09/2023 00:00	26.51	4.5	0.2	31.3	128.9	11.3
24/09/2023 01:00	26.08	4.3	0.2	31.1	128.7	11.1
24/09/2023 02:00	25.89	4.2	0.2	31.2	127.6	11
24/09/2023 03:00	26.28	4.4	0.2	31.2	128.4	11.2
24/09/2023 04:00	26.03	4.4	0.2	30.9	128.6	11
24/09/2023 05:00	25.81	4.3	0.2	30.7	128.4	11
24/09/2023 06:00	25.77	4.4	0.2	30.7	128.5	10.9
24/09/2023 07:00	25.49	4.2	0.2	30.6	128.5	10.8
24/09/2023 08:00	25.6	4.2	0.2	30.7	128.5	10.9
24/09/2023 09:00	26.14	4.4	0.2	31	121.7	11.1
24/09/2023 10:00	25.68	4.2	0.2	30.9	125.8	10.9
24/09/2023 11:00	26.03	4.4	0.2	31	127.1	11
24/09/2023 12:00	25.72	4.2	0.2	30.9	127	10.9
24/09/2023 13:00	26.35	4.4	0.2	31.3	127.5	11.2
24/09/2023 14:00	25.89	4.3	0.2	30.9	127.7	11
24/09/2023 15:00	25.69	4.4	0.2	30.5	128.6	10.9
24/09/2023 16:00	25.02	4.1	0.2	30.3	128	10.6
24/09/2023 17:00	25.48	4.4	0.2	30.3	128.3	10.8
24/09/2023 18:00	25.24	4.2	0.2	30.4	127.5	10.7
24/09/2023 19:00	25.55	4.4	0.2	30.3	128.4	10.8
24/09/2023 20:00	25.22	4.2	0.2	30.3	128.5	10.7
24/09/2023 21:00	25.5	4.3	0.2	30.4	128.2	10.8
24/09/2023 22:00	25.14	4.2	0.2	30.3	128.2	10.7
24/09/2023 23:00	25.11	4.1	0.2	30.3	127.8	10.7
25/09/2023 00:00	25.36	4.3	0.2	30.3	128.3	10.8
25/09/2023 01:00	25.16	4.2	0.2	30.2	128.6	10.7
25/09/2023 02:00	25.13	4.3	0.2	29.9	128.6	10.7
25/09/2023 03:00	25.2	4.2	0.2	30.2	128.2	10.7
25/09/2023 04:00	24.85	3.9	0.2	30.3	127.9	10.5
25/09/2023 05:00	25.07	4.1	0.2	30.3	128	10.6
25/09/2023 06:00	25.31	4.1	0.2	30.2	128.1	10.7
25/09/2023 07:00	25.39	4.4	0.2	30.1	128.7	10.8
25/09/2023 08:00	25.53	4.4	0.2	30.3	129.1	10.8
25/09/2023 09:00	26.47	4.4	0.2	31.4	129.1	11.2
25/09/2023 10:00	26.7	4.3	0.2	31.8	128.7	11.3
25/09/2023 11:00	25.98	4.2	0.2	31.3	127.5	11
25/09/2023 12:00	26.35	4.3	0.2	31.4	125.5	11.2
25/09/2023 13:00	25.96	4.1	0.2	31.3	125	11
25/09/2023 14:00	25.25	4	0.2	30.6	127.5	10.7
25/09/2023 15:00	24.97	3.9	0.2	30.5	127.8	10.6
25/09/2023 16:00	25.43	4.2	0.2	30.5	128.2	10.8
25/09/2023 17:00	25.41	4.1	0.2	30.7	127.7	10.8
25/09/2023 18:00	25.28	4.1	0.2	30.6	127.9	10.7
25/09/2023 19:00	25.56	4.2	0.2	30.7	128.3	10.8
25/09/2023 20:00	25.58	4.2	0.2	30.7	128.3	10.9
25/09/2023 21:00	25.38	4.2	0.2	30.6	128.3	10.8
25/09/2023 22:00	25.33	4.2	0.2	30.4	128.4	10.8
25/09/2023 23:00	25.16	4.2	0.2	30.3	128.3	10.7
26/09/2023 00:00	24.89	4.1	0.2	30.1	128	10.6
26/09/2023 01:00	25.1	4.3	0.2	30	128.4	10.7
26/09/2023 02:00	25.14	4.3	0.2	30.1	128.3	10.7
26/09/2023 03:00	25.3	4.4	0.2	30.1	128.1	10.7
26/09/2023 04:00	24.87	4.1	0.2	30	128.5	10.6
26/09/2023 05:00	25.09	4.3	0.2	30	128.4	10.7
26/09/2023 06:00	24.82	4.1	0.2	30	128.2	10.5
26/09/2023 07:00	25.17	4.4	0.2	29.8	128.9	10.7
26/09/2023 08:00	25.81	4.4	0.2	30.7	126.8	11
26/09/2023 09:00	25.73	4.2	0.2	30.9	127.1	10.9

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
26/09/2023 10:00	25	4	0.2	30.3	127.7	10.6
26/09/2023 11:00	25.19	3.9	0.2	30.8	127.5	10.7
26/09/2023 12:00	25.91	4.2	0.2	31.1	127.8	11
26/09/2023 13:00	25.97	4.2	0.2	31.3	126.8	11
26/09/2023 14:00	25.86	4.1	0.2	31.2	126.6	11
26/09/2023 15:00	26.11	4.1	0.2	31.6	126.9	11.1
26/09/2023 16:00	26.19	4.1	0.2	31.6	126.9	11.1
26/09/2023 17:00	25.98	4.1	0.2	31.3	126.5	11
26/09/2023 18:00	25.61	4	0.2	31.1	125.9	10.9
26/09/2023 19:00	25.78	4.2	0.2	31	126.5	10.9
26/09/2023 20:00	25.82	4.2	0.2	31	125.8	11
26/09/2023 21:00	25.72	4	0.2	31.2	125.9	10.9
26/09/2023 22:00	25.83	4.2	0.2	31.1	126.3	11
26/09/2023 23:00	25.67	4	0.2	31.2	127.1	10.9
27/09/2023 00:00	26.66	4.3	0.2	31.8	127.6	11.3
27/09/2023 01:00	26.09	4.1	0.2	31.5	127.7	11.1
27/09/2023 02:00	26.16	4.2	0.2	31.4	127.7	11.1
27/09/2023 03:00	26.43	4.4	0.2	31.3	128.1	11.2
27/09/2023 04:00	26.01	4.2	0.2	31.2	128.4	11
27/09/2023 05:00	25.92	4.2	0.2	31.1	128.6	11
27/09/2023 06:00	26.04	4.2	0.2	31.2	128.2	11.1
27/09/2023 07:00	26.01	4.2	0.2	31.3	128.4	11
27/09/2023 08:00	25.93	4	0.2	31.4	127.5	11
27/09/2023 09:00	25.82	4.1	0.2	31.2	124.5	11
27/09/2023 10:00	25.18	3.8	0.2	30.9	126	10.7
27/09/2023 11:00	25.45	3.8	0.2	31.2	126.3	10.8
27/09/2023 12:00	26.64	4.3	0.2	31.9	126	11.3
27/09/2023 13:00	26.58	4.2	0.2	31.9	125.6	11.3
27/09/2023 14:00	26.38	4.2	0.2	31.7	125	11.2
27/09/2023 15:00	26.27	4.1	0.2	31.7	124.3	11.2
27/09/2023 16:00	26.08	4	0.2	31.7	124.2	11.1
27/09/2023 17:00	26.42	4.2	0.2	31.9	124.2	11.2
27/09/2023 18:00	26.19	3.9	0.2	32	124.2	11.1
27/09/2023 19:00	27.02	4.2	0.2	32.5	124.8	11.5
27/09/2023 20:00	26.96	4.2	0.2	32.5	124.9	11.4
27/09/2023 21:00	26.89	4.2	0.2	32.3	125.7	11.4
27/09/2023 22:00	26.97	4.2	0.2	32.3	125.3	11.4
27/09/2023 23:00	26.84	4.2	0.2	32.2	125.5	11.4
28/09/2023 00:00	26.54	4	0.2	32.2	125.3	11.3
28/09/2023 01:00	26.69	4.1	0.2	32.2	125.1	11.3
28/09/2023 02:00	27.15	4.4	0.2	32.2	125.8	11.5
28/09/2023 03:00	27.13	4.4	0.2	32.2	125.9	11.5
28/09/2023 04:00	27.02	4.3	0.2	32.3	125.4	11.5
28/09/2023 05:00	27.09	4.4	0.2	32.2	125.2	11.5
28/09/2023 06:00	26.99	4.4	0.2	32.1	125.3	11.5
28/09/2023 07:00	27.21	4.5	0.2	32.1	125.3	11.5
28/09/2023 08:00	26.64	4.1	0.2	32.3	125.2	11.3
28/09/2023 09:00	27.08	4.2	0.2	32.5	125.2	11.5
28/09/2023 10:00	27.31	4.3	0.2	32.6	125.1	11.6
28/09/2023 11:00	27.29	4.4	0.2	32.4	125.2	11.6
28/09/2023 12:00	27.07	4.2	0.2	32.6	125.3	11.5
28/09/2023 13:00	27.3	4.3	0.2	32.6	125.5	11.6
28/09/2023 14:00	27.51	4.4	0.2	32.7	126.2	11.7
28/09/2023 15:00	27.37	4.3	0.2	32.7	126.3	11.6
28/09/2023 16:00	26.98	4.2	0.2	32.4	125.8	11.5
28/09/2023 17:00	27.14	4.4	0.2	32.2	125.8	11.5
28/09/2023 18:00	26.85	4.2	0.2	32.2	126.1	11.4
28/09/2023 19:00	27.02	4.5	0.2	31.9	125.8	11.5
28/09/2023 20:00	27.25	4.4	0.2	32.4	123.1	11.6
28/09/2023 21:00	26.53	4.3	0.2	31.8	125.6	11.3
28/09/2023 22:00	26.15	4.1	0.2	31.6	127	11.1

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
01/10/2023 00:00	26.52	4.4	0.2	31.4	126.7	11.3
01/10/2023 01:00	26.09	4.2	0.2	31.3	126.1	11.1
01/10/2023 02:00	26.5	4.5	0.2	31.3	126.2	11.2
01/10/2023 03:00	26.77	4.7	0.2	31.1	126.8	11.4
01/10/2023 04:00	26.46	4.6	0.2	31.1	126.9	11.2
01/10/2023 05:00	26.46	4.6	0.2	31	126.7	11.2
01/10/2023 06:00	25.86	4.2	0.2	31	126.5	11
01/10/2023 07:00	25.86	4.3	0.2	30.9	126.8	11
01/10/2023 08:00	26.29	4.3	0.2	31.4	126.6	11.2
01/10/2023 09:00	27.11	4.4	0.2	32.1	129.1	11.5
01/10/2023 10:00	27.52	4.3	1.8	32.9	129.2	11.7
01/10/2023 11:00	27.03	4.5	0.2	32	129.2	11.5
01/10/2023 12:00	26.49	4.3	0.2	31.7	127.9	11.2
01/10/2023 13:00	26.73	4.4	0.2	31.7	127.1	11.3
01/10/2023 14:00	26.67	4.5	0.2	31.5	126.9	11.3
01/10/2023 15:00	26.01	4.4	0.2	30.9	126.8	11
01/10/2023 16:00	25.6	4.2	0.2	30.7	127.8	10.9
01/10/2023 17:00	26.45	4.5	0.2	31.3	128.4	11.2
01/10/2023 18:00	26.24	4.2	0.2	31.5	127.8	11.1
01/10/2023 19:00	26.43	4.3	0.2	31.6	128.2	11.2
01/10/2023 20:00	26.58	4.5	0.2	31.3	128.8	11.3
01/10/2023 21:00	26.63	4.4	0.2	31.5	128.9	11.3
01/10/2023 22:00	26.39	4.2	0.2	31.7	128.6	11.2
01/10/2023 23:00	26.62	4.4	0.2	31.6	128.1	11.3
02/10/2023 00:00	26.17	4.4	0.2	31.1	128	11.1
02/10/2023 01:00	25.59	4.2	0.2	30.8	127.8	10.9
02/10/2023 02:00	26.25	4.4	0.2	31.2	127.5	11.1
02/10/2023 03:00	27.12	4.5	0.2	31.9	124	11.5
02/10/2023 04:00	27	4.5	0.2	31.8	126.4	11.5
02/10/2023 05:00	26.82	4.4	0.2	31.8	128	11.4
02/10/2023 06:00	26.95	4.6	0.2	31.5	126.7	11.2
02/10/2023 07:00	26.48	4.3	0.2	31.5	126.7	11.2
02/10/2023 08:00	26.44	4.3	0.2	31.6	126.7	11.2
02/10/2023 09:00	25.96	4.2	0.2	31.3	126.8	11
02/10/2023 10:00	26.08	4.1	0.2	31.5	126.9	11.1
02/10/2023 11:00	26.18	4	0.2	31.9	127.8	11.1
02/10/2023 12:00	26.92	4.2	0.2	32.4	127.9	11.4
02/10/2023 13:00	27.27	4.4	0.2	32.4	128.4	11.6
02/10/2023 14:00	26.56	4.1	0.2	32.1	127.4	11.3
02/10/2023 15:00	27.2	4.3	0.2	32.4	127.6	11.5
02/10/2023 16:00	27.05	4	0.2	32.9	127.6	11.5
02/10/2023 17:00	27.63	4.3	0.2	33.1	128.5	11.7
02/10/2023 18:00	27.13	4.2	0.2	32.8	128.4	11.5
02/10/2023 19:00	26.72	4.2	0.2	32.2	127.7	11.3
02/10/2023 20:00	26.84	4.4	0.2	31.9	127.9	11.4
02/10/2023 21:00	26.29	4.3	0.2	31.4	127.6	11.2
02/10/2023 22:00	26.07	4.2	0.2	31.4	127.4	11.1
02/10/2023 23:00	25.81	4	0.2	31.4	127.3	11
03/10/2023 00:00	26.38	4.3	0.2	31.5	127.9	11.2
03/10/2023 01:00	26.63	4.5	0.2	31.4	128.4	11.3
03/10/2023 02:00	26.03	4.2	0.2	31.3	128.2	11
03/10/2023 03:00	25.82	4.2	0.2	31	128.1	11
03/10/2023 04:00	25.7	4.3	0.2	30.7	128.1	10.9
03/10/2023 05:00	25.3	4.2	0.2	30.4	128	10.7
03/10/2023 06:00	25.6	4.3	0.2	30.5	128.5	10.9
03/10/2023 07:00	25.57	4.3	0.2	30.5	128.4	10.9
03/10/2023 08:00	25.86	4.4	0.2	30.7	128.3	11
03/10/2023 09:00	26.51	4.4	0.2	31.5	127.9	11.3
03/10/2023 10:00	26.55	4.4	0.2	31.5	127.5	11.3
03/10/2023 11:00	26.96	4.4	0.2	32	127	11.4
03/10/2023 12:00	26.45	4.3	0.2	31.6	123.3	11.2

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
03/10/2023 13:00	25.83	4	0.2	31.4	121.2	11
03/10/2023 14:00	26.06	4.2	0.2	31.2	122.1	11.1
03/10/2023 15:00	25.67	4.1	0.2	31	124.6	10.9
03/10/2023 16:00	24.96	3.8	0.2	30.6	126.5	10.6
03/10/2023 17:00	25.7	4	0.2	31.2	126.4	10.9
03/10/2023 18:00	26.45	4.3	0.2	31.6	127.5	11.2
03/10/2023 19:00	25.88	4.2	0.2	31.1	127.5	11
03/10/2023 20:00	25.31	4	0.2	30.8	125.8	10.7
03/10/2023 21:00	25.43	4	0.2	31	125.3	10.8
03/10/2023 22:00	26.09	4.1	0.2	31.5	126.2	11.1
03/10/2023 23:00	26.3	4.1	0.2	31.7	127	11.2
04/10/2023 00:00	26.68	4.3	0.2	31.8	127.5	11.3
04/10/2023 01:00	26.43	4.1	0.2	32	127	11.2
04/10/2023 02:00	27	4.4	0.2	32	127.7	11.5
04/10/2023 03:00	26.77	4.4	0.2	31.9	127.7	11.4
04/10/2023 04:00	26.61	4.2	0.2	32	127.1	11.3
04/10/2023 05:00	26.73	4.3	0.2	32	127.2	11.3
04/10/2023 06:00	26.97	4.5	0.2	31.9	128.2	11.4
04/10/2023 07:00	27.16	4.6	0.2	31.8	128.7	11.5
04/10/2023 08:00	26.94	4.6	0.2	31.6	129	11.4
04/10/2023 09:00	26.99	4.5	0.2	31.9	129	11.5
04/10/2023 10:00	27.2	4.2	0.2	32.6	128.1	11.5
04/10/2023 11:00	26.58	4.1	0.2	32.1	127.9	11.3
04/10/2023 12:00	26.3	4	0.2	32	127.2	11.2
04/10/2023 13:00	26.58	4.3	0.2	31.8	127.8	11.3
04/10/2023 14:00	27.09	4.4	0.2	32.1	128.3	11.5
04/10/2023 15:00	26.64	4.3	0.2	31.9	127.7	11.3
04/10/2023 16:00	26.12	4.1	0.2	31.5	125.8	11.1
04/10/2023 17:00	25.95	4.1	0.2	31.4	126.2	11
04/10/2023 18:00	26.47	4.2	0.2	31.9	127.2	11.2
04/10/2023 19:00	26.26	4.2	0.2	31.6	127.6	11.1
04/10/2023 20:00	25.89	4.1	0.2	31.3	128	11
04/10/2023 21:00	26.05	4.3	0.2	31.2	126.8	11.1
04/10/2023 22:00	26	4.2	0.2	31.2	126.2	11
04/10/2023 23:00	26.01	4.2	0.2	31.2	126.3	11
05/10/2023 00:00	25.98	4.3	0.2	31.1	126.7	11
05/10/2023 01:00	26.02	4.2	0.2	31.2	127.9	11
05/10/2023 02:00	26.4	4.5	0.2	31.1	126.8	11.2
05/10/2023 03:00	25.91	4.2	0.2	31.1	126.5	11
05/10/2023 04:00	26	4.4	0.2	30.9	128	11
05/10/2023 05:00	25.55	4.1	0.2	30.9	127.4	10.8
05/10/2023 06:00	25.85	4.3	0.2	31	127.5	11
05/10/2023 07:00	26.05	4.4	0.2	31	127.9	11.1
05/10/2023 08:00	26.34	4.4	0.2	31.3	128	11.2
05/10/2023 09:00	26.48	4.4	0.2	31.5	128.4	11.2
05/10/2023 10:00	25.98	4.3	0.2	31	126.3	11
05/10/2023 11:00	26.21	4.1	0.2	31.6	126.3	11.1
05/10/2023 12:00	26.05	4.2	0.2	31.3	126.4	11.1
05/10/2023 13:00	25.71	4.1	0.2	31.1	124.4	10.9
05/10/2023 14:00	25.55	4	0.2	31	127.3	10.8
05/10/2023 15:00	25.66	4.3	0.2	30.6	127.7	10.9
05/10/2023 16:00	24.05	4	0.2	29.3	127.6	10.2
05/10/2023 17:00	24.64	3.9	0.2	30.1	126.5	10.5
05/10/2023 18:00	25.65	4.3	0.2	30.7	127	10.9
05/10/2023 19:00	26.01	4.2	0.2	31.2	127.2	11
05/10/2023 20:00	26.08	4.2	0.2	31.4	126.8	11.1
05/10/2023 21:00	26.37	4.3	0.2	31.6	126.6	11.2
05/10/2023 22:00	26.02	4.3	0.2	31.2	126.7	11
05/10/2023 23:00	25.23	4.1	0.2	30.5	124.1	10.7
06/10/2023 00:00	25.68	4.2	0.2	30.8	126.6	10.9
06/10/2023 01:00	25.77	4.1	0.2	31.1	126.5	10.9

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
06/10/2023 02:00	26.24	4.3	0.2	31.4	126.3	11.1
06/10/2023 03:00	25.91	4.1	0.2	31.3	126.2	11.1
06/10/2023 04:00	26.35	4.3	0.2	31.5	126	11.2
06/10/2023 05:00	26.65	4.5	0.2	31.5	126.4	11.3
06/10/2023 06:00	26.75	4.6	0.2	31.4	127.2	11.4
06/10/2023 07:00	26.16	4.4	0.2	31.1	127.2	11.1
06/10/2023 08:00	26.35	4.2	0.2	31.6	126.7	11.2
06/10/2023 09:00	26.18	4	0.2	31.8	126	11.1
06/10/2023 10:00	26.06	4	0.2	31.8	126.2	11.1
06/10/2023 11:00	27.04	4.4	0.2	32.2	126.5	11.5
06/10/2023 12:00	27.18	4.4	0.2	32.2	126.4	11.5
06/10/2023 13:00	26.93	4.3	0.2	32.1	125.9	11.4
06/10/2023 14:00	26.98	4.4	0.2	32	126.3	11.5
06/10/2023 15:00	26.51	4.2	0.2	31.7	126.3	11.3
06/10/2023 16:00	26.43	4.2	0.2	31.7	126.3	11.2
06/10/2023 17:00	26.33	4.3	0.2	31.4	126.9	11.2
06/10/2023 18:00	26.35	4.4	0.2	31.3	127	11.2
06/10/2023 19:00	26.34	4.4	0.2	31.2	126.9	11.2
06/10/2023 20:00	26.18	4.3	0.2	31.2	127.1	11.1
06/10/2023 21:00	26.03	4.2	0.2	31.2	127.2	11
06/10/2023 22:00	25.82	4.2	0.2	31	127.7	11
06/10/2023 23:00	26.07	4.5	0.2	30.8	127.9	11.1
07/10/2023 00:00	25.82	4.3	0.2	30.9	127.7	11
07/10/2023 01:00	25.34	4	0.2	30.7	126.8	10.8
07/10/2023 02:00	26	4.3	0.2	31	127.1	11
07/10/2023 03:00	26.61	4.6	0.2	31.3	127.7	11.3
07/10/2023 04:00	26.72	4.6	0.2	31.3	127.8	11.3
07/10/2023 05:00	26.21	4.3	0.2	31.3	127.7	11.1
07/10/2023 06:00	26.51	4.6	0.2	31.1	128.3	11.3
07/10/2023 07:00	26.41	4.6	0.2	31	128.6	11.2
07/10/2023 08:00	26.85	4.5	0.2	31.6	127.9	11.4
07/10/2023 09:00	27.2	4.5	0.2	32.1	128.2	11.5
07/10/2023 10:00	27.19	4.4	0.2	32.3	128	11.5
07/10/2023 11:00	27.5	4.4	0.2	32.7	126.9	11.7
07/10/2023 12:00	28.01	4.6	0.2	32.8	128.2	11.9
07/10/2023 13:00	26.78	4.3	0.2	32	127.1	11.4
07/10/2023 14:00	27.29	4.5	0.2	32.2	127.1	11.6
07/10/2023 15:00	26.87	4.3	0.2	32	127	11.4
07/10/2023 16:00	26.91	4.4	0.2	31.9	127.4	11.4
07/10/2023 17:00	26.99	4.5	0.2	31.9	127	11.5
07/10/2023 18:00	26.81	4.3	0.2	31.9	126.3	11.4
07/10/2023 19:00	27.39	4.4	0.2	32.6	126.6	11.6
07/10/2023 20:00	27.21	4.4	0.2	32.4	126.8	11.5
07/10/2023 21:00	27.4	4.6	0.2	32.2	128	11.6
07/10/2023 22:00	27.61	4.7	0.2	32.2	128.4	11.7
07/10/2023 23:00	27.16	4.5	0.2	32.1	128.3	11.5
08/10/2023 00:00	26.82	4.4	0.2	31.9	128.1	11.4
08/10/2023 01:00	27.15	4.7	0.2	31.6	128.2	11.5
08/10/2023 02:00	26.72	4.5	0.2	31.6	128.4	11.3
08/10/2023 03:00	27.11	4.7	0.2	31.5	128.3	11.5
08/10/2023 04:00	26.9	4.5	0.2	31.8	128.1	11.4
08/10/2023 05:00	27.02	4.6	0.2	31.6	128.8	11.5
08/10/2023 06:00	26.75	4.5	0.2	31.6	128.9	11.4
08/10/2023 07:00	26.37	4.3	0.2	31.5	128.3	11.2
08/10/2023 08:00	26.65	4.2	0.2	31.9	127.5	11.3
08/10/2023 09:00	27.47	4.4	0.2	32.6	127.9	11.7
08/10/2023 10:00	27.21	4.3	0.2	32.5	127.5	11.5
08/10/2023 11:00	27.77	4.6	0.2	32.5	127.9	11.8
08/10/2023 12:00	28.53	4.6	0.2	33.4	127.6	12.1
08/10/2023 13:00	27.99	4.5	0.2	33	127.8	11.9
08/10/2023 14:00	27.45	4.5	0.2	32.3	127.5	11.7

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
11/10/2023 04:00	26.89	4.5	0.2	31.8	127.8	11.4
11/10/2023 05:00	27.26	4.8	0.2	31.6	126.2	11.6
11/10/2023 06:00	27.02	4.7	0.2	31.5	126.4	11.5
11/10/2023 07:00	26.87	4.6	0.2	31.6	126.5	11.4
11/10/2023 08:00	27.18	4.6	0.2	31.9	126.3	11.5
11/10/2023 09:00	28.21	4.8	0.2	32.7	129.1	12
11/10/2023 10:00	28.47	4.7	0.2	33.3	126.9	12.1
11/10/2023 11:00	28.67	4.7	0.2	33.4	126.7	12.2
11/10/2023 12:00	28.37	4.6	0.2	33.4	128	12
11/10/2023 13:00	29.04	5	0.2	33.3	126.2	12.3
11/10/2023 14:00	29.38	5.1	0.2	33.4	129.7	12.5
11/10/2023 15:00	28.9	4.9	0.2	33.2	126.4	12.3
11/10/2023 16:00	27.56	4.8	0.2	31.9	126.2	11.7
11/10/2023 17:00	27.47	4.7	0.2	31.9	126.3	11.7
11/10/2023 18:00	27.51	4.8	0.2	31.9	129.1	11.7
11/10/2023 19:00	27.61	4.7	0.2	32.1	129.3	11.7
11/10/2023 20:00	27.86	5	0.2	31.8	129.9	11.8
11/10/2023 21:00	27.57	4.9	0.2	31.7	129.9	11.7
11/10/2023 22:00	27.57	5	0.2	31.6	129.4	11.7
11/10/2023 23:00	27.42	4.8	0.2	31.7	128.8	11.6
12/10/2023 00:00	27.56	5	0.2	31.5	129.4	11.7
12/10/2023 01:00	27.45	5.1	0.2	31.3	129.3	11.7
12/10/2023 02:00	27.26	5.1	0.2	31.1	129.8	11.6
12/10/2023 03:00	27.86	5	0.2	31.8	129.2	11.8
12/10/2023 04:00	27.75	5.1	0.2	31.6	129.6	11.8
12/10/2023 05:00	27.39	4.9	0.2	31.5	121.4	11.6
12/10/2023 06:00	28.89	5	0.2	33	124.6	12.3
12/10/2023 07:00	28.82	5	0.2	33	127.9	12.2
12/10/2023 08:00	28.33	5	0.2	32.4	128.9	12
12/10/2023 09:00	27.7	4.9	0.2	31.9	129	11.8
12/10/2023 10:00	<Samp	<Samp	<Samp	<Samp	<Samp	<Samp
12/10/2023 11:00	28.9	5	0.2	30.7	126.9	11.4
12/10/2023 12:00	27.44	4.6	0.2	32.1	126.7	11.6
12/10/2023 13:00	28.76	5	0.2	32.9	129	12.2
12/10/2023 14:00	28.51	5.2	0.2	32.2	129.5	12.1
12/10/2023 15:00	25.99	4.6	0.2	30.4	123.5	11
12/10/2023 16:00	27.57	4.6	0.2	32.2	126.2	11.7
12/10/2023 17:00	27.34	4.6	0.2	32	126.5	11.6
12/10/2023 18:00	27.74	4.7	0.2	32.4	126.3	11.8
12/10/2023 19:00	28.1	4.8	0.2	32.5	129.1	11.9
12/10/2023 20:00	28.07	4.9	0.2	32.3	129.6	11.9
12/10/2023 21:00	27.8	4.9	0.2	32	129.2	11.8
12/10/2023 22:00	27.33	4.6	0.2	32	126.7	11.6
12/10/2023 23:00	27.73	4.9	0.2	31.8	129.5	11.8
13/10/2023 00:00	27.42	4.8	0.2	31.7	129.3	11.6
13/10/2023 01:00	27.47	5	0.2	31.5	129.6	11.7
13/10/2023 02:00	27.24	4.8	0.2	31.6	129.2	11.6
13/10/2023 03:00	27.54	5	0.2	31.5	129.5	11.7
13/10/2023 04:00	27.53	5	0.2	31.4	129.5	11.7
13/10/2023 05:00	27.35	4.8	0.2	31.6	129	11.6
13/10/2023 06:00	27.85	5.1	0.2	31.6	129.4	11.8
13/10/2023 07:00	27.41	4.9	0.2	31.5	129.3	11.6
13/10/2023 08:00	27.36	4.6	0.2	32.1	126.5	11.6
13/10/2023 09:00	28.12	4.8	0.2	32.5	126.3	11.9
13/10/2023 10:00	28.76	4.8	0.2	33.2	126.6	12.2
13/10/2023 11:00	29.63	4.9	0.2	34.1	126.4	12.6
13/10/2023 12:00	30.01	5	0.2	34.4	129.2	12.7
13/10/2023 13:00	30.2	5	0.2	34.6	129.1	12.8
13/10/2023 14:00	28.87	4.8	0.2	33.4	129.2	12.3
13/10/2023 15:00	28.07	4.8	0.2	32.5	126.5	11.9
13/10/2023 16:00	27.69	4.8	0.2	32.1	126.2	11.8

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
13/10/2023 17:00	27.49	4.9	0.2	31.6	126.9	11.7
13/10/2023 18:00	27.83	5	0.2	31.9	129.7	11.8
13/10/2023 19:00	27.28	4.6	0.2	32	129.6	11.6
13/10/2023 20:00	27.31	4.9	0.2	31.3	129.9	11.6
13/10/2023 21:00	27.31	5	0.2	31.2	130.4	11.6
13/10/2023 22:00	27.15	4.9	0.2	31.3	130.1	11.5
13/10/2023 23:00	27.3	4.9	0.2	31.4	129.8	11.6
14/10/2023 00:00	27.33	5	0.2	31.3	129.3	11.6
14/10/2023 01:00	27.07	4.7	0.2	31.6	128.5	11.5
14/10/2023 02:00	27.93	5	0.2	32	129.1	11.9
14/10/2023 03:00	27.99	4.9	0.2	32.1	129	11.9
14/10/2023 04:00	28.02	4.8	0.2	32.5	129	11.9
14/10/2023 05:00	28.25	5	0.2	32.3	129.3	12
14/10/2023 06:00	28.33	5.1	0.2	32.2	129.5	12
14/10/2023 07:00	28.65	5.1	0.2	32.5	129.2	12.2
14/10/2023 08:00	29.25	5.1	0.2	33.3	129.3	12.4
14/10/2023 09:00	29.61	4.9	0.2	34	129	12.6
14/10/2023 10:00	30.55	4.9	0.2	35.1	129	13
14/10/2023 11:00	30.89	4.8	0.2	35.8	128.8	13.1
14/10/2023 12:00	31.2	4.6	0.2	36.5	128.7	13.2
14/10/2023 13:00	30.91	4.6	0.2	36.3	128.5	13.1
14/10/2023 14:00	30.92	4.9	0.2	35.7	128.8	13.1
14/10/2023 15:00	30.61	4.9	0.2	35.3	129.2	13
14/10/2023 16:00	28.99	4.8	0.2	33.7	129.1	12.3
14/10/2023 17:00	29.55	4.8	0.2	34.3	129.4	12.5
14/10/2023 18:00	28.79	4.6	0.2	33.7	129.3	12.2
14/10/2023 19:00	28.61	4.7	0.2	33.3	129.2	12.1
14/10/2023 20:00	28.43	4.8	0.2	33	128.9	12.1
14/10/2023 21:00	28.17	4.7	0.2	32.8	129.5	12
14/10/2023 22:00	28.24	4.7	0.2	32.8	129.4	12
14/10/2023 23:00	28.48	4.7	0.2	33.1	129.4	12.1
15/10/2023 00:00	28.19	4.7	0.2	32.9	129	12
15/10/2023 01:00	28.07	5	0.2	32	129.7	11.9
15/10/2023 02:00	28.13	4.8	0.2	32.5	129.4	11.9
15/10/2023 03:00	29.1	5.1	0.2	33.1	129.4	12.4
15/10/2023 04:00	28.97	5	0.2	33.1	129.3	12.3
15/10/2023 05:00	29.05	5.1	0.2	33.1	129.5	12.3
15/10/2023 06:00	28.64	4.9	0.2	32.9	129.3	12.2
15/10/2023 07:00	28.56	5	0.2	32.6	129.5	12.1
15/10/2023 08:00	28.14	4.5	0.2	33.1	128.9	11.9
15/10/2023 09:00	28.3	3.9	0.2	34.5	127.2	12
15/10/2023 10:00	28.95	3.9	0.2	35.3	126.9	12.3
15/10/2023 11:00	29.58	4.1	0.2	35.7	126.9	12.6
15/10/2023 12:00	29.51	3.9	0.2	36.1	126.9	12.5
15/10/2023 13:00	29.16	3.7	0.2	36.2	126.4	12.4
15/10/2023 14:00	29.1	4.2	0.2	35	126.8	12.4
15/10/2023 15:00	27.79	4.3	0.2	33.1	126.6	11.8
15/10/2023 16:00	27.99	4.3	0.2	33.5	126.8	11.9
15/10/2023 17:00	27.68	4.3	0.2	33.1	123.2	11.7
15/10/2023 18:00	28.16	4.4	0.2	33.5	124.3	12
15/10/2023 19:00	28.37	4.5	0.2	33.5	127	12
15/10/2023 20:00	28.36	4.4	0.2	33.7	127.7	12
15/10/2023 21:00	28.33	4.6	0.2	33.3	128.4	12
15/10/2023 22:00	28.25	4.5	0.2	33.4	127.6	12
15/10/2023 23:00	28.21	4.4	0.2	33.4	128.2	12
16/10/2023 00:00	27.86	4.6	0.2	32.6	128.8	11.8
16/10/2023 01:00	28.01	4.8	0.2	32.5	129.1	11.9
16/10/2023 02:00	28.01	5	0.2	32.1	129.2	11.9
16/10/2023 03:00	28.13	5.1	0.2	32	128.3	11.9
16/10/2023 04:00	27.68	4.8	0.2	32.1	126.6	11.7
16/10/2023 05:00	27.96	5	0.2	32	126.9	11.9

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
16/10/2023 06:00	27.65	4.8	0.2	32	126.4	11.7
16/10/2023 07:00	27.76	4.9	0.2	32	126.9	11.8
16/10/2023 08:00	28.26	4.9	0.2	32.5	126.9	12
16/10/2023 09:00	28.95	4.8	0.2	33.6	128.1	12.3
16/10/2023 10:00	29.15	4.6	0.2	34.2	128	12.4
16/10/2023 11:00	29.5	4.6	0.2	34.5	128	12.5
16/10/2023 12:00	29.4	4.6	0.2	34.4	128	12.5
16/10/2023 13:00	28.51	4.7	0.2	33.3	126.1	12.1
16/10/2023 14:00	28.31	4.5	0.2	33.4	127.2	12
16/10/2023 15:00	28.45	4.7	0.2	33.1	127.9	12.1
16/10/2023 16:00	27.45	4.7	0.2	32	122.1	11.7
16/10/2023 17:00	27.46	4.6	0.2	32.3	125.1	11.7
16/10/2023 18:00	27.36	4.8	0.2	31.8	126.1	11.6
16/10/2023 19:00	27.12	4.7	0.2	31.7	129	11.5
16/10/2023 20:00	27.06	4.5	0.2	32	126.7	11.5
16/10/2023 21:00	26.59	4.2	0.2	31.9	126.3	11.3
16/10/2023 22:00	26.39	4.2	0.2	31.8	127.4	11.2
16/10/2023 23:00	26.95	4.4	0.2	32	127.4	11.4
17/10/2023 00:00	27	4.5	0.2	31.8	127.9	11.5
17/10/2023 01:00	26.66	4.4	0.2	31.6	127.9	11.3
17/10/2023 02:00	26.81	4.5	0.2	31.7	127.8	11.4
17/10/2023 03:00	26.61	4.4	0.2	31.7	126.1	11.3
17/10/2023 04:00	27.28	4.6	0.2	31.9	126.3	11.6
17/10/2023 05:00	27.38	4.5	0.2	32.3	128	11.6
17/10/2023 06:00	27.4	4.5	0.2	32.3	126.3	11.6
17/10/2023 07:00	27.34	4.3	0.2	32.6	127.9	11.6
17/10/2023 08:00	27.85	4.4	0.2	33.1	127.4	11.8
17/10/2023 09:00	28.01	4.3	0.2	33.4	127	11.9
17/10/2023 10:00	28.12	4.3	0.2	33.6	127.2	11.9
17/10/2023 11:00	28.09	4.1	0.2	33.9	127.2	11.9
17/10/2023 12:00	29.42	4.6	0.2	34.4	127.6	12.5
17/10/2023 13:00	30.54	4.9	0.2	35.2	128.2	13
17/10/2023 14:00	29.52	4.8	0.2	34.3	126.8	12.5
17/10/2023 15:00	27.8	4.7	0.2	32.4	126.9	11.8
17/10/2023 16:00	27.56	4.5	0.2	32.5	126.6	11.7
17/10/2023 17:00	27.84	4.6	0.2	32.6	126.7	11.8
17/10/2023 18:00	27.24	4.5	0.2	32.1	127.8	11.6
17/10/2023 19:00	27.34	4.6	0.2	32.1	127.8	11.6
17/10/2023 20:00	28.09	4.5	0.2	33.1	127.9	11.9
17/10/2023 21:00	28.82	4.8	0.2	33.4	126.3	12.2
17/10/2023 22:00	28.12	4.5	0.2	33.1	126.5	11.9
17/10/2023 23:00	27.67	4.7	0.2	32.3	126.9	11.7
18/10/2023 00:00	27.94	4.5	0.2	32.9	126.6	11.9
18/10/2023 01:00	28.15	4.7	0.2	32.8	129.3	11.9
18/10/2023 02:00	27.45	4.6	0.2	32.2	129.2	11.7
18/10/2023 03:00	27.37	4.7	0.2	32	129.1	11.6
18/10/2023 04:00	27.96	4.8	0.2	32.3	129.6	11.9
18/10/2023 05:00	27.74	4.7	0.2	32.4	129.3	11.8
18/10/2023 06:00	26.07	5	0.2	32.2	129.9	11.9
18/10/2023 07:00	27.49	4.6	0.2	32.2	129.8	11.7
18/10/2023 08:00	27.19	4.5	0.2	32	129.3	11.5
18/10/2023 09:00	27.31	4.5	0.2	32.3	129.3	11.6
18/10/2023 10:00	26.71	4.6	0.2	33.6	129.3	12.2
18/10/2023 11:00	28.4	4.6	0.2	33.3	126.5	12.1
18/10/2023 12:00	27.84	4.6	0.2	32.6	122.6	11.8
18/10/2023 13:00	27.55	4.6	0.2	32.3	125.7	11.7
18/10/2023 14:00	27.44	4.7	0.2	32	126.3	11.6
18/10/2023 15:00	27.36	4.7	0.2	32	126.9	11.6
18/10/2023 16:00	27.02	4.5	0.2	31.9	129	11.5
18/10/2023 17:00	27.42	4.5	0.2	32.4	128	11.6
18/10/2023 18:00	27.48	4.4	0.2	32.5	127.6	11.7

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
21/10/2023 08:00	29.09	4.8	0.2	33.8	128.4	12.3
21/10/2023 09:00	28.88	4.6	0.2	33.9	128.7	12.3
21/10/2023 10:00	29.5	4.7	0.2	34.5	128.4	12.5
21/10/2023 11:00	29.56	4.6	0.2	34.6	128.2	12.5
21/10/2023 12:00	29.58	4.6	0.2	34.7	128.2	12.6
21/10/2023 13:00	29.31	4.7	0.2	34.1	128.2	12.4
21/10/2023 14:00	29.2	4.7	0.2	33.9	127.9	12.4
21/10/2023 15:00	29.53	4.8	0.2	34.2	127.6	12.5
21/10/2023 16:00	29	4.7	0.2	33.9	127.4	12.3
21/10/2023 17:00	28.57	4.6	0.2	33.5	127.5	12.1
21/10/2023 18:00	28.49	4.7	0.2	33.2	128.4	12.1
21/10/2023 19:00	28.8	4.8	0.2	33.4	128	12.2
21/10/2023 20:00	28.17	4.6	0.2	33	127	12
21/10/2023 21:00	27.94	4.6	0.2	32.7	127.6	11.9
21/10/2023 22:00	27.86	4.5	0.2	32.8	127.6	11.8
21/10/2023 23:00	28.26	4.8	0.2	32.8	128.1	12
22/10/2023 00:00	28.08	4.6	0.2	32.8	128.1	11.9
22/10/2023 01:00	28.01	4.6	0.2	32.8	127.7	11.9
22/10/2023 02:00	28.3	4.8	0.2	32.8	128.2	12
22/10/2023 03:00	27.98	4.6	0.2	32.7	127.4	11.9
22/10/2023 04:00	28.22	4.7	0.2	32.8	127.8	12
22/10/2023 05:00	28.25	4.7	0.2	33	127.3	12
22/10/2023 06:00	28.02	4.5	0.2	33	127.4	11.9
22/10/2023 07:00	28.05	4.6	0.2	32.8	127.6	11.9
22/10/2023 08:00	28.48	4.8	0.2	32.9	128.4	12.1
22/10/2023 09:00	28.71	4.9	0.2	33.1	128.5	12.2
22/10/2023 10:00	28.78	4.7	0.2	33.6	128.9	12.2
22/10/2023 11:00	29.2	4.6	0.2	34.2	128.6	12.4
22/10/2023 12:00	28.8	4.4	0.2	34.2	128.1	12.2
22/10/2023 13:00	28.82	4.9	0.2	33.2	128.3	12.2
22/10/2023 14:00	27.99	4.9	0.2	32.3	124.5	11.9
22/10/2023 15:00	27.21	4.7	0.2	31.8	124.8	11.6
22/10/2023 16:00	27.35	4.7	0.2	31.8	128	11.6
22/10/2023 17:00	27.07	4.6	0.2	31.7	128.2	11.5
22/10/2023 18:00	28.21	4.9	0.2	32.5	125.5	12
22/10/2023 19:00	28.67	4.9	0.2	33	127.2	12.2
22/10/2023 20:00	28.26	4.8	0.2	32.7	127.3	12
22/10/2023 21:00	28.38	4.9	0.2	32.8	127.7	12
22/10/2023 22:00	27.81	4.6	0.2	32.6	128.6	11.8
22/10/2023 23:00	28.1	4.9	0.2	32.4	128.7	11.9
23/10/2023 00:00	27.89	4.7	0.2	32.6	127.9	11.8
23/10/2023 01:00	28.03	4.8	0.2	32.5	128.2	11.9
23/10/2023 02:00	28.08	4.8	0.2	32.4	128.7	11.9
23/10/2023 03:00	27.76	4.6	0.2	32.5	128	11.8
23/10/2023 04:00	27.97	4.7	0.2	32.5	127.7	11.9
23/10/2023 05:00	28.19	4.9	0.2	32.5	128.1	12
23/10/2023 06:00	28.54	5	0.2	32.7	128.7	12.1
23/10/2023 07:00	28.55	5	0.2	32.7	129.3	12.1
23/10/2023 08:00	28.99	4.9	0.2	33.3	129	12.3
23/10/2023 09:00	29.5	4.7	0.2	34.4	128.1	12.5
23/10/2023 10:00	29.58	4.6	0.2	34.7	128.2	12.6
23/10/2023 11:00	29.75	4.5	0.2	35.2	128.3	12.6
23/10/2023 12:00	30.31	4.8	0.2	35.2	129.2	12.9
23/10/2023 13:00	30.02	4.9	0.2	34.6	129.9	12.7
23/10/2023 14:00	29.53	4.6	0.2	34.6	129.5	12.5
23/10/2023 15:00	29.28	4.8	0.2	33.9	128	12.4
23/10/2023 16:00	28.87	4.8	0.2	33.5	128	12.3
23/10/2023 17:00	28.46	4.8	0.2	33.1	127.8	12.1
23/10/2023 18:00	28.52	5	0.2	32.6	128.3	12.1
23/10/2023 19:00	28.31	4.8	0.2	32.8	128.7	12
23/10/2023 20:00	27.85	4.5	0.2	32.9	129	11.8

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
23/10/2023 21:00	27.71	4.5	0.2	32.7	128.8	11.8
23/10/2023 22:00	27.88	4.7	0.2	32.5	128.7	11.8
23/10/2023 23:00	27.54	4.5	0.2	32.4	128.7	11.7
24/10/2023 00:00	27.64	4.4	0.2	32.7	128.1	11.7
24/10/2023 01:00	28.1	4.7	0.2	32.7	128.6	11.9
24/10/2023 02:00	28.03	4.7	0.2	32.7	128.9	11.9
24/10/2023 03:00	27.91	4.7	0.2	32.5	128.9	11.8
24/10/2023 04:00	27.48	4.5	0.2	32.5	128.4	11.7
24/10/2023 05:00	28.12	4.7	0.2	32.7	128.5	11.9
24/10/2023 06:00	28	4.4	0.2	33.2	128	11.9
24/10/2023 07:00	28.49	4.5	0.2	33.6	129	12.1
24/10/2023 08:00	29.28	4.6	0.2	34.4	128.9	12.4
24/10/2023 09:00	29.64	4.4	0.2	35.2	127.8	12.6
24/10/2023 10:00	30.02	4.4	0.2	35.6	127.5	12.7
24/10/2023 11:00	30.3	4.5	0.2	35.7	127.8	12.9
24/10/2023 12:00	29.81	4.2	0.2	35.8	127.2	12.8
24/10/2023 13:00	30.06	4.4	0.2	35.8	127.4	12.8
24/10/2023 14:00	30.23	4.3	0.2	36.1	127.5	12.8
24/10/2023 15:00	30.38	4.3	0.2	36.2	127.4	12.9
24/10/2023 16:00	30.16	4.4	0.2	35.8	127.5	12.8
24/10/2023 17:00	29.46	4.4	0.2	35.1	127.2	12.5
24/10/2023 18:00	28.51	4.3	0.2	33.9	127.4	12.1
24/10/2023 19:00	28.76	4.5	0.2	34	127.4	12.2
24/10/2023 20:00	28.53	4.6	0.2	33.5	128.5	12.1
24/10/2023 21:00	28.33	4.6	0.2	33.2	129.4	12
24/10/2023 22:00	27.86	4.4	0.2	33	128.9	11.9
24/10/2023 23:00	28.14	4.7	0.2	32.8	129	11.8
25/10/2023 00:00	28.37	4.7	0.2	33	128.3	12
25/10/2023 01:00	28.45	4.5	0.2	33.5	127.2	12.1
25/10/2023 02:00	29.44	4.7	0.2	34.3	127.9	12.5
25/10/2023 03:00	29.38	4.7	0.2	34.2	127.8	12.5
25/10/2023 04:00	29.22	4.7	0.2	34	128.1	12.4
25/10/2023 05:00	29.1	4.8	0.2	33.7	128.4	12.4
25/10/2023 06:00	28.51	4.6	0.2	33.3	128.4	12.1
25/10/2023 07:00	28.5	4.6	0.2	33.4	127.9	12.1
25/10/2023 08:00	28.59	4.7	0.2	33.3	128.6	12.1
25/10/2023 09:00	29.32	4.6	0.2	34.3	129.1	12.4
25/10/2023 10:00	29.49	4.3	0.2	35.2	128	12.5
25/10/2023 11:00	29.66	4.4	0.2	35.1	127.8	12.6
25/10/2023 12:00	29.71	4.4	0.2	35.3	127.5	12.6
25/10/2023 13:00	29.9	4.6	0.2	35	127.4	12.7
25/10/2023 14:00	29.76	4.6	0.2	34.9	128.2	12.6
25/10/2023 15:00	29.22	4.4	0.2	34.7	127.9	12.4
25/10/2023 16:00	29.33	4.6	0.2	34.4	128.4	12.4
25/10/2023 17:00	28.63	4.5	0.2	33.8	128.8	12.2
25/10/2023 18:00	28.99	4.5	0.2	34.1	128.3	12.3
25/10/2023 19:00	28.21	4.4	0.2	33.4	128.4	12
25/10/2023 20:00	27.95	4.4	0.2	33.1	128.7	11.9
25/10/2023 21:00	28.09	4.6	0.2	32.9	129.2	11.9
25/10/2023 22:00	27.61	4.6	0.2	32.5	128.8	11.7
25/10/2023 23:00	27.7	4.6	0.2	32.6	128.5	11.8
26/10/2023 00:00	27.86	4.6	0.2	32.6	129	11.8
26/10/2023 01:00	27.77	4.6	0.2	32.5	129.4	11.8
26/10/2023 02:00	27.57	4.5	0.2	32.5	128.9	11.7
26/10/2023 03:00	27.8	4.6	0.2	32.5	128.2	11.8
26/10/2023 04:00	27.53	4.6	0.2	32.2	128.4	11.7
26/10/2023 05:00	27.51	4.6	0.2	32.2	128.1	11.7
26/10/2023 06:00	27.57	4.7	0.2	32.2	128.2	11.7
26/10/2023 07:00	27.56	4.7	0.2	32.1	128.5	11.7
26/10/2023 08:00	28.15	4.4	0.2	33.4	127.9	11.9
26/10/2023 09:00	29.08	4.5	0.2	34.3	128.5	12.3

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
26/10/2023 10:00	29.27	4.7	0.2	34.2	129	12.4
26/10/2023 11:00	29.24	4.5	0.2	34.5	129.1	12.4
26/10/2023 12:00	29.38	4.6	0.2	34.5	128.8	12.5
26/10/2023 13:00	29.87	4.8	0.2	34.5	128.8	12.7
26/10/2023 14:00	29.29	4.6	0.2	34.3	128.4	12.4
26/10/2023 15:00	29.2	4.6	0.2	34.2	128.4	12.4
26/10/2023 16:00	28.92	4.7	0.2	33.8	127.8	12.3
26/10/2023 17:00	28.52	4.5	0.2	33.7	127.6	12.1
26/10/2023 18:00	28.64	4.6	0.2	33.7	127.8	12.2
26/10/2023 19:00	28.7	4.6	0.2	33.7	128.2	12.2
26/10/2023 20:00	28.77	4.6	0.2	33.6	128.6	12.2
26/10/2023 21:00	28.68	4.7	0.2	33.5	128.9	12.2
26/10/2023 22:00	28.52	4.6	0.2	33.4	128.2	12.1
26/10/2023 23:00	28.02	4.4	0.2	33.2	128.9	11.9
27/10/2023 00:00	28.22	4.7	0.2	33	129.5	12
27/10/2023 01:00	27.97	4.6	0.2	32.8	129.5	11.9
27/10/2023 02:00	27.8	4.5	0.2	32.8	129.2	11.8
27/10/2023 03:00	27.82	4.7	0.2	32.4	129.7	11.8
27/10/2023 04:00	28.28	4.9	0.2	32.5	129.1	12
27/10/2023 05:00	27.91	4.5	0.2	32.8	129.2	11.8
27/10/2023 06:00	28.09	4.7	0.2	32.7	128.9	11.9
27/10/2023 07:00	27.93	4.7	0.2	32.5	128.5	11.9
27/10/2023 08:00	28.15	4.8	0.2	32.6	129.4	11.9
27/10/2023 09:00	28.88	4.6	0.2	33.8	128.6	12.3
27/10/2023 10:00	28.82	4.4	0.2	34.1	128.1	12.2
27/10/2023 11:00	29	4.4	0.2	34.4	128	12.3
27/10/2023 12:00	29.52	4.4	0.2	35	128	12.5
27/10/2023 13:00	28.91	4.4	0.2	34.4	127.4	12.3
27/10/2023 14:00	29.71	4.6	0.2	34.7	127.8	12.6
27/10/2023 15:00	28.71	4.5	0.2	33.8	127.7	12.2
27/10/2023 16:00	28.66	4.5	0.2	33.8	127.8	12.2
27/10/2023 17:00	28.6	4.6	0.2	33.5	127.8	12.1
27/10/2023 18:00	28.15	4.5	0.2	33.1	128	11.9
27/10/2023 19:00	28.2	4.6	0.2	33.1	128.1	12
27/10/2023 20:00	27.93	4.6	0.2	32.8	129	11.9
27/10/2023 21:00	28.11	4.6	0.2	33	129.2	11.9
27/10/2023 22:00	27.94	4.6	0.2	32.8	128.9	11.9
27/10/2023 23:00	27.7	4.5	0.2	32.8	128.8	11.8
28/10/2023 00:00	27.86	4.5	0.2	32.8	129	11.8
28/10/2023 01:00	27.66	4.5	0.2	32.7	128.6	11.7
28/10/2023 02:00	27.79	4.6	0.2	32.6	128.4	11.8
28/10/2023 03:00	28.16	4.8	0.2	32.7	129.2	12
28/10/2023 04:00	27.71	4.6	0.2	32.6	128.8	11.8
28/10/2023 05:00	27.58	4.5	0.2	32.6	128.2	11.7
28/10/2023 06:00	28.05	4.8	0.2	32.5	128.9	11.9
28/10/2023 07:00	27.41	4.5	0.2	32.4	128.6	11.6
28/10/2023 08:00	28.02	4.6	0.2	32.8	129.5	11.9
28/10/2023 09:00	28.5	4.7	0.2	33.2	129.1	12.1
28/10/2023 10:00	29.03	4.8	0.2	33.7	129.3	12.3
28/10/2023 11:00	28.65	4.5	0.2	33.7	128.7	12.2
28/10/2023 12:00	28.79	4.7	0.2	33.6	128.1	12.2
28/10/2023 13:00	28.26	4.4	0.2	33.5	127.6	12
28/10/2023 14:00	29.1	4.6	0.2	34.1	127.8	12.4
28/10/2023 15:00	27.54	4.5	0.2	32.5	128.1	11.7
28/10/2023 16:00	27.77	4.5	0.2	32.8	128.7	11.8
28/10/2023 17:00	27.99	4.4	0.2	33.2	127.8	11.9
28/10/2023 18:00	28.26	4.6	0.2	33.2	127.9	12
28/10/2023 19:00	28.3	4.5	0.2	33.3	128.4	12
28/10/2023 20:00	27.6	4.3	0.2	32.9	128.3	11.7
28/10/2023 21:00	27.58	4.5	0.2	32.6	127.9	11.7
28/10/2023 22:00	28.37	4.6	0.2	33.3	127.9	12

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
31/10/2023 12:00	29.62	4.4	0.2	35.2	127.1	12.6
31/10/2023 13:00	29.73	4.5	0.2	35.1	126.9	12.6
31/10/2023 14:00	29.27	4.5	0.2	34.6	127.7	12.4
31/10/2023 15:00	29.18	4.4	0.2	34.6	127.4	12.4
31/10/2023 16:00	28.97	4.5	0.2	34.2	127.4	12.3
31/10/2023 17:00	28.71	4.4	0.2	34.1	127.9	12.2
31/10/2023 18:00	28.41	4.5	0.2	33.5	126.2	12.1
31/10/2023 19:00	28.43	4.5	0.2	33.5	126.3	12.1
31/10/2023 20:00	28.55	4.5	0.2	33.6	126.3	12.1
31/10/2023 21:00	28.54	4.5	0.2	33.8	127.8	12.1
31/10/2023 22:00	28.35	4.3	0.2	33.9	127.7	12
31/10/2023 23:00	28.7	4.6	0.2	33.7	127.7	12.2
Minimum	24.05	3.7	0.2	29.3	121.2	10.2
MinDate	05/10/2023 16:00	15/10/2023 13:00	01/10/2023 00:00	05/10/2023 16:00	03/10/2023 13:00	05/10/2023 16:00
Maximum	31.2	5.2	1.8	36.5	130.4	13.2
MaxDate	14/10/2023 12:00	12/10/2023 14:00	01/10/2023 10:00	14/10/2023 12:00	13/10/2023 21:00	14/10/2023 12:00
Avg	27.75	4.6	0.2	32.6	128.1	11.8
Num	743	743	743	743	744	743
Data[%]	99.7	99.7	99.7	99.7	99.9	99.7
STD	1.1	0.2	0.1	1.1	1.1	0.5

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
01/11/2023 00:00	28.78	4.6	0.2	33.8	127.5	12.2
01/11/2023 01:00	29.06	4.6	0.2	34	127.6	12.3
01/11/2023 02:00	29.15	4.6	0.2	34.1	127.3	12.4
01/11/2023 03:00	29.15	4.6	0.2	34.1	127.8	12.4
01/11/2023 04:00	28.83	4.6	0.2	33.9	127.5	12.2
01/11/2023 05:00	29.21	4.8	0.2	33.9	127.7	12.4
01/11/2023 06:00	29.31	4.7	0.2	34.2	127.2	12.4
01/11/2023 07:00	29.25	4.6	0.2	34.3	127.3	12.4
01/11/2023 08:00	29.33	4.4	0.2	34.8	127	12.4
01/11/2023 09:00	29.99	4.5	0.2	35.3	126.4	12.7
01/11/2023 10:00	30.19	4.6	0.2	35.4	127.5	12.8
01/11/2023 11:00	30.06	4.5	0.2	35.5	127.7	12.8
01/11/2023 12:00	30.2	4.6	0.2	35.4	128.3	12.8
01/11/2023 13:00	30.36	4.7	0.2	35.4	128.1	12.9
01/11/2023 14:00	30.03	4.5	0.2	35.5	127.5	12.7
01/11/2023 15:00	29.88	4.4	0.2	35.5	126.8	12.7
01/11/2023 16:00	29.77	4.4	0.2	35.2	127.3	12.6
01/11/2023 17:00	28.8	4.5	0.2	34	128.4	12.2
01/11/2023 18:00	28.49	4.3	0.2	34	128.6	12.1
01/11/2023 19:00	29.08	4.6	0.2	34.2	128.5	12.3
01/11/2023 20:00	28.59	4.5	0.2	33.8	128.3	12.1
01/11/2023 21:00	28.29	4.4	0.2	33.6	127.9	12
01/11/2023 22:00	28.78	4.7	0.2	33.6	128.2	12.2
01/11/2023 23:00	28.85	4.5	0.2	34	127.7	12.2
02/11/2023 00:00	29.09	4.6	0.2	34.2	127.4	12.3
02/11/2023 01:00	29.08	4.6	0.2	34.2	127.2	12.3
02/11/2023 02:00	29.32	4.6	0.2	34.3	127.4	12.4
02/11/2023 03:00	29.02	4.5	0.2	34.3	127.4	12.3
02/11/2023 04:00	29.35	4.6	0.2	34.4	127.3	12.5
02/11/2023 05:00	29.28	4.5	0.2	34.5	126.8	12.4
02/11/2023 06:00	29.62	4.6	0.2	34.7	127.6	12.6
02/11/2023 07:00	29.96	4.8	0.2	34.7	128.7	12.7
02/11/2023 08:00	30.71	4.8	0.2	35.6	126.6	13
02/11/2023 09:00	30.79	4.7	0.2	35.9	127.9	13.1
02/11/2023 10:00	31.26	4.5	0.2	36.8	127.1	13.3
02/11/2023 11:00	31.19	4.4	0.2	37	127.1	13.2
02/11/2023 12:00	31.26	4.4	0.2	37	127.4	13.3
02/11/2023 13:00	30.97	4.4	0.2	36.8	127.9	13.1
02/11/2023 14:00	31.3	4.6	0.2	36.6	128.3	13.3
02/11/2023 15:00	31.21	4.6	0.2	36.5	128.7	13.2
02/11/2023 16:00	30.18	4.6	0.2	35.5	128.1	12.8
02/11/2023 17:00	30.01	4.7	0.2	35	127.4	12.7
02/11/2023 18:00	29.35	4.5	0.2	34.6	127.7	12.5
02/11/2023 19:00	29.2	4.6	0.2	34.3	128.4	12.4
02/11/2023 20:00	28.96	4.5	0.2	34.2	128.9	12.3
02/11/2023 21:00	28.78	4.6	0.2	33.7	129.3	12.2
02/11/2023 22:00	28.4	4.5	0.2	33.5	129	12.1
02/11/2023 23:00	28.48	4.6	0.2	33.4	128.8	12.1
03/11/2023 00:00	28.36	4.6	0.2	33.3	129	12
03/11/2023 01:00	28.2	4.5	0.2	33.2	128.8	12
03/11/2023 02:00	28.57	4.7	0.2	33.3	129.1	12.1
03/11/2023 03:00	28.55	4.7	0.2	33.3	129.2	12.1
03/11/2023 04:00	28.57	4.7	0.2	33.2	128.7	12.1
03/11/2023 05:00	28.49	4.5	0.2	33.6	128	12.1
03/11/2023 06:00	28.43	4.6	0.2	33.3	128	12.1
03/11/2023 07:00	28.18	4.5	0.2	33.3	127.9	12
03/11/2023 08:00	28.66	4.5	0.2	33.8	128.2	12.2
03/11/2023 09:00	29.76	4.5	0.2	35.1	127.7	12.6
03/11/2023 10:00	30.54	4.6	0.2	35.8	127.6	13
03/11/2023 11:00	30.6	4.4	0.2	36.2	127.8	13
03/11/2023 12:00	30.59	4.4	0.2	36.3	128.1	13

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
03/11/2023 13:00	30.5	4.5	0.2	36	128.1	12.9
03/11/2023 14:00	29.58	4.5	0.2	34.8	128.2	12.6
03/11/2023 15:00	28.7	4.3	0.2	34.2	127.4	12.2
03/11/2023 16:00	28.66	4.5	0.2	33.8	127	12.2
03/11/2023 17:00	28.67	4.5	0.2	33.9	127.2	12.2
03/11/2023 18:00	28.53	4.4	0.2	33.9	127.2	12.1
03/11/2023 19:00	28.6	4.5	0.2	33.8	128	12.1
03/11/2023 20:00	28.58	4.6	0.2	33.5	122.7	12.1
03/11/2023 21:00	27.84	4.3	0.2	33.2	126.8	11.8
03/11/2023 22:00	27.98	4.5	0.2	33	128.2	11.9
03/11/2023 23:00	28.32	4.7	0.2	33	126.6	12
04/11/2023 00:00	28.23	4.4	0.2	33.4	128.3	12
04/11/2023 01:00	28.49	4.5	0.2	33.6	128.3	12.1
04/11/2023 02:00	28.15	4.5	0.2	33.2	128.3	11.9
04/11/2023 03:00	28.58	4.7	0.2	33.2	128.4	12.1
04/11/2023 04:00	28.08	4.5	0.2	33.1	128.8	11.9
04/11/2023 05:00	28.1	4.7	0.2	32.8	128.8	11.9
04/11/2023 06:00	27.78	4.4	0.2	32.9	128.5	11.8
04/11/2023 07:00	28.22	4.7	0.2	32.9	128.8	12
04/11/2023 08:00	28.46	4.8	0.2	33	129.5	12.1
04/11/2023 09:00	28.77	4.6	0.2	33.8	129.7	12.2
04/11/2023 10:00	29.04	4.3	0.2	34.6	129	12.3
04/11/2023 11:00	29.41	4.5	0.2	34.6	129	12.5
04/11/2023 12:00	28.15	4.6	0.2	32.9	125.3	11.9
04/11/2023 13:00	28.44	4.6	0.2	33.3	123.7	12.1
04/11/2023 14:00	28.72	4.6	0.2	33.7	127	12.2
04/11/2023 15:00	28.86	4.6	0.2	33.8	128.1	12.2
04/11/2023 16:00	28.06	4.4	0.2	33.3	127.3	11.9
04/11/2023 17:00	28.47	4.5	0.2	33.5	127.6	12.1
04/11/2023 18:00	28.64	4.6	0.2	33.6	127.7	12.2
04/11/2023 19:00	28.33	4.5	0.2	33.5	128.1	12
04/11/2023 20:00	28.25	4.5	0.2	33.4	128.2	12
04/11/2023 21:00	28.27	4.5	0.2	33.3	128.2	12
04/11/2023 22:00	28.1	4.5	0.2	33.1	127.9	11.9
04/11/2023 23:00	28.19	4.7	0.2	32.8	128.3	12
05/11/2023 00:00	27.97	4.7	0.2	32.6	128.3	11.9
05/11/2023 01:00	27.56	4.5	0.2	32.4	128.3	11.7
05/11/2023 02:00	27.73	4.7	0.2	32.4	128.7	11.8
05/11/2023 03:00	27.65	4.6	0.2	32.4	128.7	11.7
05/11/2023 04:00	27.46	4.5	0.2	32.3	128	11.7
05/11/2023 05:00	27.57	4.6	0.2	32.4	127.9	11.7
05/11/2023 06:00	27.88	4.7	0.2	32.5	128.3	11.8
05/11/2023 07:00	27.95	4.6	0.2	32.7	128.4	11.9
05/11/2023 08:00	27.48	4.3	0.2	32.8	128.1	11.7
05/11/2023 09:00	27.39	4.3	0.2	32.7	128.3	11.6
05/11/2023 10:00	27.85	4.2	0.2	33.5	128.2	11.9
05/11/2023 11:00	28.76	4.3	0.2	34.3	128.8	12.2
05/11/2023 12:00	29.72	4.6	0.2	34.8	129	12.6
05/11/2023 13:00	28.43	4.5	0.2	33.5	128.6	12.1
05/11/2023 14:00	28.74	4.7	0.2	33.6	128.2	12.2
05/11/2023 15:00	29.27	4.6	0.2	34.3	128.2	12.4
05/11/2023 16:00	29.53	4.7	0.2	34.3	127.6	12.5
05/11/2023 17:00	29.33	4.8	0.2	34	127.9	12.4
05/11/2023 18:00	28.87	4.7	0.2	33.7	128	12.3
05/11/2023 19:00	28.52	4.5	0.2	33.7	127.9	12.1
05/11/2023 20:00	28.62	4.7	0.2	33.4	128.2	12.1
05/11/2023 21:00	28.19	4.4	0.2	33.4	127.7	12
05/11/2023 22:00	28.9	4.7	0.2	33.6	127.9	12.3
05/11/2023 23:00	29.06	4.7	0.2	33.8	128.2	12.3
06/11/2023 00:00	28.62	4.5	0.2	33.8	127.8	12.1
06/11/2023 01:00	28.87	4.8	0.2	33.5	127.9	12.3

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
06/11/2023 02:00	28.59	4.7	0.2	33.3	128.2	12.1
06/11/2023 03:00	28.48	4.6	0.2	33.3	128.2	12.1
06/11/2023 04:00	28.49	4.6	0.2	33.4	128.1	12.1
06/11/2023 05:00	28.68	4.7	0.2	33.3	128.1	12.2

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
08/11/2023 15:00	28.23	4.5	0.2	33.4	121.7	12
08/11/2023 16:00	28.56	4.5	0.2	33.7	125.2	12.1
08/11/2023 17:00	28.09	4.3	0.2	33.6	127.2	11.9
08/11/2023 18:00	28.21	4.5	0.2	33.2	127.7	12
08/11/2023 19:00	28.16	4.5	0.2	33.2	128.3	12
08/11/2023 20:00	28.15	4.5	0.2	33.1	128.9	11.9
08/11/2023 21:00	28.22	4.6	0.2	33.1	128.9	12
08/11/2023 22:00	27.96	4.5	0.2	33	129	11.9
08/11/2023 23:00	28.07	4.6	0.2	32.9	128.7	11.9
09/11/2023 00:00	28.15	4.6	0.2	33	128.9	11.9
09/11/2023 01:00	27.79	4.4	0.2	33	128.7	11.8
09/11/2023 02:00	28.14	4.6	0.2	33	128.9	11.9
09/11/2023 03:00	28.4	4.8	0.2	33	128.7	12.1
09/11/2023 04:00	28.02	4.6	0.2	32.9	128.5	11.9
09/11/2023 05:00	27.8	4.6	0.2	32.6	127.8	11.8
09/11/2023 06:00	27.97	4.6	0.2	32.8	127.9	11.9
09/11/2023 07:00	27.92	4.6	0.2	32.8	128.4	11.8
09/11/2023 08:00	27.66	4.3	0.2	33.1	127.8	11.7
09/11/2023 09:00	27.75	4.2	0.2	33.3	128	11.8
09/11/2023 10:00	Maintain	Maintain	Maintain	Maintain	128.1	Maintain
09/11/2023 11:00	Maintain	Maintain	Maintain	Maintain	127.9	Maintain
09/11/2023 12:00	Maintain	Maintain	Maintain	Maintain	127.5	Maintain
09/11/2023 13:00	Maintain	Maintain	Maintain	Maintain	127.2	Maintain
09/11/2023 14:00	Maintain	Maintain	Maintain	Maintain	127.9	Maintain
09/11/2023 15:00	<Samp	<Samp	<Samp	<Samp	127.6	<Samp
09/11/2023 16:00	26.93	4.4	0.2	32	127.8	11.4
09/11/2023 17:00	27.72	4.5	0.2	32.7	128.6	11.8
09/11/2023 18:00	27.91	4.4	0.2	33.1	128.1	11.8
09/11/2023 19:00	28.21	4.5	0.2	33.4	128.7	12
09/11/2023 20:00	28.4	4.5	0.2	33.4	128.9	12.1
09/11/2023 21:00	28.49	4.5	0.2	33.6	128.5	12.1
09/11/2023 22:00	28.47	4.5	0.2	33.5	128.3	12.1
09/11/2023 23:00	28.53	4.6	0.2	33.4	128.6	12.1
10/11/2023 00:00	28.42	4.5	0.2	33.5	128.7	12.1
10/11/2023 01:00	28.66	4.6	0.2	33.6	128.6	12.2
10/11/2023 02:00	28.73	4.8	0.2	33.4	128.3	12.2
10/11/2023 03:00	28.15	4.4	0.2	33.3	127.7	11.9
10/11/2023 04:00	28.56	4.7	0.2	33.2	128	12.1
10/11/2023 05:00	28.3	4.6	0.2	33.2	128	12
10/11/2023 06:00	28.54	4.6	0.2	33.4	128	12.1
10/11/2023 07:00	28.49	4.5	0.2	33.6	128.1	12.1
10/11/2023 08:00	28.75	4.5	0.2	34	128.4	12.2
10/11/2023 09:00	29.22	4.5	0.2	34.4	128.4	12.4
10/11/2023 10:00	29.59	4.5	0.2	34.9	128.2	12.6
10/11/2023 11:00	29.46	4.5	0.2	34.7	128.1	12.5
10/11/2023 12:00	28.82	4.3	0.2	34.3	127.9	12.2
10/11/2023 13:00	29.03	4.5	0.2	34.3	127.3	12.3
10/11/2023 14:00	27.79	4.5	0.2	32.8	123.3	11.8
10/11/2023 15:00	28.08	4.4	0.2	33.3	125.9	11.9
10/11/2023 16:00	28.77	4.5	0.2	34	127.9	12.2
10/11/2023 17:00	27.78	4.3	0.2	33.1	127.7	11.8
10/11/2023 18:00	27.77	4.4	0.2	32.9	128.2	11.8
10/11/2023 19:00	27.86	4.4	0.2	33	128.3	11.8
10/11/2023 20:00	28.31	4.6	0.2	33.3	128.5	12
10/11/2023 21:00	28.04	4.5	0.2	33.2	127.9	11.9
10/11/2023 22:00	28.16	4.6	0.2	33	128.2	12
10/11/2023 23:00	28.11	4.6	0.2	33	128.2	11.9
11/11/2023 00:00	28.07	4.7	0.2	32.8	128.3	11.9
11/11/2023 01:00	27.92	4.5	0.2	32.9	128.1	11.8
11/11/2023 02:00	28.12	4.6	0.2	33.1	128.2	11.9
11/11/2023 03:00	28.12	4.6	0.2	33.1	128.2	11.9

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
11/11/2023 04:00	28.21	4.6	0.2	33.1	128.1	12
11/11/2023 05:00	28.09	4.5	0.2	33.1	128.1	11.9
11/11/2023 06:00	28.01	4.4	0.2	33.1	127.8	11.9
11/11/2023 07:00	28.08	4.5	0.2	33.2	127.6	11.9
11/11/2023 08:00	28.15	4.6	0.2	33.1	128.3	12
11/11/2023 09:00	28.3	4.6	0.2	33.2	128.3	12
11/11/2023 10:00	28.8	4.6	0.2	33.8	128.7	12.2
11/11/2023 11:00	29.46	4.3	10.2	35.1	128.5	12.5
11/11/2023 12:00	29.52	4.1	2.7	35.7	127.5	12.5
11/11/2023 13:00	30.37	4.3	4.8	36.3	127.1	12.9
11/11/2023 14:00	30.4	4.5	0.2	36	127.9	12.9
11/11/2023 15:00	29.86	4.5	0.4	35.2	128.2	12.7
11/11/2023 16:00	28.77	4.4	0.8	34	128.2	12.2
11/11/2023 17:00	28.66	4.4	0.2	34	128	12.2
11/11/2023 18:00	28.07	4.3	0.6	33.4	127.9	11.9
11/11/2023 19:00	27.9	4.4	3.2	33.2	128.7	11.8
11/11/2023 20:00	28.13	4.4	0.2	33.4	128.5	11.9
11/11/2023 21:00	28.46	4.4	0.2	33.8	128.3	12.1
11/11/2023 22:00	28.82	4.5	0.2	34	128.5	12.2
11/11/2023 23:00	28.4	4.4	0.2	33.6	128.4	12.1
12/11/2023 00:00	28.68	4.4	0.2	33.9	128	12.2
12/11/2023 01:00	28.3	4.4	0.2	33.6	127.2	12
12/11/2023 02:00	28.13	4.4	0.2	33.5	126.8	11.9
12/11/2023 03:00	28.69	4.7	0.2	33.5	127.6	12.2
12/11/2023 04:00	28.43	4.5	0.2	33.6	128.1	12.1
12/11/2023 05:00	28.77	4.7	0.2	33.6	128.1	12.2
12/11/2023 06:00	28.62	4.6	0.2	33.5	128.1	12.1
12/11/2023 07:00	28.67	4.5	0.2	33.7	128.3	12.2
12/11/2023 08:00	28.64	4.3	0.2	34.2	127.6	12.2
12/11/2023 09:00	28.95	4.3	0.2	34.6	127.6	12.3
12/11/2023 10:00	29.38	4.4	0.2	35	127.6	12.5
12/11/2023 11:00	29.1	4.3	0.2	34.7	127.1	12.4
12/11/2023 12:00	28.8	4.6	0.2	33.7	128.2	12.2
12/11/2023 13:00	28.55	4.5	0.2	33.7	127.8	12.1
12/11/2023 14:00	29.37	4.7	0.2	34.2	128.1	12.5
12/11/2023 15:00	30.22	4.8	0.2	34.9	128.9	12.8
12/11/2023 16:00	30.05	4.7	0.2	35.1	128.8	12.8
12/11/2023 17:00	29.82	4.6	0.2	34.6	128.7	12.6
12/11/2023 18:00	28.82	4.5	0.2	33.9	129.1	12.2
12/11/2023 19:00	28.64	4.6	0.2	33.6	128.9	12.2
12/11/2023 20:00	28.54	4.5	0.2	33.8	128.2	12.1
12/11/2023 21:00	28.53	4.4	0.2	33.8	128	12.1
12/11/2023 22:00	28.75	4.6	0.2	33.8	127.9	12.2
12/11/2023 23:00	28.8	4.5	0.2	34	127.8	12.2
13/11/2023 00:00	28.67	4.5	0.2	33.9	127.9	12.2
13/11/2023 01:00	28.99	4.7	0.2	33.8	128	12.3
13/11/2023 02:00	28.78	4.6	0.2	33.7	128.1	12.2
13/11/2023 03:00	28.98	4.7	0.2	33.7	128.1	12.3
13/11/2023 04:00	28.73	4.5	0.2	33.9	127.7	12.2
13/11/2023 05:00	29.23	4.8	0.2	33.9	128.2	12.4
13/11/2023 06:00	29.04	4.6	0.2	34.1	127.6	12.3
13/11/2023 07:00	29.39	4.8	0.2	34.1	128.1	12.5
13/11/2023 08:00	28.9	4.6	0.2	33.9	128.1	12.3
13/11/2023 09:00	28.71	4.3	0.2	34.4	127.8	12.2
13/11/2023 10:00	29.48	4.2	4.5	35.4	127.4	12.5
13/11/2023 11:00	29.54	4.1	2	35.6	127.2	12.5
13/11/2023 12:00	30.24	4.4	13.4	36	127.2	12.8
13/11/2023 13:00	30.81	4.5	14.5	36.3	127.6	13.1
13/11/2023 14:00	30.77	4.6	2.6	36.2	128.2	13.1
13/11/2023 15:00	30.27	4.4	2.2	36	127.5	12.9
13/11/2023 16:00	30.08	4.6	14	35.4	128	12.8

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2 ppm	O2 %Vol	Flow km3/h	NOx ppm	Temp Deg C	NOx@15%O2 ppm
13/11/2023 17:00	28.37	4.5	0.8	33.5	127.9	12
13/11/2023 18:00	28.23	4.4	5.9	33.5	127.8	12
13/11/2023 19:00	28.26	4.4	6.5	33.6	128.3	12
13/11/2023 20:00	28.3	4.4	1.3	33.6	128.7	12
13/11/2023 21:00	28.6	4.4	0.2	34	128.2	12.1
13/11/2023 22:00	28.94	4.6	0.2	34	128	12.3
13/11/2023 23:00	28.76	4.5	0.2	34	127.9	12.2
14/11/2023 00:00	28.76	4.5	0.2	34	127.7	12.2
14/11/2023 01:00	29.18	4.5	0.2	34.5	127.7	12.4
14/11/2023 02:00	29.65	4.7	0.2	34.7	127.9	12.6
14/11/2023 03:00	29.59	4.6	0.2	34.8	128	12.6
14/11/2023 04:00	29.55	4.6	0.2	34.7	127.7	12.5
14/11/2023 05:00	29.28	4.5	0.2	34.5	127.4	12.4
14/11/2023 06:00	29.54	4.5	0.2	34.8	127.3	12.5
14/11/2023 07:00	29.68	4.7	0.2	34.7	128	12.6
14/11/2023 08:00	29.3	4.3	0.2	34.9	127.2	12.4
14/11/2023 09:00	29.35	4.2	0.2	35.2	126.4	12.5
14/11/2023 10:00	29.43	4.2	0.2	35.4	126.4	12.5
14/11/2023 11:00	29.55	4.2	0.2	35.6	126.5	12.5
14/11/2023 12:00	30.47	4.5	1.8	36	127.1	12.9
14/11/2023 13:00	30.51	4.4	16.4	36.1	127.2	12.9
14/11/2023 14:00	30.6	4.5	8.9	36.2	127.1	13
14/11/2023 15:00	30.7	4.5	0.3	36.1	127.4	13
14/11/2023 16:00	30.56	4.5	3.1	36.2	127.1	13
14/11/2023 17:00	30.04	4.4	0.2	35.7	127.1	12.8
14/11/2023 18:00	29.66	4.4	0.2	35.2	127.8	12.6
14/11/2023 19:00	29.71	4.5	0.2	35.1	127.9	12.6
14/11/2023 20:00	29.19	4.3	0.2	34.9	127.7	12.4
14/11/2023 21:00	29.9	4.6	0.2	35	127.7	12.7
14/11/2023 22:00	29.64	4.5	0.2	35	127.8	12.6
14/11/2023 23:00	29.78	4.6	0.2	35	127.7	12.6
15/11/2023 00:00	29.62	4.5	0.2	35	127.6	12.6
15/11/2023 01:00	29.69	4.5	0.2	35	127.2	12.6
15/11/2023 02:00	29.76	4.6	0.2	34.8	127.3	12.6
15/11/2023 03:00	29.45	4.5	0.2	34.8	127.2	12.5
15/11/2023 04:00	29.86	4.6	0.2	34.9	127.1	12.7
15/11/2023 05:00	29.93	4.5	0.2	35.2	126.8	12.7
15/11/2023 06:00	30.24	4.5	0.2	35.6	127.4	12.8
15/11/2023 07:00	30.42	4.6	0.2	35.6	127.6	12.9
15/11/2023 08:00	30.81	4.6	0.2	36	127.2	13.1
15/11/2023 09:00	<Samp	<Samp	<Samp	<Samp	95.8	<Samp
15/11/2023 10:00	Maintain	Maintain	Maintain	Maintain	104.5	Maintain
15/11/2023 11:00	<Samp	<Samp	<Samp	<Samp	132	<Samp
15/11/2023 12:00	30.13	4.1	17.7	36.4	127.5	12.8
15/11/2023 13:00	30.48	4.3	17.6	36.3	128	12.9
15/11/2023 14:00	30.11	4.1	2.6	36.3	128	12.8
15/11/2023 15:00	29.63	4.4	0	35.1	128.2	12.6
15/11/2023 16:00	29.69	4.5	2.8	34.9	128.3	12.6
15/11/2023 17:00	28.63	4.5	1.1	33.8	125.6	12.2
15/11/2023 18:00	28.39	4.5	0.2	33.5	127.2	12
15/11/2023 19:00	28.06	4.5	0.2	33.2	128.2	11.9
15/11/2023 20:00	28.67	4.4	0.2	34	127.8	12.2
15/11/2023 21:00	29.49	4.5	0.2	34.8	127.7	12.5
15/11/2023 22:00	29.42	4.4	0.2	34.9	127.9	12.5
15/11/2023 23:00	29.69	4.5	0.2	35	127.9	12.6
16/11/2023 00:00	29.68	4.5	0.2	34.9	127.8	12.6
16/11/2023 01:00	29.67	4.5	0.2	35	127.6	12.6
16/11/2023 02:00	29.81	4.5	0.2	35.1	127.2	12.7
16/11/2023 03:00	29.89	4.6	0.2	35.1	127.2	12.7
16/11/2023 04:00	30.09	4.6	0.2	35.4	127.4	12.8
16/11/2023 05:00	30.22	4.6	0.2	35.4	127.9	12.8

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2		O2		Flow		NOx		Temp		NOx@15%O2	
	ppm	%Vol	%Vol		km3/h		ppm		Deg C		ppm	
18/11/2023 19:00	33.25	4.7	0.2		38.8		126.9		14.1			
18/11/2023 20:00	32.97	4.7	0.2		38.5		127.4		14			
18/11/2023 21:00	33.09	4.7	0.2		38.6		127.2		14			
18/11/2023 22:00	33.27	4.7	0.2		38.7		127.2		14.1			
18/11/2023 23:00	33.78	4.7	0.2		39.3		127.2		14.3			
19/11/2023 00:00	34.08	4.8	0.2		39.4		127		14.5			
19/11/2023 01:00	34	4.8	0.2		39.3		126.9		14.4			
19/11/2023 02:00	34.15	4.9	0.2		39.3		126.8		14.5			
19/11/2023 03:00	34.12	4.9	0.2		39.3		127.2		14.5			
19/11/2023 04:00	34.32	4.9	0.2		39.4		127.3		14.6			
19/11/2023 05:00	34.46	4.8	0.2		39.9		126.7		14.6			
19/11/2023 06:00	34.45	4.9	0.3		39.5		126.6		14.6			
19/11/2023 07:00	34.76	5	0.2		39.8		126.6		14.8			
19/11/2023 08:00	34.74	4.9	0.2		39.9		126.8		14.7			
19/11/2023 09:00	34.17	4.6	0.2		40.1		126.1		14.5			
19/11/2023 10:00	34.71	4.8	0.2		40.1		126.6		14.7			
19/11/2023 11:00	34.75	4.9	0.2		39.9		127.1		14.8			
19/11/2023 12:00	34.62	4.9	0.2		39.9		127.4		14.7			
19/11/2023 13:00	34.3	4.9	0.2		39.5		127.8		14.6			
19/11/2023 14:00	34.37	4.9	0.2		39.6		128.2		14.6			
19/11/2023 15:00	34.14	4.9	0.2		39.3		127.9		14.5			
19/11/2023 16:00	33.92	4.9	0.2		39.1		127.8		14.4			
19/11/2023 17:00	33.65	4.8	0.2		38.9		127.5		14.3			
19/11/2023 18:00	33.63	4.8	0.2		39		127.1		14.3			
19/11/2023 19:00	33.41	4.8	0.2		38.6		127.8		14.2			
19/11/2023 20:00	32.67	4.8	0.2		37.8		128.1		13.9			
19/11/2023 21:00	32.58	4.7	0.2		37.9		127.5		13.8			
19/11/2023 22:00	33.1	4.9	0.2		38.1		127.6		14			
19/11/2023 23:00	33.29	4.9	0.2		38.2		127.3		14.1			
20/11/2023 00:00	33.45	4.9	0.2		38.4		127.3		14.2			
20/11/2023 01:00	33.46	4.9	0.2		38.4		127.2		14.2			
20/11/2023 02:00	33.55	5	0.2		38.3		127.5		14.2			
20/11/2023 03:00	33.65	5	0.2		38.6		127.2		14.3			
20/11/2023 04:00	33.74	5.1	0.3		38.4		126.9		14.3			
20/11/2023 05:00	33.68	5	0.3		38.6		126.7		14.3			
20/11/2023 06:00	34	5	0.3		39		126.8		14.4			
20/11/2023 07:00	33.65	4.8	0.2		39		126.7		14.3			
20/11/2023 08:00	34.1	4.9	0.2		39.3		127.1		14.5			
20/11/2023 09:00	33.81	4.6	0.2		39.8		126.4		14.4			
20/11/2023 10:00	33.77	4.5	0.2		39.9		126.4		14.3			
20/11/2023 11:00	33.78	4.5	0.2		39.8		126.8		14.3			
20/11/2023 12:00	34.42	4.6	0.2		40.4		127.5		14.6			
20/11/2023 13:00	34.51	4.7	0.2		40.3		128.2		14.6			
20/11/2023 14:00	34.6	4.7	0.2		40.4		128.4		14.7			
20/11/2023 15:00	34.4	4.7	0.2		40		128.5		14.6			
20/11/2023 16:00	33.03	4.7	0.2		38.4		129		14			
20/11/2023 17:00	32.98	4.7	0.2		38.4		129.4		14			
20/11/2023 18:00	32.75	4.6	0.2		38.4		128.3		13.9			
20/11/2023 19:00	32.79	4.6	0.2		38.4		127.9		13.9			
20/11/2023 20:00	32.46	4.7	0.2		37.8		128.1		13.8			
20/11/2023 21:00	32.36	4.6	0.2		37.9		127.7		13.7			
20/11/2023 22:00	32.56	4.7	0.2		37.9		127.6		13.8			
20/11/2023 23:00	32.86	4.7	0.2		38.2		126.8		13.9			
21/11/2023 00:00	32.66	4.7	0.2		38.1		126.7		13.9			
21/11/2023 01:00	32.73	4.7	0.2		38.1		126.9		13.9			
21/11/2023 02:00	33.06	4.8	0.2		38.2		126.8		14			
21/11/2023 03:00	33.03	4.8	0.2		38.2		126.6		14			
21/11/2023 04:00	33.13	4.9	0.2		38.2		126.6		14.1			
21/11/2023 05:00	33.03	4.8	0.2		38.2		126.8		14			
21/11/2023 06:00	33.15	4.9	0.2		38.2		126.7		14.1			
21/11/2023 07:00	32.93	4.6	0.2		38.5		126.8		14			

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2		O2		Flow		NOx		Temp		NOx@15%O2	
	ppm	%Vol	%Vol		km3/h		ppm		Deg C		ppm	
21/11/2023 08:00	33.25	4.8	0.2		38.4		127.4		14.1			
21/11/2023 09:00	33.46	4.8	0.2		38.7		127.6		14.2			
21/11/2023 10:00	33.35	4.7	0.2		38.9		127.5		14.2			
21/11/2023 11:00	33.33	4.4	0.2		39.6		127.2		14.1			
21/11/2023 12:00	33.88	4.5	1.2		40		127.5		14.4			
21/11/2023 13:00	34.41	4.8	0		40		128.5		14.6			
21/11/2023 14:00	34.36	4.8	0		39.9		129.1		14.6			
21/11/2023 15:00	34.18	4.8	0		39.6		129		14.5			
21/11/2023 16:00	33.26	4.7	1		38.8		128.5		14.1			
21/11/2023 17:00	32.15	4.7	0.2		37.6		128.4		13.6			
21/11/2023 18:00	31.8	4.6	0.2		37.2		128.7		13.5			
21/11/2023 19:00	31.05	4.6	0.2		36.4		128.7		13.2			
21/11/2023 20:00	31.07	4.6	0.2		36.5		128.2		13.2			
21/11/2023 21:00	31.59	4.7	0.2		36.9		127.8		13.4			
21/11/2023 22:00	31.73	4.7	0.2		37		127.6		13.5			
21/11/2023 23:00	31.62	4.6	0.2		37.2		127.7		13.4			
22/11/2023 00:00	31.73	4.6	0.2		37.3		127.3		13.5			
22/11/2023 01:00	31.84	4.6	0.2		37.4		126.9		13.5			
22/11/2023 02:00	31.99	4.7	0.2		37.3		127.3		13.6			
22/11/2023 03:00	32.05	4.8	0.2		37.1		127.5		13.6			
22/11/2023 04:00	31.89	4.7	0.2		37.2		127.5		13.5			
22/11/2023 05:00	32.1	4.8	0.2		37.2		127.5		13.6			
22/11/2023 06:00	32.13	4.8	0.2		37.3		127.3		13.6			
22/11/2023 07:00	31.98	4.7	0.2		37.3		127.2		13.6			
22/11/2023 08:00	32.12	4.7	0.2		37.5		127.7		13.6			
22/11/2023 09:00	32.18	4.5	0.2		37.9		127.1		13.7			
22/11/2023 10:00	32.92	4.7	0.4		38.4		127.5		14			
22/11/2023 11:00	32.96	4.6	1		38.7		128.3		14			
22/11/2023 12:00	33.2	4.5	0		39.2		128.7		14.1			
22/11/2023 13:00	33.9	4.7	0		39.6		128.8		14.4			
22/11/2023 14:00	32.98	4.7	0.6		39.4		128.8		14			
22/11/2023 15:00	31.79	4.6	1.8		37.2		128.6		13.5			
22/11/2023 16:00	31.26	4.6	0.6		36.7		128		13.3			
22/11/2023 17:00	30.69	4.5	0.2		36.2		127.8		13			
22/11/2023 18:00	30.55	4.5	0.2		36.1		127.9		13			
22/11/2023 19:00	30.53	4.5	0.2		36.1		127.9		13			
22/11/2023 20:00	30.25	4.5	0.2		35.7		128.1		12.8			
22/11/2023 21:00	30.37	4.6	0.2		35.7		127.8		12.9			
22/11/2023 22:00	30.33	4.5	0.2		35.8		127.8		12.9			
22/11/2023 23:00	30.54	4.5	0.2		35.9		128.1		13			
23/11/2023 00:00	30.95	4.6	0.2		36.2		127.9		13.1			
23/11/2023 01:00	30.95	4.6	0.2		36.3		127.6		13.1			
23/11/2023 02:00	31.36	4.7	0.2		36.8		127.5		13.3			
23/11/2023 03:00	31.55	4.7	0.2		36.7		127.3		13.4			
23/11/2023 04:00	31.69	4.7	0.2		36.9		127.2		13.5			
23/11/2023 05:00	31.66	4.6	0.2		37		127.6		13.4			
23/11/2023 06:00	31.56	4.6	0.2		37		127.1		13.4			
23/11/2023 07:00	31.59	4.7	0.2		36.8		127.4		13.4			
23/11/2023 08:00	31.82	4.7	0.2		37.1		127.7		13.5			
23/11/2023 09:00	32.21	4.5	0.2		38.1		127.3		13.7			
23/11/2023 10:00	32.98	4.4	0.2		39.2		126.4		14			
23/11/2023 11:00	32.5	4.3	0.2		38.7		126.6		13.8			
23/11/2023 12:00	32.19	4.3	3.7		38.5		126.7		13.7			
23/11/2023 13:00	32.88	4.4	0		39		127.1		14			
23/11/2023 14:00	33.4	4.6	4		39.1		127.6		14.2			
23/11/2023 15:00	33.07	4.5	6		39		127.7		14			
23/11/2023 16:00	32.94	4.6	0.2		38.6		127.7		14			
23/11/2023 17:00	32.34	4.4	0.2		38.3		127.5		13.7			
23/11/2023 18:00	32.04	4.5	0.2		37.9		127.4		13.6			
23/11/2023 19:00	31.76	4.6	0.2		37.2		128.2		13.5			
23/11/2023 20:00	31.48	4.6	0.2		37		128		13.4			

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
28/11/2023 23:00	32.91	5.1	0.2	37.4	127.6	14
29/11/2023 00:00	33.06	5.1	0.2	37.5	127.9	14
29/11/2023 01:00	33.2	5.2	0.2	37.5	127.6	14.1
29/11/2023 02:00	33.37	5.2	0.2	37.8	127.2	14.2
29/11/2023 03:00	32.97	5.1	0.2	37.5	127.2	14
29/11/2023 04:00	32.59	4.9	0.2	37.4	126.8	13.8
29/11/2023 05:00	33.16	5.2	0.2	37.3	127.4	14.1
29/11/2023 06:00	32.96	5.1	0.2	37.5	127.4	14
29/11/2023 07:00	33.27	5.2	0.2	37.5	127.5	14.1
29/11/2023 08:00	33.44	5.2	0.2	37.8	127.8	14.2
29/11/2023 09:00	32.8	4.9	0.2	37.7	127.7	13.9
29/11/2023 10:00	33.91	5.1	0.2	38.5	127.9	14.4
29/11/2023 11:00	33.77	4.9	0.2	38.9	127.6	14.3
29/11/2023 12:00	34.31	5	0.7	39.1	128.7	14.6
29/11/2023 13:00	34.39	5.1	0	39.2	128.7	14.6
29/11/2023 14:00	34.33	5.1	0	38.9	128.9	14.6
29/11/2023 15:00	33.61	5.1	0	38.3	129	14.3
29/11/2023 16:00	33.19	5.1	1.7	37.7	129	14.1
29/11/2023 17:00	32.3	5	1.3	36.8	129.5	13.7
29/11/2023 18:00	31.95	5	1.3	36.5	129.7	13.6
29/11/2023 19:00	31.75	4.9	0.2	36.5	129	13.5
29/11/2023 20:00	31.89	5.1	0.2	36.2	128.7	13.5
29/11/2023 21:00	31.78	5.1	0.2	36.1	128.5	13.5
29/11/2023 22:00	32	5.1	0.2	36.5	128	13.6
29/11/2023 23:00	32.16	5	0.2	36.8	127.6	13.6
30/11/2023 00:00	32.5	5.2	0.2	36.7	127.9	13.8
30/11/2023 01:00	32.48	5.1	0.2	36.9	128.1	13.8
30/11/2023 02:00	32.3	5.1	0.2	36.8	127.7	13.7
30/11/2023 03:00	32.11	5.1	0.2	36.6	127.5	13.6
30/11/2023 04:00	32.16	5.1	0.2	36.5	127.7	13.7
30/11/2023 05:00	32.46	5.2	0.2	36.6	128.3	13.8
30/11/2023 06:00	32.42	5.1	0.2	36.8	128.1	13.8
30/11/2023 07:00	32.58	5.1	0.2	36.9	128.4	13.8
30/11/2023 08:00	32.03	4.8	0.2	37	128.1	13.6
30/11/2023 09:00	32.72	4.8	0.2	37.9	127.7	13.9
30/11/2023 10:00	32.95	4.7	1.2	38.3	127.7	14
30/11/2023 11:00	33.02	4.9	0	38.1	128.3	14
30/11/2023 12:00	33.11	4.8	0	38.3	128.7	14.1
30/11/2023 13:00	32.86	5	0	37.6	129	13.9
30/11/2023 14:00	32.03	5	0	36.5	128.4	13.6
30/11/2023 15:00	31.59	4.9	0	36.3	128.4	13.4
30/11/2023 16:00	31.85	4.9	1.6	36.8	128.7	13.5
30/11/2023 17:00	32.18	5	0.2	36.9	129.2	13.7
30/11/2023 18:00	31.64	4.9	2.6	36.3	129.6	13.4
30/11/2023 19:00	31.05	5	0.2	35.5	129.8	13.2
30/11/2023 20:00	30.35	4.8	0.2	35.2	129.2	12.9
30/11/2023 21:00	30.42	4.9	0.2	35	129.1	12.9
30/11/2023 22:00	30.51	4.8	0.2	35.3	128.4	12.9
30/11/2023 23:00	30.97	5	0.2	35.4	128.2	13.1
Minimum	26.93	4.1	0	32	95.8	11.4
MinDate	09/11/2023 16:00	11/11/2023 12:00	15/11/2023 15:00	09/11/2023 16:00	15/11/2023 09:00	09/11/2023 16:00
Maximum	35.31	5.2	17.7	40.6	132	15
MaxDate	18/11/2023 06:00	28/11/2023 06:00	15/11/2023 12:00	18/11/2023 06:00	15/11/2023 11:00	18/11/2023 06:00
Avg	30.7	4.7	0.5	35.8	127.7	13
Num	711	711	711	711	720	711
Data[%]	98.6	98.6	98.6	98.6	99.9	98.6
STD	2.1	0.2	1.7	2.2	1.7	0.9

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
01/12/2023 00:00	31.3	5.1	0.2	35.5	128.1	13.3
01/12/2023 01:00	31.08	4.9	0.2	35.7	127.9	13.2
01/12/2023 02:00	31.52	5.2	0.2	35.7	128.1	13.4
01/12/2023 03:00	31.26	5	0.2	35.8	127.8	13.3
01/12/2023 04:00	31.44	5.1	0.2	35.8	127.8	13.3
01/12/2023 05:00	31.08	4.9	0.2	35.9	127.4	13.2
01/12/2023 06:00	31.54	5.1	0.2	35.8	127.9	13.4
01/12/2023 07:00	31.09	4.8	0.2	35.9	127.8	13.2
01/12/2023 08:00	31.1	4.9	0.2	35.8	127.2	13.2
01/12/2023 09:00	30.99	4.9	0.2	35.7	127.6	13.2
01/12/2023 10:00	30.91	4.8	0.2	35.7	127.6	13.1
01/12/2023 11:00	30.84	4.7	3.3	35.9	127.8	13.1
01/12/2023 12:00	30.94	4.7	8	36	127.7	13.1
01/12/2023 13:00	30.94	4.7	0	36.1	128.2	13.1
01/12/2023 14:00	30.37	4.8	0.5	35.1	127.2	12.9
01/12/2023 15:00	28.82	4.9	0.2	33.2	124.2	12.2
01/12/2023 16:00	28.63	4.7	0.2	33.3	127.6	12.2
01/12/2023 17:00	28.62	4.8	0.2	33.1	128.9	12.1
01/12/2023 18:00	28.2	4.7	0.2	32.8	128.9	12
01/12/2023 19:00	28.33	4.9	0.2	32.7	129.5	12
01/12/2023 20:00	28.53	4.7	0.2	33.2	128.9	12.1
01/12/2023 21:00	29.05	4.8	0.2	33.7	128.7	12.3
01/12/2023 22:00	29.4	4.8	0.2	34.1	127.9	12.5
01/12/2023 23:00	29.47	4.7	0.2	34.4	127.9	12.5
02/12/2023 00:00	29.3	4.7	0.2	34.2	127.7	12.4
02/12/2023 01:00	29.92	4.9	0.2	34.5	127.7	12.7
02/12/2023 02:00	29.87	4.9	0.2	34.5	127.8	12.7
02/12/2023 03:00	29.64	4.8	0.2	34.3	127.4	12.6
02/12/2023 04:00	29.66	4.7	0.2	34.5	127.2	12.6
02/12/2023 05:00	30	4.7	0.2	34.9	127.6	12.7
02/12/2023 06:00	30.01	4.7	0.2	34.9	127.6	12.7
02/12/2023 07:00	30.41	4.8	0.2	35.2	127.4	12.9
02/12/2023 08:00	30.72	4.8	0.2	35.5	127	13
02/12/2023 09:00	30.51	4.8	0.2	35.0	126.9	12.9
02/12/2023 10:00	31.38	4.8	0.2	36.4	127.4	13.3
02/12/2023 11:00	31.34	4.4	0.2	37.2	126.9	13.3
02/12/2023 12:00	32.12	4.6	0.2	37.6	127.2	13.6
02/12/2023 13:00	32.1	4.7	2	37.5	127.1	13.6
02/12/2023 14:00	31.96	4.6	0	37.4	127.6	13.6
02/12/2023 15:00	31.86	4.5	0	37.6	127.8	13.5
02/12/2023 16:00	31.44	4.5	2.5	37.2	127.4	13.3
02/12/2023 17:00	31.53	4.6	0.2	37	127.4	13.4
02/12/2023 18:00	31.5	4.5	0.2	37.2	127.1	13.4
02/12/2023 19:00	31.37	4.5	0.2	37.1	127	13.3
02/12/2023 20:00	30.98	4.5	0.2	36.5	127.3	13.2
02/12/2023 21:00	30.53	4.5	0.2	35.9	127.7	13
02/12/2023 22:00	30.37	4.6	0.2	35.6	127.8	12.9
02/12/2023 23:00	30.17	4.6	0.2	35.5	127.5	12.8
03/12/2023 00:00	30.18	4.6	0.2	35.3	127.5	12.8
03/12/2023 01:00	30.01	4.5	0.2	35.4	126.8	12.7
03/12/2023 02:00	30.03	4.5	0.2	35.5	126.8	12.7
03/12/2023 03:00	30.5	4.7	0.2	35.6	126.9	12.9
03/12/2023 04:00	30.67	4.6	0.2	36	126.8	13
03/12/2023 05:00	31.05	4.6	0.2	36.4	126.1	13.2
03/12/2023 06:00	30.71	4.5	0.2	36.1	126.3	13
03/12/2023 07:00	30.87	4.6	0.2	36.1	126	13.1
03/12/2023 08:00	31.12	4.6	0.2	36.5	126.1	13.2
03/12/2023 09:00	30.8	4.5	0.2	36.4	126.3	13.1
03/12/2023 10:00	31.18	4.6	0.2	36.5	126.9	13.2
03/12/2023 11:00	31.18	4.6	0.2	36.5	127	13.2
03/12/2023 12:00	31.12	4.6	0.2	36.4	126.9	13.2

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
03/12/2023 13:00	31.59	4.8	1.9	36.6	126.9	13.4
03/12/2023 14:00	30.72	4.7	0.2	35.9	126.8	13
03/12/2023 15:00	29.37	4.6	0.2	34.4	126.9	12.5
03/12/2023 16:00	30.5	4.6	0.2	35.9	127.2	12.9
03/12/2023 17:00	30.19	4.5	0.2	35.6	127	12.8
03/12/2023 18:00	30.56	4.7	0.2	35.5	127.1	13
03/12/2023 19:00	30.65	4.5	0.2	36.2	126.8	13
03/12/2023 20:00	30.18	4.6	0.2	35.3	127.4	12.8
03/12/2023 21:00	29.55	4.6	0.2	34.7	127.9	12.5
03/12/2023 22:00	29.7	4.6	0.2	34.7	128.3	12.6
03/12/2023 23:00	29.31	4.6	0.2	34.3	128.7	12.4
04/12/2023 00:00	29.03	4.6	0.2	34	128.9	12.3
04/12/2023 01:00	29.33	4.6	0.2	34.4	128.6	12.5
04/12/2023 02:00	29.39	4.7	0.2	34.3	129	12.5
04/12/2023 03:00	29.23	4.5	0.2	34.4	128	12.4
04/12/2023 04:00	29.58	4.7	0.2	34.5	127.8	12.6
04/12/2023 05:00	28.93	4.6	0.2	33.8	127.7	12.3
04/12/2023 06:00	29.1	4.6	0.2	34.2	127.5	12.4
04/12/2023 07:00	29.55	4.6	0.2	34.7	127.5	12.5
04/12/2023 08:00	30.15	4.6	0.2	35.3	127.4	12.8
04/12/2023 09:00	30.87	4.7	0.2	36	127.5	13.1
04/12/2023 10:00	30.96	4.8	0.2	35.9	127.5	13.1
04/12/2023 11:00	31.18	4.8	0.2	36.2	127.3	13.2
04/12/2023 12:00	31.19	4.7	0.2	36.3	127.8	13.2
04/12/2023 13:00	31.46	4.7	2.3	36.7	128.3	13.4
04/12/2023 14:00	31.46	4.6	0	36.9	128.5	13.4
04/12/2023 15:00	31.11	4.6	0	36.6	128.2	13.2
04/12/2023 16:00	30.16	4.6	0.6	35.4	127.4	12.8
04/12/2023 17:00	29.65	4.6	0.2	34.8	127	12.6
04/12/2023 18:00	29.69	4.5	0.2	35	127.8	12.6
04/12/2023 19:00	29.46	4.6	0.2	34.5	128.1	12.5
04/12/2023 20:00	29.1	4.5	0.2	34.2	128.3	12.4
04/12/2023 21:00	28.98	4.6	0.2	34	128.3	12.3
04/12/2023 22:00	29.12	4.6	0.2	34.2	128.1	12.4
04/12/2023 23:00	29.03	4.6	0.2	34.1	128.1	12.3
05/12/2023 00:00	29.21	4.6	0.2	34.2	127.7	12.4
05/12/2023 01:00	29.19	4.6	0.2	34.2	127.6	12.4
05/12/2023 02:00	29.36	4.7	0.2	34.3	127.8	12.5
05/12/2023 03:00	29.4	4.7	0.2	34.3	128.5	12.5
05/12/2023 04:00	29.24	4.7	0.2	34.2	128	12.4
05/12/2023 05:00	29.21	4.7	0.2	34	127.7	12.4
05/12/2023 06:00	29.09	4.7	0.2	34	128.5	12.3
05/12/2023 07:00	29.33	4.8	0.2	34	128	12.4
05/12/2023 08:00	28.51	4.4	0.2	33.9	127.6	12.1
05/12/2023 09:00	29.82	4.4	0.2	35.4	127	12.7
05/12/2023 10:00	30.47	4.4	0.2	36.2	126.7	12.9
05/12/2023 11:00	30.79	4.4	1.7	36.7	126.9	13.1
05/12/2023 12:00	31.25	4.5	0	36.9	127.1	13.3
05/12/2023 13:00	31.35	4.7	0	36.5	128.2	13.3
05/12/2023 14:00	30.4	4.7	0	35.4	128.3	12.9
05/12/2023 15:00	29.78	4.6	2.5	34.8	127.8	12.6
05/12/2023 16:00	29.84	4.5	0.2	35.1	127.7	12.7
05/12/2023 17:00	29.87	4.6	0.2	35.1	127.7	12.7
05/12/2023 18:00	29.39	4.4	0.2	34.8	127.6	12.5
05/12/2023 19:00	29.36	4.5	0.2	34.7	127.7	12.5
05/12/2023 20:00	29.28	4.5	0.2	34.5	128.5	12.4
05/12/2023 21:00	29.45	4.5	0.2	34.7	128.7	12.5
05/12/2023 22:00	29.26	4.5	0.2	34.4	128.4	12.4
05/12/2023 23:00	28.98	4.5	0.2	34.1	128.4	12.3
06/12/2023 00:00	29.02	4.7	0.2	33.8	128.6	12.3
06/12/2023 01:00	29.21	4.7	0.2	34.1	128.9	12.4

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
08/12/2023 15:00	<Samp	<Samp	0	<Samp	127.2	<Samp
08/12/2023 16:00	32.31	4.2	0	38.8	127	13.7
08/12/2023 17:00	33.15	4.2	0	39.8	126.9	14.1
08/12/2023 18:00	33.02	4.1	0	39.9	126.5	14
08/12/2023 19:00	33.16	4.2	3.2	39.7	126.9	14.1
08/12/2023 20:00	33.12	4.2	0.2	39.7	127.2	14.1
08/12/2023 21:00	32.78	4.1	0.2	39.5	127.3	13.9
08/12/2023 22:00	33.35	4.5	0.2	39.3	128	14.2
08/12/2023 23:00	33.71	4.6	0.2	39.6	128.5	14.3
09/12/2023 00:00	33	4.4	0.2	39.1	128.4	14
09/12/2023 01:00	32.83	4.6	0.2	38.4	128.4	13.9
09/12/2023 02:00	32.47	4.5	0.2	38.2	128.2	13.8
09/12/2023 03:00	32.65	4.6	0.2	38.2	128.1	13.9
09/12/2023 04:00	32.64	4.6	0.2	38.2	128.6	13.9
09/12/2023 05:00	32.66	4.6	0.2	38.3	128.3	13.9
09/12/2023 06:00	32.77	4.7	0.2	38.3	128.1	13.9
09/12/2023 07:00	32.33	4.5	0.2	38.2	128.1	13.7
09/12/2023 08:00	32.38	4.5	0.2	38.1	128	13.7
09/12/2023 09:00	33.27	4.6	0.2	39	128.6	14.1
09/12/2023 10:00	34.47	4.6	1.2	40.3	128.9	14.6
09/12/2023 11:00	35.04	4.6	0	41.2	128.9	14.9
09/12/2023 12:00	34.8	4.5	0	41	128.4	14.8
09/12/2023 13:00	34.05	4.6	1	40	127.7	14.5
09/12/2023 14:00	34.48	4.7	0.2	40.1	127.8	14.6
09/12/2023 15:00	33.88	4.5	0.2	39.9	127.9	14.4
09/12/2023 16:00	33.9	4.6	1.9	39.8	127.4	14.4
09/12/2023 17:00	33.41	4.4	0	39.6	127.1	14.2
09/12/2023 18:00	32.77	4.4	0.9	38.8	127.1	13.9
09/12/2023 19:00	32.09	4.4	1	38.2	127.2	13.6
09/12/2023 20:00	32.22	4.5	0.2	38	127.3	13.7
09/12/2023 21:00	32.18	4.5	0.2	38.1	127.5	13.7
09/12/2023 22:00	32.06	4.4	0.2	38.1	128.1	13.6
09/12/2023 23:00	32.07	4.5	0.2	37.9	128.2	13.6
10/12/2023 00:00	31.93	4.4	0.2	37.8	128	13.6
10/12/2023 01:00	32.09	4.6	0.2	37.6	128	13.6
10/12/2023 02:00	32.32	4.7	0.2	37.6	128.6	13.7
10/12/2023 03:00	32.36	4.7	0.2	37.7	128.7	13.7
10/12/2023 04:00	32.33	4.7	0.2	37.7	128.3	13.7
10/12/2023 05:00	32.34	4.6	0.2	37.8	128.1	13.7
10/12/2023 06:00	32.53	4.7	0.2	38	128.1	13.8
10/12/2023 07:00	32.18	4.6	0.2	37.8	128.5	13.7
10/12/2023 08:00	32.35	4.6	0.2	37.9	128.9	13.7
10/12/2023 09:00	33.03	4.5	0.2	38.9	128	14
10/12/2023 10:00	33.97	4.5	2.1	40	128.2	14.4
10/12/2023 11:00	34.16	4.5	0	40.3	128.3	14.5
10/12/2023 12:00	35.23	4.8	0	40.9	129	15
10/12/2023 13:00	34.42	4.7	1.8	40.1	128	14.6
10/12/2023 14:00	35	4.8	2	40.5	127.9	14.9
10/12/2023 15:00	35.11	4.8	0.2	40.7	127.9	14.9
10/12/2023 16:00	34.34	4.7	0.2	40	127.8	14.6
10/12/2023 17:00	33.11	4.7	0.2	38.6	127.7	14.1
10/12/2023 18:00	33.08	4.6	0.2	38.7	127.5	14
10/12/2023 19:00	32.77	4.6	0.2	38.4	127.6	13.9
10/12/2023 20:00	32.2	4.5	0.2	38.1	127.9	13.7
10/12/2023 21:00	32.25	4.6	0.2	37.8	128.8	13.7
10/12/2023 22:00	32.21	4.5	0.2	37.9	128.9	13.7
10/12/2023 23:00	32.32	4.6	0.2	37.9	128.6	13.7
11/12/2023 00:00	31.99	4.5	0.2	37.7	128.6	13.6
11/12/2023 01:00	32.41	4.7	0.2	37.7	128.7	13.8
11/12/2023 02:00	32.31	4.7	0.2	37.6	128.5	13.7
11/12/2023 03:00	31.99	4.6	0.2	37.6	128.4	13.6

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
11/12/2023 04:00	32.13	4.6	0.2	37.6	128	13.6
11/12/2023 05:00	32.02	4.5	0.2	37.7	127.9	13.6
11/12/2023 06:00	32.29	4.7	0.2	37.7	128.1	13.7
11/12/2023 07:00	31.86	4.5	0.2	37.6	128.1	13.5
11/12/2023 08:00	31.91	4.5	0.2	37.7	128.2	13.5
11/12/2023 09:00	32.86	4.6	0.5	38.6	128.7	13.9
11/12/2023 10:00	33.65	4.7	0	39.1	129.4	14.3
11/12/2023 11:00	34.2	4.7	0	39.8	129.3	14.5
11/12/2023 12:00	33.11	4.6	0.7	38.9	128.2	14.1
11/12/2023 13:00	33.52	4.6	0.2	39.2	127.9	14.2
11/12/2023 14:00	34.46	4.7	0.2	40.2	128	14.6
11/12/2023 15:00	34.6	4.7	0.2	40.2	127.9	14.7
11/12/2023 16:00	33.65	4.5	0.2	39.7	127.3	14.3
11/12/2023 17:00	33.5	4.5	0.2	39.5	127.2	14.2
11/12/2023 18:00	32.28	4.4	0.2	38.3	127.5	13.7
11/12/2023 19:00	32.14	4.4	0.2	38.1	128	13.6
11/12/2023 20:00	31.83	4.3	0.2	37.9	128.1	13.5
11/12/2023 21:00	31.19	4.4	0.2	37.1	127.9	13.2
11/12/2023 22:00	27.1	3.7	0.2	33.5	128.4	11.5
11/12/2023 23:00	27.19	3.6	0.2	33.9	127.1	11.5
12/12/2023 00:00	27.17	3.6	0.2	33.7	127.4	11.5
12/12/2023 01:00	27.03	3.6	0.2	33.6	127.4	11.5
12/12/2023 02:00	27.02	3.6	0.2	33.6	127.4	11.5
12/12/2023 03:00	27.14	3.7	0.2	33.6	127.5	11.5
12/12/2023 04:00	27.07	3.7	0.2	33.5	127.4	11.5
12/12/2023 05:00	27.14	3.7	0.2	33.6	127.5	11.5
12/12/2023 06:00	27.16	3.7	0.2	33.6	127.5	11.5
12/12/2023 07:00	26.89	3.8	0.2	33.1	127.7	11.4
12/12/2023 08:00	27.11	3.7	0.2	33.5	127.6	11.5
12/12/2023 09:00	27.78	3.8	0.2	34.1	128.1	11.8
12/12/2023 10:00	28.75	3.7	0.2	35.6	127.4	12.2
12/12/2023 11:00	29.69	3.7	0.2	36	127.5	12.3
12/12/2023 12:00	29.3	3.6	0.2	36.4	126.9	12.4
12/12/2023 13:00	29	3.6	0.2	36	127.1	12.3
12/12/2023 14:00	28.93	3.6	0.2	36	126.7	12.3
12/12/2023 15:00	28.59	3.6	0.2	35.6	126.5	12.1
12/12/2023 16:00	28.37	3.7	0.2	35.1	126.6	12
12/12/2023 17:00	29	4	0.2	35.3	126.5	12.3
12/12/2023 18:00	28.53	3.9	0.2	35	126.9	12.1
12/12/2023 19:00	27.31	3.8	0.2	33.6	127.1	11.6
12/12/2023 20:00	26.99	3.9	0.2	33	128	11.5
12/12/2023 21:00	27.12	4.1	0.2	32.8	128.3	11.5
12/12/2023 22:00	27.21	4	0.2	33	128.4	11.6
12/12/2023 23:00	27.1	4.2	0.2	32.6	128.5	11.5
13/12/2023 00:00	27.14	4.2	0.2	32.7	128.7	11.5
13/12/2023 01:00	27.13	4.1	0.2	32.7	128.7	11.5
13/12/2023 02:00	27.19	4.2	0.2	32.6	128.7	11.5
13/12/2023 03:00	27.18	4.2	0.2	32.6	128.6	11.5
13/12/2023 04:00	27.24	4.2	0.2	32.7	128.2	11.6
13/12/2023 05:00	27.21	4.1	0.2	32.9	127.7	11.5
13/12/2023 06:00	27.25	4.2	0.2	32.7	128.2	11.6
13/12/2023 07:00	27.15	4.1	0.2	32.8	128.2	11.5
13/12/2023 08:00	27.32	4.1	0.2	32.9	127.9	11.6
13/12/2023 09:00	27.75	3.9	0.2	34	127.4	11.8
13/12/2023 10:00	28.76	4.2	0.2	34.5	127.6	12.2
13/12/2023 11:00	29.34	3.9	0.2	35.8	127.7	12.5
13/12/2023 12:00	29.81	3.9	0.2	36.4	127.3	12.7
13/12/2023 13:00	30.24	4	0.2	36.8	127.6	12.8
13/12/2023 14:00	29.43	4.1	0.2	35.5	128	12.5
13/12/2023 15:00	28.97	4.2	0.2	34.9	128.1	12.3
13/12/2023 16:00	28.35	4.1	0.2	34.3	127.6	12

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
13/12/2023 17:00	28.16	4.1	0.2	34.1	127.3	12
13/12/2023 18:00	27.76	4	0.2	33.7	127.6	11.8
13/12/2023 19:00	27.79	4.2	0.2	33.5	128.5	11.8
13/12/2023 20:00	27.62	4.1	0.2	33.4	128.3	11.7
13/12/2023 21:00	27.58	4	0.2	33.6	127.9	11.7
13/12/2023 22:00	27.75	4	0.2	33.7	128.1	11.8
13/12/2023 23:00	28.54	4.4	0.2	34	128.4	12.1
14/12/2023 00:00	29.11	4.4	0.2	34.6	128.6	12.4
14/12/2023 01:00	29.17	4.4	0.2	34.6	128.5	12.4
14/12/2023 02:00	29.28	4.4	0.2	34.7	128.6	12.4
14/12/2023 03:00	29.18	4.3	0.2	34.8	128.1	12.4
14/12/2023 04:00	29.28	4.3	0.2	35.1	127.4	12.4
14/12/2023 05:00	29.4	4.4	0.2	35	128	12.5
14/12/2023 06:00	29.3	4.3	0.2	35.1	127.6	12.4
14/12/2023 07:00	29.24	4.3	0.2	34.9	127.9	12.4
14/12/2023 08:00	29.3	4.2	0.2	35.2	127.9	12.4
14/12/2023 09:00	29.9	4.3	0.2	35.8	128	12.7
14/12/2023 10:00	30.6	4	0.2	37.2	128	13
14/12/2023 11:00	30.78	4.1	0.2	37.1	128.1	13.1
14/12/2023 12:00	30.79	4.1	0.2	37.2	128	13.1
14/12/2023 13:00	30.91	4.2	0.2	37	128.4	13.1
14/12/2023 14:00	29.55	4.2	0.2	35.6	128.3	12.5
14/12/2023 15:00	29.17	4.3	0.2	34.8	127.9	12.4
14/12/2023 16:00	29.12	4.2	0.2	35.1	127.4	12.4
14/12/2023 17:00	29.23	4.1	0.2	35.3	127.6	12.4
14/12/2023 18:00	29.01	4.1	0.2	35.1	127.9	12.3
14/12/2023 19:00	28.77	4.1	0.2	34.7	127.9	12.2
14/12/2023 20:00	28.61	4.1	0.2	34.7	127.9	12.1
14/12/2023 21:00	28.36	4.1	0.2	34.3	127.6	12
14/12/2023 22:00	28.13	4.2	0.2	33.9	127.9	11.9
14/12/2023 23:00	28.03	4.1	0.2	33.9	128	11.9
15/12/2023 00:00	28.11	4.3	0.2	33.7	128.3	11.9
15/12/2023 01:00	28.17	4.2	0.2	33.9	128.6	12
15/12/2023 02:00	28.36	4.2	0.2	34.2	128.1	12
15/12/2023 03:00	28.81	4.3	0.2	34.4	127.7	12.2
15/12/2023 04:00	29.02	4.3	0.2	34.6	127.7	12.3
15/12/2023 05:00	28.94	4.2	0.2	34.8	127.6	12.3
15/12/2023 06:00	29.09	4.4	0.2	34.5	128.1	12.3
15/12/2023 07:00	29.08	4.1	0.2	35.1	127.9	12.3
15/12/2023 08:00	29.25	4.3	0.2	35	127.9	12.4
15/12/2023 09:00	29.74	4.3	0.2	35.5	128	12.6
15/12/2023 10:00	30.25	4.3	0.2	36.2	127.8	12.8
15/12/2023 11:00	30.55	3.9	0.2	37.4	127.4	13
15/12/2023 12:00	30.8	3.9	2.6	37.7	127.7	13.1
15/12/2023 13:00	30.66	4.1	0.6	37	128.4	13
15/12/2023 14:00	30.54	4	0.3	37	126.8	13
15/12/2023 15:00	31.38	3.9	0.2	38.3	126.5	13.3
15/12/2023 16:00	32.65	4.2	0.2	39.3	126.5	13.9
15/12/2023 17:00	33.28	4.3	0.2	39.6	126.6	14.1
15/12/2023 18:00	34.23	4.5	0.2	40.4	127.2	14.5
15/12/2023 19:00	33.86	4.5	0.2	39.9	127.9	14.4
15/12/2023 20:00	33.68	4.5	0.2	39.6	127.9	14.3
15/12/2023 21:00	33.33	4.4	0.2	39.6	128.4	14.1
15/12/2023 22:00	32.86	4.4	0.2	38.9	128.6	13.9
15/12/2023 23:00	32.62	4.5	0.2	38.6	128.6	13.8
16/12/2023 00:00	32.38	4.4	0.2	38.4	128.3	13.7
16/12/2023 01:00	32.51	4.5	0.2	38.4	128.6	13.8
16/12/2023 02:00	32.57	4.5	0.2	38.5	128.9	13.8
16/12/2023 03:00	32.95	4.6	0.2	38.7	128.5	14
16/12/2023 04:00	33.34	4.7	0.2	38.8	128.3	14.2
16/12/2023 05:00	33.15	4.7	0.2	38.7	128	14.1

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
18/12/2023 19:00	33.99	4.6	0.2	39.2	126.3	14.2
18/12/2023 20:00	33.05	4.5	0.2	38.9	126.2	14
18/12/2023 21:00	33.33	4.6	0.2	39	126.1	14.1
18/12/2023 22:00	33.61	4.7	0.2	39.4	126.2	14.4
18/12/2023 23:00	34.06	4.7	0.2	39.8	126.2	14.5
19/12/2023 00:00	34.28	4.7	0.2	40	127.7	14.6
19/12/2023 01:00	34.64	4.7	0.2	40.4	126.8	14.7
19/12/2023 02:00	34.85	4.7	0.2	40.5	126.8	14.8
19/12/2023 03:00	34.86	4.7	0.2	40.7	126.9	14.86
19/12/2023 04:00	35.19	4.8	0.2	40.7	127.1	14.9
19/12/2023 05:00	35.28	4.8	0.2	40.8	127.3	15
19/12/2023 06:00	35.4	4.9	0.2	40.9	127.1	15
19/12/2023 07:00	35.37	4.8	0.2	41	127	15
19/12/2023 08:00	35.22	4.7	0.2	41.2	127.2	14.9
19/12/2023 09:00	35.33	4.5	0.2	41.8	126.9	15
19/12/2023 10:00	35.86	4.6	0.2	42	126.9	15.2
19/12/2023 11:00	35.6	4.3	0.2	42.4	127.2	15.1
19/12/2023 12:00	35.78	4.4	0.2	42.6	127.4	15.2
19/12/2023 13:00	36.63	4.8	0.2	42.5	128.3	15.5
19/12/2023 14:00	34.47	4.5	0.2	40.6	127.9	14.6
19/12/2023 15:00	34.64	4.7	0.2	40.4	127.8	14.7
19/12/2023 16:00	34.89	4.6	0.2	40.9	127.8	14.8
19/12/2023 17:00	34.71	4.6	0.2	40.8	127.7	14.7
19/12/2023 18:00	34.16	4.6	0.2	40	127.7	14.5
19/12/2023 19:00	33.88	4.6	0.2	39.7	128.6	14.4
19/12/2023 20:00	33.59	4.7	0.2	39.2	129	14.3
19/12/2023 21:00	33.12	4.6	0.2	38.7	128.9	14.1
19/12/2023 22:00	32.86	4.6	0.2	38.4	128.9	13.9
19/12/2023 23:00	33.04	4.7	0.2	38.4	129	14
20/12/2023 00:00	32.98	4.7	0.2	38.5	128.8	14
20/12/2023 01:00	33.38	4.6	0.2	39.1	127.8	14.2
20/12/2023 02:00	34.04	4.7	0.2	39.7	127.8	14.4
20/12/2023 03:00	34.32	4.7	0.2	40.1	127.7	14.6
20/12/2023 04:00	34.43	4.7	0.2	40.2	128	14.6
20/12/2023 05:00	34.14	4.6	0.2	40	127.8	14.5
20/12/2023 06:00	34.46	4.7	0.2	40.2	127.4	14.6
20/12/2023 07:00	34.65	4.7	0.2	40.4	127.4	14.7
20/12/2023 08:00	34.73	4.6	0.2	40.8	127.5	14.7
20/12/2023 09:00	35.65	4.7	0.2	41.5	127.4	15.1
20/12/2023 10:00	35.54	4.5	0.2	41.9	127.3	15.1
20/12/2023 11:00	35.35	4.3	0.2	42.2	127	15
20/12/2023 12:00	35.59	4.3	0.2	42.8	127.2	15.1
20/12/2023 13:00	35.86	4.3	0.2	42.8	127.3	15.2
20/12/2023 14:00	35.58	4.5	0.2	41.9	127.9	15.1
20/12/2023 15:00	33.92	4.6	0.2	39.8	127.7	14.4
20/12/2023 16:00	33.59	4.6	0.2	39.5	127.6	14.3
20/12/2023 17:00	33.35	4.5	0.2	39.3	127.5	14.2
20/12/2023 18:00	32.87	4.5	0.2	38.8	127.3	14
20/12/2023 19:00	32.71	4.5	0.2	38.7	128.4	13.9
20/12/2023 20:00	32.89	4.5	0.2	38.8	127.9	14
20/12/2023 21:00	32.79	4.5	0.2	38.6	127.9	13.9
20/12/2023 22:00	32.52	4.6	0.2	38.2	127.8	13.8
20/12/2023 23:00	33.33	4.6	0.2	39.1	127.4	14.1
21/12/2023 00:00	34.25	4.6	0.2	40.2	127.2	14.5
21/12/2023 01:00	34.54	4.6	0.2	40.5	127.1	14.7
21/12/2023 02:00	34.93	4.7	0.2	40.7	127.3	14.8
21/12/2023 03:00	35.66	4.8	0.2	41.3	126.9	15.1
21/12/2023 04:00	35.92	4.8	0.2	41.7	126.6	15.2
21/12/2023 05:00	36	4.7	0.2	41.8	126.6	15.3
21/12/2023 06:00	35.96	4.8	0.2	41.7	126.3	15.3
21/12/2023 07:00	36.06	4.8	0.2	41.8	126.6	15.3

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
21/12/2023 08:00	36.34	4.7	0.2	42.4	126.4	15.4
21/12/2023 09:00	36.83	4.7	0.2	42.9	126.2	15.6
21/12/2023 10:00	36.74	4.6	0.2	43.1	126.3	15.6
21/12/2023 11:00	36.58	4.5	0.2	43.1	126.7	15.5
21/12/2023 12:00	36.37	4.3	0.2	43.3	126.7	15.4
21/12/2023 13:00	36.89	4.5	0.2	43.5	127.4	15.7
21/12/2023 14:00	37.49	4.8	0.2	43.5	128	15.9
21/12/2023 15:00	36.8	4.6	0.2	43	127.9	15.6
21/12/2023 16:00	37.35	4.6	0.2	43.7	127.5	15.9
21/12/2023 17:00	36.86	4.6	0.2	43.3	126.7	15.6
21/12/2023 18:00	36.88	4.6	0.2	43.3	126.6	15.7
21/12/2023 19:00	36.99	4.7	0.2	43.2	126.7	15.7
21/12/2023 20:00	36.72	4.6	0.2	43.1	126.8	15.6
21/12/2023 21:00	36.85	4.7	0.2	43	126.6	15.6
21/12/2023 22:00	37.12	4.8	0.2	42.9	127	15.8
21/12/2023 23:00	37.35	4.8	0.2	43.2	127.3	15.9
22/12/2023 00:00	37.61	4.7	0.2	43.8	126.9	16
22/12/2023 01:00	38.09	4.8	0.2	44.1	126.4	16.2
22/12/2023 02:00	38.31	4.9	0.2	44.2	126.4	16.3
22/12/2023 03:00	38.29	4.9	0.2	44.2	126.2	16.3
22/12/2023 04:00	38.12	4.9	0.2	43.9	125.9	16.2
22/12/2023 05:00	38.43	5	0.3	44.1	125.9	16.3
22/12/2023 06:00	38.61	5	0.3	44.3	125.6	16.4
22/12/2023 07:00	38.65	4.9	0.3	44.4	125.5	16.4
22/12/2023 08:00	39.13	5	0.2	44.6	125.3	16.6
22/12/2023 09:00	38.57	4.8	0.2	44.6	124.9	16.4
22/12/2023 10:00	39.03	4.8	0.2	45.2	125.6	16.6
22/12/2023 11:00	39.29	4.9	0.2	45.1	126.6	16.7
22/12/2023 12:00	39.07	4.9	0.2	45	126.6	16.6
22/12/2023 13:00	39.09	4.8	0.2	45.1	126.4	16.6
22/12/2023 14:00	39.26	4.8	0.2	45.3	126.5	16.7
22/12/2023 15:00	39.52	4.9	0.2	45.5	126.7	16.8
22/12/2023 16:00	39.22	4.8	0.2	45.3	126.4	16.6
22/12/2023 17:00	38.96	4.8	0.2	45.2	126.3	16.5
22/12/2023 18:00	39.04	4.8	0.2	45.1	126.7	16.6
22/12/2023 19:00	38.9	4.9	0.2	44.9	126.4	16.5
22/12/2023 20:00	38.9	4.8	0.2	45.1	126.5	16.5
22/12/2023 21:00	38.8	4.9	0.2	44.7	126.6	16.5
22/12/2023 22:00	39.54	4.9	0.2	45.5	126.2	16.8
22/12/2023 23:00	39.75	4.9	0.2	45.7	126.2	16.9
23/12/2023 00:00	39.58	4.9	0.2	45.4	126.7	16.8
23/12/2023 01:00	40.32	5.1	0.2	45.7	126.6	17.1
23/12/2023 02:00	39.82	4.9	0.3	45.7	125.7	16.9
23/12/2023 03:00	39.69	5	0.3	45.5	125.8	16.8
23/12/2023 04:00	39.72	5.1	0.3	45.1	125.7	16.9
23/12/2023 05:00	39.53	5.1	0.3	45.1	125.8	16.8
23/12/2023 06:00	39.63	5.2	0.3	44.9	125.9	16.8
23/12/2023 07:00	39.42	5	0.3	45	125.8	16.7
23/12/2023 08:00	39.92	5.2	0.3	45	126.1	16.9
23/12/2023 09:00	39.65	5	0.2	45.2	125.8	16.8
23/12/2023 10:00	40.19	5.2	0.2	45.3	126.4	17.1
23/12/2023 11:00	39.33	4.9	0.2	45.2	126.8	16.7
23/12/2023 12:00	39.53	4.8	0.2	45.9	126.1	16.8
23/12/2023 13:00	39.57	4.8	0.2	45.8	126.4	16.8
23/12/2023 14:00	40.1	5.1	0.2	45.6	127.3	17
23/12/2023 15:00	39.93	5	0.2	45.7	127.4	16.9
23/12/2023 16:00	39.76	5	0.2	45.5	127.4	16.9
23/12/2023 17:00	39.65	5	0.2	45.4	126.9	16.8
23/12/2023 18:00	39.84	5	0.2	45.6	126.7	16.9
23/12/2023 19:00	39.59	5	0.2	45.3	127.4	16.8
23/12/2023 20:00	39.46	5.1	0.2	44.9	127.5	16.8

Site Report - GPSC CUP2 AB21						
Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
23/12/2023 21:00	39.66	5	0.2	45.2	127.3	16.8
23/12/2023 22:00	39.6	5	0.2	45.4	126.7	16.8
23/12/2023 23:00	39.67	5	0.2	45.3	126.7	16.8
24/12/2023 00:00	39.7	5	0.2	45.3	126.7	16.8
24/12/2023 01:00	39.82	5.1	0.2	45.3	126.8	16.9
24/12/2023 02:00	40.37	5.2	0.2	45.7	126.7	17.1
24/12/2023 03:00	39.64	5.1	0.2	45.1	126.8	16.8
24/12/2023 04:00	39.83	5	0.2	45.5	126.6	16.9
24/12/2023 05:00	39.98	5.2	0.2	45.1	126.6	17
24/12/2023 06:00	40.05	5.2	0.2	45.3	126.6	17
24/12/2023 07:00	39.81	5.1	0.3	45.3	126.3	16.9
24/12/2023 08:00	39.71	5.2	0.2	44.8	126.7	16.9
24/12/2023 09:00	39.52	5.1	0.2	44.8	126.7	16.8
24/12/2023 10:00	39.25	5.1	0.2	44.7	126.1	16.7
24/12/2023 11:00	39.75	5.3	0.2	44.6	126.7	16.9
24/12/2023 12:00	38.97	5.2	0.2	44.1	126.7	16.5
24/12/2023 13:00	38.96	5.1	0.2	44.4	126.3	16.5
24/12/2023 14:00	39.42	5.2	0.2	44.7	126.5	16.7
24/12/2023 15:00	39.14	5.1	0.2	44.4	126.6	16.6
24/12/2023 16:00	39.42	5.2	0.2	44.6	126.5	16.7
24/12/2023 17:00	39.11	5.1	0.2	44.3	126.8	16.6
24/12/2023 18:00	39.37	5.2	0.2	44.5	126.9	16.7
24/12/2023 19:00	39.31	5.1	0.2	44.6	126.8	16.7
24/12/2023 20:00	39.17	5.1	0.2	44.4	127	16.6
24/12/2023 21:00	39.15	5.1	0.2	44.6	126.6	16.6
24/12/2023 22:00	39.42	5.1	0.2	44.9	126.8	16.7
24/12/2023 23:00	39.51	5.2	0.2	44.7	127.1	16.8
25/12/2023 00:00	39.25	5.1	0.2	44.7	126.9	16.7
25/12/2023 01:00	39.42	5.2	0.2	44.5	127	16.7
25/12/2023 02:00	39.48	5.2	0.2	44.6	127	16.8
25/12/2023 03:00	39.32	5.1	0.2	44.6	126.9	16.7
25/12/2023 04:00	39.52	5.2	0.2	44.7	126.5	16.8
25/12/2023 05:00	39.38	5	0.2	44.9	126.2	16.7
25/12/2023 06:00	39.74	5.1	0.2	45.1	126.3	16.9
25/12/2023 07:00	39.39	5.1	0.2	44.7	126.6	16.7
25/12/2023 08:00	39.76	5.3	0.2	44.8	126.8	16.9
25/12/2023 09:00	39.32	5.1	0.2	44.8	126.5	16.7
25/12/2023 10:00	39.61	5	0.2	45.2	126.1	16.8
25/12/2023 11:00	39.84	5.1	0.2	45.3	126.8	16.9
25/12/2023 12:00	39.99	5.1	0.2	45.6	127	17
25/12/2023 13:00	40.03	5	0.2	45.8	127.2	17
25/12/2023 14:00	40.26	5.1	0.2	45.8	127.6	17.1
25/12/2023 15:00	39.87	5	0.2	45.7	127.2	16.9
25/12/2023 16:00	39.5	4.9	0.2	45.4	127.2	16.8
25/12/2023 17:00	39.5	5	0.2	45.2	126.9	16.8
25/12/2023 18:00	39.24	4.9	0.2	45.2	127.2	16.7
25/12/2023 19:00	39.44	5	0.2	45.2	127.2	16.7
25/12/2023 20:00	39.87	4.9	0.2	45.9	126.7	16.9
25/12/2023 21:00	39.79	4.9	0.2	45.9	126.8	16.9
25/12/2023 22:00	39.99	5	0.2	45.9	126.8	17
25/12/2023 23:00	39.88	4.9	0.2	45.8	127	16.9
26/12/2023 00:00	39.65	5	0.2	45.5	127.3	16.8
26/12/2023 01:00	39.56	4.9	0.2	45.4	127.3	16.8
26/12/2023 02:00	39.74	5	0.2	45.5	127	16.9
26/12/2023 03:00	39.46	5	0.2	45.1	127	16.7
26/12/2023 04:00	39.35	5.1	0.2	44.7	126.9	16.7
26/12/2023 05:00	39.17	5	0.2	44.9	126.9	16.7
26/12/2023 06:00	39.41	5	0.2	45	126.7	16.7
26/12/2023 07:00	39.31	5	0.2	44.9	126.4	16.7
26/12/2023 08:00	39.39	5	0.2	45	126.6	16.7
26/12/2023 09:00	39.31	4.9	0.2	45.4	126	16.7

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
28/12/2023 23:00	36.1	5	0.2	41.3	127.8	15.3
29/12/2023 00:00	35.81	4.7	0.2	41.6	127.2	15.2
29/12/2023 01:00	36.06	4.7	0.2	41.9	127.3	15.3
29/12/2023 02:00	35.73	4.5	0.2	42.2	126.3	15.2
29/12/2023 03:00	35.6	4.3	0.2	42.5	125.9	15.1
29/12/2023 04:00	35.7	4.2	0.2	42.8	125.4	15.2
29/12/2023 05:00	35.95	4.3	0.2	42.9	125.5	15.3
29/12/2023 06:00	36.09	4.3	0.2	43.1	125.5	15.3
29/12/2023 07:00	36.11	4.3	0.2	43.1	125.5	15.3
29/12/2023 08:00	36.07	4.3	0.2	43.2	125.8	15.3
29/12/2023 09:00	36.12	4.2	0.2	43.5	126.2	15.3
29/12/2023 10:00	35.65	3.9	0.2	43.6	125.4	15.1
29/12/2023 11:00	35.45	3.8	0.2	43.5	125.5	15
29/12/2023 12:00	36.09	4.1	0.2	43.7	126	15.3
29/12/2023 13:00	36.44	4.2	0.2	43.8	127.1	15.5
29/12/2023 14:00	36.13	4.3	0.2	43.1	127.4	15.3
29/12/2023 15:00	35.07	4.3	0.2	41.9	127.3	14.9
29/12/2023 16:00	35.33	4.4	0.2	42	127	15
29/12/2023 17:00	34.88	4.2	0.2	42	127	14.8
29/12/2023 18:00	35.08	4.3	0.2	41.9	127.5	14.9
29/12/2023 19:00	34.76	4.2	0.2	41.7	127.9	14.8
29/12/2023 20:00	34.4	4.3	0.2	41.2	127.9	14.6
29/12/2023 21:00	34.22	4.3	0.2	40.9	127.6	14.5
29/12/2023 22:00	34.06	4.2	0.2	40.9	127.3	14.5
29/12/2023 23:00	34.34	4.2	0.2	41.3	126.6	14.6
30/12/2023 00:00	35.22	4.3	0.2	42.2	126.3	15
30/12/2023 01:00	35.97	4.3	0.2	42.9	126.2	15.3
30/12/2023 02:00	36.53	4.3	0.2	43.5	125.9	15.5
30/12/2023 03:00	36.76	4.3	0.2	43.8	125.4	15.6
30/12/2023 04:00	36.36	4.2	0.2	43.6	125.3	15.4
30/12/2023 05:00	36.53	4.4	0.2	43.5	125.5	15.5
30/12/2023 06:00	36.38	4.3	0.2	43.3	125.5	15.4
30/12/2023 07:00	36.05	4.3	0.2	43.2	125.7	15.3
30/12/2023 08:00	36.02	4.3	0.2	42.9	126.1	15.3
30/12/2023 09:00	36.23	4.4	0.2	43.1	126.7	15.4
30/12/2023 10:00	36.39	4.4	0.2	43.2	126.6	15.4
30/12/2023 11:00	35.96	4.1	0.2	43.4	126.8	15.3
30/12/2023 12:00	36.71	4.3	0.2	44	127.1	15.6
30/12/2023 13:00	35.58	4.2	0.2	42.8	127.3	15.1
30/12/2023 14:00	35.09	4.1	0.2	42.4	126.6	14.9
30/12/2023 15:00	35.41	4.4	0.2	42	127	15
30/12/2023 16:00	34.1	4.2	0.2	41	126.8	14.5
30/12/2023 17:00	34.43	4.3	0.2	41	126.4	14.6
30/12/2023 18:00	34.07	4.3	0.2	40.8	126.5	14.5
30/12/2023 19:00	34.09	4.3	0.2	40.8	127.1	14.5
30/12/2023 20:00	33.62	4.2	0.2	40.5	127.1	14.3
30/12/2023 21:00	33.2	4.1	0.2	40	127.3	14.1
30/12/2023 22:00	33.36	4.2	0.2	40.1	127	14.2
30/12/2023 23:00	33.49	4.2	0.2	40.3	126.7	14.2
31/12/2023 00:00	33.61	4.2	0.2	40.4	126.7	14.3
31/12/2023 01:00	33.68	4.2	0.2	40.5	126.7	14.3
31/12/2023 02:00	33.87	4.2	0.2	40.8	126.1	14.4
31/12/2023 03:00	34.3	4.2	0.2	41.2	126.3	14.6
31/12/2023 04:00	34.36	4.2	0.2	41.2	126	14.6
31/12/2023 05:00	34.45	4.2	0.2	41.3	125.8	14.6
31/12/2023 06:00	34.5	4.2	0.2	41.5	125.7	14.6
31/12/2023 07:00	34.83	4.3	0.2	41.7	126.1	14.8
31/12/2023 08:00	34.54	4.1	0.2	41.7	126.3	14.7
31/12/2023 09:00	35.21	4.2	0.2	42.3	126.3	14.9
31/12/2023 10:00	35.97	4.4	0.2	42.7	126.7	15.3
31/12/2023 11:00	36.16	4.5	0.2	42.8	127.1	15.3

Site Report - GPSC CUP2 AB21

Date&Time	NOx@7%O2	O2	Flow	NOx	Temp	NOx@15%O2
	ppm	%Vol	km3/h	ppm	Deg C	ppm
31/12/2023 12:00	36.9	4.6	0.2	43.2	128.3	15.7
31/12/2023 13:00	36.67	4.6	0.2	42.9	128.3	15.6
31/12/2023 14:00	35.51	4.8	0.2	41.1	128.2	15.1
31/12/2023 15:00	35.55	4.8	0.2	41.1	128	15.1
31/12/2023 16:00	35.54	4.6	0.2	41.6	127.7	15.1
31/12/2023 17:00	35.24	4.4	0.2	41.8	126.9	15
31/12/2023 18:00	35.68	4.6	0.2	41.9	127	15.1
31/12/2023 19:00	34.73	4.4	0.2	41.1	127.6	14.7
31/12/2023 20:00	34.82	4.6	0.2	40.9	127.9	14.8
31/12/2023 21:00	34.2	4.5	0.2	40.4	127.9	14.5
31/12/2023 22:00	33.72	4.2	0.2	40.5	127.2	14.3
31/12/2023 23:00	33.72	4.2	0.2	40.5	127.1	14.3
Minimum	26.89	3.6	0	32.6	123.9	11.4
MinDate	12/12/2023 07:00	11/12/2023 23:00	01/12/2023 13:00	12/12/2023 23:00	07/12/2023 19:00	12/12/2023 07:00
Maximum	40.37	5.3	8	45.9	129.6	17.1
MaxDate	24/12/2023 02:00	24/12/2023 11:00	01/12/2023 12:00	23/12/2023 12:00	17/12/2023 15:00	23/12/2023 01:00
Avg	33.59	4.6	0.3	39.3	127.5	14.3
Num	742	742	742	742	744	742
Data[%]	99.6	99.6	99.6	99.6	99.9	99.6
STD	3.7	0.3	0.4	3.9	0.9	1.6

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
01/07/2023 00:00	11.2	46.21	0.08	0
01/07/2023 01:00	11.2	46.08	0.08	0
01/07/2023 02:00	11.3	62.52	0.08	0
01/07/2023 03:00	11.1	59.49	0.08	0
01/07/2023 04:00	10.9	53.04	0.08	0
01/07/2023 05:00	10.8	49.67	0.08	0
01/07/2023 06:00	10.8	47.98	0.08	0
01/07/2023 07:00	10.8	44.83	0.08	0
01/07/2023 08:00	10.8	45.85	0.08	0
01/07/2023 09:00	10.9	44.95	0.08	0
01/07/2023 10:00	10.9	46.22	0.08	0
01/07/2023 11:00	10.9	46.84	0.08	0
01/07/2023 12:00	11	46	0.08	0
01/07/2023 13:00	11	44.92	0.08	0
01/07/2023 14:00	11	44.07	0.08	0
01/07/2023 15:00	11	46.57	0.08	0
01/07/2023 16:00	11	49.75	0.08	0
01/07/2023 17:00	11.1	64.6	0.08	0
01/07/2023 18:00	11.1	50.76	0.08	0
01/07/2023 19:00	11.1	46.87	0.08	0
01/07/2023 20:00	11.1	44.35	0.08	0
01/07/2023 21:00	11.1	44.67	0.08	0
01/07/2023 22:00	11.1	44.02	0.08	0
01/07/2023 23:00	11.1	46.63	0.08	0
02/07/2023 00:00	11	45.06	0.08	0
02/07/2023 01:00	11	45.08	0.08	0
02/07/2023 02:00	10.9	45.18	0.08	0
02/07/2023 03:00	10.9	43.33	0.08	0
02/07/2023 04:00	10.9	43.26	0.08	0
02/07/2023 05:00	10.9	43.34	0.08	0
02/07/2023 06:00	10.9	48.05	0.08	0
02/07/2023 07:00	10.9	52.03	0.08	0
02/07/2023 08:00	10.9	47.63	0.08	0
02/07/2023 09:00	10.9	45.77	0.08	0
02/07/2023 10:00	11	43.94	0.08	0
02/07/2023 11:00	11	43.57	0.08	0
02/07/2023 12:00	11.1	43.47	0.08	0
02/07/2023 13:00	11.1	42.88	0.08	0
02/07/2023 14:00	11.1	38.01	0.08	0
02/07/2023 15:00	11.1	38.37	0.08	0
02/07/2023 16:00	11.1	40.27	0.08	0
02/07/2023 17:00	11.1	40.29	0.08	0
02/07/2023 18:00	11.1	43.01	0.08	0
02/07/2023 19:00	11.1	44.71	0.08	0
02/07/2023 20:00	11.1	42.69	0.08	0
02/07/2023 21:00	11.1	43.12	0.08	0
02/07/2023 22:00	11	43.34	0.08	0
02/07/2023 23:00	11	43.75	0.08	0
03/07/2023 00:00	10.9	41.43	0.08	0
03/07/2023 01:00	10.9	43.19	0.08	0
03/07/2023 02:00	11	42.34	0.08	0
03/07/2023 03:00	11	40.76	0.08	0
03/07/2023 04:00	11	41.61	0.08	0
03/07/2023 05:00	11	40.7	0.08	0
03/07/2023 06:00	11	41.08	0.08	0
03/07/2023 07:00	11.1	41.21	0.08	0
03/07/2023 08:00	11.1	42.19	0.08	0
03/07/2023 09:00	11.1	41.45	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
03/07/2023 10:00	11	40.2	0.08	0
03/07/2023 11:00	11	40.31	0.08	0
03/07/2023 12:00	11.1	40.25	0.08	0
03/07/2023 13:00	11.1	40.09	0.08	0
03/07/2023 14:00	11.2	56.65	0.08	0
03/07/2023 15:00	11.2	44.52	0.08	0
03/07/2023 16:00	11.2	41.56	0.08	0
03/07/2023 17:00	11.2	39.27	0.08	0
03/07/2023 18:00	11.3	53.27	0.08	0
03/07/2023 19:00	11.2	51.39	0.08	0
03/07/2023 20:00	11.1	48.43	0.08	0
03/07/2023 21:00	11.1	45.64	0.08	0
03/07/2023 22:00	11.1	43.16	0.08	0
03/07/2023 23:00	11.1	43.03	0.08	0
04/07/2023 00:00	11	41.93	0.08	0
04/07/2023 01:00	11	41.77	0.08	0
04/07/2023 02:00	11	41.61	0.08	0
04/07/2023 03:00	10.9	40.44	0.08	0
04/07/2023 04:00	10.9	41.31	0.08	0
04/07/2023 05:00	10.9	42.91	0.08	0
04/07/2023 06:00	10.9	40.9	0.08	0
04/07/2023 07:00	11	43.53	0.08	0
04/07/2023 08:00	11	40.62	0.08	0
04/07/2023 09:00	11	41.4	0.08	0
04/07/2023 10:00	10.8	41.05	0.08	0
04/07/2023 11:00	10.8	40.38	0.08	0
04/07/2023 12:00	10.9	40.82	0.08	0
04/07/2023 13:00	11	39.34	0.08	0
04/07/2023 14:00	11.1	38.99	0.08	0
04/07/2023 15:00	11.2	38.25	0.08	0
04/07/2023 16:00	11.2	40.18	0.08	0
04/07/2023 17:00	11.2	40.88	0.08	0
04/07/2023 18:00	11.3	38.96	0.08	0
04/07/2023 19:00	11.3	41.49	0.08	0
04/07/2023 20:00	11.3	42.18	0.08	0
04/07/2023 21:00	11.2	42.85	0.08	0
04/07/2023 22:00	11.1	43.5	0.08	0
04/07/2023 23:00	11.2	43.62	0.08	0
05/07/2023 00:00	11.2	42.3	0.08	0
05/07/2023 01:00	11.2	43.05	0.08	0
05/07/2023 02:00	11.2	44.1	0.08	0
05/07/2023 03:00	11.2	44.64	0.08	0
05/07/2023 04:00	11.2	43.59	0.08	0
05/07/2023 05:00	11.2	43.72	0.08	0
05/07/2023 06:00	11.2	43.37	0.08	0
05/07/2023 07:00	11.2	42.68	0.08	0
05/07/2023 08:00	11.3	42.74	0.08	0
05/07/2023 09:00	11.2	41.79	0.08	0
05/07/2023 10:00	11.2	41.06	0.08	0
05/07/2023 11:00	11.3	41.28	0.08	0
05/07/2023 12:00	11.3	41.32	0.08	0
05/07/2023 13:00	11.4	39.9	0.08	0
05/07/2023 14:00	11.5	37.51	0.08	0
05/07/2023 15:00	11.6	37.7	0.08	0
05/07/2023 16:00	11.7	37.25	0.08	0
05/07/2023 17:00	11.7	39.64	0.08	0
05/07/2023 18:00	11.7	40.68	0.08	0
05/07/2023 19:00	11.6	38.61	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
05/07/2023 20:00	11.6	39.27	0.08	0
05/07/2023 21:00	11.5	43.4	0.08	0
05/07/2023 22:00	11.4	43.2	0.08	0
05/07/2023 23:00	11.4	41.93	0.08	0
06/07/2023 00:00	11.3	42.06	0.08	0
06/07/2023 01:00	11.3	41.12	0.08	0
06/07/2023 02:00	11.2	51.62	0.08	0
06/07/2023 03:00	11.2	46.52	0.08	0
06/07/2023 04:00	11.1	46.2	0.08	0
06/07/2023 05:00	11	45.52	0.08	0
06/07/2023 06:00	11	44.71	0.08	0
06/07/2023 07:00	11.1	40.96	0.08	0
06/07/2023 08:00	11.2	40.74	0.08	0
06/07/2023 09:00	11.2	41.85	0.08	0
06/07/2023 10:00	11.3	40.8	0.08	0
06/07/2023 11:00	11.4	40.79	0.08	0
06/07/2023 12:00	11.5	39.57	0.08	0
06/07/2023 13:00	11.6	40.29	0.08	0
06/07/2023 14:00	11.7	39.06	0.08	0
06/07/2023 15:00	11.8	37.31	0.08	0
06/07/2023 16:00	11.9	38.2	0.08	0
06/07/2023 17:00	11.9	39.56	0.08	0
06/07/2023 18:00	11.9	40.89	0.08	0
06/07/2023 19:00	11.9	41.8	0.08	0
06/07/2023 20:00	11.9	41.54	0.08	0
06/07/2023 21:00	11.8	40.62	0.08	0
06/07/2023 22:00	11.8	40.48	0.08	0
06/07/2023 23:00	11.7	40.44	0.08	0
07/07/2023 00:00	11.7	41.82	0.08	0
07/07/2023 01:00	11.7	49.31	0.08	0
07/07/2023 02:00	11.6	47.48	0.08	0
07/07/2023 03:00	11.6	45.96	0.08	0
07/07/2023 04:00	11.5	44.4	0.08	0
07/07/2023 05:00	11.5	43.04	0.08	0
07/07/2023 06:00	11.5	44.31	0.08	0
07/07/2023 07:00	11.5	43.03	0.08	0
07/07/2023 08:00	11.6	42.34	0.08	0
07/07/2023 09:00	11.6	41.37	0.08	0
07/07/2023 10:00	11.6	41.75	0.08	0
07/07/2023 11:00	11.6	40.78	0.08	0
07/07/2023 12:00	11.6	41.25	0.08	0
07/07/2023 13:00	11.3	46.25	0.08	0
07/07/2023 14:00	11.2	48.61	0.08	0
07/07/2023 15:00	11.1	48	0.08	0
07/07/2023 16:00	11.1	61.08	0.08	0
07/07/2023 17:00	11.1	57.8	0.08	0
07/07/2023 18:00	11.2	50.02	0.08	0
07/07/2023 19:00	11.2	46.46	0.08	0
07/07/2023 20:00	11.2	45.34	0.08	0
07/07/2023 21:00	11.2	45.61	0.08	0
07/07/2023 22:00	11.3	44.05	0.08	0
07/07/2023 23:00	11.3	42.16	0.08	0
08/07/2023 00:00	11.3	41.42	0.08	0
08/07/2023 01:00	11.4	42.42	0.08	0
08/07/2023 02:00	11.4	42.08	0.08	0
08/07/2023 03:00	11.4	44.7	0.08	0
08/07/2023 04:00	11.3	42.41	0.08	0
08/07/2023 05:00	11.2	107.14	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
08/07/2023 06:00	11.2	90.88	0.08	0
08/07/2023 07:00	11.3	63.11	0.08	0
08/07/2023 08:00	11.3	52.9	0.08	0
08/07/2023 09:00	11.2	47.54	0.08	0
08/07/2023 10:00	11.1	47.3	0.08	0
08/07/2023 11:00	11.1	45.86	0.08	0
08/07/2023 12:00	10.9	50.6	0.08	0
08/07/2023 13:00	10.9	138.57	0.08	0
08/07/2023 14:00	11.2	84.72	0.08	0
08/07/2023 15:00	11.3	65.42	0.08	0
08/07/2023 16:00	11.3	58.46	0.08	0
08/07/2023 17:00	11.2	51.43	0.08	0
08/07/2023 18:00	11.2	47.38	0.08	0
08/07/2023 19:00	11.1	44.54	0.08	0
08/07/2023 20:00	11.1	43.99	0.08	0
08/07/2023 21:00	11	43.29	0.08	0
08/07/2023 22:00	10.9	44.51	0.08	0
08/07/2023 23:00	10.9	43.69	0.08	0
09/07/2023 00:00	10.9	43.82	0.08	0
09/07/2023 01:00	10.8	43.4	0.08	0
09/07/2023 02:00	10.7	44.52	0.08	0
09/07/2023 03:00	10.7	44.04	0.08	0
09/07/2023 04:00	10.6	44.02	0.08	0
09/07/2023 05:00	10.6	42.92	0.08	0
09/07/2023 06:00	10.6	44.14	0.08	0
09/07/2023 07:00	10.6	43.94	0.08	0
09/07/2023 08:00	10.7	43.61	0.08	0
09/07/2023 09:00	10.7	44.55	0.08	0
09/07/2023 10:00	10.6	41.96	0.08	0
09/07/2023 11:00	10.6	41.22	0.08	0
09/07/2023 12:00	10.5	41.67	0.08	0
09/07/2023 13:00	10.4	47.29	0.08	0
09/07/2023 14:00	10.4	48.67	0.08	0
09/07/2023 15:00	10.4	48.94	0.08	0
09/07/2023 16:00	10.4	48.37	0.08	0
09/07/2023 17:00	10.4	51.49	0.08	0
09/07/2023 18:00	10.5	48.19	0.08	0
09/07/2023 19:00	10.5	45.38	0.08	0
09/07/2023 20:00	10.5	44.49	0.08	0
09/07/2023 21:00	10.5	44.84	0.08	0
09/07/2023 22:00	10.6	44.03	0.08	0
09/07/2023 23:00	10.6	43.93	0.08	0
10/07/2023 00:00	10.7	45.11	0.08	0
10/07/2023 01:00	10.7	45.58	0.08	0
10/07/2023 02:00	10.7	48.07	0.08	0
10/07/2023 03:00	10.8	45.61	0.08	0
10/07/2023 04:00	10.8	43.65	0.08	0
10/07/2023 05:00	10.8	52.22	0.08	0
10/07/2023 06:00	10.9	49.21	0.08	0
10/07/2023 07:00	10.9	42.23	0.08	0
10/07/2023 08:00	10.9	42.45	0.08	0
10/07/2023 09:00	10.9	68.67	0.08	0
10/07/2023 10:00	11.7	92.95	0.08	0
10/07/2023 11:00	12.4	59.58	0.08	0
10/07/2023 12:00	12	52.19	0.08	0
10/07/2023 13:00	11.9	48.91	0.08	0
10/07/2023 14:00	11.8	45.31	0.08	0
10/07/2023 15:00	11.7	45.29	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
10/07/2023 16:00	11.6	44.6	0.08	0
10/07/2023 17:00	11.5	43.5	0.08	0
10/07/2023 18:00	11.4	42.64	0.08	0
10/07/2023 19:00	11.3	42.38	0.08	0
10/07/2023 20:00	11.1	42.7	0.08	0
10/07/2023 21:00	11.1	42.61	0.08	0
10/07/2023 22:00	11	41.97	0.08	0
10/07/2023 23:00	11	41.96	0.08	0
11/07/2023 00:00	11	42.07	0.08	0
11/07/2023 01:00	11	42.8	0.08	0
11/07/2023 02:00	11	40.95	0.08	0
11/07/2023 03:00	11	41.6	0.08	0
11/07/2023 04:00	10.9	44.51	0.08	0
11/07/2023 05:00	10.9	44.63	0.08	0
11/07/2023 06:00	10.9	40.25	0.09	0
11/07/2023 07:00	10.9	51.23	0.08	0
11/07/2023 08:00	10.9	50.01	0.08	0
11/07/2023 09:00	10.9	45.24	0.08	0
11/07/2023 10:00	10.8	42.67	0.08	0
11/07/2023 11:00	10.7	42.28	0.08	0
11/07/2023 12:00	10.8	43.87	0.08	0
11/07/2023 13:00	10.9	40.61	0.08	0
11/07/2023 14:00	10.9	46.46	0.08	0
11/07/2023 15:00	11	42.95	0.08	0
11/07/2023 16:00	11.1	42.27	0.08	0
11/07/2023 17:00	11.1	42.11	0.08	0
11/07/2023 18:00	11.1	39.91	0.08	0
11/07/2023 19:00	11.2	41.86	0.08	0
11/07/2023 20:00	11.2	42.44	0.08	0
11/07/2023 21:00	11.2	42.22	0.08	0
11/07/2023 22:00	11.2	40.44	0.08	0
11/07/2023 23:00	11.2	42.77	0.08	0
12/07/2023 00:00	11.2	43.12	0.08	0
12/07/2023 01:00	11.1	41.58	0.08	0
12/07/2023 02:00	11.1	40.98	0.08	0
12/07/2023 03:00	10.9	40.58	0.08	0
12/07/2023 04:00	10.9	40.34	0.08	0
12/07/2023 05:00	10.9	41.4	0.08	0
12/07/2023 06:00	10.9	43.08	0.08	0
12/07/2023 07:00	10.9	41.61	0.08	0
12/07/2023 08:00	10.9	42.15	0.08	0
12/07/2023 09:00	10.9	40.83	0.08	0
12/07/2023 10:00	10.9	40.36	0.08	0
12/07/2023 11:00	10.9	39.97	0.08	0
12/07/2023 12:00	11	40.22	0.08	0
12/07/2023 13:00	11.2	38.26	0.08	0
12/07/2023 14:00	11.3	37.25	0.08	0
12/07/2023 15:00	11.3	36.69	0.08	0
12/07/2023 16:00	11.4	41.34	0.08	0
12/07/2023 17:00	11.4	47.66	0.08	0
12/07/2023 18:00	11.5	48.46	0.08	0
12/07/2023 19:00	11.5	46.57	0.08	0
12/07/2023 20:00	11.4	43.81	0.08	0
12/07/2023 21:00	11.3	42.12	0.08	0
12/07/2023 22:00	11.3	41.85	0.08	0
12/07/2023 23:00	11.2	40.21	0.08	0
13/07/2023 00:00	11.2	42.76	0.08	0
13/07/2023 01:00	11.2	46.46	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
13/07/2023 02:00	11.2	46.19	0.08	0
13/07/2023 03:00	11.1	49.6	0.08	0
13/07/2023 04:00	11	53.08	0.08	0
13/07/2023 05:00	10.9	50.35	0.08	0
13/07/2023 06:00	10.9	46.35	0.08	0
13/07/2023 07:00	10.9	42.54	0.08	0
13/07/2023 08:00	10.9	41.39	0.08	0
13/07/2023 09:00	10.7	40.88	0.08	0
13/07/2023 10:00	10.7	42.16	0.08	0
13/07/2023 11:00	10.7	45.56	0.08	0
13/07/2023 12:00	10.9	49.29	0.08	0
13/07/2023 13:00	11.1	44.63	0.08	0
13/07/2023 14:00	11.2	41.74	0.08	0
13/07/2023 15:00	11.2	38.5	0.08	0
13/07/2023 16:00	11.2	40.55	0.08	0
13/07/2023 17:00	11.2	41.58	0.08	0
13/07/2023 18:00	11.2	42.74	0.08	0
13/07/2023 19:00	11.2	43.21	0.08	0
13/07/2023 20:00	11.2	42.92	0.08	0
13/07/2023 21:00	11.1	41.58	0.08	0
13/07/2023 22:00	11.1	43.14	0.08	0
13/07/2023 23:00	11.1	46.62	0.08	0
14/07/2023 00:00	11	52.83	0.08	0
14/07/2023 01:00	11	58	0.08	0
14/07/2023 02:00	10.9	56.17	0.08	0
14/07/2023 03:00	10.9	53.05	0.08	0
14/07/2023 04:00	10.8	55.47	0.08	0
14/07/2023 05:00	10.8	54.41	0.08	0
14/07/2023 06:00	10.8	53.42	0.08	0
14/07/2023 07:00	10.8	51.66	0.08	0
14/07/2023 08:00	10.8	47.24	0.08	0
14/07/2023 09:00	10.8	43.13	0.08	0
14/07/2023 10:00	10.7	43.15	0.08	0
14/07/2023 11:00	10.8	43.63	0.08	0
14/07/2023 12:00	11	43	0.08	0
14/07/2023 13:00	11.2	41.72	0.08	0
14/07/2023 14:00	11.3	38.82	0.08	0
14/07/2023 15:00	11.3	37.91	0.08	0
14/07/2023 16:00	11.3	39.75	0.08	0
14/07/2023 17:00	11.3	40.36	0.08	0
14/07/2023 18:00	11.3	40.72	0.08	0
14/07/2023 19:00	11.4	40.91	0.08	0
14/07/2023 20:00	11.5	37.61	0.08	0
14/07/2023 21:00	11.5	39.17	0.08	0
14/07/2023 22:00	11.6	38.65	0.08	0
14/07/2023 23:00	11.7	35.46	0.08	0
15/07/2023 00:00	11.8	34.87	0.08	0
15/07/2023 01:00	12	38.68	0.08	0
15/07/2023 02:00	12.1	38.11	0.08	0
15/07/2023 03:00	12.1	38.17	0.08	0
15/07/2023 04:00	12.2	44.72	0.08	0
15/07/2023 05:00	12.1	51.89	0.08	0
15/07/2023 06:00	12.1	46.49	0.08	0
15/07/2023 07:00	12.1	41.88	0.08	0
15/07/2023 08:00	12.2	40.31	0.08	0
15/07/2023 09:00	12.2	37.89	0.08	0
15/07/2023 10:00	12.2	38.41	0.08	0
15/07/2023 11:00	12.2	41.86	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
15/07/2023 12:00	12.2	44.73	0.08	0
15/07/2023 13:00	12.2	41.3	0.08	0
15/07/2023 14:00	12.1	38.35	0.08	0
15/07/2023 15:00	12.2	35.83	0.08	0
15/07/2023 16:00	12.2	34.96	0.08	0
15/07/2023 17:00	12.2	35.72	0.08	0
15/07/2023 18:00	12.2	35.37	0.08	0
15/07/2023 19:00	12.2	37.68	0.08	0
15/07/2023 20:00	12.2	37.89	0.08	0
15/07/2023 21:00	12.2	37.27	0.08	0
15/07/2023 22:00	12.2	37.32	0.08	0
15/07/2023 23:00	12.1	35.61	0.08	0
16/07/2023 00:00	12.1	37.74	0.08	0
16/07/2023 01:00	12.1	37.6	0.08	0
16/07/2023 02:00	12.1	37.93	0.08	0
16/07/2023 03:00	12.1	37.14	0.08	0
16/07/2023 04:00	12.1	38.49	0.08	0
16/07/2023 05:00	12.1	38.7	0.08	0
16/07/2023 06:00	12.1	38.79	0.08	0
16/07/2023 07:00	12.1	38.61	0.08	0
16/07/2023 08:00	12.1	37.77	0.08	0
16/07/2023 09:00	12.1	36.6	0.08	0
16/07/2023 10:00	12.1	36.68	0.08	0
16/07/2023 11:00	12.1	36.65	0.08	0
16/07/2023 12:00	12.2	36.19	0.08	0
16/07/2023 13:00	12.3	35.8	0.08	0
16/07/2023 14:00	12.3	34.61	0.08	0
16/07/2023 15:00	12.4	34.88	0.08	0
16/07/2023 16:00	12.5	34.77	0.08	0
16/07/2023 17:00	12.5	34.1	0.08	0
16/07/2023 18:00	12.6	34.19	0.08	0
16/07/2023 19:00	12.6	34.31	0.08	0
16/07/2023 20:00	12.6	33.76	0.08	0
16/07/2023 21:00	12.6	33.92	0.08	0
16/07/2023 22:00	12.5	36.3	0.08	0
16/07/2023 23:00	12.5	36.37	0.08	0
17/07/2023 00:00	12.5	35.41	0.08	0
17/07/2023 01:00	12.6	36.32	0.08	0
17/07/2023 02:00	12.6	35.73	0.08	0
17/07/2023 03:00	12.5	40.7	0.08	0
17/07/2023 04:00	12.2	49.04	0.08	0
17/07/2023 05:00	12.3	41.46	0.08	0
17/07/2023 06:00	12.3	38.24	0.08	0
17/07/2023 07:00	12.2	37.23	0.08	0
17/07/2023 08:00	12.2	37.18	0.08	0
17/07/2023 09:00	12.1	36.3	0.08	0
17/07/2023 10:00	12.3	35.41	0.08	0
17/07/2023 11:00	12.3	35.64	0.08	0
17/07/2023 12:00	12.1	36.09	0.08	0
17/07/2023 13:00	12.2	34.99	0.08	0
17/07/2023 14:00	12.3	34.47	0.08	0
17/07/2023 15:00	12.3	33.72	0.08	0
17/07/2023 16:00	12.2	32.55	0.08	0
17/07/2023 17:00	12.2	34.41	0.08	0
17/07/2023 18:00	12.2	35.06	0.08	0
17/07/2023 19:00	12.1	34.58	0.08	0
17/07/2023 20:00	12.1	33.14	0.08	0
17/07/2023 21:00	12.1	31.51	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
17/07/2023 22:00	12	30.86	0.08	0
17/07/2023 23:00	11.9	30.9	0.08	0
18/07/2023 00:00	11.9	30.36	0.08	0
18/07/2023 01:00	12	30.59	0.08	0
18/07/2023 02:00	11.9	29.91	0.08	0
18/07/2023 03:00	11.9	29.65	0.08	0
18/07/2023 04:00	11.9	31.07	0.08	0
18/07/2023 05:00	11.9	31.74	0.08	0
18/07/2023 06:00	11.9	32.46	0.08	0
18/07/2023 07:00	11.9	32.42	0.08	0
18/07/2023 08:00	11.8	31.2	0.08	0
18/07/2023 09:00	11.8	31.32	0.08	0
18/07/2023 10:00	11.9	31.28	0.08	0
18/07/2023 11:00	12	30.02	0.08	0
18/07/2023 12:00	12.1	29.63	0.08	0
18/07/2023 13:00	12.2	28.23	0.08	0
18/07/2023 14:00	12.2	27.07	0.08	0
18/07/2023 15:00	12.2	28.59	0.08	0
18/07/2023 16:00	12.2	28.62	0.08	0
18/07/2023 17:00	12.2	27.71	0.08	0
18/07/2023 18:00	12.2	27.24	0.08	0
18/07/2023 19:00	12.1	26.99	0.08	0
18/07/2023 20:00	12.1	27.64	0.08	0
18/07/2023 21:00	12.1	27.25	0.08	0
18/07/2023 22:00	12.1	26.82	0.08	0
18/07/2023 23:00	12.1	25.83	0.08	0
19/07/2023 00:00	12	26.34	0.08	0
19/07/2023 01:00	12	26.81	0.08	0
19/07/2023 02:00	12	26.65	0.08	0
19/07/2023 03:00	12	27.42	0.08	0
19/07/2023 04:00	12	27.12	0.08	0
19/07/2023 05:00	12	25.81	0.08	0
19/07/2023 06:00	12	26.1	0.08	0
19/07/2023 07:00	12	25.95	0.08	0
19/07/2023 08:00	11.9	25.7	0.08	0
19/07/2023 09:00	12	32.21	0.08	0
19/07/2023 10:00	11.9	31.27	0.08	0
19/07/2023 11:00	12	32.54	0.08	0
19/07/2023 12:00	12.1	31.78	0.08	0
19/07/2023 13:00	12.1	29.43	0.08	0
19/07/2023 14:00	12.2	27.53	0.08	0
19/07/2023 15:00	12.3	24.47	0.08	0
19/07/2023 16:00	12.4	26.8	0.08	0
19/07/2023 17:00	12.6	26.1	0.08	0
19/07/2023 18:00	12.5	25.32	0.08	0
19/07/2023 19:00	12.5	24.68	0.08	0
19/07/2023 20:00	12.4	24.06	0.08	0
19/07/2023 21:00	12.4	23.32	0.08	0
19/07/2023 22:00	12.3	22.65	0.08	0
19/07/2023 23:00	12.3	21.95	0.08	0
20/07/2023 00:00	12.3	21.72	0.08	0
20/07/2023 01:00	12.3	21.61	0.08	0
20/07/2023 02:00	12.3	21.44	0.08	0
20/07/2023 03:00	12.3	20.95	0.08	0
20/07/2023 04:00	12.3	20.75	0.08	0
20/07/2023 05:00	12.3	20.41	0.08	0
20/07/2023 06:00	12.2	20.27	0.08	0
20/07/2023 07:00	12.2	20.26	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
20/07/2023 08:00	12.2	19.8	0.08	0
20/07/2023 09:00	12.2	19.54	0.08	0
20/07/2023 10:00	12.2	19.25	0.08	0
20/07/2023 11:00	12.3	17.92	0.08	0
20/07/2023 12:00	12.4	17.67	0.08	0
20/07/2023 13:00	12.5	16.62	0.08	0
20/07/2023 14:00	12.5	15.59	0.08	0
20/07/2023 15:00	12.4	15.43	0.08	0
20/07/2023 16:00	12.6	16.55	0.08	0
20/07/2023 17:00	12.6	16.85	0.08	0
20/07/2023 18:00	12.5	16.62	0.08	0
20/07/2023 19:00	12.3	16.37	0.08	0
20/07/2023 20:00	12.3	18.36	0.08	0
20/07/2023 21:00	12.1	17.9	0.08	0
20/07/2023 22:00	12.1	24.48	0.08	0
20/07/2023 23:00	12.2	25.64	0.08	0
21/07/2023 00:00	12	25.15	0.08	0
21/07/2023 01:00	11.7	26.01	0.08	0
21/07/2023 02:00	11.6	26.22	0.08	0
21/07/2023 03:00	11.6	26.51	0.08	0
21/07/2023 04:00	11.8	41.23	0.09	0
21/07/2023 05:00	11.8	88.36	0.09	0
21/07/2023 06:00	12	121.59	0.09	0
21/07/2023 07:00	12.1	60.79	0.09	0
21/07/2023 08:00	12.2	41.25	0.09	0
21/07/2023 09:00	12.2	36.74	0.09	0
21/07/2023 10:00	12.1	34.84	0.08	0
21/07/2023 11:00	11.9	32.54	0.08	0
21/07/2023 12:00	11.9	33.13	0.08	0
21/07/2023 13:00	12	31.39	0.08	0
21/07/2023 14:00	11.7	30.08	0.09	0
21/07/2023 15:00	11.7	29.78	0.09	0
21/07/2023 16:00	11.8	28.57	0.08	0
21/07/2023 17:00	11.8	27.11	0.08	0
21/07/2023 18:00	11.9	24.66	0.08	0
21/07/2023 19:00	11.8	23.24	0.08	0
21/07/2023 20:00	11.8	35.37	0.08	0
21/07/2023 21:00	11.7	92.85	0.08	0
21/07/2023 22:00	11.4	169.98	0.08	0
21/07/2023 23:00	11.1	197.25	0.08	0
22/07/2023 00:00	10.9	187.06	0.08	0
22/07/2023 01:00	10.7	220.18	0.08	0
22/07/2023 02:00	11.5	250.61	0.08	0
22/07/2023 03:00	11.7	205.25	0.09	0
22/07/2023 04:00	11.7	153.81	0.08	0
22/07/2023 05:00	11.5	81.32	0.09	0
22/07/2023 06:00	11.5	51.77	0.08	0
22/07/2023 07:00	11.4	44.93	0.09	0
22/07/2023 08:00	11.5	36.44	0.09	0
22/07/2023 09:00	11.5	32.79	0.09	0
22/07/2023 10:00	11.5	31.53	0.08	0
22/07/2023 11:00	11.6	30.32	0.08	0
22/07/2023 12:00	11.7	27.25	0.08	0
22/07/2023 13:00	11.4	26.53	0.08	0
22/07/2023 14:00	11.2	29.25	0.08	0
22/07/2023 15:00	11.3	27.89	0.08	0
22/07/2023 16:00	11.3	27.29	0.08	0
22/07/2023 17:00	11.2	25.23	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
22/07/2023 18:00	11.3	25.35	0.08	0
22/07/2023 19:00	11.4	26.73	0.08	0
22/07/2023 20:00	11.4	25.48	0.08	0
22/07/2023 21:00	11.5	25.32	0.08	0
22/07/2023 22:00	11.4	30.04	0.08	0
22/07/2023 23:00	11.5	30.82	0.09	0
23/07/2023 00:00	11.5	30.2	0.09	0
23/07/2023 01:00	11.5	29.96	0.09	0
23/07/2023 02:00	11.5	28.7	0.09	0
23/07/2023 03:00	11.6	33.72	0.09	0
23/07/2023 04:00	11.6	35.94	0.08	0
23/07/2023 05:00	11.7	32.3	0.09	0
23/07/2023 06:00	11.8	28.96	0.09	0
23/07/2023 07:00	11.7	26.74	0.09	0
23/07/2023 08:00	11.9	26.5	0.09	0
23/07/2023 09:00	11.9	24.96	0.09	0
23/07/2023 10:00	12	22.94	0.08	0
23/07/2023 11:00	11.9	19.05	0.08	0
23/07/2023 12:00	11.6	21.93	0.08	0
23/07/2023 13:00	11.8	23.3	0.08	0
23/07/2023 14:00	11.9	22.53	0.08	0
23/07/2023 15:00	12	22.81	0.08	0
23/07/2023 16:00	12	24.18	0.09	0
23/07/2023 17:00	11.9	24.87	0.08	0
23/07/2023 18:00	12	25.1	0.09	0
23/07/2023 19:00	12	22.54	0.08	0
23/07/2023 20:00	12	20.79	0.08	0
23/07/2023 21:00	12	19.85	0.09	0
23/07/2023 22:00	12	18.21	0.09	0
23/07/2023 23:00	12	16.72	0.09	0
24/07/2023 00:00	12	15.44	0.09	0
24/07/2023 01:00	12	14.59	0.09	0
24/07/2023 02:00	11.9	13.28	0.08	0
24/07/2023 03:00	11.9	13.14	0.08	0
24/07/2023 04:00	11.9	13.16	0.09	0
24/07/2023 05:00	11.9	11.7	0.08	0
24/07/2023 06:00	11.8	11.13	0.09	0
24/07/2023 07:00	11.8	17.57	0.09	0
24/07/2023 08:00	11.8	19.87	0.09	0
24/07/2023 09:00	11.9	19.29	0.08	0
24/07/2023 10:00	11.9	17.76	0.08	0
24/07/2023 11:00	12	16.39	0.08	0
24/07/2023 12:00	12	15.25	0.08	0
24/07/2023 13:00	12	14.74	0.08	0
24/07/2023 14:00	12.1	13.93	0.08	0
24/07/2023 15:00	12.1	13.71	0.08	0
24/07/2023 16:00	12.2	12.8	0.08	0
24/07/2023 17:00	12.2	12.27	0.08	0
24/07/2023 18:00	12.2	12.63	0.08	0
24/07/2023 19:00	12.2	12.83	0.08	0
24/07/2023 20:00	12.1	12.58	0.08	0
24/07/2023 21:00	12	12.84	0.08	0
24/07/2023 22:00	12	13.1	0.08	0
24/07/2023 23:00	11.9	12.65	0.08	0
25/07/2023 00:00	11.8	11.38	0.08	0
25/07/2023 01:00	11.9	11.14	0.08	0
25/07/2023 02:00	11.8	11.29	0.08	0
25/07/2023 03:00	11.8	11.32	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
25/07/2023 04:00	11.9	11.44	0.08	0
25/07/2023 05:00	11.9	11.19	0.09	0
25/07/2023 06:00	11.8	11.36	0.08	0
25/07/2023 07:00	11.8	11.51	0.08	0
25/07/2023 08:00	11.8	11.23	0.08	0
25/07/2023 09:00	11.8	13.03	0.08	0
25/07/2023 10:00	11.8	13.55	0.08	0
25/07/2023 11:00	11.9	11.82	0.08	0
25/07/2023 12:00	12	10.94	0.08	0
25/07/2023 13:00	12	10.79	0.08	0
25/07/2023 14:00	12	10.82	0.08	0
25/07/2023 15:00	12	10.51	0.08	0
25/07/2023 16:00	12	10.57	0.08	0
25/07/2023 17:00	12	9.32	0.08	0
25/07/2023 18:00	12	9.19	0.08	0
25/07/2023 19:00	12	9.72	0.08	0
25/07/2023 20:00	12	9.73	0.08	0
25/07/2023 21:00	12	9.41	0.08	0
25/07/2023 22:00	11.9	9.3	0.08	0
25/07/2023 23:00	12	8.91	0.08	0
26/07/2023 00:00	12	9.76	0.08	0
26/07/2023 01:00	12	10.23	0.08	0
26/07/2023 02:00	12	10.05	0.08	0
26/07/2023 03:00	12	9.63	0.08	0
26/07/2023 04:00	12	9.27	0.08	0
26/07/2023 05:00	12	8.91	0.08	0
26/07/2023 06:00	11.9	8.88	0.08	0
26/07/2023 07:00	11.9	8.92	0.08	0
26/07/2023 08:00	11.9	9.08	0.08	0
26/07/2023 09:00	11.9	8.61	0.08	0
26/07/2023 10:00	12	8.61	0.08	0
26/07/2023 11:00	12	8.27	0.08	0
26/07/2023 12:00	12	7.79	0.08	0
26/07/2023 13:00	12	7.34	0.08	0
26/07/2023 14:00	12	7.13	0.08	0
26/07/2023 15:00	12	6.86	0.08	0
26/07/2023 16:00	12.1	6.34	0.08	0
26/07/2023 17:00	12.1	6.34	0.08	0
26/07/2023 18:00	12.1	6.3	0.08	0
26/07/2023 19:00	12.2	6.66	0.08	0
26/07/2023 20:00	12.1	6.96	0.08	0
26/07/2023 21:00	12.1	7.08	0.08	0
26/07/2023 22:00	12.1	7.25	0.08	0
26/07/2023 23:00	12.1	7.08	0.08	0
27/07/2023 00:00	12.1	6.88	0.08	0
27/07/2023 01:00	12.1	6.96	0.08	0
27/07/2023 02:00	12.1	7.04	0.08	0
27/07/2023 03:00	12.1	7	0.08	0
27/07/2023 04:00	12.2	6.81	0.08	0
27/07/2023 05:00	12.1	7.05	0.08	0
27/07/2023 06:00	12.1	7.11	0.09	0
27/07/2023 07:00	12.1	7.48	0.08	0
27/07/2023 08:00	12.2	7.67	0.08	0
27/07/2023 09:00	12.2	7.63	0.08	0
27/07/2023 10:00	12.2	7.18	0.08	0
27/07/2023 11:00	12.2	6.15	0.08	0
27/07/2023 12:00	12.2	4.96	0.08	0
27/07/2023 13:00	12.3	3.9	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
27/07/2023 14:00	12.3	3.16	0.08	0
27/07/2023 15:00	12.4	1.29	0.08	0
27/07/2023 16:00	12.4	0.86	0.08	0
27/07/2023 17:00	12.4	1.03	0.08	0
27/07/2023 18:00	12.5	0.95	0.08	0
27/07/2023 19:00	12.7	0.61	0.08	0
27/07/2023 20:00	12.7	0.5	0.08	0
27/07/2023 21:00	12.6	0.68	0.08	0
27/07/2023 22:00	12.6	0.71	0.08	0
27/07/2023 23:00	12.6	0.5	0.08	0
28/07/2023 00:00	12.6	0.29	0.08	0
28/07/2023 01:00	12.6	0.3	0.08	0
28/07/2023 02:00	12.6	0.54	0.08	0
28/07/2023 03:00	12.6	0.51	0.08	0
28/07/2023 04:00	12.6	0.37	0.08	0
28/07/2023 05:00	12.5	0.3	0.08	0
28/07/2023 06:00	12.4	0.4	0.08	0
28/07/2023 07:00	12.4	0.65	0.08	0
28/07/2023 08:00	12.5	0.66	0.08	0
28/07/2023 09:00	12.5	0.56	0.08	0
28/07/2023 10:00	12.7	3.55	0.08	0
28/07/2023 11:00	12.8	6.11	0.08	0
28/07/2023 12:00	13	4.78	0.08	0
28/07/2023 13:00	13	3.54	0.08	0
28/07/2023 14:00	13.1	2.39	0.08	0
28/07/2023 15:00	13.1	1.94	0.08	0
28/07/2023 16:00	13.1	1.75	0.08	0
28/07/2023 17:00	13.1	1.08	0.08	0
28/07/2023 18:00	13.1	0.78	0.08	0
28/07/2023 19:00	13.1	0.72	0.08	0
28/07/2023 20:00	13.1	0.81	0.08	0
28/07/2023 21:00	13.1	0.53	0.08	0
28/07/2023 22:00	13	0.51	0.08	0
28/07/2023 23:00	13	0.4	0.08	0
29/07/2023 00:00	12.9	0.62	0.08	0
29/07/2023 01:00	12.9	0.59	0.08	0
29/07/2023 02:00	12.8	0.42	0.08	0
29/07/2023 03:00	12.8	0.39	0.08	0
29/07/2023 04:00	12.7	0.34	0.08	0
29/07/2023 05:00	12.7	0.49	0.08	0
29/07/2023 06:00	12.7	0.53	0.08	0
29/07/2023 07:00	12.7	0.48	0.08	0
29/07/2023 08:00	12.6	0.37	0.08	0
29/07/2023 09:00	<Samp	<Samp	<Samp	0
29/07/2023 10:00	Maintain	Maintain	Maintain	0
29/07/2023 11:00	Maintain	Maintain	Maintain	0
29/07/2023 12:00	Maintain	Maintain	Maintain	0
29/07/2023 13:00	Maintain	Maintain	Maintain	0
29/07/2023 14:00	Maintain	Maintain	Maintain	0
29/07/2023 15:00	Maintain	Maintain	Maintain	0
29/07/2023 16:00	Maintain	Maintain	Maintain	0
29/07/2023 17:00	<Samp	<Samp	<Samp	0
29/07/2023 18:00	12.5	0.36	0.08	0
29/07/2023 19:00	13	0.13	0.08	0
29/07/2023 20:00	12.7	1.73	0.08	0
29/07/2023 21:00	12.8	2.3	0.08	0
29/07/2023 22:00	12.8	1.63	0.08	0
29/07/2023 23:00	12.8	3.12	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
30/07/2023 00:00	12.9	5.17	0.08	0
30/07/2023 01:00	12.8	7.2	0.09	0
30/07/2023 02:00	12.8	11.17	0.09	0
30/07/2023 03:00	12.8	14.09	0.09	0
30/07/2023 04:00	12.7	15.25	0.09	0
30/07/2023 05:00	12.7	16.46	0.09	0
30/07/2023 06:00	12.7	17.68	0.09	0
30/07/2023 07:00	12.7	19.42	0.09	0
30/07/2023 08:00	12.7	20.05	0.09	0
30/07/2023 09:00	12.7	20.6	0.08	0
30/07/2023 10:00	12.8	21.54	0.08	0
30/07/2023 11:00	12.9	21.74	0.08	0
30/07/2023 12:00	13.1	19.44	0.08	0
30/07/2023 13:00	13.2	18	0.08	0
30/07/2023 14:00	13.3	16.93	0.08	0
30/07/2023 15:00	13.3	15.2	0.08	0
30/07/2023 16:00	13.3	14.05	0.08	0
30/07/2023 17:00	13.3	14.15	0.08	0
30/07/2023 18:00	13.1	15.56	0.08	0
30/07/2023 19:00	13.1	15.25	0.08	0
30/07/2023 20:00	13	13.76	0.08	0
30/07/2023 21:00	13	12.89	0.08	0
30/07/2023 22:00	12.9	12.54	0.08	0
30/07/2023 23:00	12.9	12.47	0.09	0
31/07/2023 00:00	12.9	12.44	0.08	0
31/07/2023 01:00	12.9	12.08	0.08	0
31/07/2023 02:00	12.8	11.87	0.08	0
31/07/2023 03:00	12.8	11.68	0.08	0
31/07/2023 04:00	12.8	11.26	0.08	0
31/07/2023 05:00	12.8	11.08	0.09	0
31/07/2023 06:00	12.8	10.83	0.08	0
31/07/2023 07:00	12.8	12.06	0.08	0
31/07/2023 08:00	12.8	14.54	0.08	0
31/07/2023 09:00	12.8	16.99	0.08	0
31/07/2023 10:00	12.8	23.53	0.09	0
31/07/2023 11:00	12.9	30.83	0.08	0
31/07/2023 12:00	12.9	33.02	0.08	0
31/07/2023 13:00	12.9	27.31	0.08	0
31/07/2023 14:00	13	24.04	0.08	0
31/07/2023 15:00	13	21.29	0.08	0
31/07/2023 16:00	13.1	19.48	0.08	0
31/07/2023 17:00	13.1	18.18	0.08	0
31/07/2023 18:00	13	17.19	0.08	0
31/07/2023 19:00	13	16.37	0.08	0
31/07/2023 20:00	12.9	15.64	0.08	0
31/07/2023 21:00	12.9	14.94	0.08	0
31/07/2023 22:00	12.8	14.64	0.08	0
31/07/2023 23:00	12.8	14.16	0.08	0
Minimum	10.4	0.13	0.08	0
MinDate	09/07/2023 13:00	29/07/2023 19:00	01/07/2023 00:00	01/07/2023 00:00
Maximum	13.3	250.61	0.09	0
MaxDate	30/07/2023 14:00	22/07/2023 02:00	11/07/2023 06:00	01/07/2023 00:00
Avg	11.7	33.92	0.08	0
Num	735	735	744	744
Data[%]	98.8	98.8	98.8	100
STD	0.7	23.7	0	0
	8610.3	24928.15	59.28	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
01/08/2023 00:00	12.8	14.67	0.08	0
01/08/2023 01:00	12.8	15.28	0.08	0
01/08/2023 02:00	12.8	15.9	0.08	0
01/08/2023 03:00	12.8	16.71	0.08	0
01/08/2023 04:00	12.8	17.18	0.08	0
01/08/2023 05:00	12.8	17.61	0.08	0
01/08/2023 06:00	12.8	19.24	0.08	0
01/08/2023 07:00	12.8	19.36	0.08	0
01/08/2023 08:00	12.8	19.31	0.08	0
01/08/2023 09:00	12.8	20.16	0.08	0
01/08/2023 10:00	12.9	20.36	0.08	0
01/08/2023 11:00	12.9	20.45	0.08	0
01/08/2023 12:00	13.1	35.5	0.08	0
01/08/2023 13:00	13.5	68.81	0.08	0
01/08/2023 14:00	13.8	90.43	0.08	0
01/08/2023 15:00	13.2	97.05	0.08	0
01/08/2023 16:00	12.3	112.29	0.08	0
01/08/2023 17:00	11.8	120.14	0.08	0
01/08/2023 18:00	11.5	127.89	0.08	0
01/08/2023 19:00	11.4	126.28	0.08	0
01/08/2023 20:00	11.6	120.28	0.08	0
01/08/2023 21:00	12.9	127.9	0.08	0
01/08/2023 22:00	13.9	105.47	0.08	0
01/08/2023 23:00	13.7	99.81	0.08	0
02/08/2023 00:00	13.6	97.93	0.08	0
02/08/2023 01:00	13.5	88.68	0.08	0
02/08/2023 02:00	13.1	90.89	0.08	0
02/08/2023 03:00	13	88.2	0.08	0
02/08/2023 04:00	13	67.82	0.08	0
02/08/2023 05:00	12.9	51.97	0.08	0
02/08/2023 06:00	12.9	51.52	0.08	0
02/08/2023 07:00	12.9	55.78	0.08	0
02/08/2023 08:00	12.9	55.37	0.08	0
02/08/2023 09:00	12.8	55.01	0.08	0
02/08/2023 10:00	12.8	55.26	0.08	0
02/08/2023 11:00	12.8	53.61	0.08	0
02/08/2023 12:00	12.7	50.49	0.08	0
02/08/2023 13:00	12.7	52.45	0.08	0
02/08/2023 14:00	12.7	55.3	0.08	0
02/08/2023 15:00	12.7	53.69	0.08	0
02/08/2023 16:00	12.7	52.32	0.08	0
02/08/2023 17:00	12.7	50.06	0.08	0
02/08/2023 18:00	12.7	53.44	0.08	0
02/08/2023 19:00	12.8	52.86	0.08	0
02/08/2023 20:00	12.8	54.24	0.08	0
02/08/2023 21:00	12.8	56.14	0.08	0
02/08/2023 22:00	12.8	57.27	0.08	0
02/08/2023 23:00	12.8	63.65	0.08	0
03/08/2023 00:00	12.8	63.61	0.08	0
03/08/2023 01:00	12.8	59.28	0.08	0
03/08/2023 02:00	12.8	59.7	0.08	0
03/08/2023 03:00	12.8	57.09	0.08	0
03/08/2023 04:00	12.7	56.06	0.08	0
03/08/2023 05:00	12.7	53.61	0.08	0
03/08/2023 06:00	12.7	55.32	0.08	0
03/08/2023 07:00	12.7	55.27	0.08	0
03/08/2023 08:00	12.7	55.22	0.08	0
03/08/2023 09:00	12.7	54.96	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
03/08/2023 10:00	12.8	58.24	0.08	0
03/08/2023 11:00	12.7	61.59	0.08	0
03/08/2023 12:00	12.6	56.78	0.08	0
03/08/2023 13:00	12.7	56.31	0.08	0
03/08/2023 14:00	12.7	53.65	0.08	0
03/08/2023 15:00	12.7	54.11	0.08	0
03/08/2023 16:00	12.7	57.11	0.08	0
03/08/2023 17:00	12.7	59.86	0.08	0
03/08/2023 18:00	12.7	63.23	0.08	0
03/08/2023 19:00	12.7	68.97	0.08	0
03/08/2023 20:00	12.7	71.56	0.08	0
03/08/2023 21:00	12.7	63.05	0.08	0
03/08/2023 22:00	12.6	64.14	0.08	0
03/08/2023 23:00	12.6	60.72	0.08	0
04/08/2023 00:00	12.6	60.3	0.08	0
04/08/2023 01:00	12.6	56.33	0.08	0
04/08/2023 02:00	12.6	60.77	0.09	0
04/08/2023 03:00	12.6	60.91	0.08	0
04/08/2023 04:00	12.6	61.43	0.08	0
04/08/2023 05:00	12.6	62.35	0.08	0
04/08/2023 06:00	12.6	60.67	0.08	0
04/08/2023 07:00	12.6	60.13	0.08	0
04/08/2023 08:00	12.6	54.01	0.08	0
04/08/2023 09:00	12.6	51.36	0.08	0
04/08/2023 10:00	12.6	49.42	0.08	0
04/08/2023 11:00	12.6	48.39	0.08	0
04/08/2023 12:00	12.7	53.71	0.08	0
04/08/2023 13:00	12.8	50.84	0.08	0
04/08/2023 14:00	12.8	58.8	0.08	0
04/08/2023 15:00	12.8	50.74	0.08	0
04/08/2023 16:00	12.8	41.39	0.08	0
04/08/2023 17:00	12.8	40.16	0.08	0
04/08/2023 18:00	12.9	38.33	0.08	0
04/08/2023 19:00	13	34	0.08	0
04/08/2023 20:00	13	31.44	0.08	0
04/08/2023 21:00	13.2	28.85	0.08	0
04/08/2023 22:00	13.3	27.43	0.08	0
04/08/2023 23:00	13.4	26.18	0.08	0
05/08/2023 00:00	13.4	25.39	0.08	0
05/08/2023 01:00	13.5	25.87	0.08	0
05/08/2023 02:00	13.6	25.15	0.08	0
05/08/2023 03:00	13.7	24.35	0.08	0
05/08/2023 04:00	13.7	23.25	0.08	0
05/08/2023 05:00	13.9	22.52	0.08	0
05/08/2023 06:00	14	22.63	0.08	0
05/08/2023 07:00	14.1	22.47	0.08	0
05/08/2023 08:00	14.1	22	0.08	0
05/08/2023 09:00	14	22.3	0.08	0
05/08/2023 10:00	14.1	21.88	0.08	0
05/08/2023 11:00	14.1	21.67	0.08	0
05/08/2023 12:00	14.1	20.93	0.08	0
05/08/2023 13:00	14.2	19.71	0.08	0
05/08/2023 14:00	14.2	21.44	0.08	0
05/08/2023 15:00	14.3	25.14	0.08	0
05/08/2023 16:00	14.3	25.17	0.08	0
05/08/2023 17:00	14.4	24.85	0.08	0
05/08/2023 18:00	14.4	30.77	0.08	0
05/08/2023 19:00	14.4	33.16	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
05/08/2023 20:00	14.4	29.85	0.08	0
05/08/2023 21:00	14.6	28.83	0.08	0
05/08/2023 22:00	14.6	27.75	0.08	0
05/08/2023 23:00	14.6	27.2	0.08	0
06/08/2023 00:00	14.7	25.91	0.08	0
06/08/2023 01:00	14.7	24.93	0.08	0
06/08/2023 02:00	14.9	24.25	0.08	0
06/08/2023 03:00	15.3	24.03	0.08	0
06/08/2023 04:00	15.4	23.4	0.08	0
06/08/2023 05:00	15.5	21.62	0.08	0
06/08/2023 06:00	15.7	21.36	0.08	0
06/08/2023 07:00	15.6	20.47	0.08	0
06/08/2023 08:00	15.7	19.69	0.08	0
06/08/2023 09:00	15.5	20.68	0.08	0
06/08/2023 10:00	15.4	20.59	0.08	0
06/08/2023 11:00	15.3	19.86	0.08	0
06/08/2023 12:00	15.2	19.33	0.08	0
06/08/2023 13:00	15.1	18.41	0.08	0
06/08/2023 14:00	15.1	18.37	0.08	0
06/08/2023 15:00	15	21.88	0.08	0
06/08/2023 16:00	15	23.24	0.08	0
06/08/2023 17:00	14.9	22.13	0.08	0
06/08/2023 18:00	14.9	21.16	0.08	0
06/08/2023 19:00	14.8	20.29	0.08	0
06/08/2023 20:00	14.7	19.89	0.08	0
06/08/2023 21:00	14.7	20.58	0.08	0
06/08/2023 22:00	14.8	20.79	0.08	0
06/08/2023 23:00	14.7	21.43	0.08	0
07/08/2023 00:00	14.6	22.07	0.08	0
07/08/2023 01:00	14.6	22.44	0.08	0
07/08/2023 02:00	14.6	23.15	0.08	0
07/08/2023 03:00	14.6	23.01	0.08	0
07/08/2023 04:00	14.5	23.64	0.08	0
07/08/2023 05:00	14.5	23.28	0.08	0
07/08/2023 06:00	14.5	22.61	0.08	0
07/08/2023 07:00	14.5	21.95	0.08	0
07/08/2023 08:00	14.5	21.1	0.08	0
07/08/2023 09:00	14.4	21.61	0.08	0
07/08/2023 10:00	14.3	21.86	0.08	0
07/08/2023 11:00	14.3	21.73	0.08	0
07/08/2023 12:00	14.4	21.23	0.08	0
07/08/2023 13:00	14.4	20.73	0.08	0
07/08/2023 14:00	14.4	20.63	0.08	0
07/08/2023 15:00	14.5	20.25	0.08	0
07/08/2023 16:00	14.5	20.34	0.08	0
07/08/2023 17:00	14.4	20.8	0.08	0
07/08/2023 18:00	14.4	20.84	0.08	0
07/08/2023 19:00	14.4	20.99	0.08	0
07/08/2023 20:00	14.4	20.8	0.08	0
07/08/2023 21:00	14.5	22.8	0.08	0
07/08/2023 22:00	14.6	22.73	0.08	0
07/08/2023 23:00	14.7	22.41	0.08	0
08/08/2023 00:00	14.7	22.35	0.08	0
08/08/2023 01:00	14.7	22.73	0.08	0
08/08/2023 02:00	14.8	31.1	0.08	0
08/08/2023 03:00	14.8	28.56	0.08	0
08/08/2023 04:00	14.9	26.73	0.08	0
08/08/2023 05:00	15	26.32	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
08/08/2023 06:00	15.1	25.19	0.08	0
08/08/2023 07:00	15.1	24.27	0.08	0
08/08/2023 08:00	15.2	23.74	0.08	0
08/08/2023 09:00	15.1	23.05	0.08	0
08/08/2023 10:00	15.1	22.04	0.08	0
08/08/2023 11:00	15.1	21.91	0.08	0
08/08/2023 12:00	15.2	20.97	0.08	0
08/08/2023 13:00	15.3	20.33	0.08	0
08/08/2023 14:00	15.3	19.84	0.08	0
08/08/2023 15:00	15.3	19.04	0.08	0
08/08/2023 16:00	15.4	19.21	0.08	0
08/08/2023 17:00	15.4	19.77	0.08	0
08/08/2023 18:00	15.5	20.03	0.08	0
08/08/2023 19:00	15.5	20.2	0.08	0
08/08/2023 20:00	15.6	20.13	0.08	0
08/08/2023 21:00	15.5	21.21	0.08	0
08/08/2023 22:00	15.5	22.05	0.08	0
08/08/2023 23:00	15.5	22.2	0.08	0
09/08/2023 00:00	15.5	21.82	0.08	0
09/08/2023 01:00	15.5	21.39	0.08	0
09/08/2023 02:00	15.5	21.3	0.08	0
09/08/2023 03:00	15.5	21.33	0.08	0
09/08/2023 04:00	15.4	21.34	0.08	0
09/08/2023 05:00	15.4	21.24	0.08	0
09/08/2023 06:00	15.4	20.98	0.08	0
09/08/2023 07:00	15.4	21.76	0.08	0
09/08/2023 08:00	15.5	21.11	0.08	0
09/08/2023 09:00	15.4	20.76	0.08	0
09/08/2023 10:00	15.5	20.87	0.08	0
09/08/2023 11:00	15.5	21.22	0.08	0
09/08/2023 12:00	15.6	20.97	0.08	0
09/08/2023 13:00	15.8	19.76	0.08	0
09/08/2023 14:00	15.9	19.22	0.08	0
09/08/2023 15:00	16	18.14	0.08	0
09/08/2023 16:00	16.1	17.99	0.08	0
09/08/2023 17:00	16.1	18.81	0.08	0
09/08/2023 18:00	16.1	19.09	0.08	0
09/08/2023 19:00	16.1	19.61	0.08	0
09/08/2023 20:00	16	20.2	0.08	0
09/08/2023 21:00	<Samp	<Samp	<Samp	<Samp
09/08/2023 22:00	Maintain	Maintain	Maintain	Maintain
09/08/2023 23:00	Maintain	Maintain	Maintain	Maintain
10/08/2023 00:00	Maintain	Maintain	Maintain	Maintain
10/08/2023 01:00	NoData	NoData	NoData	NoData
10/08/2023 02:00	NoData	NoData	NoData	NoData
10/08/2023 03:00	---	---	---	---
10/08/2023 04:00	<Samp	<Samp	<Samp	<Samp
10/08/2023 05:00	Maintain	Maintain	Maintain	Maintain
10/08/2023 06:00	Maintain	Maintain	Maintain	Maintain
10/08/2023 07:00	Maintain	Maintain	Maintain	Maintain
10/08/2023 08:00	Maintain	Maintain	Maintain	0
10/08/2023 09:00	Maintain	Maintain	Maintain	0
10/08/2023 10:00	Maintain	Maintain	Maintain	0
10/08/2023 11:00	<Samp	<Samp	<Samp	0
10/08/2023 12:00	Maintain	Maintain	Maintain	0
10/08/2023 13:00	Maintain	Maintain	Maintain	0
10/08/2023 14:00	Maintain	Maintain	Maintain	0
10/08/2023 15:00	Maintain	Maintain	Maintain	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
10/08/2023 16:00	Maintain	Maintain	Maintain	0
10/08/2023 17:00	Maintain	Maintain	Maintain	0
10/08/2023 18:00	Maintain	Maintain	Maintain	0
10/08/2023 19:00	Maintain	Maintain	Maintain	0
10/08/2023 20:00	Maintain	Maintain	Maintain	0
10/08/2023 21:00	Maintain	Maintain	Maintain	0
10/08/2023 22:00	Maintain	Maintain	Maintain	0
10/08/2023 23:00	Maintain	Maintain	Maintain	0
11/08/2023 00:00	Maintain	Maintain	Maintain	0
11/08/2023 01:00	Maintain	Maintain	Maintain	0
11/08/2023 02:00	Maintain	Maintain	Maintain	0
11/08/2023 03:00	16.6	47.94	0.08	0
11/08/2023 04:00	16.7	46.57	0.08	0
11/08/2023 05:00	16.7	42.82	0.08	0
11/08/2023 06:00	16.7	40.05	0.08	0
11/08/2023 07:00	16.6	38.47	0.08	0
11/08/2023 08:00	16.7	36.8	0.08	0
11/08/2023 09:00	16.6	35.49	0.08	0
11/08/2023 10:00	16.5	34.64	0.08	0
11/08/2023 11:00	16.5	33.92	0.08	0
11/08/2023 12:00	16.9	33.57	0.08	0
11/08/2023 13:00	17.2	31.14	0.08	0
11/08/2023 14:00	17.6	28.1	0.08	0
11/08/2023 15:00	<Samp	<Samp	<Samp	<Samp
11/08/2023 16:00	Maintain	Maintain	Maintain	Maintain
11/08/2023 17:00	<Samp	Maintain	Maintain	Maintain
11/08/2023 18:00	13.8	Maintain	Maintain	Maintain
11/08/2023 19:00	13.7	23.5	0.08	<Samp
11/08/2023 20:00	13.7	23.83	0.08	0
11/08/2023 21:00	13.7	23.77	0.08	0
11/08/2023 22:00	13.8	23.97	0.08	0
11/08/2023 23:00	13.7	23.97	0.08	0
12/08/2023 00:00	13.7	23.88	0.08	0
12/08/2023 01:00	13.6	23.79	0.08	0
12/08/2023 02:00	13.6	23.79	0.08	0
12/08/2023 03:00	13.6	23.65	0.08	0
12/08/2023 04:00	13.6	24.13	0.08	0
12/08/2023 05:00	13.5	24.8	0.08	0
12/08/2023 06:00	13.5	24.87	0.08	0
12/08/2023 07:00	13.5	24.73	0.08	0
12/08/2023 08:00	13.5	24.19	0.08	0
12/08/2023 09:00	13.5	23.56	0.08	0
12/08/2023 10:00	13.5	23.61	0.08	0
12/08/2023 11:00	13.3	23.73	0.08	0
12/08/2023 12:00	13.3	23.82	0.08	0
12/08/2023 13:00	13.3	22.67	0.08	0
12/08/2023 14:00	13.3	24.6	0.08	0
12/08/2023 15:00	13.4	29.31	0.08	0
12/08/2023 16:00	13.3	33.61	0.08	0
12/08/2023 17:00	13.4	34.87	0.08	0
12/08/2023 18:00	13.4	33.67	0.08	0
12/08/2023 19:00	13.4	31.74	0.08	0
12/08/2023 20:00	13.4	31.12	0.08	0
12/08/2023 21:00	13.4	33.07	0.08	0
12/08/2023 22:00	13.4	43.61	0.08	0
12/08/2023 23:00	13.4	38.23	0.08	0
13/08/2023 00:00	13.4	33.98	0.08	0
13/08/2023 01:00	13.3	32.21	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
13/08/2023 02:00	13.4	29.87	0.08	0
13/08/2023 03:00	13.3	28.88	0.08	0
13/08/2023 04:00	13.2	28.26	0.08	0
13/08/2023 05:00	13.2	27.96	0.08	0
13/08/2023 06:00	13.3	27.63	0.08	0
13/08/2023 07:00	13.4	27.4	0.08	0
13/08/2023 08:00	13.5	26.72	0.08	0
13/08/2023 09:00	13.5	26.13	0.08	0
13/08/2023 10:00	13.5	27.9	0.08	0
13/08/2023 11:00	13.4	27.57	0.08	0
13/08/2023 12:00	13.4	27.06	0.08	0
13/08/2023 13:00	13.5	24.65	0.08	0
13/08/2023 14:00	13.3	23.93	0.08	0
13/08/2023 15:00	13.3	22.45	0.08	0
13/08/2023 16:00	13.3	22.64	0.08	0
13/08/2023 17:00	13.3	22.47	0.08	0
13/08/2023 18:00	13.3	23.08	0.08	0
13/08/2023 19:00	13.4	23.36	0.08	0
13/08/2023 20:00	13.4	24.86	0.08	0
13/08/2023 21:00	13.4	25.97	0.08	0
13/08/2023 22:00	13.4	25.25	0.08	0
13/08/2023 23:00	13.4	25.35	0.08	0
14/08/2023 00:00	13.4	25.31	0.08	0
14/08/2023 01:00	13.4	25	0.08	0
14/08/2023 02:00	13.4	24.99	0.08	0
14/08/2023 03:00	13.4	24.76	0.08	0
14/08/2023 04:00	13.5	25	0.08	0
14/08/2023 05:00	13.5	24.62	0.08	0
14/08/2023 06:00	13.5	25.34	0.08	0
14/08/2023 07:00	13.5	25.34	0.08	0
14/08/2023 08:00	13.6	25.14	0.08	0
14/08/2023 09:00	13.7	24.72	0.08	0
14/08/2023 10:00	13.7	25.26	0.08	0
14/08/2023 11:00	13.6	28.22	0.08	0
14/08/2023 12:00	13.5	32.17	0.08	0
14/08/2023 13:00	13.6	35.75	0.08	0
14/08/2023 14:00	13.5	34.87	0.08	0
14/08/2023 15:00	13.5	33.94	0.08	0
14/08/2023 16:00	13.5	37.86	0.08	0
14/08/2023 17:00	13.5	36.19	0.08	0
14/08/2023 18:00	13.5	37.72	0.08	0
14/08/2023 19:00	13.6	34.8	0.08	0
14/08/2023 20:00	13.6	33.09	0.08	0
14/08/2023 21:00	13.6	32.08	0.08	0
14/08/2023 22:00	13.6	31.27	0.08	0
14/08/2023 23:00	13.6	29.97	0.08	0
15/08/2023 00:00	13.5	28.99	0.08	0
15/08/2023 01:00	13.5	28.31	0.08	0
15/08/2023 02:00	13.5	28.43	0.08	0
15/08/2023 03:00	13.4	28.49	0.08	0
15/08/2023 04:00	13.4	29.21	0.08	0
15/08/2023 05:00	13.5	35.75	0.08	0
15/08/2023 06:00	13.5	34.02	0.08	0
15/08/2023 07:00	13.5	32.53	0.08	0
15/08/2023 08:00	13.4	30	0.08	0
15/08/2023 09:00	13.4	29.5	0.08	0
15/08/2023 10:00	13.4	29.08	0.08	0
15/08/2023 11:00	13.2	35.34	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
15/08/2023 12:00	13.2	33.44	0.08	0
15/08/2023 13:00	13.3	30.8	0.08	0
15/08/2023 14:00	13.2	28.54	0.08	0
15/08/2023 15:00	13.2	28.14	0.08	0
15/08/2023 16:00	13.1	27.83	0.08	0
15/08/2023 17:00	12.6	28.3	0.08	0
15/08/2023 18:00	12.6	27.84	0.08	0
15/08/2023 19:00	12.7	27.92	0.08	0
15/08/2023 20:00	12.7	28.03	0.08	0
15/08/2023 21:00	12.7	27.6	0.08	0
15/08/2023 22:00	12.9	27.4	0.08	0
15/08/2023 23:00	12.9	27.08	0.08	0
16/08/2023 00:00	12.9	27.55	0.08	0
16/08/2023 01:00	12.9	27.62	0.08	0
16/08/2023 02:00	12.9	27.48	0.08	0
16/08/2023 03:00	12.9	27.79	0.08	0
16/08/2023 04:00	12.8	27.54	0.08	0
16/08/2023 05:00	12.8	27.16	0.08	0
16/08/2023 06:00	12.8	27.84	0.08	0
16/08/2023 07:00	12.7	27.51	0.08	0
16/08/2023 08:00	12.7	27.92	0.08	0
16/08/2023 09:00	12.8	28.36	0.08	0
16/08/2023 10:00	13	28.29	0.08	0
16/08/2023 11:00	12.7	28.2	0.08	0
16/08/2023 12:00	12.7	28.22	0.08	0
16/08/2023 13:00	12.8	27.28	0.08	0
16/08/2023 14:00	<Samp	<Samp	<Samp	0
16/08/2023 15:00	<Samp	<Samp	<Samp	0
16/08/2023 16:00	1.7	35.67	0.08	0
16/08/2023 17:00	1.8	50.21	0.08	0
16/08/2023 18:00	1.8	64.51	0.08	0
16/08/2023 19:00	1.5	69.91	0.08	0
16/08/2023 20:00	1.3	73.33	0.08	0
16/08/2023 21:00	1.2	77.11	0.08	0
16/08/2023 22:00	1	85.29	0.08	0
16/08/2023 23:00	0.8	97.79	0.08	0
17/08/2023 00:00	0.8	91.96	0.08	0
17/08/2023 01:00	0.9	90.45	0.08	0
17/08/2023 02:00	1	64.02	0.08	0
17/08/2023 03:00	0.9	48.04	0.08	0
17/08/2023 04:00	0.9	41.8	0.08	0
17/08/2023 05:00	0.8	38.19	0.08	0
17/08/2023 06:00	0.8	39.51	0.08	0
17/08/2023 07:00	0.8	63.26	0.08	0
17/08/2023 08:00	0.6	107.49	0.08	0
17/08/2023 09:00	0.5	123.17	0.08	0
17/08/2023 10:00	0.4	132.23	0.08	0
17/08/2023 11:00	0.3	132.68	0.08	0
17/08/2023 12:00	0.2	133.8	0.08	0
17/08/2023 13:00	0.2	136.23	0.08	0
17/08/2023 14:00	0.2	144.52	0.08	0
17/08/2023 15:00	0.1	171.01	0.08	0
17/08/2023 16:00	0.1	185.79	0.08	0
17/08/2023 17:00	0.3	165.25	0.08	0
17/08/2023 18:00	0.3	135.44	0.08	0
17/08/2023 19:00	0.2	124.08	0.08	0
17/08/2023 20:00	0.2	120.66	0.08	0
17/08/2023 21:00	0.1	105.92	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD ppm	FLOW m3/Hr	POWER KW	Fire_Alarm #
17/08/2023 22:00	0.1	81.61	0.08	0
17/08/2023 23:00	0.1	68.22	0.08	0
18/08/2023 00:00	0.2	55.23	0.08	0
18/08/2023 01:00	0.2	45.26	0.08	0
18/08/2023 02:00	0.2	39.84	0.08	0
18/08/2023 03:00	0.3	34.99	0.08	0
18/08/2023 04:00	0.4	33.71	0.08	0
18/08/2023 05:00	0.4	32.83	0.08	0
18/08/2023 06:00	0.5	31.87	0.08	0
18/08/2023 07:00	0.5	31.11	0.08	0
18/08/2023 08:00	0.6	27.3	0.08	0
18/08/2023 09:00	0.6	26.29	0.08	0
18/08/2023 10:00	0.6	26.46	0.08	0
18/08/2023 11:00	0.6	25.07	0.08	0
18/08/2023 12:00	0.6	22.8	0.08	0
18/08/2023 13:00	0.7	23.55	0.08	0
18/08/2023 14:00	0.8	23.41	0.08	0
18/08/2023 15:00	0.9	23.46	0.08	0
18/08/2023 16:00	0.9	22.98	0.08	0
18/08/2023 17:00	0.9	23.23	0.08	0
18/08/2023 18:00	1	24.81	0.08	0
18/08/2023 19:00	1	25.99	0.08	0
18/08/2023 20:00	0.9	27.78	0.08	0
18/08/2023 21:00	0.9	31.23	0.08	0
18/08/2023 22:00	0.9	35.63	0.08	0
18/08/2023 23:00	0.9	41.11	0.08	0
19/08/2023 00:00	0.9	40	0.08	0
19/08/2023 01:00	0.9	35.59	0.08	0
19/08/2023 02:00	0.9	33.7	0.08	0
19/08/2023 03:00	1	32.48	0.08	0
19/08/2023 04:00	1	31.81	0.08	0
19/08/2023 05:00	1	34.04	0.08	0
19/08/2023 06:00	1	38.42	0.08	0
19/08/2023 07:00	1	35.36	0.08	0
19/08/2023 08:00	1.1	31.42	0.08	0
19/08/2023 09:00	1.1	30.13	0.08	0
19/08/2023 10:00	1.1	29.64	0.08	0
19/08/2023 11:00	1.2	28.19	0.08	0
19/08/2023 12:00	1.4	27.4	0.08	0
19/08/2023 13:00	1.5	26.51	0.08	0
19/08/2023 14:00	1.7	25.91	0.08	0
19/08/2023 15:00	1.8	26.03	0.08	0
19/08/2023 16:00	1.7	25.41	0.08	0
19/08/2023 17:00	1.7	27.05	0.08	0
19/08/2023 18:00	1.7	33.13	0.08	0
19/08/2023 19:00	1.7	37.48	0.08	0
19/08/2023 20:00	1.8	34.6	0.08	0
19/08/2023 21:00	1.9	32.86	0.08	0
19/08/2023 22:00	2	32.49	0.08	0
19/08/2023 23:00	2	34.28	0.08	0
20/08/2023 00:00	2	43.76	0.08	0
20/08/2023 01:00	2.1	38.71	0.08	0
20/08/2023 02:00	2	35.35	0.08	0
20/08/2023 03:00	2	33.3	0.08	0
20/08/2023 04:00	1.9	31.99	0.08	0
20/08/2023 05:00	1.9	30.65	0.08	0
20/08/2023 06:00	1.9	29.65	0.08	0
20/08/2023 07:00	1.8	29.8	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD ppm	FLOW m3/Hr	POWER KW	Fire_Alarm #
20/08/2023 08:00	1.8	29.06	0.08	0
20/08/2023 09:00	1.8	27.96	0.08	0
20/08/2023 10:00	1.8	28.43	0.08	0
20/08/2023 11:00	1.8	27.22	0.08	0
20/08/2023 12:00	1.9	26.45	0.08	0
20/08/2023 13:00	1.9	32.39	0.08	0
20/08/2023 14:00	2	32.42	0.08	0
20/08/2023 15:00	2.1	30.6	0.08	0
20/08/2023 16:00	2.1	30.32	0.08	0
20/08/2023 17:00	2	29.53	0.08	0
20/08/2023 18:00	2.1	28.8	0.08	0
20/08/2023 19:00	2.2	28.3	0.08	0
20/08/2023 20:00	2.2	27.97	0.08	0
20/08/2023 21:00	2.2	27.79	0.08	0
20/08/2023 22:00	2.1	27.55	0.08	0
20/08/2023 23:00	2.1	27.19	0.08	0
21/08/2023 00:00	2	33.29	0.08	0
21/08/2023 01:00	1.9	37.83	0.08	0
21/08/2023 02:00	1.9	34.35	0.08	0
21/08/2023 03:00	2	34.13	0.08	0
21/08/2023 04:00	1.9	32.11	0.08	0
21/08/2023 05:00	1.9	31.15	0.08	0
21/08/2023 06:00	1.9	31.07	0.08	0
21/08/2023 07:00	1.8	30.15	0.08	0
21/08/2023 08:00	1.8	29.65	0.08	0
21/08/2023 09:00	1.8	29.38	0.08	0
21/08/2023 10:00	1.8	29.47	0.08	0
21/08/2023 11:00	1.8	29.37	0.08	0
21/08/2023 12:00	1.7	28.7	0.08	0
21/08/2023 13:00	1.7	28.56	0.08	0
21/08/2023 14:00	1.7	27.73	0.08	0
21/08/2023 15:00	1.7	28.13	0.08	0
21/08/2023 16:00	1.8	27.92	0.08	0
21/08/2023 17:00	1.8	29.21	0.08	0
21/08/2023 18:00	1.8	30.36	0.08	0
21/08/2023 19:00	1.7	31.28	0.08	0
21/08/2023 20:00	1.7	28.83	0.08	0
21/08/2023 21:00	1.7	35.06	0.08	0
21/08/2023 22:00	1.7	34.71	0.08	0
21/08/2023 23:00	1.6	34.67	0.08	0
22/08/2023 00:00	1.6	34.32	0.08	0
22/08/2023 01:00	1.6	34.57	0.08	0
22/08/2023 02:00	1.6	34.49	0.08	0
22/08/2023 03:00	1.6	34.22	0.08	0
22/08/2023 04:00	1.6	34.28	0.09	0
22/08/2023 05:00	1.6	33.01	0.08	0
22/08/2023 06:00	1.6	33.87	0.08	0
22/08/2023 07:00	1.6	33.82	0.08	0
22/08/2023 08:00	1.6	32.31	0.08	0
22/08/2023 09:00	1.6	33.38	0.08	0
22/08/2023 10:00	1.6	32.06	0.08	0
22/08/2023 11:00	1.6	34.88	0.08	0
22/08/2023 12:00	1.7	36.04	0.08	0
22/08/2023 13:00	1.7	33.86	0.08	0
22/08/2023 14:00	1.7	33.48	0.08	0
22/08/2023 15:00	1.7	33.58	0.08	0
22/08/2023 16:00	1.7	33.77	0.08	0
22/08/2023 17:00	1.7	34.17	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD ppm	FLOW m3/Hr	POWER KW	Fire_Alarm #
22/08/2023 18:00	1.7	46.74	0.08	0
22/08/2023 19:00	1.7	40.7	0.08	0
22/08/2023 20:00	1.8	39.33	0.08	0
22/08/2023 21:00	1.8	37.4	0.08	0
22/08/2023 22:00	1.8	37.44	0.08	0
22/08/2023 23:00	1.8	38.1	0.08	0
23/08/2023 00:00	1.7	36.93	0.08	0
23/08/2023 01:00	1.7	36.87	0.08	0
23/08/2023 02:00	1.7	35.97	0.08	0
23/08/2023 03:00	1.7	35.19	0.08	0
23/08/2023 04:00	1.7	34.67	0.08	0
23/08/2023 05:00	1.7	33.61	0.08	0
23/08/2023 06:00	1.7	34.16	0.08	0
23/08/2023 07:00	1.7	32.54	0.08	0
23/08/2023 08:00	1.7	31.71	0.08	0
23/08/2023 09:00	1.7	32.43	0.08	0
23/08/2023 10:00	1.6	31.54	0.08	0
23/08/2023 11:00	1.6	32.16	0.08	0
23/08/2023 12:00	1.6	31.87	0.08	0
23/08/2023 13:00	1.6	32.76	0.08	0
23/08/2023 14:00	1.7	32.3	0.08	0
23/08/2023 15:00	1.7	32.57	0.08	0
23/08/2023 16:00	1.7	31.95	0.08	0
23/08/2023 17:00	1.7	32.12	0.08	0
23/08/2023 18:00	1.7	33.3	0.08	0
23/08/2023 19:00	1.7	33	0.08	0
23/08/2023 20:00	1.7	31.86	0.08	0
23/08/2023 21:00	1.7	33.26	0.08	0
23/08/2023 22:00	1.7	33.88	0.08	0
23/08/2023 23:00	1.7	33.34	0.08	0
24/08/2023 00:00	1.7	32.99	0.08	0
24/08/2023 01:00	1.7	33.25	0.08	0
24/08/2023 02:00	1.7	33.53	0.08	0
24/08/2023 03:00	1.7	32.69	0.08	0
24/08/2023 04:00	1.7	33.5	0.08	0
24/08/2023 05:00	1.7	32.33	0.08	0
24/08/2023 06:00	1.6	32.75	0.08	0
24/08/2023 07:00	1.6	33.23	0.08	0
24/08/2023 08:00	1.6	32.92	0.08	0
24/08/2023 09:00	1.7	34.72	0.08	0
24/08/2023 10:00	1.6	34.92	0.08	0
24/08/2023 11:00	1.6	34.92	0.08	0
24/08/2023 12:00	1.7	34.87	0.08	0
24/08/2023 13:00	1.7	34.71	0.08	0
24/08/2023 14:00	1.7	35.61	0.08	0
24/08/2023 15:00	1.7	34.9	0.08	0
24/08/2023 16:00	1.7	34.06	0.08	0
24/08/2023 17:00	1.8	34.18	0.08	0
24/08/2023 18:00	1.8	35.46	0.08	0
24/08/2023 19:00	1.8	36.58	0.08	0
24/08/2023 20:00	1.8	34.55	0.08	0
24/08/2023 21:00	1.8	36.74	0.08	0
24/08/2023 22:00	1.8	35.88	0.08	0
24/08/2023 23:00	1.8	35.91	0.08	0
25/08/2023 00:00	1.8	37.12	0.08	0
25/08/2023 01:00	1.8	37.12	0.08	0
25/08/2023 02:00	1.8	37.81	0.08	0
25/08/2023 03:00	1.8	38.27	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
25/08/2023 04:00	1.8	38.32	0.08	0
25/08/2023 05:00	1.8	37.8	0.08	0
25/08/2023 06:00	1.8	38.04	0.08	0
25/08/2023 07:00	1.8	36.1	0.08	0
25/08/2023 08:00	1.8	35.76	0.08	0
25/08/2023 09:00	1.8	34.97	0.08	0
25/08/2023 10:00	1.8	34.83	0.08	0
25/08/2023 11:00	1.8	38.72	0.08	0
25/08/2023 12:00	1.9	42.44	0.08	0
25/08/2023 13:00	1.9	41.42	0.08	0
25/08/2023 14:00	2	39.94	0.08	0
25/08/2023 15:00	2	38.37	0.08	0
25/08/2023 16:00	2	36.75	0.08	0
25/08/2023 17:00	2	37.49	0.08	0
25/08/2023 18:00	2	37.35	0.08	0
25/08/2023 19:00	2	39.15	0.08	0
25/08/2023 20:00	2	37.79	0.08	0
25/08/2023 21:00	2	39.51	0.08	0
25/08/2023 22:00	2	47.71	0.08	0
25/08/2023 23:00	2	44.28	0.08	0
26/08/2023 00:00	2	43.21	0.08	0
26/08/2023 01:00	2	42.35	0.08	0
26/08/2023 02:00	2	42.33	0.08	0
26/08/2023 03:00	2	42.04	0.08	0
26/08/2023 04:00	2	59.25	0.08	0
26/08/2023 05:00	2	48.25	0.08	0
26/08/2023 06:00	2	45.22	0.08	0
26/08/2023 07:00	2	41.21	0.08	0
26/08/2023 08:00	2	40.77	0.08	0
26/08/2023 09:00	2	39.32	0.08	0
26/08/2023 10:00	2	38.56	0.08	0
26/08/2023 11:00	2	39.08	0.08	0
26/08/2023 12:00	2.1	39.07	0.08	0
26/08/2023 13:00	2.1	39.6	0.08	0
26/08/2023 14:00	2.2	38.49	0.08	0
26/08/2023 15:00	2.3	37.54	0.08	0
26/08/2023 16:00	2.3	35.79	0.08	0
26/08/2023 17:00	2.3	35.92	0.08	0
26/08/2023 18:00	2.2	35.58	0.08	0
26/08/2023 19:00	2.2	38.21	0.08	0
26/08/2023 20:00	2.2	39.32	0.08	0
26/08/2023 21:00	2.3	40.45	0.08	0
26/08/2023 22:00	2.3	40.73	0.08	0
26/08/2023 23:00	2.3	40.8	0.08	0
27/08/2023 00:00	2.3	41.28	0.08	0
27/08/2023 01:00	2.3	38.89	0.08	0
27/08/2023 02:00	2.3	41.36	0.08	0
27/08/2023 03:00	2.3	41.99	0.08	0
27/08/2023 04:00	2.4	42.2	0.08	0
27/08/2023 05:00	2.4	42.34	0.08	0
27/08/2023 06:00	2.4	42.4	0.08	0
27/08/2023 07:00	2.4	38.92	0.08	0
27/08/2023 08:00	2.4	38.57	0.08	0
27/08/2023 09:00	2.4	38.57	0.08	0
27/08/2023 10:00	2.4	38.38	0.08	0
27/08/2023 11:00	2.4	39.68	0.08	0
27/08/2023 12:00	2.4	40	0.08	0
27/08/2023 13:00	2.5	39.37	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD ppm	FLOW m3/Hr	POWER KW	Fire Alarm #
27/08/2023 14:00	2.5	39.07	0.08	0
27/08/2023 15:00	2.5	36.99	0.08	0
27/08/2023 16:00	2.5	36.47	0.08	0
27/08/2023 17:00	2.6	36.46	0.08	0
27/08/2023 18:00	2.6	38.53	0.08	0
27/08/2023 19:00	2.6	40.39	0.08	0
27/08/2023 20:00	2.7	40.9	0.08	0
27/08/2023 21:00	2.7	45.88	0.08	0
27/08/2023 22:00	2.7	44.05	0.08	0
27/08/2023 23:00	2.7	43.36	0.08	0
28/08/2023 00:00	2.7	51.45	0.08	0
28/08/2023 01:00	2.7	55.7	0.08	0
28/08/2023 02:00	2.7	47.23	0.08	0
28/08/2023 03:00	2.7	44.52	0.08	0
28/08/2023 04:00	2.7	43.28	0.08	0
28/08/2023 05:00	2.7	41.75	0.08	0
28/08/2023 06:00	2.7	42.19	0.08	0
28/08/2023 07:00	2.7	40.47	0.08	0
28/08/2023 08:00	2.7	39.64	0.08	0
28/08/2023 09:00	2.7	39.03	0.08	0
28/08/2023 10:00	2.6	39.03	0.08	0
28/08/2023 11:00	2.6	40.05	0.08	0
28/08/2023 12:00	2.7	40.9	0.08	0
28/08/2023 13:00	2.8	39.79	0.08	0
28/08/2023 14:00	2.8	38.74	0.08	0
28/08/2023 15:00	2.9	38.05	0.08	0
28/08/2023 16:00	2.9	37.24	0.08	0
28/08/2023 17:00	2.9	36.61	0.08	0
28/08/2023 18:00	2.9	39.49	0.08	0
28/08/2023 19:00	3	41.43	0.08	0
28/08/2023 20:00	3	42.2	0.08	0
28/08/2023 21:00	3	41.87	0.08	0
28/08/2023 22:00	3	42.7	0.08	0
28/08/2023 23:00	3	42.23	0.08	0
29/08/2023 00:00	3	42.13	0.08	0
29/08/2023 01:00	3	41.14	0.08	0
29/08/2023 02:00	3	42.4	0.08	0
29/08/2023 03:00	3	42.34	0.08	0
29/08/2023 04:00	3	41.54	0.08	0
29/08/2023 05:00	3	42.31	0.08	0
29/08/2023 06:00	3	43.09	0.08	0
29/08/2023 07:00	3	42.47	0.08	0
29/08/2023 08:00	3	40.68	0.08	0
29/08/2023 09:00	3	39.03	0.08	0
29/08/2023 10:00	3	39.12	0.08	0
29/08/2023 11:00	3	42.86	0.08	0
29/08/2023 12:00	3	46.4	0.08	0
29/08/2023 13:00	3.1	45.28	0.08	0
29/08/2023 14:00	3.2	42.19	0.08	0
29/08/2023 15:00	3.1	39.62	0.08	0
29/08/2023 16:00	3.1	40.32	0.08	0
29/08/2023 17:00	3.1	42.57	0.08	0
29/08/2023 18:00	3.1	46.62	0.08	0
29/08/2023 19:00	3.1	51.07	0.08	0
29/08/2023 20:00	3.1	48.41	0.08	0
29/08/2023 21:00	3.1	46.96	0.08	0
29/08/2023 22:00	3.1	46.94	0.08	0
29/08/2023 23:00	3.1	47	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD ppm	FLOW m3/Hr	POWER KW	Fire Alarm #
30/08/2023 00:00	3.1	46.56	0.08	0
30/08/2023 01:00	3.2	54.31	0.08	0
30/08/2023 02:00	3.2	46.47	0.08	0
30/08/2023 03:00	3.1	47.27	0.08	0
30/08/2023 04:00	3.1	45.4	0.08	0
30/08/2023 05:00	3.1	55.43	0.08	0
30/08/2023 06:00	3.2	54.91	0.08	0
30/08/2023 07:00	3.2	50.48	0.08	0
30/08/2023 08:00	3.3	46.63	0.08	0
30/08/2023 09:00	3.2	46.98	0.08	0
30/08/2023 10:00	3.2	45.21	0.08	0
30/08/2023 11:00	3.3	45.61	0.08	0
30/08/2023 12:00	3.4	48.89	0.08	0
30/08/2023 13:00	3.5	49.27	0.08	0
30/08/2023 14:00	3.4	47.75	0.08	0
30/08/2023 15:00	3.5	46.45	0.08	0
30/08/2023 16:00	3.4	45.11	0.08	0
30/08/2023 17:00	3.4	43.37	0.08	0
30/08/2023 18:00	3.4	61.46	0.08	0
30/08/2023 19:00	3.4	53.13	0.08	0
30/08/2023 20:00	3.5	48.75	0.08	0
30/08/2023 21:00	3.5	48.27	0.08	0
30/08/2023 22:00	3.4	46.14	0.08	0
30/08/2023 23:00	3.4	45.88	0.08	0
31/08/2023 00:00	3.4	46.91	0.08	0
31/08/2023 01:00	3.3	48.21	0.08	0
31/08/2023 02:00	3.3	47.93	0.08	0
31/08/2023 03:00	3.2	47.53	0.08	0
31/08/2023 04:00	3.2	46.58	0.08	0
31/08/2023 05:00	3.2	45.87	0.08	0
31/08/2023 06:00	3.1	44.82	0.08	0
31/08/2023 07:00	3.1	43.63	0.08	0
31/08/2023 08:00	3.1	44.49	0.08	0
31/08/2023 09:00	3	44.38	0.08	0
31/08/2023 10:00	3	56.98	0.08	0
31/08/2023 11:00	3.3	85.97	0.08	0
31/08/2023 12:00	3.2	61.74	0.08	0
31/08/2023 13:00	3.2	51.02	0.08	0
31/08/2023 14:00	3.2	49.39	0.08	0
31/08/2023 15:00	3.1	47.71	0.08	0
31/08/2023 16:00	3.2	45.28	0.08	0
31/08/2023 17:00	3.1	46.35	0.08	0
31/08/2023 18:00	3.2	45.65	0.08	0
31/08/2023 19:00	3.2	47.33	0.08	0
31/08/2023 20:00	3.2	45.88	0.08	0
31/08/2023 21:00	3.2	47.21	0.08	0
31/08/2023 22:00	3.1	46.84	0.08	0
31/08/2023 23:00	3	46.02	0.08	0
Minimum	0.1	14.67	0.08	0
MinDate	17/08/2023 15:00	01/08/2023 00:00	01/08/2023 00:00	01/08/2023 00:00
Maximum	17.6	185.79	0.09	0
MaxDate	11/08/2023 14:00	17/08/2023 16:00	04/08/2023 02:00	01/08/2023 00:00
Avg	7.7	39.02	0.08	0
Num	709	708	708	728
Data(%)	95.2	95	95	97.7
STD	6	21.4	0	0
	5451.8	27624.84	56.66	0

Site Report - DATA TO IEAT				
Date&Time	BOD ppm	FLOW m3/Hr	POWER KW	Fire Alarm #
01/09/2023 00:00	3	48.26	0.08	0
01/09/2023 01:00	2.9	47.14	0.08	0
01/09/2023 02:00	2.9	48.43	0.08	0
01/09/2023 03:00	2.9	47.6	0.08	0
01/09/2023 04:00	2.8	47.74	0.08	0
01/09/2023 05:00	2.7	47.52	0.08	0
01/09/2023 06:00	2.7	46.94	0.08	0
01/09/2023 07:00	2.6	47.94	0.09	0
01/09/2023 08:00	2.6	48.37	0.08	0
01/09/2023 09:00	2.4	49.76	0.08	0
01/09/2023 10:00	2.4	48.29	0.08	0
01/09/2023 11:00	2.3	48.03	0.08	0
01/09/2023 12:00	2.3	46.01	0.08	0
01/09/2023 13:00	2.3	49.5	0.08	0
01/09/2023 14:00	2.4	52.36	0.08	0
01/09/2023 15:00	2.4	70.39	0.08	0
01/09/2023 16:00	2.4	59.06	0.08	0
01/09/2023 17:00	2.4	55.45	0.08	0
01/09/2023 18:00	2.3	51.85	0.08	0
01/09/2023 19:00	2.3	50.38	0.08	0
01/09/2023 20:00	2.3	52.65	0.08	0
01/09/2023 21:00	2.3	54.49	0.08	0
01/09/2023 22:00	2.3	53.24	0.08	0
01/09/2023 23:00	2.3	49.41	0.08	0
02/09/2023 00:00	2.3	48.16	0.08	0
02/09/2023 01:00	2.3	47.95	0.08	0
02/09/2023 02:00	2.3	47.99	0.08	0
02/09/2023 03:00	2.3	48.5	0.08	0
02/09/2023 04:00	2.3	48.68	0.08	0
02/09/2023 05:00	2.3	49.41	0.08	0
02/09/2023 06:00	2.3	52	0.08	0
02/09/2023 07:00	2.3	49.21	0.08	0
02/09/2023 08:00	2.2	48.24	0.08	0
02/09/2023 09:00	2.2	49.22	0.08	0
02/09/2023 10:00	2.2	48.23	0.08	0
02/09/2023 11:00	2.2	48.76	0.08	0
02/09/2023 12:00	2.3	48.13	0.08	0
02/09/2023 13:00	2.3	48.17	0.08	0
02/09/2023 14:00	2.3	48.29	0.08	0
02/09/2023 15:00	2.3	49.62	0.08	0
02/09/2023 16:00	2.3	49.43	0.08	0
02/09/2023 17:00	2.3	49.71	0.08	0
02/09/2023 18:00	2.3	50.96	0.08	0
02/09/2023 19:00	2.3	52.26	0.08	0
02/09/2023 20:00	2.3	49.54	0.08	0
02/09/2023 21:00	2.3	50.01	0.08	0
02/09/2023 22:00	2.3	50.5	0.08	0
02/09/2023 23:00	2.3	49.68	0.08	0
03/09/2023 00:00	2.3	51.6	0.08	0
03/09/2023 01:00	2.3	46.7	0.08	0
03/09/2023 02:00	2.3	47.46	0.08	0
03/09/2023 03:00	2.4	50.61	0.08	0
03/09/2023 04:00	2.4	52.15	0.08	0
03/09/2023 05:00	2.4	52	0.08	0
03/09/2023 06:00	2.4	47.62	0.08	0
03/09/2023 07:00	2.4	48.91	0.08	0
03/09/2023 08:00	2.4	50.07	0.08	0
03/09/2023 09:00	2.4	49.52	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
03/09/2023 10:00	2.3	49.15	0.08	0
03/09/2023 11:00	2.3	55.38	0.08	0
03/09/2023 12:00	2.4	58.35	0.08	0
03/09/2023 13:00	2.4	52.07	0.08	0
03/09/2023 14:00	2.5	49.41	0.08	0
03/09/2023 15:00	2.5	47.69	0.08	0
03/09/2023 16:00	2.5	60.06	0.08	0
03/09/2023 17:00	2.6	51.76	0.08	0
03/09/2023 18:00	2.6	56.9	0.08	0
03/09/2023 19:00	2.7	54.59	0.08	0
03/09/2023 20:00	2.7	50.01	0.08	0
03/09/2023 21:00	2.8	48.8	0.08	0
03/09/2023 22:00	2.8	49.38	0.08	0
03/09/2023 23:00	2.9	48.33	0.08	0
04/09/2023 00:00	2.9	47.59	0.08	0
04/09/2023 01:00	2.9	50.7	0.08	0
04/09/2023 02:00	2.9	56.05	0.08	0
04/09/2023 03:00	2.9	51.83	0.08	0
04/09/2023 04:00	3	50.81	0.08	0
04/09/2023 05:00	3	52.17	0.08	0
04/09/2023 06:00	3.1	51.11	0.08	0
04/09/2023 07:00	2.9	63.7	0.08	0
04/09/2023 08:00	3	54.63	0.08	0
04/09/2023 09:00	3	49.97	0.08	0
04/09/2023 10:00	2.9	49.77	0.08	0
04/09/2023 11:00	2.9	50.65	0.08	0
04/09/2023 12:00	2.8	51.41	0.08	0
04/09/2023 13:00	2.9	50.4	0.08	0
04/09/2023 14:00	3	49.09	0.08	0
04/09/2023 15:00	3.1	48.61	0.08	0
04/09/2023 16:00	3	48.41	0.08	0
04/09/2023 17:00	3.2	47.7	0.08	0
04/09/2023 18:00	3.2	47.71	0.08	0
04/09/2023 19:00	3.2	48.53	0.08	0
04/09/2023 20:00	3.3	47.64	0.08	0
04/09/2023 21:00	3.5	48.03	0.08	0
04/09/2023 22:00	3.5	49.36	0.08	0
04/09/2023 23:00	3.6	48.36	0.08	0
05/09/2023 00:00	3.7	47.44	0.08	0
05/09/2023 01:00	3.5	49.87	0.08	0
05/09/2023 02:00	3.5	47.39	0.08	0
05/09/2023 03:00	3.4	47.3	0.08	0
05/09/2023 04:00	3.4	49.73	0.08	0
05/09/2023 05:00	3.4	49.82	0.08	0
05/09/2023 06:00	3.3	51.32	0.08	0
05/09/2023 07:00	3.3	48.65	0.08	0
05/09/2023 08:00	3.4	48.48	0.08	0
05/09/2023 09:00	3.4	49.09	0.08	0
05/09/2023 10:00	3.4	48.13	0.08	0
05/09/2023 11:00	3.3	47.88	0.08	0
05/09/2023 12:00	3.3	47.07	0.08	0
05/09/2023 13:00	3.3	47.64	0.08	0
05/09/2023 14:00	3.5	46.73	0.08	0
05/09/2023 15:00	3.4	45.4	0.08	0
05/09/2023 16:00	3.5	46.71	0.08	0
05/09/2023 17:00	3.4	46.99	0.08	0
05/09/2023 18:00	3.4	48.04	0.08	0
05/09/2023 19:00	3.7	47.54	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD ppm	FLOW m3/Hr	POWER KW	Fire_Alarm #
05/09/2023 20:00	4	51.18	0.08	0
05/09/2023 21:00	3.6	49.94	0.08	0
05/09/2023 22:00	3.7	51.97	0.08	0
05/09/2023 23:00	3.8	47.52	0.08	0
06/09/2023 00:00	3.7	50.79	0.08	0
06/09/2023 01:00	3.6	52.54	0.08	0
06/09/2023 02:00	3.7	53.57	0.08	0
06/09/2023 03:00	3.6	53.67	0.08	0
06/09/2023 04:00	3.7	52.56	0.08	0
06/09/2023 05:00	3.6	47.98	0.08	0
06/09/2023 06:00	3.5	47.21	0.08	0
06/09/2023 07:00	3.6	49.44	0.08	0
06/09/2023 08:00	3.5	50.35	0.08	0
06/09/2023 09:00	3.6	49.59	0.08	0
06/09/2023 10:00	3.5	48.79	0.08	0
06/09/2023 11:00	3.5	48.96	0.08	0
06/09/2023 12:00	3.5	49.25	0.08	0
06/09/2023 13:00	3.6	48.71	0.08	0
06/09/2023 14:00	3.6	46.72	0.08	0
06/09/2023 15:00	3.7	46.24	0.08	0
06/09/2023 16:00	3.7	46.31	0.08	0
06/09/2023 17:00	3.6	48.65	0.08	0
06/09/2023 18:00	3.7	50.04	0.08	0
06/09/2023 19:00	3.7	64.93	0.08	0
06/09/2023 20:00	3.8	57.33	0.08	0
06/09/2023 21:00	3.9	50.6	0.08	0
06/09/2023 22:00	4	50.03	0.08	0
06/09/2023 23:00	3.9	48.46	0.08	0
07/09/2023 00:00	3.8	49.7	0.08	0
07/09/2023 01:00	3.6	53.99	0.08	0
07/09/2023 02:00	3.8	52.11	0.08	0
07/09/2023 03:00	3.8	52.36	0.08	0
07/09/2023 04:00	3.7	53.01	0.08	0
07/09/2023 05:00	3.7	53.96	0.08	0
07/09/2023 06:00	3.7	52.61	0.08	0
07/09/2023 07:00	3.6	48.19	0.08	0
07/09/2023 08:00	3.6	49.85	0.08	0
07/09/2023 09:00	3.5	48.62	0.08	0
07/09/2023 10:00	3.4	48.17	0.08	0
07/09/2023 11:00	3.4	47.88	0.08	0
07/09/2023 12:00	3.5	41.15	0.08	0
07/09/2023 13:00	3.4	36.04	0.08	0
07/09/2023 14:00	3.5	34.86	0.08	0
07/09/2023 15:00	3.6	31.81	0.08	0
07/09/2023 16:00	3.6	29.27	0.08	0
07/09/2023 17:00	3.6	29.72	0.08	0
07/09/2023 18:00	3.6	30.35	0.08	0
07/09/2023 19:00	3.6	27.75	0.08	0
07/09/2023 20:00	3.7	26.26	0.08	0
07/09/2023 21:00	3.6	32.89	0.08	0
07/09/2023 22:00	3.4	36.39	0.08	0
07/09/2023 23:00	3.5	38.04	0.08	0
08/09/2023 00:00	3.4	42.42	0.08	0
08/09/2023 01:00	3.4	44.41	0.08	0
08/09/2023 02:00	3.2	46.59	0.08	0
08/09/2023 03:00	3.3	44.9	0.08	0
08/09/2023 04:00	3.3	49.99	0.08	0
08/09/2023 05:00	3.2	51.86	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD ppm	FLOW m3/Hr	POWER KW	Fire_Alarm #
08/09/2023 06:00	3.3	48.74	0.08	0
08/09/2023 07:00	3.1	49.29	0.08	0
08/09/2023 08:00	3	50.36	0.08	0
08/09/2023 09:00	3	59.68	0.08	0
08/09/2023 10:00	3	57.14	0.08	0
08/09/2023 11:00	3	64.17	0.08	0
08/09/2023 12:00	3.1	53.8	0.08	0
08/09/2023 13:00	3.2	51.76	0.08	0
08/09/2023 14:00	3.2	51.49	0.08	0
08/09/2023 15:00	3.1	49.19	0.08	0
08/09/2023 16:00	3.2	46.86	0.08	0
08/09/2023 17:00	3.4	44.73	0.08	0
08/09/2023 18:00	3.4	46.13	0.08	0
08/09/2023 19:00	3.5	47.56	0.08	0
08/09/2023 20:00	3.4	46.53	0.08	0
08/09/2023 21:00	3.4	48.76	0.08	0
08/09/2023 22:00	3.3	50.47	0.08	0
08/09/2023 23:00	3.1	51.77	0.08	0
09/09/2023 00:00	3.1	52.47	0.08	0
09/09/2023 01:00	3	52.08	0.08	0
09/09/2023 02:00	3	50.83	0.08	0
09/09/2023 03:00	3	52.49	0.08	0
09/09/2023 04:00	2.9	51.81	0.08	0
09/09/2023 05:00	2.9	50.4	0.08	0
09/09/2023 06:00	2.9	49.8	0.08	0
09/09/2023 07:00	2.9	47.61	0.08	0
09/09/2023 08:00	2.9	48.82	0.08	0
09/09/2023 09:00	2.8	49.16	0.08	0
09/09/2023 10:00	2.8	49.52	0.08	0
09/09/2023 11:00	2.8	49.11	0.08	0
09/09/2023 12:00	2.9	48.74	0.08	0
09/09/2023 13:00	2.9	48.66	0.08	0
09/09/2023 14:00	3	47.77	0.08	0
09/09/2023 15:00	2.9	50.56	0.08	0
09/09/2023 16:00	3	49.35	0.08	0
09/09/2023 17:00	3	49.86	0.08	0
09/09/2023 18:00	3	51.77	0.08	0
09/09/2023 19:00	3	53.12	0.08	0
09/09/2023 20:00	3	52.93	0.08	0
09/09/2023 21:00	3	51.15	0.08	0
09/09/2023 22:00	3	49.58	0.08	0
09/09/2023 23:00	3	49.1	0.08	0
10/09/2023 00:00	3	47.39	0.08	0
10/09/2023 01:00	2.9	49.61	0.08	0
10/09/2023 02:00	2.9	49.39	0.08	0
10/09/2023 03:00	2.9	52.25	0.08	0
10/09/2023 04:00	2.9	52.04	0.08	0
10/09/2023 05:00	2.9	51.14	0.08	0
10/09/2023 06:00	2.9	49.89	0.08	0
10/09/2023 07:00	2.9	48.2	0.08	0
10/09/2023 08:00	2.9	48.48	0.08	0
10/09/2023 09:00	2.8	48.37	0.08	0
10/09/2023 10:00	2.8	49	0.08	0
10/09/2023 11:00	2.8	48.22	0.08	0
10/09/2023 12:00	2.9	48.46	0.08	0
10/09/2023 13:00	2.9	48.19	0.08	0
10/09/2023 14:00	3	47.08	0.08	0
10/09/2023 15:00	3	44.86	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD ppm	FLOW m3/Hr	POWER KW	Fire_Alarm #
10/09/2023 16:00	3	46.87	0.08	0
10/09/2023 17:00	3.1	48.25	0.08	0
10/09/2023 18:00	3.1	49.01	0.08	0
10/09/2023 19:00	3.1	47.44	0.08	0
10/09/2023 20:00	3.1	46.1	0.08	0
10/09/2023 21:00	3.2	47.23	0.08	0
10/09/2023 22:00	3.2	46.39	0.08	0
10/09/2023 23:00	3.1	46.34	0.08	0
11/09/2023 00:00	3.1	46.07	0.08	0
11/09/2023 01:00	3.1	45.59	0.08	0
11/09/2023 02:00	3	47.1	0.08	0
11/09/2023 03:00	3	49.39	0.08	0
11/09/2023 04:00	3	51.89	0.08	0
11/09/2023 05:00	3	49.52	0.08	0
11/09/2023 06:00	3	51.28	0.08	0
11/09/2023 07:00	3	56.77	0.08	0
11/09/2023 08:00	2.9	63.02	0.08	0
11/09/2023 09:00	2.9	57.99	0.08	0
11/09/2023 10:00	2.9	52.19	0.08	0
11/09/2023 11:00	2.9	49.84	0.08	0
11/09/2023 12:00	2.9	47.9	0.08	0
11/09/2023 13:00	2.9	47.99	0.08	0
11/09/2023 14:00	2.9	64.69	0.08	0
11/09/2023 15:00	3	60.04	0.08	0
11/09/2023 16:00	3	52.94	0.08	0
11/09/2023 17:00	3	48.05	0.08	0
11/09/2023 18:00	3	47.49	0.08	0
11/09/2023 19:00	3	47.4	0.08	0
11/09/2023 20:00	3	47.42	0.08	0
11/09/2023 21:00	3	45.85	0.08	0
11/09/2023 22:00	3	46.81	0.08	0
11/09/2023 23:00	3	46.6	0.08	0
12/09/2023 00:00	3	46.45	0.08	0
12/09/2023 01:00	3	46.52	0.08	0
12/09/2023 02:00	3	47.44	0.08	0
12/09/2023 03:00	3	47.1	0.08	0
12/09/2023 04:00	2.9	47.91	0.08	0
12/09/2023 05:00	2.9	48.11	0.08	0
12/09/2023 06:00	2.9	47.5	0.08	0
12/09/2023 07:00	2.9	49.93	0.08	0
12/09/2023 08:00	2.9	49.97	0.08	0
12/09/2023 09:00	2.9	49.51	0.08	0
12/09/2023 10:00	2.9	48.71	0.08	0
12/09/2023 11:00	2.9	48.05	0.08	0
12/09/2023 12:00	3	47.42	0.08	0
12/09/2023 13:00	3	45.98	0.08	0
12/09/2023 14:00	3.1	45.15	0.08	0
12/09/2023 15:00	3.1	45.02	0.08	0
12/09/2023 16:00	3.1	46.55	0.08	0
12/09/2023 17:00	3.1	46.3	0.08	0
12/09/2023 18:00	3.1	46.85	0.08	0
12/09/2023 19:00	3.1	48.28	0.08	0
12/09/2023 20:00	3.2	49.02	0.08	0
12/09/2023 21:00	3.1	46.6	0.08	0
12/09/2023 22:00	3.1	49.52	0.08	0
12/09/2023 23:00	3.2	50.86	0.08	0
13/09/2023 00:00	3.2	51.55	0.08	0
13/09/2023 01:00	3.2	53.16	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD ppm	FLOW m3/Hr	POWER KW	Fire_Alarm #
13/09/2023 02:00	3.2	51.88	0.08	0
13/09/2023 03:00	3.2	65.24	0.08	0
13/09/2023 04:00	3.1	60.11	0.08	0
13/09/2023 05:00	3.1	52.99	0.08	0
13/09/2023 06:00	3.1	49.76	0.08	0
13/09/2023 07:00	3.1	49.75	0.08	0
13/09/2023 08:00	3.1	50.07	0.08	0
13/09/2023 09:00	3.1	47.9	0.08	0
13/09/2023 10:00	3.1	69.54	0.08	0
13/09/2023 11:00	3.1	63.73	0.08	0
13/09/2023 12:00	3.1	54.53	0.08	0
13/09/2023 13:00	3.2	50.06	0.08	0
13/09/2023 14:00	3.3	48.98	0.08	0
13/09/2023 15:00	3.3	47.32	0.08	0
13/09/2023 16:00	3.3	45.34	0.08	0
13/09/2023 17:00	3.4	45.12	0.08	0
13/09/2023 18:00	3.4	46.19	0.08	0
13/09/2023 19:00	3.5	47.77	0.08	0
13/09/2023 20:00	3.5	48.13	0.08	0
13/09/2023 21:00	3.5	48.73	0.08	0
13/09/2023 22:00	3.4	50.23	0.08	0
13/09/2023 23:00	3.4	52.13	0.08	0
14/09/2023 00:00	3.3	53.02	0.08	0
14/09/2023 01:00	3.2	52.33	0.08	0
14/09/2023 02:00	NoData	NoData	NoData	NoData
14/09/2023 03:00	NoData	NoData	NoData	NoData
14/09/2023 04:00	NoData	NoData	NoData	NoData
14/09/2023 05:00	NoData	NoData	NoData	NoData
14/09/2023 06:00	NoData	NoData	NoData	NoData
14/09/2023 07:00	NoData	NoData	NoData	NoData
14/09/2023 08:00	NoData	NoData	NoData	NoData
14/09/2023 09:00	NoData	NoData	NoData	NoData
14/09/2023 10:00	NoData	NoData	NoData	NoData

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
25/09/2023 04:00	14.2	54.56	0.08	0
25/09/2023 05:00	14.1	51.09	0.08	0
25/09/2023 06:00	14.1	49.81	0.08	0
25/09/2023 07:00	14.1	50.2	0.08	0
25/09/2023 08:00	14.1	49.61	0.08	0
25/09/2023 09:00	14.1	55.36	0.08	0
25/09/2023 10:00	14.1	52.83	0.08	0
25/09/2023 11:00	14.1	50.6	0.08	0
25/09/2023 12:00	14.1	49.16	0.08	0
25/09/2023 13:00	14.1	50.93	0.08	0
25/09/2023 14:00	14.1	52.9	0.08	0
25/09/2023 15:00	14.1	60.46	0.08	0
25/09/2023 16:00	14.1	63.36	0.08	0
25/09/2023 17:00	14.1	53.65	0.08	0
25/09/2023 18:00	14.1	51.23	0.08	0
25/09/2023 19:00	14.1	50.77	0.08	0
25/09/2023 20:00	14.1	48.87	0.08	0
25/09/2023 21:00	14.1	49.24	0.09	0
25/09/2023 22:00	14.1	49.04	0.08	0
25/09/2023 23:00	14.1	48.77	0.09	0
26/09/2023 00:00	14.1	48.51	0.08	0
26/09/2023 01:00	14.2	49.9	0.08	0
26/09/2023 02:00	14.2	49.72	0.08	0
26/09/2023 03:00	14.2	49.54	0.08	0
26/09/2023 04:00	14.2	48.74	0.08	0
26/09/2023 05:00	14.2	48.35	0.09	0
26/09/2023 06:00	14.2	48.6	0.08	0
26/09/2023 07:00	14.2	45.86	0.09	0
26/09/2023 08:00	14.1	44.31	0.08	0
26/09/2023 09:00	14.1	47.09	0.08	0
26/09/2023 10:00	14.1	49.62	0.09	0
26/09/2023 11:00	14.1	50.82	0.08	0
26/09/2023 12:00	14.1	49.05	0.08	0
26/09/2023 13:00	14.1	47.51	0.08	0
26/09/2023 14:00	14.1	49.35	0.08	0
26/09/2023 15:00	14.1	49.05	0.08	0
26/09/2023 16:00	14.1	49.04	0.08	0
26/09/2023 17:00	14.1	45.93	0.08	0
26/09/2023 18:00	14.2	49.24	0.08	0
26/09/2023 19:00	14.1	47.72	0.08	0
26/09/2023 20:00	14.1	47.12	0.08	0
26/09/2023 21:00	14.2	44.58	0.08	0
26/09/2023 22:00	14.2	44.2	0.08	0
26/09/2023 23:00	14.2	44.07	0.08	0
27/09/2023 00:00	14.2	43.1	0.08	0
27/09/2023 01:00	14.1	45.86	0.08	0
27/09/2023 02:00	14.1	47.72	0.08	0
27/09/2023 03:00	14.1	48.74	0.08	0
27/09/2023 04:00	14.1	47.02	0.08	0
27/09/2023 05:00	14.2	47.48	0.09	0
27/09/2023 06:00	14.2	47.37	0.09	0
27/09/2023 07:00	14.2	47.95	0.09	0
27/09/2023 08:00	14.2	49.12	0.08	0
27/09/2023 09:00	13.9	51.6	0.08	0
27/09/2023 10:00	13.7	49.2	0.08	0
27/09/2023 11:00	13.7	50.71	0.08	0
27/09/2023 12:00	13.7	47.68	0.08	0
27/09/2023 13:00	13.7	47.31	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
27/09/2023 14:00	13.7	45.71	0.08	0
27/09/2023 15:00	13.8	44.92	0.08	0
27/09/2023 16:00	13.8	44.96	0.08	0
27/09/2023 17:00	13.8	44.98	0.08	0
27/09/2023 18:00	13.8	44.9	0.08	0
27/09/2023 19:00	13.8	46.16	0.08	0
27/09/2023 20:00	13.8	47.35	0.08	0
27/09/2023 21:00	13.8	45.62	0.08	0
27/09/2023 22:00	13.8	46.2	0.08	0
27/09/2023 23:00	13.8	46.01	0.08	0
28/09/2023 00:00	13.9	45.87	0.08	0
28/09/2023 01:00	13.9	45.33	0.08	0
28/09/2023 02:00	13.9	45.92	0.08	0
28/09/2023 03:00	13.9	44.85	0.08	0
28/09/2023 04:00	13.9	45.47	0.08	0
28/09/2023 05:00	13.9	46.44	0.08	0
28/09/2023 06:00	13.9	46.24	0.08	0
28/09/2023 07:00	13.9	48.01	0.08	0
28/09/2023 08:00	13.9	46.89	0.08	0
28/09/2023 09:00	13.9	46.56	0.08	0
28/09/2023 10:00	13.8	45.77	0.08	0
28/09/2023 11:00	13.9	50.68	0.08	0
28/09/2023 12:00	13.9	50.89	0.08	0
28/09/2023 13:00	13.9	49.24	0.08	0
28/09/2023 14:00	13.9	47.51	0.08	0
28/09/2023 15:00	13.9	47.15	0.08	0
28/09/2023 16:00	13.9	47.51	0.08	0
28/09/2023 17:00	13.9	51.2	0.08	0
28/09/2023 18:00	13.9	61.21	0.08	0
28/09/2023 19:00	13.9	51.89	0.08	0
28/09/2023 20:00	13.8	55.87	0.08	0
28/09/2023 21:00	13.8	53.28	0.08	0
28/09/2023 22:00	13.8	53.46	0.09	0
28/09/2023 23:00	13.8	50.94	0.08	0
29/09/2023 00:00	13.8	49.89	0.08	0
29/09/2023 01:00	13.9	47.48	0.08	0
29/09/2023 02:00	13.9	49.08	0.09	0
29/09/2023 03:00	13.9	47.62	0.09	0
29/09/2023 04:00	13.9	54.91	0.09	0
29/09/2023 05:00	13.9	67.31	0.09	0
29/09/2023 06:00	13.9	56.2	0.09	0
29/09/2023 07:00	13.9	50.47	0.09	0
29/09/2023 08:00	13.9	50.68	0.08	0
29/09/2023 09:00	13.9	49.85	0.08	0
29/09/2023 10:00	13.9	49.11	0.08	0
29/09/2023 11:00	13.9	48.35	0.08	0
29/09/2023 12:00	13.9	48.24	0.08	0
29/09/2023 13:00	13.9	48.34	0.08	0
29/09/2023 14:00	13.9	48.6	0.08	0
29/09/2023 15:00	13.9	48	0.08	0
29/09/2023 16:00	13.9	47.01	0.08	0
29/09/2023 17:00	13.9	52.48	0.08	0
29/09/2023 18:00	13.9	57.07	0.08	0
29/09/2023 19:00	13.9	52.48	0.08	0
29/09/2023 20:00	13.9	51.66	0.08	0
29/09/2023 21:00	13.9	50.45	0.08	0
29/09/2023 22:00	13.9	48.99	0.08	0
29/09/2023 23:00	13.9	47.73	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
30/09/2023 00:00	13.9	48.28	0.08	0
30/09/2023 01:00	13.9	48.65	0.09	0
30/09/2023 02:00	13.9	47.74	0.09	0
30/09/2023 03:00	13.9	65.3	0.09	0
30/09/2023 04:00	14	56.03	0.09	0
30/09/2023 05:00	13.9	51.25	0.09	0
30/09/2023 06:00	13.9	49.7	0.09	0
30/09/2023 07:00	13.9	47.81	0.09	0
30/09/2023 08:00	13.9	48.01	0.08	0
30/09/2023 09:00	13.9	48.24	0.08	0
30/09/2023 10:00	13.9	48.28	0.08	0
30/09/2023 11:00	13.8	46.17	0.08	0
30/09/2023 12:00	13.8	47.77	0.08	0
30/09/2023 13:00	13.9	46.19	0.08	0
30/09/2023 14:00	13.9	45.9	0.08	0
30/09/2023 15:00	13.9	44.74	0.08	0
30/09/2023 16:00	13.9	42.99	0.08	0
30/09/2023 17:00	13.9	48.3	0.08	0
30/09/2023 18:00	13.9	55.04	0.08	0
30/09/2023 19:00	14	46.87	0.08	0
30/09/2023 20:00	14	44.08	0.08	0
30/09/2023 21:00	14	48.04	0.08	0
30/09/2023 22:00	14	46.49	0.08	0
30/09/2023 23:00	14	48.95	0.08	0
Minimum	2.2	26.26	0.08	0
MinDate	02/09/2023 08:00	07/09/2023 20:00	01/09/2023 00:00	01/09/2023 00:00
Maximum	14.3	95.13	0.09	0
MaxDate	23/09/2023 14:00	24/09/2023 09:00	01/09/2023 07:00	01/09/2023 00:00
Avg	7.1	49.43	0.08	0
Num	496	496	496	496
Data[%]	68.8	68.8	68.8	68.8
STD	5.3	5.4	0	0
	3506	24518.95	39.91	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
01/10/2023 00:00	14	47.77	0.08	0
01/10/2023 01:00	14	48.15	0.08	0
01/10/2023 02:00	14	43.65	0.08	0
01/10/2023 03:00	14	47.99	0.08	0
01/10/2023 04:00	14	44.95	0.09	0
01/10/2023 05:00	14	42.54	0.08	0
01/10/2023 06:00	14	48.06	0.08	0
01/10/2023 07:00	14	44.86	0.08	0
01/10/2023 08:00	14	44.31	0.08	0
01/10/2023 09:00	14	45.48	0.08	0
01/10/2023 10:00	14	46.37	0.08	0
01/10/2023 11:00	14	45.7	0.08	0
01/10/2023 12:00	14	46.24	0.08	0
01/10/2023 13:00	14	45.41	0.08	0
01/10/2023 14:00	14	44.82	0.08	0
01/10/2023 15:00	13.9	46.2	0.08	0
01/10/2023 16:00	13.9	46.44	0.08	0
01/10/2023 17:00	13.9	46.4	0.08	0
01/10/2023 18:00	13.9	46.91	0.08	0
01/10/2023 19:00	13.9	47.3	0.08	0
01/10/2023 20:00	13.9	46.9	0.08	0
01/10/2023 21:00	13.9	47.7	0.08	0
01/10/2023 22:00	13.9	46.27	0.08	0
01/10/2023 23:00	13.9	45.64	0.08	0
02/10/2023 00:00	13.9	45.23	0.08	0
02/10/2023 01:00	13.9	46.37	0.08	0
02/10/2023 02:00	14	47.4	0.08	0
02/10/2023 03:00	14.1	75.25	0.08	0
02/10/2023 04:00	14.2	72.19	0.08	0
02/10/2023 05:00	14.1	59.21	0.09	0
02/10/2023 06:00	14.1	54.02	0.09	0
02/10/2023 07:00	14.1	51.51	0.08	0
02/10/2023 08:00	14.1	49.69	0.09	0
02/10/2023 09:00	14.1	49.62	0.08	0
02/10/2023 10:00	14.1	49.21	0.08	0
02/10/2023 11:00	14	47.18	0.08	0
02/10/2023 12:00	14	54.81	0.08	0
02/10/2023 13:00	14	49.12	0.08	0
02/10/2023 14:00	14	47.91	0.08	0
02/10/2023 15:00	14	46.05	0.08	0
02/10/2023 16:00	14.1	46.33	0.08	0
02/10/2023 17:00	14.1	63.72	0.08	0
02/10/2023 18:00	14.1	52.91	0.08	0
02/10/2023 19:00	14	47.67	0.08	0
02/10/2023 20:00	14	48.38	0.08	0
02/10/2023 21:00	14	44.58	0.08	0
02/10/2023 22:00	14	45.26	0.08	0
02/10/2023 23:00	14	49.37	0.08	0
03/10/2023 00:00	14	47.83	0.08	0
03/10/2023 01:00	14	43.46	0.08	0
03/10/2023 02:00	13.9	47.71	0.08	0
03/10/2023 03:00	13.9	47.66	0.08	0
03/10/2023 04:00	13.9	48.29	0.08	0
03/10/2023 05:00	13.9	48.99	0.08	0
03/10/2023 06:00	13.9	53.93	0.08	0
03/10/2023 07:00	13.9	51.72	0.09	0
03/10/2023 08:00	13.9	49.13	0.09	0
03/10/2023 09:00	13.9	48.46	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
03/10/2023 10:00	13.9	47.46	0.08	0
03/10/2023 11:00	13.9	48.59	0.08	0
03/10/2023 12:00	13.9	56.18	0.08	0
03/10/2023 13:00	13.9	69.95	0.08	0
03/10/2023 14:00	13.9	71.24	0.09	0
03/10/2023 15:00	13.9	64.58	0.09	0
03/10/2023 16:00	13.9	57.73	0.08	0
03/10/2023 17:00	13.9	51.06	0.09	0
03/10/2023 18:00	13.9	52.87	0.08	0
03/10/2023 19:00	13.9	52.29	0.08	0
03/10/2023 20:00	14.7	49.23	0.08	0
03/10/2023 21:00	14	50.48	0.09	0
03/10/2023 22:00	13.9	49.29	0.09	0
03/10/2023 23:00	13.9	50.48	0.09	0
04/10/2023 00:00	13.8	46.29	0.09	0
04/10/2023 01:00	13.8	49.93	0.09	0
04/10/2023 02:00	13.8	50.41	0.08	0
04/10/2023 03:00	13.8	56.24	0.09	0
04/10/2023 04:00	13.8	60.1	0.09	0
04/10/2023 05:00	13.8	53.96	0.09	0
04/10/2023 06:00	13.8	50.12	0.09	0
04/10/2023 07:00	13.8	49.49	0.09	0
04/10/2023 08:00	13.8	49.11	0.09	0
04/10/2023 09:00	13.9	67.06	0.09	0
04/10/2023 10:00	13.8	58.5	0.08	0
04/10/2023 11:00	13.8	51.97	0.08	0
04/10/2023 12:00	13.9	49.74	0.08	0
04/10/2023 13:00	13.9	47.1	0.08	0
04/10/2023 14:00	13.9	46.15	0.08	0
04/10/2023 15:00	14	45.45	0.08	0
04/10/2023 16:00	13.9	47.01	0.08	0
04/10/2023 17:00	13.9	45.74	0.08	0
04/10/2023 18:00	13.9	47.27	0.08	0
04/10/2023 19:00	13.9	49.4	0.08	0
04/10/2023 20:00	13.8	48.67	0.08	0
04/10/2023 21:00	13.9	47.92	0.08	0
04/10/2023 22:00	13.9	47.76	0.08	0
04/10/2023 23:00	13.8	46.84	0.09	0
05/10/2023 00:00	13.8	47.35	0.09	0
05/10/2023 01:00	13.8	46.75	0.09	0
05/10/2023 02:00	13.9	47	0.09	0
05/10/2023 03:00	13.9	46.13	0.09	0
05/10/2023 04:00	13.9	47.2	0.09	0
05/10/2023 05:00	13.9	46.6	0.08	0
05/10/2023 06:00	13.9	47.83	0.09	0
05/10/2023 07:00	13.9	46	0.09	0
05/10/2023 08:00	13.9	46.16	0.09	0
05/10/2023 09:00	13.9	46.61	0.08	0
05/10/2023 10:00	13.9	47.43	0.08	0
05/10/2023 11:00	13.9	42.62	0.08	0
05/10/2023 12:00	13.8	36.44	0.08	0
05/10/2023 13:00	13.8	36.27	0.08	0
05/10/2023 14:00	13.8	35	0.08	0
05/10/2023 15:00	13.8	32.77	0.08	0
05/10/2023 16:00	13.8	31.24	0.08	0
05/10/2023 17:00	13.8	30.54	0.08	0
05/10/2023 18:00	13.8	28.89	0.08	0
05/10/2023 19:00	13.7	31.45	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
05/10/2023 20:00	13.7	38.8	0.08	0
05/10/2023 21:00	13.7	43.25	0.08	0
05/10/2023 22:00	13.7	45.05	0.08	0
05/10/2023 23:00	13.7	50.33	0.08	0
06/10/2023 00:00	13.7	50.26	0.08	0
06/10/2023 01:00	13.7	48.1	0.08	0
06/10/2023 02:00	13.7	47.79	0.09	0
06/10/2023 03:00	13.7	48	0.09	0
06/10/2023 04:00	13.8	47.22	0.08	0
06/10/2023 05:00	13.7	45.94	0.08	0
06/10/2023 06:00	13.8	45.79	0.08	0
06/10/2023 07:00	13.8	45.88	0.08	0
06/10/2023 08:00	13.8	46.49	0.08	0
06/10/2023 09:00	13.8	47.37	0.08	0
06/10/2023 10:00	13.8	48.15	0.08	0
06/10/2023 11:00	13.8	52.07	0.08	0
06/10/2023 12:00	13.8	52.26	0.08	0
06/10/2023 13:00	13.8	47.77	0.08	0
06/10/2023 14:00	13.8	46.02	0.08	0
06/10/2023 15:00	13.8	46.42	0.08	0
06/10/2023 16:00	13.8	47.03	0.08	0
06/10/2023 17:00	13.9	51.99	0.08	0
06/10/2023 18:00	13.9	58.47	0.08	0
06/10/2023 19:00	13.9	52.27	0.08	0
06/10/2023 20:00	13.9	49.57	0.08	0
06/10/2023 21:00	13.9	49.05	0.08	0
06/10/2023 22:00	13.9	49.37	0.08	0
06/10/2023 23:00	13.9	46.34	0.08	0
07/10/2023 00:00	13.9	46.74	0.08	0
07/10/2023 01:00	13.9	46.48	0.08	0
07/10/2023 02:00	13.9	45.43	0.08	0
07/10/2023 03:00	13.9	46.21	0.08	0
07/10/2023 04:00	13.9	46.06	0.08	0
07/10/2023 05:00	13.9	46.28	0.08	0
07/10/2023 06:00	13.9	46.18	0.08	0
07/10/2023 07:00	13.8	47.69	0.08	0
07/10/2023 08:00	13.9	48.7	0.08	0
07/10/2023 09:00	3	49.2	0.08	0
07/10/2023 10:00	1.5	48.6	0.08	0
07/10/2023 11:00	1.5	49.02	0.08	0
07/10/2023 12:00	1.5	45.8	0.08	0
07/10/2023 13:00	1.5	48.62	0.08	0
07/10/2023 14:00	1.5	49.78	0.08	0
07/10/2023 15:00	1.5	50.87	0.08	0
07/10/2023 16:00	1.5	48.54	0.08	0
07/10/2023 17:00	1.5	47.43	0.08	0
07/10/2023 18:00	1.5	46.89	0.08	0
07/10/2023 19:00	1.5	45.96	0.08	0
07/10/2023 20:00	1.5	46.86	0.08	0
07/10/2023 21:00	1.5	49.61	0.08	0
07/10/2023 22:00	1.5	48.31	0.08	0
07/10/2023 23:00	1.5	48.61	0.08	0
08/10/2023 00:00	1.5	48.88	0.08	0
08/10/2023 01:00	1.5	45.06	0.08	0
08/10/2023 02:00	1.5	45.6	0.08	0
08/10/2023 03:00	1.5	45.78	0.08	0
08/10/2023 04:00	1.5	47.62	0.09	0
08/10/2023 05:00	1.5	48.91	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
08/10/2023 06:00	1.5	51.14	0.09	0
08/10/2023 07:00	1.5	46.8	0.08	0
08/10/2023 08:00	1.5	48.93	0.08	0
08/10/2023 09:00	1.5	49.13	0.08	0
08/10/2023 10:00	1.5	49.18	0.08	0
08/10/2023 11:00	1.5	47.91	0.08	0
08/10/2023 12:00	1.5	46.57	0.08	0
08/10/2023 13:00	1.5	47.37	0.08	0
08/10/2023 14:00	1.5	45.89	0.08	0
08/10/2023 15:00	1.5	46.17	0.08	0
08/10/2023 16:00	1.5	47.52	0.08	0
08/10/2023 17:00	1.5	46.73	0.08	0
08/10/2023 18:00	1.5	47.52	0.08	0
08/10/2023 19:00	1.5	50.35	0.08	0
08/10/2023 20:00	1.5	50.03	0.08	0
08/10/2023 21:00	1.5	52.04	0.08	0
08/10/2023 22:00	1.5	53.98	0.08	0
08/10/2023 23:00	1.5	48.75	0.08	0
09/10/2023 00:00	1.5	47.53	0.08	0
09/10/2023 01:00	1.5	52.74	0.08	0
09/10/2023 02:00	1.5	61.77	0.08	0
09/10/2023 03:00	1.5	53.42	0.08	0
09/10/2023 04:00	1.5	52.17	0.08	0
09/10/2023 05:00	1.5	52.83	0.08	0
09/10/2023 06:00	1.6	50.13	0.08	0
09/10/2023 07:00	1.6	50.35	0.08	0
09/10/2023 08:00	1.6	49.83	0.08	0
09/10/2023 09:00	1.6	50.27	0.08	0
09/10/2023 10:00	1.5	50.09	0.08	0
09/10/2023 11:00	1.6	48.79	0.08	0
09/10/2023 12:00	1.6	48.42	0.08	0
09/10/2023 13:00	1.6	48.59	0.08	0
09/10/2023 14:00	1.6	48.51	0.08	0
09/10/2023 15:00	1.6	48.56	0.08	0
09/10/2023 16:00	1.6	47.01	0.08	0
09/10/2023 17:00	1.6	47.1	0.08	0
09/10/2023 18:00	1.6	47.61	0.08	0
09/10/2023 19:00	1.6	48.83	0.08	0
09/10/2023 20:00	1.6	45.8	0.08	0
09/10/2023 21:00	1.6	50.11	0.08	0
09/10/2023 22:00	1.5	45.18	0.08	0
09/10/2023 23:00	1.5	50.07	0.08	0
10/10/2023 00:00	1.5	48.71	0.08	0
10/10/2023 01:00	1.6	48.41	0.08	0
10/10/2023 02:00	1.5	48.71	0.08	0
10/10/2023 03:00	1.6	50.99	0.09	0
10/10/2023 04:00	1.6	50.31	0.08	0
10/10/2023 05:00	1.5	50.68	0.08	0
10/10/2023 06:00	1.4	50.98	0.09	0
10/10/2023 07:00	1.5	49.99	0.08	0
10/10/2023 08:00	1.5	51.19	0.08	0
10/10/2023 09:00	1.5	51.51	0.08	0
10/10/2023 10:00	1.5	49.3	0.08	0
10/10/2023 11:00	1.5	48.89	0.08	0
10/10/2023 12:00	1.5	46.02	0.08	0
10/10/2023 13:00	1.4	47.68	0.08	0
10/10/2023 14:00	1.5	48.34	0.08	0
10/10/2023 15:00	1.4	48.77	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
10/10/2023 16:00	1.4	50.8	0.08	0
10/10/2023 17:00	1.5	50.13	0.08	0
10/10/2023 18:00	1.5	49.8	0.08	0
10/10/2023 19:00	1.5	50.07	0.08	0
10/10/2023 20:00	1.5	48.93	0.08	0
10/10/2023 21:00	1.5	50.68	0.08	0
10/10/2023 22:00	1.5	47.37	0.08	0
10/10/2023 23:00	1.5	50.81	0.09	0
11/10/2023 00:00	1.5	46.07	0.08	0
11/10/2023 01:00	1.5	47	0.08	0
11/10/2023 02:00	1.5	50.24	0.09	0
11/10/2023 03:00	1.5	51.67	0.09	0
11/10/2023 04:00	1.5	49.14	0.08	0
11/10/2023 05:00	1.5	48.92	0.08	0
11/10/2023 06:00	1.6	48.8	0.09	0
11/10/2023 07:00	1.6	47.93	0.09	0
11/10/2023 08:00	1.6	49.4	0.09	0
11/10/2023 09:00	NoData	NoData	NoData	NoData
11/10/2023 10:00	NoData	NoData	NoData	NoData
11/10/2023 11:00	NoData	NoData	NoData	NoData
11/10/2023 12:00	NoData	NoData	NoData	NoData
11/10/2023 13:00	NoData	NoData	NoData	NoData
11/10/2023 14:00	NoData	NoData	NoData	NoData
11/10/2023 15:00	NoData	NoData	NoData	NoData
11/10/2023 16:00	---	---	---	---
11/10/2023 17:00	<Samp	<Samp	<Samp	<Samp
11/10/2023 18:00	1.5	51.88	0.08	0
11/10/2023 19:00	1.5	51.6	0.08	0
11/10/2023 20:00	1.5	50.48	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
13/10/2023 02:00	1.5	69.6	0.07	0
13/10/2023 03:00	1.5	61.33	0.07	0
13/10/2023 04:00	1.5	57.37	0.07	0
13/10/2023 05:00	1.5	55.33	0.07	0
13/10/2023 06:00	1.5	54.75	0.07	0
13/10/2023 07:00	1.5	54.28	0.07	0
13/10/2023 08:00	1.6	54.85	0.07	0
13/10/2023 09:00	1.6	55.13	0.07	0
13/10/2023 10:00	1.6	55.65	0.07	0
13/10/2023 11:00	1.6	53.7	0.07	0
13/10/2023 12:00	1.6	52.19	0.07	0
13/10/2023 13:00	1.6	51.2	0.07	0
13/10/2023 14:00	1.6	51.21	0.07	0
13/10/2023 15:00	1.6	50.89	0.07	0
13/10/2023 16:00	1.6	49.84	0.07	0
13/10/2023 17:00	1.6	50.15	0.07	0
13/10/2023 18:00	1.6	50.69	0.07	0
13/10/2023 19:00	1.6	52.21	0.07	0
13/10/2023 20:00	1.5	53.78	0.07	0
13/10/2023 21:00	1.5	55.37	0.07	0
13/10/2023 22:00	1.5	54.69	0.07	0
13/10/2023 23:00	1.5	52.77	0.07	0
14/10/2023 00:00	1.6	53.49	0.07	0
14/10/2023 01:00	1.6	52.68	0.07	0
14/10/2023 02:00	1.6	51.66	0.07	0
14/10/2023 03:00	1.6	52.86	0.07	0
14/10/2023 04:00	1.6	54.8	0.07	0
14/10/2023 05:00	1.6	52.16	0.07	0
14/10/2023 06:00	1.6	51.38	0.07	0
14/10/2023 07:00	1.6	52.62	0.07	0
14/10/2023 08:00	1.6	54.84	0.07	0
14/10/2023 09:00	1.6	54.71	0.07	0
14/10/2023 10:00	1.6	54.27	0.07	0
14/10/2023 11:00	1.5	53.39	0.07	0
14/10/2023 12:00	1.5	50.34	0.07	0
14/10/2023 13:00	1.5	48.01	0.07	0
14/10/2023 14:00	1.6	46.58	0.07	0
14/10/2023 15:00	1.6	48.69	0.07	0
14/10/2023 16:00	1.6	47.24	0.07	0
14/10/2023 17:00	1.6	46.03	0.07	0
14/10/2023 18:00	1.6	46.74	0.07	0
14/10/2023 19:00	1.6	48.68	0.07	0
14/10/2023 20:00	1.6	49.64	0.07	0
14/10/2023 21:00	1.6	50.17	0.07	0
14/10/2023 22:00	1.6	50.17	0.07	0
14/10/2023 23:00	1.6	50.24	0.07	0
15/10/2023 00:00	1.6	49.88	0.07	0
15/10/2023 01:00	1.6	47.74	0.07	0
15/10/2023 02:00	1.6	48.73	0.07	0
15/10/2023 03:00	1.6	50.64	0.07	0
15/10/2023 04:00	1.6	45.76	0.07	0
15/10/2023 05:00	1.5	46.94	0.07	0
15/10/2023 06:00	1.5	52.33	0.07	0
15/10/2023 07:00	1.6	51.1	0.07	0
15/10/2023 08:00	1.6	50.49	0.07	0
15/10/2023 09:00	1.6	51.49	0.07	0
15/10/2023 10:00	1.6	50.78	0.07	0
15/10/2023 11:00	1.6	49.78	0.07	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
15/10/2023 12:00	1.6	49.06	0.07	0
15/10/2023 13:00	1.6	47.79	0.07	0
15/10/2023 14:00	1.6	45.92	0.07	0
15/10/2023 15:00	1.6	45.83	0.07	0
15/10/2023 16:00	1.6	46.69	0.07	0
15/10/2023 17:00	1.5	69.39	0.07	0
15/10/2023 18:00	1.4	70.43	0.07	0
15/10/2023 19:00	1.4	61.26	0.07	0
15/10/2023 20:00	1.4	55.86	0.07	0
15/10/2023 21:00	1.4	54.22	0.07	0
15/10/2023 22:00	1.5	52.69	0.07	0
15/10/2023 23:00	1.5	54.06	0.07	0
16/10/2023 00:00	1.5	53.15	0.07	0
16/10/2023 01:00	1.5	51.7	0.07	0
16/10/2023 02:00	1.5	52.97	0.07	0
16/10/2023 03:00	1.5	53.04	0.07	0
16/10/2023 04:00	1.5	52.03	0.07	0
16/10/2023 05:00	1.5	55.54	0.07	0
16/10/2023 06:00	1.5	54.47	0.07	0
16/10/2023 07:00	1.5	54.29	0.07	0
16/10/2023 08:00	1.5	53.48	0.07	0
16/10/2023 09:00	1.5	55.15	0.07	0
16/10/2023 10:00	1.5	53.91	0.07	0
16/10/2023 11:00	1.5	52.42	0.07	0
16/10/2023 12:00	1.5	51.71	0.07	0
16/10/2023 13:00	1.5	48.54	0.07	0
16/10/2023 14:00	1.6	54.54	0.07	0
16/10/2023 15:00	1.6	72.68	0.07	0
16/10/2023 16:00	1.5	89.9	0.07	0
16/10/2023 17:00	1.4	84.77	0.07	0
16/10/2023 18:00	1.4	65.76	0.07	0
16/10/2023 19:00	1.4	58.47	0.07	0
16/10/2023 20:00	1.4	55.32	0.07	0
16/10/2023 21:00	1.4	60.47	0.07	0
16/10/2023 22:00	1.4	57.63	0.07	0
16/10/2023 23:00	1.4	53.77	0.07	0
17/10/2023 00:00	1.5	52.63	0.07	0
17/10/2023 01:00	1.5	54.69	0.07	0
17/10/2023 02:00	1.5	71.06	0.07	0
17/10/2023 03:00	1.5	58.97	0.07	0
17/10/2023 04:00	1.5	55.81	0.07	0
17/10/2023 05:00	1.5	52.51	0.07	0
17/10/2023 06:00	1.5	49.31	0.07	0
17/10/2023 07:00	1.5	51.16	0.07	0
17/10/2023 08:00	1.5	53.97	0.07	0
17/10/2023 09:00	1.5	53.92	0.07	0
17/10/2023 10:00	1.5	52.35	0.07	0
17/10/2023 11:00	1.5	56.04	0.07	0
17/10/2023 12:00	1.5	61.55	0.07	0
17/10/2023 13:00	1.5	53.47	0.07	0
17/10/2023 14:00	1.5	49.22	0.07	0
17/10/2023 15:00	1.6	46.11	0.07	0
17/10/2023 16:00	1.6	46.72	0.07	0
17/10/2023 17:00	1.6	43.63	0.07	0
17/10/2023 18:00	1.6	42.01	0.07	0
17/10/2023 19:00	1.6	42.28	0.07	0
17/10/2023 20:00	1.5	43.02	0.07	0
17/10/2023 21:00	1.5	54.63	0.07	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
17/10/2023 22:00	1.5	51.84	0.07	0
17/10/2023 23:00	1.5	47.7	0.07	0
18/10/2023 00:00	1.5	47.62	0.07	0
18/10/2023 01:00	1.5	47.84	0.07	0
18/10/2023 02:00	1.5	46.79	0.07	0
18/10/2023 03:00	1.5	47.52	0.07	0
18/10/2023 04:00	1.5	47.31	0.07	0
18/10/2023 05:00	1.5	46.75	0.07	0
18/10/2023 06:00	1.5	47.54	0.07	0
18/10/2023 07:00	1.5	43.93	0.07	0
18/10/2023 08:00	1.5	46.57	0.07	0
18/10/2023 09:00	1.5	46.56	0.07	0
18/10/2023 10:00	1.5	61.63	0.07	0
18/10/2023 11:00	1.5	62.1	0.07	0
18/10/2023 12:00	1.4	81.77	0.07	0
18/10/2023 13:00	1.3	65.57	0.07	0
18/10/2023 14:00	1.3	58.13	0.07	0
18/10/2023 15:00	1.4	52.49	0.07	0
18/10/2023 16:00	1.4	50.28	0.07	0
18/10/2023 17:00	1.4	48.39	0.07	0
18/10/2023 18:00	1.5	47.83	0.07	0
18/10/2023 19:00	1.6	46.83	0.07	0
18/10/2023 20:00	1.7	47.51	0.07	0
18/10/2023 21:00	1.7	46.95	0.07	0
18/10/2023 22:00	1.7	46.93	0.07	0
18/10/2023 23:00	1.6	45.82	0.07	0
19/10/2023 00:00	1.6	48.59	0.07	0
19/10/2023 01:00	1.6	47.13	0.07	0
19/10/2023 02:00	1.5	46.08	0.07	0
19/10/2023 03:00	1.5	46.56	0.07	0
19/10/2023 04:00	1.5	46.08	0.07	0
19/10/2023 05:00	1.5	49.44	0.07	0
19/10/2023 06:00	1.5	50.06	0.07	0
19/10/2023 07:00	1.5	47.06	0.07	0
19/10/2023 08:00	1.4	47.04	0.07	0
19/10/2023 09:00	1.4	46.6	0.07	0
19/10/2023 10:00	1.4	46.32	0.07	0
19/10/2023 11:00	1.3	50.61	0.07	0
19/10/2023 12:00	1.3	62.29	0.07	0
19/10/2023 13:00	1.3	56.59	0.07	0
19/10/2023 14:00	1.6	50.91	0.07	0
19/10/2023 15:00	1.5	72.62	0.07	0
19/10/2023 16:00	1.5	55.02	0.07	0
19/10/2023 17:00	1.5	49.01	0.07	0
19/10/2023 18:00	1.6	46.13	0.07	0
19/10/2023 19:00	1.5	45.22	0.07	0
19/10/2023 20:00	1.5	45.22	0.07	0
19/10/2023 21:00	1.5	44.09	0.07	0
19/10/2023 22:00	1.5	43.63	0.07	0
19/10/2023 23:00	1.5	44.44	0.07	0
20/10/2023 00:00	1.5	44.12	0.07	0
20/10/2023 01:00	1.5	43.74	0.07	0
20/10/2023 02:00	1.5	43.85	0.07	0
20/10/2023 03:00	1.5	43.99	0.07	0
20/10/2023 04:00	1.4	44.26	0.07	0
20/10/2023 05:00	1.4	43.69	0.07	0
20/10/2023 06:00	1.4	43.25	0.07	0
20/10/2023 07:00	1.5	43.46	0.07	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
20/10/2023 08:00	1.5	41.45	0.07	0
20/10/2023 09:00	1.4	43.83	0.07	0
20/10/2023 10:00	1.4	44.12	0.07	0
20/10/2023 11:00	1.4	43.43	0.07	0
20/10/2023 12:00	1.5	42.44	0.07	0
20/10/2023 13:00	1.5	39.94	0.07	0
20/10/2023 14:00	1.5	40.74	0.07	0
20/10/2023 15:00	1.5	40.93	0.07	0
20/10/2023 16:00	1.5	41.08	0.07	0
20/10/2023 17:00	1.5	43.09	0.07	0
20/10/2023 18:00	1.5	42.99	0.07	0
20/10/2023 19:00	1.5	44.17	0.07	0
20/10/2023 20:00	1.5	43.58	0.07	0
20/10/2023 21:00	1.5	43.42	0.07	0
20/10/2023 22:00	1.5	42.6	0.07	0
20/10/2023 23:00	1.5	43.42	0.07	0
21/10/2023 00:00	1.5	43.18	0.07	0
21/10/2023 01:00	1.5	43.94	0.07	0
21/10/2023 02:00	1.5	42.14	0.07	0
21/10/2023 03:00	1.5	43.64	0.07	0
21/10/2023 04:00	1.5	42.84	0.07	0
21/10/2023 05:00	1.5	43.16	0.07	0
21/10/2023 06:00	1.5	43.62	0.07	0
21/10/2023 07:00	1.5	43.19	0.07	0
21/10/2023 08:00	1.5	43.3	0.07	0
21/10/2023 09:00	1.5	42.79	0.07	0
21/10/2023 10:00	1.5	43.46	0.07	0
21/10/2023 11:00	1.5	42.84	0.07	0
21/10/2023 12:00	1.5	42.36	0.07	0
21/10/2023 13:00	1.5	42.08	0.07	0
21/10/2023 14:00	1.6	42.17	0.07	0
21/10/2023 15:00	1.6	41.4	0.07	0
21/10/2023 16:00	1.6	42.01	0.07	0
21/10/2023 17:00	1.6	41.71	0.07	0
21/10/2023 18:00	1.5	41.62	0.07	0
21/10/2023 19:00	1.5	41.09	0.07	0
21/10/2023 20:00	1.5	43.52	0.07	0
21/10/2023 21:00	1.4	44.78	0.07	0
21/10/2023 22:00	1.5	43.85	0.07	0
21/10/2023 23:00	1.5	42.75	0.07	0
22/10/2023 00:00	1.5	45.13	0.07	0
22/10/2023 01:00	1.5	44.97	0.07	0
22/10/2023 02:00	1.5	44.17	0.07	0
22/10/2023 03:00	1.5	43.94	0.07	0
22/10/2023 04:00	1.5	43.05	0.07	0
22/10/2023 05:00	1.5	43.8	0.07	0
22/10/2023 06:00	1.5	43.35	0.07	0
22/10/2023 07:00	1.5	42.42	0.07	0
22/10/2023 08:00	1.6	43.1	0.07	0
22/10/2023 09:00	1.6	43.01	0.07	0
22/10/2023 10:00	1.5	59.89	0.07	0
22/10/2023 11:00	1.5	51.32	0.07	0
22/10/2023 12:00	1.6	45.02	0.07	0
22/10/2023 13:00	1.6	42.46	0.07	0
22/10/2023 14:00	1.5	42.29	0.07	0
22/10/2023 15:00	1.4	74.96	0.07	0
22/10/2023 16:00	1.5	59.6	0.07	0
22/10/2023 17:00	1.5	61.43	0.07	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire_Alarm
	ppm	m3/Hr	KW	#
22/10/2023 18:00	1.5	60.07	0.07	0
22/10/2023 19:00	1.6	53.6	0.07	0
22/10/2023 20:00	1.6	48.21	0.07	0
22/10/2023 21:00	1.8	73.67	0.07	0
22/10/2023 22:00	2.1	55.72	0.07	0
22/10/2023 23:00	2.2	61.6	0.07	0
23/10/2023 00:00	2.3	56.93	0.07	0
23/10/2023 01:00	2.6	49.13	0.07	0
23/10/2023 02:00	2.4	47.07	0.07	0
23/10/2023 03:00	2.3	46.46	0.07	0
23/10/2023 04:00	2.2	46.44	0.07	0
23/10/2023 05:00	2.2	45.66	0.07	0
23/10/2023 06:00	2.1	44.16	0.07	0
23/10/2023 07:00	2	43.7	0.07	0
23/10/2023 08:00	2	43.61	0.07	0
23/10/2023 09:00	1.9	44.61	0.07	0
23/10/2023 10:00	1.9	43.98	0.07	0
23/10/2023 11:00	1.9	43.28	0.07	0
23/10/2023 12:00	1.8	42.23	0.07	0
23/10/2023 13:00	1.8	41.68	0.07	0
23/10/2023 14:00	1.8	41.12	0.07	0
23/10/2023 15:00	1.8	40.76	0.07	0
23/10/2023 16:00	1.8	40.21	0.07	0
23/10/2023 17:00	1.8	39.05	0.07	0
23/10/2023 18:00	1.8	40.42	0.07	0
23/10/2023 19:00	1.8	38.14	0.07	0
23/10/2023 20:00	1.8	42.63	0.07	0
23/10/2023 21:00	1.7	43.5	0.07	0
23/10/2023 22:00	1.7	43.18	0.07	0
23/10/2023 23:00	1.7	42.83	0.07	0
24/10/2023 00:00	1.7	43.22	0.07	0
24/10/2023 01:00	1.7	42.87	0.07	0
24/10/2023 02:00	1.7	42.93	0.07	0
24/10/2023 03:00	1.7	43.53	0.07	0
24/10/2023 04:00	1.7	42.88	0.07	0
24/10/2023 05:00	1.7	43.29	0.07	0
24/10/2023 06:00	1.7	42.42	0.07	0
24/10/2023 07:00	1.7	43.01	0.07	0
24/10/2023 08:00	1.7	42.51	0.07	0
24/10/2023 09:00	1.7	43.62	0.07	0
24/10/2023 10:00	1.7	42.55	0.07	0
24/10/2023 11:00	1.7	42.98	0.07	0
24/10/2023 12:00	1.7	42.66	0.07	0
24/10/2023 13:00	1.7	42.34	0.07	0
24/10/2023 14:00	1.7	41.91	0.07	0
24/10/2023 15:00	1.7	42.15	0.07	0
24/10/2023 16:00	1.7	41.46	0.07	0
24/10/2023 17:00	1.8	41.49	0.07	0
24/10/2023 18:00	1.8	42.12	0.07	0
24/10/2023 19:00	1.8	42.22	0.07	0
24/10/2023 20:00	1.8	43.06	0.07	0
24/10/2023 21:00	1.8	43.03	0.07	0
24/10/2023 22:00	1.8	43.67	0.07	0
24/10/2023 23:00	1.8	43.45	0.07	0
25/10/2023 00:00	1.8	43.37	0.07	0
25/10/2023 01:00	1.8	43.95	0.07	0
25/10/2023 02:00	1.8	43.74	0.07	0
25/10/2023 03:00	1.8	44.12	0.07	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire_Alarm
	ppm	m3/Hr	KW	#
25/10/2023 04:00	1.8	43.88	0.07	0
25/10/2023 05:00	1.8	43.43	0.07	0
25/10/2023 06:00	1.8	44.27	0.07	0
25/10/2023 07:00	1.8	43.21	0.07	0
25/10/2023 08:00	1.7	43.24	0.07	0
25/10/2023 09:00	1.7	43.05	0.07	0
25/10/2023 10:00	1.7	42.91	0.07	0
25/10/2023 11:00	1.8	42.42	0.07	0
25/10/2023 12:00	1.8	42.5	0.07	0
25/10/2023 13:00	1.8	42.17	0.07	0
25/10/2023 14:00	1.8	41.64	0.07	0
25/10/2023 15:00	1.8	40.53	0.07	0
25/10/2023 16:00	1.8	39.96	0.07	0
25/10/2023 17:00	1.8	40.33	0.07	0
25/10/2023 18:00	1.8	39.13	0.07	0
25/10/2023 19:00	1.8	39.1	0.07	0
25/10/2023 20:00	1.8	40.09	0.07	0
25/10/2023 21:00	1.8	39.99	0.07	0
25/10/2023 22:00	1.8	36.61	0.07	0
25/10/2023 23:00	1.8	40.22	0.07	0
26/10/2023 00:00	1.8	40.25	0.07	0
26/10/2023 01:00	1.8	39.8	0.07	0
26/10/2023 02:00	1.8	40.5	0.07	0
26/10/2023 03:00	1.8	39.57	0.07	0
26/10/2023 04:00	1.8	40.33	0.07	0
26/10/2023 05:00	1.8	39.64	0.07	0
26/10/2023 06:00	1.8	39.85	0.07	0
26/10/2023 07:00	1.8	41	0.07	0
26/10/2023 08:00	1.8	41.04	0.07	0
26/10/2023 09:00	1.8	40.53	0.07	0
26/10/2023 10:00	1.7	40.28	0.07	0
26/10/2023 11:00	1.7	40.12	0.07	0
26/10/2023 12:00	1.8	39.48	0.07	0
26/10/2023 13:00	1.8	38.99	0.07	0
26/10/2023 14:00	1.8	48.74	0.07	0
26/10/2023 15:00	1.8	44.54	0.07	0
26/10/2023 16:00	1.9	40.68	0.07	0
26/10/2023 17:00	1.8	41.26	0.07	0
26/10/2023 18:00	1.8	40.49	0.07	0
26/10/2023 19:00	1.8	50.26	0.07	0
26/10/2023 20:00	1.8	47.98	0.07	0
26/10/2023 21:00	1.8	44.76	0.07	0
26/10/2023 22:00	1.8	42.91	0.07	0
26/10/2023 23:00	1.8	41.62	0.07	0
27/10/2023 00:00	1.8	40.97	0.07	0
27/10/2023 01:00	1.8	40.28	0.07	0
27/10/2023 02:00	1.8	40.27	0.07	0
27/10/2023 03:00	1.8	38.65	0.07	0
27/10/2023 04:00	1.8	40.03	0.07	0
27/10/2023 05:00	1.8	40.45	0.07	0
27/10/2023 06:00	1.8	40.4	0.07	0
27/10/2023 07:00	1.8	39.23	0.07	0
27/10/2023 08:00	1.8	40.97	0.07	0
27/10/2023 09:00	1.8	40.78	0.07	0
27/10/2023 10:00	1.8	39.92	0.07	0
27/10/2023 11:00	1.8	39.25	0.07	0
27/10/2023 12:00	1.8	38.9	0.07	0
27/10/2023 13:00	1.8	38.97	0.07	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire_Alarm
	ppm	m3/Hr	KW	#
27/10/2023 14:00	1.8	38.24	0.07	0
27/10/2023 15:00	1.8	39	0.07	0
27/10/2023 16:00	1.9	38.24	0.07	0
27/10/2023 17:00	1.9	36.06	0.07	0
27/10/2023 18:00	1.8	38.12	0.07	0
27/10/2023 19:00	1.8	37.82	0.07	0
27/10/2023 20:00	1.8	39.7	0.07	0
27/10/2023 21:00	1.8	40.22	0.07	0
27/10/2023 22:00	1.8	39.48	0.07	0
27/10/2023 23:00	1.8	40.32	0.07	0
28/10/2023 00:00	1.8	39.86	0.07	0
28/10/2023 01:00	1.8	40.43	0.07	0
28/10/2023 02:00	1.8	40.6	0.07	0
28/10/2023 03:00	1.8	40.17	0.07	0
28/10/2023 04:00	1.8	39.75	0.07	0
28/10/2023 05:00	1.8	40.79	0.07	0
28/10/2023 06:00	1.8	40.52	0.07	0
28/10/2023 07:00	1.8	39.52	0.07	0
28/10/2023 08:00	1.8	39.49	0.07	0
28/10/2023 09:00	1.8	37.29	0.07	0
28/10/2023 10:00	1.8	39.15	0.07	0
28/10/2023 11:00	1.8	38.67	0.07	0
28/10/2023 12:00	1.8	38.72	0.07	0
28/10/2023 13:00	1.9	39.13	0.07	0
28/10/2023 14:00	1.9	37.68	0.07	0
28/10/2023 15:00	1.9	36.5	0.07	0
28/10/2023 16:00	1.9	38.85	0.07	0
28/10/2023 17:00	1.9	40.22	0.07	0
28/10/2023 18:00	1.9	39.5	0.07	0
28/10/2023 19:00	1.9	40.18	0.07	0
28/10/2023 20:00	1.9	40.16	0.07	0
28/10/2023 21:00	1.9	40.6	0.07	0
28/10/2023 22:00	1.9	40.55	0.07	0
28/10/2023 23:00	1.9	40.31	0.07	0
29/10/2023 00:00	1.8	40.18	0.07	0
29/10/2023 01:00	1.8	40.18	0.07	0
29/10/2023 02:00	1.8	39.87	0.07	0
29/10/2023 03:00	1.8	40.24	0.07	0
29/10/2023 04:00	1.8	40.11	0.07	0
29/10/2023 05:00	1.8	39.35	0.07	0
29/10/2023 06:00	1.8	40.25	0.07	0
29/10/2023 07:00	1.8	40.09	0.07	0
29/10/2023 08:00	1.9	39.98	0.07	0
29/10/2023 09:00	1.9	39.89	0.07	0
29/10/2023 10:00	1.8	40.87	0.07	0
29/10/2023 11:00	1.8	43.16	0.07	0
29/10/2023 12:00	1.9	45.55	0.07	0
29/10/2023 13:00	1.9	44.16	0.07	0
29/10/2023 14:00	1.7	56.41	0.07	0
29/10/2023 15:00	1.7	50.89	0.07	0
29/10/2023 16:00	1.7	58.87	0.07	0
29/10/2023 17:00	1.7	47.48	0.07	0
29/10/2023 18:00	1.7	46.33	0.07	0
29/10/2023 19:00	1.8	43.45	0.07	0
29/10/2023 20:00	1.8	41.79	0.07	0
29/10/2023 21:00	1.8	41.41	0.07	0
29/10/2023 22:00	1.8	40.87	0.07	0
29/10/2023 23:00	1.8	41.25	0.07	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire_Alarm
	ppm	m3/Hr	KW	#
30/10/2023 00:00	1.8	41.06	0.07	0
30/10/2023 01:00	1.8	40.77	0.07	0
30/10/2023 02:00	1.8	39.02	0.07	0
30/10/2023 03:00	1.8	40.63	0.07	0
30/10/2023 04:00	1.8	39.78	0.07	0
30/10/2023 05:00	1.8	40.03	0.07	0
30/10/2023 06:00	1.8	39.72	0.07	0
30/10/2023 07:00	1.8	38.13	0.07	0
30/10/2023 08:00	1.9	40.12	0.07	0
30/10/2023 09:00	1.8	40.3	0.07	0
30/10/2023 10:00	1.8	40.08	0.07	0
30/10/2023 11:00	1.8	39.53	0.07	0
30/10/2023 12:00	1.9	39.53	0.07	0
30/10/2023 13:00	1.9	39.22	0.07	0
30/10/2023 14:00	1.9	38.05	0.07	0
30/10/2023 15:00	1.8	37.32	0.07	0
30/10/2023 16:00	1.7	45.43	0.07	0
30/10/2023 17:00	1.7	49.89	0.07	0
30/10/2023 18:00	1.7	48.81	0.07	0
30/10/2023 19:00	1.7	45.52	0.07	0
30/10/2023 20:00	1.7	43.91	0.07	0
30/10/2023 21:00	1.7	43.21	0.07	0
30/10/2023 22:00	1.7	43.27	0.07	0
30/10/2023 23:00	1.7	42.73	0.07	0
31/10/2023 00:00	1.8	42.6	0.07	0
31/10/2023 01:00	1.8	42.23	0.07	0
31/10/2023 02:00	1.7	41.64	0.07	0
31/10/2023 03:00	1.7	41.04	0.07	0
31/10/2023 04:00	1.7	41.12	0.07	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
01/11/2023 00:00	2	39.95	0.07	0
01/11/2023 01:00	2	38.72	0.07	0
01/11/2023 02:00	2	39.88	0.07	0
01/11/2023 03:00	2	38.58	0.07	0
01/11/2023 04:00	2	39.13	0.07	0
01/11/2023 05:00	2	39.24	0.07	0
01/11/2023 06:00	2	38.69	0.07	0
01/11/2023 07:00	2	39.43	0.07	0
01/11/2023 08:00	2	44.09	0.07	0
01/11/2023 09:00	2	44.87	0.07	0
01/11/2023 10:00	2	42.41	0.07	0
01/11/2023 11:00	2	40.85	0.07	0
01/11/2023 12:00	2	40.29	0.07	0
01/11/2023 13:00	2	39.34	0.07	0
01/11/2023 14:00	2	39.63	0.07	0
01/11/2023 15:00	2.1	39.29	0.07	0
01/11/2023 16:00	2.1	48.82	0.07	0
01/11/2023 17:00	2.1	50.17	0.07	0
01/11/2023 18:00	2.1	49.88	0.07	0
01/11/2023 19:00	2.1	43.75	0.07	0
01/11/2023 20:00	2.1	39.39	0.07	0
01/11/2023 21:00	2.1	40.7	0.07	0
01/11/2023 22:00	2.1	40.86	0.07	0
01/11/2023 23:00	2.1	41.05	0.07	0
02/11/2023 00:00	2.1	40.04	0.07	0
02/11/2023 01:00	2.1	40.36	0.07	0
02/11/2023 02:00	2.1	39.62	0.07	0
02/11/2023 03:00	2.1	39.58	0.07	0
02/11/2023 04:00	2.2	38.83	0.07	0
02/11/2023 05:00	2.2	40.41	0.07	0
02/11/2023 06:00	2.2	38.83	0.07	0
02/11/2023 07:00	2.2	38.07	0.07	0
02/11/2023 08:00	2.2	38.86	0.07	0
02/11/2023 09:00	2.2	43.41	0.07	0
02/11/2023 10:00	2.2	56.25	0.07	0
02/11/2023 11:00	2.3	40.81	0.07	0
02/11/2023 12:00	2.3	34.41	0.07	0
02/11/2023 13:00	2.3	30.94	0.07	0
02/11/2023 14:00	2.3	28.98	0.07	0
02/11/2023 15:00	2.3	34.06	0.07	0
02/11/2023 16:00	2.4	35.47	0.07	0
02/11/2023 17:00	2.4	34.95	0.07	0
02/11/2023 18:00	2.3	35.68	0.07	0
02/11/2023 19:00	2.2	39.78	0.07	0
02/11/2023 20:00	2.2	39.72	0.07	0
02/11/2023 21:00	2.2	40.62	0.07	0
02/11/2023 22:00	2.2	39.7	0.07	0
02/11/2023 23:00	2.2	40.23	0.07	0
03/11/2023 00:00	2.2	40.31	0.07	0
03/11/2023 01:00	2.1	37.88	0.07	0
03/11/2023 02:00	2.1	40.29	0.07	0
03/11/2023 03:00	2.1	44.24	0.07	0
03/11/2023 04:00	2.2	55.41	0.07	0
03/11/2023 05:00	2.4	46.53	0.07	0
03/11/2023 06:00	2.4	43.73	0.07	0
03/11/2023 07:00	2.4	41.96	0.07	0
03/11/2023 08:00	2.4	42.37	0.07	0
03/11/2023 09:00	2.4	41.42	0.07	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
03/11/2023 10:00	2.3	40.79	0.07	0
03/11/2023 11:00	2.3	39.88	0.07	0
03/11/2023 12:00	2.3	38.83	0.07	0
03/11/2023 13:00	2.3	37.77	0.07	0
03/11/2023 14:00	2.3	36.92	0.07	0
03/11/2023 15:00	2.3	37.51	0.07	0
03/11/2023 16:00	2.3	37.18	0.07	0
03/11/2023 17:00	2.3	36.06	0.07	0
03/11/2023 18:00	2.2	36.74	0.07	0
03/11/2023 19:00	2.2	39.28	0.07	0
03/11/2023 20:00	2	45.89	0.07	0
03/11/2023 21:00	2	46.16	0.07	0
03/11/2023 22:00	2	44.49	0.07	0
03/11/2023 23:00	2	44.34	0.07	0
04/11/2023 00:00	2	42.67	0.07	0
04/11/2023 01:00	2	41.79	0.07	0
04/11/2023 02:00	2	42.19	0.07	0
04/11/2023 03:00	2	41.16	0.07	0
04/11/2023 04:00	2	40.06	0.07	0
04/11/2023 05:00	2	41.12	0.07	0
04/11/2023 06:00	2	40.5	0.07	0
04/11/2023 07:00	2	40.5	0.07	0
04/11/2023 08:00	2	40.1	0.07	0
04/11/2023 09:00	2	55.12	0.07	0
04/11/2023 10:00	2.3	70.56	0.07	0
04/11/2023 11:00	2.4	56.2	0.07	0
04/11/2023 12:00	2.1	55.62	0.07	0
04/11/2023 13:00	2.2	94.14	0.07	0
04/11/2023 14:00	2.3	59.97	0.07	0
04/11/2023 15:00	2.5	51.75	0.07	0
04/11/2023 16:00	2.5	46.24	0.07	0
04/11/2023 17:00	2.4	45	0.07	0
04/11/2023 18:00	2.3	43.52	0.07	0
04/11/2023 19:00	2.4	42.08	0.07	0
04/11/2023 20:00	2.4	41.28	0.07	0
04/11/2023 21:00	2.3	40.54	0.07	0
04/11/2023 22:00	2.3	41.16	0.07	0
04/11/2023 23:00	2.3	40.97	0.07	0
05/11/2023 00:00	2.3	41.56	0.07	0
05/11/2023 01:00	2.2	40.88	0.07	0
05/11/2023 02:00	2.2	39.86	0.07	0
05/11/2023 03:00	2.1	40.78	0.07	0
05/11/2023 04:00	2.1	40.1	0.07	0
05/11/2023 05:00	2.1	40.17	0.07	0
05/11/2023 06:00	2.1	40.54	0.07	0
05/11/2023 07:00	2.1	39.94	0.07	0
05/11/2023 08:00	2.1	39.84	0.07	0
05/11/2023 09:00	2.1	40.37	0.07	0
05/11/2023 10:00	2.1	40.52	0.07	0
05/11/2023 11:00	2	42.89	0.07	0
05/11/2023 12:00	2	51.6	0.07	0
05/11/2023 13:00	2	45.3	0.07	0
05/11/2023 14:00	1.9	40.84	0.07	0
05/11/2023 15:00	2	38.78	0.07	0
05/11/2023 16:00	1.9	37.64	0.07	0
05/11/2023 17:00	1.9	39.24	0.07	0
05/11/2023 18:00	1.9	40.08	0.07	0
05/11/2023 19:00	1.9	39.58	0.07	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
05/11/2023 20:00	1.9	39.75	0.07	0
05/11/2023 21:00	1.9	39.3	0.07	0
05/11/2023 22:00	1.9	40.06	0.07	0
05/11/2023 23:00	1.9	39.85	0.07	0
06/11/2023 00:00	1.9	39.77	0.07	0
06/11/2023 01:00	1.8	40.17	0.07	0
06/11/2023 02:00	1.8	40.56	0.07	0
06/11/2023 03:00	1.8	39.82	0.07	0
06/11/2023 04:00	1.8	39.47	0.07	0
06/11/2023 05:00	1.8	40.22	0.07	0
06/11/2023 06:00	1.8	38.62	0.07	0
06/11/2023 07:00	1.8	38.56	0.07	0
06/11/2023 08:00	1.8	39.64	0.07	0
06/11/2023 09:00	1.8	39.48	0.07	0
06/11/2023 10:00	1.8	45.57	0.07	0
06/11/2023 11:00	1.8	52.72	0.07	0
06/11/2023 12:00	1.8	44.34	0.07	0
06/11/2023 13:00	1.8	41.75	0.07	0
06/11/2023 14:00	1.8	39.37	0.07	0
06/11/2023 15:00	1.8	36.77	0.07	0
06/11/2023 16:00	1.8	38.53	0.07	0
06/11/2023 17:00	1.8	39.59	0.07	0
06/11/2023 18:00	1.8	39.89	0.07	0
06/11/2023 19:00	1.8	39.17	0.07	0
06/11/2023 20:00	1.8	39.01	0.07	0
06/11/2023 21:00	1.8	39.46	0.07	0
06/11/2023 22:00	1.8	39.79	0.07	0
06/11/2023 23:00	1.8	40.1	0.07	0
07/11/2023 00:00	1.8	39.05	0.07	0
07/11/2023 01:00	1.8	38.4	0.07	0
07/11/2023 02:00	1.8	40.19	0.07	0
07/11/2023 03:00	1.8	40.2	0.07	0
07/11/2023 04:00	1.8	40.38	0.07	0
07/11/2023 05:00	1.8	39.65	0.07	0
07/11/2023 06:00	1.8	39.39	0.07	0
07/11/2023 07:00	1.8	39.28	0.07	0
07/11/2023 08:00	1.8	40.39	0.07	0
07/11/2023 09:00	1.8	38.81	0.07	0
07/11/2023 10:00	1.8	55.43	0.07	0
07/11/2023 11:00	1.8	49.55	0.07	0
07/11/2023 12:00	1.8	42.8	0.07	0
07/11/2023 13:00	1.8	38.56	0.07	0
07/11/2023 14:00	1.7	40.77	0.07	0
07/11/2023 15:00	1.7	41.7	0.07	0
07/11/2023 16:00	1.7	42.07	0.07	0
07/11/2023 17:00	1.8	42.04	0.07	0
07/11/2023 18:00	1.8	40.89	0.07	0
07/11/2023 19:00	1.8	42.64	0.07	0
07/11/2023 20:00	1.9	42.45	0.07	0
07/11/2023 21:00	1.9	41	0.07	0
07/11/2023 22:00	1.9	41.91	0.07	0
07/11/2023 23:00	1.9	44.13	0.07	0
08/11/2023 00:00	1.8	37.64	0.07	0
08/11/2023 01:00	1.8	33.16	0.07	0
08/11/2023 02:00	1.8	31.02	0.07	0
08/11/2023 03:00	1.8	28.99	0.07	0
08/11/2023 04:00	1.8	27.95	0.07	0
08/11/2023 05:00	1.9	26.6	0.07	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
08/11/2023 06:00	1.9	25.57	0.07	0
08/11/2023 07:00	1.9	25.71	0.07	0
08/11/2023 08:00	1.9	25.14	0.07	0
08/11/2023 09:00	1.9	24.52	0.07	0
08/11/2023 10:00	1.9	24.6	0.07	0
08/11/2023 11:00	1.9	26.35	0.07	0
08/11/2023 12:00	1.8	27.69	0.07	0
08/11/2023 13:00	1.8	28.88	0.07	0
08/11/2023 14:00	1.8	30.81	0.07	0
08/11/2023 15:00	1.7	36.64	0.07	0
08/11/2023 16:00	1.6	48.55	0.07	0
08/11/2023 17:00	1.6	44.79	0.07	0
08/11/2023 18:00	1.6	43.11	0.07	0
08/11/2023 19:00	1.6	40.41	0.07	0
08/11/2023 20:00	1.6	40.04	0.07	0
08/11/2023 21:00	1.6	39.39	0.07	0
08/11/2023 22:00	1.6	37.97	0.07	0
08/11/2023 23:00	1.6	37.48	0.07	0
09/11/2023 00:00	1.6	35.46	0.07	0
09/11/2023 01:00	1.7	34.43	0.07	0
09/11/2023 02:00	1.7	34.17	0.07	0
09/11/2023 03:00	1.7	33.61	0.07	0
09/11/2023 04:00	1.7	33.33	0.07	0
09/11/2023 05:00	1.7	32.78	0.07	0
09/11/2023 06:00	1.7	32.95	0.07	0
09/11/2023 07:00	1.7	33.24	0.07	0
09/11/2023 08:00	1.8	34.12	0.07	0
09/11/2023 09:00	1.8	34.73	0.07	0
09/11/2023 10:00	1.8	35.22	0.07	0
09/11/2023 11:00	1.8	34.79	0.07	0
09/11/2023 12:00	1.8	34.86	0.07	0
09/11/2023 13:00	1.8	33.37	0.07	0
09/11/2023 14:00	1.8	36.53	0.07	0
09/11/2023 15:00	1.8	42.37	0.07	0
09/11/2023 16:00	1.8	48.96	0.07	0
09/11/2023 17:00	1.9	52.86	0.07	0
09/11/2023 18:00	1.9	54.19	0.07	0
09/11/2023 19:00	1.9	55.72	0.07	0
09/11/2023 20:00	1.9	54.2	0.07	0
09/11/2023 21:00	1.9	54.44	0.07	0
09/11/2023 22:00	1.9	54.25	0.07	0
09/11/2023 23:00	1.9	55	0.07	0
10/11/2023 00:00	1.9	55.95	0.07	0
10/11/2023 01:00	1.9	64.84	0.07	0
10/11/2023 02:00	2	62.25	0.07	0
10/11/2023 03:00	2	58.74	0.07	0
10/11/2023 04:00	2	55.16	0.07	0
10/11/2023 05:00	2	55.26	0.07	0
10/11/2023 06:00	2	54.08	0.07	0
10/11/2023 07:00	2.1	57.92	0.07	0
10/11/2023 08:00	2.1	61.03	0.07	0
10/11/2023 09:00	2.1	62.56	0.07	0
10/11/2023 10:00	2.1	63.51	0.07	0
10/11/2023 11:00	2	59.68	0.07	0
10/11/2023 12:00	2	60.54	0.07	0
10/11/2023 13:00	2	55.87	0.07	0
10/11/2023 14:00	1.9	59.45	0.07	0
10/11/2023 15:00	1.8	66.72	0.07	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
10/11/2023 16:00	1.8	64.3	0.07	0
10/11/2023 17:00	1.8	60.39	0.07	0
10/11/2023 18:00	1.8	69.14	0.07	0
10/11/2023 19:00	1.8	73.47	0.07	0
10/11/2023 20:00	1.9	62.19	0.07	0
10/11/2023 21:00	1.9	61.19	0.07	0
10/11/2023 22:00	1.9	60.52	0.07	0
10/11/2023 23:00	1.9	58.9	0.07	0
11/11/2023 00:00	1.9	58.18	0.07	0
11/11/2023 01:00	1.9	59.74	0.07	0
11/11/2023 02:00	1.9	57.27	0.07	0
11/11/2023 03:00	2	56.46	0.07	0
11/11/2023 04:00	2	57.93	0.07	0
11/11/2023 05:00	2	54.41	0.07	0
11/11/2023 06:00	2	54.67	0.07	0
11/11/2023 07:00	2	54.93	0.07	0
11/11/2023 08:00	2	57.2	0.07	0
11/11/2023 09:00	2	59.29	0.07	0
11/11/2023 10:00	2	58.79	0.07	0
11/11/2023 11:00	1.9	59.01	0.07	0
11/11/2023 12:00	2	58.24	0.07	0
11/11/2023 13:00	1.9	57.14	0.07	0
11/11/2023 14:00	2	57.54	0.07	0
11/11/2023 15:00	2	56.09	0.07	0
11/11/2023 16:00	2	54.84	0.07	0
11/11/2023 17:00	2	54.62	0.07	0
11/11/2023 18:00	2	54.71	0.07	0
11/11/2023 19:00	1.9	55.73	0.07	0
11/11/2023 20:00	1.9	56.28	0.07	0
11/11/2023 21:00	1.9	58.67	0.07	0
11/11/2023 22:00	1.9	56.71	0.07	0
11/11/2023 23:00	1.9	57.74	0.07	0
12/11/2023 00:00	1.9	58.2	0.07	0
12/11/2023 01:00	1.9	57.37	0.07	0
12/11/2023 02:00	1.9	58.14	0.07	0
12/11/2023 03:00	1.9	59.04	0.07	0
12/11/2023 04:00	1.9	57.43	0.07	0
12/11/2023 05:00	1.9	57.28	0.07	0
12/11/2023 06:00	1.9	58.87	0.07	0
12/11/2023 07:00	1.9	56.07	0.07	0
12/11/2023 08:00	1.9	58.36	0.07	0
12/11/2023 09:00	1.9	59.33	0.07	0
12/11/2023 10:00	1.9	59.15	0.07	0
12/11/2023 11:00	1.9	59.03	0.07	0
12/11/2023 12:00	1.9	56.93	0.07	0
12/11/2023 13:00	1.8	56.67	0.07	0
12/11/2023 14:00	1.9	56.56	0.07	0
12/11/2023 15:00	1.9	48.25	0.07	0
12/11/2023 16:00	1.9	42.73	0.07	0
12/11/2023 17:00	1.9	59.33	0.07	0
12/11/2023 18:00	1.8	73.34	0.07	0
12/11/2023 19:00	1.8	76.25	0.07	0
12/11/2023 20:00	1.9	77.58	0.07	0
12/11/2023 21:00	1.9	77.51	0.07	0
12/11/2023 22:00	1.9	77.6	0.07	0
12/11/2023 23:00	1.9	78.52	0.07	0
13/11/2023 00:00	1.8	77.91	0.07	0
13/11/2023 01:00	1.8	78.12	0.07	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
13/11/2023 02:00	1.7	79.2	0.07	0
13/11/2023 03:00	1.7	78.38	0.07	0
13/11/2023 04:00	1.6	81.98	0.07	0
13/11/2023 05:00	1.6	79.79	0.07	0
13/11/2023 06:00	1.6	86.41	0.07	0
13/11/2023 07:00	1.6	80.75	0.07	0
13/11/2023 08:00	1.6	81.21	0.07	0
13/11/2023 09:00	1.5	83.72	0.07	0
13/11/2023 10:00	<Samp	<Samp	<Samp	0
13/11/2023 11:00	0.8	84.36	0.07	0
13/11/2023 12:00	0.7	81.71	0.07	0
13/11/2023 13:00	0.8	80.76	0.07	0
13/11/2023 14:00	0.7	80.27	0.07	0
13/11/2023 15:00	0.8	79.72	0.07	0
13/11/2023 16:00	0.7	77.46	0.07	0
13/11/2023 17:00	0.7	91.51	0.07	0
13/11/2023 18:00	0.7	115.01	0.07	0
13/11/2023 19:00	0.6	119.17	0.07	0
13/11/2023 20:00	0.6	101.15	0.07	0
13/11/2023 21:00	0.6	99.12	0.07	0
13/11/2023 22:00	0.5	98.79	0.07	0
13/11/2023 23:00	0.4	99.7	0.07	0
14/11/2023 00:00	0.4	98.96	0.07	0
14/11/2023 01:00	0.3	98.93	0.07	0
14/11/2023 02:00	0.1	98.25	0.07	0
14/11/2023 03:00	0	96.88	0.07	0
14/11/2023 04:00	0	70.06	0.07	0
14/11/2023 05:00	0	59.81	0.07	0
14/11/2023 06:00	0	58.07	0.07	0
14/11/2023 07:00	0	55.86	0.07	0
14/11/2023 08:00	0	59.92	0.07	0
14/11/2023 09:00	0.3	59.54	0.07	0
14/11/2023 10:00	<Samp	<Samp	<Samp	0
14/11/2023 11:00	Maintain	Maintain	Maintain	0
14/11/2023 12:00	Maintain	Maintain	Maintain	0
14/11/2023 13:00	<Samp	<Samp	<Samp	0
14/11/2023 14:00	0.7	47.89	0.07	0
14/11/2023 15:00	0.8	48.01	0.07	0
14/11/2023 16:00	1	46.56	0.07	0
14/11/2023 17:00	0.9	45.37	0.07	0
14/11/2023 18:00	1	44.28	0.07	0
14/11/2023 19:00	0.9	45.2	0.07	0
14/11/2023 20:00	0.9	45.12	0.07	0
14/11/2023 21:00	0.8	45.85	0.07	0
14/11/2023 22:00	0.7	46.57	0.07	0
14/11/2023 23:00	0.7	46.93	0.07	0
15/11/2023 00:00	0.7	46.37	0.07	0
15/11/2023 01:00	0.6	46.86	0.07	0
15/11/2023 02:00	0.6	45.69	0.07	0
15/11/2023 03:00	0.6	46.36	0.07	0
15/11/2023 04:00	0.4	47.08	0.07	0
15/11/2023 05:00	0.4	47.32	0.07	0
15/11/2023 06:00	0.3	47.67	0.07	0
15/11/2023 07:00	0.3	47.19	0.07	0
15/11/2023 08:00	0.3	49.21	0.07	0
15/11/2023 09:00	10.1	48.1	0.07	0
15/11/2023 10:00	15.5	47.95	0.07	0
15/11/2023 11:00	15.6	48.42	0.07	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
15/11/2023 12:00	Calib	Calib	Calib	0
15/11/2023 13:00	Calib	Calib	Calib	0
15/11/2023 14:00	<Samp	<Samp	<Samp	0
15/11/2023 15:00	1.5	45.25	0.07	0
15/11/2023 16:00	1.6	45.29	0.07	0
15/11/2023 17:00	1.5	45.97	0.07	0
15/11/2023 18:00	1.4	48.9	0.07	0
15/11/2023 19:00	1.4	49.18	0.07	0
15/11/2023 20:00	1.5	48.18	0.07	0
15/11/2023 21:00	1.5	47.94	0.07	0
15/11/2023 22:00	1.5	47.84	0.07	0
15/11/2023 23:00	1.5	46.83	0.07	0
16/11/2023 00:00	1.5	47.92	0.07	0
16/11/2023 01:00	1.5	47.45	0.07	0
16/11/2023 02:00	1.4	49.45	0.07	0
16/11/2023 03:00	1.4	48.49	0.07	0
16/11/2023 04:00	1.4	46.37	0.07	0
16/11/2023 05:00	1.4	48.04	0.07	0
16/11/2023 06:00	1.4	47.9	0.07	0
16/11/2023 07:00	1.4	46.85	0.07	0
16/11/2023 08:00	1.4	47.94	0.07	0
16/11/2023 09:00	1.4	49.32	0.07	0
16/11/2023 10:00	1.4	48.78	0.07	0
16/11/2023 11:00	1.5	48.87	0.07	0
16/11/2023 12:00	1.6	48.7	0.07	0
16/11/2023 13:00	1.6	47.38	0.07	0
16/11/2023 14:00	1.6	46.57	0.07	0
16/11/2023 15:00	1.6	46.35	0.07	0
16/11/2023 16:00	1.6	47.27	0.07	0
16/11/2023 17:00	1.6	46.53	0.07	0
16/11/2023 18:00	1.6	46.08	0.07	0
16/11/2023 19:00	1.6	46.43	0.07	0
16/11/2023 20:00	1.5	46.38	0.07	0
16/11/2023 21:00	1.6	48.81	0.07	0
16/11/2023 22:00	1.6	48.44	0.07	0
16/11/2023 23:00	1.5	44.69	0.07	0
17/11/2023 00:00	1.5	46.48	0.07	0
17/11/2023 01:00	1.5	48.19	0.07	0
17/11/2023 02:00	1.5	48.48	0.07	0
17/11/2023 03:00	1.4	47.92	0.07	0
17/11/2023 04:00	1.4	47.91	0.07	0
17/11/2023 05:00	1.4	47.1	0.07	0
17/11/2023 06:00	1.4	47.38	0.07	0
17/11/2023 07:00	1.4	55.31	0.07	0
17/11/2023 08:00	1.3	52.25	0.07	0
17/11/2023 09:00	1.3	49.58	0.07	0
17/11/2023 10:00	1.2	48.24	0.07	0
17/11/2023 11:00	1.3	47.54	0.07	0
17/11/2023 12:00	1.3	46.68	0.07	0
17/11/2023 13:00	1.4	46.51	0.07	0
17/11/2023 14:00	1.4	45.61	0.08	0
17/11/2023 15:00	1.4	45.06	0.09	0
17/11/2023 16:00	1.4	45.88	0.09	0
17/11/2023 17:00	1.4	46.1	0.09	0
17/11/2023 18:00	1.3	65.17	0.09	0
17/11/2023 19:00	1.3	54.25	0.09	0
17/11/2023 20:00	1.2	49.01	0.09	0
17/11/2023 21:00	1.2	47.98	0.09	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
17/11/2023 22:00	1.1	46.84	0.09	0
17/11/2023 23:00	1.1	45.59	0.09	0
18/11/2023 00:00	1.1	46	0.09	0
18/11/2023 01:00	1	46.22	0.09	0
18/11/2023 02:00	1	46.86	0.09	0
18/11/2023 03:00	1	46.8	0.09	0
18/11/2023 04:00	0.9	46.48	0.09	0
18/11/2023 05:00	0.9	47.16	0.09	0
18/11/2023 06:00	0.8	47.86	0.09	0
18/11/2023 07:00	0.8	48.37	0.09	0
18/11/2023 08:00	0.8	48.12	0.09	0
18/11/2023 09:00	0.8	46.12	0.09	0
18/11/2023 10:00	0.8	46.16	0.09	0
18/11/2023 11:00	0.8	45.64	0.09	0
18/11/2023 12:00	0.9	45.38	0.09	0
18/11/2023 13:00	0.9	44.59	0.09	0
18/11/2023 14:00	1	44.3	0.09	0
18/11/2023 15:00	1	45.22	0.09	0
18/11/2023 16:00	1	45.05	0.09	0
18/11/2023 17:00	1	44.73	0.09	0
18/11/2023 18:00	1	45.46	0.09	0
18/11/2023 19:00	0.9	44.12	0.09	0
18/11/2023 20:00	0.9	43.94	0.09	0
18/11/2023 21:00	0.9	44.04	0.09	0
18/11/2023 22:00	0.8	44.25	0.09	0
18/11/2023 23:00	0.8	44.79	0.09	0
19/11/2023 00:00	0.8	45.73	0.09	0
19/11/2023 01:00	0.8	46.86	0.09	0
19/11/2023 02:00	0.8	47.69	0.09	0
19/11/2023 03:00	0.8	48.48	0.09	0
19/11/2023 04:00	0.8	47.36	0.09	0
19/11/2023 05:00	0.7	45.89	0.09	0
19/11/2023 06:00	0.7	44.24	0.09	0
19/11/2023 07:00	0.7	43.79	0.09	0
19/11/2023 08:00	0.7	44.63	0.09	0
19/11/2023 09:00	0.7	41.61	0.09	0
19/11/2023 10:00	0.7	41.37	0.09	0
19/11/2023 11:00	0.8	41.08	0.09	0
19/11/2023 12:00	0.8	39.83	0.09	0
19/11/2023 13:00	0.9	39.31	0.09	0
19/11/2023 14:00	1	39.4	0.09	0
19/11/2023 15:00	1	39.61	0.09	0
19/11/2023 16:00	1	39.56	0.09	0
19/11/2023 17:00	1	39.66	0.09	0
19/11/2023 18:00	1	40.04	0.09	0
19/11/2023 19:00	0.9	38.41	0.09	0
19/11/2023 20:00	0.9	38.88	0.09	0
19/11/2023 21:00	0.9	39.53	0.09	0
19/11/2023 22:00	0.8	39.45	0.09	0
19/11/2023 23:00	0.8	41.45	0.09	0
20/11/2023 00:00	0.8	42.13	0.09	0
20/11/2023 01:00	0.8	43.08	0.09	0
20/11/2023 02:00	0.8	41.9	0.09	0
20/11/2023 03:00	0.8	42.8	0.09	0
20/11/2023 04:00	0.8	42.43	0.09	0
20/11/2023 05:00	0.8	42.56	0.09	0
20/11/2023 06:00	0.8	43.17	0.09	0
20/11/2023 07:00	0.7	43.94	0.09	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
20/11/2023 08:00	0.7	43.64	0.09	0
20/11/2023 09:00	0.7	40.65	0.09	0
20/11/2023 10:00	0.7	40.56	0.09	0
20/11/2023 11:00	0.8	40.47	0.09	0
20/11/2023 12:00	0.9	39.87	0.09	0
20/11/2023 13:00	0.9	41.82	0.09	0
20/11/2023 14:00	1	42.57	0.09	0
20/11/2023 15:00	1	41.05	0.09	0
20/11/2023 16:00	1	40.15	0.09	0
20/11/2023 17:00	1	38.7	0.09	0
20/11/2023 18:00	1	44.47	0.09	0
20/11/2023 19:00	1	43.91	0.09	0
20/11/2023 20:00	1	41.98	0.09	0
20/11/2023 21:00	0.9	40.93	0.09	0
20/11/2023 22:00	0.9	41.85	0.09	0
20/11/2023 23:00	0.9	41.1	0.09	0
21/11/2023 00:00	0.9	41.14	0.09	0
21/11/2023 01:00	0.9	41.95	0.09	0
21/11/2023 02:00	0.8	42.78	0.09	0
21/11/2023 03:00	0.8	42.36	0.09	0
21/11/2023 04:00	0.8	43.38	0.09	0
21/11/2023 05:00	0.8	43.26	0.09	0
21/11/2023 06:00	0.8	42.65	0.09	0
21/11/2023 07:00	0.7	42.57	0.09	0
21/11/2023 08:00	0.7	41.92	0.09	0
21/11/2023 09:00	0.7	41.11	0.09	0
21/11/2023 10:00	0.7	41.67	0.09	0
21/11/2023 11:00	0.8	40.68	0.09	0
21/11/2023 12:00	0.9	39.03	0.08	0
21/11/2023 13:00	0.9	38.77	0.08	0
21/11/2023 14:00	1	38.84	0.08	0
21/11/2023 15:00	1.1	38.58	0.08	0
21/11/2023 16:00	1.1	38.17	0.08	0
21/11/2023 17:00	1.1	36.79	0.08	0
21/11/2023 18:00	1.1	35.39	0.08	0
21/11/2023 19:00	1.1	35.76	0.09	0
21/11/2023 20:00	1	34.64	0.09	0
21/11/2023 21:00	1	33.38	0.09	0
21/11/2023 22:00	1	33.41	0.09	0
21/11/2023 23:00	1	33.18	0.09	0
22/11/2023 00:00	1	33.95	0.09	0
22/11/2023 01:00	0.9	33.93	0.09	0
22/11/2023 02:00	0.9	33.78	0.09	0
22/11/2023 03:00	0.9	33.25	0.09	0
22/11/2023 04:00	0.9	33.21	0.09	0
22/11/2023 05:00	0.9	33.31	0.09	0
22/11/2023 06:00	0.9	33.62	0.09	0
22/11/2023 07:00	0.9	33.12	0.09	0
22/11/2023 08:00	0.9	34.43	0.09	0
22/11/2023 09:00	0.9	34.34	0.09	0
22/11/2023 10:00	0.9	33.51	0.09	0
22/11/2023 11:00	1	33.23	0.09	0
22/11/2023 12:00	1.1	32.71	0.09	0
22/11/2023 13:00	1.2	32.17	0.09	0
22/11/2023 14:00	1.3	32.01	0.09	0
22/11/2023 15:00	1.4	31.95	0.09	0
22/11/2023 16:00	1.4	31.78	0.09	0
22/11/2023 17:00	1.4	31.94	0.09	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
22/11/2023 18:00	1.4	32.91	0.09	0
22/11/2023 19:00	1.4	32.65	0.09	0
22/11/2023 20:00	1.3	32.43	0.09	0
22/11/2023 21:00	1.3	33.46	0.09	0
22/11/2023 22:00	1.3	33.26	0.09	0
22/11/2023 23:00	1.3	33.23	0.09	0
23/11/2023 00:00	1.3	33.74	0.09	0
23/11/2023 01:00	1.2	33.32	0.09	0
23/11/2023 02:00	1.2	33.63	0.09	0
23/11/2023 03:00	1.2	33.96	0.09	0
23/11/2023 04:00	1.2	34.03	0.09	0
23/11/2023 05:00	1.2	33.91	0.09	0
23/11/2023 06:00	1.2	34.26	0.09	0
23/11/2023 07:00	1.2	33.65	0.09	0
23/11/2023 08:00	1.2	34.34	0.09	0
23/11/2023 09:00	1.2	33.97	0.09	0
23/11/2023 10:00	1.2	33.78	0.09	0
23/11/2023 11:00	1.3	33.72	0.09	0
23/11/2023 12:00	1.4	32.62	0.08	0
23/11/2023 13:00	1.5	31.96	0.08	0
23/11/2023 14:00	1.5	31.97	0.08	0
23/11/2023 15:00	1.6	31.82	0.08	0
23/11/2023 16:00	1.6	32.12	0.08	0
23/11/2023 17:00	1.6	30.08	0.08	0
23/11/2023 18:00	1.5	30.61	0.08	0
23/11/2023 19:00	1.5	30.47	0.08	0
23/11/2023 20:00	1.5	30.69	0.08	0
23/11/2023 21:00	1.4	30.81	0.08	0
23/11/2023 22:00	1.4	31.18	0.08	0
23/11/2023 23:00	1.3	31.09	0.08	0
24/11/2023 00:00	1.4	31.47	0.08	0
24/11/2023 01:00	1.4	31.96	0.09	0
24/11/2023 02:00	1.4	32.51	0.09	0
24/11/2023 03:00	1.3	32.75	0.09	0
24/11/2023 04:00	1.3	32.37	0.08	0
24/11/2023 05:00	1.3	31.88	0.09	0
24/11/2023 06:00	1.3	32	0.09	0
24/11/2023 07:00	1.3	32.23	0.09	0
24/11/2023 08:00	1.3	32.24	0.09	0
24/11/2023 09:00	1.3	30.57	0.09	0
24/11/2023 10:00	1.3	29.13	0.08	0
24/11/2023 11:00	1.4	28.42	0.08	0
24/11/2023 12:00	1.6	26.73	0.08	0
24/11/2023 13:00	1.7	24.68	0.08	0
24/11/2023 14:00	1.8	24.12	0.08	0
24/11/2023 15:00	1.9	23.81	0.08	0
24/11/2023 16:00	2	23.31	0.08	0
24/11/2023 17:00	2.3	22.86	0.08	0
24/11/2023 18:00	2.7	26.48	0.08	0
24/11/2023 19:00	2.7	27.99	0.08	0
24/11/2023 20:00	2.6	27.27	0.08	0
24/11/2023 21:00	2.6	27.45	0.08	0
24/11/2023 22:00	2.6	25.82	0.08	0
24/11/2023 23:00	2.5	25.19	0.08	0
25/11/2023 00:00	2.5	24.49	0.08	0
25/11/2023 01:00	2.4	25.61	0.09	0
25/11/2023 02:00	2.4	29.42	0.09	0
25/11/2023 03:00	2.4	28.91	0.09	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
25/11/2023 04:00	2.4	27.38	0.09	0
25/11/2023 05:00	2.2	28.43	0.09	0
25/11/2023 06:00	2.3	25.42	0.09	0
25/11/2023 07:00	2.3	25.16	0.09	0
25/11/2023 08:00	2.2	24.48	0.09	0
25/11/2023 09:00	2.3	24.16	0.09	0
25/11/2023 10:00	2.3	24.04	0.09	0
25/11/2023 11:00	2.4	23.55	0.08	0
25/11/2023 12:00	2.5	22.97	0.08	0
25/11/2023 13:00	2.6	22.33	0.08	0
25/11/2023 14:00	2.9	21.61	0.08	0
25/11/2023 15:00	3.1	21.54	0.08	0
25/11/2023 16:00	3.4	21.33	0.08	0
25/11/2023 17:00	3.6	21.3	0.08	0
25/11/2023 18:00	3.8	21.67	0.08	0
25/11/2023 19:00	3.8	21.91	0.08	0
25/11/2023 20:00	3.6	22.04	0.08	0
25/11/2023 21:00	3.7	22.14	0.08	0
25/11/2023 22:00	3.7	22.28	0.08	0
25/11/2023 23:00	3.5	22.44	0.08	0
26/11/2023 00:00	3.5	22.38	0.08	0
26/11/2023 01:00	3.5	22.37	0.08	0
26/11/2023 02:00	3.5	22.61	0.08	0
26/11/2023 03:00	3.4	22.59	0.08	0
26/11/2023 04:00	3.4	22.76	0.08	0
26/11/2023 05:00	3.4	22.98	0.08	0
26/11/2023 06:00	3.3	22.91	0.08	0
26/11/2023 07:00	3.2	22.97	0.08	0
26/11/2023 08:00	3.3	22.78	0.08	0
26/11/2023 09:00	3.3	22.36	0.08	0
26/11/2023 10:00	3.3	22.49	0.08	0
26/11/2023 11:00	3.4	22.23	0.08	0
26/11/2023 12:00	3.5	21.86	0.08	0
26/11/2023 13:00	3.7	21.9	0.08	0
26/11/2023 14:00	4.1	21.81	0.08	0
26/11/2023 15:00	4.4	21.66	0.08	0
26/11/2023 16:00	4.7	21.43	0.08	0
26/11/2023 17:00	3.7	21.8	0.08	0
26/11/2023 18:00	3.4	22.52	0.08	0
26/11/2023 19:00	3.4	22.24	0.08	0
26/11/2023 20:00	3.6	22.89	0.08	0
26/11/2023 21:00	3.8	24.99	0.08	0
26/11/2023 22:00	3.9	26.11	0.08	0
26/11/2023 23:00	3.9	27.25	0.08	0
27/11/2023 00:00	3.8	28.41	0.08	0
27/11/2023 01:00	3.8	29.39	0.08	0
27/11/2023 02:00	4	29.71	0.08	0
27/11/2023 03:00	3.9	30.16	0.08	0
27/11/2023 04:00	3.7	30.91	0.08	0
27/11/2023 05:00	3.6	31.07	0.08	0
27/11/2023 06:00	3.5	31.48	0.08	0
27/11/2023 07:00	3.5	31.8	0.08	0
27/11/2023 08:00	3.5	29.97	0.08	0
27/11/2023 09:00	3.4	28.22	0.08	0
27/11/2023 10:00	3.3	27.44	0.08	0
27/11/2023 11:00	3.4	26.17	0.08	0
27/11/2023 12:00	3.6	25.07	0.08	0
27/11/2023 13:00	3.6	24.53	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
27/11/2023 14:00	3.9	23.68	0.08	0
27/11/2023 15:00	4.1	23.33	0.08	0
27/11/2023 16:00	4.4	23.41	0.08	0
27/11/2023 17:00	4.4	23.01	0.08	0
27/11/2023 18:00	3.4	22.55	0.08	0
27/11/2023 19:00	3.7	22.6	0.08	0
27/11/2023 20:00	3.8	22.76	0.08	0
27/11/2023 21:00	3.8	25.86	0.08	0
27/11/2023 22:00	3.8	29.3	0.08	0
27/11/2023 23:00	3.8	28.63	0.08	0
28/11/2023 00:00	3.6	26.88	0.08	0
28/11/2023 01:00	3.5	25.61	0.08	0
28/11/2023 02:00	3.3	24.88	0.08	0
28/11/2023 03:00	3.2	24.39	0.08	0
28/11/2023 04:00	3.2	23.81	0.08	0
28/11/2023 05:00	3.2	23.5	0.08	0
28/11/2023 06:00	2.9	23.12	0.08	0
28/11/2023 07:00	3	28.78	0.08	0
28/11/2023 08:00	2.9	29.65	0.08	0
28/11/2023 09:00	2.7	28.03	0.08	0
28/11/2023 10:00	2.8	26.88	0.08	0
28/11/2023 11:00	3	25.23	0.08	0
28/11/2023 12:00	3.2	24.85	0.08	0
28/11/2023 13:00	3.2	23.84	0.08	0
28/11/2023 14:00	3.6	23.45	0.08	0
28/11/2023 15:00	4	22.74	0.08	0
28/11/2023 16:00	4.1	22.52	0.08	0
28/11/2023 17:00	4.5	22.5	0.08	0
28/11/2023 18:00	4.8	22.31	0.08	0
28/11/2023 19:00	4.7	22.4	0.08	0
28/11/2023 20:00	4.5	22.24	0.08	0
28/11/2023 21:00	4.4	22.26	0.08	0
28/11/2023 22:00	3.6	22.42	0.08	0
28/11/2023 23:00	3.4	22.61	0.08	0
29/11/2023 00:00	3.3	22.47	0.08	0
29/11/2023 01:00	3.1	22.63	0.08	0
29/11/2023 02:00	3.2	22.94	0.08	0
29/11/2023 03:00	3.1	22.6	0.08	0
29/11/2023 04:00	3.1	23.05	0.08	0
29/11/2023 05:00	3	22.83	0.08	0
29/11/2023 06:00	2.8	22.77	0.08	0
29/11/2023 07:00	2.8	23.04	0.08	0
29/11/2023 08:00	2.8	23.43	0.08	0
29/11/2023 09:00	2.7	22.81	0.08	0
29/11/2023 10:00	2.8	23	0.08	0
29/11/2023 11:00	2.8	23.03	0.08	0
29/11/2023 12:00	3	22.55	0.08	0
29/11/2023 13:00	3.1	21.67	0.08	0
29/11/2023 14:00	3.3	21.61	0.08	0
29/11/2023 15:00	3.6	21.38	0.08	0
29/11/2023 16:00	3.9	21.31	0.08	0
29/11/2023 17:00	3.9	21.78	0.08	0
29/11/2023 18:00	4.2	21.92	0.08	0
29/11/2023 19:00	4.4	22.01	0.08	0
29/11/2023 20:00	4.2	22.17	0.08	0
29/11/2023 21:00	4.2	22.47	0.08	0
29/11/2023 22:00	4.2	22.71	0.08	0
29/11/2023 23:00	4.2	22.99	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
30/11/2023 00:00	4	23.05	0.08	0
30/11/2023 01:00	3.9	22.78	0.08	0
30/11/2023 02:00	3.8	22.89	0.08	0
30/11/2023 03:00	3.9	22.82	0.08	0
30/11/2023 04:00	3.9	22.96	0.08	0
30/11/2023 05:00	3.7	22.73	0.08	0
30/11/2023 06:00	3.8	22.8	0.08	0
30/11/2023 07:00	3.7	23.24	0.08	0
30/11/2023 08:00	3.6	22.9	0.08	0
30/11/2023 09:00	3.5	23.37	0.08	0
30/11/2023 10:00	3.4	24.45	0.08	0
30/11/2023 11:00	3.7	25.66	0.08	0
30/11/2023 12:00	3.8	24.23	0.08	0
30/11/2023 13:00	3.9	23.01	0.08	0
30/11/2023 14:00	4.2	22.26	0.08	0
30/11/2023 15:00	4.5	25.72	0.08	0
30/11/2023 16:00	4.7	39.92	0.08	0
30/11/2023 17:00	4.6	41.44	0.08	0
30/11/2023 18:00	4.7	42.32	0.08	0
30/11/2023 19:00	4.9	41.9	0.08	0
30/11/2023 20:00	5	40.69	0.08	0
30/11/2023 21:00	4.9	40.19	0.08	0
30/11/2023 22:00	4.9	41.69	0.08	0
30/11/2023 23:00	4.8	41.4	0.08	0
Minimum	0	21.3	0.07	0
MinDate	14/11/2023 03:00	25/11/2023 17:00	01/11/2023 00:00	01/11/2023 00:00
Maximum	15.6	119.17	0.09	0
MaxDate	15/11/2023 11:00	13/11/2023 19:00	17/11/2023 15:00	01/11/2023 00:00
Avg	2	41.54	0.08	0
Num	712	712	712	720
Data[%]	98.8	98.8	98.8	99.9
STD	1.3	15.1	0	0
	1427.3	29576.53	54.58	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
01/12/2023 00:00	4.5	42.69	0.08	0
01/12/2023 01:00	4.5	42.08	0.08	0
01/12/2023 02:00	4.4	41.81	0.08	0
01/12/2023 03:00	4.3	41.37	0.08	0
01/12/2023 04:00	4.3	41.87	0.08	0
01/12/2023 05:00	4.3	42.86	0.08	0
01/12/2023 06:00	4	41.06	0.08	0
01/12/2023 07:00	4	42.64	0.08	0
01/12/2023 08:00	4	42.83	0.08	0
01/12/2023 09:00	3.3	43.34	0.08	0
01/12/2023 10:00	Calib	Calib	Calib	Calib
01/12/2023 11:00	3.2	50.51	0.08	0
01/12/2023 12:00	3.2	55.96	0.08	0
01/12/2023 13:00	3.2	49.37	0.08	0
01/12/2023 14:00	3.3	46.44	0.08	0
01/12/2023 15:00	3.2	48.67	0.08	0
01/12/2023 16:00	3.3	47.36	0.08	0
01/12/2023 17:00	3.3	45.26	0.08	0
01/12/2023 18:00	3.3	41.36	0.08	0
01/12/2023 19:00	3.2	39.24	0.08	0
01/12/2023 20:00	3.2	37.54	0.08	0
01/12/2023 21:00	3.2	35.51	0.08	0
01/12/2023 22:00	3.2	35.18	0.08	0
01/12/2023 23:00	3	34.4	0.08	0
02/12/2023 00:00	3	34.74	0.08	0
02/12/2023 01:00	2.9	38.83	0.08	0
02/12/2023 02:00	2.9	41.16	0.08	0
02/12/2023 03:00	2.8	39.82	0.08	0
02/12/2023 04:00	2.7	38.09	0.08	0
02/12/2023 05:00	2.6	36.23	0.08	0
02/12/2023 06:00	2.5	35.53	0.08	0
02/12/2023 07:00	2.5	35.54	0.08	0
02/12/2023 08:00	2.4	35.3	0.08	0
02/12/2023 09:00	2.3	36.63	0.08	0
02/12/2023 10:00	2.3	36.39	0.08	0
02/12/2023 11:00	2.4	35.77	0.08	0
02/12/2023 12:00	2.4	34.69	0.08	0
02/12/2023 13:00	2.5	33.78	0.08	0
02/12/2023 14:00	2.5	38.14	0.08	0
02/12/2023 15:00	2.6	38.11	0.08	0
02/12/2023 16:00	2.5	36.23	0.08	0
02/12/2023 17:00	2.6	38.79	0.08	0
02/12/2023 18:00	2.5	37.96	0.08	0
02/12/2023 19:00	2.5	35.9	0.08	0
02/12/2023 20:00	2.4	32.47	0.08	0
02/12/2023 21:00	2.4	31.31	0.08	0
02/12/2023 22:00	2.3	30.53	0.08	0
02/12/2023 23:00	2.3	29.94	0.08	0
03/12/2023 00:00	2.3	29.46	0.08	0
03/12/2023 01:00	2.4	28.99	0.08	0
03/12/2023 02:00	2.3	28.09	0.08	0
03/12/2023 03:00	2.4	27.42	0.08	0
03/12/2023 04:00	2.4	27.36	0.08	0
03/12/2023 05:00	2.3	26.73	0.08	0
03/12/2023 06:00	2.3	26.69	0.08	0
03/12/2023 07:00	2.3	26.19	0.08	0
03/12/2023 08:00	2.2	26.58	0.08	0
03/12/2023 09:00	2.2	26.91	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
03/12/2023 10:00	2.2	26.82	0.08	0
03/12/2023 11:00	2.3	26.53	0.08	0
03/12/2023 12:00	2.4	26.36	0.08	0
03/12/2023 13:00	2.5	25.71	0.08	0
03/12/2023 14:00	2.6	25.1	0.08	0
03/12/2023 15:00	2.6	25.86	0.08	0
03/12/2023 16:00	2.6	26.36	0.08	0
03/12/2023 17:00	2.5	26.56	0.08	0
03/12/2023 18:00	2.5	26.42	0.08	0
03/12/2023 19:00	2.4	26.59	0.08	0
03/12/2023 20:00	2.4	26.77	0.08	0
03/12/2023 21:00	2.4	26.91	0.08	0
03/12/2023 22:00	2.4	29.6	0.08	0
03/12/2023 23:00	2.4	30.78	0.08	0
04/12/2023 00:00	2.4	29.63	0.08	0
04/12/2023 01:00	2.3	30.85	0.08	0
04/12/2023 02:00	2.4	36.25	0.08	0
04/12/2023 03:00	2.4	33.36	0.08	0
04/12/2023 04:00	2.4	32.59	0.08	0
04/12/2023 05:00	2.3	30.77	0.08	0
04/12/2023 06:00	2.3	29.81	0.08	0
04/12/2023 07:00	2.4	29.57	0.08	0
04/12/2023 08:00	2.5	28.98	0.08	0
04/12/2023 09:00	2.5	28.67	0.08	0
04/12/2023 10:00	2.6	27.98	0.08	0
04/12/2023 11:00	2.6	27.5	0.08	0
04/12/2023 12:00	2.6	26.54	0.08	0
04/12/2023 13:00	2.7	25.8	0.08	0
04/12/2023 14:00	2.8	25.81	0.08	0
04/12/2023 15:00	2.8	26.03	0.08	0
04/12/2023 16:00	2.9	25.18	0.08	0
04/12/2023 17:00	2.8	24.6	0.08	0
04/12/2023 18:00	2.8	24.72	0.08	0
04/12/2023 19:00	2.7	27.45	0.08	0
04/12/2023 20:00	2.7	27.19	0.08	0
04/12/2023 21:00	2.7	27.01	0.08	0
04/12/2023 22:00	2.7	27.01	0.08	0
04/12/2023 23:00	2.6	27.14	0.08	0
05/12/2023 00:00	2.6	27.12	0.08	0
05/12/2023 01:00	2.6	26.95	0.08	0
05/12/2023 02:00	2.5	27.53	0.08	0
05/12/2023 03:00	2.5	27.24	0.08	0
05/12/2023 04:00	2.5	26.7	0.08	0
05/12/2023 05:00	2.5	26.47	0.08	0
05/12/2023 06:00	2.5	26.13	0.08	0
05/12/2023 07:00	2.5	26.24	0.08	0
05/12/2023 08:00	2.5	27.14	0.08	0
05/12/2023 09:00	2.5	27.49	0.08	0
05/12/2023 10:00	2.6	27.38	0.08	0
05/12/2023 11:00	2.7	27.43	0.08	0
05/12/2023 12:00	2.8	26.41	0.08	0
05/12/2023 13:00	2.9	25.59	0.08	0
05/12/2023 14:00	2.9	25.03	0.08	0
05/12/2023 15:00	3	23.36	0.08	0
05/12/2023 16:00	2.9	25.29	0.08	0
05/12/2023 17:00	2.9	27.11	0.08	0
05/12/2023 18:00	2.9	26.56	0.08	0
05/12/2023 19:00	2.8	26.02	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
05/12/2023 20:00	2.9	29.65	0.08	0
05/12/2023 21:00	2.8	29.54	0.08	0
05/12/2023 22:00	2.8	28.95	0.08	0
05/12/2023 23:00	2.8	28.45	0.08	0
06/12/2023 00:00	2.7	28.34	0.08	0
06/12/2023 01:00	2.7	27.86	0.08	0
06/12/2023 02:00	2.7	27.4	0.08	0
06/12/2023 03:00	2.7	27.03	0.08	0
06/12/2023 04:00	2.7	26.74	0.08	0
06/12/2023 05:00	2.7	26.54	0.08	0
06/12/2023 06:00	2.6	26.62	0.08	0
06/12/2023 07:00	2.6	27.31	0.08	0
06/12/2023 08:00	2.6	28.05	0.08	0
06/12/2023 09:00	2.6	27.19	0.08	0
06/12/2023 10:00	2.6	27.2	0.08	0
06/12/2023 11:00	2.7	26.85	0.08	0
06/12/2023 12:00	2.8	25.63	0.08	0
06/12/2023 13:00	2.9	24.35	0.08	0
06/12/2023 14:00	3	24.73	0.08	0
06/12/2023 15:00	3	24.86	0.08	0
06/12/2023 16:00	3.1	24.7	0.08	0
06/12/2023 17:00	3.1	27.15	0.08	0
06/12/2023 18:00	3.1	28.1	0.08	0
06/12/2023 19:00	3.1	26.3	0.08	0
06/12/2023 20:00	3	28.7	0.08	0
06/12/2023 21:00	3	28.41	0.08	0
06/12/2023 22:00	3	27.82	0.08	0
06/12/2023 23:00	3	27.3	0.08	0
07/12/2023 00:00	3	27.83	0.08	0
07/12/2023 01:00	3	27.56	0.08	0
07/12/2023 02:00	3	27.66	0.08	0
07/12/2023 03:00	2.9	27.42	0.08	0
07/12/2023 04:00	2.9	27.61	0.08	0
07/12/2023 05:00	2.9	27.41	0.08	0
07/12/2023 06:00	2.8	27.23	0.08	0
07/12/2023 07:00	2.8	26.92	0.08	0
07/12/2023 08:00	2.8	27.85	0.08	0
07/12/2023 09:00	2.8	27.39	0.08	0
07/12/2023 10:00	2.8	27.06	0.08	0
07/12/2023 11:00	2.9	28.75	0.08	0
07/12/2023 12:00	3	31.38	0.08	0
07/12/2023 13:00	3.1	28.69	0.08	0
07/12/2023 14:00	3.2	28.09	0.08	0
07/12/2023 15:00	3.3	27.43	0.08	0
07/12/2023 16:00	3.6	27.34	0.08	0
07/12/2023 17:00	4	32.66	0.08	0
07/12/2023 18:00	4	35.1	0.08	0
07/12/2023 19:00	4.1	38.96	0.08	0
07/12/2023 20:00	4.1	38.4	0.08	0
07/12/2023 21:00	3.9	36.29	0.08	0
07/12/2023 22:00	3.9	34.31	0.08	0
07/12/2023 23:00	3.8	32.28	0.08	0
08/12/2023 00:00	3.7	30.81	0.08	0
08/12/2023 01:00	3.7	30.24	0.08	0
08/12/2023 02:00	3.6	29	0.08	0
08/12/2023 03:00	3.6	28.39	0.08	0
08/12/2023 04:00	3.5	31.61	0.08	0
08/12/2023 05:00	3.4	35.5	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
08/12/2023 06:00	3.4	33.17	0.08	0
08/12/2023 07:00	3.3	31.85	0.08	0
08/12/2023 08:00	3.2	30.24	0.08	0
08/12/2023 09:00	3.1	30.22	0.08	0
08/12/2023 10:00	3.4	35.11	0.08	0
08/12/2023 11:00	3.5	37.47	0.08	0
08/12/2023 12:00	3.5	33.98	0.08	0
08/12/2023 13:00	3.4	30.34	0.08	0
08/12/2023 14:00	3.7	29.66	0.08	0
08/12/2023 15:00	4	28.08	0.08	0
08/12/2023 16:00	4.2	27.4	0.08	0
08/12/2023 17:00	4.2	27.9	0.08	0
08/12/2023 18:00	4.5	26.22	0.08	0
08/12/2023 19:00	4.5	25.9	0.08	0
08/12/2023 20:00	4.7	26.23	0.08	0
08/12/2023 21:00	4.6	28.43	0.08	0
08/12/2023 22:00	4.7	27.73	0.08	0
08/12/2023 23:00	4.8	27.09	0.08	0
09/12/2023 00:00	4.6	26.69	0.08	0
09/12/2023 01:00	4.6	26.83	0.08	0
09/12/2023 02:00	4.6	26.55	0.08	0
09/12/2023 03:00	4.3	26.37	0.08	0
09/12/2023 04:00	4.3	26.98	0.08	0
09/12/2023 05:00	4.3	26.5	0.08	0
09/12/2023 06:00	4.1	26.39	0.08	0
09/12/2023 07:00	3.9	26.82	0.08	0
09/12/2023 08:00	4	27.23	0.08	0
09/12/2023 09:00	3.9	27.55	0.08	0
09/12/2023 10:00	3.5	26.77	0.08	0
09/12/2023 11:00	3.5	26.54	0.08	0
09/12/2023 12:00	3.7	26.15	0.08	0
09/12/2023 13:00	4	30.4	0.08	0
09/12/2023 14:00	4.1	32.09	0.08	0
09/12/2023 15:00	4.2	30.26	0.08	0
09/12/2023 16:00	4.3	28.45	0.08	0
09/12/2023 17:00	4.7	28.06	0.08	0
09/12/2023 18:00	5	28.67	0.08	0
09/12/2023 19:00	5.1	26.86	0.08	0
09/12/2023 20:00	5.2	28.13	0.08	0
09/12/2023 21:00	4.9	32.21	0.08	0
09/12/2023 22:00	5.3	34.89	0.08	0
09/12/2023 23:00	5.1	33.56	0.08	0
10/12/2023 00:00	4.9	32.11	0.08	0
10/12/2023 01:00	4.9	31.38	0.08	0
10/12/2023 02:00	5.1	30.65	0.08	0
10/12/2023 03:00	4.9	30.39	0.08	0
10/12/2023 04:00	5	29.94	0.08	0
10/12/2023 05:00	5	29.75	0.08	0
10/12/2023 06:00	4.8	29.75	0.08	0
10/12/2023 07:00	4.7	30.03	0.08	0
10/12/2023 08:00	4.7	30.27	0.08	0
10/12/2023 09:00	4.4	29.69	0.08	0
10/12/2023 10:00	4.3	29.41	0.08	0
10/12/2023 11:00	4.4	29.03	0.08	0
10/12/2023 12:00	4.5	28.05	0.08	0
10/12/2023 13:00	4.5	27.6	0.08	0
10/12/2023 14:00	4.6	27.77	0.08	0
10/12/2023 15:00	4.7	27.53	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
10/12/2023 16:00	4.9	27.83	0.08	0
10/12/2023 17:00	5	27.52	0.08	0
10/12/2023 18:00	5.1	28.13	0.08	0
10/12/2023 19:00	5.2	26.85	0.08	0
10/12/2023 20:00	5.2	28.93	0.08	0
10/12/2023 21:00	5.1	31.37	0.08	0
10/12/2023 22:00	5	30.86	0.08	0
10/12/2023 23:00	5	30.3	0.08	0
11/12/2023 00:00	4.8	30.16	0.08	0
11/12/2023 01:00	4.8	29.94	0.08	0
11/12/2023 02:00	4.8	32.52	0.08	0
11/12/2023 03:00	4.9	37.77	0.08	0
11/12/2023 04:00	4.6	35.78	0.08	0
11/12/2023 05:00	4.5	34.11	0.08	0
11/12/2023 06:00	4.4	32.75	0.08	0
11/12/2023 07:00	4.2	31.78	0.08	0
11/12/2023 08:00	4.2	31.45	0.08	0
11/12/2023 09:00	4.2	29.8	0.08	0
11/12/2023 10:00	4.2	28.67	0.08	0
11/12/2023 11:00	4.3	28.41	0.08	0
11/12/2023 12:00	4.3	28.4	0.08	0
11/12/2023 13:00	4.3	28.12	0.08	0
11/12/2023 14:00	4.3	27.18	0.08	0
11/12/2023 15:00	4.3	26.92	0.08	0
11/12/2023 16:00	4.5	26.55	0.08	0
11/12/2023 17:00	4.6	27.12	0.08	0
11/12/2023 18:00	4.5	25.64	0.08	0
11/12/2023 19:00	4.4	27.22	0.08	0
11/12/2023 20:00	4.4	29.02	0.08	0
11/12/2023 21:00	4.5	28.75	0.08	0
11/12/2023 22:00	4.2	28.33	0.08	0
11/12/2023 23:00	4.1	28.69	0.08	0
12/12/2023 00:00	3.9	28.23	0.08	0
12/12/2023 01:00	3.9	29	0.08	0
12/12/2023 02:00	3.9	28.76	0.08	0
12/12/2023 03:00	3.8	28.92	0.08	0
12/12/2023 04:00	3.9	28.59	0.08	0
12/12/2023 05:00	3.9	28.54	0.08	0
12/12/2023 06:00	3.9	29.18	0.08	0
12/12/2023 07:00	4	29.74	0.08	0
12/12/2023 08:00	3.8	29.05	0.08	0
12/12/2023 09:00	3.6	29.06	0.08	0
12/12/2023 10:00	3.5	29.24	0.08	0
12/12/2023 11:00	3.5	28.55	0.08	0
12/12/2023 12:00	3.4	28.33	0.08	0
12/12/2023 13:00	3.4	27.73	0.08	0
12/12/2023 14:00	3.4	27.39	0.08	0
12/12/2023 15:00	3.5	27.27	0.08	0
12/12/2023 16:00	3.5	27.91	0.08	0
12/12/2023 17:00	3.4	28.22	0.08	0
12/12/2023 18:00	3.5	27.07	0.08	0
12/12/2023 19:00	3.5	26.65	0.08	0
12/12/2023 20:00	3.7	29.14	0.08	0
12/12/2023 21:00	3.5	28.73	0.08	0
12/12/2023 22:00	3.4	28.87	0.08	0
12/12/2023 23:00	3.3	28.8	0.08	0
13/12/2023 00:00	3.3	28.9	0.08	0
13/12/2023 01:00	3.2	29	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
13/12/2023 02:00	3.2	28.94	0.08	0
13/12/2023 03:00	3.2	28.97	0.08	0
13/12/2023 04:00	3.2	29.02	0.08	0
13/12/2023 05:00	3.2	29.42	0.08	0
13/12/2023 06:00	3.2	29.53	0.08	0
13/12/2023 07:00	3.2	29.71	0.08	0
13/12/2023 08:00	3.2	30.13	0.08	0
13/12/2023 09:00	3.1	29.37	0.08	0
13/12/2023 10:00	3.2	29.46	0.08	0
13/12/2023 11:00	3.2	28.3	0.08	0
13/12/2023 12:00	3.3	27.66	0.08	0
13/12/2023 13:00	3.3	27.08	0.08	0
13/12/2023 14:00	3.3	26.8	0.08	0
13/12/2023 15:00	3.4	27.09	0.08	0
13/12/2023 16:00	3.4	25.96	0.08	0
13/12/2023 17:00	3.4	27.48	0.08	0
13/12/2023 18:00	3.3	27.83	0.08	0
13/12/2023 19:00	3.3	27.61	0.08	0
13/12/2023 20:00	3.3	27.81	0.08	0
13/12/2023 21:00	3.2	27.79	0.08	0
13/12/2023 22:00	3.2	27.92	0.08	0
13/12/2023 23:00	3.2	27.84	0.08	0
14/12/2023 00:00	3.2	27.76	0.08	0
14/12/2023 01:00	3.2	27.54	0.08	0
14/12/2023 02:00	3.1	27.69	0.08	0
14/12/2023 03:00	3.1	27.97	0.08	0
14/12/2023 04:00	3.1	27.94	0.08	0
14/12/2023 05:00	3	27.69	0.08	0
14/12/2023 06:00	3	27.33	0.08	0
14/12/2023 07:00	3	27.93	0.08	0
14/12/2023 08:00	3	28.63	0.08	0
14/12/2023 09:00	3	28.38	0.08	0
14/12/2023 10:00	3	30.55	0.08	0
14/12/2023 11:00	3.1	31.09	0.08	0
14/12/2023 12:00	3.2	29.8	0.08	0
14/12/2023 13:00	3.2	28.6	0.08	0
14/12/2023 14:00	3.3	28.23	0.08	0
14/12/2023 15:00	3.3	27.15	0.08	0
14/12/2023 16:00	3.4	31.47	0.08	0
14/12/2023 17:00	3.3	31.7	0.08	0
14/12/2023 18:00	3.3	29.03	0.08	0
14/12/2023 19:00	3.2	30.32	0.08	0
14/12/2023 20:00	3.2	30.07	0.08	0
14/12/2023 21:00	3.2	29.29	0.08	0
14/12/2023 22:00	3.2	28.82	0.08	0
14/12/2023 23:00	3.2	28.82	0.08	0
15/12/2023 00:00	3.2	28.45	0.08	0
15/12/2023 01:00	3.1	28.04	0.08	0
15/12/2023 02:00	3.1	27.85	0.08	0
15/12/2023 03:00	3.1	27.28	0.08	0
15/12/2023 04:00	3.1	26.99	0.08	0
15/12/2023 05:00	3	27.01	0.08	0
15/12/2023 06:00	3	27.11	0.08	0
15/12/2023 07:00	2.9	28.11	0.08	0
15/12/2023 08:00	2.9	27.57	0.08	0
15/12/2023 09:00	2.9	28.21	0.08	0
15/12/2023 10:00	2.9	27.8	0.08	0
15/12/2023 11:00	3	27.34	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
15/12/2023 12:00	3.1	26.61	0.08	0
15/12/2023 13:00	3.2	25.55	0.08	0
15/12/2023 14:00	3.3	25.61	0.08	0
15/12/2023 15:00	3.4	25.33	0.08	0
15/12/2023 16:00	3.4	25.33	0.08	0
15/12/2023 17:00	3.4	24.94	0.08	0
15/12/2023 18:00	3.4	25.4	0.08	0
15/12/2023 19:00	3.4	25.82	0.08	0
15/12/2023 20:00	3.4	27.68	0.08	0
15/12/2023 21:00	3.4	27.53	0.08	0
15/12/2023 22:00	3.4	27.43	0.08	0
15/12/2023 23:00	3.3	28.1	0.08	0
16/12/2023 00:00	3.3	27.8	0.08	0
16/12/2023 01:00	3.3	27.85	0.08	0
16/12/2023 02:00	3.3	27.68	0.08	0
16/12/2023 03:00	3.3	27.94	0.08	0
16/12/2023 04:00	3.3	27.82	0.08	0
16/12/2023 05:00	3.3	27.96	0.08	0
16/12/2023 06:00	3.2	28.19	0.08	0
16/12/2023 07:00	3.2	28.99	0.08	0
16/12/2023 08:00	3.2	29.54	0.08	0
16/12/2023 09:00	3.2	28.95	0.08	0
16/12/2023 10:00	3.2	29.05	0.08	0
16/12/2023 11:00	3.3	28.74	0.08	0
16/12/2023 12:00	3.4	28.16	0.08	0
16/12/2023 13:00	3.5	27.16	0.08	0
16/12/2023 14:00	3.6	26.77	0.08	0
16/12/2023 15:00	3.6	27.04	0.08	0
16/12/2023 16:00	3.6	26.3	0.08	0
16/12/2023 17:00	3.6	26.83	0.08	0
16/12/2023 18:00	3.6	27.81	0.08	0
16/12/2023 19:00	3.6	27.74	0.08	0
16/12/2023 20:00	3.6	27.42	0.08	0
16/12/2023 21:00	3.5	27.89	0.08	0
16/12/2023 22:00	3.5	28.15	0.08	0
16/12/2023 23:00	3.5	27.9	0.08	0
17/12/2023 00:00	3.5	27.96	0.08	0
17/12/2023 01:00	3.5	28.32	0.08	0
17/12/2023 02:00	3.5	28.16	0.08	0
17/12/2023 03:00	3.5	28.78	0.08	0
17/12/2023 04:00	3.5	28.41	0.08	0
17/12/2023 05:00	3.4	28.71	0.08	0
17/12/2023 06:00	3.4	29.72	0.08	0
17/12/2023 07:00	3.3	30.31	0.08	0
17/12/2023 08:00	3.3	30.62	0.08	0
17/12/2023 09:00	3.3	36.18	0.08	0
17/12/2023 10:00	3.2	33.86	0.08	0
17/12/2023 11:00	3.3	32.98	0.08	0
17/12/2023 12:00	3.4	32.81	0.08	0
17/12/2023 13:00	3.4	37.78	0.08	0
17/12/2023 14:00	3.4	34.66	0.08	0
17/12/2023 15:00	3.4	32.29	0.08	0
17/12/2023 16:00	3.5	31.25	0.08	0
17/12/2023 17:00	3.5	30.59	0.08	0
17/12/2023 18:00	3.5	29.12	0.08	0
17/12/2023 19:00	3.5	29.07	0.08	0
17/12/2023 20:00	3.5	28.97	0.08	0
17/12/2023 21:00	3.5	28.44	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
17/12/2023 22:00	3.4	28.23	0.08	0
17/12/2023 23:00	3.5	27.66	0.08	0
18/12/2023 00:00	3.4	27.37	0.08	0
18/12/2023 01:00	3.5	27.45	0.08	0
18/12/2023 02:00	3.4	27.33	0.08	0
18/12/2023 03:00	3.5	27.27	0.08	0
18/12/2023 04:00	3.4	26.57	0.08	0
18/12/2023 05:00	3.4	26.76	0.08	0
18/12/2023 06:00	3.3	27.11	0.08	0
18/12/2023 07:00	3.2	26.96	0.08	0
18/12/2023 08:00	3.2	27.53	0.08	0
18/12/2023 09:00	3.4	27.75	0.08	0
18/12/2023 10:00	3.4	27.42	0.08	0
18/12/2023 11:00	3.6	27.51	0.08	0
18/12/2023 12:00	3.7	27.14	0.08	0
18/12/2023 13:00	3.7	26.55	0.08	0
18/12/2023 14:00	3.7	26.14	0.08	0
18/12/2023 15:00	3.9	25.73	0.08	0
18/12/2023 16:00	4.1	25.57	0.08	0
18/12/2023 17:00	4.2	26.1	0.08	0
18/12/2023 18:00	4.4	25.52	0.08	0
18/12/2023 19:00	4.5	27.25	0.08	0
18/12/2023 20:00	4.5	27.92	0.08	0
18/12/2023 21:00	4.4	28.04	0.08	0
18/12/2023 22:00	4.6	28.06	0.08	0
18/12/2023 23:00	4.4	28.16	0.08	0
19/12/2023 00:00	4.4	28.36	0.08	0
19/12/2023 01:00	4.2	28.96	0.08	0
19/12/2023 02:00	4.2	29.27	0.08	0
19/12/2023 03:00	4	29.13	0.08	0
19/12/2023 04:00	3.9	28.83	0.08	0
19/12/2023 05:00	4	28.73	0.08	0
19/12/2023 06:00	4	28.76	0.08	0
19/12/2023 07:00	3.9	28.72	0.08	0
19/12/2023 08:00	3.7	29.37	0.08	0
19/12/2023 09:00	3.8	29.43	0.08	0
19/12/2023 10:00	3.7	29.09	0.08	0
19/12/2023 11:00	3.8	28.71	0.08	0
19/12/2023 12:00	4	27.92	0.08	0
19/12/2023 13:00	4	26.98	0.08	0
19/12/2023 14:00	4.2	27.42	0.08	0
19/12/2023 15:00	4.3	27.14	0.08	0
19/12/2023 16:00	4.4	26.72	0.08	0
19/12/2023 17:00	4.5	27.82	0.08	0
19/12/2023 18:00	4.6	27.95	0.08	0
19/12/2023 19:00	4.5	28.07	0.08	0
19/12/2023 20:00	4.3	28.22	0.08	0
19/12/2023 21:00	4.6	28.41	0.08	0
19/12/2023 22:00	4.9	28.47	0.08	0
19/12/2023 23:00	4.7	28.56	0.08	0
20/12/2023 00:00	4.5	28.62	0.08	0
20/12/2023 01:00	4.5	29	0.08	0
20/12/2023 02:00	4.4	28.75	0.08	0
20/12/2023 03:00	4.3	28.81	0.08	0
20/12/2023 04:00	4.3	28.81	0.08	0
20/12/2023 05:00	4.2	28.87	0.08	0
20/12/2023 06:00	4.1	28.65	0.08	0
20/12/2023 07:00	4.1	29.25	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
20/12/2023 08:00	4.2	29.85	0.08	0
20/12/2023 09:00	4.1	29.28	0.08	0
20/12/2023 10:00	4.1	28.87	0.08	0
20/12/2023 11:00	4.1	28.68	0.08	0
20/12/2023 12:00	4.3	28.34	0.08	0
20/12/2023 13:00	4.5	27.35	0.08	0
20/12/2023 14:00	4.5	27.04	0.08	0
20/12/2023 15:00	4.8	27.25	0.08	0
20/12/2023 16:00	5	27.17	0.08	0
20/12/2023 17:00	5.1	27.35	0.08	0
20/12/2023 18:00	5	28.27	0.08	0
20/12/2023 19:00	5.1	28.36	0.08	0
20/12/2023 20:00	4.9	28.55	0.08	0
20/12/2023 21:00	4.9	27.71	0.08	0
20/12/2023 22:00	4.9	28.5	0.08	0
20/12/2023 23:00	4.8	28.49	0.08	0
21/12/2023 00:00	4.8	28.67	0.08	0
21/12/2023 01:00	4.8	28.55	0.08	0
21/12/2023 02:00	4.6	28.29	0.08	0
21/12/2023 03:00	4.4	28.55	0.08	0
21/12/2023 04:00	4.6	28.5	0.08	0
21/12/2023 05:00	4.4	28.29	0.08	0
21/12/2023 06:00	4.4	28.58	0.08	0
21/12/2023 07:00	4.4	28.9	0.08	0
21/12/2023 08:00	4.3	28.66	0.08	0
21/12/2023 09:00	4.2	28.36	0.08	0
21/12/2023 10:00	4.2	28.82	0.08	0
21/12/2023 11:00	4.2	28.77	0.08	0
21/12/2023 12:00	4.4	28.33	0.08	0
21/12/2023 13:00	4.5	27.22	0.08	0
21/12/2023 14:00	4.5	32.19	0.08	0
21/12/2023 15:00	4.6	31.28	0.08	0
21/12/2023 16:00	4.6	31.1	0.08	0
21/12/2023 17:00	4.8	30.25	0.08	0
21/12/2023 18:00	4.7	29.78	0.08	0
21/12/2023 19:00	4.8	29.11	0.08	0
21/12/2023 20:00	4.9	28.7	0.08	0
21/12/2023 21:00	4.8	28.46	0.08	0
21/12/2023 22:00	4.8	28.12	0.08	0
21/12/2023 23:00	4.7	28.03	0.08	0
22/12/2023 00:00	4.6	27.73	0.08	0
22/12/2023 01:00	4.7	27.51	0.08	0
22/12/2023 02:00	4.6	27.34	0.08	0
22/12/2023 03:00	4.5	27.03	0.08	0
22/12/2023 04:00	4.4	26.86	0.08	0
22/12/2023 05:00	4.3	27.9	0.08	0
22/12/2023 06:00	4.3	27.95	0.08	0
22/12/2023 07:00	4.3	32.41	0.08	0
22/12/2023 08:00	4.2	33.24	0.08	0
22/12/2023 09:00	4.1	31.58	0.08	0
22/12/2023 10:00	4.1	30.21	0.08	0
22/12/2023 11:00	4.1	29.32	0.08	0
22/12/2023 12:00	4.1	28.86	0.08	0
22/12/2023 13:00	4.2	28.04	0.08	0
22/12/2023 14:00	4.4	28.09	0.08	0
22/12/2023 15:00	4.5	27.92	0.08	0
22/12/2023 16:00	4.6	27.25	0.08	0
22/12/2023 17:00	4.7	27.02	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
22/12/2023 18:00	4.7	26.73	0.08	0
22/12/2023 19:00	4.6	26.75	0.08	0
22/12/2023 20:00	4.8	26.9	0.08	0
22/12/2023 21:00	4.5	26.53	0.08	0
22/12/2023 22:00	4.4	26.47	0.08	0
22/12/2023 23:00	4.5	26.66	0.08	0
23/12/2023 00:00	4.4	28.3	0.08	0
23/12/2023 01:00	4.5	28.54	0.08	0
23/12/2023 02:00	4.4	28.36	0.08	0
23/12/2023 03:00	4.4	28.38	0.08	0
23/12/2023 04:00	4.4	28.32	0.08	0
23/12/2023 05:00	4.3	28.12	0.08	0
23/12/2023 06:00	4.2	28.14	0.08	0
23/12/2023 07:00	4.2	28.33	0.08	0
23/12/2023 08:00	4	28.77	0.08	0
23/12/2023 09:00	4.1	28.57	0.08	0
23/12/2023 10:00	4	28.64	0.08	0
23/12/2023 11:00	4	27.36	0.08	0
23/12/2023 12:00	4	26.5	0.08	0
23/12/2023 13:00	4.1	26.18	0.08	0
23/12/2023 14:00	4.3	26.4	0.08	0
23/12/2023 15:00	4.4	26.38	0.08	0
23/12/2023 16:00	4.7	26.52	0.08	0
23/12/2023 17:00	4.7	26.39	0.08	0
23/12/2023 18:00	3.9	26.5	0.08	0
23/12/2023 19:00	3.9	26.25	0.08	0
23/12/2023 20:00	3.9	26.57	0.08	0
23/12/2023 21:00	4	27.25	0.08	0
23/12/2023 22:00	3.9	26.98	0.08	0
23/12/2023 23:00	3.9	27.88	0.08	0
24/12/2023 00:00	3.8	28.5	0.08	0
24/12/2023 01:00	3.9	28.96	0.08	0
24/12/2023 02:00	3.8	28.69	0.08	0
24/12/2023 03:00	3.6	28.69	0.08	0
24/12/2023 04:00	3.6	28.64	0.08	0
24/12/2023 05:00	3.8	28.7	0.08	0
24/12/2023 06:00	3.6	28.81	0.08	0
24/12/2023 07:00	3.6	28.87	0.08	0
24/12/2023 08:00	2.7	28.71	0.08	0
24/12/2023 09:00	2.2	28.85	0.08	0
24/12/2023 10:00	2.2	28.86	0.08	0
24/12/2023 11:00	2.2	28.07	0.08	0
24/12/2023 12:00	2.2	26.18	0.08	0
24/12/2023 13:00	2.2	26.15	0.08	0
24/12/2023 14:00	2.2	25.77	0.08	0
24/12/2023 15:00	2.2	25.89	0.08	0
24/12/2023 16:00	2.2	25.89	0.08	0
24/12/2023 17:00	2.2	25.97	0.08	0
24/12/2023 18:00	2.2	27.4	0.08	0
24/12/2023 19:00	2.2	28.24	0.08	0
24/12/2023 20:00	2.1	28.34	0.08	0
24/12/2023 21:00	2.1	28.54	0.08	0
24/12/2023 22:00	2.1	28.61	0.08	0
24/12/2023 23:00	2.1	28.7	0.08	0
25/12/2023 00:00	2.1	28.9	0.08	0
25/12/2023 01:00	2.1	29.03	0.08	0
25/12/2023 02:00	2	32.63	0.08	0
25/12/2023 03:00	2	31.63	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
25/12/2023 04:00	2	31.16	0.08	0
25/12/2023 05:00	1.9	30.66	0.08	0
25/12/2023 06:00	1.9	30.15	0.08	0
25/12/2023 07:00	1.9	38.42	0.08	0
25/12/2023 08:00	1.9	35.46	0.08	0
25/12/2023 09:00	1.9	33.71	0.08	0
25/12/2023 10:00	1.9	32.28	0.08	0
25/12/2023 11:00	1.9	30.35	0.08	0
25/12/2023 12:00	2	28.57	0.08	0
25/12/2023 13:00	2.1	28.01	0.08	0
25/12/2023 14:00	2.3	27.53	0.08	0
25/12/2023 15:00	2.4	27.56	0.08	0
25/12/2023 16:00	2.4	27.32	0.08	0
25/12/2023 17:00	2.4	26.83	0.08	0
25/12/2023 18:00	2.4	26.55	0.08	0
25/12/2023 19:00	2.4	26.46	0.08	0
25/12/2023 20:00	2.4	26.65	0.08	0
25/12/2023 21:00	2.3	26.93	0.08	0
25/12/2023 22:00	2.3	28.56	0.08	0
25/12/2023 23:00	2.2	37.29	0.08	0
26/12/2023 00:00	2.2	34.72	0.08	0
26/12/2023 01:00	2.1	32.97	0.08	0
26/12/2023 02:00	2.1	31.87	0.08	0
26/12/2023 03:00	2.1	31.28	0.08	0
26/12/2023 04:00	2.1	30.99	0.08	0
26/12/2023 05:00	2	31.47	0.08	0
26/12/2023 06:00	2	35.85	0.08	0
26/12/2023 07:00	2	42.28	0.08	0
26/12/2023 08:00	2.1	39.56	0.08	0
26/12/2023 09:00	2.1	36.47	0.08	0
26/12/2023 10:00	2.2	34.5	0.08	0
26/12/2023 11:00	2.3	40.11	0.08	0
26/12/2023 12:00	2.4	40.57	0.08	0
26/12/2023 13:00	2.4	35.51	0.08	0
26/12/2023 14:00	2.5	32.5	0.08	0
26/12/2023 15:00	2.6	30.66	0.08	0
26/12/2023 16:00	2.6	29.68	0.08	0
26/12/2023 17:00	2.6	29.21	0.08	0
26/12/2023 18:00	2.6	28.89	0.08	0
26/12/2023 19:00	2.6	28.44	0.08	0
26/12/2023 20:00	2.5	28.22	0.08	0
26/12/2023 21:00	2.5	27.82	0.08	0
26/12/2023 22:00	2.5	27.64	0.08	0
26/12/2023 23:00	2.5	27.68	0.08	0
27/12/2023 00:00	2.5	27.72	0.08	0
27/12/2023 01:00	2.5	27.61	0.08	0
27/12/2023 02:00	2.5	27.65	0.08	0
27/12/2023 03:00	2.4	27.59	0.08	0
27/12/2023 04:00	2.4	28.2	0.08	0
27/12/2023 05:00	2.4	29.1	0.08	0
27/12/2023 06:00	2.4	29.43	0.08	0
27/12/2023 07:00	2.5	29.78	0.08	0
27/12/2023 08:00	2.5	28.87	0.08	0
27/12/2023 09:00	2.5	27.35	0.08	0
27/12/2023 10:00	2.5	27.79	0.08	0
27/12/2023 11:00	2.5	27.8	0.08	0
27/12/2023 12:00	2.6	27.61	0.08	0
27/12/2023 13:00	2.7	27.15	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
27/12/2023 14:00	2.7	27.47	0.08	0
27/12/2023 15:00	2.8	27.15	0.08	0
27/12/2023 16:00	2.9	26.3	0.08	0
27/12/2023 17:00	2.9	26.03	0.08	0
27/12/2023 18:00	2.8	26.39	0.08	0
27/12/2023 19:00	2.8	26.81	0.08	0
27/12/2023 20:00	2.7	27.8	0.08	0
27/12/2023 21:00	2.7	28.5	0.08	0
27/12/2023 22:00	2.6	27.93	0.08	0
27/12/2023 23:00	2.6	29	0.08	0
28/12/2023 00:00	2.6	37.07	0.08	0
28/12/2023 01:00	2.6	34.72	0.08	0
28/12/2023 02:00	2.5	33.23	0.08	0
28/12/2023 03:00	2.5	40.46	0.08	0
28/12/2023 04:00	2.6	38.25	0.08	0
28/12/2023 05:00	2.6	36.88	0.08	0
28/12/2023 06:00	2.5	34.54	0.08	0
28/12/2023 07:00	2.6	33.3	0.08	0
28/12/2023 08:00	2.6	31.07	0.08	0
28/12/2023 09:00	2.6	30.41	0.08	0
28/12/2023 10:00	2.7	29.85	0.08	0
28/12/2023 11:00	2.9	28.96	0.08	0
28/12/2023 12:00	3	28.62	0.08	0
28/12/2023 13:00	3.1	27.28	0.08	0
28/12/2023 14:00	3.2	26.91	0.08	0
28/12/2023 15:00	3.3	27.15	0.08	0
28/12/2023 16:00	3.3	26.74	0.08	0
28/12/2023 17:00	3.3	26.64	0.08	0
28/12/2023 18:00	3.2	26.68	0.08	0
28/12/2023 19:00	3.2	27.31	0.08	0
28/12/2023 20:00	3.2	27.82	0.08	0
28/12/2023 21:00	3.1	30.55	0.08	0
28/12/2023 22:00	3.1	32.51	0.08	0
28/12/2023 23:00	3.3	31.79	0.08	0
29/12/2023 00:00	3.2	31.16	0.08	0
29/12/2023 01:00	3.3	30.35	0.08	0
29/12/2023 02:00	3.3	35.95	0.08	0
29/12/2023 03:00	3.4	35.63	0.08	0
29/12/2023 04:00	3.5	35.8	0.08	0
29/12/2023 05:00	3.4	40.99	0.08	0
29/12/2023 06:00	3.6	36.74	0.08	0
29/12/2023 07:00	3.6	33.93	0.08	0
29/12/2023 08:00	3.6	32.26	0.08	0
29/12/2023 09:00	3.6	31.34	0.08	0
29/12/2023 10:00	3.6	31.07	0.08	0
29/12/2023 11:00	3.7	48.78	0.08	0
29/12/2023 12:00	3.9	49.69	0.08	0
29/12/2023 13:00	3.7	49.17	0.08	0
29/12/2023 14:00	3.7	38.93	0.08	0
29/12/2023 15:00	3.6	34.34	0.08	0
29/12/2023 16:00	3.5	31.17	0.08	0
29/12/2023 17:00	3.5	29.26	0.08	0
29/12/2023 18:00	3.4	29.25	0.08	0
29/12/2023 19:00	3.3	29.35	0.08	0
29/12/2023 20:00	3.1	29.18	0.08	0
29/12/2023 21:00	3.1	28.97	0.08	0
29/12/2023 22:00	3	28.7	0.08	0
29/12/2023 23:00	3	28.93	0.08	0

Site Report - DATA TO IEAT				
Date&Time	BOD	FLOW	POWER	Fire Alarm
	ppm	m3/Hr	KW	#
30/12/2023 00:00	3	28.85	0.08	0
30/12/2023 01:00	2.9	28.4	0.08	0
30/12/2023 02:00	2.9	28.59	0.08	0
30/12/2023 03:00	2.9	32.65	0.08	0
30/12/2023 04:00	3	40.8	0.08	0
30/12/2023 05:00	3	35.82	0.08	0
30/12/2023 06:00	3.1	33.41	0.08	0
30/12/2023 07:00	3.1	31.8	0.08	0
30/12/2023 08:00	3	31.03	0.08	0
30/12/2023 09:00	3.1	30.27	0.08	0
30/12/2023 10:00	3.1	29.51	0.08	0
30/12/2023 11:00	3.2	29.05	0.08	0
30/12/2023 12:00	3.3	28.1	0.08	0
30/12/2023 13:00	3.3	27.34	0.08	0
30/12/2023 14:00	3.3	27.18	0.08	0
30/12/2023 15:00	3.4	26.92	0.08	0
30/12/2023 16:00	3.4	26.9	0.08	0
30/12/2023 17:00	3.4	26.46	0.08	0
30/12/2023 18:00	3.4	26.9	0.08	0
30/12/2023 19:00	3.3	27.4	0.08	0
30/12/2023 20:00	3.3	28.06	0.08	0
30/12/2023 21:00	3.3	28.16	0.08	0
30/12/2023 22:00	3.3	27.9	0.08	0
30/12/2023 23:00	3.3	28.36	0.08	0
31/12/2023 00:00	3.3	28.46	0.08	0
31/12/2023 01:00	3.3	28.75	0.08	0
31/12/2023 02:00	3.3	28.93	0.08	0
31/12/2023 03:00	3.2	29.16	0.08	0
31/12/2023 04:00	3.2	29.27	0.08	0
31/12/2023 05:00	3.2	29.54	0.08	0
31/12/2023 06:00	3.2	29.69	0.08	0
31/12/2023 07:00	3.2	30.1	0.08	0
31/12/2023 08:00	3.2	30.08	0.08	0
31/12/2023 09:00	3.2	29.47	0.08	0
31/12/2023 10:00	3.2	29.04	0.08	0
31/12/2023 11:00	3.3	28.76	0.08	0
31/12/2023 12:00	3.4	28.2	0.08	0
31/12/2023 13:00	3.5	27.3	0.08	0
31/12/2023 14:00	3.5	27.34	0.08	0
31/12/2023 15:00	3.6	26.71	0.08	0
31/12/2023 16:00	3.7	26.8	0.08	0
31/12/2023 17:00	3.7	27.62	0.08	0
31/12/2023 18:00	3.7	27.89	0.08	0
31/12/2023 19:00	3.6	28.08	0.08	0
31/12/2023 20:00	3.6	27.96	0.08	0
31/12/2023 21:00	3.6	28.36	0.08	0
31/12/2023 22:00	3.6	28.5	0.08	0
31/12/2023 23:00	3.5	28.26	0.08	0
Minimum	1.9	23.36	0.08	0
MinDate	25/12/2023 05:00	05/12/2023 15:00	01/12/2023 00:00	01/12/2023 00:00
Maximum	5.3	55.96	0.08	0
MaxDate	09/12/2023 22:00	01/12/2023 12:00	01/12/2023 00:00	01/12/2023 00:00
Avg	3.4	29.6	0.08	0
Num	743	743	743	743
Data(%)	99.7	99.7	99.7	99.7
STD	0.8	4.1	---	0
	2,536.30	21,992.73	59.44	-