

Request No. LA66-R0849

Report No. R6608-5100 – R6608-5103

**TEST REPORT**

CUSTOMER : Meyer Aluminium (Thailand) Co., Ltd.  
 ADDRESS : 38/32 Moo 5 Laem Chabang Industrial Estate, Sriracha, Chonburi 20230  
 SAMPLE SOURCE : Meyer Aluminium (Thailand) Co., Ltd.  
 MEASURING DATE : 21/08/2023 SAMPLE NO. : 26264-26267  
 RECEIVED DATE : 21/08/2023 REPORTED DATE : 23/08/2023  
 SAMPLING INSTRUMENT\* : Wind Vane Anemometer

Location	Temperature (°C)	Diameter (m)	Area (m <sup>2</sup> )	Velocity (m/s)	Flow Rate (m <sup>3</sup> /s)
1. Hood เตาพัก No.1	33.5	1.0	0.785714	9.13	7.17514
2. Hood เตาหลอม No.1	33.6	1.0	0.785714	12.20	9.58729
3. Hood เตาพัก No.2	45.5	1.0	0.785714	12.56	9.87171
4. Hood เตาหลอม No.2	41.5	1.0	0.785714	9.24	7.26000

**REMARK :**

\* Parameter Outside The Scope of The Registration of The Department of Industrial Works  
 (Measurement By Mr. Metee Sukprasert)



บริษัท อีสเทิร์นไทยคอนซัลติง 1992 จำกัด

Approved By



(MR. THONGCHAI BOONSAK)

23/08/2023

REPORTED TEST REFER TO SUBMITTED SAMPLES ONLY

THIS REPORT SHALL NOT REPRODUCED EXCEPT IN FULL

WITHOUT THE WRITTEN APPROVAL LABORATORY