

WL1320	PP5,6,10,11 OPERATION	21/8/2023 23:24	231042980	MONTHLY - PM REFILL LUBRICANT FOR AGITATOR-DISSOLVING TANK SEE LONG DISC	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	21/8/2023 23:24	231042982	MONTHLY - PM ROUTE REFILL LUBRICANT BEARING FAN FOR IDFAN(GROUP1) (PO)	NPP5A_PP11
MS0103	Automation Service (Instrument)	21/8/2023 23:24	231042984	Monthly PM Dust meter "Sick"(ISO 14000)	NPP5A_PP11
MS0103	Automation Service (Instrument)	21/8/2023 23:25	231043066	Monthly PM for 463Q1490 DO after Feed water pump	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/8/2023 23:45	231043067	MONTHLY - INSPECTION PH TR	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/8/2023 23:46	231043039	MONTHLY - INSPECTION PH TR	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/8/2023 23:47	231042557	MONTHLY - INSPECTION PH	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/8/2023 23:47	231042490	MONTHLY - PM FOR BL-SPRAYER DIVERT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/8/2023 23:47	231043467	MONTHLY - PM FOR BL-SPRAYER DIVERT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/8/2023 23:48	231042771	MONTHLY - PM FOR BL-SPRAYER DIVERT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/8/2023 23:48	231042773	MONTHLY - PM FOR BL-SPRAYER DIVERT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/8/2023 23:49	231043478	MONTHLY - PM FOR TRANSFORMER TE22(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/8/2023 23:49	231043470	MONTHLY - PM FOR FIRE FIGHTING RECOVERY BOILER (E)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	25/8/2023 23:55	231042719	WEEKLY - INSPECTION CAMERA	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/8/2023 22:12	231043189	2 WEEKS - INSPECTION DOSING PUMP	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/8/2023 22:12	231043177	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/8/2023 22:14	231043187	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/8/2023 22:15	231043190	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/8/2023 22:16	231043184	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR CONTROL OIL PUMP #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/8/2023 22:17	231043191	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR CONTROL OIL PUMP #2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/8/2023 22:19	231043186	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR LUBE OIL PUMP #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/8/2023 22:20	231043182	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR LUBE OIL PUMP #2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:28	231043165	MONTHLY - PM FOR START-UP BURNER #1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:29	231043166	MONTHLY - PM FOR START-UP BURNER #2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:29	231043181	MONTHLY - PM FOR START-UP BURNER #3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:30	231043194	MONTHLY - PM FOR START-UP BURNER #4 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:30	231043183	WEEKLY - PM FOR GENERATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:31	231043172	WEEKLY - PM FOR LUP OIL PUMP FEED WATER PUMP 3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:32	231043193	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:33	231043175	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:34	231043180	2 WEEKS - PM VISUAL CHECK AND BASIC PDM FOR AGITATOR-DISSOLVING TANK SEE LONG DISC	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:35	231043179	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:36	231043174	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR #2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:37	231043170	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR PRIMARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:39	231043173	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR SECONDARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:41	231043167	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR TERTIARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:43	231043168	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:45	231043176	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN #2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:47	231043171	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:50	231043192	MONTHLY - PM ROUTE REFILL LUBRICANT CHAIN CONVEYOR (GROUP2) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:51	231043188	MONTHLY - PM ROUTE REFILL OIL FAN COOLING TOWER (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:51	231043178	MONTHLY CLEANING AIR SUPPLY FILTER 452JB04	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:51	231043195	MONTHLY CLEANING AIR SUPPLY FILTER 452JB06	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:51	231041684	MONTHLY CLEANING AIR SUPPLY FILTER 452JB07	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:52	231041683	MONTHLY CLEANING AIR SUPPLY FILTER 452JB09	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:52	231041685	MONTHLY CLEANING AIR SUPPLY FILTER 463AD20	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:53	231041687	MONTHLY CLEANING AIR SUPPLY FILTER 463AD21	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:53	231041686	MONTHLY CLEANING AIR SUPPLY FILTER 463AD22	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:53	231041688	MONTHLY CLEANING AIR SUPPLY FILTER 463AD23	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:54	231041689	MONTHLY CLEANING AIR SUPPLY FILTER 463AD25A	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:54	231041690	MONTHLY CLEANING AIR SUPPLY FILTER 463AD25B	NPP5A_PP11
MS0103	Automation Service (Instrument)	27/8/2023 0:54	231042604	2 weeks check 463 Stack flue gas analyzer	NPP5A_PP11
MS0103	Automation Service (Instrument)	27/8/2023 0:56	231042605	calibrate 463 Stack flue gas analyzer (ISO14000)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:59	231042606	PM FOR FEEDWTR BLOCK VLAVE 463HV150	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:59	231042611	PM FOR RAPID DRAIN GENBANK 463HV151B	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 0:59	231042612	PM FOR RAPID DRAIN DOWNCOMER 463HV152B	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 1:00	231042441	PM FOR STARTUP BLOCK VLV 463HV154	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 1:00	231042609	PM FOR MAIN STEAM VALVE 463HV155	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 1:00	231042600	PM FOR DISC CONT BLOWDOWN 463HV158	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 1:01	231042601	PM FOR STEAM VLV BYPASS 463HV171	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 1:01	231043025	MONTHLY - PM FOR RECOVERY TRANSFORMER TH411(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 1:02	231043017	MONTHLY - PM FOR EVAPORATION TRANSFORMER TH401(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 1:02	231043293	MONTHLY - PM FOR TURBO GEN. Transformer TD11 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 1:03	231043466	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 1:06	231042506	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 1:08	2023147846	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 1:09	231042507	WEEKLY - PM ROUTE CHECK SWITCHGEAR (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/8/2023 1:10	231043491	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR STEAM TURBINE,32900KW (PO)	NPP5A_PP11
MS0103	Automation Service (Control)	27/8/2023 1:11	231041740	2 WEEKS - PM FOR PLC TURBINE & GENERATOR GOVERNOR CONTROL (A)	NPP5A_PP11
MS0103	Automation Service (Control)	27/8/2023 1:14	231043495	2 WEEKS - PM FOR HMI TURBINE & GENERATOR GOVERNOR CONTROL (A)	NPP5A_PP11
MS0103	Automation Service (Control)	27/8/2023 1:14	231043498	2 WEEKS - PM FOR HMI RODDING MASTER (463CP60) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	27/8/2023 1:14	231043496	2 WEEKS - PM FOR HMI RODDING MASTER (463CP61) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	27/8/2023 1:14	231043500	2 WEEKS - PM FOR HMI BMS (A)	NPP5A_PP11
MS0103	Automation Service (Control)	27/8/2023 1:14	231043497	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #1 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	27/8/2023 1:15	231043502	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #2 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	27/8/2023 1:15	231043503	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #3 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	27/8/2023 1:15	231043504	2 WEEKS - PM FOR PLC RODDING MASTER (463CP60) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	27/8/2023 1:15	231043506	2 WEEKS - PM FOR PLC RODDING MASTER (463CP61) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	27/8/2023 1:16	231043298	2 WEEKS - PM FOR PLC BMS (A)	NPP5A_PP11
MS0103	Automation Service (Control)	27/8/2023 1:16	231042579	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #1 (A)	NPP5A_PP11

MS0103	Automation Service (Control)	27/8/2023 1:17	231042555	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #2 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	27/8/2023 1:17	231043537	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #3 (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	28/8/2023 23:53	231041680	MONTHLY - INSPECTION AGITATOR	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	28/8/2023 23:55	231043535	MONTHLY - PM ROUTE CHECK MOTOR RAPPER ESP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	28/8/2023 23:56	2023019789	MONTHLY - PM ROUTE REFILL LUBRICANT CHAIN CONVEYOR (GROUP3) (PO)	NPP5A_PP11
MS0103	Maintenance Central Management	28/8/2023 23:56	231043536	monthly inspection Evaporation DCS Controller (A)	NPP5A_PP11
MS0103	Maintenance Central Management	28/8/2023 23:58	231043533	monthly inspection Mill Wide DCS Controller (A)	NPP5A_PP11
MS0103	Maintenance Central Management	29/8/2023 0:00	2023019785	monthly inspection Soot Blower DCS Controller (A)	NPP5A_PP11
MS0103	Maintenance Central Management	29/8/2023 0:03	231043532	monthly inspection RecoveryBoiler DCS Controller (A)	NPP5A_PP11
MS0103	Maintenance Central Management	29/8/2023 0:05	231043220	monthly inspection for R.B. DCS Power Distrib. (A)	NPP5A_PP11
MS0103	Maintenance Central Management	29/8/2023 0:05	231043221	monthly inspection for Evapor DCS Power Distrib. (A)	NPP5A_PP11
MS0103	Maintenance Central Management	29/8/2023 0:06	231043548	monthly inspection for MillWideDCS Power Distrib. (A)	NPP5A_PP11
MS0024	Predictive Maintenance	29/8/2023 0:07	231043561	Monthly vibration check for Plan 262	NPP5A_PP11
MS0024	Predictive Maintenance	29/8/2023 0:07	231042465	Monthly vibration check for Plan 282	NPP5A_PP11
MS0024	Predictive Maintenance	29/8/2023 0:07	231043001	Monthly vibration check for Plan 293	NPP5A_PP11
MS0024	Predictive Maintenance	29/8/2023 0:08	231042492	Monthly vibration check for Plan 452	NPP5A_PP11
MS0024	Predictive Maintenance	29/8/2023 0:09	231043222	Monthly vibration check for Plan 463	NPP5A_PP11
MS0024	Predictive Maintenance	29/8/2023 0:10	231043231	Monthly oil Sampling for area 463	NPP5A_PP11
MS0024	Predictive Maintenance	29/8/2023 0:10	231043362	Monthly oil Sampling for area 293	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:27	231042461	MONTHLY - PM FOR RECOVERY BOILER OS2101 (OS501) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:28	231042706	MONTHLY - PM FOR RECOVERY BOILER OS2102 (OS502) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:28	231043261	MONTHLY - PM FOR MILL WIDE OS2103 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:29	231043311	MONTHLY - PM FOR MILL WIDE OS2104 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:29	231042598	MONTHLY - PM FOR EVAPORATOR OS2105 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:29	231043218	MONTHLY - PM FOR EVAPORATOR OS2106 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:30	231043219	MONTHLY - PM FOR UPS A FOR DCS BOILER PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:30	231042566	MONTHLY - PM FOR UPS B FOR DCS BOILER PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:30	231042594	MONTHLY - PM FOR UPS FOR INSTRUMENT RECOVERY BOILER (A)	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:30	231042597	MONTHLY - PM FOR UPS A FOR DCS TURBINE PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:31	231042568	MONTHLY - PM FOR UPS B FOR DCS TURBINE PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:31	231042585	MONTHLY - PM FOR UPS A FOR DCS EVAP PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:31	231043280	MONTHLY - PM FOR UPS B FOR DCS EVAP PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:31	231043018	MONTHLY - PM FOR UPS 01 FOR DCS CONTROL ROOM PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:31	231043055	MONTHLY - PM FOR BATTERY FOR 463UPS-A DCS BOILER PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:32	231043289	MONTHLY - PM FOR BATTERY FOR 463UPS-B DCS BOILER PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:32	231041707	MONTHLY - PM FOR BATTERY FOR 463UPS-C INSTRUMENT PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:32	231042435	MONTHLY - PM FOR BATTERY FOR 293UPS-A DCS TURBINE PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:32	231043444	MONTHLY - PM FOR BATTERY FOR 293UPS-B DCS TURBINE PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:33	231043443	MONTHLY - PM FOR BATTERY FOR 452UPS-A DCS EVAP PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:33	231043355	MONTHLY - PM FOR BATTERY FOR 452UPS-B DCS EVAP PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	29/8/2023 23:33	231043376	MONTHLY - PM FOR BATTERY FOR 463UPS-CR01 DCS CONTROL ROOM PP11 (A)	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	31/8/2023 22:00	231043387	YEARLY - PM FOR AHU EE ROOM EVAPORATOR (E)	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	31/8/2023 22:00	231043388	YEARLY - PM FOR AHU RECOVERY BOILER EE ROOM (E)	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	31/8/2023 22:00	231043389	YEARLY - PM FOR AHU EE ROOM MILL WIDE (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:06	231043390	MONTHLY - PM FOR COOLING WATER PUMP NO.2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:06	231043391	MONTHLY - PM FOR COOLING WATER PUMP NO.2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:06	231043392	MONTHLY - PM FOR PRIMARY FD FAN (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:06	231043393	MONTHLY - PM FOR PRIMARY FD FAN (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:07	231043394	MONTHLY - PM FOR SECONDARY FD FANN (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:07	231043395	MONTHLY - PM FOR SECONDARY FD FANN (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:07	231043396	MONTHLY - PM FOR TERTIARY FD FAN (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:07	231043356	MONTHLY - PM FOR TERTIARY FD FAN (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:07	231043377	MONTHLY - PM FOR ID FAN # 1 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:07	231043397	MONTHLY - PM FOR ID FAN # 1 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:07	231043398	MONTHLY - PM FOR ID FAN # 2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:08	231043399	MONTHLY - PM FOR ID FAN # 2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:08	231043400	MONTHLY - PM FOR ID FAN #3 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:08	231043401	MONTHLY - PM FOR ID FAN #3 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:08	231043403	MONTHLY - PM FOR FW PUMP #2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:08	231043404	MONTHLY - PM FOR FW PUMP #2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:08	231043405	MONTHLY - PM FOR AIR COMPRESSOR NO.1 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:08	231043406	MONTHLY - PM FOR AIR COMPRESSOR NO.1 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:08	231043407	MONTHLY - PM FOR AIR COMPRESSOR NO.2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:09	231043378	MONTHLY - PM FOR AIR COMPRESSOR NO.2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:09	231043409	MONTHLY - PM FOR AIR COMPRESSOR NO.3 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:09	231043410	MONTHLY - PM FOR AIR COMPRESSOR NO.3 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:09	231043411	MONTHLY - PM FOR AIR COMPRESSOR NO.4 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:09	231043412	MONTHLY - PM FOR AIR COMPRESSOR NO.4 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:09	231043413	MONTHLY - PM FOR FW PUMP #3 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:09	231043414	MONTHLY - PM FOR FW PUMP #3 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:09	231043434	MONTHLY - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:10	231043435	MONTHLY - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:10	231043436	MONTHLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:10	231043437	MONTHLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:10	231043438	MONTHLY - PM FOR WARM WATER PUMP (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:10	231043439	MONTHLY - PM FOR WARM WATER PUMP (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:10	231043440	MONTHLY - PM FOR COOLING WATER PUMP NO.1 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:10	231043415	MONTHLY - PM FOR COOLING WATER PUMP NO.1 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:11	231043442	MONTHLY - PM FOR COOLING WATER PUMP NO.3 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:11	231043416	MONTHLY - PM FOR COOLING WATER PUMP NO.3 (E)	NPP5A_PP11

WL5114	Electrical PP6,10,11	31/8/2023 23:11	231043417	MONTHLY - PM FOR RECOVERY TRANSFORMER TE21(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:11	231043418	MONTHLY - PM FOR RECOVERY TRANSFORMER TE21(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:11	231043379	MONTHLY - PM FOR TRANSFORMER TL412(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:11	231043419	MONTHLY - PM FOR TRANSFORMER TL412(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:11	231043420	MONTHLY - PM FOR TRANSFORMER TH412(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:11	231043421	MONTHLY - PM FOR TRANSFORMER TH412(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:12	231043422	MONTHLY - PM FOR TRANSFORMER TE22(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:12	231043423	MONTHLY - PM FOR TRANSFORMER TE22(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:12	231043424	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH211(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:12	231043425	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH211(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:12	231043426	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH212(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:12	231043427	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH212(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:12	231043428	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH291(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:12	231043380	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH291(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:13	231043430	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH293(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:13	231043432	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH293(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:13	231043433	MONTHLY - PM FOR TL293E POWER BACK UP FROM EGAT (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:13	231043382	MONTHLY - PM FOR TL293E POWER BACK UP FROM EGAT (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:13	231043383	MONTHLY - PM FOR AAP2 , TURBO GENERATOR TRANSFMR TD12 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:13	231043385	MONTHLY - PM FOR AAP2 , TURBO GENERATOR TRANSFMR TD12 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:13	231043386	MONTHLY - PM FOR GROUNDING TRANSFORMER (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:13	231042437	MONTHLY - PM FOR GROUNDING TRANSFORMER (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:13	231043014	MONTHLY - PM FOR RECOVERY TRANSFORMER TH411(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:14	231042438	MONTHLY - PM FOR RECOVERY TRANSFORMER TH411(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:14	231043016	MONTHLY - PM FOR EVAPORATION TRANSFORMER TH401(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:14	231043483	MONTHLY - PM FOR EVAPORATION TRANSFORMER TH401(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:14	231043487	MONTHLY - PM FOR TURBO GEN. Transformer TD11 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:14	231043488	MONTHLY - PM FOR TURBO GEN. Transformer TD11 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:14	231043489	MONTHLY - PM FOR EGAT OUT GOING TRANSFORMER TC3 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	31/8/2023 23:14	231043490	MONTHLY - PM FOR EGAT OUT GOING TRANSFORMER TC3 (E)	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	31/8/2023 23:14	231041692	PM.Check motor area 282	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	31/8/2023 23:15	231041693	PM.Check motor area 282	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	31/8/2023 23:15	231043259	PM.Check motor area 282	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	31/8/2023 23:15	231041732	PM.Check motor area 282	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	31/8/2023 23:15	231041733	PM.Check motor area 282	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	31/8/2023 23:16	231042776	PM.Check motor area 463	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	31/8/2023 23:16	231042775	PM.Check motor area 463	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	31/8/2023 23:16	231042641	PM.Check motor area 463	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	31/8/2023 23:16	231042618	PM.Check motor area 463	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	31/8/2023 23:17	231043053	PM.Check motor area 463	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	31/8/2023 23:17	231043054	YEARLY (SD) - PM FOR AHU SWITCHGEAR ROOM (E)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	2/9/2023 0:47	231042491	WEEKLY - INSPECTION CAMERA	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 0:48	231042589	MONTHLY - PM FOR CONDUCTIVITY INDICATION OF FEED WATER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 0:49	231042935	MONTHLY - PM FOR CONDUCTIVITY INDICATION OF DEMIN WATER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 0:50	231042949	MONTHLY - PM FOR CONDUCTIVITY INDICATION AFTER ANION EXCHANGER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 0:51	231043306	MONTHLY - PM FOR CONDUCTIVITY INDICATION AFTER MIXED BED EXCHANGER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 0:51	231043307	MONTHLY - PM FOR CONDUCTIVITY INDICATION AFTER ANION EXCHANGER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 0:52	231043312	MONTHLY - PM FOR CONDUCTIVITY INDICATION AFTER MIXED BED EXCHANGER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 0:53	231043309	MONTHLY - PM FOR CONDUCT. SUM (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 0:54	231043468	MONTHLY - PM FOR CONDUCTIVITY SUMP PIT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 0:55	231043448	MONTHLY - PM FOR condensate from fibre line (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 0:56	231042487	MONTHLY - PM FOR COND FRM EVAP PLANT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 0:56	231042488	MONTHLY - PM FOR COND FROM TURBINE (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 0:57	231043479	MONTHLY - PM FOR COND FROM PULP DRYER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 0:58	231042952	WEEKLY - PM FOR GENERATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 0:59	231042966	WEEKLY - PM FOR LUP OIL PUMP FEED WATER PUMP 3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:01	231042608	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:02	231043455	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:04	231043481	2 MONTHS - PM FOR VAPOR EXTRACTOR, SEPARATION OF OIL MIST. SEE L.D. (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:05	231042937	MONTHLY- PM FOR BATTERY CHARGER 110 VDC for 22KV SYSTEM (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:05	231042964	2 WEEKS - PM VISUAL CHECK AND BASIC PDM FOR AGITATOR-DISSOLVING TANK SEE	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:07	231042936	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR # 1 (PO	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:08	231042965	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR #2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:09	231042967	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR PRIMARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:12	231043011	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR SECONDARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:14	231042963	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR TERTIARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:16	231042968	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:19	231042943	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:21	231042944	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:24	231042942	MONTHLY - PM FOR FIRE FIGHTING MILL WIDE (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:24	231042955	MONTHLY - PM FOR CO2 FIRE ALARM & FIRE FIGHTING OF TURBINE (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:25	231042442	MONTHLY - PM FOR FIRE FIGHTING EVAPORATION (E)	NPP5A_PP11
MS0103	Automation Service (Instrument)	2/9/2023 1:25	231042951	calibrate 463 Stack flue gas analyzer (ISO14000)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:27	231042954	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:31	231042957	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:32	231042958	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:34	231042959	WEEKLY - PM ROUTE CHECK SWITCHGEAR (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:35	231042946	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR STEAM TURBINE,32900KW (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:37	231042938	MONTHLY - PM FOR SOOTBLOWER 1, LEFT (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 1:37	231042947	MONTHLY - PM FOR SOOTBLOWER 2, LEFT (E)	NPP5A_PP11

WL1320	PP5,6,10,11 OPERATION	2/9/2023 22:00	231042939	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 22:01	231042948	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 22:03	231042941	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 22:05	231042950	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR CONTROL OIL PUMP #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 22:06	231042953	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR CONTROL OIL PUMP # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 22:08	231042956	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR LUBE OIL PUMP #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/9/2023 22:09	231042960	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR LUBE OIL PUMP # 2 (PO)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	3/9/2023 23:04	231042961	2 WEEKS - PM FOR 115 KV SUBSTATION AAP2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 22:58	231042931	MONTHLY - PM FOR COOLING WATER PUMP NO.2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 22:58	231042932	MONTHLY - PM FOR PRIMARY FD FAN (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 22:59	231042933	MONTHLY - PM FOR SECONDARY FD FANN (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 22:59	231042613	MONTHLY - PM FOR TERTIARY FD FAN (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 22:59	231043012	MONTHLY - PM FOR ID FAN # 1 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 22:59	231041708	MONTHLY - PM FOR ID FAN # 2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 22:59	231043460	MONTHLY - PM FOR ID FAN #3 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 22:59	231043465	MONTHLY - PM FOR FW PUMP #2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 22:59	231043464	MONTHLY - PM FOR AIR COMPRESSOR NO.1 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:00	231043458	MONTHLY - PM FOR AIR COMPRESSOR NO.2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:00	231043453	MONTHLY - PM FOR AIR COMPRESSOR NO.3 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:00	231043456	MONTHLY - PM FOR AIR COMPRESSOR NO.4 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:00	231043450	MONTHLY - PM FOR FW PUMP #3 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:00	231043452	MONTHLY - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:00	231043461	MONTHLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:00	231043511	MONTHLY - PM FOR WARM WATER PUMP (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:01	231043454	MONTHLY - PM FOR COOLING WATER PUMP NO.1 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:01	231043484	MONTHLY - PM FOR COOLING WATER PUMP NO.3 (E)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	6/9/2023 23:01	231043480	MONTHLY - PM FOR 115 KV SUBSTATION AAP2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:02	231043473	MONTHLY - PM FOR RECOVERY TRANSFORMER TE21(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:02	231043463	MONTHLY - PM FOR TRANSFORMER TL412(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:02	231042699	MONTHLY - PM FOR TRANSFORMER TH412(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:02	231043494	MONTHLY - PM FOR TRANSFORMER TE22(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:02	231043493	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH211(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:02	231043492	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH212(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:02	231041744	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH291(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:02	231043340	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH293(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:02	231043281	MONTHLY - PM FOR TL293E POWER BACK UP FROM EGAT (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:03	231043283	MONTHLY - PM FOR AAP2 , TURBO GENERATOR TRANSFMR TD12 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:03	231043343	MONTHLY - PM FOR GROUNDING TRANSFORMER (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:03	231043344	MONTHLY - PM FOR RECOVERY TRANSFORMER TH411(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:03	231042614	MONTHLY - PM FOR EVAPORATION TRANSFORMER TH401(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:03	231042993	MONTHLY - PM FOR TURBO GEN. Transformer TD11 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	6/9/2023 23:03	231041734	MONTHLY - PM FOR EGAT OUT GOING TRANSFORMER TC3 (E)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	8/9/2023 6:15	2023000808	WEEKLY - INSPECTION CAMERA	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/9/2023 22:02	231041735	2 WEEKS - INSPECTION DOSING PUMP	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/9/2023 22:03	231043308	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/9/2023 22:04	231042590	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/9/2023 22:06	231043301	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/9/2023 22:08	231042591	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR CONTROL OIL PUMP #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/9/2023 22:10	231043004	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR CONTROL OIL PUMP # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/9/2023 22:12	231042476	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR LUBE OIL PUMP #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/9/2023 22:14	231042596	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR LUBE OIL PUMP # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/9/2023 0:22	231042580	WEEKLY - PM FOR GENERATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/9/2023 0:23	231041694	WEEKLY - PM FOR LUP OIL PUMP FEED WATER PUMP 3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/9/2023 0:24	231041695	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/9/2023 0:25	231041696	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/9/2023 0:27	231041697	2 WEEKS - PM VISUAL CHECK AND BASIC PDM FOR AGITATOR-DISSOLVING TANK SEE NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/9/2023 0:29	231041700	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/9/2023 0:30	231041698	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR #2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/9/2023 0:32	231041702	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR PRIMARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/9/2023 0:34	231041699	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR SECONDARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/9/2023 0:37	231041703	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR TERTIARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/9/2023 0:39	231042714	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/9/2023 0:42	231042715	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/9/2023 0:46	231042713	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN #3 (PO)	NPP5A_PP11
MS0103	Automation Service (Intrument)	10/9/2023 0:51	231042712	2 weeks check 463 Stack flue gas analyzer	NPP5A_PP11
MS0103	Automation Service (Intrument)	10/9/2023 0:53	231042710	calibrate 463 Stack flue gas analyzer (ISO14000)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/9/2023 0:56	231042711	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/9/2023 1:01	231042709	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/9/2023 1:03	231042720	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/9/2023 1:05	231042721	WEEKLY - PM ROUTE CHECK SWITCHGEAR (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/9/2023 1:07	231042718	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR STEAM TURBINE,32900KW (PO)	NPP5A_PP11
MS0103	Automation Service (Control)	10/9/2023 1:09	231042716	2 WEEKS - PM FOR PLC TURBINE & GENERATOR GOVERNOR CONTROL (A)	NPP5A_PP11
MS0103	Automation Service (Control)	10/9/2023 1:13	231042708	2 WEEKS - PM FOR HMI TURBINE & GENERATOR GOVERNOR CONTROL (A)	NPP5A_PP11
MS0103	Automation Service (Control)	10/9/2023 1:13	231158140	2 WEEKS - PM FOR HMI RODDING MASTER (463CP60) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	10/9/2023 1:13	231158138	2 WEEKS - PM FOR HMI RODDING MASTER (463CP61) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	10/9/2023 1:13	2023111587	2 WEEKS - PM FOR HMI BMS (A)	NPP5A_PP11
MS0103	Automation Service (Control)	10/9/2023 1:13	2023111601	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #1 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	10/9/2023 1:14	231163134	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #2 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	10/9/2023 1:14	2023141499	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #3 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	10/9/2023 1:14	2023147547	2 WEEKS - PM FOR PLC RODDING MASTER (463CP60) (A)	NPP5A_PP11

MS0103	Automation Service (Control)	10/9/2023 1:15	2023147548	2 WEEKS - PM FOR PLC RODDING MASTER (463CP61) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	10/9/2023 1:15	231163159	2 WEEKS - PM FOR PLC BMS (A)	NPP5A_PP11
MS0103	Automation Service (Control)	10/9/2023 1:16	231185645	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #1 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	10/9/2023 1:17	231152151	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #2 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	10/9/2023 1:17	231174514	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #3 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	11/9/2023 0:20	231152152	MONTHLY - PM FOR MILLWIDE DCS CONTROLLER (A)	NPP5A_PP11
MS0103	Automation Service (Instrument)	11/9/2023 0:21	231174515	6Month ISOKINETIC CALIBRATE 463A1257DUST(ISO14000)	NPP5A_PP11
MS0103	Automation Service (Instrument)	11/9/2023 0:22	231152150	6Month ISOKINETIC CALIBRATE 463A1257OPA(ISO14000)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/9/2023 23:13	231174512	MONTHLY - PM FOR BATTERY FOR 293NU01 CHARGER 110 VDC MILL WIDE BANK#1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/9/2023 23:14	231152149	MONTHLY - PM FOR BATTERY FOR 293NU01 CHARGER 110 VDC MILL WIDE BANK#2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/9/2023 23:14	231174511	MONTHLY - PM FOR BATTERY 110 VDC FOR Communication 115 kv (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/9/2023 23:14	231152147	MONTHLY - PM FOR BATTERY FOR 294BTN01 CHARGER 48VDC FOR 115KV NPP11 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/9/2023 23:15	231174509	MONTHLY - PM FOR BATTERY FOR 463UPS01 MCC RECOVERY BOILER, UPS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/9/2023 23:15	231152148	MONTHLY - PM FOR BATTERY FOR 294NU01 CHARGER 110 VDC FOR 22KV SYSTEM (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/9/2023 23:15	231174510	MONTHLY - PM FOR BATTERY FOR 293UPS01 MCC MILL WIDE, UPS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/9/2023 23:16	231152146	MONTHLY - PM FOR CHARGER 110 VDC FOR Communication 115 kv (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/9/2023 23:16	231174508	MONTHLY - PM FOR CHARGER 48VDC FOR 115KV NPP11 (E)	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	12/9/2023 23:16	231152156	PM.Check motor area 282	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	12/9/2023 23:17	231174522	PM.Check motor area 463	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/9/2023 23:17	231152157	MONTHLY - ROUTE PM FOR INSPECTION FABRIC EXPANSION JOINT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/9/2023 23:19	231174523	MONTHLY - PM REFILL LUBRICANT FOR AGITATOR STRONG LIQUOR STORAGE TANK (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:17	231152158	MONTHLY - PM FOR START-UP BURNER #5 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:17	231174525	MONTHLY - PM FOR START-UP BURNER #6 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:18	231152155	MONTHLY - PM FOR ELECTROSTATIC PRECIPITATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:19	231174519	MONTHLY - PM FOR ELECTROSTATIC PRECIPITATOR # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:21	231152153	MONTHLY - PM FOR ESP #3(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:22	231174516	MONTHLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:22	231152154	MONTHLY - PM FOR RECOVERY TRANSFORMER TE21(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:23	231174518	MONTHLY - PM FOR TRANSFORMER TL412(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:24	231152145	MONTHLY - PM FOR TRANSFORMER TH412(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:25	231174504	MONTHLY - PM FOR RECTIFIER # A, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:25	2023141761	MONTHLY - PM FOR RECTIFIER # B, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:26	2023141762	MONTHLY - PM FOR RECTIFIER # C, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:27	231152126	MONTHLY - PM FOR RECTIFIER # A, PRECIPITATOR # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:28	231160506	MONTHLY - PM FOR RECTIFIER # B, PRECIPITATOR # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:28	231174453	MONTHLY - PM FOR RECTIFIER # C, PRECIPITATOR # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:29	231185614	MONTHLY - PM FOR RECTIFIER #A, PRECIPITATOR # 3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:30	231174474	MONTHLY - PM FOR RECTIFIER #B, PRECIPITATOR #3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:31	231163127	MONTHLY - PM FOR RECTIFIER #C, PRECIPITATOR #3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:32	231163130	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH211(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:32	231163132	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH212(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:33	231177944	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH291(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:34	231163122	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH293(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:35	231163129	MONTHLY - PM FOR TL293E POWER BACK UP FROM EGAT (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:36	231163128	MONTHLY - PM FOR AAP2 , TURBO GENERATOR TRANSFMR TD12 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:36	231163125	MONTHLY - PM FOR GROUNDING TRANSFORMER (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:37	231163123	MONTHLY - INSPECTION PUMP	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:42	231163124	MONTHLY - PM ROUTE REFILL LUBRICANT BEARING FAN FOR IDFAN(GROUP2) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:43	231163126	MONTHLY - PM ROUTE REFILL LUBRICANT BEARING FAN FOR IDFAN(GROUP3) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:43	231163122	PM FOR FEEDWTR BY-PASS VLV 463HV172	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:43	231163147	PM FOR SOOTBLWR STEAM HDR 463HV181	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:44	231167281	MONTHLY - PM FOR AL21 BUS 6.6KV FEED WATER PUMP P003 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:45	231167282	MONTHLY - PM FOR AL22 SWG 6.6KV FEED WATER PUMP P050 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:46	231167283	MONTHLY - PM FOR EGAT OUT GOING TRANSFORMER TC3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:46	231170834	MONTHLY - PM FOR VSD OF FIRING LIQUOR PUMP #1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:47	231170837	MONTHLY - PM FOR VSD OF FIRING LIQUOR PUMP #2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:47	231159930	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:49	231170839	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:51	231160545	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR ACID DOSING PUMP #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:53	231160550	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR ACID DOSING PUMP #2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:54	231160553	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR EMERGENCY OIL PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:56	231160557	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR GLAND COND DRAIN PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 6:58	231160559	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 A PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:00	231160561	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 B PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:02	231160537	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 C PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:04	2023112336	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 D PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:06	231160542	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 A PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:08	231152139	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 B PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:10	231160597	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 C PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:12	231174475	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 D PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:14	231185629	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 2 PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:16	2023105242	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR EFFECT II-I LIQ .TRANSF PUMP (F NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:17	231175916	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR EFFECT III CIRCULATE PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:19	2023105390	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR EFFECT III-II LIQ TRANSF PUMP (NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:21	2023105391	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR EFFECT IV CIRCULATE PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:23	2023105132	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR EFFECT V CIRCULATE PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:25	2023147558	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR PRIMARY CONDENSATE PUMP (PC NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:27	2023147559	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FOUL CONDENSATE PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:29	231189372	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SEC. CONDENSATE II PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:31	2023111665	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FOUL COND. VAC. PIT DWG (PO)	NPP5A_PP11

WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:33	231158160	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR VACUUM PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:35	231158245	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR VACUUM PUMP (STAND-BY) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:37	231158246	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR REFLUX CONDENSATE (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:39	231158244	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR WASH LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:41	231158239	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR COMBINED CONDENSATE (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:43	2023147697	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FEED LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:44	2023147698	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQ FLASH TNK PUMP#1 (NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:46	231163135	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQ FLASH TNK PUMP#1 (NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:48	2023147703	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR DESUPERHEATER PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:50	2023147704	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR STRONG LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:52	231163136	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR STRONG LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:54	2023147709	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR WARM WATER PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:56	2023147710	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SECONDARY CONDENSATE PUMP	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 7:58	231163137	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SUMP PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 8:00	2023147715	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR STRONG LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 8:02	2023147716	6 MONTHS - PM FOR NDT TEST RECORD FOR LINE TRANSFER BL (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 8:03	231163138	MONTHLY - PM FOR BMS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 8:04	231163146	MONTHLY - PM FOR BOX MAIN SUPPLY BURNER (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 8:04	231158172	MONTHLY - PM FOR AH411 MCC 690V RECOVERY BOILER #2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 8:06	231158173	MONTHLY - PM FOR AL412 MCC 400V ESP#3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 8:08	231158247	MONTHLY - PM FOR AH401 MCC 690V EVAPORATOR PULP 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 8:09	231158248	MONTHLY - PM FOR AH211 MCC. 690V MILL WIDE #1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 8:10	231158241	MONTHLY - PM FOR AH212 MCC. 690V MILL WIDE #2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 8:11	2023111649	MONTHLY - PM FOR AL291 EMERGENCY POWER SUPPLY 400 VAC (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/9/2023 8:12	2023111696	MONTHLY - PM FOR AL293 NORMAL POWER SUPPLY 400 VAC (E)	NPP5A_PP11
WL15121	MAINTENANCE EMERGENCY (TEAM A)	15/9/2023 3:02	231160503	WEEKLY - INSPECTION CAMERA	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	15/9/2023 3:03	231154824	MONTHLY - PM FOR SCRUBBER FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	15/9/2023 3:06	231154825	MONTHLY - PM FOR FIRE FIGHTING SWITCH GEAR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/9/2023 22:00	231154831	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/9/2023 22:02	231177962	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/9/2023 22:04	231177963	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/9/2023 22:06	231154828	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR CONTROL OIL PUMP #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/9/2023 22:08	231154830	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR CONTROL OIL PUMP # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/9/2023 22:10	231177964	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR LUBE OIL PUMP #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/9/2023 22:12	231177965	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR LUBE OIL PUMP # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:26	231154829	WEEKLY - PM FOR GENERATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:27	231177959	WEEKLY - PM FOR LUP OIL PUMP FEED WATER PUMP 3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:29	231177960	2 MONTHS - PM FOR AGITATOR-SBL MIX TANK SEE LONG DISCRPTION (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:30	231177961	2 MONTHS - PM FOR ASH CRUSHER, GEN BANK(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:32	231177966	MONTHLY - PM FOR AIR COMPRESSOR NO.1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:34	2023111737	MONTHLY - PM FOR AIR COMPRESSOR NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:35	2023111739	MONTHLY - PM FOR AIR COMPRESSOR NO.3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:36	231167275	MONTHLY - PM FOR AIR COMPRESSOR NO.4 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:38	231167277	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:39	231158237	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:41	231158238	MONTHLY - PM FOR BATTERY CHARGER 110 VDC MILL WIDE (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:41	231154832	MONTHLY - PM FOR MCC MILL WIDE, UPS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:42	231154833	MONTHLY - PM FOR BATTERY CHARGER 110 VDC MILL WIDE (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:42	231182820	MONTHLY - PM FOR MCC MILL WIDE, UPS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:43	231182780	MONTHLY - PM FOR MCC RECOVERY BOILER, UPS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:43	231182793	2 WEEKS - PM VISUAL CHECK AND BASIC PDM FOR AGITATOR-DISSOLVING TANK SEE NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:46	231182786	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR ASH COLLECTING CONVEYOR (PO NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:48	231182770	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR DRAG SCRAPER, ESP # 1 SEE LON NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:49	2023112075	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR DRAG SCRAPER, ESP # 2 SEE LON NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:51	2023112079	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR COLLECTING CONVEYOR, ESP # 1 NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:53	2023112077	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR COLLECTING CONVEYOR, ESP # 2 NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:55	2023112081	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SCRAPER CONVEYER ESP.3 (PO) NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:57	231182753	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR COLLECTING CONVEYER ESP.3 (P NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 0:58	231182729	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR # 1 (PO NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:00	231182719	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR #2 (PO) NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:02	2023147772	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 1 FOR AREA 182 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:04	2023147773	4 MONTHS - PM ROUTE CLEAN FOR AREA 262,272,282 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:06	2023147778	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 1 FOR AREA 293 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:08	2023147727	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 1 FOR AREA 452 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:10	2023147728	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 2 FOR AREA 452 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:12	231158174	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 3 FOR AREA 452 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:14	231158136	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 1 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:15	231158135	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 2 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:17	231158137	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 3 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:19	2023105515	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 4 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:21	231174486	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 5 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:22	231177949	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 6 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:24	231177950	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 7 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:26	231182824	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 8 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:29	231182814	MONTHLY - PM FOR AIR COMPRESSOR NO.1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:33	231167280	MONTHLY - PM FOR AIR COMPRESSOR NO.2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:37	2023147691	MONTHLY - PM FOR AIR COMPRESSOR NO.3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:41	2023147721	MONTHLY - PM FOR AIR COMPRESSOR NO.4 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:45	231147264	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR PRIMARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:49	2023111647	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR SECONDARY FD FAN (PO)	NPP5A_PP11

WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:52	2023147673	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR TERTIARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:55	2023147679	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 1:59	2023147685	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:03	2023147754	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:08	2023147760	MONTHLY - PM ROUTE REFILL LUBRICANT CHAIN CONVEYOR (GROUP1) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:08	2023147761	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP A (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:09	2023111694	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP B (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:10	2023111698	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP C (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:10	231160505	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP D (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:11	231163139	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP E (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:12	231177947	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP F (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:12	231177948	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP G (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:13	2023111655	MONTHLY CLEANING AIR SUPPLY FILTER 463AD26	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:13	231158154	MONTHLY CLEANING AIR SUPPLY FILTER 463AD27	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:14	2023111657	MONTHLY CLEANING AIR SUPPLY FILTER 282AS21	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:14	231158156	MONTHLY CLEANING AIR SUPPLY FILTER 282AS22	NPP5A_PP11
MS0103	Automation Service (Instrument)	17/9/2023 2:15	2023111659	calibrate 463 Stack flue gas analyzer (ISO14000)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:19	231158157	2 MONTHS - PM FOR MOTOR ROTARY FEEDER, ESP # 1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:20	2023111661	2 MONTHS - PM FOR MOTOR ROTARY FEEDER, ESP # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:22	231147278	2 MONTHS - PM FOR MOTOR ROTARY FEED ESP#3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:23	231158158	2 MONTHS - PM FOR MOTOR SCREW CONVEYER ESP.3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:25	231147253	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:28	231177945	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:32	231177946	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:37	2023105547	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR DUMP TANK PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:40	231158142	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SPILL COLLECTION PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:43	2023105503	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SCRUBBER RECIRCULATION PUMI	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:45	231174484	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR GREEN LIQ TRANSFER PUMP # 1 (NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:47	231158145	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR GREEN LIQ TRANSFER PUMP #2 (NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:50	231158148	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SPOUT COOLING WATER PUMP # NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:53	231158146	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SPOUT COOLING WATER PUMP # NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:55	231158149	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 2:57	231158147	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CONDENSATE FEED PUMP#A (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:00	231158150	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CONDENSATE FEED PUMP#B (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:03	231158151	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:05	231158152	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:08	231158153	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CONDENSATE PUMP NO. 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:10	231160907	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CONDENSATE PUMP NO. 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:12	2023147661	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 1, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:14	231147254	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 2, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:15	231185642	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 3, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:17	231185644	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 4, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:19	231174445	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 5, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:21	231174446	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 6, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:22	231174447	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 7, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:24	231174448	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 8, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:26	231158133	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 9, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:28	2023147667	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 10, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:29	231147255	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 11, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:31	2023111663	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 12, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:33	231158159	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 13, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:34	2023105579	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 14, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:36	231167279	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 15, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:38	2023105569	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 16, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:40	231158144	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 17, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:42	2023105557	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 18, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:43	231158143	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 19, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:45	2023105525	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 20, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:47	231174487	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 21, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:49	231177958	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 22, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:50	231177951	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 23, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:52	231177956	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 24, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:54	231177954	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 25, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:56	231177955	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 26, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:57	231177952	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 27, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 3:59	231177957	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 28, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:01	231177953	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 29, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:03	231158175	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 30, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:04	2023147766	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 31, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:06	231147267	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 32, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:08	2023112101	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 33, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:10	2023112103	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 34, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:11	231163141	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 35, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:13	231175922	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 36, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:15	231163148	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 37, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:16	231158168	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 38, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:18	231158169	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 39, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:20	231160588	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 40, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:22	231174462	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 41, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:24	231175923	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 42, RIGHT (PO)	NPP5A_PP11

WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:25	231160590	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 43, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:27	2023111924	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 44 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:29	231160592	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 45, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:31	231160593	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 46, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:32	231160594	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 47, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:34	231160595	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 48, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:36	231160596	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 49, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:38	231174463	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 50, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:39	231158179	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 51, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:41	231158181	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 52, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:43	2023112041	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 353, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:45	2023112049	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 354, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:46	2023112043	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 355, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:48	2023112051	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 356, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:50	2023112045	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 357, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:52	2023112053	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 358, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:53	2023112047	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 359, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:55	2023112055	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 360, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:57	231158201	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER #61 LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 4:59	231158202	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER # 62 RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 5:00	231160611	WEEKLY - PM ROUTE CHECK SWITCHGEAR (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 5:02	231160527	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR STEAM TURBINE,32900KW (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/9/2023 5:04	231160518	MONTHLY - PM FOR SCRUBBER FAN (E)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	17/9/2023 5:04	231160521	2 WEEKS - PM FOR 115 KV SUBSTATION AAP2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/9/2023 0:38	231158220	MONTHLY - PM REFILL LUBRICANT FOR AGITATOR-DISSOLVING TANK SEE LONG DISC	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/9/2023 0:38	231160612	MONTHLY - PM REFILL LUBRICANT FOR AGITATOR-DISSOLVING TANK SEE LONG DISC	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/9/2023 0:38	231160613	MONTHLY - PM ROUTE REFILL LUBRICANT BEARING FAN FOR IDFAN(GROUP1) (PO)	NPP5A_PP11
MS0103	Automation Service (Instrument)	18/9/2023 0:38	231160617	Monthly PM Dust meter "Sick"(ISO 14000)	NPP5A_PP11
MS0103	Automation Service (Instrument)	18/9/2023 0:40	231160618	Monthly PM for 463Q1490 DO after Feed water pump	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	21/9/2023 0:27	231158177	MONTHLY - INSPECTION PH TR	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	21/9/2023 0:32	231158178	MONTHLY - INSPECTION PH TR	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	21/9/2023 0:33	231158226	MONTHLY - INSPECTION PH	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	21/9/2023 0:33	231160513	MONTHLY - PM FOR BL-SPRAYER DIVERT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	21/9/2023 0:34	231160516	MONTHLY - PM FOR BL-SPRAYER DIVERT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	21/9/2023 0:35	231160602	MONTHLY - PM FOR BL-SPRAYER DIVERT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	21/9/2023 0:37	231158204	MONTHLY - PM FOR BL-SPRAYER DIVERT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	21/9/2023 0:38	231158203	MONTHLY - PM FOR TRANSFORMER TE22(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	21/9/2023 0:39	231158205	MONTHLY - PM FOR FIRE FIGHTING RECOVERY BOILER (E)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	23/9/2023 3:41	231158207	WEEKLY - INSPECTION CAMERA	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 3:42	231158208	MONTHLY - PM FOR START-UP BURNER #1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 3:43	231158184	MONTHLY - PM FOR START-UP BURNER #2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 3:44	2023111772	MONTHLY - PM FOR START-UP BURNER #3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 3:44	2023111774	MONTHLY - PM FOR START-UP BURNER #4 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 3:45	231158224	WEEKLY - PM FOR GENERATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 3:46	231158212	WEEKLY - PM FOR LUP OIL PUMP FEED WATER PUMP 3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 3:48	231158210	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 3:49	231160598	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 3:51	231160599	2 WEEKS - PM VISUAL CHECK AND BASIC PDM FOR AGITATOR-DISSOLVING TANK SEE	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 3:53	231158188	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 3:55	231160606	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR #2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 3:57	231160607	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR PRIMARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 4:00	231158209	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR SECONDARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 4:03	231158217	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR TERTIARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 4:06	231160524	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 4:10	231160605	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 4:14	231158211	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 4:19	231158232	3 MONTHS - PM ROUTE RE GREASE MOTOR COOLING TOWER(PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 4:20	231160857	MONTHLY - PM ROUTE REFILL LUBRICANT CHAIN CONVEYOR (GROUP2) (PO)	NPP5A_PP11
MS0103	Automation Service (Instrument)	23/9/2023 4:20	231160849	calibrate 463 Stack flue gas analyzer (ISO14000)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 4:24	231160620	PM FOR RAPID DRAIN DOWNCOMER 463HV152B	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 4:24	231160630	PM FOR STARTUP BLOCK VLV 463HV154	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 4:25	231160631	PM FOR MAIN STEAM VALVE 463HV155	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 4:25	231160632	PM FOR DISC CONT BLOWDOWN 463HV158	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 4:26	231160633	PM FOR STEAM VLV BYPASS 463HV171	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 4:26	231160634	MONTHLY - PM FOR RECOVERY TRANSFORMER TH411(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 4:27	231160636	MONTHLY - PM FOR EVAPORATION TRANSFORMER TH401(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 4:28	231160637	MONTHLY - PM FOR TURBO GEN. Transformer TD11 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 4:29	231160638	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 4:35	231160639	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 4:37	231160640	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 4:40	231160621	WEEKLY - PM ROUTE CHECK SWITCHGEAR (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 4:41	231160642	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR STEAM TURBINE,32900KW (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 22:00	231160643	2 WEEKS - INSPECTION DOSING PUMP	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 22:01	231160644	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 22:03	231160645	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 22:06	231160646	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 22:09	231160647	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR CONTROL OIL PUMP #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 22:11	231160648	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR CONTROL OIL PUMP # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 22:14	231160649	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR LUBE OIL PUMP #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/9/2023 22:17	231160650	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR LUBE OIL PUMP # 2 (PO)	NPP5A_PP11

WL1320	PP5,6,10,11 OPERATION	25/9/2023 2:11	231160651	MONTHLY - INSPECTION AGITATOR	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	25/9/2023 2:15	231160622	MONTHLY - PM ROUTE CHECK MOTOR RAPPER ESP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	25/9/2023 2:16	231160652	MONTHLY - PM ROUTE REFILL LUBRICANT CHAIN CONVEYOR (GROUP3) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	25/9/2023 2:16	231160653	MONTHLY - PM ROUTE REFILL OIL FAN COOLING TOWER (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	25/9/2023 2:16	231160654	MONTHLY CLEANING AIR SUPPLY FILTER 452JB04	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	25/9/2023 2:17	231160655	MONTHLY CLEANING AIR SUPPLY FILTER 452JB06	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	25/9/2023 2:18	231160656	MONTHLY CLEANING AIR SUPPLY FILTER 452JB07	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	25/9/2023 2:18	231160657	MONTHLY CLEANING AIR SUPPLY FILTER 452JB09	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	25/9/2023 2:19	231160768	MONTHLY CLEANING AIR SUPPLY FILTER 463AD20	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	25/9/2023 2:20	231160783	MONTHLY CLEANING AIR SUPPLY FILTER 463AD21	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	25/9/2023 2:20	231160791	MONTHLY CLEANING AIR SUPPLY FILTER 463AD22	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	25/9/2023 2:21	231160801	MONTHLY CLEANING AIR SUPPLY FILTER 463AD23	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	25/9/2023 2:22	231160810	MONTHLY CLEANING AIR SUPPLY FILTER 463AD25A	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	25/9/2023 2:22	231160818	MONTHLY CLEANING AIR SUPPLY FILTER 463AD25B	NPP5A_PP11
MS0103	Automation Service (Instrument)	25/9/2023 2:23	231160830	2 weeks check 463 Stack flue gas analyzer	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	25/9/2023 2:27	231160658	PM FOR FEEDWTR BLOCK VLAVE 463HV150	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	25/9/2023 2:28	231160839	PM FOR RAPID DRAIN GENBANK 463HV151B	NPP5A_PP11
MS0103	Automation Service (Control)	25/9/2023 2:29	231160660	2 WEEKS - PM FOR PLC TURBINE & GENERATOR GOVERNOR CONTROL (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/9/2023 2:33	231160661	2 WEEKS - PM FOR HMI TURBINE & GENERATOR GOVERNOR CONTROL (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/9/2023 2:33	231160662	2 WEEKS - PM FOR HMI RODDING MASTER (463CP60) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/9/2023 2:33	231160623	2 WEEKS - PM FOR HMI RODDING MASTER (463CP61) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/9/2023 2:34	231160664	2 WEEKS - PM FOR HMI BMS (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/9/2023 2:34	231160667	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #1 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/9/2023 2:34	231160670	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #2 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/9/2023 2:34	231160674	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #3 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/9/2023 2:35	231160680	2 WEEKS - PM FOR PLC RODDING MASTER (463CP60) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/9/2023 2:35	231160691	2 WEEKS - PM FOR PLC RODDING MASTER (463CP61) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/9/2023 2:36	231160697	2 WEEKS - PM FOR PLC BMS (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/9/2023 2:37	231160704	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #1 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/9/2023 2:38	231160712	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #2 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/9/2023 2:39	231160724	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #3 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:28	231160625	MONTHLY - PM FOR RECOVERY BOILER OS2101 (OSS01) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:29	231160738	MONTHLY - PM FOR RECOVERY BOILER OS2102 (OSS02) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:30	231160749	MONTHLY - PM FOR MILL WIDE OS2103 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:31	231160758	MONTHLY - PM FOR MILL WIDE OS2104 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:31	231160626	MONTHLY - PM FOR EVAPORATOR OS2105 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:32	231160627	MONTHLY - PM FOR EVAPORATOR OS2106 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:33	231160628	MONTHLY - PM FOR UPS A FOR DCS BOILER PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:34	231160629	MONTHLY - PM FOR UPS B FOR DCS BOILER PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:34	231160604	MONTHLY - PM FOR UPS FOR INSTRUMENT RECOVERY BOILER (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:34	231160608	MONTHLY - PM FOR UPS A FOR DCS TURBINE PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:35	2023111780	MONTHLY - PM FOR UPS B FOR DCS TURBINE PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:35	2023111788	MONTHLY - PM FOR UPS A FOR DCS EVAP PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:35	231158228	MONTHLY - PM FOR UPS B FOR DCS EVAP PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:36	231158235	MONTHLY - PM FOR UPS 01 FOR DCS CONTROL ROOM PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:36	231158234	MONTHLY - PM FOR BATTERY FOR 463UPS-A DCS BOILER PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:37	231158214	MONTHLY - PM FOR BATTERY FOR 463UPS-B DCS BOILER PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:37	231158215	MONTHLY - PM FOR BATTERY FOR 463UPS-C INSTRUMENT PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:38	231158230	MONTHLY - PM FOR BATTERY FOR 293UPS-A DCS TURBINE PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:38	231158219	MONTHLY - PM FOR BATTERY FOR 293UPS-B DCS TURBINE PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:39	231154836	MONTHLY - PM FOR BATTERY FOR 452UPS-A DCS EVAP PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:39	231163151	MONTHLY - PM FOR BATTERY FOR 452UPS-B DCS EVAP PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	26/9/2023 1:40	231163152	MONTHLY - PM FOR BATTERY FOR 463UPS-CR01 DCS CONTROL ROOM PP11 (A)	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	26/9/2023 1:41	231174464	PM.Check motor area 282	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	26/9/2023 1:41	231174465	PM.Check motor area 463	NPP5A_PP11
MS0024	Predictive Maintenance	26/9/2023 1:42	231174466	Monthly vibration check for Plan 262	NPP5A_PP11
MS0024	Predictive Maintenance	26/9/2023 1:42	231174467	Monthly vibration check for Plan 282	NPP5A_PP11
MS0024	Predictive Maintenance	26/9/2023 1:43	231174468	Monthly vibration check for Plan 293	NPP5A_PP11
MS0024	Predictive Maintenance	26/9/2023 1:44	231174469	Monthly vibration check for Plan 452	NPP5A_PP11
MS0024	Predictive Maintenance	26/9/2023 1:46	231174470	Monthly vibration check for Plan 463	NPP5A_PP11
MS0024	Predictive Maintenance	26/9/2023 1:48	231174471	Monthly oil Sampling for area 463	NPP5A_PP11
MS0024	Predictive Maintenance	26/9/2023 1:49	231174472	Monthly oil Sampling for area 293	NPP5A_PP11
MS0104	Automation Service (Control)	28/9/2023 13:56	231174473	monthly inspection Evaporation DCS Controller (A)	NPP5A_PP11
MS0104	Automation Service (Control)	28/9/2023 14:00	231163149	monthly inspection Mill Wide DCS Controller (A)	NPP5A_PP11
MS0104	Automation Service (Control)	28/9/2023 14:03	2023104947	monthly inspection Soot Blower DCS Controller (A)	NPP5A_PP11
MS0103	Maintenance Central Management	28/9/2023 14:08	231163150	monthly inspection RecoveryBoiler DCS Controller (A)	NPP5A_PP11
MS0103	Maintenance Central Management	28/9/2023 14:12	231182832	monthly inspection for R.B. DCS Power Distrib. (A)	NPP5A_PP11
MS0103	Maintenance Central Management	28/9/2023 14:13	231182895	monthly inspection for Evapor DCS Power Distrib. (A)	NPP5A_PP11
MS0103	Maintenance Central Management	28/9/2023 14:14	231182902	monthly inspection for MillWideDCS Power Distrib. (A)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	30/9/2023 5:59	231182889	WEEKLY - INSPECTION CAMERA	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:01	231182847	MONTHLY - PM FOR CONDUCTIVITY INDICATION OF FEED WATER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:02	231182870	MONTHLY - PM FOR CONDUCTIVITY INDICATION OF DEMIN WATER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:04	231182859	MONTHLY - PM FOR CONDUCTIVITY INDICATION AFTER ANION EXCHANGER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:05	231177976	MONTHLY - PM FOR CONDUCTIVITY INDICATION AFTER MIXED BED EXCHANGER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:06	231177975	MONTHLY - PM FOR CONDUCTIVITY INDICATION AFTER ANION EXCHANGER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:07	231163154	MONTHLY - PM FOR CONDUCTIVITY INDICATION AFTER MIXED BED EXCHANGER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:08	2023111667	MONTHLY - PM FOR CONDUCT. SUM (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:10	231182811	MONTHLY - PM FOR CONDUCTIVITY SUMP PIT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:11	231177967	MONTHLY - PM FOR condensate from fibre line (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:12	231177969	MONTHLY - PM FOR COND FRM EVAP PLANT (A)	NPP5A_PP11

WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:13	231177970	MONTHLY - PM FOR COND FROM TURBINE (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:15	231177973	MONTHLY - PM FOR COND FROM PULP DRYER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:16	231174481	WEEKLY - PM FOR GENERATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:17	231174476	WEEKLY - PM FOR LUP OIL PUMP FEED WATER PUMP 3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:19	231158170	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:20	231174480	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:22	231174478	MONTHLY- PM FOR BATTERY CHARGER 110 VDC FOR 22KV SYSTEM (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:23	231174477	2 WEEKS - PM VISUAL CHECK AND BASIC PDM FOR AGITATOR-DISSOLVING TANK SEE NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:26	231158171	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR # 1 (PO NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:27	231174479	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR #2 (PO) NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:29	2023105048	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR PRIMARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:33	231174483	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR SECONDARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:36	2023142572	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR TERTIARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:40	2023142573	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:44	231152143	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:49	231160876	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:54	2023147536	MONTHLY - PM FOR FIRE FIGHTING MILL WIDE (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:55	2023147537	MONTHLY - PM FOR CO2 FIRE ALARM & FIRE FIGHTING OF TURBINE (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 6:55	231150171	MONTHLY - PM FOR FIRE FIGHTING EVAPORATION (E)	NPP5A_PP11
MS0103	Automation Service (Intrument)	30/9/2023 6:56	231159925	calibrate 463 Stack flue gas analyzer (ISO14000)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 7:00	2023141133	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 7:07	2023141134	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 7:09	231152122	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 7:12	231160492	WEEKLY - PM ROUTE CHECK SWITCHGEAR (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 7:14	2023141395	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR STEAM TURBINE,32900KW (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 7:17	2023141397	MONTHLY - PM FOR SOOTBLOWER 1, LEFT (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 7:17	231152124	MONTHLY - PM FOR SOOTBLOWER 2, LEFT (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 22:00	231160496	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 22:02	2023141436	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 22:05	2023141437	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 22:09	231152125	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR CONTROL OIL PUMP #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 22:11	231160499	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR CONTROL OIL PUMP # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 22:14	2023141345	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR LUBE OIL PUMP #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	30/9/2023 22:17	2023141346	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR LUBE OIL PUMP # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	1/10/2023 23:39	231152123	2 MONTHS - PM FOR SEALING AIR FAN # 1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	1/10/2023 23:41	231160494	2 MONTHS - PM FOR SEALING AIR FAN # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	1/10/2023 23:48	2023142072	2 MONTHS - PM FOR FIRING LIQ TNK AGITATOR #1(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	1/10/2023 23:50	2023142073	2 MONTHS - PM FOR FIRING LIQ TNK AGITATOR #2(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	1/10/2023 23:51	231152134	2 MONTHS - PM FOR TURNING MOTOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	1/10/2023 23:53	231160582	2 MONTHS - PM FOR GLAND CONDENSER FAN (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	1/10/2023 23:55	2023142458	2 MONTHS - PM FOR VAPOR FAN (E)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	1/10/2023 23:57	2023142420	2 WEEKS - PM FOR 115 KV SUBSTATION AAP2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:47	2023142228	MONTHLY - PM FOR COOLING WATER PUMP NO.2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:47	2023142267	MONTHLY - PM FOR PRIMARY FD FAN (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:48	2023142305	MONTHLY - PM FOR SECONDARY FD FANN (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:48	2023141801	MONTHLY - PM FOR TERTIARY FD FAN (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:48	2023141802	MONTHLY - PM FOR ID FAN # 1 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:49	231152128	MONTHLY - PM FOR ID FAN # 2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:49	231160530	MONTHLY - PM FOR ID FAN #3 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:49	2023141840	MONTHLY - PM FOR FW PUMP #2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:49	2023141841	MONTHLY - PM FOR AIR COMPRESSOR NO.1 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:50	231152129	MONTHLY - PM FOR AIR COMPRESSOR NO.2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:50	231160533	MONTHLY - PM FOR AIR COMPRESSOR NO.3 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:50	2023142382	MONTHLY - PM FOR AIR COMPRESSOR NO.4 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:50	2023142383	MONTHLY - PM FOR FW PUMP #3 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:51	231152141	MONTHLY - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:51	231152142	MONTHLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:51	231160614	MONTHLY - PM FOR WARM WATER PUMP (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:51	231160616	MONTHLY - PM FOR COOLING WATER PUMP NO.1 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:52	231174496	MONTHLY - PM FOR COOLING WATER PUMP NO.3 (E)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	4/10/2023 23:52	231174500	MONTHLY - PM FOR 115 KV SUBSTATION AAP2 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:53	2023142190	MONTHLY - PM FOR RECOVERY TRANSFORMER TE21(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:53	2023142191	MONTHLY - PM FOR TRANSFORMER TL412(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:54	231152140	MONTHLY - PM FOR TRANSFORMER TH412(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:54	231160600	MONTHLY - PM FOR TRANSFORMER TE22(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:54	2023142034	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH211(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:54	2023142035	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH212(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:55	231152133	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH291(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:55	231160577	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH293(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:55	2023142111	MONTHLY - PM FOR TL293E POWER BACK UP FROM EGAT (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:55	2023142112	MONTHLY - PM FOR AAP2 , TURBO GENERATOR TRANSFMR TD12 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:55	231152136	MONTHLY - PM FOR GROUNDING TRANSFORMER (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:56	231160586	MONTHLY - PM FOR RECOVERY TRANSFORMER TH411(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:56	2023142534	MONTHLY - PM FOR EVAPORATION TRANSFORMER TH401(E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:56	2023142496	MONTHLY - PM FOR TURBO GEN. Transformer TD11 (E)	NPP5A_PP11
WL5114	Electrical PP6,10,11	4/10/2023 23:56	2023141917	MONTHLY - PM FOR EGAT OUT GOING TRANSFORMER TC3 (E)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	6/10/2023 12:57	2023141918	WEEKLY - INSPECTION CAMERA	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	6/10/2023 22:00	231152130	YEARLY (SD) - PM FOR AHU EE ROOM EVAPORATOR (E)	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	6/10/2023 22:00	231160563	YEARLY (SD) - PM FOR AHU RECOVERY BOILER EE ROOM (E)	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	6/10/2023 22:01	2023141956	YEARLY (SD) - PM FOR AHU EE ROOM MILL WIDE (E)	NPP5A_PP11

WL5215	Electrical PSD (SWG/Substation/Transf	6/10/2023 22:02	2023141957	YEARLY (SD) - PM FOR GENERATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	8/10/2023 5:27	231152131	WEEKLY - PM FOR GENERATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	8/10/2023 5:29	231160567	WEEKLY - PM FOR LUP OIL PUMP FEED WATER PUMP 3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	8/10/2023 5:31	2023112026	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	8/10/2023 5:32	2023120207	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	8/10/2023 5:34	231152144	2 WEEKS - PM VISUAL CHECK AND BASIC PDM FOR AGITATOR-DISSOLVING TANK SEE NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	8/10/2023 5:38	231160883	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR # 1 (PO NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	8/10/2023 5:40	2023141995	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR #2 (PO) NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	8/10/2023 5:42	2023141996	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR PRIMARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	8/10/2023 5:46	231152132	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR SECONDARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	8/10/2023 5:50	231160572	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR TERTIARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	8/10/2023 5:54	231174458	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	8/10/2023 5:59	231185619	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	8/10/2023 6:04	231163158	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN #3 (PO)	NPP5A_PP11
MS0103	Automation Service (Instrument)	8/10/2023 6:09	231163178	2 weeks check 463 Stack flue gas analyzer	NPP5A_PP11
MS0103	Automation Service (Instrument)	8/10/2023 6:13	231163156	calibrate 463 Stack flue gas analyzer (ISO14000)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	8/10/2023 6:18	231163179	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	8/10/2023 6:24	231163173	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	8/10/2023 6:27	231163174	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	8/10/2023 6:30	231163175	WEEKLY - PM ROUTE CHECK SWITCHGEAR (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	8/10/2023 6:32	231163176	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR STEAM TURBINE,32900KW (PO)	NPP5A_PP11
MS0103	Automation Service (Control)	8/10/2023 6:35	231163160	2 WEEKS - PM FOR PLC TURBINE & GENERATOR GOVERNOR CONTROL (A)	NPP5A_PP11
MS0103	Automation Service (Control)	8/10/2023 6:41	231163155	2 WEEKS - PM FOR HMI TURBINE & GENERATOR GOVERNOR CONTROL (A)	NPP5A_PP11
MS0103	Automation Service (Control)	8/10/2023 6:41	231163164	2 WEEKS - PM FOR HMI RODDING MASTER (463CP60) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	8/10/2023 6:41	231163167	2 WEEKS - PM FOR HMI RODDING MASTER (463CP61) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	8/10/2023 6:42	231163165	2 WEEKS - PM FOR HMI BMS (A)	NPP5A_PP11
MS0103	Automation Service (Control)	8/10/2023 6:42	231163168	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #1 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	8/10/2023 6:42	231163166	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #2 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	8/10/2023 6:43	231163169	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #3 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	8/10/2023 6:43	231163170	2 WEEKS - PM FOR PLC RODDING MASTER (463CP60) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	8/10/2023 6:44	231163171	2 WEEKS - PM FOR PLC RODDING MASTER (463CP61) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	8/10/2023 6:45	231163172	2 WEEKS - PM FOR PLC BMS (A)	NPP5A_PP11
MS0103	Automation Service (Control)	8/10/2023 6:46	231163177	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #1 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	8/10/2023 6:47	231163163	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #2 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	8/10/2023 6:48	231163162	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #3 (A)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:49	231163161	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR SPARE FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:49	231163157	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR SPARE FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:49	231208229	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR TH432/TH433 Feeder (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:49	231208231	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR TH434/TH435 Feeder (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:50	231229661	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR TH402 Feeder (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:50	231229663	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR TL491 Feeder (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:50	231229672	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR TE21/TH411 Feeder (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:50	231243102	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR TH421 Feeder (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:50	231208263	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR TH401 Feeder (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:51	231208261	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR TH211 Feeder (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:51	231208262	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR TL293 Feeder (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:51	231208266	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR Emergency Feeder (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:51	231243096	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR TO NAC1.03 Bus (Spare)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:52	231251324	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR TH212/TL212 Feeder (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:52	231243099	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR TH212 Feeder (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:52	231251337	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR SPARE FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:52	231229648	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR Pulp drying Feeder (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:53	231229652	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR Spare Feeder(Now use)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:53	231229670	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR NPS Feeder (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:53	231229674	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR OUT GOING TO EGAT F	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:53	231218495	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR GROUNDING TRANSFOI	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:53	231259741	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR TO 294AC3.1 FEEDER T	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:54	231208269	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR DOUBLE CB 294AC1.16	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:54	231229768	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR INCOMING FROM Gen F	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:54	231251550	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR OUT GOING POWER BA	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:54	231197235	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR TO 294AC2.3 FEEDER T	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:55	231220003	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR TE22/TH411 FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:55	231240443	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWN FOR SPARE FEEDER (Now us	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	8/10/2023 6:55	231260410	YEARLY (SD) - PM FOR POWER CABLE AFTER SHUTDOWNFOR TO 294AC1.14 FEEDER (NPP5A_PP11
MS0104	Automation Service (Control)	10/10/2023 0:51	231197237	MONTHLY - PM FOR MILLWIDE DCS CONTROLLER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/10/2023 0:52	231220006	MONTHLY - PM FOR BATTERY FOR 293NU01 CHARGER 110 VDC MILL WIDE BANK#1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/10/2023 0:53	231240444	MONTHLY - PM FOR BATTERY FOR 293NU01 CHARGER 110 VDC MILL WIDE BANK#2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/10/2023 0:53	231260412	MONTHLY - PM FOR BATTERY 110 VDC FOR Communication 115 kv (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/10/2023 0:54	231197233	MONTHLY - PM FOR BATTERY FOR 294BTN01 CHARGER 48VDC FOR 115KV NPP11 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/10/2023 0:54	231220000	MONTHLY - PM FOR BATTERY FOR 463UPS01 MCC RECOVERY BOILER, UPS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/10/2023 0:55	231240442	MONTHLY - PM FOR BATTERY FOR 294NU01 CHARGER 110 VDC FOR 22KV SYSTEM (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/10/2023 0:56	231260409	MONTHLY - PM FOR BATTERY FOR 293UPS01 MCC MILL WIDE, UPS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/10/2023 0:56	231197229	MONTHLY - PM FOR CHARGER 110 VDC FOR Communication 115 kv (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/10/2023 0:57	231219999	MONTHLY - PM FOR CHARGER 48VDC FOR 115KV NPP11 (E)	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	10/10/2023 0:57	231240441	PM.Check motor area 282	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	10/10/2023 0:58	231260408	PM.Check motor area 463	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/10/2023 0:58	231197224	MONTHLY - ROUTE PM FOR INSPECTION FABRIC EXPANSION JOINT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	10/10/2023 1:01	231219992	MONTHLY - PM REFILL LUBRICANT FOR AGITATOR STRONG LIQUOR STORAGE TANK (NPP5A_PP11
MS0103	Automation Service (Control)	10/10/2023 1:01	231240439	YEARLY (SD) - PM FOR RECOVERY BOILER OS2101 (OS501) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	10/10/2023 1:02	231260406	YEARLY (SD) - PM FOR RECOVERY BOILER OS2102 (OS502) (A)	NPP5A_PP11

MS0103	Automation Service (Control)	10/10/2023 1:02	231197226	YEARLY (SD) - PM FOR MILL WIDE OS2103 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	10/10/2023 1:03	231219997	YEARLY (SD) - PM FOR MILL WIDE OS2104 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	10/10/2023 1:03	231240440	YEARLY (SD) - PM FOR EVAPORATOR OS2105 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	10/10/2023 1:04	231260407	YEARLY (SD) - PM FOR EVAPORATOR OS2106 (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 2:30	231197223	MONTHLY - PM FOR START-UP BURNER #5 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 2:31	231219990	MONTHLY - PM FOR START-UP BURNER #6 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 2:31	231240438	MONTHLY - PM FOR ELECTROSTATIC PRECIPITATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 2:34	231260405	MONTHLY - PM FOR ELECTROSTATIC PRECIPITATOR # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 2:36	231197258	MONTHLY - PM FOR ESP #3(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 2:38	231220024	2 MONTHS - PM FOR SCANNER/IGNITOR AIR FAN # 1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 2:40	231240448	2 MONTHS - PM FOR SCRUBBER FAN (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 2:42	231260420	2 MONTHS - PM FOR HVLC GAS FAN (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 2:44	231197264	MONTHLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 2:44	231220027	MONTHLY - PM FOR RECOVERY TRANSFORMER TE21(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 2:46	231240449	MONTHLY - PM FOR TRANSFORMER TL412(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 2:47	231260422	MONTHLY - PM FOR TRANSFORMER TH412(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 2:48	231197270	MONTHLY - PM FOR RECTIFIER # A, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 2:49	231220035	MONTHLY - PM FOR RECTIFIER # B, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 2:51	231240450	MONTHLY - PM FOR RECTIFIER # C, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 2:52	231260423	MONTHLY - PM FOR RECTIFIER # A, PRECIPITATOR # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 2:53	231197253	MONTHLY - PM FOR RECTIFIER # B, PRECIPITATOR # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 2:55	231220018	MONTHLY - PM FOR RECTIFIER # C, PRECIPITATOR # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 2:56	231240447	MONTHLY - PM FOR RECTIFIER #A, PRECIPITATOR # 3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 2:57	231260417	MONTHLY - PM FOR RECTIFIER #B, PRECIPITATOR #3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 2:59	231197238	MONTHLY - PM FOR RECTIFIER #C, PRECIPITATOR #3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:00	231220007	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH211(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:01	231240445	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH212(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:02	231260413	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH291(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:04	231197246	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH293(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:05	231220013	MONTHLY - PM FOR TL293E POWER BACK UP FROM EGAT (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:06	231240446	MONTHLY - PM FOR AAP2 , TURBO GENERATOR TRANSFMR TD12 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:08	231260415	MONTHLY - PM FOR GROUNDING TRANSFORMER (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:09	231197203	MONTHLY - INSPECTION PUMP	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:18	231219961	MONTHLY - PM ROUTE REFILL LUBRICANT BEARING FAN FOR IDFAN(GROUP2) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:18	231240435	MONTHLY - PM ROUTE REFILL LUBRICANT BEARING FAN FOR IDFAN(GROUP3) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:19	231260401	PM FOR FEEDWTR BY-PASS VLV 463HV172	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:20	231207791	PM FOR SOOTBLWR STEAM HDR 463HV181	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:20	231233053	MONTHLY - PM FOR AL21 BUS 6.6KV FEED WATER PUMP P003 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:22	231250129	MONTHLY - PM FOR AL22 SWG 6.6KV FEED WATER PUMP P050 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:23	231195391	MONTHLY - PM FOR EGAT OUT GOING TRANSFORMER TC3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:25	231207038	MONTHLY - PM FOR VSD OF FIRING LIQUOR PUMP #1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:25	231217763	MONTHLY - PM FOR VSD OF FIRING LIQUOR PUMP #2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:26	231229677	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:29	231239409	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:32	231248330	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR ACID DOSING PUMP #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:35	231260264	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR ACID DOSING PUMP #2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:38	231197181	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR EMERGENCY OIL PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:42	231219943	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR GLAND COND DRAIN PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:45	231240431	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 A PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:48	231260349	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 B PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:51	231260327	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 C PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:54	231043519	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 D PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 3:58	231043099	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 A PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 4:01	231043100	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 B PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 4:04	231043101	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 C PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 4:07	231043102	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 D PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 4:10	231043096	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 2 PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 4:14	231043097	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR EFFECT II-I LIQ .TRANSF PUMP (F)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 4:17	231043098	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR EFFECT III CIRCULATE PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 4:21	231043103	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR EFFECT III-II LIQ TRANSF PUMP (NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 4:24	231043530	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR EFFECT IV CIRCULATE PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 4:27	231043531	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR EFFECT V CIRCULATE PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 4:30	231062185	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR PRIMARY CONDENSATE PUMP (PC)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 4:33	231043095	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FOUL CONDENSATE PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 4:36	231043087	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SEC. CONDENSATE II PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 4:39	231043093	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FOUL COND. VAC. PIT DWG (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 4:43	231043091	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR VACUUM PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 4:46	231043092	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR VACUUM PUMP (STAND-BY) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 4:49	231043088	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR REFLUX CONDENSATE (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 4:52	231043094	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR WASH LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 4:55	231043090	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR COMBINED CONDENSATE (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 4:58	231197159	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FEED LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 5:02	231197162	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQ FLASH TNK PUMP#1 (NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 5:05	231197164	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQ FLASH TNK PUMP#1 (NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 5:08	231197168	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR DESUPERHEATER PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 5:11	231197172	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR STRONG LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 5:14	231243139	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR STRONG LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 5:17	231243144	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR WARM WATER PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 5:20	231243148	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SECONDARY CONDENSATE PUMP	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 5:24	231243151	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SUMP PUMP (PO)	NPP5A_PP11

WL1320	PP5,6,10,11 OPERATION	12/10/2023 5:27	231243160	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR STRONG LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 5:30	231197148	MONTHLY - PM FOR BMS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 5:31	231243124	MONTHLY - PM FOR BOX MAIN SUPPLY BURNER (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 5:32	231243121	MONTHLY - PM FOR AH411 MCC 690V RECOVERY BOILER #2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 5:33	231243128	MONTHLY - PM FOR AH412 MCC 690V RECOVERY BOILER #2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 5:34	231197153	MONTHLY - PM FOR AL412 MCC 400V ESP#3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 5:37	231197157	MONTHLY - PM FOR AH401 MCC 690V EVAPORATOR PULP 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 5:38	231243130	MONTHLY - PM FOR AH211 MCC. 690V MILL WIDE #1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 5:39	231243135	MONTHLY - PM FOR AH212 MCC. 690V MILL WIDE #2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 5:41	231043111	MONTHLY - PM FOR AL291 EMERGENCY POWER SUPPLY 400 VAC (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/10/2023 5:42	231043104	MONTHLY - PM FOR AL293 NORMAL POWER SUPPLY 400 VAC (E)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	13/10/2023 7:58	231043109	WEEKLY - INSPECTION CAMERA	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	13/10/2023 8:00	231043107	MONTHLY - PM FOR SCRUBBER FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	13/10/2023 8:05	231043108	MONTHLY - PM FOR FIRE FIGHTING SWITCH GEAR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	13/10/2023 8:05	231043105	3 MONTHS - PM ROUTE RE GREASE MOTOR AREA 463 GROUP 2(PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 2:44	231043110	WEEKLY - PM FOR GENERATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 2:46	231043106	WEEKLY - PM FOR LUP OIL PUMP FEED WATER PUMP 3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 2:50	231217751	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 2:53	231217750	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 2:56	231217746	MONTHLY - PM FOR BATTERY CHARGER 110 VDC MILL WIDE (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 2:57	231217747	MONTHLY - PM FOR MCC MILL WIDE, UPS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 2:57	231217752	MONTHLY - PM FOR BATTERY CHARGER 110 VDC MILL WIDE (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 2:58	231217753	MONTHLY - PM FOR MCC MILL WIDE, UPS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 2:59	231217748	2 WEEKS - PM VISUAL CHECK AND BASIC PDM FOR AGITATOR-DISSOLVING TANK SEE NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 3:04	231217742	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR ASH COLLECTING CONVEYOR (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 3:07	231217743	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR DRAG SCRAPER, ESP # 1 SEE LON NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 3:10	231217744	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR DRAG SCRAPER, ESP # 2 SEE LON NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 3:13	231217745	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR COLLECTING CONVEYOR, ESP # 1 NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 3:16	231195403	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR COLLECTING CONVEYOR, ESP # 2 NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 3:19	231207233	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SCRAPER CONVEYER ESP.3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 3:22	231217893	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR COLLECTING CONVEYER ESP.3 (P)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 3:25	231229738	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 3:28	231239518	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR #2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 3:31	231248411	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 8 FOR AREA 452 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 3:35	231260354	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 9 FOR AREA 452 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 3:37	231233052	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 20 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 3:39	231233048	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 21 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 3:41	231219835	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 22 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 3:44	231262340	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 23 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 3:46	231213470	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 24 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 3:50	231254905	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 25 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 3:52	231213433	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR PRIMARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 3:58	231213463	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR SECONDARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 4:03	231254860	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR TERTIARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 4:10	231254894	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 4:17	231202882	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 4:23	231248318	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 4:30	231235275	MONTHLY - PM ROUTE REFILL LUBRICANT CHAIN CONVEYOR (GROUP1) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 4:30	231202880	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP A (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 4:31	231248307	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP B (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 4:33	231203473	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP C (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 4:33	231249594	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP D (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 4:34	231203478	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP E (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 4:35	231249596	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP F (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 4:36	231203469	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP G (PO)	NPP5A_PP11
MS0103	Automation Service (Instrument)	14/10/2023 4:37	231249593	calibrate 463 Stack flue gas analyzer (ISO14000)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 4:42	231203455	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 4:46	231249581	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 4:52	231203459	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 5:01	231249584	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR DUMP TANK PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 5:05	231208235	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SPILL COLLECTION PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 5:08	231251352	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SCRUBBER RECIRCULATION PUMI	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 5:12	231208242	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR GREEN LIQ TRANSFER PUMP #1 (NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 5:15	231251403	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR GREEN LIQ TRANSFER PUMP #2 (NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 5:18	231208236	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SPOUT COOLING WATER PUMP # NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 5:22	231251365	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SPOUT COOLING WATER PUMP # NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 5:25	231208244	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 5:28	231251427	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CONDENSATE FEED PUMP#A (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 5:32	231208237	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CONDENSATE FEED PUMP#B (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 5:35	231251380	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 5:38	231208250	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 5:42	231251458	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CONDENSATE PUMP NO. 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 5:45	231208239	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CONDENSATE PUMP NO. 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 5:49	231251388	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 1, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 5:52	231208253	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 2, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 5:54	231251480	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 3, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 5:57	231202892	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 4, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 6:00	231248418	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 5, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 6:03	231202893	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 6, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 6:06	231248420	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 7, RIGHT (PO)	NPP5A_PP11

WL1320	PP5,6,10,11 OPERATION	14/10/2023 6:09	231203485	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 8, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 6:12	231249597	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 9, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 6:15	231203488	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 10, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 6:18	231249599	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 11, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 6:22	231203462	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 12, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 6:25	231249586	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 13, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 6:28	231199179	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 14, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 6:31	231243110	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 15, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 6:34	231207033	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 16, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 6:37	231207035	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 17, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 6:40	231248311	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 18, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 6:44	231248313	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 19, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 6:47	231199177	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 20, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 6:50	231243106	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 21, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 6:53	231199178	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 22, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 6:56	231243108	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 23, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 7:00	231199183	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 24, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 7:03	231243116	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 25, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 7:06	231223105	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 26, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 7:10	231262333	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 27, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 7:13	231223110	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 28, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 7:16	231262334	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 29, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 7:19	231199180	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 30, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 7:21	231243111	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 31, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 7:24	231199182	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 32, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 7:27	231243115	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 33, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 7:30	231223119	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 34, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 7:33	231262336	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 35, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 7:36	231223126	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 36, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 7:39	231262337	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 37, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 7:41	231199181	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 38, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 7:44	231243113	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 39, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 7:47	231223096	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 40, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 7:50	231262330	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 41, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 7:53	231223098	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 42, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 7:56	231262331	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 43, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 7:59	231223102	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 44 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 8:02	231262332	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 45, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 8:05	231223131	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 46, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 8:08	231262338	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 47, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 8:12	231213506	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 48, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 8:15	231254928	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 49, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 8:18	231213476	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 50, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 8:22	231213489	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 51, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 8:25	231213497	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 52, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 8:28	231254909	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 353, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 8:31	231254917	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 354, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 8:34	231254924	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 355, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 8:37	231203449	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 356, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 8:40	231249577	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 357, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 8:43	231203450	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 358, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 8:47	231249579	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 359, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 8:50	231199184	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 360, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 8:53	231243118	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER #61 LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 8:56	231199185	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER # 62 RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 9:00	231243120	WEEKLY - PM ROUTE CHECK SWITCHGEAR (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 9:02	231229717	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR STEAM TURBINE,32900KW (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	14/10/2023 9:07	231229638	MONTHLY - PM FOR SCRUBBER FAN (E)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	16/10/2023 6:12	231229641	3 MONTHS - PM FOR CONTAM CODENS. (A)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	16/10/2023 6:13	231229640	3 MONTHS - PM FOR PRIM. CONDENS. (A)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	16/10/2023 6:15	231229637	3 MONTHS - PM FOR SECOND CONDENS (A)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	16/10/2023 6:16	231229634	3 MONTHS - PM FOR FOUL. CONDENS. (A)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	16/10/2023 6:18	231229627	3 MONTHS - PM FOR SECOND. CODENS. (A)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	16/10/2023 6:19	231229632	3 MONTHS - PM FOR BOILER WRT CONDUCTIVITY (A)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	16/10/2023 6:21	231229630	3 MONTHS - PM FOR COOLLING WATER TO SPOUT #1 LOW (A)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	16/10/2023 6:22	231229633	3 MONTHS - PM FOR COOLING WATER TO CONDENSATE CONDUCT (A)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	16/10/2023 6:24	231229626	3 MONTHS - PM FOR CONDENSATE CONDUCT (A)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	16/10/2023 6:25	231229624	3 MONTHS - PM FOR CONDENSATE FROM PAPER MACHINE (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/10/2023 6:27	231229635	2 MONTHS - PM FOR SCANNER/IGNITOR AIR FAN # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/10/2023 6:29	231202894	2 MONTHS - PM FOR SCRUBBER FAN (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/10/2023 6:31	231248423	MONTHLY - PM FOR AIR COMPRESSOR NO.1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/10/2023 6:33	231202857	MONTHLY - PM FOR AIR COMPRESSOR NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/10/2023 6:35	231248242	MONTHLY - PM FOR AIR COMPRESSOR NO.3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/10/2023 6:37	231202856	MONTHLY - PM FOR AIR COMPRESSOR NO.4 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/10/2023 6:39	231248239	MONTHLY - PM FOR MCC RECOVERY BOILER, UPS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/10/2023 6:40	231202858	MONTHLY - PM REFILL LUBRICANT FOR AGITATOR-DISSOLVING TANK SEE LONG DISC	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/10/2023 6:40	231248245	MONTHLY - PM REFILL LUBRICANT FOR AGITATOR-DISSOLVING TANK SEE LONG DISC	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/10/2023 6:40	231217928	MONTHLY - PM FOR AIR COMPRESSOR NO.1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/10/2023 6:46	231260378	MONTHLY - PM FOR AIR COMPRESSOR NO.2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/10/2023 6:51	231223056	MONTHLY - PM FOR AIR COMPRESSOR NO.3 (PO)	NPP5A_PP11

WL1320	PP5,6,10,11 OPERATION	16/10/2023 6:56	231262319	MONTHLY - PM FOR AIR COMPRESSOR NO.4 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/10/2023 7:02	231223066	3 MONTHS - PM ROUTE RE GREASE MOTOR AREA 282&293(PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/10/2023 7:03	231262320	MONTHLY - PM ROUTE REFILL LUBRICANT BEARING FAN FOR IDFAN(GROUP1) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/10/2023 7:03	231229718	MONTHLY CLEANING AIR SUPPLY FILTER 463AD26	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/10/2023 7:04	231229715	MONTHLY CLEANING AIR SUPPLY FILTER 463AD27	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/10/2023 7:05	231213526	MONTHLY CLEANING AIR SUPPLY FILTER 282AS21	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/10/2023 7:06	231254941	MONTHLY CLEANING AIR SUPPLY FILTER 282AS22	NPP5A_PP11
MS0103	Automation Service (Instrument)	16/10/2023 7:07	231207192	Monthly PM Dust meter "Sick"(ISO 14000)	NPP5A_PP11
MS0103	Automation Service (Instrument)	16/10/2023 7:09	231248395	Monthly PM for 463Q1490 DO after Feed water pump	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:09	231202881	YEARLY - PM TEST DGA FOR RECOVERY TRANSFORMER TH411(E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:09	231248309	YEARLY - PM TEST DGA FOR EVAPORATION TRANSFORMER TH401(E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:09	231202859	YEARLY - PM TEST DGA FOR TURBO GEN. Transformer TD11 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	16/10/2023 7:10	231243105	YEARLY - PM FOR EGAT OUT GOING TRANSFORMER TC3 (E)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	16/10/2023 7:10	231207034	2 WEEKS - PM FOR 115 KV SUBSTATION AAP2 (E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:12	231207036	YEARLY - PM TEST DGA FOR RECOVERY TRANSFORMER TE21(E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:12	231248312	YEARLY - PM TEST DGA FOR TRANSFORMER TL412 (E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:12	231248314	YEARLY - PM TEST DGA FOR TRANSFORMER TH412 (E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:12	231208240	YEARLY - PM TEST DGA FOR TRANSFORMER TE22(E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:12	231251398	YEARLY - PM TEST DGA FOR RECTIFIER # A, PRECIPITATOR # 1 (E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:13	231223050	YEARLY - PM TEST DGA FOR RECTIFIER # B, PRECIPITATOR # 1 (E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:13	231262316	YEARLY - PM TEST DGA FOR RECTIFIER # C, PRECIPITATOR # 1 (E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:13	231223053	YEARLY - PM TEST DGA FOR RECTIFIER # A, PRECIPITATOR # 2 (E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:13	231262317	YEARLY - PM TEST DGA FOR RECTIFIER # B, PRECIPITATOR # 2 (E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:13	231202874	YEARLY - PM TEST DGA FOR RECTIFIER # C, PRECIPITATOR # 2 (E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:13	231248295	YEARLY - PM TEST DGA FOR RECTIFIER #A, PRECIPITATOR # 3 (E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:13	231202876	YEARLY - PM TEST DGA FOR RECTIFIER #B, PRECIPITATOR #3 (E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:13	231248297	YEARLY - PM TEST DGA FOR RECTIFIER #C, PRECIPITATOR #3 (E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:13	231202877	YEARLY - PM TEST DGA FOR MILL WIDE TRANSFORMER TH211(E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:14	231248299	YEARLY - PM TEST DGA FOR MILL WIDE TRANSFORMER TH212 (E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:14	231202878	YEARLY - PM TEST DGA FOR MILL WIDE TRANSFORMER TH291 (E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:14	231248303	YEARLY - PM TEST DGA FOR MILL WIDE TRANSFORMER TH293(E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:14	231197146	YEARLY - PM TEST DGA FOR TL293E POWER BACK UP FROM EGAT (E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:14	231241228	YEARLY - PM TEST DGA FOR AAP2 , TURBO GENERATOR TRANSFMR TD12 (E)	NPP5A_PP11
MS0093	Electrical Service (Control)	16/10/2023 7:14	231223039	YEARLY - PM TEST DGA FOR GROUNDING TRANSFORMER (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/10/2023 4:49	231262313	MONTHLY - INSPECTION PH TR	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/10/2023 4:54	231223044	MONTHLY - INSPECTION PH TR	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/10/2023 4:55	231262315	MONTHLY - INSPECTION PH	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/10/2023 4:56	231202860	MONTHLY - PM FOR BL-SPRAYER DIVERT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/10/2023 4:57	231248260	MONTHLY - PM FOR BL-SPRAYER DIVERT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/10/2023 4:59	231217922	MONTHLY - PM FOR BL-SPRAYER DIVERT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/10/2023 5:00	231260375	MONTHLY - PM FOR BL .SPRAYER DIVERT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/10/2023 5:02	231202865	MONTHLY - PM FOR TRANSFORMER TE22(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/10/2023 5:03	231248269	MONTHLY - PM FOR FIRE FIGHTING RECOVERY BOILER (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/10/2023 5:04	231202868	3 MONTHS - PM ROUTE RE GREASE MOTOR AREA 452 GROUP 1(PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/10/2023 5:05	231248278	3 MONTHS - PM ROUTE RE GREASE MOTOR AREA 452 GROUP 2(PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/10/2023 5:07	231202866	3 MONTHS - PM ROUTE RE GREASE MOTOR AREA 452 GROUP 3(PO)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	20/10/2023 2:09	231248271	WEEKLY - INSPECTION CAMERA	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:11	231202869	YEARLY (SD) - PM FOR MCC MILL WIDE, UPS (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 2:12	231248281	YEARLY (SD) - PM FOR BATTERY CHARGER 110 VDC MILL WIDE (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:13	231202867	YEARLY (SD) - PM FOR MCC MILL WIDE, UPS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	20/10/2023 2:14	231248276	3 MONTHS - PM ROUTE RE GREASE MOTOR AREA 242&282(PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	20/10/2023 2:15	231202870	3 MONTHS - PM ROUTE RE GREASE MOTOR AREA 452 GROUP 4(PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	20/10/2023 2:17	231248283	3 MONTHS - PM ROUTE RE GREASE MOTOR AREA 463 GROUP 1(PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	20/10/2023 2:18	231202871	3 MONTHS - PM ROUTE RE GREASE MOTOR AREA 463 GROUP 3(PO)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:20	231248286	YEARLY (SD) - PM FOR BL SPRAYER DIVERT (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:20	231202872	YEARLY (SD) - PM FOR BL SPRAYER DIVERT (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:20	231248291	YEARLY (SD) - PM FOR BL-SPRAYER DIVERT (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:20	231202873	YEARLY (SD) - PM FOR ID FAN #1 SPEED CONTROL (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:20	231248293	YEARLY (SD) - PM FOR ID FAN #2 SPEED CONTROL (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:20	231207726	YEARLY (SD) - PM FOR ID-FAN#3 SPEED (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:21	231249590	YEARLY (SD) - PM FOR PRCP #3 DRAG SCRAPER (C706) (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:21	231207037	YEARLY (SD) - PM FOR PRCP #3 COLLECTING CONVEYOR (C708) (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:21	231248316	YEARLY (SD) - PM FOR ROTARY FEEDER ECO #3 (C710) (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:21	231229766	YEARLY (SD) - PM FOR SCREW CONVEYOR ESP3 (C712) (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:21	231229767	YEARLY (SD) - PM FOR ASH CONVEYOR GEN BANK (C001) (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:21	231217738	YEARLY (SD) - PM FOR ROTARY FEEDER GEN BANK (C004) (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:21	231260243	YEARLY (SD) - PM FOR ASH CONVEYOR ECO BANK #2 (C002) (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:21	231217739	YEARLY (SD) - PM FOR ROTARY FEEDER ECO BANK #2 (C005) (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:21	231260244	YEARLY (SD) - PM FOR ASH CONVEYOR ECO BANK #1 (C003) (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:21	231217740	YEARLY (SD) - PM FOR ROTARY FEEDER ECO BANK #1 (C006) (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:21	231260246	YEARLY (SD) - PM FOR ASH COLLECTOR CONVEYOR (C007) (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:21	231217741	YEARLY (SD) - PM FOR ASH CRUSHER (E080) (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:21	231260249	YEARLY (SD) - PM FOR PRCP#1 DRAG SCRAPER (C008) (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:22	231202854	YEARLY (SD) - PM FOR PRCP#1 COLLECT CONVEYOR (C010) (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:22	231248237	YEARLY (SD) - PM FOR PRCP#1 ROTARY FEEDER (C012) (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:22	231202855	YEARLY (SD) - PM FOR PRCP#2 DRAG SCRAPER (C009) (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:22	231248238	YEARLY (SD) - PM FOR PRCP#2 COLLECT CONVEYOR (C011) (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:22	231202879	YEARLY (SD) - PM FOR PRCP#2 ROTARY FEEDER (C013) (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:22	231248305	YEARLY (SD) - PM FOR PRECIP TRANSFER CONVEYOR #1 (C014) (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:22	231213517	YEARLY (SD) - PM FOR PRECIP TRANSFER CONVEYOR #2 (C015) (A)	NPP5A_PP11

WL5216	PSD AUTO-ALL	20/10/2023 2:22	231254934	YEARLY (SD) - PM FOR FEED WATER PUMP #3 SPEED (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:22	231202864	YEARLY (SD) - PM FOR SPEED CONTROL FEED WATER PUMP 1 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:22	231248266	YEARLY (SD) - PM FOR SPEED CONTROL FEED WATER PUMP 2 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:22	231202862	YEARLY (SD) - PM FOR WIND R ID FAN #1 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:23	231248263	YEARLY (SD) - PM FOR WIND R ID FAN #1 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:23	231217932	YEARLY (SD) - PM FOR WIND R ID FAN #1 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:23	231260382	YEARLY (SD) - PM FOR WIND R ID FAN #2 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:23	231223092	YEARLY (SD) - PM FOR WIND S ID FAN#2 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:24	231262329	YEARLY (SD) - PM FOR WIND T ID FAN#2 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:24	231223070	YEARLY (SD) - PM FOR WIND R MOTOR TEMP ID FAN #3 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:24	231262321	YEARLY (SD) - PM FOR WIND S MOTOR TEMP ID FAN #3 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 2:24	231223089	YEARLY (SD) - PM FOR WIND T MOTOR TEMP ID FAN #3 (A)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:24	231262326	YEARLY (SD) - PM FOR FW PUMP #2(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:25	231223082	YEARLY (SD) - PM FOR FW PUMP #3(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:27	231262324	YEARLY (SD) - PM FOR PRIMARY FD FAN(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:28	231223084	YEARLY (SD) - PM FOR SECONDARY FD FAN(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:29	231262325	YEARLY (SD) - PM FOR TERTIARY FD FAN(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:30	231223071	YEARLY (SD) - PM FOR MOTOR ID FAN # 1 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:31	231262322	YEARLY (SD) - PM FOR MOTOR ID FAN # 2 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:32	231223090	YEARLY (SD) - PM FOR ID FAN #3(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:33	231262328	YEARLY (SD) - PM FOR ASH COLLECTING CONVEYOR(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:34	231223076	YEARLY (SD) - PM FOR MOTOR DRAG SCRAPER, ESP # 1 SEE LONG DISCRPTION (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:35	231262323	YEARLY (SD) - PM FOR MOTOR DRAG SCRAPER, ESP # 2 SEE LONG DISCRPTION (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:37	231202895	YEARLY (SD) - PM FOR COLLECTING CONVEYOR, ESP # 1(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:38	231248425	YEARLY (SD) - PM FOR MOTOR COLLECTING CONVEYOR, ESP # 2 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:39	231202896	YEARLY (SD) - PM FOR MOTOR ROTARY FEEDER, ESP # 1 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:40	231248426	YEARLY (SD) - PM FOR MOTOR ROTARY FEEDER, ESP # 2 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:41	231199187	YEARLY (SD) - PM FOR MOTOR COLLECTING CONVEYER ESP.3 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:42	231243236	YEARLY (SD) - PM FOR MOTOR ROTARY FEED ESP#3 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:43	231210549	YEARLY (SD) - PM FOR MOTOR SCREW CONVEYER ESP.3 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:44	231210551	YEARLY (SD) - PM FOR ESP TRANSFER CONVEYOR # 1 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:45	231251399	YEARLY (SD) - PM FOR ESP TRANSFER CONVEYOR #2(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:46	231251401	YEARLY (SD) - PM FOR MOTOR SCRAPER CONVEYER ESP.3 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:47	231219863	YEARLY (SD) - PM FOR MOTOR FIRING LIQUOR PUMP (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:48	231262347	YEARLY (SD) - PM FOR MOTOR FIRING LIQUOR PUMP (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:49	231210552	YEARLY (SD) - PM FOR SPOUT COOLING WATER PUMP #1(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:50	231251507	YEARLY (SD) - PM FOR SPOUT COOLING WATER PUMP #2(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:51	231202888	YEARLY (SD) - PM FOR VSD OF FIRING LIQUOR PUMP #1 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 2:52	231243224	YEARLY (SD) - PM FOR VSD OF FIRING LIQUOR PUMP #2 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 2:53	231202889	YEARLY (SD) - PM FOR AL21 BUS 6.6KV FEED WATER PUMP P003 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 2:57	231243228	YEARLY (SD) - PM FOR AL22 SWG 6.6KV FEED WATER PUMP P050 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 3:01	231207196	YEARLY (SD) - PM FOR RECOVERY TRANSFORMER TH411(E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 3:03	231248397	YEARLY (SD) - PM FOR EVAPORATION TRANSFORMER TH401(E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 3:04	231217890	YEARLY (SD) - PM FOR TURBO GEN. TRANSFORMER TD11 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 3:06	231260329	YEARLY (SD) - PM FOR EGAT OUT GOING TRANSFORMER TC3 (E)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:08	231219871	YEARLY (SD) - PM FOR EXTRA STEAM VLAVE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:09	231262348	YEARLY (SD) - PM FOR BASIN CONTROL VALVE W E/P POSITIONER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:10	231207201	YEARLY (SD) - PM FOR FEEDWATER CONTROL VALVE W E/P POSITIONER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:10	231248399	YEARLY (SD) - PM FOR MP CONDENSATE RECEIVER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:11	231207204	YEARLY (SD) - PM FOR LP CONDENSATE RECEIVER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:12	231248401	YEARLY (SD) - PM FOR SOOT BLOWER CONTROL VALVE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:12	231207212	YEARLY (SD) - PM FOR DESUPPERHEATER WATER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:13	231248404	YEARLY (SD) - PM FOR SOOTBLOWER CONDENSATE DRAIN LEFT SIDE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:14	231207215	YEARLY (SD) - PM FOR SOOTBLOWER CONDENSATE DRAIN RIGHT SIDE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:14	231248405	YEARLY (SD) - PM FOR CONTROL VALVE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:15	231207223	YEARLY (SD) - PM FOR PRESSURE CONTROL VALVE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:15	231248407	YEARLY (SD) - PM FOR TEMPERATURE CONTROL VALVE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:16	231207225	YEARLY (SD) - PM FOR BL TO SPRAY GUN (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:17	231248408	YEARLY (SD) - PM FOR BL TO SPRAY GUN (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:18	231207231	YEARLY (SD) - PM FOR BL TO SPRAY GUN #1 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:18	231248410	YEARLY (SD) - PM FOR BL TO SPRAY GUN #4 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:19	231219877	YEARLY (SD) - PM FOR BL TO SPRAY GUN #4 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:19	231260331	YEARLY (SD) - PM FOR HVLC GAS TO R/B (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:20	231202904	YEARLY (SD) - PM FOR VENT STACK (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:21	231248451	YEARLY (SD) - PM FOR EMERGENCY COOLLING WATER TANK (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:21	231202913	YEARLY (SD) - PM FOR FEED WATER TANK LEVEL LEFT (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:22	231248454	YEARLY (SD) - PM FOR FEED WATER TANK LEVEL RIGHT (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:23	231207039	YEARLY (SD) - PM FOR CONDENSATE COLLECTING TANK LEVEL (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:23	231248334	YEARLY (SD) - PM FOR MIXING GAS TREATMENT (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:24	231202956	YEARLY (SD) - PM FOR CBD SUMP PUMP (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:24	231203052	YEARLY (SD) - PM FOR CBD SUMP PUMP (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:25	231248464	YEARLY (SD) - PM FOR SCRUBBER LEVEL CONTROL (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:25	231248475	YEARLY (SD) - PM FOR CBD TANK LEVEL (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:26	231202977	YEARLY (SD) - PM FOR GAS PRESSURE SCRUBBER BEFORE SCRUB (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:27	231203076	YEARLY (SD) - PM FOR GAS TEMPERATURE AFTER HEATER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:28	231248467	YEARLY (SD) - PM FOR SCRUBBER COOLER TEMPERATURE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:28	231248479	YEARLY (SD) - PM FOR CONDENSATE FROM PAPER MACHINE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:28	231202996	YEARLY (SD) - PM FOR CONDENSATE FROM PULP DRYER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:29	231203090	YEARLY (SD) - PM FOR CONDENSATE FROM FIBERLINE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:29	231248470	YEARLY (SD) - PM FOR CONDENSATE FROM FIBERLINE (A)	NPP5A_PP11

WL5216	PSD AUTO-ALL	20/10/2023 3:29	231248482	YEARLY (SD) - PM FOR CONDENSATE FROM EVAPORATION PLANT (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:29	231203025	YEARLY (SD) - PM FOR CONDENSATE FROM EVAPORATION PLANT (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:29	231203109	YEARLY (SD) - PM FOR CONDENSATE FROM TURBINE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:29	231248472	YEARLY (SD) - PM FOR CONDENSATE FROM TURBINE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:30	231248486	YEARLY (SD) - PM FOR CONDENSATE FROM PAPER MACHINE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:30	231203131	YEARLY (SD) - PM FOR CONDENSATE FROM PAPER MACHINE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:30	231248490	YEARLY (SD) - PM FOR WATER TO DEMISTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:30	231207424	YEARLY (SD) - PM FOR MIXING GAS TREATMENT (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:30	231249017	YEARLY (SD) - PM FOR MIXING GAS TREATMENT (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:30	231207049	YEARLY (SD) - PM FOR CONDENSATE COLLECTING TANK (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:30	231248350	YEARLY (SD) - PM FOR BOILER WASH WATER RECIRCULATION (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:31	231207043	YEARLY (SD) - PM FOR BL SPRAYER DIVERT (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:31	231248343	YEARLY (SD) - PM FOR HVLC GAS TO PREHEATER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:31	231207045	YEARLY (SD) - PM FOR HVLC GAS VENT ATMOSPHERE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:31	231248345	YEARLY (SD) - PM FOR CONTROL VALVE FOR HVLC FAN AT RECOVERY BOILER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:31	231203324	YEARLY (SD) - PM FOR CONDENSATE COLLECTING TANK OVERFLOW (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:31	231248719	YEARLY (SD) - PM FOR SWITCH GL/ WEAK WASH VALVE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:32	231207428	YEARLY (SD) - PM FOR SWITCH GL/ WEAK WASH VALVE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:32	231249024	YEARLY (SD) - PM FOR MILL WATER TO SCRUBBER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:32	231207433	YEARLY (SD) - PM FOR NaOH TO SCRUBBER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:32	231249033	YEARLY (SD) - PM FOR STM ON/OFF VV TO HTR (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:32	231207456	YEARLY (SD) - PM FOR SCRUBBER DRAIN VALV (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:32	231249064	YEARLY (SD) - PM FOR FEEDWTR BLOCK VLAVE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:33	231207465	YEARLY (SD) - PM FOR RAPID DRAIN GENBANK (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:34	231249072	YEARLY (SD) - PM FOR RAPID DRAIN DOWNCOMER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:34	231202897	YEARLY (SD) - PM FOR STARTUP BLOCK VLV (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:35	231248443	YEARLY (SD) - PM FOR MAIN STEAM VALVE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:35	231202899	YEARLY (SD) - PM FOR DISC CONT BLOWDOWN (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:36	231248447	YEARLY (SD) - PM FOR STEAM VLV BYPASS (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:37	231203366	YEARLY (SD) - PM FOR FEEDWTR BY-PASS VLV (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:37	231248811	YEARLY (SD) - PM FOR SOOTBLWR STEAM HDR (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:38	231207040	YEARLY (SD) - PM FOR EXTRA STEAM VLAVE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:39	231248338	YEARLY (SD) - PM FOR INTER CONNECTION (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:39	231207041	YEARLY (SD) - PM FOR MILL WATER TO DEMIN PLANT DIFF PRESSURE TRANSMITT. (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:39	231248340	YEARLY (SD) - PM FOR INSTRUMENT AIR DEMIN PLANT DIFF PRESSURE TRANSMITT. (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:40	231207312	YEARLY (SD) - PM FOR INSTRUMENT AIR DEMIN PLANT PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:40	231248934	YEARLY (SD) - PM FOR RETURN COOLING WTR FROM COMPR. DIFF PRESSURE TRANS NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:40	231203165	YEARLY (SD) - PM FOR MILL WATER TO EVAPORATION DIFF PRESSURE TRANSMITT. (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:40	231248497	YEARLY (SD) - PM FOR NaOH TO FIBRE LINE AMPLIFIER/TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:40	231203150	YEARLY (SD) - PM FOR CONDENSATE FROM FL TO RB DIFF PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:40	231248493	YEARLY (SD) - PM FOR CONDENSATE FROM TURB TO RB DIFF PRESSURE TRANSMITT NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:40	231203187	YEARLY (SD) - PM FOR CONDENSATE FROM MILL 1 DIFF PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:40	231248503	YEARLY (SD) - PM FOR HOT WATER TO RB DIFF PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:41	231203206	YEARLY (SD) - PM FOR MILL WATER TO RB DIFF PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:41	231248508	YEARLY (SD) - PM FOR COOLING WATER RETURN FROM RB DIFF PRESSURE TRANS. (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:41	231203222	YEARLY (SD) - PM FOR INSTRUMENT AIR RB DIFF PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:41	231248519	YEARLY (SD) - PM FOR MILL AIR RB DIFF PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:41	231202928	YEARLY (SD) - PM FOR SEALING WATER FROM RB DIFF PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:41	231248457	YEARLY (SD) - PM FOR INSTRUMENT AIR RB PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:41	231203335	YEARLY (SD) - PM FOR SEC. COND. FROM EVAP TO CAUST TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:41	231248736	YEARLY (SD) - PM FOR LP STEAM TO CAUST DIFF PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:42	231203342	YEARLY (SD) - PM FOR LP STEAM TO CAUST DIFF PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:42	231203354	YEARLY (SD) - PM FOR MILL WATER TO CAUST DIFF PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:42	231248766	YEARLY (SD) - PM FOR INSTRUMENT AIR CAUST DIFF PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:42	231248790	YEARLY (SD) - PM FOR MILL AIR CAUST DIFF PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:42	231203261	YEARLY (SD) - PM FOR INSTRUMENT AIR CAUST PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:42	231248601	YEARLY (SD) - PM FOR MILL AIR CAUST PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:42	231203243	YEARLY (SD) - PM FOR MILL WATER TO FIBRE LINE DIFF PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:42	231248543	YEARLY (SD) - PM FOR HOT WATER FROM FIBRE LINE DIFF PRESSURE TRANSMITT. (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:43	231207252	YEARLY (SD) - PM FOR RETURN COOLING WATER FROM FL DIFF PRESSURE TRANS. (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:43	231248427	YEARLY (SD) - PM FOR WHITE WATER WET LAP FL DIFF PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:43	231207263	YEARLY (SD) - PM FOR CONTAMINATED COND. FROM FL DIFF PRESSURE TRANSMITT. (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:43	231248430	YEARLY (SD) - PM FOR INSTRUMENT AIR FIBRE LINE DIFF PRESSURE TRANSMITT. (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:43	231202941	YEARLY (SD) - PM FOR MILL AIR FIBRE LINE DIFF PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:43	231248461	YEARLY (SD) - PM FOR SEC. COND. TO FL FROM EVAP DIFF PRESSURE TRANSMITT. (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:43	231207384	YEARLY (SD) - PM FOR INSTRUMENT AIR FIBRE LINE PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:43	231248966	YEARLY (SD) - PM FOR MILL AIR FIBRE LINE PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:44	231207397	YEARLY (SD) - PM FOR STRONG LIQOUR FLOW (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:44	231248981	YEARLY (SD) - PM FOR WASH LIQOUR FLOW (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:44	231203232	YEARLY (SD) - PM FOR water flow to stripper after (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:44	231248527	YEARLY (SD) - PM FOR CONCENTRATE LIQOUR FLOW (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:44	231203307	YEARLY (SD) - PM FOR FEED LIQ. TO EFFECT 3 (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:44	231248678	YEARLY (SD) - PM FOR SEC. CONDENSATE FLOW (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:44	231207047	YEARLY (SD) - PM FOR WEAK LIQOUR TO TANKS (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:44	231248348	YEARLY (SD) - PM FOR SEC. CONDENSATE FLOW (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:45	231207369	YEARLY (SD) - PM FOR SEALING WATER FLOW (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:45	231248957	YEARLY (SD) - PM FOR BL RETURN TO EVAP (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:45	231203255	YEARLY (SD) - PM FOR PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:45	231248574	YEARLY (SD) - PM FOR PRESSURE TRANSMITTER (A) NPP5A_PP11	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:45	231203423	YEARLY (SD) - PM FOR LIVE STEAM PRESSURE (A) NPP5A_PP11	NPP5A_PP11

WL5216	PSD AUTO-ALL	20/10/2023 3:45	231248875	YEARLY (SD) - PM FOR LIVE STREAM PRESSURE EFF. 1D (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:45	231207721	YEARLY (SD) - PM FOR PRESSURE EFFECT 1A (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:45	231249569	YEARLY (SD) - PM FOR PRESSURE EFFECT 1A (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:45	231207718	YEARLY (SD) - PM FOR PRESSURE EFFECT 1C (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:46	231249564	YEARLY (SD) - PM FOR GAS SFT.TRIM COND. (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:46	231207476	YEARLY (SD) - PM FOR TANK VENTS (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:46	231249078	YEARLY (SD) - PM FOR PRESSURE OF CONDENSATE TO VACUUM PUMP (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:46	231207550	YEARLY (SD) - PM FOR FEEDWATER TO R/B PRESSURE TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:46	231249103	YEARLY (SD) - PM FOR PRESSURE PRIMARY AIR HEATER OUTLET (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:46	231207558	YEARLY (SD) - PM FOR PRESSURE SECONDARY AIR HEATER OUTLET (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:46	231249105	YEARLY (SD) - PM FOR TERTARY AIR PRESSURE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:46	231207571	YEARLY (SD) - PM FOR VENT STACK (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:47	231249109	YEARLY (SD) - PM FOR INSTRUMENT AIR PRESSURE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:47	231207584	YEARLY (SD) - PM FOR MILL AIR PRESSURE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:47	231249111	YEARLY (SD) - PM FOR HVLC GAS TO R/ B (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:47	231207600	YEARLY (SD) - PM FOR STEAM DRUM PRESSURE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:47	231249116	YEARLY (SD) - PM FOR FLUE GAS SUPPERHEATER GENBANK (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:47	231207606	YEARLY (SD) - PM FOR FLUEGAS GENBANK / ECO #2 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:47	231249121	YEARLY (SD) - PM FOR FLUE GAS ECO #2 / ECO #1 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:47	231207608	YEARLY (SD) - PM FOR FLUE GAS AFTER ECO #1 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:48	231249126	YEARLY (SD) - PM FOR MAKE UP MILL WTR TO COOL TWR DIFF PRESSURE TRANS. (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:48	231207610	YEARLY (SD) - PM FOR INSTRUMENT AIR COOL. TWR DIFF PRESSURE TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:48	231249134	YEARLY (SD) - PM FOR MILL AIR COOL.TWR DIFF PRESSURE TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:48	231207614	YEARLY (SD) - PM FOR MP STEAM TO FUEL OIL STATION DIFF PRESSURE TRANS. (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:48	231249146	YEARLY (SD) - PM FOR INSTRUMENT AIR FUEL OIL STN DIFF PRESSURE TRANS. (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:48	231207618	YEARLY (SD) - PM FOR MILL AIR FUEL OIL STATION DIFF PRESSURE TRANSMITT. (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:48	231249162	YEARLY (SD) - PM FOR MP STEAM TO EVAPORATION DIFF PRESSURE TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:48	231207485	YEARLY (SD) - PM FOR CONDENSATE FROM EVAP TO RB DIFF PRESSURE TRANSMITT	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:49	231249084	YEARLY (SD) - PM FOR LP STEAM TO TURB FROM MILL. 1 DIFF PRESSURE TRANS. (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:49	231207628	YEARLY (SD) - PM FOR MP STEAM FROM TURB TO MILL 1 DIFF PRESSURE TRANS. (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:49	231249178	YEARLY (SD) - PM FOR MP STEAM FROM TURB TO MILL 1 DIFF PRESSURE TRANS. (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:49	231207634	YEARLY (SD) - PM FOR COOL WTR RET. TOT. TU/CO/DEM DIFF PRESSURE TRANS. (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:49	231249191	YEARLY (SD) - PM FOR INSTRUMENT AIR TURBINE DIFF PRESSURE TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:49	231207641	YEARLY (SD) - PM FOR EFFLUENT FROM RECOVERY BOILER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:49	231249216	YEARLY (SD) - PM FOR DISSOLVING GAS FLOW (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:49	231207642	YEARLY (SD) - PM FOR HVLC GAS TO R/ B (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:49	231249239	YEARLY (SD) - PM FOR STEAM TO DEARATER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:49	231207644	YEARLY (SD) - PM FOR DEMIN WATER TO DEARATER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:50	231249250	YEARLY (SD) - PM FOR MILL CONDENSATE TO DEARATER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:50	231207646	YEARLY (SD) - PM FOR FUEL OIL TANK (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:50	231249268	YEARLY (SD) - PM FOR LEVEL STRIPPER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:50	231207647	YEARLY (SD) - PM FOR LV.SEC.COND.P.TK. (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:50	231249280	YEARLY (SD) - PM FOR LEVEL VACUUM TANK (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:50	231207650	YEARLY (SD) - PM FOR LV.FOUL COND.P.TK. (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:50	231249289	YEARLY (SD) - PM FOR LEVEL SEC. COND. 1 PUMP TANK (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:50	231207651	YEARLY (SD) - PM FOR TOTAL BOILER LEVEL (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:51	231249308	YEARLY (SD) - PM FOR CONDENSATE SUMP PUMP (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:51	231207653	YEARLY (SD) - PM FOR MP CONDENSATE RECEIVER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:51	231249315	YEARLY (SD) - PM FOR LP CONDENSATE RECEIVER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:51	231207492	YEARLY (SD) - PM FOR CBD TANK LEVEL (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:51	231249090	YEARLY (SD) - PM FOR EMERG COOLWTR TANK (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:51	231207654	YEARLY (SD) - PM FOR DUMP TANK LEVEL (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:51	231249322	YEARLY (SD) - PM FOR SCRUBBER LEVEL CONTROL (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:51	231207657	YEARLY (SD) - PM FOR DISSOLVING TANK DENSITY (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:51	231249334	YEARLY (SD) - PM FOR BFP3 SUC STRAINER > 0.6 BAR (463PT473) (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:52	231207660	YEARLY (SD) - PM FOR OIL HEADER PRESSURE HI (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:52	231249340	YEARLY (SD) - PM FOR IGNITER GAS PRESSURE HI (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:52	231207661	YEARLY (SD) - PM FOR OIL HEADER PRESSURE LOW (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:52	231249356	YEARLY (SD) - PM FOR IGNITER GAS PRESSURE LOW (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:52	231207662	YEARLY (SD) - PM FOR START BURNER #1 STEAM PRESSURE LOW (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:52	231249367	YEARLY (SD) - PM FOR START BURNER #1 AIR PRESSURE LOW (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:52	231207663	YEARLY (SD) - PM FOR MILL AIR RB PRESSURE TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:52	231249378	YEARLY (SD) - PM FOR LP STEAM TO TURB FROM MILL 1 PRESSURE TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:52	231207702	YEARLY (SD) - PM FOR MP STEAM FROM TURB TO MILL 1 PRESSURE TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:52	231249534	YEARLY (SD) - PM FOR INSTRUMENT AIR TURBINE PRESSURE TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:53	231207703	YEARLY (SD) - PM FOR INSTRUMENT AIR COOL TWR PRESSURE TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:53	231249540	YEARLY (SD) - PM FOR MILL AIR COOL TWR PRESSURE TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:53	231207706	YEARLY (SD) - PM FOR INSTRUMENT AIR FUEL OIL STN PRESSURE TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:53	231249543	YEARLY (SD) - PM FOR MILL AIR FUEL OIL STATION PRESSURE TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:53	231207708	YEARLY (SD) - PM FOR DIFF. PRESSURE OF STRIPPER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:53	231249548	YEARLY (SD) - PM FOR DIFF PRESSURE ACROSS HEATER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:53	231207711	YEARLY (SD) - PM FOR GAS PRESSURE SCRUBBER BEFORE SCRUB (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:53	231249551	YEARLY (SD) - PM FOR GAS PRESSURE AFTER SCRUBBER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:53	231207713	YEARLY (SD) - PM FOR INSTRUMENT AIR DEMIN PLANT TEMP. TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:54	231249557	YEARLY (SD) - PM FOR INSTRUMENT AIR RB TEMP. TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:54	231207715	YEARLY (SD) - PM FOR MILL AIR RB TEMP. TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:54	231249560	YEARLY (SD) - PM FOR INSTRUMENT AIR CAUST TEMP. TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:54	231207664	YEARLY (SD) - PM FOR MILL AIR CAUST TEMP. TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:55	231249384	YEARLY (SD) - PM FOR INSTRUMENT AIR FIBRE LINE TEMP. TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:55	231207717	YEARLY (SD) - PM FOR MILL AIR FIBRE LINE TEMP. TRANSMITTER (A)	NPP5A_PP11

WL5216	PSD AUTO-ALL	20/10/2023 3:55	231249561	YEARLY (SD) - PM FOR BASIN DIFF. PRESSURE TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:55	231207666	YEARLY (SD) - PM FOR HYDRAULIC OIL AFTER COOLER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:56	231249393	YEARLY (SD) - PM FOR HYDRAULIC OIL RETURN TEMP FW#3 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:56	231207667	YEARLY (SD) - PM FOR LP STEAM TO TURB FROM MILL 1 TEMP. TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:56	231249404	YEARLY (SD) - PM FOR MP STEAM FROM TURB TO MILL 1 TEMP. TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:56	231207668	YEARLY (SD) - PM FOR INSTRUMENT AIR COOL TWR TEMP. TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:56	231249416	YEARLY (SD) - PM FOR MILL AIR COOL TWR TEMP. TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:57	231207498	YEARLY (SD) - PM FOR INSTRUMENT AIR FUEL OIL STN TEMP. TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:57	231249093	YEARLY (SD) - PM FOR MILL AIR FUEL OIL STATION TEMP. TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:57	231207669	YEARLY (SD) - PM FOR TEMPERATURE TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:57	231249426	YEARLY (SD) - PM FOR TEMPERATURE TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:57	231207670	YEARLY (SD) - PM FOR TEMPERATURE TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:58	231249432	YEARLY (SD) - PM FOR LIVE STEAM TEMP. (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:58	231207673	YEARLY (SD) - PM FOR STRONG LIQOUR TEMPERATURE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:58	231249441	YEARLY (SD) - PM FOR TEMP. OF PRIM. CONDENSATE BEFOR PU (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:58	231207674	YEARLY (SD) - PM FOR TEMP. DIFF. EFFECT 1D (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:59	231249456	YEARLY (SD) - PM FOR TEMPERATURE OF CONDENSATE AFTER EFF. 1B (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:59	231207675	YEARLY (SD) - PM FOR TEMPERATURE OF CONDENSATE AFTER EFF. 1C (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:59	231249460	YEARLY (SD) - PM FOR LIVE STEAM TO EFF. 1D (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:59	231207676	YEARLY (SD) - PM FOR TEMPERATURE OF CONDENSATE AFTER EFF. 1D (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 3:59	231249467	YEARLY (SD) - PM FOR TEMPERATURE OF CIRCULATION EFFECT 1D (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:00	231207680	YEARLY (SD) - PM FOR TEMPERATURE EFFECT 1D (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:00	231249480	YEARLY (SD) - PM FOR TEMPERATURE EFFECT 1D (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:00	231207683	YEARLY (SD) - PM FOR TEMPERATURE OF CONDENSATE AFTER EFF. 1A (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:00	231249490	YEARLY (SD) - PM FOR TEMPERATURE OF CONDENSATE AFTER EFF. 1B (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:00	231207689	YEARLY (SD) - PM FOR TEMPERATURE OF CONDENSATE AFTER EFF. 1C (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:01	231249499	YEARLY (SD) - PM FOR STRONG LIQUE TEMP (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:01	231207691	YEARLY (SD) - PM FOR TEMPERATURE OF CONDENSATE AFTER EFF. 2 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:01	231249506	YEARLY (SD) - PM FOR TEMPERATURE OF CIRCULATION EFF. 2 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:01	231207509	YEARLY (SD) - PM FOR T.OF NCG AFT. STRIP (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:02	231249095	YEARLY (SD) - PM FOR TEMPERATURE OF CONDENSATE AFTER EFF. 3 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:02	231207693	YEARLY (SD) - PM FOR TEMPERATURE OF CIRCULATION EFF. 3 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:02	231249514	YEARLY (SD) - PM FOR TEMPERATURE OF FEED LIQOUR TO EFFECT (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:02	231207698	YEARLY (SD) - PM FOR TEMPERATURE OF CONDENSATE AFTER EFF. 4 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:03	231249522	YEARLY (SD) - PM FOR TEMPERATURE OF CIRCULATION EFF. 4 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:03	231207700	YEARLY (SD) - PM FOR TEMPERATURE OF CIRCULATION EFF. 5 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:03	231249526	YEARLY (SD) - PM FOR TEMPERATURE OF CIRCULATION EFF. 5 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:03	231207519	YEARLY (SD) - PM FOR TEMPERATURE OF STRIPPED CONDENSATE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:03	231249096	YEARLY (SD) - PM FOR TEMPERATURE OF STRIPPED CONDENSATE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:04	231207526	YEARLY (SD) - PM FOR TEMP. OF FOUL CONDENSATE BEFOR STRIPPED (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:04	231249098	YEARLY (SD) - PM FOR TEMP. OF FIRING LIQOUR TANK (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:04	231207533	YEARLY (SD) - PM FOR TEMP. OF STRONG LIQOUR TANK (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:04	231249099	YEARLY (SD) - PM FOR T.OF STRONG LIQ. TK. (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:04	231207539	YEARLY (SD) - PM FOR TEMP. AT RAW WATER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:05	231249101	YEARLY (SD) - PM FOR TEMP. OF Na2SO4 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:05	231207341	YEARLY (SD) - PM FOR METAL FERNANCE FLOOR TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:05	231248949	YEARLY (SD) - PM FOR METAL FERNANCE FLOOR TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:05	231207410	YEARLY (SD) - PM FOR METAL FERNANCE FLOOR TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:05	231248992	YEARLY (SD) - PM FOR METAL FERNANCE FLOOR TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:06	231207418	YEARLY (SD) - PM FOR METAL FERNANCE FLOOR TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:06	231249000	YEARLY (SD) - PM FOR METAL FERNANCE FLOOR TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:06	231203380	YEARLY (SD) - PM FOR MTL FRNCE FLOOR TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:06	231203400	YEARLY (SD) - PM FOR MTL FRNCE FLOOR TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:07	231203439	YEARLY (SD) - PM FOR MTL FRNCE FLOOR TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:07	231248825	YEARLY (SD) - PM FOR MTL FRNCE FLOOR TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:07	231248845	YEARLY (SD) - PM FOR MTL FRNCE FLOOR TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:07	231248910	YEARLY (SD) - PM FOR MTL FRNCE FLOOR TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:07	231203431	YEARLY (SD) - PM FOR MTL FRNCE FLOOR TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:08	231248896	YEARLY (SD) - PM FOR MTL FRNCE FLOOR TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:08	231203282	YEARLY (SD) - PM FOR DO AFTER FEED WATER PUMP (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:08	231248629	YEARLY (SD) - PM FOR HYDRAULIC OIL FR COOLER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:08	231203296	YEARLY (SD) - PM FOR MTL FLOOR TUBE AT SPOUT #1 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:09	231248656	YEARLY (SD) - PM FOR MTL FLOOR TUBE AT SPOUT #2 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:09	231203414	YEARLY (SD) - PM FOR MTL FLOOR TUBE AT SPOUT #3 (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:09	231248858	YEARLY (SD) - PM FOR MTL FLR TUBE AT CORNER LEFT (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:09	231203313	YEARLY (SD) - PM FOR MTL FLR TUBE AT CORNER RIGHT (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:10	231248698	YEARLY (SD) - PM FOR VENT STACK TEMP. (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:10	231199186	YEARLY (SD) - PM FOR GREEN LIQOUR TO WEAK WASH LINE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:10	231243181	YEARLY (SD) - PM FOR GL/ WEAK WASH LINE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:10	231208259	YEARLY (SD) - PM FOR BL MIXING TANK LEVEL (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:10	231251525	YEARLY (SD) - PM FOR COOLLING WATER SPOUT #1 OUTLET (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:11	231208260	YEARLY (SD) - PM FOR COOLLING WATER SPOUT #2 OUTLET (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:11	231251532	YEARLY (SD) - PM FOR COOLLING WATER SPOUT #3 OUTLET (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:11	231219881	YEARLY (SD) - PM FOR GAS TEMPERATURE AFTER HEATER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:11	231260333	YEARLY (SD) - PM FOR SCRUBBER COOLER TEMPERATURE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:11	231219887	YEARLY (SD) - PM FOR MIXING GAS TREATMENT (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:12	231260334	YEARLY (SD) - PM FOR HVLC GAS TO R/ B (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:12	231219895	YEARLY (SD) - PM FOR WATER TO DEARATER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:12	231260335	YEARLY (SD) - PM FOR FEEDWTR INLET CONDNSR HEAD MOUNT TEMP. TRANSMITTER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:12	231219897	YEARLY (SD) - PM FOR FEEDWTR OUTLET CONDNSR HEAD MOUNT TEMP. TRANSMITTER (A)	NPP5A_PP11

WL5216	PSD AUTO-ALL	20/10/2023 4:12	231260336	YEARLY (SD) - PM FOR FEEDWTR BETW.ECO 1 AND 2 HEAD MOUNT TEMP.TRANSMITT	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:13	231219905	YEARLY (SD) - PM FOR TEMP. BLOWDOWN TANK (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:13	231260337	YEARLY (SD) - PM FOR TERTARY SUPPER HEATER RIGHT SIDE OUTLET (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:13	231219912	YEARLY (SD) - PM FOR SOOTBLOWER CONDENSATE DRAIN LEFT SIDE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:13	231260339	YEARLY (SD) - PM FOR SOOTBLOWER CONDENSATE DRAIN RIGHT SIDE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:14	231219920	YEARLY (SD) - PM FOR PRIMARY AIR HEATER OUTLET (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:14	231260341	YEARLY (SD) - PM FOR SECONDARY AIR HEATER OUTLET (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:14	231219928	YEARLY (SD) - PM FOR FLUE GAS SUPPERHEATER/ GENBANK LEFT SIDE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:14	231260342	YEARLY (SD) - PM FOR FLUGAS SUPPERHEATER /GENBANK RIGHT SIDE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:14	231219938	YEARLY (SD) - PM FOR FLUE GAS GENBANK / ECO #2 LEFT SIDE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:15	231260346	YEARLY (SD) - PM FOR FLUE GAS GENBANK / ECO #2 LEFT SIDE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:15	231219939	YEARLY (SD) - PM FOR FLUE GAS OUTLET ECO #1 LEFT SIDE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:15	231260348	YEARLY (SD) - PM FOR FLUE GAS OUTLET ECO #1 RIGHTSIDE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:15	231208256	YEARLY (SD) - PM FOR PRIMARY AIR INLET (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:15	231251512	YEARLY (SD) - PM FOR METAL PRIMARY 1 SUPPERHEAT TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:16	231208258	YEARLY (SD) - PM FOR METAL PRIMARY 1 SUPPERHEAT TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:16	231251517	YEARLY (SD) - PM FOR METAL PRIMARY 1 SUPPERHEAT TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:16	231229719	YEARLY (SD) - PM FOR MTL SECONDARY SUPPERHEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:16	231229734	YEARLY (SD) - PM FOR MTL SECONDARY SUPPERHEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:17	231229736	YEARLY (SD) - PM FOR MTL SECONDARY SUPPERHEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:17	231229733	YEARLY (SD) - PM FOR MTL SECONDARY SUPPERHEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:17	231229724	YEARLY (SD) - PM FOR MTL SECONDARY SUPPERHEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:17	231229731	YEARLY (SD) - PM FOR MTL SECONDARY SUPPERHEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:17	231229728	YEARLY (SD) - PM FOR MTL SECONDARY SUPPERHEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:18	231223214	YEARLY (SD) - PM FOR MTL SECONDARY SUPPERHEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:18	231262362	YEARLY (SD) - PM FOR MTL SECONDARY SUPPERHEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:18	231223206	YEARLY (SD) - PM FOR MTL SEC SPRHTR TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:18	231262360	YEARLY (SD) - PM FOR MTL TERTARY SUPPERHEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:19	231210553	YEARLY (SD) - PM FOR MTL TERTARY SUPPERHEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:19	231251536	YEARLY (SD) - PM FOR MTL TERTARY SUPPERHEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:19	231210555	YEARLY (SD) - PM FOR MTL TERTARY SUPPERHEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:19	231251543	YEARLY (SD) - PM FOR MTL TERTARY SUPPERHEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:19	231229676	YEARLY (SD) - PM FOR MTL TERTARY SUPPERHEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:20	231223141	YEARLY (SD) - PM FOR MTL TERTARY SUPPERHEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:20	231262350	YEARLY (SD) - PM FOR MTL TERTARY SUPPERHEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:20	231262351	YEARLY (SD) - PM FOR MTL TERTARY SUPPERHEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:21	231223165	YEARLY (SD) - PM FOR MTL TERTARY SUPPERHEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:21	231262353	YEARLY (SD) - PM FOR STEAM PRIMARY SUPER HEAT 1 OUT L (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:21	231223171	YEARLY (SD) - PM FOR STEAM PRIMARY SUPER HEATER 2 OUTLET (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:21	231262354	YEARLY (SD) - PM FOR SECONDARY SUPPER HEATER RIGHT SIDE OUTLET (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:22	231223194	YEARLY (SD) - PM FOR MAIN STEAM HEADER (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:22	231262357	YEARLY (SD) - PM FOR MTL PRIMARY 2 SUPPER HEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:22	231217920	YEARLY (SD) - PM FOR MTL PRIMARY 2 SUPPER HEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:22	231260370	YEARLY (SD) - PM FOR MTL PRIMARY 2 SUPPER HEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:23	231219954	YEARLY (SD) - PM FOR MTL PRIMARY 2 SUPPER HEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:23	231260361	YEARLY (SD) - PM FOR MTL PRIMARY 2 SUPPER HEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:23	231202890	YEARLY (SD) - PM FOR MTL PRIMARY 2 SUPPER HEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:23	231248415	YEARLY (SD) - PM FOR MTL PRIMARY 2 SUPPER HEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:24	231217919	YEARLY (SD) - PM FOR MTL PRIMARY 2 SUPPER HEATER TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:24	231260368	YEARLY (SD) - PM FOR MTL PRIM 2 SPRHTR TUBE (A)	NPP5A_PP11
WL5216	PSD AUTO-ALL	20/10/2023 4:24	231217909	YEARLY (SD) - PM FOR MTL PRIM 2 SPRHTR TUBE (A)	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	20/10/2023 4:24	231260365	YEARLY (SD) - PM FOR AHU SWITCHGEAR ROOM (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 4:25	231219957	YEARLY (SD) - PM FOR ELECTROSTATIC PRECIPITATOR # 1 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 4:37	231260364	YEARLY (SD) - PM FOR ELECTROSTATIC PRECIPITATOR # 2 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 4:49	231202891	YEARLY (SD) - PM FOR ESP #3(E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 5:02	231248417	YEARLY (SD) - PM FOR GENERATOR (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:03	231217914	YEARLY (SD) - PM FOR MOTOR FOR LUP OIL PUMP FEED WATER PUMP 3 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:05	231260366	YEARLY (SD) - PM FOR AGITATOR-SBL MIX TANK SEE LONG DISCRPTION (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:05	231217921	YEARLY (SD) - PM FOR AGITATOR-DISSOLVING TANK SEE LONG DISCRPTION (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:06	231260373	YEARLY (SD) - PM FOR AGITATOR-DISSOLVING TANK SEE LONG DISCRPTION (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:07	231195407	YEARLY (SD) - PM FOR ASH CRUSHER, GEN BANK(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:08	231207723	YEARLY (SD) - PM FOR SEALING AIR FAN # 1 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:09	231217973	YEARLY (SD) - PM FOR SEALING AIR FAN # 2 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:10	231229761	YEARLY (SD) - PM FOR SCANNER/IGNITOR AIR FAN # 1 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:11	231239581	YEARLY (SD) - PM FOR SCANNER/IGNITOR AIR FAN # 2 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:12	231249570	YEARLY (SD) - PM FOR SCRUBBER FAN (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:13	231260397	YEARLY (SD) - PM FOR GREEN LIQ TRANSFER PUMP #1(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:15	231194456	YEARLY (SD) - PM FOR GREEN LIQ TRANSFER PUMP #2(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:16	231207024	YEARLY (SD) - PM FOR HVLC GAS FAN (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:17	231216059	YEARLY (SD) - PM FOR SCRUBBER FAN (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:18	231229620	YEARLY (SD) - PM FOR COLLECTING RAPPER # A, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:19	231239368	YEARLY (SD) - PM FOR EMITTING RAPPER # A, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:20	231248232	YEARLY (SD) - PM FOR COLLECTING RAPPER # B, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:21	231257551	YEARLY (SD) - PM FOR EMITTING RAPPER # B, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:22	231195386	YEARLY (SD) - PM FOR COLLECTING RAPPER # C, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:23	231207027	YEARLY (SD) - PM FOR EMITTING RAPPER # C, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:24	231217754	YEARLY (SD) - PM FOR GAS SCREEN RAPPER, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:25	231229643	YEARLY (SD) - PM FOR COLLECTING RAPPER # A, PRECIPITATOR # 2 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:26	231239378	YEARLY (SD) - PM FOR EMITTING RAPPER # A, PRECIPITATOR # 2 (E)	NPP5A_PP11

WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:27	231248248	YEARLY (SD) - PM FOR COLLECTING RAPPER # B, PRECIPITATOR # 2 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:28	231260251	YEARLY (SD) - PM FOR EMITTING RAPPER # B, PRECIPITATOR # 2 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:29	231195389	YEARLY (SD) - PM FOR COLLECTING RAPPER # C, PRECIPITATOR # 2 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:29	231207030	YEARLY (SD) - PM FOR EMITTING RAPPER # C, PRECIPITATOR # 2 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:30	231217756	YEARLY (SD) - PM FOR GAS SCREEN RAPPER, PRECIPITATOR # 2 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:31	231229666	YEARLY (SD) - PM FOR COLLECTING RAPPER ESP # 3 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:32	231239392	YEARLY (SD) - PM FOR EMITTING RAPPER ESP#3 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:33	231248254	YEARLY (SD) - PM FOR COLLECTING RAPPER ESP# 3 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:35	231260257	YEARLY (SD) - PM FOR EMITTING RAPPER ESP# 3 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:36	231195390	YEARLY (SD) - PM FOR COLLECTING RAPPER ESP# 3 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:37	231207032	YEARLY (SD) - PM FOR EMITTING RAPPER ESP# 3 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:38	231217758	YEARLY (SD) - PM FOR GAS DISTRIBUTION RAPPER ESP# 3 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:39	231229667	YEARLY (SD) - PM FOR DUMP TANK PUMP (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:41	231239400	YEARLY (SD) - PM FOR SPILL COLLECTION PUMP (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:41	231248258	YEARLY (SD) - PM FOR SCRUBBER RECIRCULATION PUMP (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:42	231260261	YEARLY (SD) - PM FOR CIRCULATION PUMP (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:44	231195387	YEARLY (SD) - PM FOR CIRCULATION 1 A PUMP(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:45	231207029	YEARLY (SD) - PM FOR CIRCULATION 1 B PUMP(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:46	231217755	YEARLY (SD) - PM FOR CIRCULATION 1 C PUMP(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:47	231229645	YEARLY (SD) - PM FOR CIRCULATION 1 D PUMP(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:48	231239384	YEARLY (SD) - PM FOR CIRCULATION 1 B PUMP(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:49	231248252	YEARLY (SD) - PM FOR CIRCULATION 1 B PUMP(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:50	231260255	YEARLY (SD) - PM FOR CIRCULATION 1 C PUMP(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:52	231195401	YEARLY (SD) - PM FOR CIRCULATION 1 D PUMP(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:53	231207135	YEARLY (SD) - PM FOR CIRCULATION 2 PUMP(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:54	231217845	YEARLY (SD) - PM FOR EFFECT II-II LIQ .TRANSF PUMP(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:55	231229707	YEARLY (SD) - PM FOR EFFECT III CIRCULATE PUMP(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:56	231239489	YEARLY (SD) - PM FOR EFFECT III-II LIQ TRANSF PUMP(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:57	231248374	YEARLY (SD) - PM FOR EFFECT IV CIRCULATE PUMP(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:58	231260311	YEARLY (SD) - PM FOR EFFECT V CIRCULATE PUMP(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 5:59	231231853	YEARLY (SD) - PM FOR SEC. CONDENSATE II PUMP(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:01	231231837	YEARLY (SD) - PM FOR VACUUM PUMP (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:02	231231797	YEARLY (SD) - PM FOR VACUUM PUMP (STAND-BY) (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:03	231231807	YEARLY (SD) - PM FOR FEED LIQUOR PUMP (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:04	231231827	YEARLY (SD) - PM FOR FIRING LIQ FLASH TNK PUMP#1(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:05	231195392	YEARLY (SD) - PM FOR FIRING LIQ FLASH TNK PUMP#1(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:06	231207052	YEARLY (SD) - PM FOR SECONDARY CONDENSATE PUMP 1 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:07	231217768	YEARLY (SD) - PM FOR FIRING LIQ TNK AGITATOR #1(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:08	231229680	YEARLY (SD) - PM FOR FIRING LIQ TNK AGITATOR #2(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:09	231239423	YEARLY (SD) - PM FOR PRIMARY CONDENSATE PUMP(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:10	231248352	YEARLY (SD) - PM FOR FOUL CONDENSATE PUMP(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:11	231260272	YEARLY (SD) - PM FOR FOUL COND. VAC. PIT DWG(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:12	231195394	YEARLY (SD) - PM FOR REFLUX CONDENSATE (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:13	231207055	YEARLY (SD) - PM FOR WASH LIQUOR PUMP (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:14	231217771	YEARLY (SD) - PM FOR COMBINED CONDENSATE (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:15	231229682	YEARLY (SD) - PM FOR DESUPERHEATER PUMP (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:16	231239430	YEARLY (SD) - PM FOR STRONG LIQUOR PUMP (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:17	231248355	YEARLY (SD) - PM FOR STRONG LIQUOR PUMP (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:18	231260279	YEARLY (SD) - PM FOR WARM WATER PUMP (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:19	231195405	YEARLY (SD) - PM FOR SUMP PUMP(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:20	231195406	YEARLY (SD) - PM FOR SEAL WATER RETURN PUMP(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:21	231207441	YEARLY (SD) - PM FOR STRONG LIQUOR PUMP (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:22	231207449	YEARLY (SD) - PM FOR COOLING WATER PUMP NO.2 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:23	231217946	YEARLY (SD) - PM FOR AIR COMPRESSOR NO.1 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:24	231217968	YEARLY (SD) - PM FOR AIR COMPRESSOR NO.2 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:25	231229756	YEARLY (SD) - PM FOR AIR COMPRESSOR NO.3 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:26	231229758	YEARLY (SD) - PM FOR AIR COMPRESSOR NO.4 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:28	231239544	YEARLY (SD) - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf)	20/10/2023 6:29	231239558	YEARLY (SD) - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:30	231249042	YEARLY (SD) - PM FOR ADSORPTION DRYER NO.1 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:31	231249050	YEARLY (SD) - PM FOR ADSORPTION DRYER NO.2 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:32	231260395	YEARLY (SD) - PM FOR ADSORPTION DRYER NO.3 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:33	231260396	YEARLY (SD) - PM FOR ADSORPTION DRYER NO.4 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:34	231195404	YEARLY (SD) - PM FOR COOLING WATER PUMP NO.1 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:35	231207277	YEARLY (SD) - PM FOR COOLING WATER PUMP NO.2 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:37	231217934	YEARLY (SD) - PM FOR COOLING WATER PUMP NO.1 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:38	231229745	YEARLY (SD) - PM FOR COOLING WATER PUMP NO.3 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:40	231239528	YEARLY (SD) - PM FOR EFFLUENT MIXING PUMP(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:41	231248436	YEARLY (SD) - PM FOR EMERGENCY OIL PUMP (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:42	231260385	YEARLY (SD) - PM FOR CONTROL OIL PUMP #1(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:43	231195399	YEARLY (SD) - PM FOR CONTROL OIL PUMP # 2 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:44	231207117	YEARLY (SD) - PM FOR LUBE OIL PUMP #1(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:45	231217821	YEARLY (SD) - PM FOR LUBE OIL PUMP # 2(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:47	231229702	YEARLY (SD) - PM FOR TURNING MOTOR (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:48	231239473	YEARLY (SD) - PM FOR GLAND COND DRAIN PUMP(E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:49	231248367	YEARLY (SD) - PM FOR GLAND CONDENSER FAN. SEE LONG DESCR. (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:50	231260305	YEARLY (SD) - PM FOR VAPOR EXTRACTOR, SEPARATION OF OIL MIST. SEE L.D. (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:50	231195402	YEARLY (SD) - PM FOR VAPOR FAN (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:52	231207163	YEARLY (SD) - PM FOR CONDENSATE FEED PUMP#A (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 6:53	231217865	YEARLY (SD) - PM FOR CONDENSATE FEED PUMP#B (E)	NPP5A_PP11

WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 8:40	231170849	YEARLY (SD) - PM FOR SOOTBLOWER # 62 RIGHT (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	20/10/2023 8:41	231171029	YEARLY (SD) - PM FOR 115 KV SUBSTATION AAP2 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 9:10	231171027	YEARLY (SD) - PM FOR SWITCH GEAR LOAD 22KV PULP MILL 2 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 9:14	231170851	YEARLY (SD) - PM FOR BUS MEASURING FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 9:20	231170854	YEARLY (SD) - PM FOR TH432/TH433 FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 9:24	231170852	YEARLY (SD) - PM FOR TH434/TH435 FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 9:28	231171037	YEARLY (SD) - PM FOR TH402 FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 9:32	231171030	YEARLY (SD) - PM FOR TL491 FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 9:37	231171035	YEARLY (SD) - PM FOR TE21/TH411 FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 9:41	231172266	YEARLY (SD) - PM FOR TH421 FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 9:45	231172267	YEARLY (SD) - PM FOR TH401 FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 9:50	231172263	YEARLY (SD) - PM FOR TH211 FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 9:55	231172264	YEARLY (SD) - PM FOR TL293 FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 9:59	231172265	YEARLY (SD) - PM FOR EMERGENCY FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 10:03	231171722	YEARLY (SD) - PM FOR TO NACL.03 BUS (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 10:08	231042690	YEARLY (SD) - PM FOR TH212/TL212 FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 10:12	231172238	YEARLY (SD) - PM FOR TH212 FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 10:16	231171468	YEARLY (SD) - PM FOR PULP DRYING FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 10:20	231171469	YEARLY (SD) - PM FOR NPS FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 10:24	231171470	YEARLY (SD) - PM FOR SWITCH GEAR 22KV BUS GEN. PULP 2 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 10:30	231171471	YEARLY (SD) - PM FOR OUT GOING TO EGAT FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 10:34	231171365	YEARLY (SD) - PM FOR TO 294AC3.1 FEEDER TIE BUS TRANSFER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 10:38	231171366	YEARLY (SD) - PM FOR DOUBLE CB 294AC1.16 FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 10:43	231171363	YEARLY (SD) - PM FOR INCOMING FROM GEN PP#11 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 10:48	231171507	YEARLY (SD) - PM FOR BUS METERING (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 10:53	231171502	YEARLY (SD) - PM FOR OUT GOING POWER BACK UP AAP2 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 10:58	231171503	YEARLY (SD) - PM FOR SWITCHGEAR 22KV TRANSFER PULP 2 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 11:03	231171333	YEARLY (SD) - PM FOR TO 294AC2.3 FEEDER TIE BUS TRANSFER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 11:07	231171461	YEARLY (SD) - PM FOR TE22/TH411 FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 11:12	231171462	YEARLY (SD) - PM FOR SPARE FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 11:16	231171463	YEARLY (SD) - PM FOR TO 294AC1.14 FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 11:21	231171464	YEARLY (SD) - PM FOR GROUNDING TRANSFORMER FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 11:26	231170940	YEARLY (SD) - PM FOR SPARE FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 11:30	231170943	YEARLY (SD) - PM FOR SPARE FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 11:34	231171511	YEARLY (SD) - PM FOR SPARE FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 11:40	231171512	YEARLY (SD) - PM FOR SPARE FEEDER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 11:44	231171505	YEARLY (SD) - PM FOR RECOVERY TRANSFORMER TE21 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 11:46	231172254	YEARLY (SD) - PM FOR TRANSFORMER TL412(E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 11:47	231170905	YEARLY (SD) - PM FOR TRANSFORMER TH412 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 11:49	231170860	YEARLY (SD) - PM FOR TRANSFORMER TE22 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 11:50	231170858	YEARLY (SD) - PM FOR RECTIFIER # A, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 11:52	231172253	YEARLY (SD) - PM FOR RECTIFIER # B, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 11:53	231172252	YEARLY (SD) - PM FOR RECTIFIER # C, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 11:55	231172250	YEARLY (SD) - PM FOR RECTIFIER # A, PRECIPITATOR # 2 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 11:56	231170861	YEARLY (SD) - PM FOR RECTIFIER # B, PRECIPITATOR # 2 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 11:58	231171368	YEARLY (SD) - PM FOR RECTIFIER # C, PRECIPITATOR # 2 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 11:59	231042664	YEARLY (SD) - PM FOR RECTIFIER #A, PRECIPITATOR # 3 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 12:01	231170955	YEARLY (SD) - PM FOR RECTIFIER #B, PRECIPITATOR #3 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 12:03	231171174	YEARLY (SD) - PM FOR RECTIFIER #C, PRECIPITATOR #3 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 12:04	231043523	YEARLY (SD) - PM FOR MILL WIDE TRANSFORMER TH211(E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 12:06	231172241	YEARLY (SD) - PM FOR MILL WIDE TRANSFORMER TH212(E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 12:07	231170828	YEARLY (SD) - PM FOR MILL WIDE TRANSFORMER TH291(E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 12:09	231172240	YEARLY (SD) - PM FOR MILL WIDE TRANSFORMER TH293(E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 12:10	231043521	YEARLY (SD) - PM FOR TL293E POWER BACK UP FROM EGAT (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 12:12	231043522	YEARLY (SD) - PM FOR AAP2 , TURBO GENERATOR TRANSFMR TD12 (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 12:13	231043527	YEARLY (SD) - PM FOR GROUNDING TRANSFORMER (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 12:15	231043080	YEARLY (SD) - PM FOR BATTERY CHARGER 110 VDC MILL WIDE (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 12:16	231043082	YEARLY (SD) - PM FOR BATTERY CHARGER 110 VDC for 22KV SYSTEM (E)	NPP5A_PP11
WL5215	Electrical PSD (SWG/Substation/Transf	20/10/2023 12:17	231043524	YEARLY (SD) - PM FOR MCC RECOVERY BOILER, UPS (E)	NPP5A_PP11
WL5212	Mechanical PSD (Turbine & Utility)	20/10/2023 12:18	231043526	YEARLY (SD) - PM FOR ROTARY FEEDER-GN BANK (M)	NPP5A_PP11
WL5212	Mechanical PSD (Turbine & Utility)	20/10/2023 12:18	231043084	YEARLY (SD) - PM FOR ROTARY FEEDER-ECO 2 (M)	NPP5A_PP11
WL5212	Mechanical PSD (Turbine & Utility)	20/10/2023 12:19	231043085	YEARLY (SD) - PM FOR ROTARY FEEDER-ECO 1 (M)	NPP5A_PP11
WL5212	Mechanical PSD (Turbine & Utility)	20/10/2023 12:19	231043525	YEARLY (SD) - PM FOR ROTARY FEEDER, ESP # 1 (M)	NPP5A_PP11
WL5212	Mechanical PSD (Turbine & Utility)	20/10/2023 12:20	231043076	YEARLY (SD) - PM FOR ROTARY FEEDER, ESP # 2 (M)	NPP5A_PP11
WL5212	Mechanical PSD (Turbine & Utility)	20/10/2023 12:20	231043077	YEARLY (SD) - PM FOR ROTARY FEED ESP#3 (M)	NPP5A_PP11
WL5213	Mechanical PSD (BOP)	20/10/2023 12:20	231043078	YEARLY (SD) - PM FOR ASH CONVEYOR-GN BANK (M)	NPP5A_PP11
WL5213	Mechanical PSD (BOP)	20/10/2023 12:21	231043086	YEARLY (SD) - PM FOR ASH CONVEYOR-ECO BANK 2 (M)	NPP5A_PP11
WL5213	Mechanical PSD (BOP)	20/10/2023 12:21	231042661	YEARLY (SD) - PM FOR ASH CONVEYOR-ECO BANK 1 (M)	NPP5A_PP11
WL5213	Mechanical PSD (BOP)	20/10/2023 12:22	231042662	YEARLY (SD) - PM FOR ASH COLLECTING CONVEYOR (M)	NPP5A_PP11
WL5213	Mechanical PSD (BOP)	20/10/2023 12:22	231042900	YEARLY (SD) - PM FOR DRAG SCRAPER, ESP # 1 SEE LONG DISCRIPTION (M)	NPP5A_PP11
WL5213	Mechanical PSD (BOP)	20/10/2023 12:23	231042899	YEARLY (SD) - PM FOR DRAG SCRAPER, ESP # 2 SEE LONG DISCRIPTION (M)	NPP5A_PP11
WL5213	Mechanical PSD (BOP)	20/10/2023 12:24	231042897	YEARLY (SD) - PM FOR COLLECTING CONVEYOR, ESP # 1 (M)	NPP5A_PP11
WL5213	Mechanical PSD (BOP)	20/10/2023 12:24	231042904	YEARLY (SD) - PM FOR COLLECTING CONVEYOR, ESP # 2 (M)	NPP5A_PP11
WL5213	Mechanical PSD (BOP)	20/10/2023 12:24	231042904	YEARLY (SD) - PM FOR ESP TRANSFER CONVEYOR # 1 (M)	NPP5A_PP11
WL5213	Mechanical PSD (BOP)	20/10/2023 12:24	231042905	YEARLY (SD) - PM FOR ESP TRANSFER CONVEYOR #2 (M)	NPP5A_PP11
WL5213	Mechanical PSD (BOP)	20/10/2023 12:25	231042836	YEARLY (SD) - PM FOR SCRAPER CONVEYER ESP.3 (M)	NPP5A_PP11
WL5213	Mechanical PSD (BOP)	20/10/2023 12:25	231171146	YEARLY (SD) - PM FOR COLLECTING CONVEYER ESP.3 (M)	NPP5A_PP11
WL5212	Mechanical PSD (Turbine & Utility)	20/10/2023 12:26	231042400	YEARLY (SD) - PM CLEAN FOR ID FAN # 1 (M)	NPP5A_PP11
WL5212	Mechanical PSD (Turbine & Utility)	20/10/2023 12:26	231042686	YEARLY (SD) - PM CLEAN FOR ID FAN # 2 (M)	NPP5A_PP11
WL5212	Mechanical PSD (Turbine & Utility)	20/10/2023 12:26	231042393	YEARLY (SD) - PM CLEAN FOR ID FAN #3 (M)	NPP5A_PP11

WL5212	Mechanical PSD (Turbine & Utility)	20/10/2023 12:26	231042911	YEARLY (SD) - PM CLEAN FOR FW PUMP #2 (M)	NPP5A_PP11
WL5212	Mechanical PSD (Turbine & Utility)	20/10/2023 12:26	231171257	YEARLY (SD) - PM CLEAN FOR FW PUMP #3 (M)	NPP5A_PP11
WL5213	Mechanical PSD (BOP)	20/10/2023 12:26	231171085	YEARLY (SD) - PM FOR SCREW CONVEYER ESP.3 (M)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	21/10/2023 22:00	231042541	2 WEEKS - INSPECTION DOSING PUMP	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 6:46	231042830	MONTHLY - PM FOR START-UP BURNER #1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 6:47	231170973	MONTHLY - PM FOR START-UP BURNER #2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 6:48	231042540	MONTHLY - PM FOR START-UP BURNER #3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 6:50	231042829	MONTHLY - PM FOR START-UP BURNER #4 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 6:51	231042539	WEEKLY - PM FOR GENERATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 6:52	231042828	WEEKLY - PM FOR LUP OIL PUMP FEED WATER PUMP 3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 6:55	231042542	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 6:57	231170974	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 6:59	231170975	2 WEEKS - PM VISUAL CHECK AND BASIC PDM FOR AGITATOR-DISSOLVING TANK SEE NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 7:03	231042831	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR # 1 (PO) NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 7:06	231042832	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR #2 (PO) NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 7:09	231170970	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR PRIMARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 7:13	231170971	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR SECONDARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 7:18	231040954	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR TERTIARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 7:23	231040955	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 7:29	231042395	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 7:36	231042396	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 7:43	231042398	MONTHLY - PM ROUTE REFILL LUBRICANT CHAIN CONVEYOR (GROUP2) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 7:43	231170843	MONTHLY - PM ROUTE REFILL OIL FAN COOLING TOWER (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 7:43	231170844	MONTHLY CLEANING AIR SUPPLY FILTER 452JB04	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 7:44	231171013	MONTHLY CLEANING AIR SUPPLY FILTER 452JB06	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 7:45	231042429	MONTHLY CLEANING AIR SUPPLY FILTER 452JB07	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 7:46	231042425	MONTHLY CLEANING AIR SUPPLY FILTER 452JB09	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 7:47	231042428	MONTHLY CLEANING AIR SUPPLY FILTER 463AD20	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 7:48	231170845	MONTHLY CLEANING AIR SUPPLY FILTER 463AD21	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 7:49	231042427	MONTHLY CLEANING AIR SUPPLY FILTER 463AD22	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 7:50	231171496	MONTHLY CLEANING AIR SUPPLY FILTER 463AD23	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 7:51	231171012	MONTHLY CLEANING AIR SUPPLY FILTER 463AD25A	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 7:52	231171497	MONTHLY CLEANING AIR SUPPLY FILTER 463AD25B	NPP5A_PP11
MS0103	Automation Service (Instrument)	22/10/2023 7:53	231171797	2 weeks check 463 Stack flue gas analyzer	NPP5A_PP11
MS0103	Automation Service (Instrument)	22/10/2023 7:58	231172070	calibrate 463 Stack flue gas analyzer (ISO14000)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 8:04	231042326	PM FOR FEEDWTR BLOCK VALVE 463HV150	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 8:05	231042343	PM FOR RAPID DRAIN GENBANK 463HV151B	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 8:06	231170986	PM FOR RAPID DRAIN DOWNCOMER 463HV152B	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 8:07	231170988	PM FOR STARTUP BLOCK VLV 463HV154	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 8:07	231170992	PM FOR MAIN STEAM VALVE 463HV155	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 8:08	231171140	PM FOR DISC CONT BLOWDOWN 463HV158	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 8:09	231043528	PM FOR STEAM VLV BYPASS 463HV171	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 8:10	231043529	MONTHLY - PM FOR RECOVERY TRANSFORMER TH411(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 8:11	231171417	MONTHLY - PM FOR EVAPORATION TRANSFORMER TH401(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 8:13	231171421	MONTHLY - PM FOR TURBO GEN. Transformer TD11 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 8:14	231171418	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 8:23	231171422	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 8:27	231171419	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 8:30	231171423	WEEKLY - PM ROUTE CHECK SWITCHGEAR (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	22/10/2023 8:33	231171420	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR STEAM TURBINE,32900KW (PO)	NPP5A_PP11
MS0103	Automation Service (Control)	22/10/2023 8:37	231171424	2 WEEKS - PM FOR PLC TURBINE & GENERATOR GOVERNOR CONTROL (A)	NPP5A_PP11
MS0103	Automation Service (Control)	22/10/2023 8:43	231171426	2 WEEKS - PM FOR HMI TURBINE & GENERATOR GOVERNOR CONTROL (A)	NPP5A_PP11
MS0103	Automation Service (Control)	22/10/2023 8:44	231171415	2 WEEKS - PM FOR HMI RODDING MASTER (463CP60) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	22/10/2023 8:44	231042818	2 WEEKS - PM FOR HMI RODDING MASTER (463CP61) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	22/10/2023 8:44	231043550	2 WEEKS - PM FOR HMI BMS (A)	NPP5A_PP11
MS0103	Automation Service (Control)	22/10/2023 8:45	231043551	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #1 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	22/10/2023 8:45	231043552	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #2 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	22/10/2023 8:45	231043554	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #3 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	22/10/2023 8:46	231043555	2 WEEKS - PM FOR PLC RODDING MASTER (463CP60) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	22/10/2023 8:47	231172262	2 WEEKS - PM FOR PLC RODDING MASTER (463CP61) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	22/10/2023 8:48	231172257	2 WEEKS - PM FOR PLC BMS (A)	NPP5A_PP11
MS0103	Automation Service (Control)	22/10/2023 8:49	231170913	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #1 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	22/10/2023 8:51	231172258	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #2 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	22/10/2023 8:52	231171389	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #3 (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/10/2023 18:01	231171396	MONTHLY - INSPECTION AGITATOR	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/10/2023 18:06	231171391	MONTHLY - PM ROUTE CHECK MOTOR RAPPER ESP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	23/10/2023 18:08	231171399	MONTHLY - PM ROUTE REFILL LUBRICANT CHAIN CONVEYOR (GROUP3) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	25/10/2023 3:20	231171393	3 MONTHS - PM FOR CONDUCTIVITY SUMP PIT (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/10/2023 3:22	231171401	MONTHLY - PM FOR RECOVERY BOILER OS2101 (OSS01) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/10/2023 3:23	231171404	MONTHLY - PM FOR RECOVERY BOILER OS2102 (OSS02) (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/10/2023 3:24	231171406	MONTHLY - PM FOR MILL WIDE OS2103 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/10/2023 3:25	231171409	MONTHLY - PM FOR MILL WIDE OS2104 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/10/2023 3:26	231171451	MONTHLY - PM FOR EVAPORATOR OS2105 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/10/2023 3:28	231171079	MONTHLY - PM FOR EVAPORATOR OS2106 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/10/2023 3:29	231040950	MONTHLY - PM FOR UPS A FOR DCS BOILER PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/10/2023 3:29	231171010	MONTHLY - PM FOR UPS B FOR DCS BOILER PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/10/2023 3:30	231170983	MONTHLY - PM FOR UPS FOR INSTRUMENT RECOVERY BOILER (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/10/2023 3:30	231171017	MONTHLY - PM FOR UPS A FOR DCS TURBINE PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/10/2023 3:31	231171491	MONTHLY - PM FOR UPS B FOR DCS TURBINE PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/10/2023 3:31	231171492	MONTHLY - PM FOR UPS A FOR DCS EVAP PP11 (A)	NPP5A_PP11

MS0103	Automation Service (Control)	25/10/2023 3:32	231171117	MONTHLY - PM FOR UPS B FOR DCS EVAP PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/10/2023 3:32	231171001	MONTHLY - PM FOR UPS 01 FOR DCS CONTROL ROOM PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/10/2023 3:33	231171002	MONTHLY - PM FOR BATTERY FOR 463UPS-A DCS BOILER PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/10/2023 3:34	231170998	MONTHLY - PM FOR BATTERY FOR 463UPS-B DCS BOILER PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/10/2023 3:34	231170999	MONTHLY - PM FOR BATTERY FOR 463UPS-C INSTRUMENT PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/10/2023 3:35	231171047	MONTHLY - PM FOR BATTERY FOR 293UPS-A DCS TURBINE PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/10/2023 3:36	231171049	MONTHLY - PM FOR BATTERY FOR 293UPS-B DCS TURBINE PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/10/2023 3:37	231170996	MONTHLY - PM FOR BATTERY FOR 452UPS-A DCS EVAP PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/10/2023 3:37	231171005	MONTHLY - PM FOR BATTERY FOR 452UPS-B DCS EVAP PP11 (A)	NPP5A_PP11
MS0103	Automation Service (Control)	25/10/2023 3:38	231171006	MONTHLY - PM FOR BATTERY FOR 463UPS-CR01 DCS CONTROL ROOM PP11 (A)	NPP5A_PP11
MS0024	Predictive Maintenance	25/10/2023 3:39	231170997	Monthly vibration check for Plan 262	NPP5A_PP11
MS0024	Predictive Maintenance	25/10/2023 3:39	231171048	Monthly vibration check for Plan 282	NPP5A_PP11
MS0024	Predictive Maintenance	25/10/2023 3:41	231171003	Monthly vibration check for Plan 293	NPP5A_PP11
MS0024	Predictive Maintenance	25/10/2023 3:42	231171004	Monthly vibration check for Plan 452	NPP5A_PP11
MS0024	Predictive Maintenance	25/10/2023 3:45	231171137	Monthly vibration check for Plan 463	NPP5A_PP11
MS0024	Predictive Maintenance	25/10/2023 3:47	231042305	Monthly oil Sampling for area 463	NPP5A_PP11
MS0024	Predictive Maintenance	25/10/2023 3:49	231042357	Monthly oil Sampling for area 293	NPP5A_PP11
MS0093	Electrical Service (Control)	25/10/2023 6:13	231042358	Monthly - Inspect Thermoscan NPP11	NPP5A_PP11
MS0093	Electrical Service (Control)	25/10/2023 6:14	231042310	Monthly - Inspect Thermoscan NPP11	NPP5A_PP11
MS0093	Electrical Service (Control)	25/10/2023 6:17	231171070	Monthly - Inspect Partial Discharge PP11	NPP5A_PP11
MS0093	Electrical Service (Control)	25/10/2023 6:17	231042421	Monthly - Inspect Partial Discharge PP11	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	25/10/2023 6:18	231042548	2 Weeks - PM Inspection Absorption Chiller PP11	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	25/10/2023 6:19	231042812	2 Weeks - PM Inspection Absorption Chiller PP11	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	25/10/2023 6:19	231042797	2 Weeks - PM Inspection Absorption Chiller PP11	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	25/10/2023 6:20	231042810	2 Weeks - PM Inspection Absorption Chiller PP11	NPP5A_PP11
WL1521	MAINTENANCE EMERGENCY (TEAM A)	27/10/2023 14:46	231042725	WEEKLY - INSPECTION CAMERA	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/10/2023 14:49	231171482	MONTHLY - PM FOR CONDUCTIVITY INDICATION OF FEED WATER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/10/2023 14:51	231171481	MONTHLY - PM FOR CONDUCTIVITY INDICATION OF DEMIN WATER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/10/2023 14:53	231170967	MONTHLY - PM FOR CONDUCTIVITY INDICATION AFTER ANION EXCHANGER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/10/2023 14:55	231171016	MONTHLY - PM FOR CONDUCTIVITY INDICATION AFTER MIXED BED EXCHANGER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/10/2023 14:57	231042808	MONTHLY - PM FOR CONDUCTIVITY INDICATION AFTER ANION EXCHANGER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/10/2023 14:59	231042809	MONTHLY - PM FOR CONDUCTIVITY INDICATION AFTER MIXED BED EXCHANGER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/10/2023 15:01	231171121	MONTHLY - PM FOR CONDUCT. SUM (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/10/2023 15:03	231042777	MONTHLY - PM FOR CONDUCTIVITY SUMP PIT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/10/2023 15:05	231042873	MONTHLY - PM FOR condensate from fibre line (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/10/2023 15:07	231171474	MONTHLY - PM FOR COND FRM EVAP PLANT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/10/2023 15:09	231171460	MONTHLY - PM FOR COND FROM TURBINE (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/10/2023 15:11	231171476	MONTHLY - PM FOR COND FROM PULP DRYER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/10/2023 15:16	231171052	2 MONTHS - PM FOR VAPOR EXTRACTOR, SEPARATION OF OIL MIST. SEE L.D. (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/10/2023 15:19	231042887	MONTHLY- PM FOR BATTERY CHARGER 110 VDC for 22KV SYSTEM (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/10/2023 15:20	231042745	MONTHLY - PM FOR FIRE FIGHTING MILL WIDE (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/10/2023 15:21	231042744	MONTHLY - PM FOR CO2 FIRE ALARM & FIRE FIGHTING OF TURBINE (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/10/2023 15:22	231042742	MONTHLY - PM FOR FIRE FIGHTING EVAPORATION (E)	NPP5A_PP11
MS0104	Automation Service (Control)	27/10/2023 15:23	231171261	monthly inspection Evaporation DCS Controller (A)	NPP5A_PP11
MS0104	Automation Service (Control)	27/10/2023 15:30	231042391	monthly inspection Mill Wide DCS Controller (A)	NPP5A_PP11
MS0104	Automation Service (Control)	27/10/2023 15:37	231042778	monthly inspection Soot Blower DCS Controller (A)	NPP5A_PP11
MS0104	Automation Service (Control)	27/10/2023 15:44	231042871	monthly inspection RecoveryBoiler DCS Controller (A)	NPP5A_PP11
MS0104	Automation Service (Control)	27/10/2023 15:51	231042394	monthly inspection for R.B. DCS Power Distrib. (A)	NPP5A_PP11
MS0104	Automation Service (Control)	27/10/2023 15:53	231042397	monthly inspection for Evapor DCS Power Distrib. (A)	NPP5A_PP11
MS0104	Automation Service (Control)	27/10/2023 15:55	231042653	monthly inspection for MillWideDCS Power Distrib. (A)	NPP5A_PP11
MS0093	Electrical Service (Control)	28/10/2023 6:45	231171258	Monthly - Inspect Thermoscan NPP11	NPP5A_PP11
MS0093	Electrical Service (Control)	28/10/2023 6:47	231171260	Monthly - Inspect Partial Discharge PP11	NPP5A_PP11
MS0093	Electrical Service (Power) IP1	28/10/2023 6:48	231042768	2 Weeks - PM Inspection Absorption Chiller PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	28/10/2023 22:00	231042769	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	28/10/2023 22:04	231042423	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	28/10/2023 22:08	231042424	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	28/10/2023 22:12	231042846	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR CONTROL OIL PUMP #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	28/10/2023 22:16	231171472	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR CONTROL OIL PUMP # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	28/10/2023 22:20	231171473	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR LUBE OIL PUMP #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	28/10/2023 22:24	231042913	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR LUBE OIL PUMP # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	29/10/2023 6:50	231042417	WEEKLY - PM FOR GENERATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	29/10/2023 6:51	231042843	WEEKLY - PM FOR LUP OIL PUMP FEED WATER PUMP 3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	29/10/2023 6:54	231171128	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	29/10/2023 6:57	231171144	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	29/10/2023 6:59	231042401	2 WEEKS - PM VISUAL CHECK AND BASIC PDM FOR AGITATOR-DISSOLVING TANK SEE NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	29/10/2023 7:04	231042402	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	29/10/2023 7:07	231042687	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR #2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	29/10/2023 7:10	231171452	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR PRIMARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	29/10/2023 7:15	231042842	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR SECONDARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	29/10/2023 7:20	231170963	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR TERTIARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	29/10/2023 7:26	231171162	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	29/10/2023 7:33	231042838	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	29/10/2023 7:40	231171161	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN #3 (PO)	NPP5A_PP11
MS0103	Automation Service (Instrument)	29/10/2023 7:48	231042795	calibrate 463 Stack flue gas analyzer (ISO14000)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	29/10/2023 7:54	231171124	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	29/10/2023 8:04	231171245	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	29/10/2023 8:08	231172048	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	29/10/2023 8:13	231042833	WEEKLY - PM ROUTE CHECK SWITCHGEAR (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	29/10/2023 8:15	231172255	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR STEAM TURBINE,32900KW (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	29/10/2023 8:20	231172256	MONTHLY - PM FOR SOOTBLOWER 1, LEFT (E)	NPP5A_PP11

WL1320	PP5,6,10,11 OPERATION	29/10/2023 8:21	231042384	MONTHLY - PM FOR SOOTBLOWER 2, LEFT (E)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	29/10/2023 8:22	231042385	2 WEEKS - PM FOR 115 KV SUBSTATION AAP2 (E)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	1/11/2023 0:00	231042372	MONTHLY - PM FOR 115 KV SUBSTATION AAP2 (E)	NPP5A_PP11
WL5216	PSD AUTO-ALL	1/11/2023 0:02	231042644	YEARLY (SD) - PM FOR FEEDWATER TO R/B HEAD MOUNTED TEMP.TRANSMITTER (A)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	3/11/2023 17:01	231042315	WEEKLY - INSPECTION CAMERA	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	4/11/2023 6:07	231171142	WEEKLY - PM FOR GENERATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	4/11/2023 6:09	231171412	WEEKLY - PM FOR LUP OIL PUMP FEED WATER PUMP 3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	4/11/2023 6:12	231171428	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	4/11/2023 6:15	231171427	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	4/11/2023 6:18	231171429	2 WEEKS - PM VISUAL CHECK AND BASIC PDM FOR AGITATOR-DISSOLVING TANK SEE NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	4/11/2023 6:23	231171430	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	4/11/2023 6:26	231171431	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR #2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	4/11/2023 6:29	231171478	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR PRIMARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	4/11/2023 6:35	231171123	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR SECONDARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	4/11/2023 6:41	231170952	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR TERTIARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	4/11/2023 6:46	231171334	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	4/11/2023 6:54	231171342	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	4/11/2023 7:01	231171141	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN #3 (PO)	NPP5A_PP11
MS0103	Automation Service (Instrument)	4/11/2023 7:10	231170978	calibrate 463 Stack flue gas analyzer (ISO14000)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	4/11/2023 7:17	231171953	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	4/11/2023 7:27	231171480	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	4/11/2023 7:32	231171390	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	4/11/2023 7:36	231171398	WEEKLY - PM ROUTE CHECK SWITCHGEAR (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	4/11/2023 7:39	231171392	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR STEAM TURBINE,32900KW (PO)	NPP5A_PP11
MS0104	Automation Service (Control)	6/11/2023 7:25	231171400	MONTHLY - PM FOR MILLWIDE DCS CONTROLLER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/11/2023 7:28	231171394	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 2 FOR AREA 182 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/11/2023 7:34	231171402	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 4 FOR AREA 452 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/11/2023 7:38	231171408	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 5 FOR AREA 452 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/11/2023 7:40	231171410	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 10 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/11/2023 7:44	231171405	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 11 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/11/2023 7:46	231172260	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 12 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/11/2023 7:50	231170929	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 13 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/11/2023 7:52	231171349	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 14 FOR AREA 463 (PO)	NPP5A_PP11
MS0103	Automation Service (Instrument)	6/11/2023 7:55	231170927	2 weeks check 463 Stack flue gas analyzer	NPP5A_PP11
MS0104	Automation Service (Control)	6/11/2023 8:03	231172259	2 WEEKS - PM FOR PLC TURBINE & GENERATOR GOVERNOR CONTROL (A)	NPP5A_PP11
MS0104	Automation Service (Control)	6/11/2023 8:13	231170947	2 WEEKS - PM FOR HMI TURBINE & GENERATOR GOVERNOR CONTROL (A)	NPP5A_PP11
MS0104	Automation Service (Control)	6/11/2023 8:14	231154842	2 WEEKS - PM FOR HMI RODDING MASTER (463CP60) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	6/11/2023 8:14	231154843	2 WEEKS - PM FOR HMI RODDING MASTER (463CP61) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	6/11/2023 8:15	231042724	2 WEEKS - PM FOR HMI BMS (A)	NPP5A_PP11
MS0104	Automation Service (Control)	6/11/2023 8:15	231042789	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #1 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	6/11/2023 8:16	231040944	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #2 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	6/11/2023 8:16	231042883	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #3 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	6/11/2023 8:17	231042882	2 WEEKS - PM FOR PLC RODDING MASTER (463CP60) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	6/11/2023 8:18	231170954	2 WEEKS - PM FOR PLC RODDING MASTER (463CP61) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	6/11/2023 8:20	231171080	2 WEEKS - PM FOR PLC BMS (A)	NPP5A_PP11
MS0104	Automation Service (Control)	6/11/2023 8:22	231170980	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #1 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	6/11/2023 8:23	231042688	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #2 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	6/11/2023 8:25	231170981	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #3 (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	7/11/2023 6:25	231171438	MONTHLY - PM FOR BATTERY FOR 293NU01 CHARGER 110 VDC MILL WIDE BANK#1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	7/11/2023 6:26	231170870	MONTHLY - PM FOR BATTERY FOR 293NU01 CHARGER 110 VDC MILL WIDE BANK#2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	7/11/2023 6:27	231042689	MONTHLY - PM FOR BATTERY 110 VDC FOR Communication 115 kV (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	7/11/2023 6:28	231170958	MONTHLY - PM FOR BATTERY FOR 294BTN01 CHARGER 48VDC FOR 115KV NPP11 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	7/11/2023 6:29	231042551	MONTHLY - PM FOR BATTERY FOR 463UPS01 MCC RECOVERY BOILER, UPS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	7/11/2023 6:29	231189376	MONTHLY - PM FOR BATTERY FOR 294NU01 CHARGER 110 VDC FOR 22KV SYSTEM (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	7/11/2023 6:30	231171096	MONTHLY - PM FOR BATTERY FOR 293UPS01 MCC MILL WIDE, UPS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	7/11/2023 6:31	231171271	MONTHLY - PM FOR CHARGER 110 VDC FOR Communication 115 kV (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	7/11/2023 6:32	231171268	MONTHLY - PM FOR CHARGER 48VDC FOR 115KV NPP11 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	7/11/2023 6:33	231171269	MONTHLY - ROUTE PM FOR INSPECTION FABRIC EXPANSION JOINT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	7/11/2023 6:37	231171439	MONTHLY - PM REFILL LUBRICANT FOR AGITATOR STRONG LIQUOR STORAGE TANK (NPP5A_PP11)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 6:32	231171440	MONTHLY - PM FOR START-UP BURNER #5 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 6:34	231171442	MONTHLY - PM FOR START-UP BURNER #6 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 6:35	231171443	MONTHLY - PM FOR ELECTROSTATIC PRECIPITATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 6:38	231042823	MONTHLY - PM FOR ELECTROSTATIC PRECIPITATOR # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 6:41	231042822	MONTHLY - PM FOR ESP #3(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 6:44	231042535	MONTHLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 6:45	231042537	MONTHLY - PM FOR RECOVERY TRANSFORMER TE21(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 6:47	231042538	MONTHLY - PM FOR TRANSFORMER TL412(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 6:49	231042837	MONTHLY - PM FOR TRANSFORMER TH412(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 6:51	231042536	MONTHLY - PM FOR RECTIFIER # A, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 6:53	231042779	MONTHLY - PM FOR RECTIFIER # B, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 6:55	231042359	MONTHLY - PM FOR RECTIFIER # C, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 6:56	231042362	MONTHLY - PM FOR RECTIFIER # A, PRECIPITATOR # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 6:58	231042361	MONTHLY - PM FOR RECTIFIER # B, PRECIPITATOR # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:00	231171108	MONTHLY - PM FOR RECTIFIER # C, PRECIPITATOR # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:02	231171107	MONTHLY - PM FOR RECTIFIER #A, PRECIPITATOR # 3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:04	231171283	MONTHLY - PM FOR RECTIFIER #B, PRECIPITATOR #3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:06	231171284	MONTHLY - PM FOR RECTIFIER #C, PRECIPITATOR #3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:08	231171285	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH211(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:10	231171286	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH212(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:12	231171105	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH291(E)	NPP5A_PP11

WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:14	231171280	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH293(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:16	231171106	MONTHLY - PM FOR TL293E POWER BACK UP FROM EGAT (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:18	231171281	MONTHLY - PM FOR AAP2 , TURBO GENERATOR TRANSFMR TD12 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:20	231042517	MONTHLY - PM FOR GROUNDING TRANSFORMER (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:22	231042520	MONTHLY - INSPECTION PUMP	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:36	231042530	MONTHLY - PM ROUTE REFILL LUBRICANT BEARING FAN FOR IDFAN(GROUP2) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:36	231171448	MONTHLY - PM ROUTE REFILL LUBRICANT BEARING FAN FOR IDFAN(GROUP3) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:37	231171446	PM FOR FEEDWTR BY-PASS VLV 463HV172	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:38	231042309	PM FOR SOOTBLWR STEAM HDR 463HV181	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:39	231042523	MONTHLY - PM FOR AL21 BUS 6.6KV FEED WATER PUMP P003 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:41	231042549	MONTHLY - PM FOR AL22 SWG 6.6KV FEED WATER PUMP P050 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:43	231042392	MONTHLY - PM FOR EGAT OUT GOING TRANSFORMER TC3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:45	231171130	MONTHLY - PM FOR VSD OF FIRING LIQUOR PUMP #1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:46	231042841	MONTHLY - PM FOR VSD OF FIRING LIQUOR PUMP #2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:47	231042740	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:51	231042739	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 7:56	231170886	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR ACID DOSING PUMP #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 8:01	231171520	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR ACID DOSING PUMP #2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 8:07	231170889	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR EMERGENCY OIL PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 8:12	231171524	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR GLAND COND DRAIN PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 8:18	231171411	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 A PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 8:23	231171165	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 B PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 8:30	231170993	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 C PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 8:35	231171164	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 D PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 8:41	231171395	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 A PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 8:47	231171403	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 B PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 8:53	231171093	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 C PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 8:58	231170994	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 1 D PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 9:03	231171262	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION 2 PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 9:09	231042814	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR EFFECT II-I LIQ .TRANSF PUMP (F NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 9:14	231150903	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR EFFECT III CIRCULATE PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 9:20	231171358	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR EFFECT III-II LIQ TRANSF PUMP (NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 9:25	231171256	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR EFFECT IV CIRCULATE PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 9:31	231171487	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR EFFECT V CIRCULATE PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 9:36	231171488	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR PRIMARY CONDENSATE PUMP (PC NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 9:42	231042806	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FOUL CONDENSATE PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 9:47	231042800	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SEC. CONDENSATE II PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 9:53	231171381	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FOUL COND. VAC. PIT DWG (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 9:58	231171383	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR VACUUM PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 10:04	231171255	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR VACUUM PUMP (STAND-BY) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 10:09	231172239	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR REFLUX CONDENSATE (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 10:14	231172136	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR WASH LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 10:19	231171066	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR COMBINED CONDENSATE (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 10:25	231171050	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FEED LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 10:30	231042799	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQ FLASH TNK PUMP#1 (NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 10:35	231042874	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQ FLASH TNK PUMP#1 (NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 10:40	231171103	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR DESUPERHEATER PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 10:46	231171125	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR STRONG LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 10:51	231171265	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR STRONG LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 10:56	231171015	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR WARM WATER PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 11:02	231171014	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SECONDARY CONDENSATE PUMP	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 11:07	231171385	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SUMP PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 11:13	231170976	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR STRONG LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 11:18	231171175	MONTHLY - PM FOR BMS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 11:19	231171246	MONTHLY - PM FOR BOX MAIN SUPPLY BURNER (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 11:21	231042733	MONTHLY - PM FOR AH411 MCC 690V RECOVERY BOILER #2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 11:23	231042645	MONTHLY - PM FOR AH412 MCC 690V RECOVERY BOILER #2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 11:25	231171176	MONTHLY - PM FOR AL412 MCC 400V ESP#3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 11:30	231042405	MONTHLY - PM FOR AH401 MCC 690V EVAPORATOR PULP 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 11:32	231042864	MONTHLY - PM FOR AH211 MCC. 690V MILL WIDE #1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 11:34	231042404	MONTHLY - PM FOR AH212 MCC. 690V MILL WIDE #2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 11:36	231042863	MONTHLY - PM FOR AL291 EMERGENCY POWER SUPPLY 400 VAC (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/11/2023 11:38	231171493	MONTHLY - PM FOR AL293 NORMAL POWER SUPPLY 400 VAC (E)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	11/11/2023 12:07	231171495	WEEKLY - INSPECTION CAMERA	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 12:10	231170902	WEEKLY - PM FOR GENERATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 12:12	231171517	WEEKLY - PM FOR LUP OIL PUMP FEED WATER PUMP 3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 12:16	231042410	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 12:19	231042413	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 12:22	231042860	MONTHLY - PM FOR BATTERY CHARGER 110 VDC MILL WIDE (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 12:23	231042861	MONTHLY - PM FOR MCC MILL WIDE, UPS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 12:24	231171148	MONTHLY - PM FOR BATTERY CHARGER 110 VDC MILL WIDE (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 12:24	231171150	MONTHLY - PM FOR MCC MILL WIDE, UPS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 12:25	231172057	MONTHLY - PM FOR SCRUBBER FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 12:31	231171465	2 WEEKS - PM VISUAL CHECK AND BASIC PDM FOR AGITATOR-DISSOLVING TANK SEE NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 12:37	231171466	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR ASH COLLECTING CONVEYOR (PO NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 12:40	231171516	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR DRAG SCRAPER, ESP # 1 SEE LON NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 12:44	231171101	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR DRAG SCRAPER, ESP # 2 SEE LON NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 12:47	231171061	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR COLLECTING CONVEYOR, ESP # 1 NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 12:51	231171063	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR COLLECTING CONVEYOR, ESP # 2 NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 12:55	231171170	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SCRAPER CONVEYER ESP.3 (PO)	NPP5A_PP11

WL1320	PP5,6,10,11 OPERATION	11/11/2023 12:58	231171157	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR COLLECTING CONVEYER ESP.3 (P NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 13:02	231171181	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR # 1 (PO NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 13:06	231171110	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR #2 (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 13:09	231171042	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR PRIMARY FD FAN (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 13:16	231171043	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR SECONDARY FD FAN (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 13:23	231171166	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR TERTIARY FD FAN (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 13:31	231171071	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 1 (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 13:40	231171074	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 2 (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 13:50	231171172	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN #3 (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 14:00	231042526	MONTHLY - PM FOR FIRE FIGHTING SWITCH GEAR (E) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 14:01	231171113	MONTHLY - PM ROUTE REFILL LUBRICANT CHAIN CONVEYOR (GROUP1) (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 14:02	231171159	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP A (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 14:04	231171183	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP B (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 14:06	231171053	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP C (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 14:07	231171056	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP D (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 14:09	231171167	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP E (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 14:10	231171122	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP F (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 14:11	231171156	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP G (PO) NPP5A_PP11
MS0103	Automation Service (Instrument)	11/11/2023 14:12	231042527	calibrate 463 Stack flue gas analyzer (ISO14000) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 14:20	231042671	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #1 (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 14:25	231042665	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #2 (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 14:34	231042679	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #3 (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 14:46	231042668	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR DUMP TANK PUMP (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 14:52	231042678	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SPILL COLLECTION PUMP (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 14:57	231042667	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SCRUBBER RECIRCULATION PUMI NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 15:02	231042677	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR GREEN LIQ TRANSFER PUMP #1 (NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 15:08	231042666	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR GREEN LIQ TRANSFER PUMP #2 (NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 15:13	231042676	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SPOUT COOLING WATER PUMP # NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 15:19	231042680	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SPOUT COOLING WATER PUMP # NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 15:24	231171135	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CIRCULATION PUMP (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 15:29	231171131	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CONDENSATE FEED PUMP#A (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 15:35	231171133	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CONDENSATE FEED PUMP#B (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 15:41	231042377	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 15:46	231042378	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 15:51	231042328	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CONDENSATE PUMP NO. 1 (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 15:57	231042344	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR CONDENSATE PUMP NO. 2 (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 16:03	231042329	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 1, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 16:08	231042346	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 2, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 16:13	231042330	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 3, RIGHT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 16:17	231042347	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 4, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 16:22	231042368	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 5, RIGHT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 16:27	231042371	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 6, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 16:31	231042513	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 7, RIGHT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 16:36	231042528	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 8, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 16:41	231042316	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 9, RIGHT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 16:45	231042333	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 10, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 16:50	231042318	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 11, RIGHT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 16:55	231042335	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 12, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 17:00	231042334	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 13, RIGHT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 17:05	231042317	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 14, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 17:10	231042375	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 15, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 17:15	231042376	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 16, RIGHT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 17:19	231042514	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 17, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 17:24	231171088	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 18, RIGHT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 17:28	231042353	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 19, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 17:33	231042352	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 20, RIGHT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 17:37	231042350	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 21, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 17:41	231042868	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 22, RIGHT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 17:46	231042869	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 23, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 17:50	231171189	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 24, RIGHT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 17:54	231042365	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 25, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 17:59	231042516	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 26, RIGHT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 18:03	231042532	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 27, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 18:08	231040952	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 28, RIGHT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 18:12	231042364	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 29, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 18:17	231042521	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 30, RIGHT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 18:21	231042529	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 31, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 18:26	231042867	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 32, RIGHT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 18:30	231171197	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 33, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 18:34	231042821	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 34, RIGHT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 18:38	231171089	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 35, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 18:43	231042647	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 36, RIGHT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 18:47	231040945	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 37, RIGHT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 18:52	231040948	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 38, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 18:56	231042884	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 39, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 19:00	231042885	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 40, RIGHT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 19:05	231170960	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 41, LEFT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 19:09	231171139	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 42, RIGHT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 19:13	231040953	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 43, RIGHT (PO) NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 19:18	231042890	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 44 (PO) NPP5A_PP11

WL1320	PP5,6,10,11 OPERATION	11/11/2023 19:22	231042783	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 45, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 19:26	231042355	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 46, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 19:30	231042792	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 47, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 19:35	231042807	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 48, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 19:39	231171058	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 49, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 19:43	231171059	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 50, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 19:48	231042794	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 51, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 19:52	231042791	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 52, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 19:56	231042886	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 353, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 20:01	231042790	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 354, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 20:05	231171118	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 355, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 20:09	231171154	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 356, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 20:13	231171177	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 357, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 20:18	231042784	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 358, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 20:22	231042798	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 359, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 20:26	231042813	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 360, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 20:31	231042726	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER #61 LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 20:35	231042728	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER # 62 RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 20:39	231042729	WEEKLY - PM ROUTE CHECK SWITCHGEAR (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 20:42	231171484	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR STEAM TURBINE,32900KW (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/11/2023 20:47	231171483	MONTHLY - PM FOR SCRUBBER FAN (E)	NPP5A_PP11
MS0094	Electrical Service (Power) IP1	11/11/2023 22:49	231042663	2 Weeks - PM Inspection Absorption Chiller PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/11/2023 9:09	231042732	2 MONTHS - PM FOR AGITATOR-SBL MIX TANK SEE LONG DISCRPTION (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/11/2023 9:12	231042650	2 MONTHS - PM FOR ASH CRUSHER, GEN BANK(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/11/2023 9:15	231042651	MONTHLY - PM FOR AIR COMPRESSOR NO.1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/11/2023 9:18	231042652	MONTHLY - PM FOR AIR COMPRESSOR NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/11/2023 9:21	231042649	MONTHLY - PM FOR AIR COMPRESSOR NO.3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/11/2023 9:25	231042766	MONTHLY - PM FOR AIR COMPRESSOR NO.4 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/11/2023 9:28	231042670	MONTHLY - PM FOR MCC RECOVERY BOILER, UPS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/11/2023 9:28	231171134	MONTHLY - PM FOR AIR COMPRESSOR NO.1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/11/2023 9:36	231042682	MONTHLY - PM FOR AIR COMPRESSOR NO.2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/11/2023 9:44	231042669	MONTHLY - PM FOR AIR COMPRESSOR NO.3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/11/2023 9:52	231042681	MONTHLY - PM FOR AIR COMPRESSOR NO.4 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/11/2023 10:00	231042684	MONTHLY CLEANING AIR SUPPLY FILTER 463AD26	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/11/2023 10:02	231042683	MONTHLY CLEANING AIR SUPPLY FILTER 463AD27	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/11/2023 10:03	231042674	MONTHLY CLEANING AIR SUPPLY FILTER 282AS21	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/11/2023 10:04	231042685	MONTHLY CLEANING AIR SUPPLY FILTER 282AS22	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/11/2023 10:06	231171132	2 MONTHS - PM FOR MOTOR ROTARY FEEDER, ESP # 1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/11/2023 10:09	231042673	2 MONTHS - PM FOR MOTOR ROTARY FEEDER, ESP # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/11/2023 10:12	231042547	2 MONTHS - PM FOR MOTOR ROTARY FEED ESP#3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	12/11/2023 10:15	231171320	2 MONTHS - PM FOR MOTOR SCREW CONVEYER ESP.3 (E)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	12/11/2023 10:18	231042845	2 WEEKS - PM FOR 115 KV SUBSTATION AAP2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	13/11/2023 23:55	231171109	MONTHLY - PM REFILL LUBRICANT FOR AGITATOR-DISSOLVING TANK SEE LONG DISC	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	13/11/2023 23:55	231171510	MONTHLY - PM REFILL LUBRICANT FOR AGITATOR-DISSOLVING TANK SEE LONG DISC	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	13/11/2023 23:55	231171508	MONTHLY - PM ROUTE REFILL LUBRICANT BEARING FAN FOR IDFAN(GROUP1) (PO)	NPP5A_PP11
MS0103	Automation Service (Intrument)	13/11/2023 23:56	231170827	Monthly PM Dust meter "Sick"(ISO 14000)	NPP5A_PP11
MS0103	Automation Service (Intrument)	13/11/2023 23:58	231170831	Monthly PM for 463QI490 DO after Feed water pump	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	15/11/2023 9:30	231171228	MONTHLY - INSPECTION PH TR	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	15/11/2023 9:39	231171229	MONTHLY - INSPECTION PH TR	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	15/11/2023 9:41	231171231	MONTHLY - INSPECTION PH	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	15/11/2023 9:42	231171232	MONTHLY - PM FOR BL-SPRAYER DIVERT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	15/11/2023 9:45	231171233	MONTHLY - PM FOR BL-SPRAYER DIVERT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	15/11/2023 9:47	231171234	MONTHLY - PM FOR BL-SPRAYER DIVERT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	15/11/2023 9:50	231171289	MONTHLY - PM FOR BL .SPRAYER DIVERT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	15/11/2023 9:53	231171290	MONTHLY - PM FOR TRANSFORMER TE22(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	15/11/2023 9:55	231171291	MONTHLY - PM FOR FIRE FIGHTING RECOVERY BOILER (E)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	17/11/2023 3:22	231171102	WEEKLY - INSPECTION CAMERA	NPP5A_PP11
MS0104	Automation Service (Control)	17/11/2023 3:25	231171129	YEARLY (SD) - PM PLC TURBINE & GENERATOR GOVERNOR CONTROL (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/11/2023 3:25	231171062	YEARLY (SD) - PM HMI TURBINE & GENERATOR GOVERNOR CONTROL (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/11/2023 3:26	231171064	YEARLY (SD) - PM HMI RODDING MASTER (463CP60) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/11/2023 3:26	231171171	YEARLY (SD) - PM HMI RODDING MASTER (463CP61) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/11/2023 3:26	231171158	YEARLY (SD) - PM HMI BMS (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/11/2023 3:26	231171182	YEARLY (SD) - PM HMI ABSORPTION CHILLER #1 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/11/2023 3:27	231171111	YEARLY (SD) - PM HMI ABSORPTION CHILLER #2 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/11/2023 3:27	231171072	YEARLY (SD) - PM HMI ABSORPTION CHILLER #3 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/11/2023 3:27	231171075	YEARLY (SD) - PM PLC RODDING MASTER (463CP60) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/11/2023 3:27	231171173	YEARLY (SD) - PM PLC RODDING MASTER (463CP61) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/11/2023 3:28	231171115	YEARLY (SD) - PM PLC BMS (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/11/2023 3:28	231171160	YEARLY (SD) - PM FOR PLC ABSORPTION CHILLER #1 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/11/2023 3:28	231171184	YEARLY (SD) - PM PLC ABSORPTION CHILLER #2 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/11/2023 3:29	231171054	YEARLY (SD) - PM PLC ABSORPTION CHILLER #3 (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 7:32	231171153	MONTHLY - PM FOR START-UP BURNER #1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 7:34	231171169	MONTHLY - PM FOR START-UP BURNER #2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 7:36	231042646	MONTHLY - PM FOR START-UP BURNER #3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 7:37	231042738	MONTHLY - PM FOR START-UP BURNER #4 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	18/11/2023 7:39	231171060	6 MONTHS - PM FOR POWER CABLE XLPE LINE BMS (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	18/11/2023 7:40	231171041	6 MONTHS - PM FOR POWER CABLE XLPE LINE BOX MAIN SUPPLY BURNER (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	18/11/2023 7:41	231171045	6 MONTHS - PM FOR POWER CABLE XLPE LINE SOOTBLOWER 1, LEFT (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	18/11/2023 7:42	231171065	6 MONTHS - PM FOR POWER CABLE XLPE LINE SOOTBLOWER 2, LEFT (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	18/11/2023 7:43	231171051	6 MONTHS - PM FOR POWER CABLE XLPE LINE AH411 MCC 690V RECOVERY BOILER #	NPP5A_PP11

WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	18/11/2023 7:44	231171020	6 MONTHS - PM FOR POWER CABLE XLPE LINE AH412 MCC 690V RECOVERY BOILER #	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	18/11/2023 7:45	231154840	6 MONTHS - PM FOR POWER CABLE XLPE LINE AL412 MCC 400V ESP#3 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	18/11/2023 7:46	231154841	6 MONTHS - PM FOR POWER CABLE XLPE LINE AH401 MCC 690V EVAPORATOR PULP 2	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	18/11/2023 7:47	231172230	6 MONTHS - PM FOR POWER CABLE XLPE LINE AH212 MCC. 690V MILL WIDE #2 (E)	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	18/11/2023 7:49	231172231	6 MONTHS - PM FOR POWER CABLE XLPE LINE AL291 EMERGENCY POWER SUPPLY 40I	NPP5A_PP11
WL5214	Electrical PSD (Motor/MCC/Drive/ESP)	18/11/2023 7:50	231172232	6 MONTHS - PM FOR POWER CABLE XLPE LINE AL293 NORMAL POWER SUPPLY 400 VA	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 7:51	231172233	WEEKLY - PM FOR GENERATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 7:53	231042505	WEEKLY - PM FOR LUP OIL PUMP FEED WATER PUMP 3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 7:56	231170984	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 7:59	231171008	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 8:03	231171009	2 WEEKS - PM VISUAL CHECK AND BASIC PDM FOR AGITATOR-DISSOLVING TANK SEE	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 8:10	231171264	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR # 1 (PO	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 8:14	231042780	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR #2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 8:18	231170921	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR PRIMARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 8:26	231170915	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR SECONDARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 8:33	231170908	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR TERTIARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 8:41	231170911	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 8:50	231170932	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 9:00	231170934	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 9:11	231171361	MONTHLY - PM ROUTE REFILL LUBRICANT CHAIN CONVEYOR (GROUP2) (PO)	NPP5A_PP11
MS0103	Automation Service (Instrument)	18/11/2023 9:12	231170897	calibrate 463 Stack flue gas analyzer (ISO14000)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 9:20	231170900	PM FOR RAPID DRAIN DOWNCOMER 463HV152B	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 9:21	231170923	PM FOR STARTUP BLOCK VLV 463HV154	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 9:22	231170917	PM FOR MAIN STEAM VALVE 463HV155	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 9:23	231170919	PM FOR DISC CONT BLOWDOWN 463HV158	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 9:25	231170930	PM FOR STEAM VLV BYPASS 463HV171	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 9:26	231170925	MONTHLY - PM FOR RECOVERY TRANSFORMER TH411(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 9:28	231042802	MONTHLY - PM FOR EVAPORATION TRANSFORMER TH401(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 9:30	231042876	MONTHLY - PM FOR TURBO GEN. Transformer TD11 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 9:32	231042803	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 9:45	231042877	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 9:51	231042879	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 9:56	231170959	WEEKLY - PM ROUTE CHECK SWITCHGEAR (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 10:00	231171138	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR STEAM TURBINE,32900KW (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	18/11/2023 22:00	231042723	2 WEEKS - INSPECTION DOSING PUMP	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	20/11/2023 10:06	231042804	MONTHLY - INSPECTION AGITATOR	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	20/11/2023 10:14	231042878	MONTHLY - PM ROUTE CHECK MOTOR RAPPER ESP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	20/11/2023 10:16	231042785	MONTHLY - PM ROUTE REFILL LUBRICANT CHAIN CONVEYOR (GROUP3) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	20/11/2023 10:17	231042782	MONTHLY - PM ROUTE REFILL OIL FAN COOLING TOWER (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	20/11/2023 10:18	231042354	MONTHLY CLEANING AIR SUPPLY FILTER 452JB04	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	20/11/2023 10:19	231171119	MONTHLY CLEANING AIR SUPPLY FILTER 452JB06	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	20/11/2023 10:21	231171120	MONTHLY CLEANING AIR SUPPLY FILTER 452JB07	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	20/11/2023 10:23	231171155	MONTHLY CLEANING AIR SUPPLY FILTER 452JB09	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	20/11/2023 10:25	231171180	MONTHLY CLEANING AIR SUPPLY FILTER 463AD20	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	20/11/2023 10:26	231042805	MONTHLY CLEANING AIR SUPPLY FILTER 463AD21	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	20/11/2023 10:28	231042881	MONTHLY CLEANING AIR SUPPLY FILTER 463AD22	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	20/11/2023 10:30	231042793	MONTHLY CLEANING AIR SUPPLY FILTER 463AD23	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	20/11/2023 10:32	231171116	MONTHLY CLEANING AIR SUPPLY FILTER 463AD25A	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	20/11/2023 10:33	231042788	MONTHLY CLEANING AIR SUPPLY FILTER 463AD25B	NPP5A_PP11
MS0103	Automation Service (Instrument)	20/11/2023 10:35	231171112	2 weeks check 463 Stack flue gas analyzer	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	20/11/2023 10:43	231042786	PM FOR FEEDWTR BLOCK VLAWE 463HV150	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	20/11/2023 10:44	231042727	PM FOR RAPID DRAIN GENBANK 463HV151B	NPP5A_PP11
MS0104	Automation Service (Control)	20/11/2023 10:45	231171321	2 WEEKS - PM FOR PLC TURBINE & GENERATOR GOVERNOR CONTROL (A)	NPP5A_PP11
MS0104	Automation Service (Control)	20/11/2023 10:59	231171322	2 WEEKS - PM FOR HMI TURBINE & GENERATOR GOVERNOR CONTROL (A)	NPP5A_PP11
MS0104	Automation Service (Control)	20/11/2023 10:59	231171323	2 WEEKS - PM FOR HMI RODDING MASTER (463CP60) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	20/11/2023 11:00	231171324	2 WEEKS - PM FOR HMI RODDING MASTER (463CP61) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	20/11/2023 11:01	231171325	2 WEEKS - PM FOR HMI BMS (A)	NPP5A_PP11
MS0104	Automation Service (Control)	20/11/2023 11:01	231171326	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #1 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	20/11/2023 11:02	231171327	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #2 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	20/11/2023 11:02	231171329	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #3 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	20/11/2023 11:03	231171292	2 WEEKS - PM FOR PLC RODDING MASTER (463CP60) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	20/11/2023 11:05	231171293	2 WEEKS - PM FOR PLC RODDING MASTER (463CP61) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	20/11/2023 11:07	231171294	2 WEEKS - PM FOR PLC BMS (A)	NPP5A_PP11
MS0104	Automation Service (Control)	20/11/2023 11:09	231171295	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #1 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	20/11/2023 11:11	231171297	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #2 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	20/11/2023 11:12	231171298	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #3 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	22/11/2023 7:59	231171299	MONTHLY - PM FOR RECOVERY BOILER OS2101 (OS501) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	22/11/2023 8:01	231171300	MONTHLY - PM FOR RECOVERY BOILER OS2102 (OS502) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	22/11/2023 8:03	231171301	MONTHLY - PM FOR MILL WIDE OS2103 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	22/11/2023 8:04	231171303	MONTHLY - PM FOR MILL WIDE OS2104 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	22/11/2023 8:06	231171304	MONTHLY - PM FOR EVAPORATOR OS2105 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	22/11/2023 8:08	231171305	MONTHLY - PM FOR EVAPORATOR OS2106 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	22/11/2023 8:10	231171307	MONTHLY - PM FOR UPS A FOR DCS BOILER PP11 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	22/11/2023 8:10	231171309	MONTHLY - PM FOR UPS B FOR DCS BOILER PP11 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	22/11/2023 8:11	231171310	MONTHLY - PM FOR UPS FOR INSTRUMENT RECOVERY BOILER (A)	NPP5A_PP11
MS0104	Automation Service (Control)	22/11/2023 8:12	231171311	MONTHLY - PM FOR UPS A FOR DCS TURBINE PP11 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	22/11/2023 8:13	231171312	MONTHLY - PM FOR UPS B FOR DCS TURBINE PP11 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	22/11/2023 8:14	231171313	MONTHLY - PM FOR UPS A FOR DCS EVAP PP11 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	22/11/2023 8:15	231171314	MONTHLY - PM FOR UPS B FOR DCS EVAP PP11 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	22/11/2023 8:15	231171315	MONTHLY - PM FOR UPS 01 FOR DCS CONTROL ROOM PP11 (A)	NPP5A_PP11

MS0104	Automation Service (Control)	22/11/2023 8:16	231171247	MONTHLY - PM FOR BATTERY FOR 463UPS-A DCS BOILER PP11 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	22/11/2023 8:18	231171249	MONTHLY - PM FOR BATTERY FOR 463UPS-B DCS BOILER PP11 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	22/11/2023 8:19	231171250	MONTHLY - PM FOR BATTERY FOR 463UPS-C INSTRUMENT PP11 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	22/11/2023 8:20	231171251	MONTHLY - PM FOR BATTERY FOR 293UPS-A DCS TURBINE PP11 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	22/11/2023 8:21	231171252	MONTHLY - PM FOR BATTERY FOR 293UPS-B DCS TURBINE PP11 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	22/11/2023 8:22	231171235	MONTHLY - PM FOR BATTERY FOR 452UPS-A DCS EVAP PP11 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	22/11/2023 8:24	231171236	MONTHLY - PM FOR BATTERY FOR 452UPS-B DCS EVAP PP11 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	22/11/2023 8:26	231171238	MONTHLY - PM FOR BATTERY FOR 463UPS-CR01 DCS CONTROL ROOM PP11 (A)	NPP5A_PP11
MS0024	Predictive Maintenance	22/11/2023 8:27	231171239	Monthly vibration check for Plan 262	NPP5A_PP11
MS0024	Predictive Maintenance	22/11/2023 8:28	231171240	Monthly vibration check for Plan 282	NPP5A_PP11
MS0024	Predictive Maintenance	22/11/2023 8:31	231171241	Monthly vibration check for Plan 293	NPP5A_PP11
MS0024	Predictive Maintenance	22/11/2023 8:32	231171242	Monthly vibration check for Plan 452	NPP5A_PP11
MS0024	Predictive Maintenance	22/11/2023 8:38	231171243	Monthly vibration check for Plan 463	NPP5A_PP11
MS0024	Predictive Maintenance	22/11/2023 8:42	231171331	Monthly oil Sampling for area 463	NPP5A_PP11
MS0024	Predictive Maintenance	22/11/2023 8:44	231171332	Monthly oil Sampling for area 293	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:46	231171302	YEARLY - PM FOR POWER CABLE FOR SPARE FEEDER (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:47	231042348	YEARLY - PM FOR POWER CABLE FOR SPARE FEEDER (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:47	231042331	YEARLY - PM FOR POWER CABLE FOR TH432/TH433 Feeder (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:47	231042332	YEARLY - PM FOR POWER CABLE FOR TH434/TH435 Feeder (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:48	231042349	YEARLY - PM FOR POWER CABLE FOR TH402 Feeder (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:48	231042386	YEARLY - PM FOR POWER CABLE FOR TL491 Feeder (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:49	231042387	YEARLY - PM FOR POWER CABLE FOR TE21/TH411 Feeder (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:49	231042522	YEARLY - PM FOR POWER CABLE FOR TH421 Feeder (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:50	231171046	YEARLY - PM FOR POWER CABLE FOR TH401 Feeder (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:50	231171021	YEARLY - PM FOR POWER CABLE FOR TH211 Feeder (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:50	231171998	YEARLY - PM FOR POWER CABLE FOR TL293 Feeder (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:51	231042525	YEARLY - PM FOR POWER CABLE FOR Emergency Feeder (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:51	231042550	YEARLY - PM FOR POWER CABLE FOR To NACL.03 Bus (Spare) (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:52	231042762	YEARLY - PM FOR POWER CABLE FOR TH212/TL212 Feeder (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:52	231042888	YEARLY - PM FOR POWER CABLE FOR TH212 Feeder (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:53	231042889	YEARLY - PM FOR POWER CABLE FOR SPARE FEEDER (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:53	231040949	YEARLY - PM FOR POWER CABLE FOR Pulp drying Feeder (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:53	231171147	YEARLY - PM FOR POWER CABLE FOR Spare Feeder(Now use for TE21,TH412) (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:54	231171149	YEARLY - PM FOR POWER CABLE FOR NPS Feeder (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:54	231042730	YEARLY - PM FOR POWER CABLE FOR OUT GOING TO EGAT FEEDER (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:55	231042737	YEARLY - PM FOR POWER CABLE FOR GROUNDING TRANSFORMER FEEDER (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:55	231042796	YEARLY - PM FOR POWER CABLE FOR TO 294AC.1 FEEDER TIE BUS TRANSFER (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:56	231042741	YEARLY - PM FOR POWER CABLE FOR DOUBLE CB 294AC.1.16 FEEDER (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:56	231042893	YEARLY - PM FOR POWER CABLE FOR INCOMING FROM Gen PP#11 (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:57	231042894	YEARLY - PM FOR POWER CABLE FOR OUT GOING POWER BACK UP AAP2 (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:57	231042895	YEARLY - PM FOR POWER CABLE FOR TO 294AC.2.3 FEEDER TIE BUS TRANSFER (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:57	231042896	YEARLY - PM FOR POWER CABLE FOR TE22/TH411 FEEDER (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:58	231042763	YEARLY - PM FOR POWER CABLE FOR SPARE FEEDER (Now use for TH211) (E)	NPP5A_PP11
WL5116	Electrical PP6,10,11	22/11/2023 8:58	231042764	YEARLY - PM FOR POWER CABLE FOR TO 294AC.1.14 FEEDER (E)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	26/11/2023 1:35	231172081	WEEKLY - INSPECTION CAMERA	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 1:39	231172019	MONTHLY - PM FOR CONDUCTIVITY INDICATION OF FEED WATER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 1:43	231042839	MONTHLY - PM FOR CONDUCTIVITY INDICATION OF DEMIN WATER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 1:46	231042840	MONTHLY - PM FOR CONDUCTIVITY INDICATION AFTER ANION EXCHANGER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 1:48	231042826	MONTHLY - PM FOR CONDUCTIVITY INDICATION AFTER MIXED BED EXCHANGER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 1:52	231042827	MONTHLY - PM FOR CONDUCTIVITY INDICATION AFTER ANION EXCHANGER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 1:55	231216073	MONTHLY - PM FOR CONDUCTIVITY INDICATION AFTER MIXED BED EXCHANGER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 1:58	231152181	MONTHLY - PM FOR CONDUCT. SUM (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 2:02	231152170	MONTHLY - PM FOR CONDUCTIVITY SUMP PIT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 2:05	231152179	MONTHLY - PM FOR condensate from fibre line (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 2:09	231152182	MONTHLY - PM FOR COND FRM EVAP PLANT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 2:12	231152177	MONTHLY - PM FOR COND FROM TURBINE (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 2:15	231152183	MONTHLY - PM FOR COND FROM PULP DRYER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 2:19	231152178	WEEKLY - PM FOR GENERATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 2:22	231152175	WEEKLY - PM FOR LUP OIL PUMP FEED WATER PUMP 3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 2:26	231152159	2 MONTHS - PM FOR SEALING AIR FAN # 1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 2:31	231152160	2 MONTHS - PM FOR SEALING AIR FAN # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 2:47	231152174	2 MONTHS - PM FOR FIRING LIQ TNK AGITATOR #1(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 2:51	231152186	2 MONTHS - PM FOR FIRING LIQ TNK AGITATOR #2(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 2:55	231152176	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 2:59	231152165	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 3:04	231152185	2 MONTHS - PM FOR TURNING MOTOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 3:08	231152168	2 MONTHS - PM FOR GLAND CONDENSER FAN (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 3:12	231152173	2 MONTHS - PM FOR VAPOR FAN (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 3:16	231152172	MONTHLY- PM FOR BATTERY CHARGER 110 VDC FOR 22KV SYSTEM (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 3:17	231152167	2 WEEKS - PM VISUAL CHECK AND BASIC PDM FOR AGITATOR-DISSOLVING TANK SEE NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 3:25	231152163	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR # 1 (PO) NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 3:29	231152166	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR # 2 (PO) NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 3:35	231152161	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR PRIMARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 3:43	231152162	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR SECONDARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 3:52	231152169	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR TERTIARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 4:00	231152164	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 4:13	231152184	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 4:25	231152180	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 4:37	231152171	MONTHLY - PM FOR FIRE FIGHTING MILL WIDE (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 4:39	231152187	MONTHLY - PM FOR CO2 FIRE ALARM & FIRE FIGHTING OF TURBINE (E)	NPP5A_PP11

WL1320	PP5,6,10,11 OPERATION	26/11/2023 4:40	231043142	MONTHLY - PM FOR FIRE FIGHTING EVAPORATION (E)	NPP5A_PP11
AS2020	Maintenance Central Management	26/11/2023 4:42	231043129	monthly inspection Evaporation DCS Controller (A)	NPP5A_PP11
AS2020	Maintenance Central Management	26/11/2023 4:50	231043140	monthly inspection Mill Wide DCS Controller (A)	NPP5A_PP11
MS0104	Automation Service (Control)	26/11/2023 4:58	231043143	monthly inspection Soot Blower DCS Controller (A)	NPP5A_PP11
AS2020	Maintenance Central Management	26/11/2023 5:08	231043138	monthly inspection RecoveryBoiler DCS Controller (A)	NPP5A_PP11
MS0104	Automation Service (Control)	26/11/2023 5:17	231043144	monthly inspection for R.B. DCS Power Distrib. (A)	NPP5A_PP11
MS0104	Automation Service (Control)	26/11/2023 5:20	231043139	monthly inspection for Evapor DCS Power Distrib. (A)	NPP5A_PP11
MS0104	Automation Service (Control)	26/11/2023 5:22	231043135	monthly inspection for MillWideDCS Power Distrib. (A)	NPP5A_PP11
MS0103	Automation Service (Instrument)	26/11/2023 5:25	231043115	calibrate 463 Stack flue gas analyzer (ISO14000)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 5:34	231043116	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 5:48	231043134	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 5:55	231043148	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 6:03	231043137	WEEKLY - PM ROUTE CHECK SWITCHGEAR (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 6:06	231043123	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR STEAM TURBINE,32900KW (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 6:14	231043146	MONTHLY - PM FOR SOOTBLOWER 1, LEFT (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	26/11/2023 6:16	231043126	MONTHLY - PM FOR SOOTBLOWER 2, LEFT (E)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	26/11/2023 6:18	231043133	2 WEEKS - PM FOR 115 KV SUBSTATION AAP2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/11/2023 15:44	231043131	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/11/2023 15:50	231043125	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/11/2023 15:57	231043119	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR COOLING WATER PUMP NO.3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/11/2023 16:03	231043124	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR CONTROL OIL PUMP #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/11/2023 16:10	231043117	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR CONTROL OIL PUMP # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/11/2023 16:17	231043118	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR LUBE OIL PUMP #1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	27/11/2023 16:23	231043128	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR LUBE OIL PUMP # 2 (PO)	NPP5A_PP11
MS0093	Electrical Service (Control)	28/11/2023 11:55	231043120	Monthly - Inspect Thermoscan NPP11	NPP5A_PP11
MS0093	Electrical Service (Control)	28/11/2023 11:58	231043149	Monthly - Inspect Partial Discharge PP11	NPP5A_PP11
MS0094	Electrical Service (Power) IP1	28/11/2023 11:59	231043145	2 Weeks - PM Inspection Absorption Chiller PP11	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	30/11/2023 5:34	231043141	MONTHLY - PM FOR 115 KV SUBSTATION AAP2 (E)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	2/12/2023 9:02	231043130	WEEKLY - INSPECTION CAMERA	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/12/2023 9:06	231043161	WEEKLY - PM FOR GENERATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/12/2023 9:09	231043162	WEEKLY - PM FOR LUP OIL PUMP FEED WATER PUMP 3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/12/2023 9:12	231043160	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/12/2023 9:16	231043156	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/12/2023 9:20	231043157	2 WEEKS - PM VISUAL CHECK AND BASIC PDM FOR AGITATOR-DISSOLVING TANK SEE NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/12/2023 9:28	231043163	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/12/2023 9:32	231043158	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR #2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/12/2023 9:37	231043150	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR PRIMARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/12/2023 9:45	231043151	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR SECONDARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/12/2023 9:53	231043164	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR TERTIARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/12/2023 10:01	231043152	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/12/2023 10:11	231043154	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/12/2023 10:22	231170863	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN #3 (PO)	NPP5A_PP11
MS0103	Automation Service (Instrument)	2/12/2023 10:34	231170862	calibrate 463 Stack flue gas analyzer (ISO14000)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/12/2023 10:43	231170864	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/12/2023 10:58	231170866	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/12/2023 11:04	231170865	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/12/2023 11:10	231170867	WEEKLY - PM ROUTE CHECK SWITCHGEAR (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	2/12/2023 11:14	231170868	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR STEAM TURBINE,32900KW (PO)	NPP5A_PP11
MS0103	Automation Service (Instrument)	3/12/2023 5:48	231170869	2 weeks check 463 Stack flue gas analyzer	NPP5A_PP11
MS0104	Automation Service (Control)	3/12/2023 5:57	231171090	2 WEEKS - PM FOR PLC TURBINE & GENERATOR GOVERNOR CONTROL (A)	NPP5A_PP11
MS0104	Automation Service (Control)	3/12/2023 6:09	231171091	2 WEEKS - PM FOR HMI TURBINE & GENERATOR GOVERNOR CONTROL (A)	NPP5A_PP11
MS0104	Automation Service (Control)	3/12/2023 6:09	231171092	2 WEEKS - PM FOR HMI RODDING MASTER (463CP60) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	3/12/2023 6:10	231171097	2 WEEKS - PM FOR HMI RODDING MASTER (463CP61) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	3/12/2023 6:11	231171098	2 WEEKS - PM FOR HMI BMS (A)	NPP5A_PP11
MS0104	Automation Service (Control)	3/12/2023 6:11	231170968	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #1 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	3/12/2023 6:12	231042819	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #2 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	3/12/2023 6:13	231171095	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #3 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	3/12/2023 6:13	231171086	2 WEEKS - PM FOR PLC RODDING MASTER (463CP60) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	3/12/2023 6:16	231171087	2 WEEKS - PM FOR PLC RODDING MASTER (463CP61) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	3/12/2023 6:18	231042416	2 WEEKS - PM FOR PLC BMS (A)	NPP5A_PP11
MS0104	Automation Service (Control)	3/12/2023 6:20	231042544	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #1 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	3/12/2023 6:21	231042389	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #2 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	3/12/2023 6:23	231042910	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #3 (A)	NPP5A_PP11
AS2020	Maintenance Central Management	4/12/2023 7:39	231042390	MONTHLY - PM FOR MILLWIDE DCS CONTROLLER (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 6:57	231042909	2 MONTHS - PM FOR SCANNER/IGNITOR AIR FAN # 1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 7:01	231042306	2 MONTHS - PM FOR SCRUBBER FAN (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 7:05	231042824	2 MONTHS - PM FOR HVLC GAS FAN (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 7:10	231042825	MONTHLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 7:10	231171288	MONTHLY - PM FOR BATTERY FOR 293NU01 CHARGER 110 VDC MILL WIDE BANK#1 (E) NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 7:12	231171278	MONTHLY - PM FOR BATTERY FOR 293NU01 CHARGER 110 VDC MILL WIDE BANK#2 (E) NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 7:13	231171444	MONTHLY - PM FOR BATTERY 110 VDC FOR Communication 115 kV (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 7:14	231170891	MONTHLY - PM FOR BATTERY FOR 294BTN01 CHARGER 48VDC FOR 115KV NPP11 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 7:15	231171990	MONTHLY - PM FOR BATTERY FOR 463UPS01 MCC RECOVERY BOILER, UPS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 7:16	231154838	MONTHLY - PM FOR BATTERY FOR 294NU01 CHARGER 110 VDC FOR 22KV SYSTEM (E) NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 7:18	231154839	MONTHLY - PM FOR BATTERY FOR 293UPS01 MCC MILL WIDE, UPS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 7:19	231172202	MONTHLY - PM FOR CHARGER 110 VDC FOR Communication 115 kV (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 7:20	231170945	MONTHLY - PM FOR CHARGER 48VDC FOR 115KV NPP11 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 7:22	231172206	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 3 FOR AREA 182 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 7:26	231172214	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 2 FOR AREA 293 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 7:31	231172209	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 3 FOR AREA 293 (PO)	NPP5A_PP11

WL1320	PP5,6,10,11 OPERATION	6/12/2023 7:35	231172218	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 6 FOR AREA 452 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 7:40	231172211	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 7 FOR AREA 452 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 7:43	231172220	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 15 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 7:46	231172221	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 16 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 7:52	231172227	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 17 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 7:54	231172228	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 18 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 8:00	231171449	4 MONTHS - PM ROUTE INSPECTION AND CLEAN GROUP 19 FOR AREA 463 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 8:07	231042379	MONTHLY - ROUTE PM FOR INSPECTION FABRIC EXPANSION JOINT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 8:16	231042380	MONTHLY - PM ROUTE REFILL LUBRICANT BEARING FAN FOR IDFAN(GROUP2) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 8:17	231042382	MONTHLY - PM ROUTE REFILL LUBRICANT BEARING FAN FOR IDFAN(GROUP3) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	6/12/2023 8:18	231042383	MONTHLY - PM REFILL LUBRICANT FOR AGITATOR STRONG LIQUOR STORAGE TANK (NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	9/12/2023 0:02	231171067	WEEKLY - INSPECTION CAMERA	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 0:06	231171044	MONTHLY - PM FOR START-UP BURNER #5 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 0:08	231172249	MONTHLY - PM FOR START-UP BURNER #6 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 0:11	231170859	MONTHLY - PM FOR ELECTROSTATIC PRECIPITATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 0:17	231170857	MONTHLY - PM FOR ELECTROSTATIC PRECIPITATOR # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 0:21	231172247	MONTHLY - PM FOR ESP #3(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 0:25	231172248	WEEKLY - PM FOR GENERATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 0:28	231172246	WEEKLY - PM FOR LUP OIL PUMP FEED WATER PUMP 3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 0:32	231172245	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 0:37	231172244	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 0:41	231042817	MONTHLY - PM FOR RECOVERY TRANSFORMER TE21(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 0:44	231042767	MONTHLY - PM FOR TRANSFORMER TL412(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 0:46	231171374	MONTHLY - PM FOR TRANSFORMER TH412(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 0:49	231171378	MONTHLY - PM FOR RECTIFIER # A, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 0:52	231172261	MONTHLY - PM FOR RECTIFIER # B, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 0:55	231172268	MONTHLY - PM FOR RECTIFIER # C, PRECIPITATOR # 1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 0:58	231170995	MONTHLY - PM FOR RECTIFIER # A, PRECIPITATOR # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 1:01	231171263	MONTHLY - PM FOR RECTIFIER # B, PRECIPITATOR # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 1:04	231171024	MONTHLY - PM FOR RECTIFIER # C, PRECIPITATOR # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 1:06	231171379	MONTHLY - PM FOR RECTIFIER #A, PRECIPITATOR # 3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 1:09	231171388	MONTHLY - PM FOR RECTIFIER #B, PRECIPITATOR #3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 1:12	231171506	MONTHLY - PM FOR RECTIFIER #C, PRECIPITATOR #3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 1:15	231170991	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH211(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 1:18	231171143	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH212(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 1:21	231171414	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH291(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 1:24	231171458	MONTHLY - PM FOR MILL WIDE TRANSFORMER TH293(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 1:27	231171084	MONTHLY - PM FOR TL293E POWER BACK UP FROM EGAT (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 1:30	231171370	MONTHLY - PM FOR AAP2 , TURBO GENERATOR TRANSFMR TD12 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 1:33	231171372	MONTHLY - PM FOR GROUNDING TRANSFORMER (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 1:36	231171055	MONTHLY - PM FOR BATTERY CHARGER 110 VDC MILL WIDE (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 1:38	231171081	MONTHLY - PM FOR MCC MILL WIDE, UPS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 1:38	231171083	MONTHLY - PM FOR BATTERY CHARGER 110 VDC MILL WIDE (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 1:40	231171057	MONTHLY - PM FOR MCC MILL WIDE, UPS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 1:41	231171073	MONTHLY - PM FOR SCRUBBER FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 1:49	231171432	MONTHLY - INSPECTION PUMP	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 2:08	231042519	2 WEEKS - PM VISUAL CHECK AND BASIC PDM FOR AGITATOR-DISSOLVING TANK SEE NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 2:17	231042531	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR ASH COLLECTING CONVEYOR (PO NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 2:21	231042308	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR DRAG SCRAPER, ESP # 1 SEE LON NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 2:28	231042415	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR DRAG SCRAPER, ESP # 2 SEE LON NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 2:32	231042543	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR COLLECTING CONVEYOR, ESP # 1 NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 2:38	231171279	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR COLLECTING CONVEYOR, ESP # 2 NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 2:44	231171319	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SCRAPER CONVEYER ESP.3 (PO) NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 2:49	231171441	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR COLLECTING CONVEYER ESP.3 (P NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 2:54	231170893	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR # 1 (PO NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 3:00	231042912	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR #2 (PO) NPP5A_PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 3:06	231042418	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR PRIMARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 3:15	231042655	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR SECONDARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 3:24	231042654	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR TERTIARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 3:35	231170961	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 3:48	231042545	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 4:04	231042660	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 4:16	231042659	MONTHLY - PM FOR FIRE FIGHTING SWITCH GEAR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 4:18	231171720	MONTHLY - PM ROUTE REFILL LUBRICANT CHAIN CONVEYOR (GROUP1) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 4:19	231171716	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP A (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 4:21	231171499	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP B (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 4:24	231171526	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP C (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 4:25	231171539	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP D (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 4:27	231171541	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP E (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 4:29	231171543	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP F (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 4:30	231171544	MONTHLY - PM ROUTE REFILL LUBRICANT PUMP G (PO)	NPP5A_PP11
MS0103	Automation Service (Instrument)	9/12/2023 4:31	231171546	calibrate 463 Stack flue gas analyzer (ISO14000)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 4:45	231171547	PM FOR FEEDWTR BY-PASS VLV 463HV172	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 4:46	231171550	PM FOR SOOTBLWR STEAM HDR 463HV181	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 4:48	231171552	MONTHLY - PM FOR AL21 BUS 6.6KV FEED WATER PUMP P003 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 4:51	231171555	MONTHLY - PM FOR AL22 SWG 6.6KV FEED WATER PUMP P050 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 4:55	231171559	MONTHLY - PM FOR EGAT OUT GOING TRANSFORMER TC3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 4:57	231171501	MONTHLY - PM FOR VSD OF FIRING LIQUOR PUMP #1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 4:58	231171527	MONTHLY - PM FOR VSD OF FIRING LIQUOR PUMP #2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 4:59	231171564	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #1 (PO)	NPP5A_PP11

WL1320	PP5,6,10,11 OPERATION	9/12/2023 14:20	231042754	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 26, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 14:27	231042755	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 27, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 14:33	231042751	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 28, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 14:39	231042753	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 29, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 14:44	231042546	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 30, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 14:50	231171126	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 31, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 14:56	231042691	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 32, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 15:02	231042692	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 33, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 15:08	231171104	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 34, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 15:14	231171316	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 35, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 15:20	231171317	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 36, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 15:25	231171022	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 37, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 15:31	231042312	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 38, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 15:37	231042314	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 39, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 15:43	231042313	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 40, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 15:49	231042835	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 41, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 15:54	231042834	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 42, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 16:00	231042765	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 43, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 16:06	231171076	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 44 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 16:12	231171190	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 45, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 16:18	231042319	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 46, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 16:24	231042337	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 47, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 16:30	231042815	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 48, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 16:35	231042816	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 49, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 16:41	231042870	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 50, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 16:47	231171206	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 51, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 16:54	231042311	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 52, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 17:00	231171453	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 353, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 17:05	231171454	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 354, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 17:11	231171459	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 355, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 17:17	231171456	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 356, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 17:23	231172008	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 357, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 17:28	231171787	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 358, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 17:33	231042409	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 359, LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 17:39	231171018	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER 360, RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 17:45	231171019	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER #61 LEFT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 17:50	231172088	MONTHLY - PM VISUAL CHECK AND BASIC PDM FOR SOOTBLOWER # 62 RIGHT (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 17:55	231042675	WEEKLY - PM ROUTE CHECK SWITCHGEAR (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 17:59	231171210	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR STEAM TURBINE,32900KW (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 18:06	231171225	MONTHLY - PM FOR BMS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 18:08	231171094	MONTHLY - PM FOR BOX MAIN SUPPLY BURNER (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 18:10	231171874	MONTHLY - PM FOR AH111 MCC 690V RECOVERY BOILER #2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 18:13	231172104	MONTHLY - PM FOR AH142 MCC 690V RECOVERY BOILER #2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 18:15	231171193	MONTHLY - PM FOR AL412 MCC 400V ESP#3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 18:20	231171223	MONTHLY - PM FOR SCRUBBER FAN (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 18:21	231171191	MONTHLY - PM FOR AH401 MCC 690V EVAPORATOR PULP 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 18:24	231171224	MONTHLY - PM FOR AH211 MCC. 690V MILL WIDE #1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 18:27	231171226	MONTHLY - PM FOR AH212 MCC. 690V MILL WIDE #2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 18:29	231171273	MONTHLY - PM FOR AL291 EMERGENCY POWER SUPPLY 400 VAC (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	9/12/2023 18:32	231171222	MONTHLY - PM FOR AL293 NORMAL POWER SUPPLY 400 VAC (E)	NPP5A_PP11
MS0094	Electrical Service (Power) IP1	10/12/2023 10:13	231171227	2 Weeks - PM Inspection Absorption Chiller PP11	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/12/2023 9:08	231171200	2 MONTHS - PM FOR SCANNER/IGNITOR AIR FAN # 2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/12/2023 9:13	231171202	2 MONTHS - PM FOR SCRUBBER FAN (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/12/2023 9:18	231171199	MONTHLY - PM FOR AIR COMPRESSOR NO.1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/12/2023 9:23	231171213	MONTHLY - PM FOR AIR COMPRESSOR NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/12/2023 9:27	231170969	MONTHLY - PM FOR AIR COMPRESSOR NO.3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/12/2023 9:31	231171209	MONTHLY - PM FOR AIR COMPRESSOR NO.4 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/12/2023 9:36	231171212	MONTHLY - PM FOR MCC RECOVERY BOILER, UPS (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/12/2023 9:37	231171215	MONTHLY - PM REFILL LUBRICANT FOR AGITATOR-DISSOLVING TANK SEE LONG DISC	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/12/2023 9:37	231171216	MONTHLY - PM REFILL LUBRICANT FOR AGITATOR-DISSOLVING TANK SEE LONG DISC	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/12/2023 9:37	231171218	MONTHLY - PM FOR AIR COMPRESSOR NO.1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/12/2023 9:48	231171203	MONTHLY - PM FOR AIR COMPRESSOR NO.2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/12/2023 10:00	231171195	MONTHLY - PM FOR AIR COMPRESSOR NO.3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/12/2023 10:11	231171204	MONTHLY - PM FOR AIR COMPRESSOR NO.4 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/12/2023 10:23	231171196	MONTHLY - PM ROUTE REFILL LUBRICANT BEARING FAN FOR IDFAN(GROUP1) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/12/2023 10:24	231171205	MONTHLY CLEANING AIR SUPPLY FILTER 463AD26	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/12/2023 10:25	231171198	MONTHLY CLEANING AIR SUPPLY FILTER 463AD27	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/12/2023 10:27	231171207	MONTHLY CLEANING AIR SUPPLY FILTER 282AS21	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	11/12/2023 10:29	231171211	MONTHLY CLEANING AIR SUPPLY FILTER 282AS22	NPP5A_PP11
MS0103	Automation Service (Instrument)	11/12/2023 10:31	231171214	Monthly PM Dust meter "Sick"(ISO 14000)	NPP5A_PP11
MS0103	Automation Service (Instrument)	11/12/2023 10:34	231171219	Monthly PM for 463QI490 DU after Feed water pump	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	11/12/2023 10:36	231171221	2 WEEKS - PM FOR 115 KV SUBSTATION AAP2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	13/12/2023 9:31	231171186	MONTHLY - INSPECTION PH TR	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	13/12/2023 9:41	231171187	MONTHLY - INSPECTION PH TR	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	13/12/2023 9:44	231171188	MONTHLY - INSPECTION PH	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	13/12/2023 9:45	231042407	MONTHLY - PM FOR BL-SPRAYER DIVERT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	13/12/2023 9:49	231042534	MONTHLY - PM FOR BL-SPRAYER DIVERT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	13/12/2023 9:52	231042408	MONTHLY - PM FOR BL-SPRAYER DIVERT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	13/12/2023 9:56	231171099	MONTHLY - PM FOR BL .SPRAYER DIVERT (A)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	13/12/2023 9:59	231171274	MONTHLY - PM FOR TRANSFORMER TE22(E)	NPP5A_PP11

WL1320	PP5,6,10,11 OPERATION	13/12/2023 10:03	231170895	MONTHLY - PM FOR FIRE FIGHTING RECOVERY BOILER (E)	NPP5A_PP11
WL5121	MAINTENANCE EMERGENCY (TEAM A)	15/12/2023 7:02	231042420	WEEKLY - INSPECTION CAMERA	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	16/12/2023 22:00	231171920	2 WEEKS - INSPECTION DOSING PUMP	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 15:20	231171980	MONTHLY - PM FOR START-UP BURNER #1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 15:22	231171976	MONTHLY - PM FOR START-UP BURNER #2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 15:24	231171907	MONTHLY - PM FOR START-UP BURNER #3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 15:26	231171840	MONTHLY - PM FOR START-UP BURNER #4 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 15:28	231171895	WEEKLY - PM FOR GENERATOR (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 15:31	231171813	WEEKLY - PM FOR LUP OIL PUMP FEED WATER PUMP 3 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 15:35	231171829	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.1 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 15:40	231171941	WEEKLY - PM FOR INDUCED DRAFT FAN, CELL NO.2 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 15:44	231172234	2 WEEKS - PM VISUAL CHECK AND BASIC PDM FOR AGITATOR-DISSOLVING TANK SEE	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 15:52	231171856	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 15:57	231172126	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ESP TRANSFER CONVEYOR #2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 16:03	231172096	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR PRIMARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 16:11	231172035	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR SECONDARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 16:20	231171967	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR TERTIARY FD FAN (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 16:29	231171136	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 1 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 16:40	231172205	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN # 2 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 16:51	231172204	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR ID FAN #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:04	231172203	3 MONTHS - PM ROUTE RE GREASE MOTOR COOLING TOWER(PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:05	231042801	MONTHLY - PM ROUTE REFILL LUBRICANT CHAIN CONVEYOR (GROUP2) (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:06	231042781	MONTHLY - PM ROUTE REFILL OIL FAN COOLING TOWER (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:07	231042875	MONTHLY CLEANING AIR SUPPLY FILTER 452JB04	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:09	231170949	MONTHLY CLEANING AIR SUPPLY FILTER 452JB06	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:10	231171486	MONTHLY CLEANING AIR SUPPLY FILTER 452JB07	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:12	231043075	MONTHLY CLEANING AIR SUPPLY FILTER 452JB09	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:14	231043068	MONTHLY CLEANING AIR SUPPLY FILTER 463AD20	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:16	231043073	MONTHLY CLEANING AIR SUPPLY FILTER 463AD21	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:18	231043071	MONTHLY CLEANING AIR SUPPLY FILTER 463AD22	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:20	231043072	MONTHLY CLEANING AIR SUPPLY FILTER 463AD23	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:21	231043069	MONTHLY CLEANING AIR SUPPLY FILTER 463AD25A	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:23	231043074	MONTHLY CLEANING AIR SUPPLY FILTER 463AD25B	NPP5A_PP11
MS0103	Automation Service (Instrument)	17/12/2023 17:25	231043070	2 weeks check 463 Stack flue gas analyzer	NPP5A_PP11
MS0103	Automation Service (Instrument)	17/12/2023 17:34	231171433	calibrate 463 Stack flue gas analyzer (ISO14000)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:44	231171434	PM FOR FEEDWTR BLOCK VALVE 463HV150	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:45	231042366	PM FOR RAPID DRAIN GENBANK 463HV151B	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:47	231042367	PM FOR RAPID DRAIN DOWNCOMER 463HV152B	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:48	231042373	PM FOR STARTUP BLOCK VLV 463HV154	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:49	231042374	PM FOR MAIN STEAM VALVE 463HV155	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:51	231171489	PM FOR DISC CONT BLOWDOWN 463HV158	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:52	231171490	PM FOR STEAM VLV BYPASS 463HV171	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:54	231171100	MONTHLY - PM FOR RECOVERY TRANSFORMER TH411(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:57	231170977	MONTHLY - PM FOR EVAPORATION TRANSFORMER TH401(E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 17:59	231171253	MONTHLY - PM FOR TURBO GEN. Transformer TD11 (E)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 18:02	231043114	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FW PUMP #3 (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 18:18	231043112	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 18:24	231170937	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR FIRING LIQUOR PUMP (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 18:31	231170939	WEEKLY - PM ROUTE CHECK SWITCHGEAR (PO)	NPP5A_PP11
WL1320	PP5,6,10,11 OPERATION	17/12/2023 18:36	231171455	WEEKLY - PM VISUAL CHECK AND BASIC PDM FOR STEAM TURBINE,32900KW (PO)	NPP5A_PP11
MS0104	Automation Service (Control)	17/12/2023 18:44	231042325	2 WEEKS - PM FOR PLC TURBINE & GENERATOR GOVERNOR CONTROL (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/12/2023 18:56	231042342	2 WEEKS - PM FOR HMI TURBINE & GENERATOR GOVERNOR CONTROL (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/12/2023 18:57	231042320	2 WEEKS - PM FOR HMI RODDING MASTER (463CP60) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/12/2023 18:57	231042338	2 WEEKS - PM FOR HMI RODDING MASTER (463CP61) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/12/2023 18:58	231042321	2 WEEKS - PM FOR HMI BMS (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/12/2023 18:59	231042339	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #1 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/12/2023 19:00	231042322	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #2 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/12/2023 19:00	231042340	2 WEEKS - PM FOR HMI ABSORPTION CHILLER #3 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/12/2023 19:01	231042323	2 WEEKS - PM FOR PLC RODDING MASTER (463CP60) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/12/2023 19:03	231042341	2 WEEKS - PM FOR PLC RODDING MASTER (463CP61) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/12/2023 19:05	231171077	2 WEEKS - PM FOR PLC BMS (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/12/2023 19:08	231171450	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #1 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/12/2023 19:10	231171078	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #2 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	17/12/2023 19:12	231171267	2 WEEKS - PM FOR PLC ABSORPTION CHILLER #3 (A)	NPP5A_PP11
MS0014	Mechanical Service (Roll Service)	17/12/2023 19:14	231171007	YEARLY - PM FOR Crane Millwide (E)	NPP5A_PP11
MS0104	Automation Service (Control)	19/12/2023 5:29	231171082	MONTHLY - PM FOR RECOVERY BOILER OS2101 (OS501) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	19/12/2023 5:31	231042533	MONTHLY - PM FOR RECOVERY BOILER OS2102 (OS502) (A)	NPP5A_PP11
MS0104	Automation Service (Control)	19/12/2023 5:33	231171069	MONTHLY - PM FOR MILL WIDE OS2103 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	19/12/2023 5:34	231170874	MONTHLY - PM FOR MILL WIDE OS2104 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	19/12/2023 5:36	231170875	MONTHLY - PM FOR EVAPORATOR OS2105 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	19/12/2023 5:38	231170876	MONTHLY - PM FOR EVAPORATOR OS2106 (A)	NPP5A_PP11
MS0104	Automation Service (Control)	19/12/2023 5:40	231170877	MONTHLY - PM FOR UPS A FOR DCS BOILER PP11 (A)	NPP5A_PP11

Work Order Details

231197258: 2 WEEKS - PM FOR PLC ABSORPTION CHILLER #1 (A)

Asset: 242E001PLC PLC ABSORPTION CHILLER #1
 Location: 242 PP11-HVAC CHILLED WATER DISTRIBUTION, CHILLER
 CI:

Sched Start: 1/5/24	Site: POWER	Job Plan: APLC117
Sched Finish: 1/6/24	Priority: 5	Supervisor: 18904
Target Start: 1/4/24	Work Type: PM	Lead:
Target Finish: 1/4/24	Status: INPRG	Vendor:
Actual Start: 1/6/24	Parent:	Owner:
Actual Finish:	Failure Class:	Owner Group:
Report Date: 11/6/23	Problem Code:	Service:
Reported By: MAXADMIN	GL Account: NP5A-????????-A41	Service Group:
		Classification:

Task ID	Description	Status	Measurement Point	Value	Date	Observations
5	Inspection	INPRG		0		
10	1 POWER SUPPLY red...../OFF.....	INPRG		0		
15	2 CPU Model SLC 5/03 CPU	INPRG		0		
20	2.1 RUN green...../flashing...../OFF.....	INPRG		0		
25	2.2 FLT red...../flashing (at power up)...../flashing (during operation)...../OFF.....	INPRG		0		
30	2.3 BATT red...../OFF.....	INPRG		0		
35	2.4 FORCE yellow...../flashing...../OFF.....	INPRG		0		
40	2.5 DH-485 green...../flashing...../OFF.....	INPRG		0		
45	2.6 RS-232 green...../flashing...../OFF.....	INPRG		0		
50	2.7 DI16x115 VAC () Normal () Abnormal Please Specify.....	INPRG		0		
55	2.8 DO8 Isolate relay () Normal () Abnormal Please Specify.....	INPRG		0		
60	2.9 DO8 Isolate relay () Normal () Abnormal Please Specify.....	INPRG		0		
65	2.10 AI / AO () Normal () Abnormal Please Specify.....	INPRG		0		
70	2.11 RTD / resistance input () Normal () Abnormal Please Specify.....	INPRG		0		

Work Order Details

231197258: 2 WEEKS - PM FOR PLC ABSORPTION CHILLER #1 (A)

Task ID	Description	Status	Measurement Point	Value	Date	Observations
75	2.12 RTD / resistance input Abnormal () Normal () Please Specify.....	INPRG		0		
80	3 Cabinet fan () Normal () Abnormal Please Specify.....	INPRG		0		
85	4 Clean the filter Cabinet fan () Normal = Clean () Abnormal = Not Clean Please Specify.....	INPRG		0		
90	5 Temperature in the room (normal 26°C) () Normal () Abnormal Please Specify.....	INPRG		0		

Planned Labor

Task ID	Craft	Skill Level	Labor	Vendor	Contract	Qty	Hours	Rate	Line Cost
	PUH-AUTO	LV1				1	00:30	80,00	40,00
							Total Planned Labor:		40,00

Actual Labor

Task ID	Craft	Skill Level	Labor	Vendor	Contract Num	Regular Hours	Premium Hours	Regular Rate	Premium Rate	Line Cost
	CT-SPEC	LV1	17691			03:50	00:00	160,00	0,00	613,33
							Total Actual Labor:			613,33

The resource of this report item is not reachable.

Work Order Details

231163176: YEARLY - PM TEST DGA FOR MILL WIDE TRANSFORMER TH293(E)

Asset: 293Z004 MILL WIDE TRANSFORMER TH293
Location: 11BF Low Voltage Main Distribution Board & Transformer
CI:

Sched Start:		Site:	POWER	Job Plan:	ETR035
Sched Finish:		Priority:	5	Supervisor:	18903
Target Start:	12/15/23	Work Type:	PM	Lead:	
Target Finish:	12/15/23	Status:	WSCH	Vendor:	
Actual Start:		Parent:		Owner:	
Actual Finish:		Failure Class:		Owner Group:	
Report Date:	10/16/23	Problem Code:		Service:	
Reported By:	MAXADMIN	GL Account:	NP5A-????????-A36	Service Group:	
				Classification:	

Task ID	Description	Status	Measurement Point	Value	Date	Observations
5	การบำรุงรักษาหม้อแปลงประจำปี *** ก่อนเริ่มหยุดจ่ายไฟหม้อแปลง 3 เดือน (Out source)	WSCH		0		
10	1 การวัดค่า และ ทดสอบ DGA, DI Electric Break down , Moisture () ปกติ = ค่าเป็นการทดสอบ () ผิดปกติ = ไม่สามารถทำการทดสอบได้	WSCH		0		

Task ID	Craft	Skill Level	Labor	Vendor	Contract	Qty	Hours	Rate	Line Cost
	PUH-ELEC	LV1				1	00:30	80,00	40,00
							Total Planned Labor:		40,00

Work Order Details

231043391: YEARLY (SD) - PM FOR SOOTBLOWER 14, LEFT (E)

Asset: 463E014 SootBlower 14, LEFT
 Location: 11HC SootBlowers
 CI:

Sched Start:		Site:	POWER	Job Plan:	ESB009
Sched Finish:		Priority:	5	Supervisor:	561551
Target Start:	10/13/23	Work Type:	PM	Lead:	
Target Finish:	10/13/23	Status:	WPLAN	Vendor:	
Actual Start:		Parent:		Owner:	
Actual Finish:		Failure Class:		Owner Group:	
Report Date:	8/8/23	Problem Code:		Service:	
Reported By:	MAXADMIN	GL Account:	NP5A-????????-A36	Service Group:	
				Classification:	

Task IDs	Task ID	Description	Status	Measurement Point	Value	Date	Observations
	5	การซ่อมบำรุงประจำปี	WPLAN		0		
	8	การตรวจสอบเบื้องต้น	WPLAN		0		
	10	1. ตรวจสอบสภาพ Casing ของมอเตอร์	WPLAN		0		
	15	() ปกติ = สะอาด () ผิดปกติ = สปรก ฟูเป็นสนิม ไม่ปร รูป:.....	WPLAN		0		
	20	2. ตรวจสอบน็อตยึดฐานมอเตอร์	WPLAN		0		
	25	() ปกติ = แน่น () ผิดปกติ = หลวม/เป็นสนิม/นอตหาย/สั้น ไม่ครบ:.....	WPLAN		0		
	30	3. ตรวจสอบใบพัดลมและฝาครอบใบพัดลมของมอเตอร์	WPLAN		0		
	35	() ปกติ () ผิดปกติ = ขาด, หลุดหาย, สั้นๆ ไม่ครบ:.....	WPLAN		0		
	40	4. ตรวจสอบสภาพและซีลกันน้ำของกล่องเข้าสายของมอเตอร์	WPLAN		0		
	45	() ปกติ () ผิดปกติ = ซีลไม่ติด, สั้นๆ ไม่ครบ:.....	WPLAN		0		
	50	5. ตรวจสอบสายไฟเชื่อมมอเตอร์ (Cable)	WPLAN		0		
	55	() ปกติ () ผิดปกติ = ขาด, สั้นๆ ไม่ครบ:.....	WPLAN		0		
	60	6. ตรวจสอบก้าน (Towbar)	WPLAN		0		
	65	() ปกติ () ผิดปกติ = น็อตยึดหลุดหลวม, งอ, สั้นๆ ไม่ครบ:.....	WPLAN		0		
	70	7. ตรวจสอบลวดร้อยสาย (Support rod)	WPLAN		0		
	75	() ปกติ () ผิดปกติ = น็อตยึดหลุดหลวม, งอ, ขาด, สั้นๆ ไม่ปร รูป:.....	WPLAN		0		

The resource of this report item is not reachable.

Work Order Details

231043391: YEARLY (SD) - PM FOR SOOTBLOWER 14, LEFT (E)

Task ID	Description	Status	Measurement Point	Value	Date	Observations
80	8 ตรวจสอบที่ล้นลาว (Loop control)	WPLAN		0		
85	() มกดี () ผิดปกติ = น้อยผิดปกติ, งอ, ขาด, ลื่นๆไปรอด รูป.....	WPLAN		0		
90	การวัดค่า และ ทดสอบเดินเครื่องทำงาน	WPLAN		0		
100	1 ทดสอบค่าความเป็นฉนวนระหว่างเฟสกับกราวด์ของมอเตอร์ที่ 1 นาที (รวมสายไฟ)	WPLAN		0		
105	U,V,W - G =M-OHM (ค่าต้องมากกว่า 50 M-OHM)	WPLAN		0		
110	การดำเนินการ	WPLAN		0		
115	1 ทำความสะอาดมอเตอร์และอุปกรณ์ที่ได้ทำการตรวจสอบหน้างาน	WPLAN		0		
120	() มกดี = ทำเรียบร้อยแล้ว ไม่รอด รูป.....	WPLAN		0		

Task ID	Craft	Skill Level	Labor	Vendor	Contract	Qty	Hours	Rate	Line Cost
	PUH-ELEC	LV1				2	00:30	80.00	80.00
							Total Planned Labor:		80.00