



Analysis / Test Report

TESTING
No.0166

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O :

Project Name : Water Testing : BPK

Project Location :

Lot ID: 2393707

Date Received : Sep 06, 2023

Date Reported : Sep 22, 2023

Report Number : 2785972-1

Page 1 of 2

Sample Number	2393707-1
Sampled Date	Sep 05, 2023 1:02 PM
Sample Description	น้ำประปาต้นทาง (น้ำประปาโรงผลิตน้ำ)
Location	บ่อเก็บน้ำประปาโรงผลิต
Date Analysis Commenced	Sep 06, 2023
Condition of Sample	Contained in four plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Metals Testing							
Iron	mg/L	0.001	0.005	0.008	≤0.3	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 3125 B, 3030 F	Songkhla
Manganese	mg/L	0.001	0.005	0.02	≤0.3	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 3125 B, 3030 F	Songkhla
Microbiological Testing							
^[A] <i>Escherichia coli</i>	MPN/100mL	-	-	<1.1	<1.1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 9221 F	Bangkok
^[A] Total Coliform	MPN/100mL	-	-	<1.1	<1.1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 9221 B	Bangkok
Water Testing							
^[A] Chloride as Cl	mg/L	0.06	0.2	28.1	≤250	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4110 B	Bangkok
Color (Apparent) *	Color unit	-	5	<5	≤15	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 2120 B	Songkhla
^[A] Nitrate as NO ₃	mg/L	0.3	1.0	52.8	≤50	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4110 B	Bangkok
pH at 25 degree C		-	-	6.7	6.5-8.5	In-house method : STM 13-001 based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4500 - H (B)	Songkhla

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Ananta B.

Ananta Boonphet
Scientist (2)

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER



Analysis / Test Report

TESTING
No.0166

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O :

Project Name : Water Testing : BPK

Project Location :

Lot ID: 2393707

Date Received : Sep 06, 2023

Date Reported : Sep 22, 2023

Report Number : 2785972-1

Page 2 of 2

Sample Number	2393707-1
Sampled Date	Sep 05, 2023 1:02 PM
Sample Description	น้ำประปาต้นทาง (น้ำประปาโรงผลิตน้ำ)
Location	บ่อเก็บน้ำประปาโรงผลิต
Date Analysis Commenced	Sep 06, 2023
Condition of Sample	Contained in four plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Water Testing							
Residual Free Chlorine	mg/L	-	0.1	0.4	No Standard	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4500-Cl (F)	Songkhla
^[A] Sulfate	mg/L	0.15	0.5	7.4	≤250	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4110 B	Bangkok
Total Dissolved solids Dried at 180 degree C	mg/L	-	5	168	≤500	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 2540 C	Songkhla
Total Hardness as CaCO ₃	mg/L	-	1	47	≤300	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 2340 C	Songkhla
Turbidity	NTU	-	0.1	0.29	≤5	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 2130 B	Songkhla

Guideline : เกณฑ์คุณภาพน้ำประปาดื่มได้ ประกาศ กรมอนามัย พ.ศ. 2563

Sampling By : Yuttapong Rattana , Thaksin Aintrom

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- [A] Analysis conducted by ALS Laboratory Group (Thailand) Co.,Ltd. Bangkok Branch, DMSc Accreditation No. 1031/47.
- The laboratory has been accepted as an accredited laboratory complying with the ISO/IEC 17025.

The above results are valid only for the analyzed/tested sample(s) as indicated in this report. No part of this report or certificate may be reproduced in any form without written consent from the Laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Ananta B.

Ananta Boonphet
Scientist (2)

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER