



Accreditation No. 1031/47

Analysis / Test Report

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O :

Project Name : Water Testing : BPK

Project Location :

Lot ID: 23122774

Date Received : Nov 08, 2023

Date Reported : Nov 24, 2023

Report Number : 2839042-1

Page 1 of 1

Sample Number	23122774-14
Sampled Date	Nov 07, 2023 10:43 AM
Sample Description	น้ำดื่มขวดเขียวในระบม Cooling tower
Location	น้ำดื่มขวดเขียวในระบม Cooling tower
Date Analysis Commenced	Nov 08, 2023
Condition of Sample	Contained in two plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Method	Testing Location
Microbiological Testing						
<i>Legionella spp.</i>	CFU/L	-	-	<1	ISO 11731 (2017)	Bangkok

Note : Microbiological Testing Result <1 mean Bacteria not found in agar plate.

Sampling By : Thaksin Aintrom , Sakkarin Panpheng

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- The laboratory has been accepted as an accredited laboratory complying with the ISO/IEC 17025.

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. No part of this report may be reproduced in any form without written consent from the laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Suwannee Chuamkeaw
Section Head

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER