[redacted]

Document Title

SWITCHGEAR INSPECTION

Form Number : UGP-FO-MN-307
Revision : 00
Issued Date : 1 May 2021

TAG KKS NO.	: 10AKS07	**USER NAME**	: SPARE	**LOCATION**	: Electrical Room
RATE VOLTAGE	: 12,000 V	**RATE CURRENT**	: 800 A	**TYPE**	: VCB
MANUFACTURER	: Siemens	**SERIAL NO.**	: 3AE5/00027790	**PM FREQUENC**	: Monthly

CHECKED DATE	VOLTAGE (kV)	CURRENT (A)	COUNTER	MODE SELECTOR		PROTECTION RELAY		POWER QUALITY METER		LAMP STATUS			PANEL CLEANING		INSPECTED BY	APPROVED BY	REMARK
				LOCAL	REMOTE	NORMAL	ABNORMAL	NORMAL	ABNORMAL	CLOSE (R)	OPEN (G)	TRIP (Y)	YES	NO			
3/4/66	11.1	0	108	✓		✓		✓			✓		✓		[redacted]	[redacted]	
9/5/66	11.2	0	108	✓		✓		✓			✓		✓				
1/6/66	11.1	0	108	✓		✓		✓			✓		✓				
3/7/66	11.2	0	108	✓		✓		✓			✓		✓				
1/8/66	11.2	0	108	✓		✓		✓			✓		✓				
4/9/66	11.1	0	108	✓		✓		✓			✓		✓				
2/10/66	11.2	0	108	✓		✓		✓			✓		✓				
9/11/66	11.2	0	112	✓		✓		✓			✓		✓				
4/12/66	11.2	0	112	✓		✓		✓			✓		✓				

This document is U THONG GREEN POWER Ltd. C-Segment and cannot be used, reproduced or transmited to thirds party without prior written permission.

[redacted]

Document Title

SWITCHGEAR INSPECTION

Form Number : UGP-FO-MN-307
Revision : 00
Issued Date : 1 May 2021

TAG KKS NO.	: 10AKE01	**USER NAME**	: BUS EARTHING TR 50 KVA	**LOCATION**	: Electrical Room
RATE VOLTAGE	: 6,000/12,000 V	**RATE CURRENT**	: 6/3 A	**TYPE**	: FLBS
MANUFACTURER	: Siemens	**SERIAL NO.**	:	**PM FREQUEN(**	: Monthly

CHECKED DATE	VOLTAGE (kV)	CURRENT (A)	COUNTER	MODE SELECTOR		PROTECTION RELAY		POWER QUALITY METER		LAMP STATUS			PANEL CLEANING		INSPECTED BY	APPROVED BY	REMARK
				LOCAL	REMOTE	NORMAL	ABNORMAL	NORMAL	ABNORMAL	CLOSE (R)	OPEN (G)	TRIP (Y)	YES	NO			
3/4/66	-	-	-	-	-	✓		✓			✓	✓	✓		[redacted]	[redacted]	
9/5/66	-	-	-	✓	-	✓		✓			✓	✓	✓				
9/6/66	-	-	-	-	-	✓		✓			✓	✓	✓				
3/7/66	-	-	-	-	-	✓		-			-	-	✓				
1/8/66	-	-	-	-	-	✓		✓			-	-	✓				
4/9/66	-	-	-	-	-	✓		-			-	-	✓				
2/5/66	-	-	-	-	-	✓		-			-	-	✓				
1/11/66	-	-	-	-	-	✓		-			✓	-	✓				
4/12/66	-	-	-	-	-	✓		✓			✓	✓	✓				

This document is U THONG GREEN POWER Ltd. C-Segment and cannot be used, reproduced or transmited to thirds party without prior written permission.