



# เอกสารแนบที่ 3 แผนการบำรุงรักษาเครื่องจักร อุปกรณ์ และระบบหล่อเย็น

	Maintenance Activities Report	
	Section	Mechanical
	Subject	Pm Cooling tower fan No.1 (4,000 hrs)
	Work order No.	
	Duration	31 October 2023


Equipment Name : Cooling tower fan No.1  
 Equipment KKS : 00PAD10AN010  
 Running Time : hrs  
 Description : Pm Cooling tower fan No.1 (4,000 hrs)  
 Date of work : 31 October 2023



## Action work

Replace lubricant gear oil 70 liters and Cleaning and leaking check oil level



	Maintenance Activities Report	
	Section	Mechanical
	Subject	Pm Cooling tower fan No.1 (4,000 hrs)
	Work order No.	
	Duration	31 October 2023

Refill lubricant gear oil 70 liters



Cleaning and inspection coupling




Oil sample




cleaning working area



**Completed**

	Maintenance Activities Report	
	Section	Mechanical
	Subject	Pm Cooling tower fan No.2
	Work order No.	
	Duration	31 October 2023

Equipment Name : Cooling tower fan No.2  
 Equipment KKS : 00PAD20AN010  
 Running Time : hrs  
 Description : Pm Cooling tower fan No.2 (4,000 hrs)  
 Date of work : 31 October 2023




## Action work

Replace lubricant gear oil 70 liters and Cleaning and leaking check oil level






	Maintenance Activities Report	
	Section	Mechanical
	Subject	Pm Cooling tower fan No.2
	Work order No.	
	Duration	31 October 2023


Refill lubricant gear oil 70 liters



Cleaning and inspection coupling



Oil sample




cleaning working area



Completed


Maintenance Activities Report	
Section	Mechanical
Subject	Pm Cooling tower fan No.3
Work order No.	
Duration	2 November 2023

Equipment Name : Cooling tower fan No.3  
 Equipment KKS : 00PAD30AN010  
 Running Time : hrs  
 Description : Pm Cooling tower fan No.3 (4,000 hrs)  
 Date of work : 2 November 2023




## Action work


Replace lubricant gear oil 70 liters and Cleaning and leaking check oil level





	Maintenance Activities Report	
	Section	Mechanical
	Subject	Pm Cooling tower fan No.3
	Work order No.	
	Duration	2 November 2023

Refill lubricant gear oil 70 liters



Inspection both coupling and shaft drive and cleaning




Oil sample




cleaning working area



**Completed**

	Maintenance Activities Report	
	Section	Mechanical
	Subject	Pm Cooling tower fan No.5
	Work order No.	
	Duration	6 November 2023

Equipment Name : Cooling tower fan No.5  
 Equipment KKS : 00PAD50AN010  
 Running Time : hrs  
 Description : Pm Cooling tower fan No.5 (4,000 hrs)  
 Date of work : 6 November 2023




## Action work

Replace lubricant gear oil 70 liters and Cleaning and leaking check oil level





	Maintenance Activities Report	
	Section	Mechanical
	Subject	Pm Cooling tower fan No.5
	Work order No.	
	Duration	6 November 2023

Refill lubricant gear oil 70 liters



Inspection both coupling and shaft drive and cleaning



Oil sample



cleaning working area



**Completed**