



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000

E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 1/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	July 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	July 7, 2023
Sampling Source ^[5]	Wastewater Treatment Systems (Effluent)	Analyzed Date	July 7-14, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	July 15, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6607031

Sampling Name ^[5]	Effluent
Sampling Time ^[5]	10.23 AM
Analysis No.	25662437

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0 °C	-	SM : 4500-H ⁺ B	6.9	5.0-9.0
2. Biochemical Oxygen Demand ^[4]	mg/L	SM : 5210 B	31.5	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	11.1	≤ 40
4. Total Kjeldahl Nitrogen ^[4]	mg/L	SM : 4500 N _{org} B	17.6	≤ 35
5. Oil & Grease ^[4]	mg/L	SM : 5520 B	0.5	≤ 20
6. Total Dissolved Solids	mg/L	SM : 2540 C	609	≤ 500 ^[6]
7. Sulfide ^[4]	mg/L	SM : 4500-S ²⁻ F	0.6	≤ 1.0

Physical Appearance Sample 25662437 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class B), Vol. 122 Part 125D., December 29th 2005.

[3] : Outside the scope of certification for registration of private analytical laboratories No. ๖-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : These values are in addition to the TDS of the water used. (TDS 25662441 = 126.53 mg/L)

Reported By :

จันทิพ มิตตะ

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

17/7/23

Approved By :

สาอวพา นุกาอว

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

15/7/23

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

ห้องปฏิบัติการวิเคราะห์เอกชน

เลขทะเบียน ๖-250

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	July 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	July 7, 2023
Sampling Source ^[5]	Wastewater Treatment System (Effluent)	Analyzed Date	July 7-14, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	July 15, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat	Report No.	PKT6607031
Sampling Name ^[5]	Effluent		
Sampling Time ^[5]	10.23 AM		
Analysis No.	25662437		

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
8. Settleable Solids ^{[3][4]}	ml/L	SM : 2540 F	Not Detected	≤ 0.5

Physical Appearance Sample 25662437 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class A), Vol. 122 Part 125D., December 29th 2005.

[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : These values are in addition to the TDS of the water used. (TDS 25662441 = 126.53 mg/L)

Reported By :

Miss. Jantip Mittaka

Laboratory Analyst

17/7/66

Approved By :

Miss. Saowapa Nukaew

Laboratory Manager

15/7/66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

The results of analysis are valid for the submitted sample only.

Date announced for October 26, 2021

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 1/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	August 9, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	August 9, 2023
Sampling Source ^[5]	Wastewater Treatment Systems (Effluent)	Analyzed Date	August 9-16, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	August 17, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6608061

Sampling Name ^[5]	Effluent
Sampling Time ^[5]	10.25 AM
Analysis No.	25662906

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0°C	-	SM : 4500-H ⁺ B	6.6	5.0-9.0
2. Biochemical Oxygen Demand ^[4]	mg/L	SM : 5210 B	10.8	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	2.8	≤ 40
4. Total Kjeldahl Nitrogen ^[4]	mg/L	SM : 4500 N _{org} B	3.9	≤ 35
5. Oil & Grease ^[4]	mg/L	SM : 5520 B	Not Detected	≤ 20
6. Total Dissolved Solids	mg/L	SM : 2540 C	374	≤ 500 ^[6]
7. Sulfide ^[4]	mg/L	SM : 4500-S ²⁻ F	0.4	≤ 1.0

Physical Appearance Sample 25662906 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class B), Vol. 122 Part 125D., December 29th 2005.

[3] : Outside the scope of certification for registration of private analytical laboratories No. ๖-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : These values are in addition to the TDS of the water used. (TDS 25662910 = 275 mg/L)

Reported By : จันทิพย์ มิตราก

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

17, 8, ๒๖

Approved By : สาอวป นุกาเว

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

17, 8, ๒๖



BC & E

ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.01

The results of analysis are valid for the submitted sample only.

Date announced for October 26, 2021

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000

E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	August 9, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	August 9, 2023
Sampling Source ^[5]	Wastewater Treatment System (Effluent)	Analyzed Date	August 9-16, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	August 17, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat	Report No.	PKT6608061

Sampling Name ^[5]	Effluent
Sampling Time ^[5]	10.25 AM
Analysis No.	25662906

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
8. Settleable Solids ^{[3][4]}	ml/L	SM : 2540 F	Not Detected	≤ 0.5

Physical Appearance Sample 25662906 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017
 [2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class A), Vol. 122 Part 125D., December 29th 2005.
 [3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250
 [4] : Outside the scope of certification, TIS 17025-2017, Testing 0548
 [5] : Information received from customers
 [6] : These values are in addition to the TDS of the water used. (TDS 25662910 = 275 mg/L)

Reported By :

จันทิพย์ มิตตะกะ

Approved By :

สาอวพา นุกาแวง

Miss. Jantip Mittaka

Miss. Saowapa Nukaew

Laboratory Analyst

Laboratory Manager

17 / 8 / 66

17 / 8 / 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
 ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

The results of analysis are valid for the submitted sample only.

Date announced for October 26, 2021

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 1/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	September 7, 2023.
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	September 8, 2023
Sampling Source ^[5]	Wastewater Treatment Systems (Effluent)	Analyzed Date	September 8-15, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	September 16, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (จ-250-จ-0003)	Report No.	PKT6609036

Sampling Name ^[5]	Effluent
Sampling Time ^[5]	10.36 AM
Analysis No.	25663221

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0°C	-	SM : 4500-H ⁺ B	7.1	5.0-9.0
2. Biochemical Oxygen Demand ^[4]	mg/L	SM : 5210 B	24.3	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	3.1	≤ 40
4. Total Kjeldahl Nitrogen ^[4]	mg/L	SM : 4500 N _{org} B	2.0	≤ 35
5. Oil & Grease ^[4]	mg/L	SM : 5520 B	0.1	≤ 20
6. Total Dissolved Solids	mg/L	SM : 2540 C	380	≤ 500 ^[6]
7. Sulfide ^[4]	mg/L	SM : 4500-S ²⁻ F	0.3	≤ 1.0

Physical Appearance Sample 25663221 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class B), Vol. 122 Part 125D., December 29th 2005.

[3] : Outside the scope of certification for registration of private analytical laboratories No. จ-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : These values are in addition to the TDS of the water used. (TDS 25663225 = 355 mg/L)

Reported By : จันทิพย์ มิตตะกะ
Miss. Jantip Mittaka (จ-250-จ-0004)

Aproved By : สาอวพา นุกาแวง
Miss. Saowapa Nukaew (จ-250-ก-0002)

Laboratory Analyst
16/9/66



Laboratory Manager
16/9/66

ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน จ-250

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written appraisal.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo6 Sakdidat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	September 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	September 8, 2023
Sampling Source ^[5]	Wastewater Treatment System (Effluent)	Analyzed Date	September 8-15, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	September 16, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat	Report No.	PKT6609036

Sampling Name ^[5]	Effluent
Sampling Time ^[5]	10.36 AM
Analysis No.	25663221

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
8. Settleable Solids ^{[3][4]}	ml/L	SM : 2540 F	Not Detected	≤ 0.5

Physical Appearance Sample 25663221 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class A), Vol. 122 Part 125D., December 29th 2005.

[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : These values are in addition to the TDS of the water used. (TDS 25663225 = 355 mg/L)

Reported By :

จันทิพย์ มิตรคม

Aproved By :

สาอวพา นุกาเวย

Miss. Jantip Mittaka

Miss. Saowapa Nukaew

Laboratory Analyst

Laboratory Manager

16 / 9 / 66

16 / 9 / 66



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

The results of analysis are valid for the submitted sample only.

Date announced for October 26, 2021

The report shall not be reproduced, except in Full, without the written approral.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000

E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 1/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	October 5, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	October 5, 2023
Sampling Source ^[5]	Wastewater Treatment Systems (Effluent)	Analyzed Date	October 5-17, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	October 18, 2023
Sampling By ^[5]	Miss Yonlatda Thancerat (ว-250-ท-0003)	Report No.	PKT6610018

Sampling Name ^[5]	Effluent
Sampling Time ^[5]	10.42 AM
Analysis No.	25663605

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0°C	-	SM : 4500-H ⁺ B	7.1	5.0-9.0
2. Biochemical Oxygen Demand ^[4]	mg/L	SM : 5210 B	6.3	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	5.2	≤ 40
4. Total Kjeldahl Nitrogen ^[4]	mg/L	SM : 4500 N _{org} B	1.1	≤ 35
5. Oil & Grease ^[4]	mg/L	SM : 5520 B	Not Detected	≤ 20
6. Total Dissolved Solids	mg/L	SM : 2540 C	367	≤ 500 ^[6]
7. Sulfide ^[4]	mg/L	SM : 4500-S ²⁻ F	0.4	≤ 1.0

Physical Appearance Sample 25663605 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class B), Vol. 122 Part 125D., December 29th 2005.

[3] : Outside the scope of certification for registration of private analytical laboratories No. ว-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : These values are in addition to the TDS of the water used. (TDS 25663609 = 347.62 mg/L)

Reported By :

จันทิพร มิตตะกะ

Miss. Jantip Mittaka (ว-250-ท-0004)

Laboratory Analyst

18 / 10 / 66

Aproved By :

สาอวพา นุกาอว

Miss. Saowapa Nukaew (ว-250-ท-0002)

Laboratory Manager

18 / 10 / 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ว-250

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written appraisal.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

BC & E

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000

E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	October 5, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	October 5, 2023
Sampling Source ^[5]	Wastewater Treatment System (Effluent)	Analyzed Date	October 5-17, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	October 18, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat	Report No.	PKT6610018

Sampling Name ^[5]	Effluent
Sampling Time ^[5]	10.42 AM
Analysis No.	25663605

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
8. Settleable Solids ^{[3][4]}	ml/L	SM : 2540 F	Not Detected	≤ 0.5

Physical Appearance Sample 25663605 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017
- [2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class A), Vol. 122 Part 125D., December 29th 2005.
- [3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250
- [4] : Outside the scope of certification, TIS 17025-2017, Testing 0548
- [5] : Information received from customers
- [6] : These values are in addition to the TDS of the water used. (TDS 25663609 = 347.62 mg/L)

Reported By :

Miss. Jantip Mittaka

Laboratory Analyst

18/10/26

Approved By :

Miss. Saowapa Nukaew

Laboratory Manager

18/10/26

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

The results of analysis are valid for the submitted sample only.

Date announced for October 26, 2021

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 1/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	November 9, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	November 10, 2023
Sampling Source ^[5]	Wastewater Treatment Systems (Effluent)	Analyzed Date	November 10-17, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	November 18, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6611058

Sampling Name ^[5]	Effluent
Sampling Time ^[5]	10.46 AM
Analysis No.	25664192

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0°C	-	SM : 4500-H ⁺ B	6.7	5.0-9.0
2. Biochemical Oxygen Demand ^[4]	mg/L	SM : 5210 B	3.8	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	4.8	≤ 40
4. Total Kjeldahl Nitrogen ^[4]	mg/L	SM : 4500 N _{org} B	17.4	≤ 35
5. Oil & Grease ^[4]	mg/L	SM : 5520 B	Not Detected	≤ 20
6. Total Dissolved Solids	mg/L	SM : 2540 C	361	≤ 500 ^[6]
7. Sulfide ^[4]	mg/L	SM : 4500-S ²⁻ F	0.3	≤ 1.0

Physical Appearance Sample 25664192 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class B), Vol. 122 Part 125D., December 29th 2005.


[3] : Outside the scope of certification for registration of private analytical laboratories No. ๖-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : These values are in addition to the TDS of the water used. (TDS 25664196 = 338.09 mg/L)


Reported By :


Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

18 / 11 / 66

Aproved By :


Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

18 / 11 / 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.01

The results of analysis are valid for the submitted sample only.

Date announced for October 26, 2021

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 2/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	November 9, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	November 10, 2023
Sampling Source ^[5]	Wastewater Treatment System (Effluent)	Analyzed Date	November 10-17, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	November 18, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat	Report No.	PKT6611058
Sampling Name ^[5]	Effluent		
Sampling Time ^[5]	10.46 AM		
Analysis No.	25664192		

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
8. Settleable Solids ^{[3][4]}	ml/L	SM : 2540 F	Not Detected	≤ 0.5

Physical Appearance Sample 25664192 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class A), Vol. 122 Part 125D., December 29th 2005.

[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : These values are in addition to the TDS of the water used. (TDS 25664196 = 338.09 mg/L)

Reported By :

Miss. Jantip Mittaka

Laboratory Analyst

18 / 11 / 66

Approved By :

Miss. Saowapa Nukaew

Laboratory Manager

18 / 11 / 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 1/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	December 8, 2566
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	December 9, 2566
Sampling Source ^[5]	Wastewater Treatment Systems (Effluent)	Analyzed Date	December 9-16, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	December 18, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (๖-250-๐-0003)	Report No.	PKT6612048

Sampling Name ^[5]	Effluent
Sampling Time ^[5]	11.12 AM
Analysis No.	25664524

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0°C	-	SM : 4500-H ⁺ B	6.6	5.0-9.0
2. Biochemical Oxygen Demand ^[4]	mg/L	SM : 5210 B	3.0	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	5.6	≤ 40
4. Total Kjeldahl Nitrogen ^[4]	mg/L	SM : 4500 N _{org} B	6.3	≤ 35
5. Oil & Grease ^[4]	mg/L	SM : 5520 B	Not Detected	≤ 20
6. Total Dissolved Solids	mg/L	SM : 2540 C	348	≤ 500 ^[6]
7. Sulfide ^[4]	mg/L	SM : 4500-S ²⁻ F	0.1	≤ 1.0

Physical Appearance Sample 25664524 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017
- [2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class B), Vol. 122 Part 125D., December 29th 2005.
- [3] : Outside the scope of certification for registration of private analytical laboratories No. ๖-250
- [4] : Outside the scope of certification, TIS 17025-2017, Testing 0548
- [5] : Information received from customers
- [6] : These values are in addition to the TDS of the water used. (TDS 25664528 = 407.50 mg/L)

Reported By :

Miss. Jantip Mittaka (๖-250-๐-0004)

Laboratory Analyst

18/12/66

Aproved By :

Miss. Saowapa Nukaew (๖-250-๐-0002)

Laboratory Manager

18/12/66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.01

The results of analysis are valid for the submitted sample only.

Date announced for October 26, 2021

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	December 8, 2566
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	December 9, 2566
Sampling Source ^[5]	Wastewater Treatment System (Effluent)	Analyzed Date	December 9-16, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	December 18, 2023
Sampling By ^[5]	Miss Vonlatda Thaneerat	Report No.	PKT6612048
Sampling Name ^[5]	Effluent		
Sampling Time ^[5]	11.12 AM		
Analysis No.	25664524		

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
8. Settleable Solids ^{[3][4]}	ml/L	SM : 2540 F	Not Detected	≤ 0.5

Physical Appearance Sample 25664524 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class A), Vol. 122 Part 125D., December 29th 2005.

[3] : Outside the scope of certification for registration of private analytical laboratories No. 2-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : These values are in addition to the TDS of the water used. (TDS 25664528 = 407.50 mg/L)

Reported By :

Miss. Jantip Mittaka

Laboratory Analyst

18/12/21

Approved By :

Miss. Saowapa Nukaew

Laboratory Manager

18/12/21

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000

E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	July 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	July 7, 2023
Sampling Source ^[5]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	July 7-14, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	July 15, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6607031

Sampling Name ^[5]	Effluent
Sampling Time ^[5]	10.17 AM
Analysis No.	25662438

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0°C	-	SM : 4500-H ⁺ B	6.8	5.0-9.0
2. Biochemical Oxygen Demand ^[4]	mg/L	SM : 5210 B	62.3	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	20.5	≤ 40
4. Total Kjeldahl Nitrogen ^[4]	mg/L	SM : 4500 N _{org} B	23.8	≤ 35
5. Oil & Grease ^[4]	mg/L	SM : 5520 B	Not Detected	≤ 20
6. Total Dissolved Solids	mg/L	SM : 2540 C	598	≤ 500 ^[6]
7. Sulfide ^[4]	mg/L	SM : 4500-S ²⁻ F	0.7	≤ 1.0

Physical Appearance Sample 25662438 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class B), Vol. 122 Part 125D., December 29th 2005.

[3] : Outside the scope of certification for registration of private analytical laboratories No. ๖-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : These values are in addition to the TDS of the water used. (TDS 25662441 = 126.53 mg/L)

Reported By :

จันทิภา มิตตะกะ

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

15/7/66

Aproved By :

สาอวพา นุกาอว

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

15/7/66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

ห้องปฏิบัติการวิเคราะห์เอกชน

เลขทะเบียน ๖-250

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 4/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	July 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	July 7, 2023
Sampling Source ^[5]	Wastewater Treatment System (Retention Tank)	Analyzed Date	July 7-14, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	July 15, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat	Report No.	PKT6607031
Sampling Name ^[5]	Effluent		
Sampling Time ^[5]	10.17 AM		
Analysis No.	25662438		

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
8. Settleable Solids ^{[3][4]}	ml/L	SM : 2540 F	Not Detected	≤ 0.5

Physical Appearance Sample 25662438 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class A), Vol. 122 Part 125D., December 29th 2005.

[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : These values are in addition to the TDS of the water used. (TDS 25662441 = 126.53 mg/L)

Reported By :

จันทิพ มิตตะกา

Miss. Jantip Mittaka

Laboratory Analyst

15/7/66

Approved By :

สาอวพา นุกาแวง

Miss. Saowapa Nukaew

Laboratory Manager

15/7/66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	August 9, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	August 9, 2023
Sampling Source ^[5]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	August 9-16, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	August 17, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6608061

Sampling Name ^[5]	Effluent
Sampling Time ^[5]	10.36 AM
Analysis No.	25662907

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0 °C	-	SM : 4500-H ⁻ B	6.6	5.0-9.0
2. Biochemical Oxygen Demand ^[4]	mg/L	SM : 5210 B	4.5	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	5.7	≤ 40
4. Total Kjeldahl Nitrogen ^[4]	mg/L	SM : 4500 N _{org} B	4.3	≤ 35
5. Oil & Grease ^[4]	mg/L	SM : 5520 B	Not Detected	≤ 20
6. Total Dissolved Solids	mg/L	SM : 2540 C	351	≤ 500 ^[6]
7. Sulfide ^[4]	mg/L	SM : 4500-S ²⁻ F	0.1	≤ 1.0

Physical Appearance Sample 25662907 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017
[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class B), Vol. 122 Part 125D., December 29th 2005.
[3] : Outside the scope of certification for registration of private analytical laboratories No. ๖-250
[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[5] : Information received from customers
[6] : These values are in addition to the TDS of the water used. (TDS 25662910 = 275 mg/L)

Reported By : จันทิพ มิตตะกะ

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

17.8.๒๒

Aproved By : สาอวป นุกะว

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

17.8.๒๒

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.01

The results of analysis are valid for the submitted sample only.

Date announced for October 26, 2021

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 4/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	August 9, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	August 9, 2023
Sampling Source ^[5]	Wastewater Treatment System (Retention Tank)	Analyzed Date	August 9-16, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	August 17, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat	Report No.	PKT6608061

Sampling Name ^[5]	Effluent
Sampling Time ^[5]	10.36 AM
Analysis No.	25662907

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
8. Settleable Solids ^{[3][4]}	ml/L	SM : 2540 F	Not Detected	≤ 0.5

Physical Appearance Sample 25662907 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class A), Vol. 122 Part 125D., December 29th 2005.

[3] : Outside the scope of certification for registration of private analytical laboratories No. 3-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : These values are in addition to the TDS of the water used. (TDS 25662910 = 275 mg/L)

Reported By :

จันทิพ มิตตะกา

Approved By :

สาอวพา นุกาเว

Miss. Jantip Mittaka

Miss. Saowapa Nukaew

Laboratory Analyst

Laboratory Manager

17 / 8 / 66

17 / 8 / 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

The results of analysis are valid for the submitted sample only.

Date announced for October 26, 2021

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	September 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	September 8, 2023
Sampling Source ^[5]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	September 8-15, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	September 16, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (7-250-9-0003)	Report No.	PKT6609036

Sampling Name ^[5]	Effluent
Sampling Time ^[5]	10.32 AM
Analysis No.	25663222

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0 °C	-	SM : 4500-H ⁺ B	6.6	5.0-9.0
2. Biochemical Oxygen Demand ^[4]	mg/L	SM : 5210 B	11.9	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	3.3	≤ 40
4. Total Kjeldahl Nitrogen ^[4]	mg/L	SM : 4500 N _{org} B	Not Detected	≤ 35
5. Oil & Grease ^[4]	mg/L	SM : 5520 B	Not Detected	≤ 20
6. Total Dissolved Solids	mg/L	SM : 2540 C	371	≤ 500 ^[6]
7. Sulfide ^[4]	mg/L	SM : 4500-S ²⁻ F	0.1	≤ 1.0

Physical Appearance Sample 25663222 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017
[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class B), Vol. 122 Part 125D., December 29th 2005.
[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250
[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[5] : Information received from customers
[6] : These values are in addition to the TDS of the water used. (TDS 25663225 = 355 mg/L)

Reported By :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka (7-250-9-0004)

Laboratory Analyst

16/9/22

Aproved By :

Miss. Saowapa Nukaew

Miss. Saowapa Nukaew (7-250-9-0002)

Laboratory Manager

16/9/22

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน 7-250

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo6 Sakdidat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 4/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	September 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	September 8, 2023
Sampling Source ^[5]	Wastewater Treatment System (Retention Tank)	Analyzed Date	September 8-15, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	September 16, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat	Report No.	PKT6609036

Sampling Name ^[5]	Effluent
Sampling Time ^[5]	10.32 AM
Analysis No.	25663222

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
8. Settleable Solids ^{[3][4]}	ml/L	SM : 2540 F	Not Detected	≤ 0.5

Physical Appearance Sample 25663222 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class A), Vol. 122 Part 125D., December 29th 2005.

[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : These values are in addition to the TDS of the water used. (TDS 25663225 = 355 mg/L)

Reported By :

จันทิพ มิตตะกะ
Miss. Jantip Mittaka

Miss. Jantip Mittaka

Laboratory Analyst

16 / 9 / 66

Aproved By :

สาอวพา นุกาแวง
Miss. Saowapa Nukaew

Miss. Saowapa Nukaew

Laboratory Manager

16 / 9 / 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000

E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	October 5, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	October 5, 2023
Sampling Source ^[5]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	October 5-17, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	October 18, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (1-250-0-0003)	Report No.	PKT6610018

Sampling Name ^[5]	Effluent
Sampling Time ^[5]	10.45AM
Analysis No.	25663606

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0°C	-	SM : 4500-H ⁺ B	7.1	5.0-9.0
2. Biochemical Oxygen Demand ^[4]	mg/L	SM : 5210 B	12.0	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	5.5	≤ 40
4. Total Kjeldahl Nitrogen ^[4]	mg/L	SM : 4500 N _{org} B	3.6	≤ 35
5. Oil & Grease ^[4]	mg/L	SM : 5520 B	Not Detected	≤ 20
6. Total Dissolved Solids	mg/L	SM : 2540 C	380	≤ 500 ^[6]
7. Sulfide ^[4]	mg/L	SM : 4500-S ²⁻ F	0.1	≤ 1.0

Physical Appearance Sample 25663606 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Notification of the Ministry of Natural Resources and Environment; Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class B), Vol. 122 Part 125D., December 29th 2005.

[3] : Outside the scope of certification for registration of private analytical laboratories No. 1-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : These values are in addition to the TDS of the water used. (TDS 25663609 = 347.62 mg/L)

Reported By :

จันทิพร มิตตะ

Miss. Jantip Mittaka (1-250-0-0004)

Laboratory Analyst

18/10/66

Aproved By :

สาอวพา นุกาอว

Miss. Saowapa Nukaew (1-250-0-0002)

Laboratory Manager

18/10/66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

ห้องปฏิบัติการวิเคราะห์เอกชน

เลขทะเบียน 1-250

FM-QP-13/01 Rev.01

The results of analysis are valid for the submitted sample only.

Date announced for October 26, 2021

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 4/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	October 5, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	October 5, 2023
Sampling Source ^[5]	Wastewater Treatment System (Retention Tank)	Analyzed Date	October 5-17, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	October 18, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat	Report No.	PKT6610018
Sampling Name ^[5]	Effluent		
Sampling Time ^[5]	10.45 AM		
Analysis No.	25663606		

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
8. Settleable Solids ^{[3][4]}	ml/L	SM : 2540 F	Not Detected	≤ 0.5

Physical Appearance Sample 25663606 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017
[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class A), Vol. 122 Part 125D., December 29th 2005.
[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250
[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[5] : Information received from customers
[6] : These values are in addition to the TDS of the water used. (TDS 25663609 = 347.62 mg/L)

Reported By :

จันทิพย์ มิตตะกะ

Approved By :

Miss. Saowapa Nukaew

Miss. Jantip Mittaka

Laboratory Analyst

18, 10, 66

Laboratory Manager

18, 10, 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

The results of analysis are valid for the submitted sample only.

Date announced for October 26, 2021

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 3/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	November 9, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	November 10, 2023
Sampling Source ^[5]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	November 10-17, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	November 18, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6611058

Sampling Name ^[5]	Effluent
Sampling Time ^[5]	10.41 AM
Analysis No.	25664193

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0°C	-	SM : 4500-H ⁺ B	6.9	5.0-9.0
2. Biochemical Oxygen Demand ^[4]	mg/L	SM : 5210 B	4.4	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	4.1	≤ 40
4. Total Kjeldahl Nitrogen ^[4]	mg/L	SM : 4500 N _{org} B	14.0	≤ 35
5. Oil & Grease ^[4]	mg/L	SM : 5520 B	Not Detected	≤ 20
6. Total Dissolved Solids	mg/L	SM : 2540 C	345	≤ 500 ^[6]
7. Sulfide ^[4]	mg/L	SM : 4500-S ²⁻ F	0.9	≤ 1.0

Physical Appearance Sample 25664193 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class B), Vol. 122 Part 125D., December 29th 2005.

[3] : Outside the scope of certification for registration of private analytical laboratories No. ๖-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : These values are in addition to the TDS of the water used. (TDS 25664196 = 338.09 mg/L)

Reported By :

จันทิพร มิตตะกะ

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

18.11.66

Aproved By :

บศวรร ญะนา

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

15.11.66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 4/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	November 9, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	November 10, 2023
Sampling Source ^[5]	Wastewater Treatment System (Retention Tank)	Analyzed Date	November 10-17, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	November 18, 2023
Sampling By ^[5]	Miss Yonlatda Thanecrat	Report No.	PKT6611058
Sampling Name ^[5]	Effluent		
Sampling Time ^[5]	10.41 AM		
Analysis No.	25664193		

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
8. Settleable Solids ^{[3][4]}	ml/L	SM : 2540 F	Not Detected	≤ 0.5

Physical Appearance Sample 25664193 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class A), Vol. 122 Part 125D., December 29th 2005.

[3] : Outside the scope of certification for registration of private analytical laboratories No. 3-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : These values are in addition to the TDS of the water used. (TDS 25664196 = 338.09 mg/L)

Reported By : จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

18/11/66

Approved By : สาอวปภา นุกาเวย

Miss. Saowapa Nukaew

Laboratory Manager

18/11/66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	December 8, 2566
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	December 9, 2566
Sampling Source ^[5]	Wastewater Treatment Systems (Retention Tank)	Analyzed Date	December 9-16, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	December 18, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6612048

Sampling Name ^[5]	Effluent
Sampling Time ^[5]	10.42 AM
Analysis No.	25664525

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0°C	-	SM : 4500-H ⁺ B	6.5	5.0-9.0
2. Biochemical Oxygen Demand ^[4]	mg/L	SM : 5210 B	3.0	≤ 30
3. Total Suspended Solids	mg/L	SM : 2540 D	6.6	≤ 40
4. Total Kjeldahl Nitrogen ^[4]	mg/L	SM : 4500 N _{org} B	8.7	≤ 35
5. Oil & Grease ^[4]	mg/L	SM : 5520 B	Not Detected	≤ 20
6. Total Dissolved Solids	mg/L	SM : 2540 C	344	≤ 500 ^[6]
7. Sulfide ^[4]	mg/L	SM : 4500-S ²⁻ F	0.6	≤ 1.0

Physical Appearance Sample 25664525 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017
- [2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class B), Vol. 122 Part 125D., December 29th 2005.
- [3] : Outside the scope of certification for registration of private analytical laboratories No. ๖-250
- [4] : Outside the scope of certification, TIS 17025-2017, Testing 0548
- [5] : Information received from customers
- [6] : These values are in addition to the TDS of the water used. (TDS 25664528 = 407.50 mg/L)

Reported By :

จิราภรณ์ มิตรากะ

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

18/12/66

Approved By :

Miss. Saowapa Nukaew

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

18/12/66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

ห้องปฏิบัติการวิเคราะห์ตัวอย่าง

เลขที่ใบรับรอง ๖-๒๕๐-๖-๐๐๐๔

FM-QP-13/01 Rev.01

The results of analysis are valid for the submitted sample only.

Date announced for October 26, 2021

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000

E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 4/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	December 8, 2566
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	December 9, 2566
Sampling Source ^[5]	Wastewater Treatment System (Retention Tank)	Analyzed Date	December 9-16, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	December 18, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat	Report No.	PKT6612048
Sampling Name ^[5]	Effluent		
Sampling Time ^[5]	10.42 AM		
Analysis No.	25664525		

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
8. Settlicable Solids ^{[3][4]}	ml/L	SM : 2540 F	Not Detected	≤ 0.5

Physical Appearance Sample 25664525 : Clear yellow Liquid, no sediment Container : Normal PE 1.0 L, PE 2.0 L, G 0.5 L

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Notification of the Ministry of Natural Resources and Environment: Building Effluents Standards dated November 7th 2005 published in the Royal Government Gazette (Building Class A), Vol. 122 Part 125D., December 29th 2005.

[3] : Outside the scope of certification for registration of private analytical laboratories No. 2-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : These values are in addition to the TDS of the water used. (TDS 25664528 = 407.50 mg/L)

Reported By :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

18 / 12 / 66

Approved By :

สาอวปภา นุกาเอว

Miss. Saowapa Nukaew

Laboratory Manager

18 / 12 / 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

ห้องปฏิบัติการวิเคราะห์น้ำ

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	July 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	July 7, 2023
Sampling Source ^[5]	Main Pool	Analyzed Date	July 7-14, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	July 15, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6607031

Sampling Name ^[5]	Swimming Pool
Sampling Time ^[5]	10.11 AM
Analysis No.	25662442

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0°C	-	SM : 4500-H ⁺ B	6.3	7.2-8.4
2.Total Dissolved Solids	mg/L	SM : 2510	2950	-

Physical Appearance	Sample 25662442 : Clear liquid, colorless, no sediment	Container Normal : G 1000 mL
REMARK	<p>[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017</p> <p>[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar</p> <p>[3] : Outside the scope of certification for registration of private analytical laboratories No. ๖-250</p> <p>[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548</p> <p>[5] : Information received from customers</p> <p>[6] : < 1.8 = undetected by means of the Laboratory.</p>	

Reported by :

จันทิพ มิตตะกะ

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

15/7/๒๕

Approved by :

สาอวพา นุกะว

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

15/7/๒๕

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo6 Sakdidat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000

E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 4/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	July 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	July 7, 2023
Sampling Source ^[5]	Main Pool	Analyzed Date	July 7-14, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	July 15, 2023
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6607031

Sampling Name ^[5]	Swimming Pool
Sampling Time ^[5]	10.11 AM
Analysis No.	25662442

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Alkalinity ^{[3][4]}	mg/L as CaCO ₃	SM : 2320 B	17.0	80-100
4. Chloride ^{[3][4]}	mg/L	SM : 4500- Cl ⁻ B	1986	≤ 600
5. Cyanuric Acid ^{[3][4]}	mg/L	SM : 4500 - CN-	232	30-60
6. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 10.0
7. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25662442 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar

[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

15, 9, 66

Approved by :

สาอวพา นุกาเวย

Miss. Saowapa Nukaew

Laboratory Manager

15, 7, 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo6 Sakdidat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000

E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	August 9, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	August 9, 2023
Sampling Source ^[5]	Main Pool	Analyzed Date	August 9-16, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	August 17, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6608061
Sampling Name ^[5]	Swimming Pool		
Sampling Time ^[5]	10.23 AM		
Analysis No.	25662911		

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0 °C	-	SM : 4500-H ⁺ B	5.3	7.2-8.4
2.Total Dissolved Solids	mg/L	SM : 2510	1404	-

Physical Appearance	Sample 25662911 : Clear liquid, colorless, no sediment	Container Normal : G 1000 mL
REMARK	<p>[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017</p> <p>[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar</p> <p>[3] : Outside the scope of certification for registration of private analytical laboratories No. ๖-250</p> <p>[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548</p> <p>[5] : Information received from customers</p> <p>[6] : < 1.8 = undetected by means of the Laboratory.</p>	

Reported by :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

๑๗/๘/๖๖

Approved by :

สาอวปะ นุกะว

Miss. Saowapa Nukacw (๖-250-๖-0002)

Laboratory Manager

๑๗/๘/๖๖

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

ห้องปฏิบัติการวิเคราะห์เอกชน

เลขทะเบียน ๖-250

FM-QP-13/01 Rev.01

The results of analysis are valid for the submitted sample only.

Date announced for October 26, 2021

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo6 Sakdidat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000

E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 4/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	August 9, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	August 9, 2023
Sampling Source ^[5]	Main Pool	Analyzed Date	August 9-16, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	August 17, 2023
Sampling By ^[5]	Miss. Yonlatda Thancerat	Report No.	PKT6608061

Sampling Name ^[5]	Swimming Pool
Sampling Time ^[5]	10.23 AM
Analysis No.	25662911

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Alkalinity ^{[3][4]}	mg/L as CaCO ₃	SM : 2320 B	10.0	80-100
4. Chloride ^{[3][4]}	mg/L	SM : 4500- Cl ⁻ B	886	≤ 600
5. Cyanuric Acid ^{[3][4]}	mg/L	SM : 4500 - CN-	198	30-60
6. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 10.0
7. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25662911 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar

[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : < 1.8 = undetected by means of the Laboratory.

Rreported by :

จันทิพย์ มิตตะ

Miss. Jantip Mittaka

Laboratory Analyst

17/8/66

Approved by :

สาอวพา นุกา

Miss. Saowapa Nukaew

Laboratory Manager

17/8/66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo6 Sakdidat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	September 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	September 8, 2023
Sampling Source ^[5]	Main Pool	Analyzed Date	September 8-15, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	September 16, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (T-250-0-0003)	Report No.	PKT6609036

Sampling Name ^[5]	Swimming Pool
Sampling Time ^[5]	10.24 AM
Analysis No.	25663226

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0 °C	-	SM : 4500-H ⁺ B	5.8	7.2-8.4
2.Total Dissolved Solids	mg/L	SM : 2510	1203	-

Physical Appearance

Sample 25663226 : Clear liquid, colorless, no sediment

Container Normal : G 1000 mL

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017
[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar
[3] : Outside the scope of certification for registration of private analytical laboratories No. 3-250
[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[5] : Information received from customers
[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกะ

Approved by :

Miss. Saowapa Nukaew (T-250-0-0002)

Miss. Jantip Mittaka (T-250-0-0004)

Laboratory Analyst

16/9/66

Laboratory Manager

16/9/66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน 3-250

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 4/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	September 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	September 8, 2023
Sampling Source ^[5]	Main Pool	Analyzed Date	September 8-15, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	September 16, 2023
Sampling By ^[5]	Miss. Yonlatda Thancerat	Report No.	PKT6609036
Sampling Name ^[5]	Swimming Pool		
Sampling Time ^[5]	10.24 AM		
Analysis No.	25663226		

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Alkalinity ^{[3][4]}	mg/L as CaCO ₃	SM : 2320 B	11.0	80-100
4. Chloride ^{[3][4]}	mg/L	SM : 4500- Cl ⁻ B	755	≤ 600
5. Cyanuric Acid ^{[3][4]}	mg/L	SM : 4500 - CN-	138	30-60
6. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 10.0
7. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25663226 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar

[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะ

Miss. Jantip Mittaka

Laboratory Analyst

16/9/66

Approved by :

Miss. Saowapa Nukaew

Miss. Saowapa Nukaew

Laboratory Manager

16/9/66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	October 5, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	October 5, 2023
Sampling Source ^[5]	Main Pool	Analyzed Date	October 5-17, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	October 18, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (7-250-ท-0003)	Report No.	PKT6610018

Sampling Name ^[5]	Swimming Pool
Sampling Time ^[5]	10.36 AM
Analysis No.	25663610

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0 °C	-	SM : 4500-H ⁺ B	5.8	7.2-8.4
2.Total Dissolved Solids	mg/L	SM : 2510	727	-

Physical Appearance Sample 25663610 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar

[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกะ

Approved by :

สาอวพา นุกาเว

Miss. Jantip Mittaka (7-250-ท-0004)

Miss. Saowapa Nukaew (7-250-ท-0002)

Laboratory Analyst

18/10/66

Laboratory Manager

18/10/66

ACCREDITED LABORATORY GLP/DIW 2550



BC&E

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน 7-250

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get The Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 4/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	October 5, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	October 5, 2023
Sampling Source ^[5]	Main Pool	Analyzed Date	October 5-17, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	October 18, 2023
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6610018

Sampling Name ^[5]	Swimming Pool
Sampling Time ^[5]	10.36 AM
Analysis No.	25663610

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Alkalinity ^{[3][4]}	mg/L as CaCO ₃	SM : 2320 B	8.0	80-100
4. Chloride ^{[3][4]}	mg/L	SM : 4500- Cl ⁻ B	755	≤ 600
5. Cyanuric Acid ^{[3][4]}	mg/L	SM : 4500 - CN-	125	30-60
6. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 10.0
7. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25663610 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar

[3] : Outside the scope of certification for registration of private analytical laboratories No. 3-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

Miss. Jantip Mittaka

Laboratory Analyst

18 / 10 / 66

Approved by :

Miss. Saowapa Nukacw

Laboratory Manager

18 / 10 / 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	November 9, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	November 10, 2023
Sampling Source ^[5]	Main Pool	Analyzed Date	November 10-17, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	November 18, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6611058

Sampling Name ^[5]	Swimming Pool
Sampling Time ^[5]	10.43 AM
Analysis No.	25664197

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0 °C	-	SM : 4500-H ⁺ B	6.0	7.2-8.4
2.Total Dissolved Solids	mg/L	SM : 2510	1306	-

Physical Appearance Sample 25664197 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017
- [2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar
- [3] : Outside the scope of certification for registration of private analytical laboratories No. ๖-250
- [4] : Outside the scope of certification, TIS 17025-2017, Testing 0548
- [5] : Information received from customers
- [6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิภา มิตตะ

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

18/11/66

Approved by :

สาอวพา นุกาอ

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

18/11/66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

ห้องปฏิบัติการวิเคราะห์เอกชน

เลขทะเบียน ๖-250

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 4/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	November 9, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	November 10, 2023
Sampling Source ^[5]	Main Pool	Analyzed Date	November 10-17, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	November 18, 2023
Sampling By ^[5]	Miss. Yonlatda Thancerat	Report No.	PKT6611058

Sampling Name ^[5]	Swimming Pool
Sampling Time ^[5]	10.43 AM
Analysis No.	25664197

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Alkalinity ^{[3][4]}	mg/L as CaCO ₃	SM : 2320 B	Not Detected	80-100
4. Chloride ^{[3][4]}	mg/L	SM : 4500- Cl ⁻ B	815	≤ 600
5. Cyanuric Acid ^{[3][4]}	mg/L	SM : 4500 - CN-	100	30-60
6. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 10.0
7. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25664197 : Clear liquid, colorlss, no sediment Container Normal : G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar

[3] : Outside the scope of certification for registration of private analytical laboratories No. 2-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพ มิตตะ

Miss. Jantip Mittaka

Laboratory Analyst

18.11.66

Approved by :

สาอวพา นุกาเว

Miss. Saowapa Nukaew

Laboratory Manager

18.11.66

ACCREDITED LABORATORY GLP/DIW 2550



BC&E

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน


FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 3/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	December 8, 2566
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	December 9, 2566
Sampling Source ^[5]	Main Pool	Analyzed Date	December 9-16, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	December 18, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6612048

Sampling Name ^[5]	Swimming Pool
Sampling Time ^[5]	10.54 AM
Analysis No.	25664529

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0 °C	-	SM : 4500-H ⁺ B	7.2	7.2-8.4
2.Total Dissolved Solids	mg/L	SM : 2510	939	-

Physical Appearance Sample 25664529 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar

[3] : Outside the scope of certification for registration of private analytical laboratories No. ๖-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกะ
Miss. Jantip Mittaka (๖-250-๖-0004)

Approved by :

สาอวพา นุกาเว
Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Analyst

18.12.66

Laboratory Manager

18.12.66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 4/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	December 8, 2566
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	December 9, 2566
Sampling Source ^[5]	Main Pool	Analyzed Date	December 9-16, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	December 18, 2023
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6612048

Sampling Name ^[5]	Swimming Pool
Sampling Time ^[5]	10.54 AM
Analysis No.	25664529

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Alkalinity ^{[3][4]}	mg/L as CaCO ₃	SM : 2320 B	72.0	80-100
4. Chloride ^{[3][4]}	mg/L	SM : 4500- Cl ⁻ B	535	≤ 600
5. Cyanuric Acid ^{[3][4]}	mg/L	SM : 4500 - CN-	270	30-60
6. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 10.0
7. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25664529 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Suggestion by Public health committee no.1/2007 type control trading swimming pool or business others in similar

[3] : Outside the scope of certification for registration of private analytical laboratories No. 3-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

18 / 12 / 66

Approved by :

สาอวพา นุกาเวย

Miss. Saowapa Nukaew

Laboratory Manager

18 / 12 / 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 1/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	July 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	July 7, 2023
Sampling Source ^[5]	Cold Water Tank	Analyzed Date	July 7-14, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	July 15, 2023
Sampling By ^[5]	Miss Vonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6607031

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.15 AM
Analysis No.	25662441

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0°C	-	SM : 4500-H ⁺ B	7.6	6.5-8.5
2. Total Dissolved Solids	mg/L	SM : 2510	127	≤ 600

Physical Appearance Sample 25662441 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.


[3] : Outside the scope of certification for registration of private analytical laboratories No. ๖-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :



Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

15 / 7 / 66

Approved by :



Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

15 / 7 / 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000

E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	July 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	July 7, 2023
Sampling Source ^[5]	Cold Water Tank	Analyzed Date	July 7-14, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	July 15, 2023
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6607031

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.15 AM
Analysis No.	25662441

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Total Hardness ^{[3][4]}	mg/L as CaCO ₃	SM : 2340 C	60.0	≤ 300
4. Chloride ^{[3][4]}	mg/L	SM : 4500- Cl ⁻ B	29.6	< 250
5. Iron ^{[3][4]}	mg/L	SM : 3500-Fe B	Not Detected	≤ 0.30
6. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	Not Detected
7. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25662441 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.

[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะ

Miss. Jantip Mittaka

Laboratory Analyst

15/7/66

Approved by :

สาอวพา นุกา

Miss. Saowapa Nukaew

Laboratory Manager

15/7/66

ACCREDITED LABORATORY GLP/DIW 2550



BC&E

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 1/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	August 9, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	August 9, 2023
Sampling Source ^[5]	Cold Water Tank	Analyzed Date	August 9-16, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	August 17, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (7-250-ท-0003)	Report No.	PKT6608061

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.32 AM
Analysis No.	25662910

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0 °C	-	SM : 4500-H ⁺ B	7.5	6.5-8.5
2.Total Dissolved Solids	mg/L	SM : 2510	275	≤ 600

Physical Appearance Sample 25662910 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017
[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.
[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250
[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[5] : Information received from customers
[6] : < 1.8 = undetected by means of the Laboratory.

Rreported by :

จันทิพย์ มิตราก
Miss. Jantip Mittaka (7-250-ท-0004)

Laboratory Analyst

17.8.66

Approved by :

สาอวป นุกาอ
Miss. Saowapa Nukaew (7-250-ท-0002)

Laboratory Manager

17.8.66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน 7-250

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo6 Sakdidat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	August 9, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	August 9, 2023
Sampling Source ^[5]	Cold Water Tank	Analyzed Date	August 9-16, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	August 17, 2023
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6608061

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.32 AM
Analysis No.	25662910

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Total Hardness ^{[3][4]}	mg/L as CaCO ₃	SM : 2340 C	140	≤ 300
4. Chloride ^{[3][4]}	mg/L	SM : 4500- Cl ⁻ B	119	< 250
5. Iron ^{[3][4]}	mg/L	SM : 3500-Fe B	Not Detected	≤ 0.30
6. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	Not Detected
7. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25662910 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.

[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

17.8.23

Approved by :

Miss. Saowapa Nukaew

Miss. Saowapa Nukaew

Laboratory Manager

17.8.23

ACCREDITED LABORATORY GLP/DIW 2550



BC&E

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

The results of analysis are valid for the submitted sample only.

Date announced for October 26, 2021

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 1/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	September 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	September 8, 2023
Sampling Source ^[5]	Cold Water Tank	Analyzed Date	September 8-15, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	September 16, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (1-250-0-0003)	Report No.	PKT6609036

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.30 AM
Analysis No.	25663225

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0°C	-	SM : 4500-H ⁺ B	7.2	6.5-8.5
2. Total Dissolved Solids	mg/L	SM : 2510	355	≤ 600

Physical Appearance

Sample 25663225 : Clear liquid, colorless, no sediment

Container Normal : G 1000 mL

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017
[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.
[3] : Outside the scope of certification for registration of private analytical laboratories No. 1-250
[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[5] : Information received from customers
[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกะ

Approved by :

Miss. Saowapa Nukaew (1-250-0-0002)

Miss. Jantip Mittaka (1-250-0-0004)

Laboratory Analyst

16 / 9 / 66

Laboratory Manager

16 / 9 / 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน 1-250

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยซ์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	September 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	September 8, 2023
Sampling Source ^[5]	Cold Water Tank	Analyzed Date	September 8-15, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	September 16, 2023
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6609036

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.30 AM
Analysis No.	25663225

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Total Hardness ^{[3][4]}	mg/L as CaCO ₃	SM : 2340 C	244	≤ 300
4. Chloride ^{[3][4]}	mg/L	SM : 4500- Cl B	137	< 250
5. Iron ^{[3][4]}	mg/L	SM : 3500-Fe B	Not Detected	≤ 0.30
6. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	Not Detected
7. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25663225 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017
[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.
[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250
[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[5] : Information received from customers
[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

16 / 9 / 66

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

16 / 9 / 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยซ์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 1/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	October 5, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	October 5, 2023
Sampling Source ^[5]	Cold Water Tank	Analyzed Date	October 5-17, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	October 18, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6610018

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.40 AM
Analysis No.	25663609

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0 °C	-	SM : 4500-H ⁺ B	7.6	6.5-8.5
2. Total Dissolved Solids	mg/L	SM : 2510	348	≤ 600

Physical Appearance Sample 25663609 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017
[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.
[3] : Outside the scope of certification for registration of private analytical laboratories No. ๖-250
[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[5] : Information received from customers
[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะ

Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst

18/10/66

Approved by :

สาอวป นุกา

Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager

18/10/66

ACCREDITED LABORATORY GLP/DIW 2550



BC&E

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo6 Sakdidal Rd., Tambol Vichit Amphur Muangphuket Phuket 83000

E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	October 5, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	October 5, 2023
Sampling Source ^[5]	Cold Water Tank	Analyzed Date	October 5-17, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	October 18, 2023
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6610018

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.40 AM
Analysis No.	25663609

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Total Hardness ^{[3][4]}	mg/L as CaCO ₃	SM : 2340 C	252	≤ 300
4. Chloride ^{[3][4]}	mg/L	SM : 4500- Cl ⁻ B	162	< 250
5. Iron ^{[3][4]}	mg/L	SM : 3500-Fe B	Not Detected	≤ 0.30
6. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	Not Detected
7. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25663609 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.

[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

18/10/23

Approved by :

สาอวพา นุกาแะว

Miss. Saowapa Nukaew

Laboratory Manager

18/10/23

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 1/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	November 9, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	November 10, 2023
Sampling Source ^[5]	Cold Water Tank	Analyzed Date	November 10-17, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	November 18, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (๖-250-๖-0003)	Report No.	PKT6611058

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.35 AM
Analysis No.	25664196

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0 °C	-	SM : 4500-H ⁺ B	7.3	6.5-8.5
2.Total Dissolved Solids	mg/L	SM : 2510	338	≤ 600

Physical Appearance	Sample 25664196 : Clear liquid, colorless, no sediment	Container Normal : G 1000 mL
REMARK	<p>[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017</p> <p>[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.</p> <p>[3] : Outside the scope of certification for registration of private analytical laboratories No. ๖-250</p> <p>[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548</p> <p>[5] : Information received from customers</p> <p>[6] : < 1.8 = undetected by means of the Laboratory.</p>	

Reported by :

จันทิพย์ มิตตะ
Miss. Jantip Mittaka (๖-250-๖-0004)

Laboratory Analyst
18/11/66

Approved by :

สาอวพา นุกาเอว
Miss. Saowapa Nukaew (๖-250-๖-0002)

Laboratory Manager
18/11/66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน ๖-250

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	November 9, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	November 10, 2023
Sampling Source ^[5]	Cold Water Tank	Analyzed Date	November 10-17, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	November 18, 2023
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6611058

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.35 AM
Analysis No.	25664196

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Total Hardness ^{[3][4]}	mg/L as CaCO ₃	SM : 2340 C	252	≤ 300
4. Chloride ^{[3][4]}	mg/L	SM : 4500- Cl ⁻ B	152	< 250
5. Iron ^{[3][4]}	mg/L	SM : 3500-Fe B	Not Detected	≤ 0.30
6. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	Not Detected
7. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25664196 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.

[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

18 / 11 / 66

Approved by :

สาอวพา นุกาแฉว

Miss. Saowapa Nukaew

Laboratory Manager

18 / 11 / 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 1/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	December 8, 2566
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	December 9, 2566
Sampling Source ^[5]	Cold Water Tank	Analyzed Date	December 9-16, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	December 18, 2023
Sampling By ^[5]	Miss Yonlatda Thaneerat (7-250-0-0003)	Report No.	PKT6612048

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.30 AM
Analysis No.	25664528

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. pH at 25.0 °C	-	SM : 4500-H ⁺ B	7.5	6.5-8.5
2. Total Dissolved Solids	mg/L	SM : 2510	408	≤ 600

Physical Appearance Sample 25664528 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017
[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.
[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250
[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[5] : Information received from customers
[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพพร มิตตะกะ

Miss. Jantip Mittaka (7-250-0-0004)

Laboratory Analyst

18/12/66

Approved by :

สาอวพา นุกาเอว

Miss. Saowapa Nukaew (7-250-0-0002)

Laboratory Manager

18/12/66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน
เลขทะเบียน 7-250

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222



WATER ANALYSIS REPORT

Page 2/4

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	December 8, 2566
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	December 9, 2566
Sampling Source ^[5]	Cold Water Tank	Analyzed Date	December 9-16, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	December 18, 2023
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6612048

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.38 AM
Analysis No.	25664528

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
3. Total Hardness ^{[3][4]}	mg/L as CaCO ₃	SM : 2340 C	230	≤ 300
4. Chloride ^{[3][4]}	mg/L	SM : 4500- Cl ⁻ B	154	< 250
5. Iron ^{[3][4]}	mg/L	SM : 3500-Fe B	Not Detected	≤ 0.30
6. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	Not Detected
7. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25664528 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017
[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.
[3] : Outside the scope of certification for registration of private analytical laboratories No. 2-250
[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[5] : Information received from customers
[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

Miss. Jantip Mittaka

Laboratory Analyst

18, 12, 66

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

18, 12, 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000

E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 2/2

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	July 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	July 7, 2023
Sampling Source ^[5]	Guest room No.952	Analyzed Date	July 7-14, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	July 15, 2023
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6607031

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.16 AM
Analysis No.	25662440

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	Not Detected
2. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25662440 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.

[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพร มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

15/7/23

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

15/7/23

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo6 Sakdidat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 2/2

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	August 9, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	August 9, 2023
Sampling Source ^[5]	Guest room No.240	Analyzed Date	August 9-16, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	August 17, 2023
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6608061
Sampling Name ^[5]	Tap Water		
Sampling Time ^[5]	10.30 AM		
Analysis No.	25662909		

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	Not Detected
2. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25662909 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.

[3] : Outside the scope of certification for registration of private analytical laboratories No. 2-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพร มิตตะ

Miss. Jantip Mittaka

Laboratory Analyst

17/8/66

Approved by :

สาอวพา นุกาอว

Miss. Saowapa Nukaew

Laboratory Manager

17/8/66

ACCREDITED LABORATORY GLP/DIW 2550



BC&E

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts

**BEST CHOICE****CHEMICALS & ENGINEERING CO., LTD.****BC & E**

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo6 Sakdidat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000

E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 2/2

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	September 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	September 8, 2023
Sampling Source ^[5]	Guest room No.199	Analyzed Date	September 8-15, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	September 16, 2023
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6609036

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.20 AM
Analysis No.	25663224

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	Not Detected
2. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25663224 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.

[3] : Outside the scope of certification for registration of private analytical laboratories No. 3-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

16.9.23

Approved by :

Saowapa Nukaew

Miss. Saowapa Nukaew

Laboratory Manager

16.9.23

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

BC & E

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000

E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 2/2

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	October 5, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	October 5, 2023
Sampling Source ^[5]	Guest room No.138	Analyzed Date	October 5-17, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	October 18, 2023
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6610018

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.38 AM
Analysis No.	25663608

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	Not Detected
2. E.coli ^{[3][4]}	MPN/100 mL	SM: 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25663608 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

- [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017
 [2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.
 [3] : Outside the scope of certification for registration of private analytical laboratories No. 3-250
 [4] : Outside the scope of certification, TIS 17025-2017, Testing 0548
 [5] : Information received from customers
 [6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

Miss. Jantip Mittaka

Laboratory Analyst

18 / 10 / 66

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

18 / 10 / 66

ACCREDITED LABORATORY GLP/DIW 2550

**BC & E**

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
 ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Amphur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 2/2

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	November 9, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	November 10, 2023
Sampling Source ^[5]	Guest room No.944	Analyzed Date	November 10-17, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	November 18, 2023
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6611058

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	10.45 AM
Analysis No.	25664195

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	Not Detected
2. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25664195 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.

[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตรตะก

Miss. Jantip Mittaka

Laboratory Analyst

18 / 11 / 66

Approved by :

สมิทธิ นุกะว

Miss. Saowapa Nukacw

Laboratory Manager

18 / 11 / 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน


FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumphur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 2/2

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	December 8, 2566
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	December 9, 2566
Sampling Source ^[5]	Guest room No.146	Analyzed Date	December 9-16, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	December 18, 2023
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6612048

Sampling Name ^[5]	Tap Water
Sampling Time ^[5]	11.00 AM
Analysis No.	25664527

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	Not Detected
2. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25664527 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Water quality standards of the Waterworks. As recommended by the World Health Organization (WHO) in 2011.

[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตรตะม

Miss. Jantip Mittaka

Laboratory Analyst

18/12/26

Approved by :

สาอวพา นุกาอว

Miss. Saowapa Nukaew

Laboratory Manager

18/12/26

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 1/2

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	July 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	July 7, 2023
Sampling Source ^[5]	Ice Machine - Ice cube	Analyzed Date	July 7-14, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	July 15, 2023
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6607031

Sampling Name ^[5]	Ice Melt
Sampling Time ^[5]	10.09 AM
Analysis No.	25662439

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 2.2
2. E.coli ^{[3][4]}	MPN/100 mL	SM: 9221 F	Not Detected	Not Detected

Physical Appearance	Sample 25662439 : Clear liquid, colorless, no sediment	Container Normal : G 1000 mL
REMARK	<p>[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017</p> <p>[2] : Ministry of Public Health No.78 (1984) and No.137 (1991) .Ice Melt</p> <p>[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250</p> <p>[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548</p> <p>[5] : Information received from customers</p> <p>[6] : < 1.8 = undetected by means of the Laboratory.</p>	

Reported by :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

15/7/22

Approved by :

Miss. Saowapa Nukaew

Miss. Saowapa Nukaew

Laboratory Manager

15/7/22

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000

E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 1/2

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	August 9, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	August 9, 2023
Sampling Source ^[5]	Ice Machine - Building J	Analyzed Date	August 9-16, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	August 17, 2023
Sampling By ^[5]	Miss. Vonlatda Thaneerat	Report No.	PKT6608061

Sampling Name ^[5]	Ice Melt
Sampling Time ^[5]	10.20 AM
Analysis No.	25662908

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 2.2
2. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance	Sample 25662908 : Clear liquid, colorless, no sediment	Container Normal : G 1000 mL
REMARK	<p>[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017</p> <p>[2] : Ministry of Public Health No.78 (1984) and No.137 (1991) .Ice Melt</p> <p>[3] : Outside the scope of certification for registration of private analytical laboratories No. 2-250</p> <p>[4] : Outside the scope of certification, TIS 17025-2017,Testing 0548</p> <p>[5] : Information received from customers</p> <p>[6] : < 1.8 = undetected by means of the Laboratory.</p>	

Reported by :

จันทิพย์ มิตตะ

Miss. Jantip Mittaka

Laboratory Analyst

17/8/66

Approved by :

สาอวพา นุกา

Miss. Saowapa Nukaew

Laboratory Manager

17/8/66

ACCREDITED LABORATORY GLP/DIW 2550



BC&E

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

The results of analysis are valid for the submitted sample only.

Date announced for October 26, 2021

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 1/2

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	September 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	September 8, 2023
Sampling Source ^[5]	Ice Machine - Ice cube	Analyzed Date	September 8-15, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	September 16, 2023
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6609036

Sampling Name ^[5]	Ice Melt
Sampling Time ^[5]	10.15 AM
Analysis No.	25663223

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 2.2
2. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance

Sample 25663223 : Clear liquid, colorless, no sediment

Container Normal : G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Ministry of Public Health No.78 (1984) and No.137 (1991) .Ice Melt

[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250

[4] : Outside the scope of certification, TIS 17025-2017,Testing 0548

[5] : Information received from customers

[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

16 / 9 / 66

Approved by :

สาอวพา นุกาเว

Miss. Saowapa Nukaew

Laboratory Manager

16 / 9 / 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000

E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 1/2

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	October 5, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	October 5, 2023
Sampling Source ^[5]	Ice Machine - Ice cube	Analyzed Date	October 5-17, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	October 18, 2023
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6610018

Sampling Name ^[5]	Ice Melt
Sampling Time ^[5]	10.34 AM
Analysis No.	25663607

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 2.2
2. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25663607 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Ministry of Public Health No.78 (1984) and No.137 (1991) .Ice Melt

[3] : Outside the scope of certification for registration of private analytical laboratories No. 3-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

18/10/66

Approved by :

สาอวพา นุกาเว

Miss. Saowapa Nukaew

Laboratory Manager

18/10/66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 1/2

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	November 9, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	November 10, 2023
Sampling Source ^[5]	Ice Machine - Ice cube	Analyzed Date	November 10-17, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	November 18, 2023
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6611058

Sampling Name ^[5]	Ice Melt
Sampling Time ^[5]	10.00 AM
Analysis No.	25664194

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 2.2
2. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25664194 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK

[1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017

[2] : Ministry of Public Health No.78 (1984) and No.137 (1991) .Ice Melt

[3] : Outside the scope of certification for registration of private analytical laboratories No. 2-250

[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548

[5] : Information received from customers

[6] : < 1.8 = undetected by means of the Laboratory.

Rreported by :

จันทิพย์ มิตตะ

Miss. Jantip Mittaka

Laboratory Analyst

18 / 11 / 66

Approved by :

สาอวพา นุกา

Miss. Saowapa Nukaew

Laboratory Manager

18 / 11 / 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdidat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 1/2

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date ^[5]	December 8, 2566
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	December 9, 2566
Sampling Source ^[5]	Ice Machine - Ice cube	Analyzed Date	December 9-16, 2023
Sampling Method ^[5]	Grab Sampling	Report Date	December 18, 2023
Sampling By ^[5]	Miss. Yonlatda Thaneerat	Report No.	PKT6612048

Sampling Name ^[5]	Ice Melt
Sampling Time ^[5]	10.53 AM
Analysis No.	25664526

Parameter	Unit	Method of Analysis ^[1]	Result	Standard ^[2]
1. Total Coliform Bacteria ^{[3][4]}	MPN/100 mL	SM: 9221 B	< 1.8 ^[6]	≤ 2.2
2. E.coli ^{[3][4]}	MPN/100 mL	SM : 9221 F	Not Detected	Not Detected

Physical Appearance Sample 25664526 : Clear liquid, colorless, no sediment Container Normal : G 1000 mL

REMARK [1] : Standard Methods for The Examination of Water and Wastewater, APHA, AWWA, WEF., 23rd Edition 2017
[2] : Ministry of Public Health No.78 (1984) and No.137 (1991) .Ice Melt
[3] : Outside the scope of certification for registration of private analytical laboratories No. 7-250
[4] : Outside the scope of certification, TIS 17025-2017, Testing 0548
[5] : Information received from customers
[6] : < 1.8 = undetected by means of the Laboratory.

Reported by :

จันทิพย์ มิตตะคิก

Miss. Jantip Mittaka

Laboratory Analyst

18/12/66

Approved by :

Miss. Saowapa Nukaew

Laboratory Manager

18/12/66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

FM-QP-13/01 Rev.01

Date announced for October 26, 2021

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000

E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 1/5

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date	September 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	September 7, 2023
Sampling Source	Main Pool	Analyzed Date	September 7, 2023
Sampling Method	Grab Sample	Report Date	September 20, 2023
Sampling By	Miss. Yonlatda Thancrat	Report No.	PKT66/09/L004

Sampling Name	Swimming Pool
Sampling Time	10.24 AM
Analysis No.	L09008

Parameter	Unit	Method of Analysis	Result	Standard
1. <i>Legionella spp.</i>	CFU/L	Culture (CDC, 2005)	Not Detected	Not Detected

Physical Appearance Sample : Liquid Colorless, Clear Container : Normal G 1.0 L

REMARK : European Working Group for Legionella Infections (EWGLI)
: Regulation control of legionella in cooling tower in Thailand, Department of Health, Ministry of Public Health.
Announced on January 8, 2002.

Reported By : จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

20/9/61

Aproved By :

Miss. Saowapa Nukaew

Laboratory Supervisor

20/9/61



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

ห้องปฏิบัติการวิเคราะห์เอกชน

ACCREDITED LABORATORY GLP/DIW 2550

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo 6, Sakdidek RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 1/5

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date	December 8, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	December 9, 2023
Sampling Source	Main Pool	Analyzed Date	December 9, 2023
Sampling Method	Grab Sample	Report Date	December 26, 2023
Sampling By	Miss. Yonlatda Thancerat	Report No.	PKT66/12/L004

Sampling Name	Swimming Pool
Sampling Time	10.54 AM
Analysis No.	L12012

Parameter	Unit	Method of Analysis	Result	Standard
1. <i>Legionella</i> spp.	CFU/L	Culture (CDC, 2005)	Not Detected	Not Detected

Physical Appearance Sample : Liquid Colorless, Clear Container : Normal G 1.0 L

REMARK : European Working Group for Legionella Infections (EWGLI)
: Regulation control of legionella in cooling tower in Thailand, Department of Health, Ministry of Public Health.
Announced on January 8, 2002.

Reported By :
Miss. Jantip Mittaka

Laboratory Analyst

26 / 12 / 66

Approved By :

Miss. Saowapa Nukacw

Laboratory Supervisor

26 / 12 / 66



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000

E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 2/5

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date	September 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	September 7, 2023
Sampling Source	Guest Room No. 199	Analyzed Date	September 7, 2023
Sampling Method	Grab Sample	Report Date	September 20, 2023
Sampling By	Miss. Yonlatda Thancrat	Report No.	PKT66/09/L004

Sampling Name	Tap Water
Sampling Time	10.20 AM
Analysis No.	L09009

Parameter	Unit	Method of Analysis	Result	Standard
1. <i>Legionella spp.</i>	CFU/L	Culture (CDC, 2005)	Not Detected	Not Detected

Physical Appearance Sample : Liquid Colorless, Clear Container : Normal G 1.0 L

REMARK : European Working Group for Legionella Infections (EWGLI)
: Regulation control of legionella in cooling tower in Thailand, Department of Health, Ministry of Public Health.
Announced on January 8, 2002.

Reported By :

จันทิพย์ มิตตะ

Miss. Jantip Mittaka

Laboratory Analyst

๑๐/๑/๖๖

Approved By :

สาอวพา นุกะว

Miss. Saowapa Nukacw

Laboratory Supervisor

๑๐/๑/๖๖



BC & E

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

ห้องปฏิบัติการวิเคราะห์เอกชน

ACCREDITED LABORATORY GLP/DIW 2550

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 2/5

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date	December 8, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	December 9, 2023
Sampling Source	Guest Room No. 146	Analyzed Date	December 9, 2023
Sampling Method	Grab Sample	Report Date	December 26, 2023
Sampling By	Miss. Yonlatda Thancerat	Report No.	PKT66/12/L004

Sampling Name	Tap Water
Sampling Time	11.00 AM
Analysis No.	L12013

Parameter	Unit	Method of Analysis	Result	Standard
1. <i>Legionella</i> spp.	CFU/L	Culture (CDC, 2005)	Not Detected	Not Detected

Physical Appearance Sample : Liquid Colorless, Clear Container : Normal G 1.0 L

REMARK : European Working Group for Legionella Infections (EWGLI)
: Regulation control of legionella in cooling tower in Thailand, Department of Health, Ministry of Public Health.
Announced on January 8, 2002.

Reported By : จันทิพร มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

26 / 12 / 66

Aproved By :

Miss. Saowapa Nukaew

Laboratory Supervisor

26 / 12 / 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000

E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 3/5

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date	September 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	September 7, 2023
Sampling Source	Main Kitchen	Analyzed Date	September 7, 2023
Sampling Method	Grab Sample	Report Date	September 20, 2023
Sampling By	Miss. Yonlatda Thancerat	Report No.	PKT66/09/L004

Sampling Name	Tap Water
Sampling Time	10.18 AM
Analysis No.	L09010

Parameter	Unit	Method of Analysis	Result	Standard
1. <i>Legionella</i> spp.	CFU/L	Culture (CDC, 2005)	Not Detected	Not Detected

Physical Appearance Sample : Liquid Colorless, Clear Container : Normal G 1.0 L

REMARK : European Working Group for Legionella Infections (EWGLI)
: Regulation control of legionella in cooling tower in Thailand, Department of Health, Ministry of Public Health.
Announced on January 8, 2002.

Reported By :

จันทิพย์ มิตรากา

Miss. Jantip Mittaka

Laboratory Analyst

20 / 9 / 66

Approved By :

สาอวพา นุกาอว

Miss. Saowapa Nukaew

Laboratory Supervisor

20 / 9 / 66



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

ACCREDITED LABORATORY GLP/DIW 2550

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยซ์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000

E-mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 3/5

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date	December 8, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	December 9, 2023
Sampling Source	Main Kitchen	Analyzed Date	December 9, 2023
Sampling Method	Grab Sample	Report Date	December 26, 2023
Sampling By	Miss. Yonlatda Thanecrat	Report No.	PKT66/12/L004

Sampling Name	Tap Water
Sampling Time	10.52 AM
Analysis No.	L12014

Parameter	Unit	Method of Analysis	Result	Standard
1. <i>Legionella spp.</i>	CFU/L	Culture (CDC, 2005)	Not Detected	Not Detected

Physical Appearance Sample : Liquid Colorless, Clear Container : Normal G 1.0 L

REMARK : European Working Group for Legionella Infections (EWGLI)
: Regulation control of legionella in cooling tower in Thailand, Department of Health, Ministry of Public Health.
Announced on January 8, 2002.

Reported By : จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

26 / 12 / 66

Approved By :

Miss. Saowapa Nukacw

Laboratory Supervisor

26 / 12 / 66



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยซ์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000
E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 4/5

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date	September 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	September 7, 2023
Sampling Source	Raw Water Tank	Analyzed Date	September 7, 2023
Sampling Method	Grab Sample	Report Date	September 20, 2023
Sampling By	Miss. Yonlatda Thancerat	Report No.	PKT66/09/L004

Sampling Name	Raw Water
Sampling Time	10.28 AM
Analysis No.	L09011

Parameter	Unit	Method of Analysis	Result	Standard
1. <i>Legionella spp.</i>	CFU/L	Culture (CDC, 2005)	Not Detected	Not Detected

Physical Appearance Sample : Clear yellow, yellow Liquid Container : Normal G 1.0 L

REMARK : European Working Group for Legionella Infections (EWGLI)
: Regulation control of legionella in cooling tower in Thailand, Department of Health, Ministry of Public Health.
Announced on January 8, 2002.

Reported By : จันทิพร มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

20 / 9 / 66

Approved By :

Miss. Saowapa Nukaew

Laboratory Supervisor

20 / 9 / 66



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

ACCREDITED LABORATORY GLP/DIW 2550

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 4/5

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date	December 8, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	December 9, 2023
Sampling Source	Raw Water Tank	Analyzed Date	December 9, 2023
Sampling Method	Grab Sample	Report Date	December 26, 2023
Sampling By	Miss. Yonlatda Thancrat	Report No.	PKT66/12/L004

Sampling Name	Raw Water
Sampling Time	10.41 AM
Analysis No.	L12015

Parameter	Unit	Method of Analysis	Result	Standard
1. <i>Legionella</i> spp.	CFU/L	Culture (CDC, 2005)	Not Detected	Not Detected

Physical Appearance	Sample : Clear yellow, yellow Liquid	Container : Normal G 1.0 L
REMARK	: European Working Group for Legionella Infections (EWGLI) : Regulation control of legionella in cooling tower in Thailand, Department of Health, Ministry of Public Health. Announced on January 8, 2002.	

Reported By : จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

26 / 12 / 66

Aproved By :

สาอวพา นุกะว

Miss. Saowapa Nukacw

Laboratory Supervisor

26 / 12 / 66

ACCREDITED LABORATORY GLP/DIW 2550



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด

72/12 Moo6 Sakdilat Rd., Tambol Vichit Amphur Muangphuket Phuket 83000

E-Mail : bestchoice@outlook.co.th www.bestchoice.co.th

Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 5/5

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date	September 7, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	September 7, 2023
Sampling Source	Cold Water Tank	Analyzed Date	September 7, 2023
Sampling Method	Grab Sample	Report Date	September 20, 2023
Sampling By	Miss. Yonlatda Thaneerat	Report No.	PKT66/09/L004

Sampling Name	Tap Water
Sampling Time	10.30 AM
Analysis No.	L09012

Parameter	Unit	Method of Analysis	Result	Standard
1. Legionella spp.	CFU/L	Culture (CDC, 2005)	Not Detected	Not Detected

Physical Appearance Sample : Liquid Colorless, Clear Container : Normal G 1.0 L

REMARK : European Working Group for Legionella Infections (EWGLI)
: Regulation control of legionella in cooling tower in Thailand, Department of Health, Ministry of Public Health.
Announced on January 8, 2002.

Reported By : จันทิพร มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

20/9/66

Aproved By :

Miss. Saowapa Nukaew

Laboratory Supervisor

20/9/66



บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

ACCREDITED LABORATORY GLP/DIW 2550

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts



BEST CHOICE

CHEMICALS & ENGINEERING CO., LTD.

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
72/12 Moo 6, Sakdilat RD., Tambol Vichit, Aumthur Muangphuket, Phuket 83000
E-mail : bestchoice@outlook.co.th www.bestchoice.co.th
Tel. (076) 391 320-2 Fax. (076) 391 222

WATER ANALYSIS REPORT

Page 5/5

Customer/Code	Samui Beach Club Owner Limited/6S-071/1	Sampling Date	December 8, 2023
Customer Address	239-239/1 Moo 3 T.Maikhao A.Thalang Phuket 83110	Receiving Date	December 9, 2023
Sampling Source	Cold Water Tank	Analyzed Date	December 9, 2023
Sampling Method	Grab Sample	Report Date	December 26, 2023
Sampling By	Miss. Yonlatda Thaneerat	Report No.	PKT66/12/L004

Sampling Name	Tap Water
Sampling Time	10.38 AM
Analysis No.	L12016

Parameter	Unit	Method of Analysis	Result	Standard
1. <i>Legionella spp.</i>	CFU/L	Culture (CDC, 2005)	Not Detected	Not Detected

Physical Appearance Sample : Liquid Colorless, Clear Container : Normal G 1.0 L

REMARK : European Working Group for Legionella Infections (EWGLI)
: Regulation control of legionella in cooling tower in Thailand, Department of Health, Ministry of Public Health.
Announced on January 8, 2002.

Reported By : จันทิพย์ มิตตะกะ

Miss. Jantip Mittaka

Laboratory Analyst

26 / 12 / 66

Aproved By :

Miss. Saowapa Nukaew

Laboratory Supervisor

26 / 12 / 66



ACCREDITED LABORATORY GLP/DIW 2550

บริษัท เบสท์ ชอยส์ เคมีคัลส์ แอนด์ เอ็นจิเนียริ่ง จำกัด
ห้องปฏิบัติการวิเคราะห์เอกชน

The results of analysis are valid for the submitted sample only.

The report shall not be reproduced, except in Full, without the written approval.

Get the Experience of Experts