

LOG SHEET OF SWIMMING POOL / POND									
BUILDING : The Strand thonglor (Adult swimming pool)									
Date		Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
				Chlorine (ppm)	pH				
1	Morning	6:00	1.5	7.8	16	[Redacted]	[Redacted]	[Redacted]	[Redacted]
	Afternoon	17:00	1.5	7.4	16				
2	Morning	06:00	1.5	7.4	16				
	Afternoon	17:00	1.0	7.8	16				
3	Morning	06:00	1.5	7.8	16				
	Afternoon	17:00	0.3	7.8	16				
4	Morning	06:00	3.0	7.4	16				
	Afternoon	17:00	0.3	7.8	16				
5	Morning	06:00	1.5	7.8	16				
	Afternoon	17:00	0.5	7.4	16				
6	Morning	06:00	3.0	7.8	16				
	Afternoon	17:00	0.5	7.8	16				
7	Morning	06:00	3.0	7.8	16				
	Afternoon	17:00	0.3	7.8	16				
Comment : _____ _____ _____									

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01		Rev. Date: 31/01/2015		Month: ธันวาคม		Year: 2023			
BUILDING: The Strand thonglor		(Kid swimming pool) สระเด็ก		Recorded By (Technician)		Verified By (Sr. Technician)		Remark	
Date	Shift / Time	Water Quality		Filter Pressure (psi)					
		Chlorine (ppm)	pH						
1	Morning	6.00	3.0	7.8	16				PPM 2500
	Afternoon	17.00	0.3	7.4	16				
2	Morning	06.00	1.5	7.4	16				PPM = 2500
	Afternoon	17.00	0.3	7.8	16				
3	Morning	06.00	1.5	7.4	16				PPM = 2470
	Afternoon	17.00	1.5	7.8	16				
4	Morning	06.00	3.0	7.8	16				PPM = 3000
	Afternoon	17.00	1.5	7.8	16				
5	Morning	06.00	3.0	7.8	16				PPM 3040
	Afternoon	17.00	3.0	7.8	16				
6	Morning	06.00	3.0	7.8	16				PPM 3040
	Afternoon	17.00	3.0	7.8	16				
7	Morning	06.00	3.0	7.8	16				
	Afternoon	17.00	1.5	7.8	16				
Comment: _____ _____ _____									

2, 1, 67

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND																											
Ref No: JLL-OP-SN-004/01																											
Rev. Date : 31/01/2015																											
BUILDING : The Strand thonglor (Adult swimming pool)		Month : 01/2023 Year : 2023																									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark																				
		Chlorine (ppm)	pH																								
8	Morning	06.00	3.0	7.8	[Redacted]		PPM 3080																				
	Afternoon	17.00	0.3	7.8																							
9	Morning	06.00	0.3	7.9				[Redacted]		PPM 3080																	
	Afternoon	17.00	0.3	7.8																							
10	Morning	06.00	1.5	7.4							[Redacted]		PPM 3060 / 3080 Back Wash PPM 3650														
	Afternoon	17.00	0.3	7.8																							
11	Morning	06.00	0.3	7.4										[Redacted]		PPM 3650 3.630 PPM 3.630 PPM 3.630 PPM 3.630 PPM											
	Afternoon	17.00	0.3	7.8																							
12	Morning	06.00	3.0	7.8													[Redacted]		3.630 PPM 3.630 PPM 3.630 PPM 3.630 PPM								
	Afternoon	17.00	0.3	7.8																							
13	Morning	06.00	0.3	7.8																[Redacted]		3.630 PPM 3.630 PPM 3.630 PPM 3.630 PPM					
	Afternoon	17.00	0.3	7.8																							
14	Morning	06.00	3.0	7.8																			[Redacted]		3.630 PPM 3.630 PPM 3.630 PPM 3.630 PPM		
	Afternoon	17.00	1.5	7.8																							
Comment :					BSE : 2, 7, 1, 67																						

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor				(Kid swimming pool) สระเด็ก		Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015	
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Month : ธันวาคม Year : 2023	
	Morning	Afternoon	Chlorine (ppm)	pH				Remark	
8	06.00	17.00	3.0	7.8	16				
9	06.00	17.00	3.0	7.8	16			PPM 3040	
10	06.00	17.00	1.5	7.8	16			PPM 3030	
11	06.00	17.00	1.5	7.8	16			PPM 3030	
12	06.00	17.00	3.0	7.8	16			back Wash PPM 3610	
13	06.00	17.00	1.5	7.8	16			PPM 3580	
14	06.00	17.00	3.0	7.8	16			3610 PPM	
								3560 PPM	
Comment : <div style="text-align: right; font-size: 2em;">2, 1, 67</div>									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
BUILDING: The Strand thonglor (Adult swimming pool)		Month: ธันวาคม		Year: 2023					
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
16	Morning	06.00	1.5	7.8			PPM 3620 / (Chlorine)		
	Afternoon	17.00	0.3	7.8					
16	Morning	06.00	1.0	7.8			PPM 3630		
	Afternoon	17.00	0.3	7.8					
17	Morning	06.00	1.5	7.8			PPM 3630		
	Afternoon	17.00	0.3	7.8					
18	Morning	06.00	1.5	7.8			PPM 3630 / Back Wash		
	Afternoon	17.00	0.3	7.8					
19	Morning	06.00	1.0	7.8			PPM 3640		
	Afternoon	17.00	0.3	7.8					
20	Morning	06.00	1.5	7.8			PPM 3630		
	Afternoon	17.00	0.3	7.8					
21	Morning	06.00	2.0	7.8			PPM 3630		
	Afternoon	17.00	0.3	7.8					
Comment:								21, 62	

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
BUILDING: The Strand thonglor (Kid swimming pool) สระเด็ก		Month: ธันวาคม		Year: 2023					
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
15	Morning	06.00	3.0	7.8	[Redacted]	[Redacted]	PPM 3570		
	Afternoon	17.00	1.5	7.8					
16	Morning	06.00	1.5	7.8	[Redacted]	[Redacted]	PPM 3540		
	Afternoon	17.00	1.5	7.8					
17	Morning	06.00	1.5	7.8	[Redacted]	[Redacted]	PPM 3530		
	Afternoon	17.00	1.5	7.8					
18	Morning	06.00	1.5	7.8	[Redacted]	[Redacted]	Back Wash / 3550		
	Afternoon	17.00	1.5	7.8					
19	Morning	06.00	1.5	7.8	[Redacted]	[Redacted]	PPM 3560		
	Afternoon	17.00	1.5	7.8					
20	Morning	06.00	1.5	7.8	[Redacted]	[Redacted]	PPM 3560		
	Afternoon	17.00	1.5	7.8					
21	Morning	06.00	1.5	7.8	[Redacted]	[Redacted]	PPM 3540		
	Afternoon	17.00	1.5	7.8					
Comment: 2, 7 67									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND														
Ref No: JLL-OP-SN-004/01														
Rev. Date : 31/01/2015														
Month : 01/2023		Year : 2023												
BUILDING :		The Strand thonglor (Adult swimming pool)												
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark							
		Chlorine (ppm)	pH											
22	Morning	06.00	1.6	7.8	[Redacted]	[Redacted]	ppm 3570 (Inkjet)							
	Afternoon	17.00	0.3	7.8										
23	Morning	06.00	3.0	7.8						ppm 3540				
	Afternoon	17.00	0.3	7.8										
24	Morning	06.00	0.3	7.8						ppm 3540 (Inkjet)				
	Afternoon	17.00	0.3	7.8										
25	Morning	06.00	1.5	7.8						ppm 3530				
	Afternoon	17.00	1.0	7.8										
26	Morning	06.00	2.0	7.8						ppm 3450				
	Afternoon	17.00	1.6	7.8										
27	Morning	06.00	3.0	7.8						ppm 3450				
	Afternoon	17.00	0.3	7.8										
28	Morning	06.00	3.0	7.8						ppm 3440				
	Afternoon	17.00	0.3	7.8										
Comment : _____ _____ _____														

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01		Rev. Date: 31/01/2015		Month: ธันวาคม		Year: 2023			
BUILDING: The Strand thonglor		(Kid swimming pool) สระว่ายน้ำ		Recorded By (Technician)		Verified By (Sr. Technician)		Remark	
Date	Shift / Time	Water Quality		Filter Pressure (psi)	pH	Chlorine (ppm)	pH	pH	pH
		Chlorine (ppm)	pH						
22	Morning	06.00	3.0	16	7.8	16	PPM 3560 (ไม่ผ่าน)		
	Afternoon	17.00	3.0	16	7.8	16			
23	Morning	06.00	3.0	16	7.8	16	PPM 3510		
	Afternoon	17.00	1.5	16	7.8	16			
24	Morning	06.00	1.5	16	7.8	16	PPM 3550		
	Afternoon	17.00	3.0	16	7.8	16			
25	Morning	06.00	3.0	16	7.8	16	PPM 3550		
	Afternoon	17.00	1.5	16	7.8	16			
26	Morning	06.00	3.0	16	7.8	16	PPM 3470		
	Afternoon	17.00	3.0	16	7.8	16			
27	Morning	06.00	1.5	16	7.8	16	PPM 3420		
	Afternoon	17.00	3.0	16	7.8	16			
28	Morning	06.00	3.0	16	7.8	16			
	Afternoon	17.00	3.0	16	7.8	16			
Comment: 2, 1, 167									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01		Rev. Date : 31/01/2015							
BUILDING :		The Strand thonglor				(Adult swimming pool)			
Date		Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
				Chlorine (ppm)	pH				
29	Morning	6.00	3.0	7.8	16				
	Afternoon	16.30	0.3	7.8	16				
30	Morning	6.00	3.0	7.8	16				
	Afternoon	16.30	0.5	7.8	16				
31	Morning	6.00	3.0	7.8	16				
	Afternoon	17.00	0.3	7.8	16				
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
Comment : _____ _____ _____									

2, 1 1 67

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: ธันวาคม		Year: 2023							
BUILDING:	The Strand thonglor		(Kid swimming pool) สระว่ายน้ำเด็ก		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
	Date	Shift / Time	Chlorine (ppm)	pH					
29	Morning	6.00	3.0	7.8	16				
	Afternoon	16.30	3.0	7.8					
30	Morning	6.00	3.0	7.8	16				
	Afternoon	16.30	3.0	7.8					
31	Morning	6.00	3.0	7.8	16				
	Afternoon	17.20	3.0	7.8					
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
Comment: _____ _____ _____									

BSE

2, 1, 62

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		(Kid swimming pool)		Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015 Month : November Year : 2023			
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
1	Morning	06.00	1.5	7.8	16	[Redacted]	[Redacted]	2,750 PPM	
	Afternoon	17.00	8.0	7.6	16				
2	Morning	06.00	3.0	7.8	16			2,650 PPM	
	Afternoon	17.00	2.0	7.8	16				
3	Morning	06.00	3.0	7.9	16			2,380 PPM	
	Afternoon	17.00	1.5	7.8	16				
4	Morning	06.00	3.0	8.2	16			2,690 PPM	
	Afternoon	17.00	6.0	7.8	16				
5	Morning	06.00	1.5	7.8	16			2,610 PPM	
	Afternoon	17.00	1.0	7.4	16				
6	Morning	06.00	1.5	7.8	16			1,940 PPM	
	Afternoon	17.00	3.0	7.4	16				
7	Morning	06.00	3.0	7.8	16			2,780 PPM	
	Afternoon	18.00	1.5	7.8	16				
Comment : _____ _____ _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND																										
Ref No: JLL-OP-SN-004/01																										
Rev. Date : 31/01/2015																										
Month : November		Year : 2023																								
BUILDING : The Strand thonglor (Adult swimming pool)																										
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark																		
			Chlorine (ppm)	pH																						
1	Morning	06.00	0.5	7.8	16			3,060 PPM																		
	Afternoon	17.00	0.3	7.4	16																					
2	Morning	06.00	1.5	7.4	16						2,660 PPM															
	Afternoon	17.00	0.3	7.8	16																					
3	Morning	06.00	1.5	7.8	16									2,470 PPM												
	Afternoon	17.00	0.3	7.4	16																					
4	Morning	06.00	1.0	7.2	16												2,490 PPM									
	Afternoon	17.00	0.3	7.8	16																					
5	Morning	06.00	1.0	7.8	16															2,830 PPM						
	Afternoon	17.00	0.3	7.4	16																					
6	Morning	06.00	0.3	7.8	16																		3,220 PPM			
	Afternoon	17.00	0.3	7.4	16																					
7	Morning	06.00	1.5	7.8	16																					2890 PPM
	Afternoon	18.00	0.3	7.8	16																					
Comment :																										

2, 12, 66

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		(Kid swimming pool)		Ref No: JLL-OP-SN-004/01		Rev. Date : 31/01/2015	
Date		Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
				Chlorine (ppm)	pH				
8/11/66	Morning	06.00	3.0	7.8	16				
	Afternoon	17.00	1.0	7.8	16				
9	Morning	06.00	3.0	7.8	16				Back wash 2,440 PPM
	Afternoon	17.00	1.5	7.8	16				
10	Morning	06.00	3.0	7.8	16				2,270 PPM
	Afternoon	17.00	1.5	7.8	16				
11	Morning	06.00	1.5	7.8	16				2,630 PPM
	Afternoon	17.00	1.5	7.8	16				
12	Morning	06.00	3.0	7.8	16				2,530 PPM
	Afternoon	17.00	1.5	7.8	16				
13	Morning	06.00	3.0	7.8	16				Back wash
	Afternoon	17.00	1.5	7.8	16				
14	Morning	06.00	3.0	7.8	16				2760 PPM
	Afternoon	17.00	1.5	7.8	16				
Comment : _____ _____ _____									

2, 12, 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01		Month : November Year : 2023							
Rev. Date : 31/01/2015		Month : November Year : 2023							
BUILDING : The Strand thonglor (Adult swimming pool)		Recorded By (Technician)		Verified By (Sr. Technician)		Remark			
Date	Shift / Time	Water Quality		Filter Pressure (psi)	pH	Chlorine (ppm)	pH	Filter Pressure (psi)	Remark
		Chlorine (ppm)	pH						
8	Morning	06.00	1.5	7.8	16				
	Afternoon	17.00	0.3	7.8	16				
9	Morning	06.00	3.0	7.8	16				
	Afternoon	17.00	0.3	7.8	16				Back wash 2520 PPM
10	Morning	06.00	3.0	7.8	16				8,960 PPM
	Afternoon	17.00	0.3	7.8	16				10,110 PPM
11	Morning	06.00	1.0	7.8	16				2,750 PPM
	Afternoon	17.00	0.3	7.8	16				
12	Morning	06.00	3.0	7.8	16				2620 PPM
	Afternoon	17.00	0.3	7.8	16				Back wash
13	Morning	06.00	1.0	7.8	16				
	Afternoon	17.00	3.0	7.8	16				
14	Morning	06.00	0.3	7.8	16				2820 PPM
	Afternoon	17.00	0.3	7.8	16				
Comment : _____ _____ _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor		(Kid swimming pool)		Ref No: JLL-OP-SN-004/01		Rev. Date : 31/01/2015	
				Filter Pressure (psi)		Recorded By (Technician)		Verified By (Sr. Technician)	
Date		Shift / Time		Water Quality		Filter Pressure (psi)		Remark	
				Chlorine (ppm)	pH				
15	Morning	06.00	3.0	7.8	16	[Redacted]	[Redacted]	[Redacted]	2,610 ppm
	Afternoon	17.00	1.5	7.8	16				
16	Morning	06.00	3.0	7.8	16	[Redacted]	[Redacted]	[Redacted]	Back Wash 2,800 ppm
	Afternoon	17.00	1.5	7.8	16				
17	Morning	06.00	3.0	7.8	16	[Redacted]	[Redacted]	[Redacted]	2,620 ppm
	Afternoon	17.00	1.5	7.8	16				
18	Morning	06.00	1.5	7.8	16	[Redacted]	[Redacted]	[Redacted]	2,590 ppm
	Afternoon	17.00	1.5	7.8	16				
19	Morning	06.00	1.5	7.8	16	[Redacted]	[Redacted]	[Redacted]	2,610 ppm
	Afternoon	17.00	1.5	7.8	16				
20	Morning	06.00	3.0	7.8	16	[Redacted]	[Redacted]	[Redacted]	2,630 ppm
	Afternoon	17.00	1.5	7.8	16				
21	Morning	06.00	1.0	7.8	16	[Redacted]	[Redacted]	[Redacted]	2,510 ppm
	Afternoon	17.00	1.5	7.8	16				
Comment : _____ _____ _____									

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: November		Year: 2023							
BUILDING: The Strand thonglor (Adult swimming pool)				Recorded By (Technician)		Verified By (Sr. Technician)		Remark	
Date	Shift / Time		Water Quality		Filter Pressure (psi)				
			Chlorine (ppm)	pH					
15	Morning	06.00	1.5	7.8	16				2,700 PPM
	Afternoon	17.00	0.3	7.8	16				
16	Morning	06.00	3.2	7.8	16				Back Wash 17.00 2,720 PPM
	Afternoon	17.00	0.3	7.8	16				
17	Morning	06.00	1.5	7.8	16				2,640 PPM
	Afternoon	17.00	0.3	7.8	16				
18	Morning	06.00	1.5	7.8	16				2,660 PPM
	Afternoon	17.00	0.3	7.8	16				
19	Morning	06.00	0.3	7.8	16				2,610 PPM
	Afternoon	17.00	0.3	7.8	16				
20	Morning	06.00	1.0	7.8	16				2,540 PPM
	Afternoon	17.00	0.3	7.8	16				
21	Morning	06.00	0.3	7.8	16				2,520 PPM
	Afternoon	17.00	0.3	7.8	16				
Comment: <u>2, 12, 16</u>									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND																													
Ref No: JLL-OP-SN-004/01																													
Rev. Date: 31/01/2015																													
Month: November		Year: 2023																											
BUILDING :	The Strand thonglor		(Kid swimming pool)		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark																					
	Date	Shift / Time	Chlorine (ppm)	pH																									
22	Morning	06.00	1.0	7.8	16	[Redacted]		PPM 2,510																					
	Afternoon	17.00	1.5	7.8	16																								
23	Morning	06.00	3.0	7.8	16				[Redacted]		Back Wash																		
	Afternoon	17.00	1.8	7.8	16																								
24	Morning	06.00	1.5	7.4	16							[Redacted]		PPM 2470															
	Afternoon	17.00	1.5	7.8	16																								
25	Morning	06.00	1.5	7.4	16										[Redacted]		Back Wash												
	Afternoon	17.00	1.5	7.8	16																								
26	Morning	06.00	1.5	7.4	16													[Redacted]		PPM 2500									
	Afternoon	17.00	1.5	7.8	16																								
27	Morning	06.00	1.5	7.4	16																[Redacted]		Back Wash						
	Afternoon	17.00	1.5	7.8	16																								
28	Morning	06.00	1.5	7.4	16																			[Redacted]		PPM 2470			
	Afternoon	17.00	1.5	7.8	16																								
Comment :					2, 12, 66																								

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND																			
Ref No: JLL-OP-SN-004/01		Rev. Date: 31/01/2015																	
Month: November		Year: 2023																	
BUILDING: The Strand thonglor		(Adult swimming pool)																	
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark												
		Chlorine (ppm)	pH																
22	Morning	06.00	0.3	7.8	[Redacted]		PPM 2530												
	Afternoon	17.00	0.3	7.8															
23	Morning	06.00	3.0	7.8				[Redacted]		Wash wash									
	Afternoon	17.00	0.1	7.8															
24	Morning	06.00	1.5	7.4							[Redacted]		PPM 2479						
	Afternoon	17.00	0.3	7.8															
25	Morning	06.00	1.5	7.4										[Redacted]		Back Wash			
	Afternoon	17.00	0.3	7.8															
26	Morning	06.00	1.5	7.4													[Redacted]		PPM 2500
	Afternoon	17.00	0.3	7.8															
27	Morning	06.00	1.5	7.4	[Redacted]		Back Wash												
	Afternoon	17.00	0.3	7.8															
28	Morning	06.00	1.5	7.4				[Redacted]		PPM 2480									
	Afternoon	17.00	0.3	7.8															
Comment: _____ _____ _____																			

2, 72, 66

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor (Kid swimming pool) สระเด็ก				Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015			
						Month : November		Year : 2023	
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
29	Morning	06.00	3.0	7.8	16	[Redacted]	[Redacted]	[Redacted]	
	Afternoon	17.00	1.5	7.8	16				
30	Morning	06.00	3.0	7.8	16	[Redacted]	[Redacted]	[Redacted]	
	Afternoon	17.00	1.5	7.8	16				
	Morning					[Redacted]	[Redacted]	[Redacted]	
	Afternoon								
	Morning					[Redacted]	[Redacted]	[Redacted]	
	Afternoon								
	Morning					[Redacted]	[Redacted]	[Redacted]	
	Afternoon								
	Morning					[Redacted]	[Redacted]	[Redacted]	
	Afternoon								
	Morning					[Redacted]	[Redacted]	[Redacted]	
	Afternoon								
	Morning					[Redacted]	[Redacted]	[Redacted]	
	Afternoon								
	Morning					[Redacted]	[Redacted]	[Redacted]	
	Afternoon								
Comment : _____ BSE : _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01		Month : November Year : 2023							
Rev. Date : 31/01/2015		Month : November Year : 2023							
BUILDING :	The Strand thonglor		(Adult swimming pool)				Recorded By (Technician)	Verified By (Sr. Technician)	Remark
	Date	Shift / Time	Chlorine (ppm)	pH	Filter Pressure (psi)				
29	Morning	06.00	1.5	7.8	16	[Redacted]	[Redacted]	[Redacted]	[Redacted]
	Afternoon	17.00	0.3	7.8	16				
30	Morning	06.00	3.0	7.8	16	[Redacted]	[Redacted]	[Redacted]	[Redacted]
	Afternoon	17.00	0.9	7.8	16				
	Morning					[Redacted]	[Redacted]	[Redacted]	[Redacted]
	Afternoon								
	Morning					[Redacted]	[Redacted]	[Redacted]	[Redacted]
	Afternoon								
	Morning					[Redacted]	[Redacted]	[Redacted]	[Redacted]
	Afternoon								
	Morning					[Redacted]	[Redacted]	[Redacted]	[Redacted]
	Afternoon								
	Morning					[Redacted]	[Redacted]	[Redacted]	[Redacted]
	Afternoon								
	Morning					[Redacted]	[Redacted]	[Redacted]	[Redacted]
	Afternoon								
	Morning					[Redacted]	[Redacted]	[Redacted]	[Redacted]
	Afternoon								
Comment : _____ BSE : _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND										
BUILDING :		The Strand thonglor				(Adult swimming pool) 55-100%				
Date		Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
				Chlorine (ppm)	pH					
1	Morning	06.00	1.5	7.8	16	[Redacted]			PPM 3500	
	Afternoon	17.00	0.3	7.8	16					
2	Morning	06.00	0.5	7.8	16					Back Wash PPM 3500
	Afternoon	17.00	0.5	7.8	16					
3	Morning	06.00	1.6	7.8	16					PPM 3180
	Afternoon	18.00	0.5	7.8	16					
4	Morning	06.00	3.0	7.8	16					PPM 3050
	Afternoon	17.00	0.3	7.8	16					
5	Morning	06.00	3.0	7.8	16					PPM 2800
	Afternoon	17.00	0.3	7.8	16					
6	Morning	06.00	1.0	7.8	16					PPM 9500
	Afternoon	17.00	1.5	7.8	16					
7	Morning	06.00	1.5	7.8	16					Back Wash PPM 3500
	Afternoon	17.00	1.5	7.8	16					
Comment : * 60% chlorine 100% chlorine 5 100% 2 / 11 / 66										

Note: pH: normal range 7.2 - 7.8
 Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01
Rev. Date: 31/01/2015

BUILDING :		The Strand thonglor				(Kid swimming pool)		Month : October		Year : 2023															
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark																		
		Chlorine (ppm)	pH																						
1	Morning	06.00	1.5	7.8	[Redacted]	[Redacted]	PPM 3400																		
	Afternoon	17.00	1.5	7.8																					
2	Morning	06.00	3.0	7.8				[Redacted]	[Redacted]	Back Wash PPM 3430															
	Afternoon	17.00	3.0	7.8																					
3	Morning	06.00	1.5	7.8							[Redacted]	[Redacted]	PPM 3230												
	Afternoon	17.30	1.5	7.8																					
4	Morning	06.00	1.5	7.8										[Redacted]	[Redacted]	PPM 3050									
	Afternoon	17.00	1.5	7.8																					
5	Morning	06.00	1.5	7.8													[Redacted]	[Redacted]	PPM 2900						
	Afternoon	17.00	1.5	7.8																					
6	Morning	06.00	3.0	7.8																[Redacted]	[Redacted]	PPM 3400			
	Afternoon	17.00	3.0	7.8																					
7	Morning	06.00	3.0	7.8																			[Redacted]	[Redacted]	Back Wash PPM 3400
	Afternoon	17.00	3.0	7.8																					
Comment :							2 / 17 / 06																		

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm




LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01
Rev. Date: 31/01/2015

Month: October Year: 2023

The Strand thonglor (Adult swimming pool)

BUILDING :

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
8	Morning	1.5	7.8	16			PPM 3200
	Afternoon	0.5	7.8	16			
9	Morning	1.5	7.8	16			PPM 3000
	Afternoon	0.3	7.8	16			
10	Morning	1.5	7.8	16			PPM 3400
	Afternoon	0.3	7.8	16			
11	Morning	1.7	7.8	16			PPM 2900 (Max 1700)
	Afternoon	0.3	7.8	16			
12	Morning	2.0	7.8	16			PPM 3400
	Afternoon	0.3	7.8	16			
13	Morning	2.0	7.6	16			PPM 3335
	Afternoon	0.3	7.8	16			
14	Morning	2.0	7.8	16			PPM 3000
	Afternoon	0.3	7.8	16			

Comment :

2, 17 / 16

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor				(Kid swimming pool)			
Date		Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (S-Technician)	Remark
				Chlorine (ppm)	pH				
8	Morning	06.00	3.0	7.8	16	[Redacted]	[Redacted]	[Redacted]	PPM. 3100
	Afternoon	17.00	3.0	7.8	16				
9	Morning	06.00	3.0	7.8	16	[Redacted]	[Redacted]	[Redacted]	PPM. 2900
	Afternoon	17.00	3.0	7.8	16				
10	Morning	06.00	1.5	7.8	16	[Redacted]	[Redacted]	[Redacted]	PPM. 3200
	Afternoon	17.00	3.0	7.8	16				
11	Morning	06.00	1.5	7.8	16	[Redacted]	[Redacted]	[Redacted]	PPM. 3200
	Afternoon	17.00	3.0	7.8	16				
12	Morning	06.00	3.0	7.8	16	[Redacted]	[Redacted]	[Redacted]	PPM. 3300
	Afternoon	17.00	3.0	7.8	16				
13	Morning	07.00	3.0	7.8	16	[Redacted]	[Redacted]	[Redacted]	PPM. 3090
	Afternoon	17.00	3.0	7.8	16				
14	Morning	06.00	3.0	7.8	16	[Redacted]	[Redacted]	[Redacted]	PPM. 3200
	Afternoon	17.00	3.0	7.8	16				
Comment : _____ _____ _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01					
Rev. Date: 31/01/2015					
Month: October		Year: 2023			
BUILDING: The Strand thonglor		(Adult swimming pool)			
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)
		Chlorine (ppm)	pH		
15	Morning	06.00	1.5	7.8	PPM 2600, MAINTAIN 9 PPM
	Afternoon	17.00	0.3	7.8	
16	Morning	06.00	1.5	8.2	PPM 3600
	Afternoon	17.00	0.3	7.9	
17	Morning	06.00	3.0	7.4	PPM 3800
	Afternoon	17.00	0.3	7.8	
18	Morning	06.00	1.0	7.8	PPM 3000, MAINTAIN 5 PPM
	Afternoon	17.00	0.3	7.8	
19	Morning	06.00	1.0	7.8	PPM 3320
	Afternoon	17.00	0.3	7.8	
20	Morning	06.00	1.0	7.8	PPM 3100, MAINTAIN 4 PPM
	Afternoon	17.00	0.3	7.8	
21	Morning	06.00	1.0	7.8	PPM 3300
	Afternoon	17.00	0.3	7.8	
Comment: _____ _____ _____					

2/11/20

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01		Rev. Date: 31/01/2015							
Month: October		Year: 2023							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr Technician)	Remark		
		Chlorine (ppm)	pH						
15	Morning	06.00	3.0	7.4	[Redacted]	[Redacted]	PPM- 2600		
	Afternoon	17.00	3.0	7.8					
16	Morning	06.00	3.0	8.2			PPM- 2400		
	Afternoon	17.00	3.0	7.8					
17	Morning	06.00	3.0	7.8			PPM 3200		
	Afternoon	17.00	3.0	7.8					
18	Morning	06.00	3.0	7.8			PPM- 2000		
	Afternoon	17.00	3.0	7.8					
19	Morning	06.00	3.0	7.8			PPM 3200		
	Afternoon	17.00	3.0	7.8					
20	Morning	06.00	3.0	7.8			PPM 2900		
	Afternoon	17.00	3.0	7.8					
21	Morning	06.00	3.0	7.8			PPM- 3100		
	Afternoon	17.00	1.5	7.8					

Comment: _____

21/11/20

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: October		Year: 2023							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
22	Morning	06.00	1.5	7.8	[Redacted]	[Redacted]	PPM 3000		
	Afternoon	14.00	0.3	7.8					
23	Morning	06.00	1.5	7.4	[Redacted]	[Redacted]	PPM 2800		
	Afternoon	17.00	0.3	7.8					
24	Morning	06.00	0.5	7.4	[Redacted]	[Redacted]	PPM 3500		
	Afternoon	14.00	0.3	7.8					
25	Morning	06.00	1.0	7.8	[Redacted]	[Redacted]	PPM 3200		
	Afternoon	17.00	0.3	7.8					
26	Morning	06.00	3.0	7.8	[Redacted]	[Redacted]	Back wash. PPM		
	Afternoon	19.00	0.3	7.4					
27	Morning	06.00	1.0	7.4	[Redacted]	[Redacted]	PPM 3000		
	Afternoon	17.00	0.3	7.4					
28	Morning	06.00	1.6	7.4	[Redacted]	[Redacted]	Back wash PPM 3600		
	Afternoon	17.00	0.3	7.4					
Comment: _____ _____ _____									

27/10/2023

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01		Rev. Date: 31/01/2015							
Month: October		Year: 2023							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
22	Morning	06.00	1.5	7.8	[Redacted]	[Redacted]	PPM 3,000		
	Afternoon	17.00	3.0	7.8					
23	Morning	06.00	1.5	7.8	[Redacted]	[Redacted]	PPM 2700		
	Afternoon	17.00	0.5	7.8					
24	Morning	06.00	0.5	7.8	[Redacted]	[Redacted]	PPM 3300		
	Afternoon	17.00	1.5	7.8					
25	Morning	06.00	1.5	7.8	[Redacted]	[Redacted]	PPM 3100		
	Afternoon	17.00	3.0	7.8					
26	Morning	06.00	3.0	7.8	[Redacted]	[Redacted]	Back wash PPM		
	Afternoon	17.00	3.0	7.8					
27	Morning	06.00	4.0	7.8	[Redacted]	[Redacted]	PPM 3,000		
	Afternoon	17.00	3.0	7.8					
28	Morning	06.00	4.0	7.8	[Redacted]	[Redacted]	Back wash PPM 3600		
	Afternoon	17.00	3.0	7.8					
Comment: _____									

2, 17 / 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01
Rev. Date: 31/01/2015

Month: October Year: 2023

The Strand thonglor (Adult swimming pool)

BUILDING :

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
29	Morning	3.0	7.8	16	[Redacted]	[Redacted]	ppm 3600
	Afternoon	0.9	7.8	16			
30	Morning	0.0	7.8	16			ppm 3300
	Afternoon	1.5	7.8	16			
31	Morning	0.0	7.8	16			ppm 3200
	Afternoon	0.3	7.8	16			
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						

Comment :

BSE :

2, 11, 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01						Year : 2023							
Rev. Date : 31/01/2015													
BUILDING :		The Strand thonglor				(Kid swimming pool)							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark						
		Chlorine (ppm)	pH										
29	Morning	3.0	7.4	16	[Redacted]	[Redacted]	ppm 3400						
	Afternoon	3.0	7.2	16									
30	Morning	3.0	7.4	16				[Redacted]	[Redacted]	ppm 3200			
	Afternoon	3.0	7.8	16									
31	Morning	3.0	7.4	16							[Redacted]	[Redacted]	ppm 3000
	Afternoon	3.0	7.8	16									
	Morning				[Redacted]	[Redacted]							
	Afternoon												
	Morning							[Redacted]	[Redacted]				
	Afternoon												
	Morning										[Redacted]	[Redacted]	
	Afternoon												
	Morning				[Redacted]	[Redacted]							
	Afternoon												
	Morning							[Redacted]	[Redacted]				
	Afternoon												
Comment : _____ BSE : _____ 2/11/16													

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: September Year: 2023									
BUILDING: The Strand thonglor (Kid swimming pool)									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
1	Morning	06.00	1.5	7.8	[Redacted]	[Redacted]	PPM 3450		
	Afternoon	17.00	3.0	8.2					
2	Morning	06.00	3.0	7.8	[Redacted]	[Redacted]	PPM 3450		
	Afternoon	16.30	1.5	8.2					
3	Morning	06.00	1.5	7.8	[Redacted]	[Redacted]	PPM 3450		
	Afternoon	17.00	1.5	7.8					
4	Morning	06.00	1.5	7.8	[Redacted]	[Redacted]	Back Wash PPM 3325		
	Afternoon	17.00	1.5	8.2					
5	Morning	06.00	1.5	7.8	[Redacted]	[Redacted]	PPM 3450		
	Afternoon	16.30	1.5	8.2					
6	Morning	06.00	3.0	7.8	[Redacted]	[Redacted]	PPM 3450		
	Afternoon	17.00	1.5	8.2					
7	Morning	06.00	3.0	7.8	[Redacted]	[Redacted]	PPM 3450		
	Afternoon	17.30	1.5	8.2					

Comment: 8/16

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND																
Ref No: JLL-OP-SN-004/01		Rev. Date: 31/01/2015														
Month: September		Year: 2023														
BUILDING: The Strand thonglor (Adult swimming pool)																
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark									
		Chlorine (ppm)	pH													
1	Morning	06.00	1.5	7.8	[Redacted]		PPM 9450									
	Afternoon	17.00	0.3	8.2												
2	Morning	06.00	1.5	7.8				[Redacted]		PPM 9450						
	Afternoon	16.30	0.5	8.2												
3	Morning	06.00	1.5	7.8							[Redacted]		PPM 9450			
	Afternoon	17.00	1.5	7.8												
4	Morning	06.00	0.5	7.8										[Redacted]		PPM 9450
	Afternoon	17.00	0.3	8.2												
5	Morning	06.00	1.5	7.8	[Redacted]		PPM 9450									
	Afternoon	16.30	0.3	7.8												
6	Morning	06.00	1.5	7.8				[Redacted]		PPM 9450						
	Afternoon	17.00	0.5	8.2												
7	Morning	06.00	1.5	7.8							[Redacted]		PPM 9450			
	Afternoon	17.00	0.5	8.2												
8	Morning	06.00	1.5	7.8										[Redacted]		PPM 9450
	Afternoon	17.00	0.5	8.2												

Comment: _____

8/9/66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: September		Year: 2023							
BUILDING: The Strand thonglor (Kid swimming pool)		Recorded By (Technician)		Verified By (Sr. Technician)		Remark			
Date	Shift / Time	Water Quality		Filter Pressure (psi)	pH	Chlorine (ppm)	pH	Filter Pressure (psi)	Remark
		Chlorine (ppm)	pH						
8	Morning	06.00	3.0	8.2	16				
	Afternoon								
9	Morning	06.00	3.0	7.8	16				
	Afternoon	17.00	1.5	7.8	16				
10	Morning	06.00	1.5	7.8	16				
	Afternoon	17.00	1.5	7.8	16				
11	Morning	06.00	3.0	7.8	16				
	Afternoon	17.00	1.5	7.8	16				
12	Morning	06.00	1.5	7.8	16				
	Afternoon	17.00	1.5	7.8	16				
13	Morning	06.00	1.0	7.8	16				
	Afternoon	17.00	1.5	7.8	16				
14	Morning	06.00	1.5	7.8	16				
	Afternoon	17.00	1.0	7.8	16				

Comment: _____

18/9/20

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: September		Year: 2023							
BUILDING: The Strand thonglor (Adult swimming pool)		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
Date	Shift / Time	Chlorine (ppm)	pH						
8	Morning	06.00	1.5	8.2	[Redacted]	[Redacted]			
	Afternoon								
9	Morning	06.00	1.0	7.8	[Redacted]	[Redacted]	Back Wash PPM = 3320		
	Afternoon	17.00	0.3	7.8					
10	Morning	06.00	1.0	7.8	[Redacted]	[Redacted]	PPM = 3250 (check)		
	Afternoon	17.00	0.3	7.8					
11	Morning	06.00	1.0	7.8	[Redacted]	[Redacted]	PPM = 3196		
	Afternoon	17.00	0.3	7.8					
12	Morning	06.00	0.5	7.4	[Redacted]	[Redacted]	PPM = 3180		
	Afternoon	17.00	0.3	7.8					
13	Morning	06.00	0.3	7.8	[Redacted]	[Redacted]	PPM = 3400		
	Afternoon	17.00	0.3	7.8					
14	Morning	06.00	1.5	7.8	[Redacted]	[Redacted]	PPM = 3100 (check)		
	Afternoon	17.00	0.3	7.8					
Comment: _____ _____ _____									

14/9/20

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01							
Rev. Date: 31/01/2015							
Month: September Year: 2023							
BUILDING: The Strand thonglor (Kid swimming pool)							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
15	Morning	06.00	1.5	7.8	[Redacted]	[Redacted]	PPM 3000
	Afternoon	17.00	1.5	7.8			
16	Morning	06.00	3.0	7.8	[Redacted]	[Redacted]	PPM 2900
	Afternoon	17.00	1.5	7.8			
17	Morning	06.00	3.0	7.8	[Redacted]	[Redacted]	PPM 3100
	Afternoon	17.00	1.5	7.8			
18	Morning	06.00	3.0	7.8	[Redacted]	[Redacted]	Back Wash PPM 3330
	Afternoon	17.00	1.5	7.8			
19	Morning	06.00	3.0	7.8	[Redacted]	[Redacted]	PPM 3360 / 6.25 mg/kg
	Afternoon	17.00	1.5	7.8			
20	Morning	06.00	1.5	7.4	[Redacted]	[Redacted]	PPM 3500
	Afternoon	17.00	1.0	7.8			
21	Morning	06.00	3.0	7.8	[Redacted]	[Redacted]	PPM
	Afternoon	17.00	1.5	7.8			
Comment: _____ _____ 22/09/2023							

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01		Month : September Year : 2023							
Rev. Date : 31/01/2015		Recorded By (Technician)							
BUILDING : The Strand thonglor (Adult swimming pool)		Water Quality		Filter Pressure (psi)		Verified By (Sr. Technician)		Remark	
Date	Shift / Time	Chlorine (ppm)	pH	Filter Pressure (psi)		Verified By (Sr. Technician)	Remark		
				Chlorine (ppm)	pH				
15	Morning	06.00	1.0	7.8	16	[Redacted]	PPM 3500		
	Afternoon	17.00	0.3	7.8	16				
16	Morning	06.00	1.6	7.8	16	[Redacted]	PPM 3000		
	Afternoon	17.00	0.3	7.8	16				
17	Morning	06.00	1.0	7.8	16	[Redacted]	PPM 3400		
	Afternoon	17.00	0.3	7.8	16				
18	Morning	06.00	1.5	7.8	16	[Redacted]	Bach Wash PPM 3350		
	Afternoon	17.00	0.5	7.8	16				
19	Morning	06.00	1.6	7.8	16	[Redacted]	PPM 3380 / 600000 2		
	Afternoon	17.00	0.3	7.8	16				
20	Morning	06.00	1.5	7.8	16	[Redacted]	PPM 3600		
	Afternoon	17.00	0.3	7.8	16				
21	Morning	06.00	1.6	7.8	16	[Redacted]	PPM 3400		
	Afternoon	17.00	0.3	7.8	16				
Comment : _____ _____ _____									

22, 9, 16

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: September		Year: 2023							
BUILDING: The Strand thonglor (Kid swimming pool)		Recorded By (Technician)		Verified By (Sr. Technician)		Remark			
Date	Shift / Time	Water Quality		Filter Pressure (psi)					
		Chlorine (ppm)	pH						
22	Morning	0.5	7.8	16	PPM 3200				
	Afternoon	1.5	7.9	16					
23	Morning	1.5	7.8	16	PPM 3150				
	Afternoon	1.5	7.4	16					
24	Morning	1.5	7.8	16	PPM 3000 / 1000000 2 N/A, 2023				
	Afternoon	1.5	7.8	16					
25	Morning	3.0	7.8	16	PPM 3980				
	Afternoon	1.5	7.9	16					
26	Morning	1.5	7.8	16	PPM 3200				
	Afternoon	1.0	7.8	16					
27	Morning	1.5	7.8	16	PPM 2890				
	Afternoon	1.0	7.8	16					
28	Morning	1.5	7.8	16	PPM 2820				
	Afternoon	1.0	7.8	16					
Comment: <u>2, 10, 66</u>									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND																									
Ref No: JLL-OP-SN-004/01																									
Rev. Date: 31/01/2015																									
Month: September		Year: 2023																							
BUILDING: The Strand thonglor		(Adult swimming pool)																							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark																		
		Chlorine (ppm)	pH																						
22	Morning	06.00	0.5	7.8	[Redacted]		PPM 3300																		
	Afternoon	16.30	0.5	7.8																					
23	Morning	06.00	1.5	7.8				[Redacted]		PPM 3300															
	Afternoon	17.00	1.5	7.4																					
24	Morning	06.00	0.5	7.8							[Redacted]		PPM 3300												
	Afternoon	17.00	0.3	7.8																					
25	Morning	06.00	1.5	7.8										[Redacted]		PPM 3300									
	Afternoon	17.00	0.3	7.8																					
26	Morning	06.00	0.5	7.8													[Redacted]		PPM 3300						
	Afternoon	17.00	0.3	7.8																					
27	Morning	06.00	0.3	7.8																[Redacted]		PPM 3300			
	Afternoon	17.00	0.3	7.8																					
28	Morning	06.00	0.5	7.8																			[Redacted]		PPM 3300
	Afternoon	17.00	0.3	7.8																					

Comment: _____

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01 Rev. Date: 31/01/2015									
BUILDING : The Strand thonglor (Kid swimming pool)									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr Technician)	Remark		
		Chlorine (ppm)	pH						
29	Morning	06:00	1.5	7.8	[Redacted]	[Redacted]	PPM		
	Afternoon	17:00	1.5	7.8					
30	Morning	06:00	1.5	7.8					
	Afternoon	17:00	3.0	7.8					
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								

Month : September Year : 2023

Comment : _____

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01							
Rev. Date: 31/01/2015							
Month: September Year: 2023							
BUILDING: The Strand thonglor (Adult swimming pool)							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
29	Morning	0.5	7.8	16	[Redacted]	[Redacted]	PPM 17.5, 17.2, 17.2, 17.2
	Afternoon	0.3	7.8	16			
30	Morning	0.5	7.8	16	[Redacted]	[Redacted]	PPM 35.40
	Afternoon	0.3	7.8	16			
	Morning				[Redacted]	[Redacted]	
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						
Comment:					2 / 10 / 66		

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor (Kid swimming pool)				Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015			
						Month : August	Year : 2023		
Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark	
			Chlorine (ppm)	pH					
1	Morning	06.00	1.5	7.8	16	[Redacted]			
	Afternoon	17.00	1.0	7.8	16				
2	Morning	06.00	1.5	7.8	16				
	Afternoon	17.00	1.5	8.2	16				
3	Morning	06.00	1.5	7.8	16				
	Afternoon	17.30	0.5	7.8	16				
4	Morning	06.00	1.5	7.8	16				
	Afternoon	17.00	1.0	7.8	16				
5	Morning	06.00	1.5	7.8	16				
	Afternoon	17.00	1.5	7.8	16				
6	Morning	06.00	1.5	7.8	16				
	Afternoon	17.00	3.0	8.2	16				
7	Morning	06.00	1.0	7.8	16				
	Afternoon	17.00	0.3	8.2	16				
Comment : _____ _____ _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01

Rev. Date: 31/01/2015

Month: August Year: 2023

BUILDING: The Strand thonglor (Adult swimming pool)

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
1	Morning	06.00	7.8	16	[REDACTED]	[REDACTED]	2060 PPM.
	Afternoon	17.00	7.8	16			
2	Morning	06.00	7.8	16			1990 RPM
	Afternoon	17.00	8.2	16			
3	Morning	06.00	7.4	16			Brack 1900 PPM.
	Afternoon	17.30	7.8	16			
4	Morning	06.00	7.8	16			1890 PPM
	Afternoon	17.00	7.8	16			
5	Morning	06.00	7.4	16			2400 PPM.
	Afternoon	17.00	7.8	16			
6	Morning	06.00	8.2	16			3080 PPM
	Afternoon	17.00	7.8	16			
7	Morning	06.00	8.2	16			3050 PPM
	Afternoon	17.00	8.2	16			

Comment:

8 / 8 / 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01

Rev. Date: 31/01/2015

Month: August Year: 2023

BUILDING: The Strand thonglor (Kid swimming pool)

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr Technician)	Remark
		Chlorine (ppm)	pH				
8	Morning	1.5	7.8	16	[REDACTED]	[REDACTED]	3100 PPM
	Afternoon	1.5	7.8	16			
9	Morning	1.0	8.2	16			3620 PPM
	Afternoon	1.5	7.8	16			
10	Morning	1.5	8.2	16			Bach wash, 3500 PPM.
	Afternoon	1.5	7.8	16			
11	Morning	1.5	7.8	16			3600 PPM.
	Afternoon	1.5	7.8	16			
12	Morning	1.5	8.2	16			3600 PPM
	Afternoon	1.5	8.2	16			
13	Morning	3.0	8.2	16			3600 PPM.
	Afternoon	1.5	8.2	16			
14	Morning	1.5	8.2	16			3700 PPM
	Afternoon	1.5	8.2	16			

Comment:

10/8/2023

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: August		Year: 2023							
BUILDING: The Strand thonglor		(Adult swimming pool)		Recorded By (Technician)		Verified By (Sr. Technician)		Remark	
Date	Shift / Time	Water Quality		Filter Pressure (psi)	pH	Chlorine (ppm)	pH	Filter Pressure (psi)	Remark
		Chlorine (ppm)	pH						
8	Morning	06.00	1.0	7.8	16				
	Afternoon	17.00	0.3	7.8	16				3090 PPM.
9	Morning	06.00	1.0	8.2	16				
	Afternoon	17.00	0.5	7.8	16				3670 PPM.
10	Morning	06.00	2.0	8.2	16				
	Afternoon	17.00	0.3	7.8	16				3600 PPM.
11	Morning	06.00	1.0	7.8	16				
	Afternoon	17.00	0.3	7.8	16				3600 PPM.
12	Morning	06.00	1.0	8.2	16				
	Afternoon	17.00	0.3	7.8	16				3600 PPM.
13	Morning	06.00	1.5	8.2	16				
	Afternoon	17.00	0.3	8.2	16				3600 PPM.
14	Morning	06.00	1.5	8.2	16				
	Afternoon	17.00	0.3	8.2	16				3600 PPM.
Comment: _____ _____ _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND											
Ref No: JLL-OP-SN-004/01		Rev. Date: 31/01/2015									
Month: August		Year: 2023									
BUILDING: The Strand thonglor		(Kid swimming pool)									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark				
		Chlorine (ppm)	pH								
15	Morning	06.00	1.5	8.2	[Redacted]	[Redacted]	PPM 3620				
	Afternoon	17.00	1.5	8.2							
16	Morning	06.00	1.5	7.8			PPM 3600				
	Afternoon	17.00	1.5	8.2							
17	Morning	06.00	1.5	8.2			PPM 3600				
	Afternoon	17.00	1.5	7.8							
18	Morning	06.00	1.5	8.2			PPM 3300				
	Afternoon	17.00	1.5	7.8							
19	Morning	06.00	1.5	8.2			PPM 3310				
	Afternoon	17.00	1.5	8.2							
20	Morning	06.00	1.5	8.2			PPM 3600				
	Afternoon	17.00	1.5	8.2							
21	Morning	06.00	3.0	8.2			Back wash PPM 3600				
	Afternoon	17.00	1.5	8.2							
Comment: 17/8/66 LED light on 22/8/66											

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: August		Year: 2023							
BUILDING: The Strand thonglor		(Adult swimming pool)							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
15	Morning	06.00	1.5	8.2	[Redacted]	[Redacted]	PPM 3650		
	Afternoon	17.00	0.3	8.2					
16	Morning	06.00	1.0	7.8	[Redacted]	[Redacted]	PPM 3600		
	Afternoon	17.00	0.5	8.2					
17	Morning	06.00	1.5	8.2	[Redacted]	[Redacted]	PPM 3600		
	Afternoon	17.00	0.3	7.8					
18	Morning	06.00	1.5	8.2	[Redacted]	[Redacted]	PPM 3400 100% 2ND DO		
	Afternoon	17.00	0.3	7.8					
19	Morning	06.00	1.5	8.2	[Redacted]	[Redacted]	PPM 3470		
	Afternoon	17.00	0.3	8.2					
20	Morning	06.00	1.5	8.2	[Redacted]	[Redacted]	PPM 3420		
	Afternoon	17.00	1.0	8.4					
21	Morning	06.00	1.0	8.2	[Redacted]	[Redacted]	Back Wash PPM 3400		
	Afternoon	17.00	1.0	8.2					
Comment: _____								92/ 8 / 66	

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



Ref No: JLL-OP-SN-004/01

Ref No:

JLL-OP-SN-004/01

Rev. Date: 31/01/2015

31/01/2015

Month :	August	Year :	2023
---------	--------	--------	------

The Strand thonglor
(Adult swimming pool)

Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark						
			Chlorine (ppm)	pH										
22	Morning	06.00	0.3	8.2	16			10000-50000						
	Afternoon	17.00	0.3	7.8	16			2600 PPM.						
23	Morning	06.00	1.5	8.2	16					10000-50000				
	Afternoon	17.00	1.5	4.1	16									
24	Morning	06.00	1.5	8.2	16							Bach wash. 3340 ppm.		
	Afternoon	17.00	1.5	7.8	16							10000-50000		
25	Morning	06.00	0.3	8.2	16									3160 ppm
	Afternoon	17.00	0.3	8.2	16									3400 ppm
26	Morning	06.00	0.15	8.2	16									
	Afternoon	17.00	0.3	8.2	16									
27	Morning	06.00	1.0	7.8	16									
	Afternoon	17.30	0.3	7.8	16									
28	Morning	06.00	1.5	9.2	16									3000 ppm.
	Afternoon	17.00	0.3	8.2	16									10000-50000 2960 ppm

Comment :

$$\frac{17}{8} \frac{1}{10}$$

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
Ref No: JLL-OP-SN-004/01									
Rev. Date: 31/01/2015									
Month: August		Year: 2023							
BUILDING: The Strand thonglor		(Adult swimming pool)							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
29	Morning	06.00	1.15	8.2	[Redacted]	[Redacted]	3510 ppm.		
	Afternoon	17.00	0.3	8.2					
30	Morning	06.00	1.0	7.8	[Redacted]	[Redacted]			
	Afternoon	17.00	0.5	7.8					
31	Morning	07.00	1.5	8.2	[Redacted]	[Redacted]			
	Afternoon	17.00	0.5	8.2					
	Morning				[Redacted]	[Redacted]			
	Afternoon								
	Morning				[Redacted]	[Redacted]			
	Afternoon								
	Morning				[Redacted]	[Redacted]			
	Afternoon								
	Morning				[Redacted]	[Redacted]			
	Afternoon								
Comment: 1 BSE: 4, 9, 66									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

BUILDING :

The Strand thonglor

(Adult swimming pool)

Ref No: JLL-OP-SN-004/01
Rev. Date: 31/01/2015

Month : JULY Year : 2023

Date	Shift / Time		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
			Chlorine (ppm)	pH				
1	Morning	06.00	1.5	7.8	16			4550 ppm
	Afternoon	18.00	0.3	7.8	16			
2	Morning	06.00	1.5	7.8	16			4550 ppm
	Afternoon	17.00	1.5	7.8	16			
3	Morning	06.00	1.5	7.8	16			4550 ppm
	Afternoon	18.00	1.0	7.8	16			
4	Morning	06.00	1.0	7.8	16			4460 ppm
	Afternoon	18.00	1.0	7.8	16			
5	Morning	06.00	1.0	7.8	16			4500 ppm
	Afternoon	18.00	1.0	7.8	16			
6	Morning	06.00	1.5	7.8	16			4400 ppm
	Afternoon	17.00	1.0	7.8	16			
7	Morning	06.00	1.5	8.2	16			4400 ppm
	Afternoon	18.00	1.0	8.2	16			4460 ppm

Comment :

8, 7, 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
<div> <div>Ref No: JLL-OP-SN-004/01</div> <div>Rev. Date : 31/01/2015</div> </div>									
<div> <div>BUILDING : The Strand thonglor</div> <div>(Kid swimming pool)</div> </div>									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr Technician)	Remark	Month : JULY	Year : 2023
		Chlorine (ppm)	pH						
1	Morning	06.00	1.5	7.4	[Redacted]				
	Afternoon	18.00	1.0	7.8					
2	Morning	06.00	1.5	7.4					
	Afternoon	17.00	1.5	7.8					
3	Morning	06.00	1.0	7.8					
	Afternoon	18.00	1.0	7.8					
4	Morning	06.00	0.5	7.8					
	Afternoon	18.00	1.0	7.8					
5	Morning	06.00	1.5	7.8					
	Afternoon	18.00	1.0	7.8					
6	Morning	06.00	1.5	7.8					
	Afternoon	17.00	1.5	7.8					
7	Morning	06.00	1.5	7.8					
	Afternoon	18.00	1.5	7.8					
<div> <div>Comment :</div> <div>8, 7, 66</div> </div>									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND																																							
BUILDING : The Strand thonglor (Adult swimming pool)																																							
Ref No: JLL-OP-SN-004/01		Rev. Date : 31/01/2015		Month : JULY		Year : 2023																																	
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark																																
		Chlorine (ppm)	pH																																				
8	Morning	1.5	8.2	16	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]																														
	Afternoon	1.5	7.8	16						4400 PPM																													
9	Morning	1.5	8.2	16						[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]																									
	Afternoon	1.0	8.2	16											4400 PPM																								
10	Morning	1.5	8.2	16											[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]																				
	Afternoon	1.0	8.2	16																4400 PPM																			
11	Morning	1.3	7.8	16																[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]															
	Afternoon	1.0	7.8	16																																			
12	Morning	1.6	8.2	16																					[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]										
	Afternoon	1.0	8.2	16																										4310 PPM									
13	Morning	1.5	8.2	16																										[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]					
	Afternoon	1.0	8.2	16																															Back Wash 4150 PPM				
14	Morning	1.5	7.8	16																															[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]
	Afternoon	1.0	7.8	16																																			
Comment : _____ _____ _____																																							

6 / 7 / 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01
Rev. Date: 31/01/2015

Month: JULY Year: 2023

The Strand thonglor
(Kid swimming pool)

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
8	Morning	1.5	8.2	16	[Redacted]	[Redacted]	
	Afternoon	1.5	7.2	16			
9	Morning	1.3	8.2	16			
	Afternoon	1.5	8.2	16			
10	Morning	1.5	8.2	16			
	Afternoon	1.6	8.2	16			
11	Morning	1.5	8.2	16			
	Afternoon	1.5	8.2	16			
12	Morning	3.0	8.2	16			
	Afternoon	1.5	8.2	16			
13	Morning	2.0	8.2	16			
	Afternoon	1.5	8.2	16			
14	Morning	1.5	7.4	16			
	Afternoon	1.5	7.8	16			

Comment:

10/7/2023

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01
Rev. Date: 31/01/2015

BUILDING : The Strand thonglor

(Adult swimming pool)

Month : JULY Year : 2023

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
15	Morning	06.00	1.5	8.2	[Redacted]	[Redacted]	PPM 3760
	Afternoon	18.00	1.0	7.5			
16	Morning	06.00	1.5	7.8			
	Afternoon	17.00	1.0	6.2			
17	Morning	06.00	1.5	8.2			
	Afternoon	17.00	1.5	8.2			
18	Morning	06.00	1.5	8.2			
	Afternoon	17.00	1.0	8.2			
19	Morning	06.00	1.5	8.2			
	Afternoon	17.10	1.0	7.9			
20	Morning	06.00	2.0	8.2			
	Afternoon	17.38	1.0	8.2			
21	Morning	06.00	1.5	8.2			
	Afternoon	17.00	1.0	7.8			

Comment :

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01
Rev. Date: 31/01/2015

BUILDING : The Strand thonglor

(Kid swimming pool)

Month : JULY Year : 2023

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
15	Morning	1.6	8.2	16	[Redacted]	[Redacted]	
	Afternoon	1.5	7.5	16			
16	Morning	1.5	7.4	16			489 3760
	Afternoon	1.0	8.2	16			
17	Morning	1.5	8.2	16			ppm 3570 3090 5090 1640 1180 2800 ppm 3150 ppm 3310
	Afternoon	1.5	8.2	16			
18	Morning	1.5	8.2	16			Back Wash ppm 3190.
	Afternoon	3.0	8.2	16			
19	Morning	1.0	8.2	16			ppm 2940 Back Wash
	Afternoon	1.5	8.2	16			
20	Morning	1.5	8.2	16			
	Afternoon	1.5	8.2	16			
21	Morning	1.3	8.2	16			
	Afternoon	3.0	7.8	16			

Comment :

27 7, 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND


Ref No: JLL-OP-SN-004/01

Rev. Date: 31/01/2015

BUILDING : The Strand thonglor

(Adult swimming pool)

Month : JULY Year : 2023

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
22	Morning	1.5	8.2	16			
	Afternoon	1.5	8.2	16			
23	Morning	1.5	7.4	16			
	Afternoon	0.3	7.8	16			
24	Morning	1.5	7.4	16			
	Afternoon	0.3	7.8	16			
25	Morning	1.0	7.8	16			
	Afternoon	1.5	7.8	16			
26	Morning	1.0	8.2	16			
	Afternoon	1.0	8.2	16			
27	Morning	0.3	8.2	16			
	Afternoon	1.0	7.8	16			
28	Morning	1.0	8.2	16			
	Afternoon	1.0	8.2	16			

Comment :

31, 7 166

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01

Rev. Date : 31/01/2015

BUILDING :

The Strand thonglor

(Kid swimming pool)

Month : JULY Year : 2023

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
22	Morning	1.5	8.9	16	[Redacted]	[Redacted]	[Redacted]
	Afternoon	1.5	8.2	16			
23	Morning	1.5	7.4	16			
	Afternoon	0.5	7.8	16			
24	Morning	1.5	8.9	16			
	Afternoon	1.5	8.8	16			
25	Morning	1.5	8.8	16			
	Afternoon	1.0	8.8	16			
26	Morning	1.5	8.2	16			
	Afternoon	1.5	8.2	16			
27	Morning	1.5	8.2	16			
	Afternoon	1.5	8.2	16			
28	Morning	1.5	8.2	16			
	Afternoon	1.5	8.2	16			

Comment :

31, 7, 66

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING :		The Strand thonglor (Adult swimming pool)				Ref No: JLL-OP-SN-004/01 Rev. Date : 31/01/2015			
		Month : JULY		Year : 2023					
Date	Shift / Time	Chlorine (ppm)	pH	Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
29	Morning	06.00	1.5	8.2	16	[Redacted]	[Redacted]	3200 ppm	
	Afternoon	17.00	0.7	7.8	16				
30	Morning	06.00	1.0	7.8	16	[Redacted]	[Redacted]		
	Afternoon	17.00	0.3	8.2	16				
31	Morning	06.00	1.6	8.2	16	[Redacted]	[Redacted]	Water 2140 ppm	
	Afternoon	17.00	0.3	8.2	16				
	Morning					[Redacted]	[Redacted]		
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
Comment :					BSE : 31.7 / 66				

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01

Rev. Date : 31/01/2015

BUILDING :

The Strand thonglor

(Kid swimming pool)

Month : JULY

Year : 2023

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
	Morning	1.5	8.2	16			3200 ppm
	Afternoon	1.6	7.8	16			
	Morning	0.5	7.8	16			
	Afternoon	0.0	7.8	16			
	Morning	1.5	8.2	16			ppm 2100
	Afternoon	1.5	8.2	16			
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						

Comment :

BSE :

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm

